





# **Development Document for Proposed Effluent Limitations Guidelines and Standards for Industrial Waste Combustors**





**DEVELOPMENT DOCUMENT  
FOR  
PROPOSED EFFLUENT LIMITATIONS  
GUIDELINES AND STANDARDS  
FOR THE  
INDUSTRIAL WASTE COMBUSTOR SUBCATEGORY  
OF THE  
WASTE COMBUSTORS POINT SOURCE CATEGORY**

**Carol M. Browner  
Administrator**

**Robert Perciasepe  
Assistant Administrator, Office of Water**

**Sheila Frace  
Acting Director, Engineering and Analysis Division**


**Elwood H. Forsht  
Chief, Chemicals and Metals Branch**

**Samantha Hopkins  
Project Manager**

**December 1997**

**U.S. Environmental Protection Agency  
Office of Water  
Washington, DC 20460**

**Additional Support by Contract No. 68-C5-0041**



## TABLE OF CONTENTS


EXECUTIVE SUMMARY .....	ES-1
SECTION 1 STATUTORY REQUIREMENT .....	1-1
1.1 LEGAL AUTHORITY .....	1-1
1.1.1 Best Practicable Control Technology Currently Available (BPT) (Section 304(b)(1) of the CWA) .....	1-1
1.1.2 Best Conventional Pollutant Control Technology (BCT) (Section 304(a)(4) of the CWA) .....	1-2
1.1.3 Best Available Technology Economically Achievable (BAT) (Sections 304(b)(2)(B) of the CWA) .....	1-2
1.1.4 New Source Performance Standards (NSPS) (Section 306 of the CWA) .....	1-3
1.1.5 Pretreatment Standards for Existing Sources (PSES) (Section 307(b) of the CWA) .....	1-3
1.1.6 Pretreatment Standards for New Sources (PSNS) (Section 307(b) of the CWA) .....	1-4
1.2 SECTION 304(M) REQUIREMENTS AND LITIGATION .....	1-4
SECTION 2 DATA COLLECTION .....	2-1
2.1 CLEAN WATER ACT SECTION 308 QUESTIONNAIRES AND SCREENER SURVEYS .....	2-2
2.1.1 Development of Questionnaires and Screener Surveys .....	2-2
2.1.2 Distribution of Screener Surveys and Questionnaires .....	2-4
2.2 SAMPLING PROGRAM .....	2-5
2.2.1 Pre-1989 Sampling Program .....	2-5
2.2.2 1993 - 1995 Sampling Program .....	2-6
2.2.2.1 Facility Selection .....	2-6
2.2.2.2 5-Day Sampling Episodes .....	2-7
SECTION 3 DESCRIPTION OF THE INDUSTRY .....	3-1
3.1 GENERAL INFORMATION .....	3-1
3.2 SCOPE OF THIS REGULATION .....	3-3
3.2.1 Commercial IWC Facilities .....	3-3
3.2.2 Captive and Intra-company IWC Facilities .....	3-3
3.3 SUMMARY INFORMATION ON 84 COMMERCIAL IWC FACILITIES ..	3-5
3.4 SUMMARY INFORMATION ON 26 COMMERCIAL IWC FACILITIES WHICH GENERATE IWC WASTEWATER .....	3-6
3.4.1 RCRA Designation of 26 IWC Facilities .....	3-8
3.4.2 Waste Burned at 26 IWC Facilities .....	3-9
3.4.3 Air Pollution Control Systems for 26 IWC Facilities .....	3-9
3.5 SUMMARY INFORMATION ON 11 COMMERCIAL IWC FACILITIES	

	WHICH GENERATE AND DISCHARGE IWC WASTEWATER . . . . .	3-12
3.6	INDUSTRY SUBCATEGORIZATION . . . . .	3-13
SECTION 4	WASTEWATER USE AND WASTEWATER CHARACTERIZATION . . . .	4-1
4.1	WATER USE AND SOURCES OF WASTEWATER . . . . .	4-1
4.2	WATER USE BY MODE OF DISCHARGE . . . . .	4-2
4.3	WASTEWATER CHARACTERIZATION . . . . .	4-3
	4.3.1 Conventional Pollutants . . . . .	4-4
	4.3.2 Priority and Non-Conventional Pollutants . . . . .	4-7
4.4	WASTEWATER POLLUTANT DISCHARGES . . . . .	4-7
SECTION 5	POLLUTANTS AND POLLUTANT PARAMETERS SECLECTED FOR REGULATION . . . . .	5-1
5.1	POLLUTANT PARAMETERS . . . . .	5-1
5.2	PRIORITY AND NON-CONVENTIONAL POLLUTANTS . . . . .	5-1
	5.2.1 Dioxins/Furans in Industrial Waste Combustor Subcategory . . . . .	5-2
	5.2.2 Selection of Priority and Non-Conventional Pollutants for Regulation . . . . .	5-5
5.3	SELECTION OF POLLUTANTS TO BE REGULATED FOR PSES AND PSNS . . . . .	5-7
	5.3.1 Pass-Through Analysis Approach . . . . .	5-8
	5.3.2 50 POTW Study Database . . . . .	5-8
	5.3.3 RREL Treatability Data Base . . . . .	5-9
	5.3.4 Final POTW Data Editing . . . . .	5-10
	5.3.5 Final Pass-Through Analysis Results . . . . .	5-11
SECTION 6	WASTEWATER TREATMENT TECHNOLOGIES . . . . .	6-1
6.1	AVAILABLE BAT AND PSES TECHNOLOGIES . . . . .	6-2
6.1.1	Physical/Chemical Treatment . . . . .	6-2
	6.1.1.1 Equalization . . . . .	6-2
	6.1.1.2 Neutralization or pH Control . . . . .	6-3
	6.1.1.3 Flocculation . . . . .	6-5
	6.1.1.4 Gravity-Assisted Separation . . . . .	6-7
	6.1.1.5 Chemical Precipitation . . . . .	6-9
	6.1.1.6 Stripping . . . . .	6-11
	6.1.1.7 Filtration . . . . .	6-11
	6.1.1.7.1 Sand/Multi-Media Filtration . . . . .	6-14
	6.1.1.7.2 Fabric Filters . . . . .	6-16
	6.1.1.7.3 Ultrafiltration . . . . .	6-16
	6.1.1.8 Carbon Adsorption . . . . .	6-18
	6.1.1.9 Chromium Reduction . . . . .	6-20
6.1.2	Sludge Handling . . . . .	6-20
	6.1.2.1 Sludge Slurrying . . . . .	6-22
	6.1.2.2 Vacuum Filtration . . . . .	6-22

	6.1.2.3	Pressure Filtration .....	6-22
	6.1.2.4	Centrifuges .....	6-25
	6.1.2.5	Dryer .....	6-25
	6.1.3	Zero Discharge Options .....	6-26
	6.1.3.1	Incineration .....	6-26
	6.1.3.2	Off-Site Disposal .....	6-26
	6.1.3.3	Evaporation/Land Applied .....	6-26
6.2	TREATMENT OPTIONS FOR OTHER WASTEWATERS GENERATED BY IWC OPERATIONS .....		6-26
	6.2.1	Chemical Oxidation .....	6-27
	6.2.2	Zero Discharge Options .....	6-28
	6.2.2.1	Deep Well Disposal .....	6-30
6.3	OTHER WASTEWATER TREATMENT TECHNOLOGIES .....		6-30
6.4	TREATMENT PERFORMANCE AND DEVELOPMENT OF REGULATORY OPTIONS .....		6-31
	6.4.1	Performance of EPA Sampled Treatment Processes .....	6-31
	6.4.1.1	Treatment Performance for Episode #4646 .....	6-31
	6.4.1.2	Treatment Performance for Episode #4671 .....	6-38
	6.4.1.3	Treatment Performance for Episode #4733 .....	6-43
	6.4.2	Rationale Used for Selection of BAT Treatment Technologies .....	6-47
SECTION 7	ENGINEERING COSTS .....		7-1
7.1	COSTS DEVELOPMENT .....		7-2
	7.1.1	Sources of Cost Data .....	7-2
	7.1.1.1	Cost Models .....	7-2
	7.1.1.2	Vendor Data .....	7-3
	7.1.1.3	Waste Treatment Industry Phase II: Incinerators 308 Questionnaire Costing Data .....	7-4
	7.1.1.4	Other EPA Effluent Guideline Studies .....	7-4
	7.1.2	Benchmark Analysis and Evaluation Criteria .....	7-4
	7.1.3	Selection of Final Cost Models .....	7-7
7.2	ENGINEERING COSTING METHODOLOGY .....		7-8
	7.2.1	Treatment Costing Methodology .....	7-9
	7.2.2	Option Costing Methodology .....	7-11
7.3	TREATMENT TECHNOLOGIES COSTING .....		7-13
	7.3.1	Physical/Chemical Wastewater Treatment Technology Costs .....	7-15
	7.3.1.1	Chemical Feed Systems .....	7-15
	7.3.1.2	Pumping .....	7-33
	7.3.1.3	Rapid Mix Tanks .....	7-33
	7.3.1.4	Flocculation .....	7-38
	7.3.1.5	Primary Clarification .....	7-41
	7.3.1.6	Secondary Clarification .....	7-41
	7.3.1.7	Multi-Media Filtration .....	7-44

7.3.2	Sludge Treatment and Disposal	7-48
7.3.2.1	Plate and Frame Pressure Filtration	7-48
7.3.2.2	Filter Cake Disposal Costs	7-51
7.4	ADDITIONAL COSTS	7-51
7.4.1	Retrofit and Upgrade Costs	7-52
7.4.2	Land Costs	7-52
7.4.3	RCRA Permit Modification Costs	7-53
7.4.4	Monitoring Costs	7-53
7.5	WASTEWATER OFF-SITE DISPOSAL COSTS	7-55
7.6	COSTS FOR REGULATORY OPTIONS	7-56
7.6.1	BPT/BAT Costs	7-56
7.6.1.1	BPT/BAT Option A: Two-Stage Chemical Precipitation	7-56
7.6.1.2	BPT/BAT Option B: Two-Stage Chemical Precipitation and Multi-Media Filtration	7-57
7.6.2	PSES Costs	7-57
7.6.2.1	PSES Option A: Two-Stage Chemical Precipitation	7-57
7.6.2.2	PSES Option B: Two-Stage Chemical Precipitation and Multi-Media Filtration	7-60
7.6.3	New Source Performance Standards Costs	7-60
7.6.4	Pretreatment Standards for New Sources Costs	7-60
SECTION 8	DEVELOPMENT OF LIMITATIONS AND STANDARDS	8-1
8.1	ESTABLISHMENT OF BPT	8-1
8.2	BCT	8-6
8.3	BAT	8-6
8.4	NSPS	8-6
8.5	PSES	8-8
8.6	PSNS	8-10
8.7	COST OF TECHNOLOGY OPTIONS	8-10
8.7.1	Proposed BPT Costs	8-11
8.7.2	Proposed BCT/BAT Costs	8-11
8.7.3	Proposed PSES Costs	8-11
8.8	POLLUTANT REDUCTIONS	8-12
8.8.1	Conventional Pollutant Reductions	8-12
8.8.2	Priority and Nonconventional Pollutant Reductions	8-12
8.8.2.1	Methodology	8-12
8.8.2.2	Direct Discharges (BPT/BAT)	8-13
8.8.2.3	PSES Effluent Discharges to POTWs	8-13
SECTION 9	NON-WATER QUALITY IMPACTS	9-1
9.1	AIR POLLUTION	9-1
9.2	SOLID WASTE	9-2

9.3	ENERGY REQUIREMENTS .....	9-3
Appendix A	Range of Pollutant Influent Concentrations of the Pooled Daily Data from the Three 5-Day EPA Sampling Episodes for all Analytes	
Appendix B	ACRONYMS AND DEFINITIONS	



## LIST OF TABLES

- ES-1 Technology Basis of BPT Effluent Limitations
- ES-2 Cost of Implementing Regulations (in millions of 1992 dollars)
- 3-1 Number of Thermal Units at Each of the 84 IWC Facility Locations
- 3-2 Types of Thermal Units at 84 IWC Facilities
- 3-3 Amount of Waste Treated by 84 Commercial Facilities in Calendar Year 1992 (Tons)
- 3-4 Quantity of Process Wastewater Generated by 84 IWC Facilities in Calendar Year 1992 (Thousand Gallons)
- 3-5 1992 RCRA Designation of 26 Commercial Facilities
- 3-6 Number of Customers/Facilities Served in 1992 by 26 Commercial Facilities
- 3-7 Types of Air Pollution Control Systems at 26 Commercial Facilities
- 3-8 Air Pollutants for Which Add-On Control Systems are in Operation for 26 Commercial Facilities
- 3-9 Scrubbing Liquor Used in Air Pollution Control Systems of 26 Commercial Facilities
- 3-10 Type of Water Recirculation System Used in Air Pollution Control Systems of the 26 IWC Facilities
- 4-1 Amount of IWC Wastewater Discharged
- 4-2 Range of Pollutant Influent Concentrations (ug/l)
- 4-3 IWC Industry Current Performance
- 5-1 Breakdown of Detected Dioxin/Furans During IWC Sampling Program
- 5-2 Pollutants Excluded from Regulation Due to the Concentration Detected for the IWC Industry
- 5-3 Pollutants Excluded from Regulation Due to Ineffective Treatment for the IWC Industry
- 5-4 Pollutants Indirectly Controlled Through Regulation of Other Pollutants
- 5-5 Pollutants Selected for Regulation for the IWC Industry
- 5-6 Final POTW Removals for IWC Industry Pollutants
- 5-7 Final Pass-Through Results for IWC Industry Options A and B
- 6-1 Description of IWC Sampling Episodes
- 6-2 Treatment Technology Performance for Facility 4646?
- 6-3 Treatment Technology Performance for Facility 4671?
- 6-4 Treatment Technology Performance for Facility 4733?
- 6-5 Primary Chemical Precipitation Treatment Technology Performance Comparison
- 6-6 Secondary Chemical Precipitation and Filtration Treatment Technology Performance Comparison
- 7-1 Benchmark Analysis Cost Comparison
- 7-2 Breakdown of Costing Method by Treatment Technology
- 7-3 Additional Cost Factors
- 7-4 Regulatory Option Wastewater Treatment Technology Breakdown
- 7-5 Chemical Addition Design Method
- 7-6 Treatment Chemical Costs
- 7-7 Sodium Hydroxide Requirements for Chemical Precipitation

- 7-8 State Land Costs
- 7-9 Analytical Monitoring Costs
- 7-10 IWC Facilities Costed for Off-Site Disposal
- 8-1 BPT Effluent Limitations (mg/l)
- 8-2 PSES Effluent Limitations (mg/l)
- 8-3. Direct Discharge Loads (in lbs.)
- 8-4. Indirect Discharge Loads (in lbs.)
- 9-1 Filter Cake Generation for the IWC Industry

## LIST OF FIGURES

- 6-1 Equalization
- 6-2 Neutralization
- 6-3 Clarification System Incorporating Coagulation and Flocculation
- 6-4 Chemical Precipitation System Design
- 6-5 Typical Air Stripping System
- 6-6 Multimedia Filtration
- 6-7 Ultrafiltration System Diagram
- 6-8 Granular Activated Carbon Adsorption
- 6-9 Chromium Reduction
- 6-10 Vacuum Filtration
- 6-11 Plate and Frame Pressure Filtration System Diagram
- 6-12 Cyanide Destruction
- 6-13 EPA Sampling Episode 4646 - IWC Wastewater Treatment System Block Flow Diagram with Sampling Locations
- 6-14 EPA Sampling Episode 4671 - IWC Wastewater Treatment System Block Flow Diagram with Sampling Locations
- 6-15 EPA Sampling Episode 4733 - IWC Wastewater Treatment System Block Flow Diagram with Sampling Locations
- 7-1 Option-Specific Costing Logic Flow Diagram
- 7-2 Sodium Hydroxide Capital Cost Curve
- 7-3 Sodium Hydroxide O&M Cost Curve
- 7-4 Ferric Chloride Capital Cost Curve
- 7-5 Ferric Chloride O&M Cost Curve
- 7-6 Sodium Bisulfite Capital Cost Curve
- 7-7 Sodium Bisulfite O&M Cost Curve
- 7-8 Hydrochloric Acid Capital Cost Curve
- 7-9 Hydrochloric Acid O&M Cost Curve
- 7-10 Polymer Feed Capital Cost Curve
- 7-11 Polymer Feed O&M Cost Curve
- 7-12 Wastewater Pumping Capital Cost Curve
- 7-13 Wastewater Pumping O&M Cost Curve
- 7-14 Mix Tank Capital Cost Curve
- 7-15 Mix Tank O&M Cost Curve
- 7-16 Flocculation Capital Cost Curve
- 7-17 Flocculation O&M Cost Curve
- 7-18 Primary Clarifier Capital Cost Curve
- 7-19 Primary Clarifier O&M Cost Curve
- 7-20 Secondary Clarifier Capital Cost Curve
- 7-21 Secondary Clarifier O&M Cost Curve
- 7-22 Multimedia Filtration Capital Cost Curve
- 7-23 Sludge Dewatering Capital Cost Curve

## 7-24 Sludge Dewatering O&M Cost Curve

## EXECUTIVE SUMMARY

EPA has proposed technology-based limits for the discharge of pollutants into navigable waters of the United States and into publicly-owned treatment works by existing and new facilities that are engaged in combustion of industrial waste from off-site facilities - the Industrial Waste Combustor Subcategory of the Waste Combustors Point Source Category. This proposed regulation establishes effluent limitations guidelines for direct dischargers based on the following treatment technologies: "best practicable control technology" (BPT), "best conventional pollutant control technology" (BCT), and "best available technology economically achievable" (BAT). New source performance standards are based on "best demonstrated technology". The proposal also establishes pretreatment standards for new and existing indirect dischargers.

EPA identified 84 facilities in the Industrial Waste Combustor Industry. The scope of the Industrial Waste Combustor Industry includes: commercially-operating hazardous waste combustor facilities regulated as "incinerators" or "boilers and industrial furnaces" under the Resource Conservation and Recovery Act (RCRA) as well as commercially-operating non-hazardous waste industrial waste combustor facilities. The proposed effluent limitations guidelines and standards are intended to cover wastewater discharges resulting from air pollution control systems, flue gas quench systems and slag quench systems associated with the operation of industrial waste combustors. Any other discharges associated with the operations of industrial waste combustors (e.g., truck washing water and boiler blowdown) are not included in the regulation. EPA has estimated that the proposed regulation will apply to 11 facilities which discharge specified IWC wastewater. Eight facilities discharge directly and three discharge indirectly to publicly-owned treatment works (POTWs).

The EPA evaluated various treatment technologies in developing the effluent limitations and standards. Table ES-1 lists the treatment technologies that are proposed for the BPT limitations and for the PSES pretreatment standards. The treatment technologies proposed for BPT are the same technologies proposed for BCT, BAT and NSPS. The treatment technologies proposed for PSES are the same treatment technologies proposed for PSNS.

**Table ES-1. Technology Basis for Effluent Limitations and Pretreatment Standards**

<b>Proposed 40 CFR Subpart</b>	<b>Type</b>	<b>Technology Basis</b>
<b>444</b>	<b>BPT, BAT, BCT, and NSPS Effluent Limitations</b>	<b>Primary Precipitation, Solid-Liquid Separation, Secondary Precipitation, Solid-Liquid Separation, and Sand Filtration</b>
<b>444</b>	<b>PSES and PSNS Pretreatment Standards</b>	<b>Primary Precipitation, Solid-Liquid Separation, Secondary Precipitation and Solid-Liquid Separation</b>

After identifying treatment technologies, the EPA calculated facility costs to upgrade facility operations to achieve the proposed limitations based on the selected technology options. Table ES-2 presents the capital and operating and maintenance costs associated with the proposed technology options. In addition to the costs for upgrading facility operations, costs were also developed for: additional land requirements, additional wastewater monitoring requirements for the proposed regulation, and RCRA permit modifications, when necessary. Overall, the proposed technology options are estimated to have a post-tax annualized cost of \$1.381 million (in 1992\$) for direct dischargers and \$0.531 million (in 1992\$) for indirect dischargers.

**Table ES-2. Cost of Implementing Regulations [in Millions of 1992 dollars]**

<b>Type</b>	<b>Number of Facilities</b>	<b>Capital Costs [in 1992\$]</b>	<b>Annual O &amp; M Costs [in 1992\$]</b>
<b>BPT, BAT, BCT, and NSPS Effluent Limitations</b>	<b>8</b>	<b>6.346</b>	<b>1.255</b>
<b>PSES and PSNS Pretreatment Standards</b>	<b>3</b>	<b>2.090</b>	<b>0.529</b>

## **SECTION 1**

### **STATUTORY REQUIREMENTS**

Effluent limitations guidelines and standards for the Industrial Waste Combustor Industry were proposed under the authority of Section 301, 304, 306, 307, 308 and 501 of the Clean Water Act (CWA) (the Federal Water Pollution Control Act Amendments of 1972, 33 U.S.C. 1251 et seq., as amended by the Clean Water Act of 1977, Pub. L. 95-217, and the Water Quality Act of 1987, Pub. L. 100-4), also referred to as "the Act".

#### **1.1            *LEGAL AUTHORITY***

The Federal Water Pollution Control Act Amendments of 1972 established a comprehensive program to "restore and maintain the chemical, physical, and biological integrity of the Nation's waters". (Section 101(a)). To implement the Act, EPA is required to issue effluent limitations guidelines and pretreatment standards for industrial discharges. These guidelines and standards are summarized briefly in the following sections.

##### **1.1.1            *Best Practicable Control Technology Currently Available (BPT)* *(Section 304(b)(1) of the CWA)***

In the guidelines, EPA defines BPT effluent limits for conventional, priority, and non-conventional pollutants. In specifying BPT, EPA looks at a number of factors. EPA first considers the cost of achieving effluent reductions in relation to the effluent reduction benefits. The Agency next considers: 1) the age of the equipment and facilities, the processes employed and any required process changes, engineering aspects of the control technologies, non-water quality environmental impacts (including energy requirements), and such other factors as the Agency deems appropriate (CWA §304(b)(1)(B)). Traditionally, EPA establishes BPT effluent limitations based on the average of the best performances of facilities within the industry of various ages, sizes, processes or other common characteristics. Where, however, existing performance within a category or subcategory is uniformly inadequate, EPA may require higher levels of control than currently in place in an industrial category (or subcategory) if the Agency determines that the technology can be practically

applied. BPT may be transferred from a different subcategory or category.

In the initial stages of EPA CWA regulation, EPA efforts emphasized the achievement of BPT limitations for control of the "classical" pollutants (e.g., TSS, pH, BOD<sub>5</sub>). However, nothing on the face of the statute specifically restricted BPT limitations to such pollutants. Following passage of the CWA of 1977 with its requirement for point sources to achieve best available technology limitations to control discharges of toxic pollutants, EPA shifted its focus to address the listed priority pollutants under the guidelines program. BPT guidelines continue to include limitations to address all pollutants.

#### **1.1.2      *Best Conventional Pollutant Control Technology (BCT)* *(Section 304(a)(4) of the CWA)***

The 1977 Amendments added Section 301 (b)(2)(E) to the Act establishing BCT for discharges of conventional pollutants from existing industrial point sources. Section 304(a)(4) designated the following as conventional pollutants: biochemical oxygen demanding pollutants (BOD), total suspended solids (TSS), fecal coliform, pH, and any additional pollutants defined by the Administrator as conventional. The Administrator designated oil and grease as an additional conventional pollutant on July 30, 1979 (44 FR 44501). BCT is not an additional limitation, but replaces BAT for the control of conventional pollutants. In addition to other factors specified in Section 304(b)(4)(B), the Act requires that BCT limitations be established in light of a two-part "cost-effectiveness" test [*American Paper Institute v. EPA*, 660 F.2d 954 (4th Cir. 1981)]. EPA's current methodology for the general development of BCT limitations was issued in 1986 (51 FR 24974; July 9, 1986).

#### **1.1.3      *Best Available Technology Economically Achievable (BAT)* *(Sections 304(b)(2)(B) of the CWA)***

In general, BAT effluent limitations guidelines represent the best economically achievable performance of plants in the industrial subcategory or category. The CWA establishes BAT as a principle means of controlling the direct discharge of priority and non-conventional pollutants to waters of the United States. The factors considered in assessing BAT include the cost of achieving

BAT effluent reductions, the age of equipment and facilities involved, the process employed, potential process changes, and non-water quality environmental impacts, including energy requirements. The Agency retains considerable discretion in assigning the weight to be accorded these factors. Unlike BPT limitations, BAT limitations may be based on effluent reductions attainable through changes in a facility's processes and operations. As with BPT, where existing performance is uniformly inadequate, BAT may require a higher level of performance than is currently being achieved based on technology transferred from a different subcategory or category. BAT may be based upon process changes or internal controls, even when these technologies are not common industry practice.

#### **1.1.4            *New Source Performance Standards (NSPS)* *(Section 306 of the CWA)***

NSPS reflect effluent reductions that are achievable based on the best available demonstrated treatment technology. New plants have the opportunity to install the best and most efficient production processes and wastewater treatment technologies. As a result, NSPS should represent the most stringent controls attainable through the application of the best available control technology for all pollutants (i.e., conventional, non-conventional, and priority pollutants). In establishing NSPS, EPA is directed to take into consideration the cost of achieving the effluent reduction and any non-water quality environmental impacts and energy requirements.

#### **1.1.5            *Pretreatment Standards for Existing Sources (PSES)* *(Section 307(b) of the CWA)***

PSES are designed to prevent the discharge of pollutants that pass-through, interfere-with, or are otherwise incompatible with the operation of publicly-owned treatment works (POTWs). The CWA authorized EPA to establish pretreatment standards for pollutants that pass-through POTWs or interfere with treatment processes or sludge disposal methods at a POTW. Pretreatment standards are technology-based and analogous to BAT effluent limitations guidelines.

The general Pretreatment Regulations, which set forth the framework for the implementation of categorical pretreatment standards, are found in 40 CFR Part 403. Those regulations contain a definition of pass-through that addresses localized rather than national instances of pass-through and

established pretreatment standards that apply to all non-domestic dischargers (52 FR 1586; January 14, 1987).

**1.1.6      *Pretreatment Standards for New Sources (PSNS)*  
*(Section 307(b) of the CWA)***


Like PSES, PSNS are designed to prevent the discharges of pollutants that pass-through, interfere-with, or are otherwise incompatible with the operation of POTWs. PSNS are to be issued at the same time as NSPS. New indirect dischargers have the opportunity to incorporate into their plants the best available demonstrated technologies. The Agency considers the same factors in promulgating PSNS as it considers in promulgating NSPS.

**1.2            *SECTION 304(M) REQUIREMENTS AND LITIGATION***

Section 304(m) of the CWA (33 U.S.C. 1314(m)), added by the Water Quality Act of 1987, requires EPA to establish schedules for (i) reviewing and revising existing effluent limitations guidelines and standards ("effluent guidelines"), and (ii) promulgating new effluent guidelines. On January 2, 1990, EPA published an Effluent Guidelines Plan (55 FR 80), that included schedules for developing new and revised effluent guidelines for several industry categories. One of the industries for which the Agency established a schedule was the "Hazardous Waste Treatment, Phase II" category. EPA subsequently changed the category name "Hazardous Waste Treatment, Phase II" to "Landfills and Incinerators".

Natural Resources Defense Council, Inc. (NRDC) and Public Citizen, Inc. challenged the Effluent Guidelines Plan in a suit filed in U.S. District Court for the District of Columbia (*NRDC et al v. Reilly*, Civ. No. 89-2980). The district court entered a Consent Decree in this litigation on January 31, 1992. The Decree required, among other things, that EPA propose effluent guidelines for the "Landfills and Incinerators" category by December 1995 and take final action on these effluent guidelines by December 1997. On February 4, 1997, the court approved modifications to the Decree which revised the deadlines to November 1997 for proposal and November 1999 for final action. EPA provided notice of these modifications on February 26, 1997 at 62 FR 8726. Also, although "Landfills and Incinerators" is listed as a single entry in the Consent Decree schedule, EPA is

publishing two separate rulemaking actions in the Federal Register.



## **SECTION 2**

### **DATA COLLECTION**

In 1986, the Agency initiated a study of waste treatment facilities which receive waste from off site for treatment, recovery, or disposal. The Agency looked at various segments of the waste management industry including combustors, centralized waste treatment facilities, landfills, fuel blending operations, and waste solidification/stabilization processes (Preliminary Data Summary for the Hazardous Waste Treatment Industry, EPA 440-1-89-100, September 1989).

Development of effluent limitations guidelines and standards for the Industrial Waste Combustor Subcategory began in 1993. EPA originally looked at RCRA hazardous waste incinerators, RCRA boilers and industrial furnaces (BIFs), and non-hazardous combustion units that treat industrial waste. Sewage sludge incinerators, municipal waste incinerators, and medical waste incinerators were not included in the 1989 study or in the initial data collection effort in 1993. EPA limited this phase of the rulemaking to the development of regulations for Industrial Waste Combustors.

EPA has gathered and evaluated technical and economic data from various sources in the course of developing the effluent limitations guidelines and standards for the Industrial Waste Combustor Industry. These data sources include:

- Responses to EPA's "1992 Waste Treatment Industry Phase II: Incinerators Screener Survey",
- Responses to EPA's "1994 Waste Treatment Industry Phase II: Incinerators Questionnaire",
- Responses to EPA's "1994 Detailed Monitoring Questionnaire",
- EPA's 1993 - 1995 sampling of selected IWC facilities
- Literature data, and
- Facility NPDES and POTW wastewater discharge permit data.

EPA has used data from these sources to profile the industry with respect to: wastes received

for treatment or recovery, treatment/recovery processes, geographical distribution, and wastewater and solid waste disposal practices. EPA then characterized the wastewater generated by treatment/recovery operations through an evaluation of water usage, type of discharge or disposal, and the occurrence of conventional, non-conventional, and priority pollutants.

## **2.1            *CLEAN WATER ACT SECTION 308 QUESTIONNAIRES AND SCREENER SURVEYS***

### **2.1.1            *Development of Questionnaires and Screener Surveys***

A major source of information and data used in developing effluent limitations guidelines and standards is industry responses to questionnaires and screener surveys distributed by EPA under the Authority of Section 308 of the CWA. The questionnaires typically request information concerning treatment processes, wastes received for treatment, and disposal practices, as well as wastewater treatment system performance data. Questionnaires also request financial and economic data for use in assessing economic impacts and the economic achievability of technology options. Screener surveys generally request less detailed information than the questionnaires regarding treatment processes, wastes received for treatment, and disposal practices.

EPA used its experience with previous questionnaires to develop one screener survey (the 1992 Waste Treatment Industry Phase II: Incinerators Screener Survey) and two questionnaires (the 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire and the Detailed Monitoring Questionnaire) for this project. The 1992 Waste Treatment Industry Phase II: Incinerators Screener Survey was designed to obtain general information on facility operations from a census of the industry. The 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire was designed to request 1992 technical, economic, and financial data to describe industrial operations adequately from a census of facilities in the industry that were operating commercially and from a sample of facilities in the industry that were not operating commercially. The Detailed Monitoring Questionnaire was designed to elicit daily analytical data from a limited number of facilities which would be selected after receipt and review of the 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire responses.

For the 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire, EPA wanted to minimize the burden to IWC facilities. Thus, only a statistical sample of the non-commercial facilities meeting the preliminary scope qualifications received the 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire. The questionnaire specifically requested information on:

- combustion processes,
- types of waste received for combustion,
- wastewater and solid waste disposal practices,
- ancillary waste management operations,
- summary analytical monitoring data,
- the degree of co-combustion (combustion of waste received from off site with other on-site industrial waste),
- cost of waste combustion processes, and
- the extent of wastewater recycling or reuse at facilities.

In the 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire, EPA requested summary monitoring data from all recipients, but summary information is not sufficient for determining limitations and industry variability. Therefore, the Detailed Monitoring Questionnaire was designed to collect daily analytical data from a limited number of facilities. Facilities were chosen to complete the Detailed Monitoring Questionnaire based on technical information submitted in the 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire. The burden was minimized in the Detailed Monitoring Questionnaire by tailoring the questionnaire to the facility operations.

EPA sent draft screener surveys and questionnaires to industry trade associations, incinerator facilities who had expressed interest, and environmental groups for review and comment. A pre-test for both the 1992 Waste Treatment Industry Phase II: Incinerators Screener Survey and the 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire was conducted at nine IWC facilities to determine if the type of information necessary would be received from the questions posed as well as to determine if questions were designed to minimize the burden to facilities. Based on comments from the reviewers, EPA modified the draft questionnaire.

As required by the Paperwork Reduction Act, 44 U.S.C. 3501 *et seq.*, EPA submitted the questionnaire package (including the 1992 Waste Treatment Industry Phase II: Incinerators Screener Survey and the 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire and the Detailed Monitoring Questionnaire) to the Office of Management and Budget (OMB) for review. EPA also redistributed the questionnaire package to industry trade associations, IWC facilities, environmental groups, and to any others who requested a copy of the questionnaire package.

#### **2.1.2      *Distribution of Screener Surveys and Questionnaires***

Under the authority of Section 308 of the CWA, EPA sent the Waste Treatment Industry Phase II: Incinerators 1992 Screener Survey (OMB Approval Number: 2040-0162, Expired: 08/31/96) in September 1993 to 606 facilities that the Agency had identified as possible Industrial Waste Combustor facilities. EPA identified the 606 facilities as possible IWC facilities from various sources; such as, companies listed in the 1992 Environmental Information (EI) Directory, companies that were listed as incinerators in the RCRIS National Oversight Database (November 1992 and February 1993 versions), companies that were listed as BIF Facilities by EPA (updated December 1992), and incinerator facilities identified in the development of the Centralized Waste Treatment Industry effluent guidelines. Since the Industrial Waste Combustor Subcategory was not represented by a SIC code at the time of the survey, identification of facilities was difficult. The screener survey requested summary information on: (1) the types of wastes accepted for combustion; (2) the types of combustion units at a facility; (3) the quantity, treatment, and disposal of wastewater generated from combustion operations; (4) available analytical monitoring data on wastewater treatment; and (5) the degree of co-treatment (treatment of Industrial Waste Combustor wastewater with wastewater from other industrial operations at the facility). The responses from 564 facilities indicated that 357 facilities burned industrial waste in 1992. The remaining 207 did not burn industrial waste in 1992. Of the 357 facilities that burned industrial waste, 142 did not generate any Industrial Waste Combustor wastewater as a result of their combustion operations. Of the remaining 215 facilities that generated Industrial Waste Combustor wastewater, 59 operated commercially, and 156 only burned wastes generated on site, and/or only burned wastes generated from off-site facilities under the same corporate structure.

Following an analysis of the screener survey results, EPA sent the 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire (OMB Approval Number: 2040-0167, Expired: 12/31/96) in March, 1994 to selected facilities which burned industrial waste and generated Industrial Waste Combustor wastewater. EPA sent the questionnaire to all 59 of the commercial facilities and all 16 of the non-commercial facilities that burned non-hazardous industrial waste. Further, EPA sent 32 of the remaining 140 non-commercial facilities a questionnaire. These 32 facilities were selected based on a statistical random sample. The questionnaire specifically requested information on: (1) the type of wastes accepted for treatment; (2) the types of combustion units at a facility; (3) the types of air pollution control devices used to control emissions from the combustion units at a facility; (4) the quantity, treatment, and disposal of wastewater generated from combustion operations; (5) available analytical monitoring data on wastewater treatment; (6) the degree of co-treatment (treatment of Industrial Waste Combustor wastewater with wastewater from other industrial operations at the facility); and (7) the extent of wastewater recycling and/or reuse at the facility. Information was also obtained through follow-up telephone calls and written requests for clarification of questionnaire responses.

EPA also requested a subset of Industrial Waste Combustor facilities that received a questionnaire to submit wastewater monitoring data in the form of individual data points rather than monthly or annual aggregates. Only facilities that had identified a sample point location where the stream was over 50 percent Industrial Waste Combustor wastewater received the Detailed Monitoring Questionnaire. These wastewater monitoring data included information on pollutant concentrations at various points in the wastewater treatment processes. Data were requested from 26 facilities. Sixteen of these facilities operated commercially and 10 operated non-commercially.

## **2.2            *SAMPLING PROGRAM***

### **2.2.1            *Pre-1989 Sampling Program***

In the sampling program for the 1989 Hazardous Waste Treatment Industry Study, 12 facilities were sampled to characterize the wastes received and evaluate the on-site treatment technology performance at combustors, landfills, and hazardous waste treatment facilities. Since all

of the facilities sampled had more than one on-site operation (e.g., combustion and landfill leachate generation), the data collected can not be used for this project because data were collected for mixed waste streams and the waste characteristics and treatment technology performance for the combustor facilities cannot be differentiated. Information collected in the study is presented in the Preliminary Data Summary for the Hazardous Waste Treatment Industry (EPA 440/1-89/100, September 1989).

## **2.2.2        *1993 - 1995 Sampling Program***

### **2.2.2.1       Facility Selection**

Between 1993 and 1995, EPA visited 14 Industrial Waste Combustor facilities. Eight of the fourteen Industrial Waste Combustors EPA visited were captive facilities because captive facilities were still being considered for inclusion in the scope of the Industrial Waste Combustor regulation at the time of the site visits. During each visit, EPA gathered the following information:

- the process for accepting waste for combustion,
- the types of waste accepted for combustion,
- design and operating procedures for combustion technologies,
- general facility management practices,
- water discharge options,
- solid waste disposal practices, and
- other facility operations.

EPA also took one grab sample of untreated Industrial Waste Combustor scrubber blowdown water at 12 of the 14 facilities. EPA analyzed most of these grab-samples for over 450 analytes to identify pollutants at these facilities. The grab samples from the 12 site visits allowed EPA to assess whether there was a significant difference in raw wastewater characteristics from a wide variety of combustion unit types. (See Section 3 for a description of the types of combustion units.) EPA determined that the raw wastewater characteristics were similar for all types of combustion units both in the types of pollutants detected and the concentrations of pollutants detected. Specifically, organics,

pesticides/herbicides, and dioxins/furans were generally only detected, if at all, in low concentrations in the grab samples. (See Section 5 of this document for a discussion of dioxins/furans found at seven of the twelve Industrial Waste Combustor facilities sampled.) However, a variety of metal analytes were detected in significant concentrations in the grab samples.

Based on these data and the responses to the 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire, EPA selected three of the Industrial Waste Combustor facilities for the BAT sampling program in order to collect data to characterize discharges and the performance of selected treatment systems. Using data supplied by the facilities, EPA applied five criteria in initially selecting which facilities to sample. The criteria were based on whether the wastewater treatment system: (1) was effective in removing pollutants; (2) treated wastes received from a variety of sources (solids as well as liquids); (3) employed either novel treatment technologies or applied traditional treatment technologies in a novel manner; (4) applied waste management practices that increased the effectiveness of the treatment unit; and (5) discharged its treated wastewater under a NPDES permit. The other 11 facilities visited were not sampled because they did not meet these criteria. Eight of these eleven facilities visited did not operate commercially, and are thus no longer in the scope of the project.

#### **2.2.2.2 Five-Day Sampling Episodes**

After a facility was chosen to participate in the five-day sampling program, a draft sampling plan was prepared which described the location of sample points and analyses to be performed at specific sample points, as well as the procedures to be followed during the sampling episode. Prior to sampling, a copy of the draft sampling plan was provided to the facility for review and comment to ensure that EPA properly described and understood facility operations. All comments were incorporated into the final sampling plan. During the sampling episode, teams of EPA employees and contractors collected and preserved samples. Samples were sent to EPA approved laboratories for analysis. Samples were collected at both influent and effluent points. Samples were also taken at intermediate points to assess the performance of individual treatment units. Facilities were given the option to split all samples with EPA, but most facilities split only effluent sample points with EPA. Following the sampling episode, a draft sampling report was prepared that included descriptions of

the treatment/recovery processes, sampling procedures, and analytical results. After all information was gathered, the reports were provided to facilities for review and comment. Corrections were incorporated into the final report. The facilities also identified any information in the draft sampling report that were considered to be Confidential Business Information (CBI).

During each sampling episode, wastewater treatment system influent and effluent streams were sampled. Samples were also taken at intermediate points to assess the performance of individual treatment units. Selected sampling information is summarized in Section 4 and Appendix A of this document. In all sampling episodes, samples were analyzed for over 450 analytes to identify the pollutants at these facilities. Again, organic compounds, pesticides/herbicides, and dioxins/furans were generally only detected in low concentrations in the composite daily samples, if they were detected at all. Dioxin/furan analytes were not detected in the sampling episode used to establish BPT/BAT/PSES. However, dioxin/furan analytes were found in the two other sampling episodes (see discussion in Section 5 of this document).

EPA completed the three sampling episodes for the Industrial Waste Combustor Subcategory from 1994 to 1995. Selection of facilities to be sampled was limited due to the small number of facilities in the scope of the project. Only eight of the operating facilities identified discharged their treated wastewater under a NPDES permit. Of these eight facilities, only five burned solid as well as liquid waste. All of the facilities sampled used some form of chemical precipitation for treatment of the metal-bearing waste streams. All of the facilities were direct dischargers and were therefore designed to effectively treat the one conventional pollutant found in this industry, TSS. Data from two of these facilities could not be used to calculate the proposed limitations and standards in combination with the third facility because they did not employ the selected treatment technology. However, data from all three facilities were used to characterize the raw waste streams. Thus, only one sampling episode contained data which were used to characterize the treatment technology performance of the Industrial Waste Combustors Industry.

Information on waste stream characteristics is included in Section 4 of this document and system performance is included in Section 6.

## **SECTION 3**

### **DESCRIPTION OF THE INDUSTRY AND SUBCATEGORIZATION**

#### **3.1           GENERAL INFORMATION**

The universe of combustion facilities currently in operation in the United State is broad. These include municipal waste incinerators that burn household and other municipal trash and incinerators that burn hazardous wastes. Other types of incinerators include those that burn medical wastes exclusively and sewage sludge incinerators for incineration of POTWs' wastewater treatment residual sludge. In addition, some boilers and industrial furnaces (e.g., cement kilns) may burn waste materials for fuel.

While many industries began incinerating some of their wastes as early as the late 1950's, the current market for waste combustion (particularly combustion of hazardous wastes) is essentially a creature of the Resource Conservation and Recovery Act (RCRA) and EPA's resulting regulation of hazardous waste disposal. Among the major regulatory spurs to combustion of hazardous wastes have been the land-ban restrictions under the Hazardous and Solid Waste Amendments (HSWA) of 1984 and clean-up agreements for Superfund sites called "Records of Decision" (RODs).

Prior to the promulgation of EPA's Land Disposal Restrictions (LDRs)(40 CFR Part 268), hazardous waste generators were free to send untreated wastes directly to landfills. The LDRs mandated alternative treatment standards for wastes, known as Best Demonstrated Available Technologies (BDATs). Quite often, combustion was the stipulated BDAT. Future modifications to the LDRs may either increase or decrease the quantity of wastes directed to the combustion sector.

The LDRs have also influenced hazardous waste management under the Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA)(42 U.S.C §§ 9601, et. seq.). The RODs set out the clean-up plan for contaminated sites under CERCLA. A key attribute of the RODs is the choice of remediation technology. Incineration is often a technology selected for remediation. While remediation efforts contribute a minority of the wastes managed by combustion, combustion has been used frequently on remediation projects. In addition, future Congressional changes to CERCLA may affect remediation disposal volumes directed to the combustion sector.

The Agency proposed a draft Waste Minimization and Combustion Strategy in 1993 and 1994

to promote better combustion of hazardous waste and encourage reduced generation of wastes. The key projects under the broad umbrella of the strategy are: "Revised Standards for Hazardous Waste Combustors" 61 FR 17358, April 1996, the Waste Minimization National Plan completed in May 1995, and the "RCRA Expanded Public Participation Rule" 60 FR 63417, December 1995. Waste minimization will directly affect waste volumes sent to the combustion and all other waste management sectors.

In recent years, a number of contrary forces have contributed to a reduction in the volume of wastes being incinerated. Declines in waste volumes and disposal prices have been attributed to: waste minimization by waste generators, intense price competition driven by overcapacity, and changes in the competitive balance between cement kilns (and other commercial Boilers and Industrial Furnaces (BIFs)) and commercial incinerators. These trends have been offset by factors such as increased overall waste generation as part of general economic improvement, Industrial Waste Combustors consolidation, and reductions in on-site combustion.

The segment of the universe of combustion units for which EPA is proposing regulations includes all units which operate commercially and which use controlled flame combustion in the treatment or recovery of industrial waste. For example, industrial boilers, industrial furnaces, rotary kiln incinerators, and liquid-injection incinerators are all types of units included in the Industrial Waste Combustor Industry.

Combustion or recovery operations at these facilities generate the following types of wastewater, described more fully in Section 4: air pollution control wastewater, flue gas quench wastewater, slag quench, truck/equipment wash water, container wash water, laboratory drain wastewater, and floor washings from process areas. Typical non-wastewater by-products of combustion or recovery operations may include: slag or ash developed in the combustion unit itself, and emission particles collected using air pollution control systems. There are many different types of air pollution control systems in use by combustion units. The types employed by combustion units include, but are not limited to: packed towers (which use a caustic scrubbing solution for the removal of acid gases), baghouses (which remove particles and do not use any water), wet electrostatic precipitators (which remove particles using water but do not generate a wastewater stream), and venturi scrubbers (which remove particles using water and generate a wastewater stream). Thus, the

amount of wastewater and types of wastewater generated by a combustion unit are directly dependent upon the types of air pollution control systems employed by the combustion unit.

## **3.2            *SCOPE OF THE REGULATION***

### **3.2.1            *Commercial IWC Facilities***

EPA proposed effluent limitations guidelines and pretreatment standards for new and existing commercial facilities that are engaged in the combustion of industrial waste received from off-site facilities not under the same corporate ownership as the industrial waste combustor. The proposal would not apply to wastewater generated in burning wastes from intracompany transfers exclusively and/or from on-site industrial processes exclusively.

The proposed regulation applies to the discharge of wastewater associated with the operation of the following:

- RCRA Incinerators (as defined in 40 CFR 260.10 and in the Definitions Section of this document),
- RCRA Boiler and Industrial Furnaces (BIFs) (as defined in 40 CFR 260.10 and in the Definitions Section of this document), and
- Non-hazardous commercial combustors.

### **3.2.2            *Captive and Intra-company IWC Facilities***

As noted above, the proposal would not apply to wastewater discharges associated with combustion units that burn only wastes generated on site. Furthermore, wastewater discharges from RCRA hazardous incinerators, RCRA BIFs, and non-hazardous combustors that burn waste generated off site from facilities that are under the same corporate ownership (or effective control) as the combustor are similarly not included within the scope of this proposal. Facilities subject to the guidelines and standards would include commercial facilities whose operation is the combustion of off-site generated industrial waste as well as industrial or manufacturing combustors that burn waste

received from off-site facilities that are not within the same corporate structure.

As noted, facilities which only burn waste from off-site facilities under the same corporate structure (intracompany facility) and/or only burn waste generated on site (captive facility) are not included in the scope of the IWC proposal. EPA has decided not to include these facilities within the scope of this regulation for the following reasons. First, based on its survey, EPA identified (as of 1992) approximately 185 captive facilities and 89 facilities that burn wastes received from other facilities within the same corporate umbrella.<sup>1</sup> A significant number of these facilities generated no Industrial Waste Combustor wastewater. EPA's data show that 73 captive facilities (39 percent) and 36 intracompany facilities (42 percent) generated no wastewater as a result of their industrial waste combustor operations. Second, EPA believes the wastewater generated by Industrial Waste Combustor operations at most of the captive and intracompany facilities that EPA has identified are already subject to national effluent limitations (or pretreatment standards) based on the manufacturing operations at the facility. Specifically, 140 of the 156 captive and intracompany facilities which received a screener survey and generated Industrial Waste Combustor wastewater as a result of their combustion operations: 1) were either previously identified as subject to other effluent guidelines by EPA; or 2) identified themselves as subject to other effluent guidelines. There are 97 facilities subject to the Organic Chemicals, Plastics and Synthetic Fibers category (40 CFR Part 414), 17 facilities subject to the Pharmaceuticals category (40 CFR Part 439), 16 facilities subject to the Steam Electric Power Generating category (40 CFR Part 423), 3 facilities subject to the Pesticide Manufacturing category (40 CFR Part 455), and 7 facilities subject to other categories. EPA could not identify an effluent guideline category applicable to their discharges for the remaining 16 of the 156 identified captive and intracompany facilities (five of these are federal facilities).

Also, 83 percent of all captive facilities and 73 percent of all intracompany facilities reported that the combustion unit wastewaters made up less than 20 percent of the final wastewater stream discharged from each facility. EPA concluded that, in these circumstances, it is likely that the

---

<sup>1</sup>As explained in Section 2, EPA conducted an extensive survey (with follow-up questionnaire), in part, to characterize the universe of facilities being considered for regulation. Following proposal, EPA plans to review its screener survey and questionnaire results in order to confirm the accuracy of its assignment of wastewater flows and facilities as captive, intracompany, or commercial Industrial Waste Combustors.

Industrial Waste Combustor waste streams are being treated along with other categorical waste. Also, 71 percent of all captive facilities and 67 percent of all intracompany facilities reported that their IWC wastewater is covered as process wastewater under existing EPA effluent limitations (40 CFR Parts 405-471). This indicates that most Industrial Waste Combustor waste streams are subject either directly (where discharged separately) or when mixed with other wastes subject to national effluent guidelines (or pretreatment standards) comparable to those being considered here. Given these facts, EPA has concluded preliminarily that it should not include such captive or intracompany facilities within the scope of the proposed IWC rule.

### 3.3 *SUMMARY INFORMATION ON 84 COMMERCIAL IWC FACILITIES*

For 1992, EPA identified 84 combustor facilities that accept hazardous or non-hazardous industrial waste from off-site facilities not under the same corporate umbrella for combustion. The following tables provide summary information from the 1992 Waste Treatment Industry Phase II: Incinerators Screener Survey on these 84 combustor facilities.

Many of the 84 commercial IWC facilities have more than one unit on site. The majority of facilities with two or more units on site operate boilers, industrial furnaces, or cement, lime, or aggregate kilns. Table 3-1 presents the number of thermal units at each of the 84 IWC facilities.

**Table 3-1. Number of Thermal Units at Each of the 84 Commercial IWC Facility Locations**

<b>Number of Units</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6</b>	<b>7</b>	<b>8</b>	<b>&gt;8</b>
<b>Number of Facilities</b>	39	23	9	6	2	1	0	0	1

There are more industrial furnaces, boilers, cement kilns, lime kilns, and aggregate kilns than any other unit types. However, more than one of these units often exist at a single facility. Table 3-2 presents the unit types at all 84 IWC facilities.

Most of the waste burned by the 84 IWC facilities is hazardous or non-hazardous industrial waste containing organic compounds. Only one facility indicated that it burned waste containing dioxins/furans, and only four facilities indicated burning waste regulated under the Toxic Substances

**Table 3-2. Types of Thermal Units at 84 Commercial IWC Facilities**

Type of Thermal Unit	Number of Each Unit Type
Rotary Kiln Incinerator	23
Liquid Injection Incinerator	17
Fluidized-Bed Incinerator	1
Multiple-Hearth Incinerator	6
Fixed-Hearth Incinerator	3
Pyrolytic Destructor	3
Industrial Boiler	32
Industrial Furnace	38
Cement, Lime, or Aggregate Kiln	31
Other	19

Control Act (TSCA). Table 3-3 presents the types and amount of waste treated at all 84 IWC facilities.

For the proposed IWC regulations, only air pollution control water, slag quench and flue gas quench are considered "IWC Wastewater." The largest wastewater stream generated by the 84 IWC facilities, stormwater runoff, is regulated under other effluent guidelines. The industry also generates large quantities of boiler blowdown. Boiler blowdown wastewater was not considered for regulation for this industry because it does not come into contact with any of the wastes being burned. Table 3-4 presents the quantity of process wastewater generated by the 84 IWC facilities.

#### **3.4 SUMMARY INFORMATION ON 26 COMMERCIAL IWC FACILITIES WHICH GENERATE IWC WASTEWATER**

Following the distribution of the screener survey, EPA sent the 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire to only those commercial facilities that generated IWC wastewater. Fifty-eight of the 84 commercial IWC facilities did not generate any IWC wastewater;

**Table 3-3. Amount of Waste Treated by 84 Commercial IWC Facilities in Calendar Year 1992 (Tons)**

	Tons							# of Facilities
Waste Type	1-50	51-100	101-500	501-1,000	1,001-5,000	5,001-10,000	> 10,000	
Non-RCRA								
Sewage Sludge	0	1	0	0	0	0	0	1
Municipal Waste	0	0	0	1	1	0	0	2
Containing Metals	3	0	4	1	4	1	4	17
Containing Organics	13	4	10	1	11	5	7	51
All Other Types	7	0	5	1	7	0	1	21
RCRA								
Containing Metals	6	0	3	3	7	2	20	41
Containing Organics	10	2	6	5	5	6	32	66
Containing Dioxins/Furans	0	0	1	0	0	0	0	1
Containing Pesticides/Herbicides	0	2	1	1	8	0	1	13
All Other Types	3	0	1	1	1	1	6	13
Special								
Radioactive Wastes	1	0	0	0	0	0	0	1
TSCA Wastes (PCBs)	0	0	0	0	1	0	3	4
Medical Wastes	0	0	1	0	0	0	0	1

thus, EPA only has detailed operation information on the 26 commercial IWC facilities that generated wastewater. The following tables provide summary information from the 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire from these 26 combustor facilities.

**Table 3-4. Quantity of Process Wastewater Generated by 84 Commercial IWC Facilities in Calendar Year 1992 (Thousand Gallons)**

Type of Process Water	Gallons (1,000s)							# of Facilities
	0-5	5-15	15-50	50-100	100-500	500-750	>750	
None	25	0	0	0	0	0	0	25
Air Pollution Control Wastewater	2	1	2	2	0	0	14	21
Slag Quench	1	0	2	0	2	0	0	5
Process Area Washdown	6	2	3	1	5	0	4	21
Truck/Equipment Wash Water	2	0	2	2	2	0	3	11
Container Wash Water	2	0	1	1	1	1	0	6
Stormwater Runoff	2	2	0	2	3	3	17	29
Laboratory Wastewater	5	0	0	2	3	0	1	11
Flue Gas Quench Wastewater	2	0	1	0	0	0	8	11
Boiler Blowdown	6	1	3	1	0	3	11	25
Other	2	0	3	0	0	0	9	14

### 3.4.1 RCRA Designation of 26 Commercial IWC Facilities

Most of the 26 facilities that generate IWC wastewater are regulated as incinerators under RCRA. Very few boilers and industrial furnaces regulated under RCRA generate air pollution control wastewater, flue gas quench, or slag quench. There were no non-RCRA industrial waste combustors that generated IWC wastewater identified by EPA. Table 3-5 presents the RCRA designation of the 26 commercial facilities.

**Table 3-5. 1992 RCRA Designation of 26 Commercial IWC Facilities**

	<b>Total Thermal Units</b>
<b>Hazardous Waste Incinerator</b>	25
<b>Boiler and/or Industrial Furnace</b>	8
<b>Exempt under 40 CFR Part 264 Subpart O</b>	0

**3.4.2 *Waste Burned at 26 IWC Facilities***

The number of customers served by a facility varies greatly in this industry. Some facilities burn primarily waste generated on site and take very few waste shipments from facilities not under their corporate structure. Other facilities operate a strictly commercial operation, serving hundreds or thousands of customers on a regular basis. Table 3-6 presents the number of customers served by the 26 commercial facilities.

**Table 3-6. Number of Customers/Facilities Served in 1992 by 26 Commercial IWC Facilities**

	<b>Number of Customers</b>
<b>Minimum</b>	1
<b>Maximum</b>	4,000
<b>Mean</b>	807
<b>Median</b>	75
<b>Total</b>	27,452

**3.4.3 *Air Pollution Control Systems for 26 Commercial IWC Facilities***

The type of air pollution control system used by an IWC facility has a direct effect on the characteristics and quantity of the IWC wastewater generated by that facility. Table 3-7 presents the types of air pollution control systems in use at the 26 commercial facilities. Table 3-8 presents the

types of air pollutants for which add-on control systems are in operation for the 26 IWC facilities. Some of these systems do not generate any wastewater (e.g., a fabric filter for particulate removal). Other systems would generate wastewater (e.g., a packed tower scrubber with lime used for halogenated acid gas removal).

**Table 3-7. Types of Air Pollution Control Systems at 26 Commercial IWC Facilities**

<b>Type of Air Pollution Control System</b>	<b>Total Thermal Units</b>
<b>Spray Chamber Scrubber</b>	16
<b>Impingement Baffle Scrubber</b>	2
<b>Wet Cyclone (including multiclones)</b>	2
<b>Venturi Scrubber</b>	12
<b>Sieve Tray Tower</b>	2
<b>Packed Tower</b>	16
<b>Ionizing Wet Scrubber</b>	4
<b>Wet Electrostatic Precipitator</b>	3
<b>Fabric Filter</b>	11
<b>Dry Scrubber</b>	2
<b>Spray Dryer</b>	1
<b>Other (Includes: Demister; Dry Cyclone; Dry Electrostatic Precipitator; Horizontal Packed Absorber; Scrubber Quench Unit; Steam Atomization)</b>	14

Of the facilities that use water in their air pollution control systems, the chemicals added to the water and the types of water recirculation systems vary greatly by facility. The addition of chemicals to the water is dependent upon the purpose of the scrubbing system (e.g., no chemicals would be used to trap particulates in a cyclonic scrubber and sodium hydroxide would be used to remove halogenated acid gases in a packed tower scrubber.) The chemicals added to the scrubber

**Table 3-8. Air Pollutants for Which Add-On Control Systems are in Operation for 26 Commercial IWC Facilities**

<b>Air Pollutant</b>	<b>Total Thermal Units</b>
<b>None</b>	2
<b>Halogenated Acid Gases</b>	21
<b>Sulfur Compounds</b>	19
<b>Nitrogen Compounds</b>	7
<b>Particulates</b>	30
<b>Metals</b>	23
<b>Other (Organics)</b>	1

water would have a direct effect on the characteristics of the wastewater generated. Table 3-9 presents the types of scrubbing liquors in use at the 26 commercial IWC facilities.

**Table 3-9. Scrubbing Liquor Used in Air Pollution Control Systems of 26 Commercial IWC Facilities**

<b>Scrubbing Liquor</b>	<b>Total Thermal Units</b>
<b>None</b>	7
<b>Water With No Added Chemicals</b>	13
<b>Sodium Hydroxide</b>	17
<b>Lime Slurry</b>	8
<b>Other (Includes: Lime-Hydrated; Sodium Carbonate Solution; Sulfuric Acid)</b>	7

The type of water recirculation system used by a facility also has a direct effect on the amount of wastewater generated. If a facility operated a closed loop air pollution control system with no discharge, no wastewater would be generated. Alternately, a facility that did not recirculate its air pollution control system wastewater, would tend to generate a large quantity of wastewater. Table

3-10 presents the types of water recirculation systems.

**Table 3-10. Type of Water Recirculation System Used in Air Pollution Control Systems at the 26 Commercial IWC Facilities**

<b>Water Recirculation System</b>	<b>Total Thermal Units</b>
<b>None (once through)</b>	2
<b>Closed Loop (no discharge)</b>	7
<b>Recirculating with Intermittent Blowdown</b>	1
<b>Recirculating with Continuous Blowdown</b>	14

**3.5 SUMMARY INFORMATION ON 11 COMMERCIAL IWC FACILITIES WHICH GENERATE AND DISCHARGE IWC WASTEWATER**

Thirteen of the twenty-six facilities generate Industrial Waste Combustor wastewater but do not discharge the wastewater to a receiving stream or to a POTW. These facilities are considered "zero or alternative dischargers" and use a variety of methods to dispose of their wastewater. At these facilities: (1) wastewater is sent off site for treatment or disposal (four facilities); (2) wastewater is burned or evaporated on site (five facilities); (3) wastewater is sent to a surface impoundment on site (three facilities); and (4) wastewater is injected underground on site (one facility). Thus, EPA has identified only 13 facilities that were discharging Industrial Waste Combustor wastewater to a receiving stream or to a POTW in 1992. Of these 13 facilities, 2 facilities have either stopped accepting waste from off site for combustion or have closed their combustion operations since 1992. Eight of the eleven open facilities discharge their Industrial Waste Combustor wastewater to a receiving stream and three of the eleven facilities discharge their Industrial Waste Combustor wastewater to a POTW. These 11 facilities are found near the industries generating the wastes undergoing combustion.

The 11 open facilities identified by EPA operate a wide variety of combustion units. Four facilities operate rotary kilns and are regulated as incinerators under RCRA. Three facilities operate liquid injection incinerators and are regulated as incinerators under RCRA. Three facilities operate

furnaces and are regulated as BIFs under RCRA. One facility operates a liquid injection device and is regulated as a BIF under RCRA. And, one facility operates a combustion device that is not regulated as a BIF or as an incinerator under RCRA.

The 11 open facilities identified by EPA use a wide variety of air pollution control systems. The types of air pollution control systems in use are: fabric filters, spray chamber scrubbers, packed tower scrubbers, ionizing wet scrubbers, venturi scrubbers, dry scrubbers, dry cyclones, and wet electrostatic precipitators. Ten of the 11 open facilities use more than one of the air pollution control systems listed above. Six of the eleven facilities use a combination of wet and dry air pollution control systems. Four of the eleven facilities use only wet air pollution control systems. It is unknown what types of air pollution systems are used by two of the facilities.

### **3.6            *INDUSTRY SUBCATEGORIZATION***

Division of an industry into groupings entitled "subcategories" provides a mechanism for addressing variations between products, raw materials, processes, and other parameters which result in distinctly different effluent characteristics. Regulation of an industry by subcategory provides that each has a uniform set of effluent limitations which take into account technology achievability and economic impacts unique to that subcategory.

The factors considered in the regulation of the Industrial Waste Combustor Industry include:

- waste type received;
- type of combustion process;
- air pollution control used;
- nature of wastewater generated;
- facility size, age, and location;
- non-water quality impact characteristics; and
- treatment technologies and costs.

EPA evaluated these factors and determined that subcategorization is not required.

For most facilities in this industry, a wide variety of wastes are combusted. These facilities,

however, employ the same wastewater treatment technologies regardless of the specific type of waste being combusted in a given day.


EPA concluded that a number of factors did not provide an appropriate basis for subcategorization. The Agency concluded that the age of a facility should not be a basis for subcategorization because many older facilities have unilaterally improved or modified their treatment process over time. Facility size is also not a useful technical basis for subcategorization for the Industrial Waste Combustor Industry because wastes can be burned to the same level regardless of the facility size and has no significant relation to the quality or character of the wastewaters generated or treatment performance. Likewise, facility location is not a good basis for subcategorization; no consistent differences in wastewater treatment performance or costs exist because of geographical location. Non-water quality characteristics (waste treatment residuals and air emission effects) did not constitute a basis for subcategorization. The environmental effects associated with disposal of waste treatment residual or the transport of potentially hazardous wastewater are a result of individual facility practices. The Agency did not identify any consistent basis for these decisions that would support subcategorization. Treatment costs do not appear to be a basis for subcategorization because costs will vary and are dependent on the following waste stream variables: flow rates, waste quality, waste energy content, and pollutant loadings. Therefore, treatment costs were not used as a factor in determining subcategories.

EPA identified three factors with significance for potentially subcategorizing the Industrial Waste Combustor Industry: the type of waste received for treatment, the type of air pollution control system used by a facility, and the types of Industrial Waste Combustor wastewater sources (e.g., container wash water vs. air pollution control water).

A review of untreated Industrial Waste Combustor air pollution control system wastewater showed that there is some difference in the concentration of pollutants between solid and liquid waste combustion units. In particular, for nine of the 27 metals analyzed at six Industrial Waste Combustor facilities, the average concentration of a particular metal was higher in the water from facilities that burned solids (as well as liquids) than in facilities that burned liquids only. EPA believes that this difference is probably the result of two factors: the type of air pollution control employed by the facilities and the amount of wastewater generated. Specifically, the data reviewed by EPA showed

that two of the three facilities that burn liquid waste use dry scrubbing devices prior to using scrubbing devices which generate wastewater. One of these facilities uses a baghouse initially and the other uses a fabric filter. These dry scrubbers would remove some of the metals which would have ended up in the wastewater stream. In comparison, only one of the three facilities that burn solids uses a dry scrubbing device prior to using scrubber devices which generate wastewater. This facility uses an electrostatic precipitator initially. In addition, all three of the facilities that burn liquid waste do not recycle any of their wastewater for reuse in the scrubbing system following partial wastewater treatment. In comparison, two of the three facilities that burn solids recycle some of their partially treated wastewater for reuse in their scrubbing system. One of these facilities recycles 60 percent and the other recycles 82 percent. The reuse of partially treated wastewater would have the effect of reducing the wastewater discharge and increasing the concentration of metals in the recycled wastewater. Thus, it is difficult to assess whether there is in fact any significant difference in the concentrations of pollutants in wastewater from facilities burning solid versus liquid waste. This situation in general makes subcategorizing on this basis difficult. Therefore, EPA has concluded that available data do not support subcategorization either by the type of waste received for treatment or the type of air pollution control system used by a facility.

Based on analysis of the Industrial Waste Combustor Industry, EPA has determined that it should not subcategorize the Industrial Waste Combustors for purposes of determining appropriate limitations and standards.



## **SECTION 4**

### **WASTEWATER USE AND WASTEWATER CHARACTERIZATION**

In 1993, under authority of Section 308 of the Clean Water Act (CWA), the EPA distributed the "Waste Treatment Industry Phase II: Incinerators 1992 Screener Survey" and, subsequently, the "1994 Waste Treatment Industry Phase II: Incinerators Questionnaire" to facilities that EPA had identified as possible IWC facilities. Responses to the screener survey and questionnaire indicated that, in 1992, 13 IWC facilities operated commercially and discharged their IWC wastewater to a receiving stream or to a POTW. Of these 13 facilities, 2 facilities have either stopped accepting waste from off site for combustion or have closed their combustion operations since 1992. Thus, this section presents information on water use at only the remaining 11 facilities. This section also presents information on wastewater characteristics for the IWC facilities that were sampled by EPA and for some of those facilities that provided self-monitoring data.

#### **4.1            *WATER USE AND SOURCES OF WASTEWATER***

Approximately 861 million gallons of wastewater are generated and discharged annually at the 11 Industrial Waste Combustor facilities. EPA has identified the sources described below as contributing to wastewater discharges at Industrial Waste Combustor operations. Only air pollution control wastewater, flue gas quench, and slag quench, however, would be subject to the proposed effluent limitations and standards. Most of the wastewater generated by Industrial Waste Combustor operations result from these sources.

a.     Air Pollution Control System Wastewater. Particulate matter in the effluent gas stream of an Industrial Waste Combustor is removed by four main physical mechanisms (Handbook of Hazardous Waste Incineration, Brunner 1989). One mechanism is interception, which is the collision between a water droplet and a particle. Another method is gravitational force, which causes a particle to fall out of the direction of the streamline. The third mechanism is impingement, which causes a water particle to fall out of the streamline due to inertia. Finally, contraction and expansion of a gas stream allow particulate matter to be removed from the stream. Thus, removal of particulate matter can be accomplished with or without the use of water. Depending upon the type of waste being burned,

Industrial Waste Combustors may produce acid gases in the air pollution control system. In order to collect these acid gases, a caustic solution is generally used in a wet scrubbing system.

b. Flue Gas Quench Wastewater. Water is used to rapidly cool the gas emissions from combustion units. There are many types of air pollution control systems that are used to quench the gas emission from Industrial Waste Combustors. For example, in packed tower scrubbing systems, water enters from the top of the tower and gas enters from the bottom. Water droplets collect on the packing material and are rinsed off by the water stream entering the top of the tower (Handbook of Hazardous Waste Incineration, Brunner 1989). This rapidly cools the gas stream along with removing some particulate matter.

c. Slag Quench Wastewater. Water is used to cool molten material generated in slagging-type combustors.

d. Truck/Equipment Wash Water. Water is used to clean the inside of trucks and the equipment used for transporting wastes.

e. Container Wash Water. Water is used to clean the insides of waste containers.

f. Laboratory Wastewater. Water is used in on-site laboratories which characterize incoming waste streams and monitor on-site treatment performance.

g. Floor Washings and Other Wastewater from Process Area. This includes stormwater which comes in direct contact with the waste or waste handling and treatment areas. (Stormwater which does not come into contact with the wastes would not be subject to today's proposed limitations and standards. However, this stormwater is covered under the NPDES stormwater rule, 40 CFR 122.26).

## **4.2 WATER USE BY MODE OF DISCHARGE**

As mentioned in Section 4.1, approximately 861 million gallons of wastewater were discharged from 11 of the 84 commercial industrial combustors identified by EPA based on questionnaire responses. Eight of the 11 facilities discharge wastewater directly into a receiving stream or body of water. The other three facilities discharge indirectly by introducing their wastewater into a publicly-owned treatment works (POTW). Table 4-1 presents the total, average, and range of discharge flow rates for the eight direct and the three indirect discharging facilities. There are 71 facilities that either do not generate any Industrial Waste Combustor wastewater (58)

or do not discharge their wastewater to a receiving stream or POTW (13) as discussed previously. In general, the primary types of wastewater discharges from discharging facilities are: air pollution control system wastewater and flue gas quench. EPA is using the phrase "Industrial Waste Combustor wastewater" to refer to these three types of wastewaters only. Other types of wastewater generated as a result of combustor operations (e.g., truck washing water) are not considered "Industrial Waste Combustor wastewater".

This regulation applies to direct and indirect discharges only.

**Table 4-1. Amount of IWC Wastewater Discharged**

<b>Type of Discharger</b>	<b>Number of Facilities</b>	<b>Total Amount of IWC Wastewater Discharged (Gallons/Day)</b>	<b>Average Amount of IWC Wastewater Discharged (Gallons/Day)</b>	<b>Range In Amount of IWC Wastewater Discharged (Gallons/Day)</b>
<b>Direct</b>	8	2,110,799	263,850	14 to 1,000,286
<b>Indirect</b>	3	225,812	75,271	89 to 113,867

#### **4.3 WASTEWATER CHARACTERIZATION**

The Agency's five-day sampling program for this industry detected 21 pollutants (conventional, priority, and non-conventional) in waste streams at treatable levels at the facility that provides the basis for the BPT/BAT limits. Two additional pollutants were detected at treatable levels in the two other five-day sampling episodes: strontium and dichlorprop. The quantity of these pollutants currently being discharged from all facilities is difficult to assess. Limited monitoring data are available from facilities for the list of pollutants identified from the Agency's sampling program prior to commingling of these wastewaters with non-contaminated stormwater and other industrial wastewater before discharge. EPA used monitoring data supplied in the 1994 Waste Treatment Industry Phase II: Incinerators Questionnaire and data supplied in the Detailed Monitoring Questionnaire, wastewater permit information, and EPA sampling data to estimate raw waste and

current pollutant discharge levels. EPA used a "non-process wastewater" factor to quantify the amount of non-contaminated stormwater and other industrial process water in a facility's discharge. Section 4.4 of this document provides a more detailed description of "non-process wastewater" factors and their use. A facility's current discharge of treated Industrial Waste Combustor wastewater was calculated using the monitoring data supplied multiplied by the "non-process wastewater" factor.

#### 4.3.1 *Conventional Pollutants*

The most appropriate conventional pollutant parameters for characterizing untreated wastewater and wastewater discharged by IWC facilities are:

- Total Suspended Solids, and
- pH

Total solids in wastewater are defined as the residue remaining upon evaporation at just above the boiling point. Total suspended solids (TSS) is the portion of the total solids that can be filtered out of the solution using a 1 micron filter. Untreated wastewater TSS content is a function of the type and form of waste accepted for treatment (e.g., wastewater that results from the combustion of solid waste receipts would tend to have higher TSS values than waste received in a liquid form). TSS can also be due to treatment chemicals added to the wastewater as it is being generated (e.g., a caustic solution may be used in an IWC air pollution control system). The total solids are composed of matter which is settleable, in suspension or in solution, and can be removed in a variety of ways, such as during the metals precipitation process or by multimedia filtration, depending on a facility's operation. Untreated wastewater TSS levels found in the three five-day EPA sampling episodes are presented in Table 4-2.

The pH of a solution is a unitless measurement which represents the acidity or alkalinity of a wastewater stream, based on the dissociation of the acid or base in the solution into hydrogen ( $H^+$ ) or hydroxide ( $OH^-$ ) ions, respectively. Untreated wastewater pH is a function of the source of waste receipts as well as a function of the chemicals used in the air pollution control devices. This parameter can vary widely from facility to facility. Control of pH is necessary to achieve proper

removal of pollutants in the BPT/BAT treatment system (chemical precipitation).

As shown in Table 4-2, raw waste five-day biochemical oxygen demand and oil and grease are very low, ranging from 1 mg/l to 53 mg/l and from 5 mg/l (not detected) to 6 mg/l, respectively. Both of these parameters are indirect measures of the organic strength of wastewater. The wastewater sampled by EPA is generated from air pollution control systems and consists primarily of inorganic pollutants and very low concentrations of organic compounds because they are destroyed during combustion. (Furthermore, a more direct measure of the organic strength of the raw wastewater, total organic carbon, also shown in Table 4-2, only ranges from 10 mg/l (not detected) to 16 mg/l).

**Table 4-2. Range of Pollutant Influent Concentrations of the Pooled Daily Data from the Three Five-Day EPA Sampling Episodes (ug/l)**

<b>Pollutant</b>	<b>Mean</b>	<b>Minimum</b>	<b>Maximum</b>
<b>Aluminum</b>	897.6	13.6	2,538.0
<b>Ammonia as Nitrogen</b>	14,312.4	100.0	75,000.0
<b>Antimony</b>	268.2	7.8	958.8
<b>Arsenic</b>	166.4	4.6	827.2
<b>BOD<sub>5</sub></b>	9,960	1,000	53,000
<b>Boron</b>	1,604.6	918.0	3,760.0
<b>Cadmium</b>	312.2	1.8	2,616.0
<b>Calcium</b>	293,146.0	8,140.0	1,270,000.0
<b>Chemical Oxygen Demand</b>	343,140.0	67,000.0	1,036,000.0
<b>Chloride</b>	6,833,746.7	1,010,000.0	17,002,400.0
<b>Chromium</b>	127.2	5.8	529.2
<b>Copper</b>	1,786.7	8.5	10,554.0
<b>Fluoride</b>	82,620.5	16,500.0	360,000.0
<b>Iron</b>	2,904.1	149.0	10,838.0

**Table 4-2. (Continued)**

<b>Pollutant</b>	<b>Mean</b>	<b>Minimum</b>	<b>Maximum</b>
<b>Lead</b>	1,613.9	2.1	13,248.0
<b>Manganese</b>	114.7	4.0	388.0
<b>Mercury</b>	21.1	0.2	115.4
<b>Molybdenum</b>	336.7	4.6	1024.4
<b>Nitrate/Nitrite</b>	2,650.9	360.0	4,560.0
<b>Oil and Grease</b>	5,067	5,000	6,000
<b>Phosphorus</b>	32,480.0	3,210.0	225,800.0
<b>Potassium</b>	77,743.0	1,310.0	195,400.0
<b>Selenium</b>	102.8	2.3	429.2
<b>Silicon</b>	15,414.0	5,380.0	28,100.0
<b>Silver</b>	98.9	1.0	390.8
<b>Sodium</b>	3,443,333.3	6,400.0	11,250,600.0
<b>Strontium</b>	630.2	100.0	2,280.0
<b>Sulfur</b>	400,788.1	2,145.0	1,078,240.0
<b>Tin</b>	665.9	14.5	6,046.0
<b>Titanium</b>	777.7	5.0	4,474.2
<b>Total Dissolved Solids</b>	12,815,853.3	158,000.0	32,641,200.0
<b>Total Organic Carbon</b>	10,485	10,000	16,000
<b>Total Phosphorus</b>	1,088.6	10.0	4,460.0
<b>Total Sulfide</b>	28,261.3	1,000.0	103,200.0
<b>Total Suspended Solids</b>	122,553.3	4,000.0	522,000.0
<b>Zinc</b>	3,718.8	89.8	12,310.0
<b>Dichlorprop</b>	7.7	1.0	47.0
<b>MCP</b>	375.7	50.0	2,594.0

#### 4.3.2 *Priority and Non-Conventional Pollutants*

Table 4-2 below presents the range of the pooled daily pollutant influent concentration data from the three five-day EPA sampling episodes. This table includes treatment chemicals and nutrients found in IWC wastewater as well as pollutants to be removed from IWC wastewater. Appendix A presents this information for all pollutants analyzed in the three five-day EPA sampling episodes.

#### 4.4 *WASTEWATER POLLUTANT DISCHARGES*

As previously discussed, most of the effluent monitoring data received from facilities included non-IWC wastewater, such as other industrial waste streams and stormwater. Due to the lack of effluent data for IWC wastewater, the EPA had to develop various methods to estimate their current wastewater pollutant discharge. This section describes the various methodologies used to estimate current performance.

Most of the data supplied by the IWC facilities represented data that included non-IWC wastewater in the form of noncontaminated stormwater and other industrial stormwater prior to discharge. Therefore, the amount of a pollutant in the final effluent would be equal to the amount of the pollutant in the IWC process in addition to the amount in the non-IWC process, as shown in Equation 4.1.

$$C_T * F_{TOTAL} = C_{IWC} * F_{IWC} + C_{NON-IWC} * F_{NON-IWC} \quad (4.1)$$

where:

$C_T$  = Concentration of pollutant in the combined wastewater stream -- the concentration reported in the Incinerators Questionnaire, the Incinerators Detailed Monitoring Questionnaire, in POTW permits, in NPDES permits, or from EPA sampling program.

$F_{TOTAL}$  = Flowrate of total wastewater stream.

$C_{IWC}$  = Concentration of pollutant in the IWC (and other similar) wastewater

streams.

$F_{IWC}$  = Flowrate of IWC (and other similar) wastewater streams.

$C_{NON-IWC}$  = Concentration of pollutant in stormwater or non-contact wastewater streams.

$F_{NON-IWC}$  = Flowrate of stormwater or non-contact wastewater streams.

Stormwater or non-contact wastewater was assumed to be significantly lower in concentration in comparison to the IWC wastewater, and thus, the concentration of non-IWC wastewater streams was set equal to zero. This assumption simplifies Equation 4.1 as shown in Equation 4.2 below. Also, other industrial wastewater streams were assumed to have the same concentrations as the IWC wastewater streams.

$$C_T * F_{TOTAL} = C_{IWC} * F_{IWC} \quad (4.2)$$

For each facility, the EPA calculated the portion of IWC wastewater in the facility discharge and then calculated the IWC effluent concentration by solving Equation 4.2. Thus, the non-process wastewater factor is the flowrate of the total wastewater stream divided by the flowrate of the IWC (and other similar) wastewater stream.

The hierarchy of data used to estimate current loading concentrations was as follows:

- 1.) **Detailed Monitoring Questionnaire (DMQ) for the Incinerators Industry data from effluent sample locations for 1992.** The facility's long-term monitoring data was supplied in this questionnaire. Often, this data had to be corrected for inclusion of non-IWC wastewater streams using Equation 4.2 above.
- 2.) **Detailed Monitoring Report (DMR) data from effluent sample locations for 1992.** The facility's long-term monitoring data was supplied to EPA in this report. Often, this data had to be corrected for inclusion of non-IWC wastewater streams using Equation 4.2 above.
- 3.) **Waste Treatment Industry Phase II: Incinerators Questionnaire data from effluent sample locations for 1992.** The facility's year-long monitoring data was supplied in this questionnaire. Often, this data had to be corrected for inclusion of non-IWC wastewater streams

using Equation 4.2 above.

- 4.) **POTW or NPDES permit effluent concentrations for 1992.** Often, this data had to be corrected for inclusion of non-IWC wastewater streams using Equation 4.2 above.
- 5.) **EPA Five-Day Sampling Data for Three IWC facilities.** This data was used either for specific facilities sampled or averages were obtained to model facilities for which limited data was available.
- 6.) **Averages from Similar Facilities.** Data averages from similar facilities were used to model current loadings concentrations for facilities for which limited data was available.

The average, flow-weighted, estimated current discharge concentration for facilities in the IWC Industry is presented in Table 4-3.

**Table 4-3. IWC Industry Current Discharge Concentration**

<b>Pollutant</b>	<b>Discharge Concentration</b>	<b>Unit</b>
<b>CHEMICAL OXYGEN DEMAND</b>	145.2	mg/l
<b>TOTAL DISSOLVED SOLIDS</b>	10,430.0	mg/l
<b>TOTAL SUSPENDED SOLIDS</b>	30.6	mg/l
<b>ALUMINUM</b>	663.7	ug/l
<b>ANTIMONY</b>	559.0	ug/l
<b>ARSENIC</b>	217.7	ug/l
<b>BORON</b>	1,614.9	ug/l
<b>CADMIUM</b>	118.4	ug/l
<b>CHROMIUM</b>	4,276.9	ug/l
<b>COPPER</b>	944.2	ug/l
<b>IRON</b>	306.2	ug/l
<b>LEAD</b>	363.4	ug/l
<b>MANGANESE</b>	156.2	ug/l
<b>MERCURY</b>	10.6	ug/l
<b>MOLYBDENUM</b>	239.2	ug/l
<b>SELENIUM</b>	34.2	ug/l
<b>SILVER</b>	31.0	ug/l
<b>TIN</b>	88.4	ug/l
<b>TITANIUM</b>	79.6	ug/l
<b>ZINC</b>	385.6	ug/l

## **SECTION 5**

### **POLLUTANTS AND POLLUTANT PARAMETERS SELECTED FOR REGULATION**

As previously discussed, EPA evaluated wastewater sampling data that was collected for this industry in order to determine the pollutants that were further evaluated for the proposed regulation; the "pollutants of concern" for the Industrial Waste Combustor (IWC) Industry. This section discusses the pollutants and pollutant parameters detected in the Industrial Waste Combustor Industry.

#### **5.1**                    ***POLLUTANT PARAMETERS***

In addition to looking at specific pollutants in wastewater, EPA also relies on a number of other yardsticks for evaluating water quality. Some of these pollutant parameters, like total suspended solids (TSS), measure the conventional pollutants while others, like chemical oxygen demand (COD), are surrogates for non-conventional pollutants like ammonia. Traditionally, EPA has regulated conventional pollutants only in direct discharge permits and has not regulated discharges of conventional pollutants by facilities which are indirect dischargers.

The pollutant parameters proposed for regulation are a function of the characteristics of IWC wastewater. In the IWC wastewater, TSS, COD, and total dissolved solids (TDS) were the only pollutant parameters found at treatable concentrations. COD is not proposed for regulation because the technology selected for BPT/BAT will not effectively reduce COD levels. Also, TDS is not proposed for regulation because EPA's data showed that the treatment chemicals associated with the technology selected for BPT/BAT increase the TDS levels. EPA is proposing to regulate TSS. The level of TSS detected in IWC wastewater is important because of its correlation to treatment unit effectiveness.

#### **5.2**                    ***PRIORITY AND NON-CONVENTIONAL POLLUTANTS***

During sampling visits at the beginning of EPA's study of this industry, EPA analyzed for more than 450 priority, conventional, and non-conventional pollutants, listed in Appendix A. All

pollutants listed in Appendix A have EPA approved analytical methods, including RCRA and TSCA compounds. All of these pollutants were analyzed to characterize the full range of wastewater pollutants that are observed in the IWC Industry.

The Agency has not proposed to regulate any pollutant that was not detected in the sampling episodes at least three times at a significant concentration. Dioxins/furans were not selected for regulation because they were detected infrequently and at low concentrations. A further discussion of dioxins/furans in the IWC Industry appears below.

#### 5.2.1 *Dioxins/Furans in Industrial Waste Combustor Subcategory*

1. Background. Scientific research has identified 210 isomers of chlorinated dibenzo-p-dioxins (CDD) and chlorinated dibenzofurans (CDF). EPA attention has primarily focused on the 2,3,7,8-substituted congeners, a priority pollutant under the CWA, of which 2,3,7,8- TCDD and 2,3,7,8-TCDF are considered the most toxic. Evidence suggests that non-2,3,7,8-substituted congeners may not be as toxic. Some sources report that these non-2,3,7,8-substituted congeners may either be broken down or quickly eliminated by biological systems.

Dioxins and furans are formed as a by-product during many industrial and combustion activities, as well as during several other processes. The combustion activities that may create dioxins under certain conditions may include:

- Combustion of chlorinated compounds; including PCBs;
- Some metals are suspected to serve as catalysts in the formation of dioxin/furans;
- Metal processing and smelting;
- Petroleum refining;
- Chlorinated organic compound manufacturing.

2. Dioxin/Furans in Industrial Waste Combustor Wastewater. EPA identified a number of dioxin/furan compounds as present in the untreated wastewater streams at seven of the twelve facilities sampled (including grab and composite samples). Two of the facilities with dioxins detected in their Industrial Waste Combustor wastewater are now closed and no longer within the scope of

the proposed rule, so data from these facilities has not been further considered here. Thus, the following discussion relates to data from the ten remaining facilities (a total of 32 aqueous samples). Table 5-1 below summarizes the dioxin/furans detected in IWC wastewaters during the sampling program. Similar isomers that contain the 2,3,7,8 base were grouped together for this analysis due to their similar nature and characteristics.

**Table 5-1. Breakdown of Detected Dioxin/Furans During IWC Sampling Program**

<b>Dioxin/Furan</b>	<b>Toxic Equivalent Value (TEQ)</b>	<b>Universal Treatment Standards</b>	<b>Mean concentrations IWC Industry (detects only)</b>	<b>Total # of aqueous samples detected (out of 32)</b>	<b># of facilities detected (out of 10)</b>
2,3,7,8- TCDF	0.1	63,000 pg/l	17 pg/l	2	2
2,3,7,8- PeCDF	0.5	35,000 pg/l	93 pg/l	1	1
2,3,7,8- HxCDD	0.1	63,000 pg/l	68 pg/l	1	1
2,3,7,8- HxCDF	0.1	63,000 pg/l	249 pg/l	7	3
2,3,7,8- HpCDD	0.01	none	272 pg/l	5	4
2,3,7,8- HpCDF	0.01	none	939 pg/l	7	4
OCDD	0.001	none	971 pg/l	10	5
OCDF	0.001	none	6165 pg/l	6	4

It is important to note that EPA did not detect 2,3,7,8-TCDD (the most toxic congener) or 2,3,7,8-PeCDD in the raw wastewater samples collected. The dioxin/furans detected in untreated Industrial Waste Combustor wastewaters during EPA sampling at 10 sites show that these dioxin/furans were all detected at levels significantly (orders of magnitude) below the "Universal Treatment Standard" (40 CFR 268.48) level established under RCRA for dioxins/furans. In addition, low levels of HpCDD and OCDD (as indicated above) are generally considered pervasive in the environment and Universal Treatment Standards have not been set for these compounds. EPA identified no dioxin/furans in the Industrial Waste Combustor wastewater treated effluent.

CDD/CDFs are lipophilic and hydrophobic. As such, they are most often associated, or have an affinity for, suspended particulates in wastewater matrices. The more highly chlorinated isomers (i.e. the hepta- and octa- congeners) are the least volatile and more likely to be removed through particulate adsorption or filtration. While recommended treatment technologies differ according to the wastewater characteristics, there is some evidence that dioxins generally will bind with suspended solids and some sources (EPA RREL Treatability database) have asserted that these compounds may be removed by precipitation and filtration technologies.

Of the three week long sampling episodes conducted by EPA, the episode from which BAT/BPT limits were developed had no dioxins detected in the influent or effluent. At the other two facilities, HpCDD, HpCDF, OCDD, and OCDF were detected in the influent but none were detected in the effluent. Both facilities employed a combination of chemical precipitation and filtration that may have contributed to these removals.

The most toxic congener, 2,3,7,8- TCDD, was never detected in Industrial Waste Combustor scrubber water during the sampling program; and the CDD/CDFs detected were neither detected at most facilities sampled nor found in any significant quantity. The toxic equivalent (TEQ) values found in the Industrial Waste Combustor wastewater were low when compared to other dioxin sources in industry. The detected congeners were of the highly chlorinated type which may be treated by the methods recommended by this guideline (chemical precipitation, filtration). Also, since no dioxins were detected in the treated effluents at any of the three facilities EPA sampled, this may be evidence of dioxin removals.

Based on EPA's sampling program, no CDD/CDF met the criteria for wastewater regulation in the proposed rule.

The Agency has proposed CDD/CDF air emission limits of 0.2 ng/dscm from the stacks of hazardous waste burning incinerators (see 61 FR 17358 of 4/19/96 and 62 FR 24212 of 5/2/97), and believes that the incinerators have to operate with good combustion conditions to meet the proposed emission limits. In the final Land Disposal Restrictions (LDR) rulemaking that set treatment standards for CDD/CDF constituents in non-wastewater and wastewater from F032, the Agency has established (62 FR 26000, 5/12/97) incineration as the BDAT, after which the CDD/CDF constituents do not have to be analyzed in the effluent. EPA, therefore, considers that dioxins/furans will be

sufficiently destroyed given good combustion practices.

### **5.2.2      *Selection of Priority and Non-Conventional Pollutants for Regulation***

The priority and non-conventional pollutants proposed for regulation were determined by reviewing sampling data from the facility used for the proposed BPT/BAT technology. If a pollutant was not detected at all in the Sampling Program for the BPT/BAT facility, it was dropped from the analysis.

The initial pollutants of concern were the pollutants that were detected a minimum of three times in the BPT/BAT facility raw waste stream. EPA applied a minimum number of times (3) for detection as a rule of thumb so as to focus attention only on those pollutants likely to be present in wastewater at Industrial Waste Combustor facilities. Pollutants not detected at least three times were removed from the list of pollutants considered for regulation. Next, pollutants used as treatment chemicals and pollutants known to be nutrients in water were also removed from the list for further consideration. These pollutants are: ammonia as nitrogen, nitrate/nitrite, calcium, chloride, fluoride, phosphorus, potassium, silicon, sodium, sulfur, total phosphorus, and total sulfide. These pollutants are either added to the wastewater during treatment or are naturally present in the source water.

Additional pollutants were removed from the list of pollutants considered for regulation if the average of the influent concentrations (with non-detect values set at the detection limit) was below a treatable level in the BPT/BAT sampling episode. For most pollutants, the concentration was set at 10 times the method detection limit. For aluminum, the concentration was set at 5 times the method detection limit of 200ug/L because 200ug/L is a high method detection limit. Also, for lead, the concentration was set at 3 times the detection limit of 50ug/l due to the toxicity of lead in water. These pollutants are presented in Table 5-2.

Other pollutants were excluded from regulation because the technology option proposed was not effective in treating the pollutant. EPA applied the following test: if pollutant concentrations increase across the treatment system or the pollutant concentrations decrease by an insignificant amount, the pollutant was not considered effectively treated. These pollutants are listed in Table 5-3.

**Table 5-2. Pollutants Excluded from Regulation Due to the Concentration Detected for the IWC Industry**

<b>Pollutants</b>
BOD Hexavalent Chromium Barium Cobalt Lithium Magnesium Nickel Strontium Thallium Vanadium Bis(2-ethylhexyl)Phthalate N-Hexacosane N-Octacosane N-Triacontane

**Table 5-3. Pollutants Excluded from Regulation Due to Ineffective Treatment for the IWC Industry**

<b>Pollutants</b>
Boron Manganese MCP

Finally, pollutants were excluded from further consideration for regulation if they are indirectly controlled through regulation of other pollutants by the proposed regulations. These pollutants are listed in Table 5-4.

After evaluating all of these factors, the Agency selected 11 pollutants for regulation. The final list of pollutants to be regulated is presented in Table 5-5.

**Table 5-4. Pollutants Indirectly Controlled Through Regulation of Other Pollutants**

<b>Pollutants</b>
Aluminum Antimony Iron Molybdenum Selenium Tin

**Table 5-5. Pollutants Selected for Regulation for the IWC Industry**

<b>Pollutants</b>
Arsenic Cadmium Chromium Copper Lead Mercury pH Silver Titanium Total Suspended Solids Zinc

### **5.3            *SELECTION OF POLLUTANTS TO BE REGULATED FOR PSES AND PSNS***

Indirect dischargers in the IWC Industry send their wastewater streams to a POTW for further treatment, unlike direct dischargers, whose wastewater will receive no further treatment once it leaves their facility. Therefore, the levels of pollutants allowable in the wastewater of an indirect discharger are dependent upon: (1) whether a given pollutant “passes through” the POTW’s treatment system or (2) whether additional treatment provided by the POTW will result in removal of the pollutant to a level equivalent to that obtained through treatment by a direct discharger.

### 5.3.1 *Pass-Through Analysis Approach*

To establish PSES, EPA must first determine which of the IWC Industry pollutants of concern (identified earlier in this section) pass-through, interfere with, or are incompatible with the operation of POTWs (including interferences with sludge disposal practices). EPA determines pollutant pass-through by comparing the percentage removed by POTWs with the percentage removed by direct dischargers using BPT/BAT technology. A pollutant "passes through" POTWs when the average percentage removed by well-operated POTWs nationwide (those meeting secondary treatment requirements) is less than the percentage removed by IWC direct dischargers complying with BPT/BAT limitations for a given pollutant. EPA has assumed, for the purposes of this analysis and based upon the data received, that the untreated wastewater at indirect discharge facilities is not significantly different from direct discharge facilities.

This approach to the definition of pass-through analysis satisfies two competing objectives set by Congress: (1) that standards for indirect dischargers be equivalent to standards for direct dischargers and (2) that the treatment capability and performance of the POTW be recognized and taken into account in regulating the discharge of pollutants from indirect dischargers. Rather than compare the mass or concentration of pollutants discharged by the POTW with the mass or concentration of pollutants discharged by a BAT facility, EPA compares the percentage of the pollutants removed by the facility with the POTW removal. EPA takes this approach because a comparison of mass or concentration of pollutants in a POTW effluent with pollutants in a BAT facility's effluent would not take into account the mass of pollutants discharged to the POTW from non-industrial sources, nor the dilution of the pollutants in the POTW effluent to lower concentrations from the addition of large amounts of non-industrial wastewater.

### 5.3.2 *50-POTW Study Database*

For past effluent guidelines, a study of 50 well-operated POTWs was used for the pass-through analysis. This study is referred to as the "The Fate of Priority Pollutants in Publicly Owned Treatment Works", September 1982 [EPA 440/1-82/303]. Because the data collected for evaluating POTW removals included influent levels of pollutants that were close to the detection limit, the

POTW data were edited to eliminate influent levels less than 10 times the minimum level and the corresponding effluent values, except in the cases where none of the influent concentrations exceeded 10 times the minimum level. In the latter case, where no influent data exceeded 10 times the minimum level, the data were edited to eliminate influent values less than 5 times the minimum level. Further, where no influent data exceeded 5 times the minimum level, the data were edited to eliminate influent values less than 20 µg/l and the corresponding effluent values. These editing rules were used to allow for the possibility that low POTW removal simply reflected the low influent levels.

EPA then averaged the remaining influent data and also averaged the remaining effluent data from the 50-POTW database. The percent removals achieved for each pollutant was determined from these averaged influent and effluent levels. This percent removal was then compared to the percent removal for the BAT option treatment technology.

### **5.3.3        *RREL Treatability Database***

Due to the large number of pollutants considered for this industry, additional data from the EPA Risk Reduction Engineering Laboratory (RREL) Treatability Database were used to supplement the 50-POTW Study data. (The EPA Risk Reduction Engineering Laboratory is now called the National Risk Management Research Laboratory (NRMRL). The editing rules used for the POTW database needed to be modified due to the organization of the RREL database.

For each of the pollutants of concern not found in the 50-POTW database, data from the liquid waste portions of the RREL Treatability Database were obtained. These files were edited so that only treatment technology data for activated sludge (including secondary clarification), aerobic lagoons, and activated sludge (including secondary clarification) with filtration were used. These technologies are representative of typical POTW secondary treatment options. The files were further edited to include only information pertaining to domestic or industrial wastewater, unless only other types of wastewater data were available. Only full-scale or pilot-scale data were used; bench-scale data were edited out. Only data from a paper in a peer-reviewed journal or government report or database were retained; all lesser-quality references were not used. Additionally, the retained references were reviewed and non-applicable study data were accordingly eliminated. Because the database is organized into groupings of influent values, the influent editing rules used for the 50-

POTW Study database could not be applied here. From the remaining pollutant removal data, the average percent removal for each pollutant was calculated.

#### 5.3.4 *Final POTW Data Editing*

For each pollutant, the edited percent removals from the 50-POTW Study and RREL Treatability Database were compared. The final percent removal for each pollutant was selected based on a data hierarchy, which was related to the quality of the data source. This hierarchy was:

1. 50-POTW Study Data (10x NOMDL edit)
2. 50-POTW Study Data (5x NOMDL edit)
3. 50-POTW Study Data (20ug/l edit)
4. RREL Treatability Data (domestic wastewater only edit)
5. RREL Treatability Data (domestic and industrial wastewater edit).

The final POTW removals for the IWC Industry pollutants, determined via the data use hierarchy, are presented in Table 5-6.

**Table 5-6. Final POTW Removals for IWC Industry Pollutants**


<b>Pollutant</b>	<b>CAS Number</b>	<b>Removal Percent</b>	<b>Source of Data</b>
<b>Arsenic</b>	7440382	66	50-POTW - (20ug/l edit)
<b>Cadmium</b>	7440439	90	50-POTW - (10x NOMDL edit)
<b>Chromium</b>	7440473	82	50-POTW - (10x NOMDL edit)
<b>Copper</b>	7440508	90	50-POTW - (10x NOMDL edit)
<b>Lead</b>	7439921	85	50-POTW - (10x NOMDL edit)
<b>Mercury</b>	7439976	90	50-POTW - (10x NOMDL edit)
<b>Silver</b>	7440224	59	50-POTW - (20ug/l edit)
<b>Titanium</b>	7440326	79	RREL - (domestic wastewater edit)
<b>Zinc</b>	7440666	81	50-POTW - (10x NOMDL edit)

### 5.3.5 *Final Pass-Through Analysis Results*

For each IWC pollutant in each option, the daily removals were calculated using the BPT/BAT data. Then, the average overall BPT/BAT removal was calculated for each pollutant from the daily removals. The averaging of daily removals is appropriate for this industry as BPT/BAT treatment technologies typically have retention times of less than one day. For the final pass-through analysis, the final POTW removal data determined for each IWC pollutant was compared to the percent removal achieved for that pollutant using the BPT/BAT option treatment technologies. Of the nine pollutants regulated under BPT/BAT, all were found to pass through for Regulatory Options A and B and are proposed for PSES. The final pass through analysis results for the IWC Options are presented in Table 5-7.

**Table 5-7. Final Pass-Through Results for IWC Industry Options A and B**

Pollutant	Option Removal (Percent)		POTW Removal (Percent)	Final Pass-Through	
	A	B		A	B
Arsenic	99	98	66	YES	YES
Cadmium	94	98	90	YES	YES
Chromium	95	95	82	YES	YES
Copper	99	99	90	YES	YES
Lead	99	99	85	YES	YES
Mercury	91	97	90	YES	YES
Silver	91	98	59	YES	YES
Titanium	99	99	79	YES	YES
Zinc	99	99	81	YES	YES



## SECTION 6

### WASTEWATER TREATMENT TECHNOLOGIES

This section describes the technologies available for the treatment of wastewater generated by the 84 commercial facilities within the Industrial Waste Combustor (IWC) Industry. This section also presents an evaluation of performance data on treatment systems collected by EPA during field sampling programs and the rationale used in the development of the proposed regulatory options. Specifically, Section 6.1 describes the technologies used by commercial IWC facilities to treat air pollution control, flue gas quench, and ash/slag quench wastewaters, which are the only types of wastewater proposed for regulation. Section 6.2 describes technologies used by commercial IWC facilities for the treatment of wastewater generated as a result of IWC operations (e.g. container wash water and truck wash water) for which EPA is not proposing regulations. Section 6.3 lists technologies used by commercial IWC facilities for the treatment of wastewater generated as a result of other operations on-site (e.g. landfill leachate and sanitary water). Section 6.4 presents the EPA performance data on selected treatment technologies, as well as, the rationale used in selecting the treatment technologies for the regulatory options.

Of the 84 commercial IWC facilities, 39 facilities generate no wastewater. A breakdown of the types of wastewaters collected at the remaining 45 commercial IWC facilities which generate wastewater is as follows:

<u>Type of wastewater collected</u>	<u>Number of commercial IWC facilities</u>
IWC wastewaters only (air pollution control, ash/slag quench, flue gas quench)	8
wastewaters generated from IWC operations only (container, area, and truck wash waters)	7
other on-site wastewaters only (sanitary wastewater, leachates)	9
IWC wastewaters and wastewaters generated from IWC operations	15
IWC wastewaters, wastewaters generated from IWC operations, and other on-site wastewaters	3
wastewaters generated from IWC operations and other on-site wastewaters	3

As demonstrated above, only 26 of the 84 commercial IWC facilities generate IWC wastewaters and therefore, were considered to be within the scope of this proposed regulation.

## **6.1            *AVAILABLE BAT AND PSES TECHNOLOGIES***

Commercial IWC facilities use either physical/chemical treatment technology to treat IWC wastewaters or treatment and disposal methods that result in no discharge of IWC wastewaters.

Through its CWA Section 308 Questionnaire, EPA obtained information on nine different wastewater treatment technologies currently in use by the 26 commercial IWC facilities for the treatment of air pollution control, flue gas quench, and ash/slag quench wastewater. In addition, EPA collected other detailed information on available technologies from engineering plant visits to a number of IWC facilities. The data presented in Section 6.4 are based on these data collection activities.

### **6.1.1            *Physical/Chemical Treatment***

#### **6.1.1.1            *Equalization***

Wastewater generation rates at incinerators are sometimes variable due to variations in burn rates and system down times. To allow for the equalization of pollutant loadings and flow rates, IWC wastewaters may be collected in tanks or lined ponds prior to treatment. These are designed with sufficient capacity to hold the peak flows and thus dampen the variation in hydraulic and pollutant loads. Minimization of this variability increases the performance and reliability of downstream treatment systems, and can reduce the size of subsequent treatment by reducing the maximum flow rates and concentrations of pollutants that they will experience. Equalization also lowers the operating costs of associated treatment units by reducing instantaneous treatment capacity demand and by optimizing the amount of treatment chemicals required for a less erratic set of treatment variables. The EPA's Section 308 Questionnaire database identifies 12 facilities that use equalization technology as part of their treatment of IWC wastewaters.

Equalization systems consist of steel or fiberglass holding tanks or lined ponds that provide sufficient capacity to contain peak flow conditions and wastewater volumes of high pollutant loadings. Detention times can vary from a few hours to several days, with one day being a typical value. Some equalization systems contain mechanical mixing systems that enhance the equalization process.


A breakdown of equalization systems used is as follows:

<u>Equalization Type</u>	<u>Number of Units</u>
Unstirred	8
Mechanically stirred	4

A typical equalization system is shown in Figure 6-1.

#### **6.1.1.2 Neutralization or pH Control**

In the treatment of IWC wastewaters, neutralization or pH control systems are used in conjunction with certain chemical treatment processes, such as chemical precipitation, to adjust the pH of the wastewater to optimize process control. Acids, such as sulfuric acid or hydrochloric acid, are added to reduce pH, whereas, alkalis, such as sodium hydroxides, are added to raise pH values. Neutralization may be performed in a holding tank, rapid mix tank, or an equalization tank. Neutralization systems are widely used at IWC facilities for pH control in chemical precipitation systems. Chemicals, such as sodium hydroxide or lime, are frequently used in order to raise the pH of the wastewater to a range somewhere between 9 to 12 in order to optimize precipitation of metal compounds. Acids, such as hydrochloric acid, is also used in conjunction with ferric chloride for chemical precipitation. Neutralization systems at the end of a treatment system are typically designed to control the pH of the discharge to between 6 and 9. There are 16 neutralization systems in place among the commercial IWC facilities that use various caustic and/or alkalis to treat IWC wastewaters. A breakdown of these neutralization systems is as follows:



**Figure 6-1. Equalization**

<u>Type of Neutralization</u>	<u>Number of Units</u>
Caustic	5
Lime	1
Acid	3
Multiple chemicals	6
Other	1

Figure 6-2 presents a flow diagram for a typical neutralization system.

#### **6.1.1.3 Flocculation**

Flocculation is a treatment technology used to enhance sedimentation or filtration treatment. Flocculation precedes these processes and consists usually of a rapid mix tank, or in-line mixer and a flocculation tank. The waste stream is initially mixed while a flocculation chemical is added. Flocculants adhere readily to suspended solids and each other to facilitate gravity sedimentation or filtration. Coagulants can be added to reduce the electrostatic surface charges and enhance the formation of complex hydrous oxides. Coagulation allows for the formation of larger, heavier particles, or flocculants (which are usually formed in a flocculation chamber), that can settle faster. There are three different types of flocculants commonly used; inorganic electrolytes, natural organic polymers, and synthetic polyelectrolytes. The selection of the specific treatment chemical is highly dependent upon the characteristics and chemical properties of the contaminants. A rapid mix tank is usually designed for a detention time ranging from 15 seconds to several minutes. After mixing, the coagulated wastewater flows to a flocculation basin where slow mixing of the waste occurs. The slow mixing allows for the particles to agglomerate into heavier, more settleable solids. Mixing is provided either by mechanical paddle mixers or by diffused air. Flocculation basins are typically designed for a detention time of 15 to 60 minutes. There are seven flocculation systems used among the commercial IWC facilities used to treat IWC wastewaters.




Figure 6-2 Neutralization

#### 6.1.1.4 Gravity-Assisted Separation

Gravity-assisted separation is a simple, economical, and widely used method for the treatment of IWC wastewaters. There are 14 such systems in place at the commercial IWC facilities. Clarification systems remove suspended matter by allowing the wastewater to become quiescent. As a result, suspended matter, which is heavier than water, settles to the bottom, forming a sludge which can be removed. This process may take place in specially designed tanks, or in earthen ponds and basins. Sedimentation units at IWC facilities are typically used as either primary treatment options to remove suspended solids or following a chemical precipitation process.


Clarifiers may be rectangular, square, or circular in shape. In rectangular tanks, wastewater flows from one end of the tank to the other with settled sludge collected into a hopper located at one end of the tank. In circular tanks, flow enters from the center and flows towards the outside edge with sludge collected in a center hopper. Treated wastewater exits the clarifier by flowing over a weir located at the top of the clarifier. Sludge which accumulates in the bottom of the clarifiers is periodically removed and is typically stabilized and/or dewatered prior to disposal.

Flocculation systems are commonly used in conjunction with gravity assisted clarification systems in order to improve their solids removal efficiency. Some clarifiers are designed with a center well to introduce flocculants and allow for coagulation in order to improve removal efficiencies. A schematic of a typical clarification system using coagulation and flocculation is shown in Figure 6-3. The main design parameters used in designing a clarifier are the overflow rate, detention time and the side water depth. The overflow rate is the measure of the flow as a function of the surface area of the clarifier. Typical design parameters used for both primary and secondary clarifiers are presented below:

<u>Design Parameter</u>	<u>Primary</u>	<u>Secondary</u>
Overflow rate, gpd/sq ft	600-1,000	500-700
Detention time, min	90-150	90-150
Minimum Side water depth, ft	8	10

Source: ASCE/WEF, *Design of Municipal Wastewater Treatment Plants*, 1991.

There are three facilities that use corrugated plate interceptor technology. These systems include a series of small (approximately 2 inch square) inclined tubes in the clarification settling zone. The suspended matter must only travel a short distance, when settling or floating, before they reach



**Figure 6-3: Clarification System Incorporating Coagulation and Flocculation**

a surface of the tube. At the tubes' surface, the suspended matter further coagulate. Because of the enhanced removal mechanism, corrugated plate interceptor units can have much smaller settling chambers than standard clarifiers.


#### **6.1.1.5 Chemical Precipitation**

Chemical precipitation is used for the removal of metal compounds from wastewater. In the chemical precipitation process, soluble metallic ions and certain anions, which are found in IWC wastewaters, are converted to insoluble forms, which precipitate from the solution. Most metals are relatively insoluble as hydroxides, sulfides, or carbonates. Coagulation processes are used in conjunction with precipitation in order to facilitate removal by agglomeration of suspended and colloidal materials. The precipitated metals are subsequently removed from the wastewater stream by liquid filtration or clarification (or some other form of gravity assisted sedimentation). Other treatment processes such as equalization, chemical oxidation or reduction (e.g., hexavalent chromium reduction), precede the chemical precipitation process. The performance of the chemical precipitation process is affected by chemical interactions, temperature, pH, solubility of waste contaminants, and mixing effects. There are a total of nine chemical precipitation systems in use by the commercial IWC facilities to treat IWC wastewater.


Common precipitation chemicals used in the IWC industry include lime, sodium hydroxide, soda ash, sodium sulfide, and alum. Other chemicals used in the precipitation process for pH adjustment and/or coagulation include sulfuric and phosphoric acid, ferric chloride, and polyelectrolytes. Many facilities use, or have the means to use, a combination of these chemicals. Precipitation using sodium hydroxide or lime is the conventional method of removing metals from wastewater. However, sulfide precipitation is also frequently used instead of hydroxide precipitation in order to remove certain metal ions. Hydroxide precipitation is effective in removing such metals as antimony, arsenic, chromium, copper, lead, mercury, nickel, and zinc. Sulfide precipitation is more appropriate for removing mercury, lead, and silver. Carbonate precipitation, while not frequently used in the Incinerator industry, is another method of chemical precipitation and is used primarily to remove antimony and lead. Alum, another precipitant/coagulant agent infrequently used, forms aluminum hydroxides in wastewaters containing calcium or magnesium bicarbonate alkalinity.

Aluminum hydroxide is an insoluble gelatinous floc which settles slowly and entraps suspended materials. For metals such as arsenic and cadmium, coprecipitation with iron or aluminum is an effective treatment process.

Hydroxide precipitation using lime or sodium hydroxide is the most commonly used means of chemical precipitation in the Incinerator industry, and of these, lime is used more often than sodium hydroxide. The chief advantage of lime over caustic is its lower cost. However, lime is more difficult to handle and feed, as it must be slaked, slurried, and mixed, and can plug the feed system lines. Lime precipitation also produces a larger volume of sludge. The reaction mechanism for precipitation of a divalent metal using lime is shown below:



The reaction mechanism for precipitation of a divalent metal using sodium hydroxide is as follows:



In addition to the type of treatment chemical chosen, another important design factor in the chemical precipitation operation is pH. Metal hydroxides are amphoteric, meaning that they can react chemically as acids or bases. As such, their solubilities increase toward both lower and higher pH levels. Therefore, there is an optimum pH for precipitation for each metal, which corresponds to its point of minimum solubility. Another key consideration in a chemical precipitation application is the detention time in the sedimentation phase of the process, which is specific to the wastewater being treated and the desired effluent quality.

The first step of a chemical precipitation process is pH adjustment and the addition of coagulants. This process usually takes place in separate mixing and flocculation tanks. After mixing the wastewater with treatment chemicals, the resultant mixture is allowed to agglomerate in the flocculation tank which is slowly mixed by either mechanical means, such as mixers, or recirculation pumping. The wastewater then undergoes a separation/dewatering process such as clarification or

filtration, where the precipitated metals are removed from solution. In a clarification system, a flocculent, such as a polymer, is sometimes added to aid in the settling process. The resulting sludge from the clarifier or filter must be further treated, disposed, or recycled. A typical chemical precipitation system is shown in Figure 6-4.

#### **6.1.1.6 Stripping**

Stripping refers to the removal of pollutant compounds from a wastewater by the passage of air, steam, or other gas, through the liquid. The stripped volatile components are generally condensed and recovered for reuse, disposal, or allowed to be stripped into the atmosphere. If the pollutants are in sufficiently low concentrations, the gaseous phase can be emitted through a stack without treatment.

Air stripping is a process in which air is brought into contact with the liquid. During this contact, the volatile compounds move from the liquid to the gas stream. The process usually takes place in a stripping tower (as shown in Figure 6-5) which consists of a vertical shell filled with packing material to increase the surface area for gas-liquid contact. Usually, the liquid flows down through the stripping column and air passes upward in a counter-current fashion. Another orientation is called "crossflow", where the air is pulled through the sides of the tower along its entire length.

There is only one commercial IWC facility that use air stripping as a treatment option for the removal of excess treatment chemicals contained in its flue gas quench wastewater.

#### **6.1.1.7 Filtration**

Filtration is a method for separating solid particles from wastewaters through the use of a porous medium. The driving force in filtration is a pressure gradient, caused by gravity, centrifugal force, vacuum, or higher than atmospheric pressure. Filtration treatment processes can be used at IWC facilities to remove solids from wastewaters after a chemical precipitation treatment step, or can be used as the primary source of treatment. Filtration processes include a broad range of media and membrane separation technologies from sand filtration to ultrafiltration. To aid in removal, the filter medium may be precoated with a filtration aid such as ground cellulose or diatomaceous earth.





Figure 6-4. Chemical Precipitation System Design



**Figure 6-5. Typical Air Stripping System**

Commercial IWC facilities currently have the following types of filtration systems in operation to treat their IWC wastewaters:

<u>Type of Filtration System</u>	<u>Number of Units</u>
Sand	3
Granular multimedia	1
Fabric	1
Ultrafiltration	1


Dissolved compounds in IWC wastewaters can be pretreated by chemical precipitation processes to convert the compound to an insoluble solid particle before filtration. Polymers can be injected into the filter feed piping downstream of feed pumps to enhance flocculation of smaller flocs that may escape an upstream clarifier.

The following paragraphs describe each type of filtration system.

#### **6.1.1.7.1 Sand/Multimedia Filtration**

Granular bed filtration in the IWC industry is used primarily for achieving supplemental removal of residual suspended solids from the effluent of chemical treatment processes, or rarely, as the primary form of wastewater treatment. These filters can be operated either by gravity or in a pressure vessel. In granular bed filtration, the wastewater stream is sent through a bed containing one or more layers of different granular materials. The solids are retained in the voids between the media particles while the wastewater passes through the bed. Typical media used in granular bed filters include anthracite coal, sand, and garnet. These media can be used alone, such as in sand filtration, or in a multimedia combination. Multimedia filters are designed such that the individual layers of media remain fairly discrete. This is accomplished by selecting appropriate filter loading rates, media grain size, and bed density. Hydraulic loading rates for a multi-media filter is between 4 to 10 gpm/sq ft. A typical multimedia filter vessel is shown in Figure 6-6.

The complete filtration process involves two phases: filtration and backwashing. As the filter becomes filled with trapped solids, the efficiency of the filtration process falls off. Head loss is a measure of solids trapped in the filter. As the head loss across the filter bed increases to a limiting



**Figure 6-6: Multimedia Filtration**

value, the end of the filter run is reached and the filter must be backwashed to remove the suspended solids in the bed. During backwashing, the flow through the filter is reversed so that the solids trapped in the media are dislodged and can exit the filter. The bed may also be agitated with air to aid in solids removal. The backwash water is then recycled back into the wastewater feed stream.


#### **6.1.1.7.2 Fabric Filters**

Fabric filters consist of a vessel that contains a cloth or paper barrier through which the wastewater must pass. The suspended matter is screened by the fabric, and the effectiveness of the filter depends on the mesh size of the fabric. Fabric filters may either be backwashed, or built as disposable units.

For waters having less than 10 mg/l suspended solids, cartridge fabric filters may be cost effective. Cartridge filters have very low capital cost and can remove particles of one micron or larger in size. Using two-stage cartridge filters (coarse and fine) in series extends the life of the fine cartridge. Disposable or backwashable bag filters are also available and may be quite cost effective for certain applications. Typically, these fabric filters act as a pre-filter and are used to remove suspended solids prior to other filtrations systems in order to protect membranes and equipment and reduce solids fouling.

#### **6.1.1.7.3 Ultrafiltration**

Ultrafiltration uses a semi-permeable, microporous membrane, through which the wastewater is passed under pressure. Water and low molecular weight solutes, such as salts and surfactants, pass through the membrane and are removed as permeate. Emulsified oils and suspended solids are rejected by the membrane and removed with some of the wastewater as a concentrated liquid. The concentrate is recirculated through the membrane unit until the flow of permeate drops, while the permeate can either be discharged or passed along to another treatment unit. The concentrate is usually stored and held for further treatment or disposal. Several types of ultrafiltration membranes configurations are available: tubular, spiral wound, hollow fiber, and plate and frame. A typical ultrafiltration system is presented in Figure 6-7.




**Figure 6-7. Ultrafiltration System Diagram**

Ultrafiltration in the IWC industry is used for the treatment of metal-bearing wastewaters. It can remove substances with molecular weights greater than 500, including suspended solids, oil and grease, and complexed heavy metals. Ultrafiltration is used when the solute molecules are greater than ten times the size of the solvent molecules, and are less than one-half micron. The primary design consideration in ultrafiltration is the membrane selection. A membrane pore size is chosen based on the size of the contaminant particles targeted for removal. Other design parameters to be considered are the solids concentration, viscosity, and temperature of the feed stream, and the membrane permeability and thickness.

#### **6.1.1.8 Carbon Adsorption**

Granular activated carbon adsorption (GAC) is a physical separation process in which organic and inorganic materials are removed from wastewater by adsorption, attraction, and/or accumulation of the compounds on the surface of the carbon granules. While the primary removal mechanism is adsorption, the activated carbon also acts as a filter for additional pollutant removal. Adsorption capacities of 0.5 to 10 percent by weight are typical. Spent carbon can be regenerated thermally on site by processes such as wet-air oxidation or steam stripping. For smaller operations, spent carbon can be regenerated off site or sent for directly for disposal. Vendors of carbon typically, under contract, exchange spent carbon with fresh carbon.

Activated carbon systems usually consist of a vessel containing a bed of carbon (typically 4 to 12 feet in depth), whereby the wastewater is either passed upflow or downflow through the filter bed. A carbon adsorption vessel is shown in Figure 6-8. Carbon vessels are typically operated under pressure, however some designs use gravity beds. For smaller applications, GAC systems are also available in canister systems which can be readily changed-out and sent for either off-site regeneration or disposal. The key design parameter is the adsorption capacity of the GAC, which is a measure of the mass of contaminant adsorbed per unit mass of carbon, and is a function of the chemical compounds being removed, type of carbon used, and process and operating conditions. The volume of carbon required is based upon the COD of the wastewater to be treated and desired frequency of carbon change-outs. The vessel is typically designed for an empty bed contact time of 15 to 60 minutes. Non-polar, high molecular weight organics with low solubility are readily adsorbed using



**Figure 6-8. Granular Activated Carbon Adsorption**

GAC. Certain organic compounds have a competitive advantage for adsorption onto the GAC, which results in compounds being preferentially adsorbed or causing other less competitive compounds to be desorbed from the GAC. Most organic compounds and some metals typically found in IWC wastewaters are effectively removed using GAC. Two commercial IWC facility employs GAC for treatment of IWC wastewaters.

#### 6.1.1.9 Chromium Reduction


Chemical reduction processes involve a chemical reaction in which electrons are transferred from one chemical to another in order to reduce the chemical state of a contaminant. The main application of chemical reduction in IWC wastewater treatment is the reduction of hexavalent chromium to trivalent chromium. The reduction enables the trivalent chromium to be precipitated from solution in conjunction with other metallic salts. Sodium bisulfate is the reducing agents used by the one commercial IWC facility that incorporates reduction technology for treatment of its IWC wastewater.

Once the chromium has been reduced to the trivalent state, it can be further treated in a chemical precipitation process, where it is removed as a metal hydroxide or sulfide. A typical chromium reduction process is shown in Figure 6-9.

#### 6.1.2 Sludge Handling

Sludges are generated by a number of treatment technologies, including gravity-assisted separation and filtration. These sludges are further processed at IWC facilities using various methods. Listed below are the number of commercial IWC facilities which employ each type of sludge handling process.

<u>Type of Sludge Handling</u>	<u>Number of Units</u>
Sludge Slurrying	1
Vacuum Filtration	1
Pressure Filtration	7
Centrifuge	1
Dryer	1



**Figure 6-9. Chromium Reduction**

The following paragraphs describe each type of sludge handling system.

#### **6.1.2.1 Sludge Slurrying**

Sludge slurrying is the process of transporting sludge from one treatment process to another. It can only be applied to liquid sludges that can be pumped through a pipe under pressure. Only one commercial IWC facility utilizes a sludge slurry process.


#### **6.1.2.2 Vacuum Filtration**

A typical vacuum filtration unit is shown in Figure 6-10. Vacuum filtration provides more aggressive sludge drying by placing the sludge on a screen or mesh and drawing a vacuum through the screen, which draws the liquid out of the sludge. Often the screen is oriented on a cylindrical support, which rotates. The sludge is distributed over the cylinder as it rotates. As the screen rotates, the dried sludge is removed with a scraper, and collected in a hopper placed below the filtration unit. These units can dry sludges to approximately 30 to 50 percent solids. Only one commercial IWC facility utilizes vacuum filtration for sludge dewatering.


#### **6.1.2.3 Pressure Filtration**

The plate and frame pressure filtration system is the most common process used by the IWC industry to dewater sludges from physical/chemical treatment processes. Seven commercial IWC facilities use a plate and frame pressure filtration system to dewater sludge. Sludges generated by IWC wastewater treatment processes are typically 2 to 5 percent solids by weight. These sludges are then dewatered to a 30 to 50 percent solids by weight using a plate and frame filter. Sludges from treatment systems can be thickened by gravity or stabilized prior to dewatering, or may be processed directly with the plate and frame pressure filtration unit.

A pressure filter consists of a series of screens (see Figure 6-11) upon which the sludge is applied under pressure. A precoat material may be applied to the screens to aid in solids removal. The applied pressure forces the liquid through the screen, leaving the solids to accumulate behind the screen. Filtrate which passes through the screen media is typically recirculated back to the head of



**Figure 6-10. Vacuum Filtration**



**Figure 6-11: Plate and Frame Pressure Filtration System Diagram**

the on-site wastewater treatment plant. Screens (also referred to as plates) are held by frames placed side by side and held together with a vice-type mechanism. The unit processes sludge until all of the plates are filled with dry sludge as indicated by a marked rise in the application pressure. Afterwards, the vice holding the plates is loosened and the frames separated. Dried sludge is manually scraped from the plates and collected in a hopper for final disposal. The size of the filter and the number of plates utilized depends not only on the amount of solids produced by treatment processes, but also is highly dependent on the desired operational requirements for the filter (e.g., shifts per day). A plate and frame pressure filter can produce a sludge with a higher solids content than most other methods of sludge dewatering. Pressure filters offer operational flexibility since they are typically operated in a batch mode.

#### **6.1.2.4 Centrifuges**

Centrifuges use centripetal force to separate the liquid from the sludge solids. The sludge enters the top of a rapidly spinning cylinder where the solids are "thrown" to the outer wall of the vessel. The separated solids are continually removed through an orifice on the outer wall, and the liquid stream is collected at the bottom.

Because the unit is spinning rapidly, and sludge often contains abrasive materials, centrifuges often require a high level of maintenance. Centrifuges typically dry sludges to the range of 20 to 30 percent solids by weight. Only one commercial IWC facility utilizes a centrifuges for sludge dewatering.

#### **6.1.2.5 Dryer**

One commercial IWC facility employs a sludge dryer to remove the moisture from its sludge prior to disposal of the solid waste. The sludge dryer uses thermal energy derived from steam or electricity to evaporate the moisture from the sludge in a drying bed/tank.

### **6.1.3      *Zero Discharge Options***

Some IWC facilities use treatment and disposal practices that result in no discharge of IWC wastewaters to surface waters. These practices are described below.

#### **6.1.3.1      *Incineration***

Two commercial IWC facilities generate annual flow rates of 108,100 and 300,000 gallons and dispose of their IWC wastewater exclusively by incinerating them on site. Normally, these wastewater flows are minimal compared to the amount of fuel and/or waste the thermal unit handles, and as such, these IWC facilities find it cheaper to dispose of their wastewaters in this fashion rather than utilizing other disposal methods.

#### **6.1.3.2      *Off-Site Disposal***

Three commercial IWC facilities transport their wastewater off site to either another IWC facility's wastewater treatment system or to a Centralized Wastewater Treatment (CWT) facility for ultimate disposal. These three facilities generate annual flow rates of 18,250 gallons, 10,000 gallons, and 43 million gallons. A fourth facility with an annual flow rate of 4.865 million gallons sells their wastewater as oil well completion fluid.

#### **6.1.3.3      *Evaporation/Land Applied***

One commercial IWC facility with an annual flow rate of approximately 100 million gallons discharges its IWC wastewater into on-site surface impoundments as a means of ultimate disposal. There is no discharge to a receiving water from these impoundments. Rather, water is lost by evaporation.

### **6.2      *TREATMENT OPTIONS FOR OTHER WASTEWATERS GENERATED BY IWC OPERATIONS***

Commercial IWC facilities employ the same two treatment options (physical/chemical treatment or zero discharge) to treat other wastewaters generated as a result of IWC operations (see

Section 4). Most of the same treatment technologies are used to treat these secondary wastewaters as are being used to treat IWC wastewaters. The EPA's Section 308 Questionnaire obtained information on eight different technologies currently in use by 39 commercial IWC facilities for the treatment of various wash down waters, run-off from IWC areas, and laboratory wastewater. A breakdown of these treatment systems is shown below:

<u>Treatment technology</u>	<u>Number of commercial IWC facilities</u>
Equalization	8
Neutralization	9
Flocculation	6
Gravity Assisted Separation	8
Chemical Precipitation	6
Air Stripping	1
Carbon Adsorption	5
Chemical Oxidation	3
Sludge Handling	11

Each of the above treatment technologies, with the exception of chemical oxidation, has been previously described in Section 6.1. As for IWC wastewaters, the design and operation of these treatment systems to treat other wastewaters generated by IWC operations are the same. Since the amount of wastewater generated by other IWC operations is minimal as compared to IWC wastewater flow rates, these small flows are typically mixed with IWC wastewaters for treatment in the physical/chemical treatment system. Below is a description of the only new treatment technology listed above that was not described in the previous section: chemical oxidation.

#### **6.2.1      *Chemical Oxidation***

Chemical oxidation treatment processes may be used to remove ammonia, to reduce the concentration of residual organics, and to reduce the bacterial and viral content of wastewaters. IWC facilities that use chemical oxidation processes use them for the treatment of other out-of-scope wastewaters generated at these facilities, such as landfill leachate, storm water, groundwater, or sanitary wastewater. Both chlorine and ozone can be used to destroy some residual organics in


wastewater. When these chemicals are used for this purpose, disinfection of the wastewater is usually an added benefit. A further benefit of using ozone is the removal of color. Ozone can also be combined with hydrogen peroxide for removing organic compounds in contaminated wastewater. Oxidation is also used to convert pollutants to terminal end products or to intermediate products that are more readily biodegradable or more readily removed by adsorption. There are three commercial IWC facilities that use chemical oxidation units as part of their treatment process to treat secondary IWC wastewaters.

Chemical oxidation is a chemical reaction process in which one or more electrons are transferred from the chemical being oxidized to the chemical initiating the transfer (the oxidizing agent). The electron acceptor may be another element, including an oxygen molecule, or it may be a chemical species containing oxygen, such as hydrogen peroxide and chlorine dioxide or some other electron acceptor. This process is also effective in destroying cyanide and toxic organic compounds. Figure 6-12 illustrates one such chemical oxidation process. According to the Section 308 Questionnaire data, IWC facilities use chemical oxidation processes to treat organic pollutants and as a disinfectant. When treating organic wastes, these processes use oxidizing chemicals, such as hydrogen peroxide, or ozone. As a disinfection process, an oxidant (usually chlorine) is added to the wastewater in the form of either chlorine dioxide or sodium hypochlorite. Other disinfectant chemicals include ozone, peroxide, and calcium hypochlorite. Once the oxidant is mixed with the wastewater, sufficient detention time is allowed (usually 30 minutes) for the disinfecting reactions to occur.

### 6.2.2 *Zero Discharge Options*

Other IWC facilities use treatment and disposal practices that result in no discharge of their secondary IWC wastewaters to surface waters. A breakdown of the zero discharge options for secondary IWC wastewaters at commercial IWC facilities is as follows:

<u>Zero discharge option</u>	<u>Number of commercial IWC facilities</u>
Incineration	2
Off-site disposal	5



**Figure 6-12. Cyanide Destruction**

Evaporated/land applied	2
Recycled	3
Deep well disposal	2

Most of the above zero discharge options, with the exception of deep well disposal, have been described previously in section 6.1.3. Below is a description of the only new zero discharge option listed above that was not described in the previous section; deep well disposal.

#### **6.2.2.1 Deep Well Disposal**

Deep well disposal consists of pumping the wastewater into a disposal well which discharges the liquid into a deep aquifer. These aquifers do not typically contain potable water and commonly are brackish. These aquifers are thoroughly characterized to insure that they are not hydrogeologically connected to an aquifer which is or has the potential to be used for potable water. Characterization confirms the existence of impervious layers of rock above and below the aquifer in order to prevent the migration of pollutants.

### **6.3 OTHER ON-SITE WASTEWATER TREATMENT TECHNOLOGIES**

There are other treatment technologies used by commercial IWC facilities to treat other on-site wastewaters (leachates, sanitary wastewater). Some facilities may use one or more of the technologies described above for the treatment of these wastewaters. Four commercial IWC facilities use some form of biological treatment as the preferred method of treatment of leachates and other organic wastewaters. The biological treatment technologies used at these IWC facilities are listed below:

<u>Treatment technology</u>	<u>Number of Facilities</u>
Activated sludge	1
Trickling filter	1
PAC system (powdered activated carbon)	2

## **6.4            *TREATMENT PERFORMANCE AND DEVELOPMENT OF REGULATORY OPTIONS***

This section presents an evaluation of performance data on treatment systems collected by EPA during field sampling programs and the rationale used in the development of the proposed regulatory options.

### **6.4.1            *Performance of EPA Sampled Treatment Processes***

To collect data on potential BAT treatment technologies, Questionnaire responses were reviewed to identify candidate facilities that had well operated and designed wastewater treatment systems. EPA conducted site visits to 13 IWC facilities to evaluate treatment systems; based on these site visits, three facilities were selected for a five consecutive day sampling episode (Episode ID #s 4646, 4671, and 4733). At these facilities, EPA collected data on a variety of physical and chemical treatment processes. Technologies evaluated at the selected sampling facilities include hydroxide precipitation, sulfide precipitation, sedimentation, carbon adsorption, sand filtration and ultrafiltration. Table 6-1 presents a summary of the treatment technologies sampled during each EPA sampling episode. Summaries of the treatment system performance data collected by EPA during each of these sampling episodes are presented below.


#### **6.4.1.1            *Treatment Performance for Episode #4646***

EPA performed a week-long sampling program, episode # 4646. This facility was evaluated by EPA in order to obtain performance data on several treatment technologies installed at this facility including hydroxide precipitation, ferric chloride precipitation, and sand filtration. A flow diagram of the IWC wastewater treatment system sampled during episode # 4626 is presented in Figure 6-13. The wastewater treatment system used at this IWC facility treats wastewater from the air pollution control system (quench chamber run-down and packed tower wastewater) and the ionizing wet scrubber. The wastewater treatment system is comprised of two separate systems both of which were sampled by EPA. The primary system is part of the primary water circulation loop that serves the incinerator and consists of chromium reduction and hydroxide precipitation treatment followed by

Table 6-1. Description of IWC Sampling Episodes

Episode	Influent Sample Point	Effluent Sample Point	Description
4646	1+2	4	First-stage chemical precipitation using sodium hydroxide
	4	5	Second-stage chemical precipitation using ferric chloride
	5	6	Sand filtration
	1+2	6	Overall treatment system- first-stage chemical precipitation, second-stage chemical precipitation, and sand filter
4671	1	2	First-stage chemical precipitation using sodium hydroxide
	2	3	Second-stage chemical precipitation using sodium hydroxide and ultrafiltration
	1	3	Overall treatment system- first-stage chemical precipitation, second-stage chemical precipitation, and ultrafiltration
	1	2	Sulfide precipitation and Lancy filters
4733	2	4	Carbon adsorption system
	1	4	Overall treatment system- sulfide precipitation, Lancy filters and carbon adsorption system

Figure 6-13. EPA Sampling Episode 4646 - IWC Wastewater Treatment System Block Flow Diagram with Sampling Locations



sedimentation. Only the precipitation portion of the primary system was sampled by EPA. Blowdown from the primary loop is treated in the secondary system. Treatment in the secondary loop consists of precipitation using ferric chloride followed by sedimentation and sand filtration. Table 6-2 presents a summary of percent removal data collected at episode #4646 for the performance of the entire treatment system, both the primary and secondary system, as well as the primary system, secondary system, and sand filter separately. Percent removal efficiencies for the processes were calculated by first obtaining an average concentration based upon the daily sampling results for each sample collection location (influent and effluent point to the treatment process). Next, the percent removal efficiency of the system was calculated using the following equation:

$$\text{Percent Removal} = \frac{[\text{Concentration Influent} - \text{Concentration Effluent}]}{\text{Concentration Influent}} \times 100$$

Negative percent removals for a treatment process were reported on the table as "0.0" percent removals.

The treatment efficiency of the primary system was assessed using the data obtained from sampling points 01, 02, and 04 (see Figure 6-13). Influent concentration data was obtained using a flow-weighted average for sample points 01 and 02. Effluent from the primary treatment system was represented by sample point 04. As demonstrated on the Table 6-2, the primary treatment system experienced good overall removals for TSS (90.9 percent). COD was removed at 70.9 percent, whereas, no removal was observed for TDS. Many of the metals observed in the influent were removed to high levels; these include aluminum, cadmium, chromium, copper, iron, lead, tin, titanium, and zinc. Other metals also with limited removals include manganese (66.5 percent), mercury (63.9 percent), silver (40.3 percent), and strontium (19.7 percent). Poor removal efficiencies were observed for in the primary system for antimony, arsenic, boron, molybdenum, and selenium.

The treatment efficiency of the secondary system was assessed using the data obtained from sampling points 04 and 05 (see Figure 6-13). Influent concentration data to the secondary system was obtained using sampling point 04 which is also the effluent from the primary system. Effluent from the secondary treatment system was represented by sample point 05. As demonstrated on the

Table 6-2. Treatment Technology Performance for Facility 4646

Pollutant of Interest	CAS #	First Stage Chemical Precipitation Sample Points 1+2 to 4						Second Stage Chemical Precipitation Sample Points 4 to 5					
		DL	Influent		Effluent	% Removal	DL	sp	Influent		Effluent	% Removal	
			sp	Conc. (ug/l)					sp	Conc. (ug/l)			
<b>Conventional</b>													
TSS	C-009	4,000	01+02	122,560	04	11,200	4,000	04	11,200	05	13,400	0.0	0.0
<b>Non-Conventional</b>													
COD	C-004	5,000	01+02	535,920	04	156,200	5,000	04	156,200	05	238,800	0.0	0.0
TDS	C-010		01+02	30,694,160	04	50,320,000	0.0	04	50,320,000	05	36,910,000	26.6	26.6
<b>Metals</b>													
Aluminum	7429905	200	01+02	1,104	04	170	84.6	04	170	05	197	0.0	0.0
Antimony	7440360	20.0	01+02	672	04	1,026	0.0	04	1,026	05	381	62.9	62.9
Arsenic	7440382	10.0	01+02	475	04	494	0.0	04	494	05	8.8	98.2	98.2
Boron	7440428	100	01+02	1,280	04	1,744	0.0	04	1,744	05	1,705	2.2	2.2
Cadmium	7440439	5.0	01+02	929	04	174	81.2	04	174	05	47.2	72.9	72.9
Chromium	7440473	10.0	01+02	220	04	53.4	75.8	04	53.4	05	ND	81.3	81.3
Copper	7440508	25.0	01+02	5,228	04	321	93.9	04	321	05	18.8	94.2	94.2
Iron	7439896	100	01+02	7,066	04	254	96.4	04	254	05	1,994	0.0	0.0
Lead	7439921	50.0	01+02	4,691	04	117	97.5	04	117	05	47.7	59.1	59.1
Manganese	7439976	15.0	01+02	228	04	76.6	66.5	04	76.6	05	517	0.0	0.0
Mercury	7439987	0.2	01+02	59.2	04	21.4	63.9	04	21.4	05	2.6	87.7	87.7
Molybdenum	7439987	10.0	01+02	936	04	1,137	0.0	04	1,137	05	578	49.1	49.1
Selenium	7782492	5.0	01+02	240	04	263	0.0	04	263	05	49.6	81.1	81.1
Silver	7440224	10.0	01+02	283	04	169	40.3	04	169	05	9.5	94.4	94.4
Strontium	7440246	100	01+02	408	04	328	19.7	04	328	05	689	0.0	0.0
Tin	7440315	30.0	01+02	1,882	04	45.9	97.6	04	45.9	05	33.0	28.2	28.2
Titanium	7440326	5.0	01+02	2,116	04	32.9	98.4	04	32.9	05	3.9	88.2	88.2
Zinc	7440666	20.0	01+02	9,456	04	209	97.8	04	209	05	121	42.2	42.2
<b>Pesticides/Herbicides</b>													
Dichloroprop	120365	1.0	01+02	3.1	04	NS	NS	04	NS	05	NS	NS	NS
MCPP	7085190	50.0	01+02	1,027	04	NS	NS	04	NS	05	NS	NS	NS

Negative percent removal are recorded as 0.0.

NS: Not Sampled

ND: Non-detect

DL: Specific detection limits of sample when there is a non-detect, otherwise it is the method detection limitSP: Sample point.

Table 6-2 con't. Treatment Technology Performance for Facility 4646

Pollutant of Interest	CAS #	Sand Filtration Sample Points 5 to 6						Entire Treatment System Sample Points 1+2 to 6					
		DL	sp	Influent Conc. (ug/l)	Effluent Conc. (ug/l)	% Removal	DL	sp	Influent Conc. (ug/l)	Effluent Conc. (ug/l)	% Removal	DL	sp
Conventional													
TSS	C-009	4,000	05	13,400	5,500	59.0	4,000	01+02	122,560	5,500			
Non-Conventional													
COD	C-004	5,000	05	238,800	257,900	0.0	5,000	01+02	535,920	257,900			
TDS	C-010		05	36,910,000	38,150,000	0.0		01+02	30,694,160	38,150,000			
Metals													
Aluminum	7429905	200	05	197	160	18.4	200	01+02	1,104	160			
Antimony	7440360	20.0	05	381	346	9.3	20.0	01+02	672	346			
Arsenic	7440382	10.0	05	8.8	8.1	8.1	10.0	01+02	475	8.1			
Boron	7440428	100	05	1,705	1,731	0.0	100	01+02	1,280	1,731			
Cadmium	7440439	5.0	05	47.2	19.9	57.7	5.0	01+02	929	19.9			
Chromium	7440473	10.0	05	ND	ND	0.0	10.0	01+02	220	ND			
Copper	7440508	25.0	05	18.8	10.1	46.1	25.0	01+02	5,228	10.1			
Iron	7439896	100	05	1,994	128	93.6	100	01+02	7,066	128			
Lead	7439921	46.8	05	47.7	ND	1.8	46.8	01+02	4,691	ND			
Manganese	7439965	15.0	05	517	545	0.0	15.0	01+02	228	545			
Mercury	7439976	2.0	05	2.6	ND	24.2	2.0	01+02	59.2	ND			
Molybdenum	7439987	10.0	05	578	580	0.0	10.0	01+02	936	580			
Selenium	7782492	5.0	05	49.6	26.0	47.5	5.0	01+02	240	26.0			
Silver	7440224	5.0	05	9.5	ND	47.3	5.0	01+02	283	ND			
Strontium	7440246	100	05	689	674	2.1	100	01+02	408	674			
Tin	7440315	30.0	05	33.0	31.5	4.5	30.0	01+02	1,882	31.5			
Titanium	7440326	5.0	05	3.9	6.8	0.0	5.0	01+02	2,116	6.8			
Zinc	7440666	20.0	05	121	24.2	80.0	20.0	01+02	9,456	24.2			
Pesticides/Herbicides													
Dichloroprop	120365	1.0	05	NS	ND	NS	1.0	01+02	3.1	ND			
MCPp	7085190	50.0	05	NS	1,482	NS	50.0	01+02	1,027	1,482			

Negative percent removal are recorded as 0.0.

NS: Not Sampled

ND: Non-detect

DL: Specific detection limits of sample when there is a non-detect, otherwise it is the method detection limit

SP: Sample point.

Table 6-2, the secondary treatment system experienced no additional removals for TSS or COD. As in the primary system, no removal was observed for TDS. For those metals for which there was little or no removal in the primary system, improved removals were generally observed in the second system. These metals include antimony (62.9 percent), arsenic (98.2 percent), selenium (81.1 percent), and silver (94.4 percent). Other metals for which adequate removals were observed in the primary system also experienced additional removals in the secondary system. The data show the following removals: cadmium (72.9 percent), chromium (81.3 percent), copper (94.2 percent), mercury (87.7 percent), and titanium (88.2 percent).

The treatment efficiency of the sand filter was evaluated using the data obtained from sampling points 05 and 06 (see Figure 6-13). Influent concentration data was obtained using sample point 05 which represents the discharge from the secondary treatment system. Effluent from the sand filter, as well as, the overall effluent from the treatment process was represented by sample point 06. As demonstrated on the Table 6-2, the treatment system achieved a removal rate for TSS of 59.0 percent. No removals were observed for COD or TDS. Additional metals were removed by the sand filter including cadmium, copper, iron, selenium, silver, and zinc. Limited additional removals were also observed for aluminum and mercury.

The treatment efficiency of the entire treatment system was evaluated using the data obtained from sampling points 01, 02, and 06 (see Figure 6-13). Influent concentration data was obtained using a flow-weighted average for sample points 01 and 02. Effluent from the treatment system was represented by sample point 06. As demonstrated on the Table 6-2, the treatment system achieved good overall removal for TSS (95.5 percent). COD was removed at 51.9 percent, whereas, no removal was observed for TDS. Many of the metals observed in the influent were removed to levels exceeding 95 percent removal. These include arsenic, cadmium, chromium, copper, iron, lead, mercury, silver, tin, titanium, and zinc. Other metals also with high removals include aluminum (85.5 percent) and selenium (89.1 percent). Overall poor removal efficiencies were observed for antimony (48.5 percent) and molybdenum (38.0 percent). No removals were observed for the treatment system for boron, manganese, and strontium. Dichloroprop, a pesticide parameter, was detected in the influent in low levels and was not detected in the effluent. MCPP did not experience any removal through the treatment system.

#### 6.4.1.2 Treatment Performance for Episode #4671

EPA performed a week-long sampling program, episode #4671. This facility was evaluated by EPA to obtain performance data on various treatment units which are in operation at this facility, including a combination sulfide and hydroxide precipitation process, conventional hydroxide precipitation, and ultrafiltration. A flow diagram of the IWC wastewater treatment system sampled during episode # 4671 is presented in Figure 6-14. The wastewater treatment system used at this IWC facility treats wastewater from the air pollution control system. The air pollution control system consists of a quench tank, packed tower, and a venturi scrubber. The wastewater treatment system is comprised of two separate systems both of which were sampled by EPA. The primary system is part of the primary water circulation loop that serves the incinerator. Treatment processes for the primary system consists of sulfide precipitation using ferrous sulfate followed by hydroxide precipitation using sodium hydroxide and lime and then followed by sedimentation. The facility treats the discharge from the primary loop in the secondary system. Treatment in the secondary loop consists of hydroxide precipitation using sodium hydroxide followed by sedimentation and ultrafiltration. Table 6-3 presents a summary of percent removal data collected at episode #4671 for the performance of the entire treatment system, both the primary and secondary system, and for the primary system only.

The treatment efficiency of the primary treatment system was evaluated using the data obtained from sampling points 01 and 02 (see Figure 6-14). Influent concentration data for the primary system was obtained using sample point 01. Effluent from the primary treatment system was represented by sample point 02. As demonstrated on Table 6-3, the primary treatment system removal rate for TSS was 70.6 percent. COD was removed at 12.3 percent, whereas, TDS was removed at 7.8 percent. Metals with high removal rates in the primary system include: aluminum (83.1 percent), chromium (97.4 percent), copper (72.0 percent), iron (93.4 percent), lead (90.4 percent), and titanium (95.1 percent). The system achieved limited removals for other metals through the primary system. These include boron, cadmium, manganese, mercury, tin, and zinc. Poor to no removals were observed for antimony, arsenic, molybdenum, silver, and strontium. However, influent concentrations to the primary treatment system for some metals, such as arsenic, cadmium,

Figure 6-14. EPA Sampling Episode 4671 - IWC Wastewater Treatment System Block Flow Diagram with Sampling Locations




Table 6-3. Treatment Technology Performance for Facility 4671

Pollutant of Interest	CAS #	First Stage Chemical Precipitation Sample Points 1 to 2					Second Stage Chemical Precipitation Sample Points 2 to 3						
		DL	sp	Influent Conc. (ug/l)	sp	Effluent Conc. (ug/l)	% Removal	DL	sp	Influent Conc. (ug/l)	sp	Effluent Conc. (ug/l)	% Removal
Conventional													
TSS	C-009	4,000	01	241,100	02	70,900	70.6	4,000	02	70,900	03	13,800	80.5
Non-Conventional													
COD	C-004	5,000	01	259,400	02	227,600	12.3	5,000	02	227,600	03	154,800	32.0
TDS	C-010		01	7,481,000	02	6,896,000	7.8		02	6,896,000	03	6,560,000	4.9
Metals													
Aluminum	7429905	200	01	1,575	02	266	83.1	6.5	02	266	03	ND	97.6
Antimony	7440360	20.0	01	110	02	107	2.5	20.0	02	107	03	94.2	12.2
Arsenic	7440382	10.0	01	19.2	02	19.9	0.0	10.0	02	19.9	03	25.6	0.0
Boron	7440428	100	01	1,723	02	1,219	29.2	100	02	1,219	03	1,069	12.3
Cadmium	7440439	5.0	01	4.2	02	2.4	43.1	5.0	02	2.4	03	0.4	83.6
Chromium	7440473	10.0	01	124	02	3.2	97.4	10.0	02	3.2	03	1.0	67.7
Copper	7440508	25.0	01	121	02	33.8	72.0	25.0	02	33.8	03	18.8	44.4
Iron	7439896	100	01	1,217	02	79.8	93.4	100	02	79.8	03	50.1	37.1
Lead	7439921	50.0	01	149	02	14.3	90.4	1.5	02	14.3	03	ND	89.5
Manganese	7439965	15.0	01	107	02	74.3	30.5	15.0	02	74.3	03	2.3	96.9
Mercury	7439976	0.2	01	0.7	02	0.4	33.8	0.2	02	0.4	03	ND	54.5
Molybdenum	7439987	10.0	01	69.7	02	66.6	4.5	10.0	02	66.6	03	59.5	10.6
Selenium	7782492	9.7	01	ND	02	14.0	0.0	11.5	02	14.0	03	ND	17.6
Silver	7440224	10.0	01	5.7	02	9.1	0.0	10.0	02	9.1	03	2.0	77.7
Strontium	7440246	100	01	1,382	02	1,582	0.0	100	02	1,582	03	1,315	16.8
Tin	7440315	30.0	01	49.5	02	39.0	21.2	28.3	02	39.0	03	ND	27.4
Titanium	7440326	10.0	01	206	02	ND	95.1	10.0	02	ND	03	ND	0.0
Zinc	7440666	20.0	01	1,598	02	813	49.1	20.0	02	813	03	239	70.7
Pesticides/Herbicides													
Dichloroprop	120365	1.0	01	ND	02	NS	NS	1.0	02	NS	03	ND	NS
MCP	7085190	50.0	01	ND	02	NS	NS	50.0	02	NS	03	ND	NS

Negative percent removal are recorded as 0.0.

NS: Not Sampled

ND: Non-detect

DL: Specific detection limits of sample when there is a non-detect, otherwise it is the method detection limit

SP: Sample point.

Table 6-3 con't. Treatment Technology Performance for Facility 4671

Pollutant of Interest	CAS #	Entire Treatment System Sample Points 1 to 3					
		DL	Influent		Effluent		% Removal
			sp	Conc. (ug/l)	sp	Conc. (ug/l)	
<b>Conventional</b>							
TSS	C-009	4,000	01	241,100	03	13,800	94.3
<b>Non-Conventional</b>							
COD	C-004	5,000	01	259,400	03	154,800	40.3
TDS	C-010		01	7,481,000	03	6,560,000	12.3
<b>Metals</b>							
Aluminum	7429905	6.5	01	1,575	03	ND	99.6
Antimony	7440360	20.0	01	110	03	94.2	14.4
Arsenic	7440382	10.0	01	19.2	03	25.6	0.0
Boron	7440428	100	01	1,723	03	1,069	37.9
Cadmium	7440439	5.0	01	4.2	03	0.4	90.7
Chromium	7440473	10.0	01	124	03	1.0	99.2
Copper	7440508	25.0	01	121	03	18.8	84.5
Iron	7439896	100	01	1,217	03	50.1	95.9
Lead	7439921	1.5	01	149	03	ND	99.0
Manganese	7439965	15.0	01	107	03	2.3	97.8
Mercury	7439976	0.2	01	0.7	03	ND	69.9
Molybdenum	7439987	10.0	01	69.7	03	59.5	14.6
Selenium	7782492	9.7	01	ND	03	ND	0.0
		/11.5					
Silver	7440224	10.0	01	5.7	03	2.0	64.1
Strontium	7440246	100	01	1,382	03	1,315	4.8
Tin	7440315	28.3	01	49.5	03	ND	42.8
Titanium	7440326	10.0	01	206	03	ND	95.1
Zinc	7440666	20.0	01	1,598	03	239	85.1
<b>Pesticides/Herbicides</b>							
Dichloroprop	120365	1.0	01	ND	03	ND	0.0
MCPP	7085190	50.0	01	ND	03	ND	0.0

Negative percent removal are recorded as 0.0.

NS: Not Sampled

ND: Non-detect

DL: Specific detection limits of sample when there is a non-detect, otherwise it is the method detection limit

SP: Sample point.

silver, and zinc, were low or not detected. Therefore, the influent concentrations for these parameters are close to the treatability levels using chemical precipitation, making it difficult to achieve additional removals for these pollutants. For example, cadmium was found in the influent and effluent of the primary treatment system at concentrations of 4.2 ug/l and 2.4 ug/l, respectively. This resulted in a percent removal of only 43.1 percent. Therefore, the low percent removal efficiency is a function of the low influent concentration (near treatability levels) and not indicative of poor performance.

The treatment efficiency of the secondary treatment system was evaluated using the data obtained from sampling points 02 and 03 (see Figure 6-14). Influent concentration data to the secondary system was obtained using sample point 02, which is the effluent from the primary system. Effluent from the secondary treatment system was represented by sample point 03. As demonstrated on the Table 6-3, the secondary treatment system removal rate for TSS was 80.5 percent. COD was removed at 32.0 percent, whereas, TDS was removed at 4.9 percent. Metals with high removal rates or removed to non-detectable levels in the secondary system include; aluminum, cadmium, chromium, lead, manganese, mercury, silver, tin, and zinc. Limited additional removals were observed for copper and iron. Poor removals were observed in the secondary system for antimony, boron, molybdenum, and strontium.

The treatment efficiency of the entire treatment system, both primary and secondary treatment system, was evaluated using the data obtained from sampling points 01 and 03 (see Figure 6-14). Influent concentration data was obtained using sample point 01. Effluent from the entire treatment system was represented by sample point 03. As demonstrated on the Table 6-3, the treatment system achieved good overall removals for TSS (94.3 percent). COD was removed at 40.3 percent, whereas, TDS was removed at 12.3 percent. Selenium, dichloroprop, and MCPP were not detected in the influent or effluent. Many of the metals observed in the influent were removed to levels exceeding 95 percent removal; these include aluminum, chromium, iron, lead, manganese, and titanium. Other metals also with high removals or removed to non-detectable levels include cadmium (90.7 percent), copper (84.5 percent), mercury (69.9 percent), silver (64.1 percent), and tin (42.8 percent). Poor removal efficiencies were observed for the entire treatment system for antimony (14.4 percent), boron (37.9 percent), molybdenum (14.6 percent), and strontium (4.8 percent). Arsenic was observed at below treatable levels throughout the system.

#### 6.4.1.3 Treatment Performance for Episode #4733

EPA performed a week-long sampling program, episode #4733. This facility was evaluated by EPA to obtain performance data on various treatment units which are in operation at this facility, including sulfide precipitation, Lancy filtration, and carbon adsorption. A flow diagram of the IWC wastewater treatment system sampled during episode # 4733 is presented in Figure 6-15. The wastewater treatment system used at this IWC facility treats wastewater from the air pollution control system. The air pollution control system consists of a quench tank and a wet scrubber. Table 6-4 presents a summary of percent removal data collected at episode #4733 for the performance of the sulfide precipitation and Lancy filtration process, carbon adsorption system, and the entire treatment system.

The treatment efficiency of the sulfide precipitation and Lancy filtration system was evaluated using the data obtained from sampling points 01 and 02 (see Figure 6-15). Influent concentration data to the primary system was obtained using sample point 01. Effluent from the first-stage treatment system was represented by sample point 02. As demonstrated on the Table 6-4, the first-stage treatment system had non-detectable levels in the influent for TSS, aluminum, cadmium, lead, molybdenum, silver, strontium, and MCP. Other parameters were observed in the influent at levels near to or below treatable levels, such as antimony, arsenic, and copper. COD was removed at 11.8 percent, whereas, no removal was observed for TDS. Metals with high removal rates in the first-stage system include; chromium (84.4 percent), iron (85.3 percent), manganese (86.3 percent), mercury (94.0 percent), and zinc (92.2 percent). Titanium was removed to non-detectable levels in the first-stage system. The treatment system achieved limited removal of selenium through the first-stage primary system (25.6 percent). Poor to no removals were observed for boron and tin.

The treatment efficiency of the carbon adsorption system was evaluated using the data obtained from sampling points 02 and 04 (see Figure 6-15). Influent concentration data to the carbon adsorption system was obtained using sample point 02, which is also the effluent from the first-stage treatment system. Effluent from the carbon adsorption system was represented by sample point 04 which is also the effluent point for the entire treatment system. As demonstrated on Table 6-4, the carbon adsorption system had non-detectable levels in the influent for the same parameters

Figure 6-15. EPA Sampling Episode 4733 - IWC Wastewater Treatment System Block Flow Diagram with Sampling Locations




Table 6-4. Treatment Technology Performance for Facility 4733

Pollutant of Interest	CAS #	First Stage Lancy Filter Sample Points 1 to 2						Carbon Adsorption System Sample Points 2 to 4					
		DL	Influent		sp	Effluent Conc. (ug/l)	% Removal	DL	Influent		sp	Effluent Conc. (ug/l)	% Removal
			Conc. (ug/l)	Conc. (ug/l)					Conc. (ug/l)	Conc. (ug/l)			
Conventional													
TSS	C-009	4,000	01	ND	02	ND	0.0	4,000	02	ND	04	ND	0.0
Non-Conventional													
COD	C-004	5,000	01	234,100	02	206,600	11.8	5,000	02	206,600	04	192,300	6.9
TDS	C-010		01	272,400	02	2,206,000	0.0		02	2,206,000	04	2,899,000	0.0
Metals													
Aluminum	7429905	13.6	01	ND	02	ND	0.0	13.6	02	ND	04	ND	0.0
Antimony	7440360	20.0	01	22.8	02	24.6	0.0	20.0	02	24.6	04	26.4	0.0
Arsenic	7440382	10.0	01	5.3	02	4.9	8.3	10.0	02	4.9	04	4.1	15.4
Boron	7440428	100	01	1,811	02	1,846	0.0	100	02	1,846	04	2,381	0.0
Cadmium	7440439	3.5	01	ND	02	ND	0.0	3.5	02	ND	04	ND	0.0
Chromium	7440473	5.8	01	37.1	02	ND	84.4	5.8	02	ND	04	ND	0.0
Copper	7440508	25.0	01	10.9	02	9.5	12.5	25.0	02	9.5	04	7.4	22.1
Iron	7439896	100	01	430	02	63.4	85.3	2.4	02	63.4	04	ND	96.2
Lead	7439921	2.1	01	ND	02	ND	0.0	2.1	02	ND	04	ND	0.0
Manganese	7439965	1.2	01	8.8	02	ND	86.3	1.2	02	ND	04	1.3	0.0
Mercury	7439976	0.2	01	3.3	02	ND	94.0	0.2	02	ND	04	0.4	0.0
Molybdenum	7439987	4.6	01	ND	02	ND	0.0	4.6	02	ND	04	7.1	0.0
Selenium	7782492	5.0	01	59.1	02	43.9	25.6	5.0	02	43.9	04	56.5	0.0
Silver	7440224	7.8	01	ND	02	8.1	0.0	7.8	02	8.1	04	8.1	0.0
Strontium	7440246	100	01	ND	02	ND	0.0	100	02	ND	04	ND	0.0
Tin	7440315	30.0	01	65.9	02	145	0.0	30.0	02	145	04	48.6	66.4
Titanium	7440326	5.0	01	11.4	02	ND	56.3	5.0	02	ND	04	ND	0.0
Zinc	7440666	20.0	01	102	02	7.9	92.2	2.4	02	7.9	04	ND	69.8
Pesticides/Herbicides													
Dichloroprop	120365	1.0	01	18.9	02	NS	NS	1.0	02	NS	04	ND	NS
MCPP	7085190	50.0	01	ND	02	NS	NS	50.0	02	NS	04	ND	NS

Negative percent removal are recorded as 0.0.

NS: Not Sampled

ND: Non-detect

DL: Specific detection limits of sample when there is a non-detect, otherwise it is the method detection limit

SP: Sample point.

Table 6-4 con't. Treatment Technology Performance for Facility 4733

Pollutant of Interest	CAS #	Entire Treatment System Sample Points 1 to 4					
		DL	sp	Influent		Effluent Conc. (ug/l)	% Removal
				Conc. (ug/l)	sp		
Conventional							
TSS	C-009	4,000	01	ND	04	ND	0.0
Non-Conventional							
COD	C-004	5,000	01	234,100	04	192,300	17.9
TDS	C-010		01	272,400	04	2,899,000	0.0
Metals							
Aluminum	7429905	13.6	01	ND	04	ND	0.0
Antimony	7440360	20.0	01	22.8	04	26.4	0.0
Arsenic	7440382	10.0	01	5.3	04	4.1	22.5
Boron	7440428	100	01	1,811	04	2,381	0.0
Cadmium	7440439	3.5	01	ND	04	ND	0.0
Chromium	7440473	5.8	01	37.1	04	ND	84.4
Copper	7440508	25.0	01	10.9	04	7.4	31.8
Iron	7439896	2.4	01	430	04	ND	99.4
Lead	7439921	2.1	01	ND	04	ND	0.0
		1.8					
Manganese	7439965	15.0	01	8.8	04	1.3	85.2
Mercury	7439976	0.2	01	3.3	04	0.4	88.6
Molybdenum	7439987	4.6	01	ND	04	7.1	0.0
Selenium	7782492	5.0	01	59.1	04	56.5	4.4
Silver	7440224	7.8	01	ND	04	8.1	0.0
Strontium	7440246	100	01	ND	04	ND	0.0
		86.7					
Tin	7440315	30.0	01	65.9	04	48.6	26.2
Titanium	7440326	5.0	01	11.4	04	ND	56.3
Zinc	7440666	2.4	01	102	04	ND	97.7
Pesticides/Herbicides							
Dichloroprop	120365	1.0	01	18.9	04	ND	94.7
MCPP	7085190	5.0	01	ND	04	ND	0.0

Negative percent removal are recorded as 0.0.

NS: Not Sampled

ND: Non-detect

DL: Specific detection limits of sample when there is a non-detect, otherwise it is the method detection limit

SP: Sample point.

as in the first-stage system, plus the metals removed to non-detectable levels in the first-stage system, such as chromium, manganese, mercury, and titanium. Additional removals were observed for iron (96.2 percent), tin (66.4 percent), and zinc (69.8 percent). No removals in the carbon adsorption system were observed for boron and selenium. As in the first-stage system, antimony, arsenic, and copper are at concentrations in the influent below treatable levels.

The treatment efficiency of the entire treatment system, both first-stage sulfide precipitation, Lancy filtration, and carbon adsorption, was evaluated using the data obtained from sampling points 01 and 04 (see Figure 6-15). Influent concentration data was obtained using sample point 01. Effluent from the entire treatment system was represented by sample point 04. As demonstrated on Table 6-4, the treatment system achieved a COD removal of 17.9 percent, whereas, there is no removal for TDS. For the overall treatment system, the metals with high removal rates include chromium, iron, manganese, mercury, titanium, and zinc. Poor removals were observed for selenium and tin. Other metals were only detected at concentrations at or near treatable levels. Dichlorprop was removed to non-detectable levels at 94.7 percent. MCPP was not detected in the influent or effluent from the treatment system.

#### **6.4.2      *Rationale Used for Selection of BAT Treatment Technologies***

This section presents the rationale used in selecting the treatment technologies used in the proposed regulatory options. Treatment technologies used at episode 4733 were not considered for further evaluation, since influent concentrations for many parameters were low and performance data for the treatment systems could not adequately be ascertained. Therefore, the technologies utilized at episodes 4646 and 4671 were further evaluated in order to select the most appropriate technologies to be used as the basis for the BAT options. The basis of this evaluation consists of a comparative analysis of the performance data for the proposed BAT treatment technologies based upon EPA sampling data.

Table 6-5 presents a summary of the percent removal data collected at EPA sampling episodes 4646 and 4671 for the primary chemical precipitation systems. As demonstrated on this table, both chemical precipitation systems achieved similar removals for many of the same metal parameters. Although the loadings for some metal parameters were lower for episode 4671 which resulted in

**Table 6-5. Primary Chemical Precipitation Treatment Technology Performance Comparison**

Pollutant of Interest	CAS #	4646 First Stage Chemical Precipitation Sample Points 1+2 to 4					4671 First Stage Chemical Precipitation Sample Points 1 to 2				
		DL	sp	Influent Conc. (ug/l)	Effluent Conc. (ug/l)	% Removal	DL	sp	Influent Conc. (ug/l)	Effluent Conc. (ug/l)	% Removal
<b>Conventional</b>											
TSS	C-009	4,000	01+02	122,560	11,200	90.9	4,000	01	241,100	70,900	70.6
<b>Non-Conventional</b>											
COD	C-004	5,000	01+02	535,920	156,200	70.9	5,000	01	259,400	227,600	12.3
TDS	C-010		01+02	30,694,160	50,320,000	0.0		01	7,481,000	6,896,000	7.8
<b>Metals</b>											
Aluminum	7429905	200	01+02	1,104	170	84.6	200	01	1,575	266	83.1
Antimony	7440360	20.0	01+02	672	1,026	0.0	20.0	01	110	107	2.5
Arsenic	7440382	10.0	01+02	475	494	0.0	10.0	01	19.2	19.9	0.0
Boron	7440428	100	01+02	1,280	1,744	0.0	100	01	1,723	1,219	29.2
Cadmium	7440439	5.0	01+02	929	174	81.2	5.0	01	4.2	2.4	43.1
Chromium	7440473	10.0	01+02	220	53.4	75.8	10.0	01	124	3.2	97.4
Copper	7440508	25.0	01+02	5,228	321	93.9	25.0	01	121	33.8	72.0
Iron	7439896	100	01+02	7,066	254	96.4	100	01	1,217	79.8	93.4
Lead	7439921	50.0	01+02	4,691	117	97.5	50.0	01	149	14.3	90.4
Manganese	7439965	15.0	01+02	228	76.6	66.5	15.0	01	107	74.3	30.5
Mercury	7439976	0.2	01+02	59.2	21.4	63.9	0.2	01	0.7	0.4	33.8
Molybdenum	7439987	10.0	01+02	936	1,137	0.0	10.0	01	69.7	66.6	4.5
Selenium	7782492	5.0	01+02	240	263	0.0	9.7	01	ND	14.0	0.0
Silver	7440224	10.0	01+02	283	169	40.3	10.0	01	5.7	9.1	0.0
Strontium	7440246	100	01+02	408	328	19.7	100	01	1,382	1,582	0.0
Tin	7440315	30.0	01+02	1,882	45.9	97.6	30.0	01	49.5	39.0	21.2
Titanium	7440326	5.0	01+02	2,116	32.9	98.4	10.0	01	206	ND	95.1
Zinc	7440666	20.0	01+02	9,456	209	97.8	20.0	01	1,598	813	49.1
<b>Pesticides/Herbicides</b>											
Dichloroprop	120365	1.0	01+02	3.1	NS	NS	1.0	01	ND	NS	NS
MCPP	7085190	50.0	01+02	1,027	NS	NS	50.0	01	ND	NS	NS

Negative percent removal are recorded as 0.0.

NS: Not Sampled

ND: Non-detect

DL: Specific detection limits of sample when there is a non-detect, otherwise it is the method detection limit

SP: Sample point.

lower percent removals, the overall concentrations for some of the pollutants were treated to similar concentration levels as those for episode 4646. For instance, manganese percent removal for episode 4671 was only 33.8 percent, however the effluent concentration of 74.3 ug/l was comparable to that of episode 4646 of 76.6 ug/l during which a 66.5 percent removal was achieved. Metals which experienced good overall removals in both chemical precipitation treatment systems include aluminum, cadmium, chromium, copper, iron, lead, manganese, mercury, tin, titanium, and zinc. Neither system was effective in treating antimony, arsenic, boron, selenium, silver, and strontium. Episode 4646 had higher removals for TSS (90.9 percent) and COD (70.9 percent).

Next, an evaluation of the secondary precipitation process plus filtration for both facilities was performed. Table 6-6 presents a summary of the percent removal data collected at EPA for sampling episodes 4646 and 4671 for the secondary precipitation process and sand filter or ultrafiltration process, respectively. As demonstrated on this table, either process resulted in low effluent concentrations for many of the metal parameters; such as cadmium, chromium, copper, iron, lead, mercury, and zinc. However, the most significant difference between the two systems is the removal of antimony (66.3 percent), arsenic (98.4 percent), and selenium (90.1 percent) in the secondary system for episode 4646. Episode 4671, which employs a secondary treatment system consisting of hydroxide precipitation and ultrafiltration, did not achieve significant removals for antimony, arsenic, or selenium.

Overall both facilities achieved similar removals and/or treated to the same degree for many of the metal parameters which are readily removed by chemical precipitation using sodium hydroxide; including but not limited to cadmium, chromium, copper, iron, lead, mercury, and zinc. Both facilities utilized a two tiered approach in the design of their treatment system using some type of a chemical precipitation process to provide treatment. Primary treatment system design are comparable at both facilities and are designed to remove similar pollutants. Both primary treatment systems are designed to remove those metals which readily precipitate out of solution at a high pH range using a sodium hydroxide precipitation treatment process. Based upon EPA sampling data, this treatment process was determined not to be very effective in treating antimony, arsenic, boron, selenium, silver, and strontium. The treatment system at episode 4671 uses a secondary treatment system targeted to achieve additional removals for the same parameters which receive initial removals in the primary

**Table 6-6. Secondary Chemical Precipitation and Filtration Treatment Technology Performance Comparison**

Pollutant of Interest	CAS #	4646 Second Stage Chemical Precipitation & Sand Filtration Sample Points 4 to 6					4671 Second Stage Chemical Precipitation & Ultrafiltration Sample Points 2 to 3				
		DL	sp	Influent		% Removal	DL	sp	Influent		% Removal
				Conc. (ug/l)	sp				Conc. (ug/l)	sp	
Conventional											
TSS	C-009	4,000	04	11,200	05	5,500	4,000	02	70,900	03	80.5
Non-Conventional											
COD	C-004	5,000	04	156,200	05	257,900	5,000	02	227,600	03	32.0
TDS	C-010		04	50,320,000	05	38,150,000		02	6,896,000	03	4.9
Metals											
Aluminum	7429905	200	04	170	05	160	6.5	02	266	03	97.6
Antimony	7440360	20.0	04	1,026	05	346	20.0	02	107	03	12.2
Arsenic	7440382	10.0	04	494	05	8.1	10.0	02	19.9	03	0.0
Boron	7440428	100	04	1,744	05	1,731	100	02	1,219	03	12.3
Cadmium	7440439	5.0	04	174	05	19.9	5.0	02	2.4	03	83.6
Chromium	7440473	10.0	04	53.4	05	ND	10.0	02	3.2	03	67.7
Copper	7440508	25.0	04	321	05	10.1	25.0	02	33.8	03	44.4
Iron	7439896	100	04	254	05	128	100	02	79.8	03	37.1
Lead	7439921	50.0	04	117	05	ND	1.5	02	14.3	03	89.5
Manganese	7439965	15.0	04	76.6	05	545	15.0	02	74.3	03	96.9
Mercury	7439976	0.2	04	21.4	05	ND	0.2	02	0.4	03	54.5
Molybdenum	7439987	10.0	04	1,137	05	580	10.0	02	66.6	03	10.6
Selenium	7782492	5.0	04	263	05	26.0	11.5	02	14.0	03	17.6
Silver	7440224	10.0	04	169	05	ND	10.0	02	9.1	03	77.7
Strontium	7440246	100	04	328	05	674	100	02	1,582	03	16.8
Tin	7440315	30.0	04	45.9	05	31.5	28.3	02	39.0	03	27.4
Titanium	7440326	5.0	04	32.9	05	6.8	10.0	02	ND	03	0.0
Zinc	7440666	20.0	04	209	05	24.2	20.0	02	813	03	70.7
Pesticides/Herbicides											
Dichloroprop	120365	1.0	04	NS	05	ND	1.0	02	NS	03	NS
MCPP	7085190	50.0	04	NS	05	1,482	50.0	02	NS	03	NS

Negative percent removal are recorded as 0.0.

NS: Not Sampled


ND: Non-detect

DL: Specific detection limits of sample when there is a non-detect, otherwise it is the method detection limit

SP: Sample point.

system. Chemical precipitation by hydroxide precipitation is once again utilized with ultrafiltration as a polishing step in the secondary system. The design of this treatment system is primarily due to the characteristics of the wastewater at this facility, as well as a function of the discharge limitations in their NPDES permit. During the sampling episode, the facility for episode 4671 was permitted for antimony (2,000 ug/l daily maximum) and for arsenic (100 ug/l daily maximum). However, neither of these two parameters were observed in the influent at levels above their respective discharge limitation in EPA's sampling episode. Therefore, the design and operation of the treatment system at episode 4671 is not driven by the removals of parameters such as antimony or arsenic, but rather by other metals which are removed by hydroxide precipitation; such as aluminum. Conversely, the facility for episode 4646 is designed to remove those metals in the secondary treatment process which are not readily removed by hydroxide precipitation. At the time of the sampling episode, this facility's NPDES permit contains discharge limitations for antimony (600 ug/l daily maximum), arsenic (100 ug/l daily maximum), selenium (100 ug/l daily maximum), and silver (100 ug/l daily maximum). Each of these parameters were observed in the influent to the treatment system at concentrations over their respective discharge limitation. Therefore, the wastewater treatment system used at episode 4646 is designed and operated with a secondary treatment system consisting of chemical precipitation at a low pH range by ferric chloride and multimedia filtration aimed at removing these additional metal parameters which are not removed by hydroxide precipitation in the primary treatment system.

Based upon the results of the above comparative analysis of chemical precipitation and filtration processes used at IWC facilities sampled by EPA, the proposed regulatory options utilize unit treatment processes such as those found at episode 4646. Performance data from this facility indicates that a primary chemical precipitation system utilizing a sodium hydroxide precipitation process can readily achieve high removals for many metal parameters. A secondary system consisting of chemical precipitation using ferric chloride and sand filtration can effectively remove additional metals not readily removed by hydroxide precipitation, such as antimony, arsenic, and selenium, as well as, achieve high additional removals for other metals which are removed by hydroxide precipitation. Therefore, the combining of these treatment processes results in a highly effective treatment operation which can readily accommodate the pollutants of interest for the IWC industry.



## **SECTION 7**

### **ENGINEERING COSTS**

This section of the Industrial Waste Combustor (IWC) Industry Development Document presents the following information: sources of cost data along with a benchmark analysis of models; engineering costing methodology and description of each type of additional cost to comply with proposed options; individual treatment technology costs; and individual compliance costs for each facility in the database for each proposed option.

This chapter contains the following sections:

- Section 7.1 presents a discussion of the various costing options that were evaluated. The criteria used to evaluate these costing options are presented, as well as a benchmark analysis to compare the accuracy of each of these options. The selected costing option is also presented in this section.
- Section 7.2 presents a discussion of the costing methodology used to develop regulatory costs. This section discusses the methodology used to cost treatment systems and components, as well as to develop regulatory option costs.
- Section 7.3 presents the costing method used to cost for individual treatment technologies which comprise the regulatory options. Cost curves and equations developed for each treatment technology are presented in this section.
- Section 7.4 presents the approach to developing additional regulatory costs associated with the implementation of the IWC regulation. Additional costs which were developed include retrofit, monitoring, RCRA permit modification, and land costs.
- Section 7.5 presents the wastewater off-site disposal costs used for facilities with very low flow rates of IWC wastewater.
- Section 7.6 presents summary tables of the total compliance costs, by facility, for each of the IWC Industry regulatory options, including BPT/BAT and PSES. Also presented in this section are the compliance costs for NSPS and PSNS.

## **7.1**                    ***COSTS DEVELOPMENT***

This section presents a discussion of the various costing options which were evaluated in order to calculate compliance costs for the IWC Industry. A discussion of the selection criteria used to evaluate these costing options are presented in this section, as well as a benchmark analysis to compare the accuracy of each of these options. The selected costing option is then presented.

### **7.1.1**                ***Sources of Cost Data***

The following sections present the various costing sources considered in developing regulatory costs for the IWC Industry, including computer models, vendor quotes, the Waste Treatment Industry Phase II: Incinerators 308 Questionnaire, and other effluent guidelines.

#### **7.1.1.1**            **Cost Models**

Cost estimates of wastewater treatment systems are required to be developed in order to evaluate the economic impact of the regulation. Mathematical cost models were used to assist in developing estimated costs. In a mathematical cost model, various design and vendor data are combined to develop cost equations which describe costs as a function of system parameters, such as flow. Using such models readily allows for iterative costing to be performed to assist in option selection.

For developing costs for the IWC Industry regulation, two commonly used cost models were evaluated:

- Computer-Assisted Procedure for the Design and Evaluation of Wastewater Treatment Systems (CAPDET), developed by the U.S. Army Corps of Engineers.
- W/W Costs Program (WWC), Version 2.0, developed by CWC Engineering Software.

CAPDET is intended to provide planning level cost estimates to analyze alternate design technologies for wastewater treatment systems. It was developed to estimate treatment system costs primarily for high flow, municipal wastewater applications. Modules are used which represent

physical, chemical, and biological treatment unit processes. Equations in each of these modules are based upon engineering principles historically used for wastewater treatment plant design. Modules can be linked together to represent entire treatment trains. CAPDET designs and costs various treatment trains and ranks them with respect to present worth, capital, operating, or energy costs.

WWC is a cost model developed by Culp/Wesner/Culp from a variety of engineering sources, including vendor supplied data, actual plant construction data, unit takeoffs from actual and conceptual designs, and published data. The program allows for the costing of various unit processes. As with CAPDET, this program allows for these unit processes to be strung together to develop cost for treatment trains. WWC does not perform the design of the unit process, but rather prompts the user to provide design input parameters which form the basis for the costing. The WWC program is provided with a separate spreadsheet program entitled Design Criteria Guidelines to assist in developing the input parameters to the costing program. The Design Criteria Guidelines is a spreadsheet of treatment component design equations which is supplied using default parameters to assist in designing particular treatment units. Default parameters are based upon commonly accepted design criteria used in wastewater treatment. Flexibility is provided with this spreadsheet, in that particular design parameters can be modified to best satisfy given situations. Once design inputs are entered into the program, the WWC costing program yields both construction and operation and maintenance (O&M) costs for the system.

#### **7.1.1.2 Vendor Data**

For certain treatment processes, the cost models do not yield acceptable and valid treatment costs. In these instances, it was more reliable to obtain equipment and maintenance costs directly from treatment system or component manufacturers. Information on the wastewater characteristics was provided to the vendor in order to determine accurately the appropriate treatment unit and sizing. Vendor quotes were used to determine cost curves for multi-media filtration and for sludge dewatering using plate and frame technology. The cost curves used are based on the vendor quotes and information obtained as part of the CWT effluent guidelines effort.

#### **7.1.1.3      Waste Treatment Industry Phase II: Incinerators 308 Questionnaire Costing Data**

The Waste Treatment Industry Phase II: Incinerators 308 Questionnaire costing data was only utilized in the benchmark analysis to compare the accuracy of the costing models and is discussed further in Section 7.1.2.

#### **7.1.1.4      Other EPA Effluent Guideline Studies**

Other EPA effluent studies, such as the Organic Chemicals and Plastics and Synthetic Fibers (OCPSF) industry effluent guidelines, were reviewed in order to obtain additional costing background and supportive information. However, costs developed as part of other industrial effluent guidelines were not used in costing for this industry, with the exception of the CWT effluent guideline data referenced in Section 7.1.1.2 above.

#### **7.1.2      *Benchmark Analysis and Evaluation Criteria***

A benchmark analysis was performed to gauge the accuracy of the costing models presented above. This benchmark analysis used actual costs provided in the Incinerator 308 questionnaires as compared to costs generated using various costing options. Two BPT/BAT facilities (Questionnaire ID#s 4646 and 4671) were selected to be used in the benchmark analysis. The BPT/BAT facilities had installed treatment systems similar to the proposed regulatory options. Treatment technologies which were used in the benchmark analysis include:

- equalization
- chemical precipitation
- sedimentation
- multimedia filtration


Table 7-1 presents a cost comparison of capital and O&M costs for the above technologies. Costs were developed using the average design flow of the selected BPT/BAT facilities and average

pollutant loadings (see Section 4.0). This table presents costs developed using the WWC program, CAPDET, and vendor quotes, as compared to industry provided treatment system capital and O&M costs provided in the 308 Technical Questionnaires for the BPT/BAT facilities.


Capital costs provided in the 308 Technical Questionnaire for chemical precipitation systems installed at facility ID#s 4646 and 4671 were \$2,207,000 and \$1,215,000, respectively. Questionnaire capital cost for the second-stage chemical precipitation system and filtration process at facility ID # 4646 is \$2,751,000, whereas, the capital cost for the second-stage chemical precipitation at facility ID # 4671 is \$2,265,000. As demonstrated on Table 7-1, capital costs developed by the WWC program for the various treatment technologies were typically close to the actual costs as provided in the questionnaire. For the WWC program, the range of accuracy in predicting treatment component capital costs ranged from plus 76.6 percent for the chemical precipitation system for facility ID# 4671 to a minus 34.8 percent for the second-stage chemical precipitation system also for facility ID# 4671. The range of accuracy for the CAPDET program capital costs was greater than that of the WWC program and ranged from a positive 110.6 percent for the chemical precipitation system for facility ID# 4646 to a minus 46.6 percent for the second-stage chemical precipitation and filtration system at the same facility. Vendor quotes consistently had a large variability from actual questionnaire costs and were typically much lower.

O&M costs provided in the 308 Technical Questionnaire for chemical precipitation systems installed at facility ID#s 4646 and 4671 were \$910,000 and \$1,837,000, respectively. Questionnaire O&M cost for the second-stage chemical precipitation system and filtration process at facility ID # 4646 is \$315,000, whereas, the O&M cost for the second-stage chemical precipitation at facility ID # 4671 is \$363,000. As demonstrated on Table 7-1, O&M costs developed by the WWC program for the various treatment technologies were typically close to the actual costs as provided in the questionnaire. For the WWC program, the range of accuracy in predicting treatment component O&M costs ranged from plus 89.1 percent for the second-stage chemical precipitation system for facility ID# 4671 to a minus 26.4 percent for the second-stage chemical precipitation and filtration system for facility ID# 4646. The ranges of accuracy for the CAPDET program and vendor quotes in predicting O&M costs were typically greater than the WWC program costs or were significantly lower than questionnaire provided costs.

Table 7-1. Costing Source Comparison



	4646 Chem Precip	4646 2-stage Chem Precip and Sand Filtration	4671 Chem Precip	4671 2-stage Chem Precip
Questionnaire	2,206,980	2,751,204	1,214,563	2,265,009
WWC	3,543,264	2,950,035	2,144,446	1,476,821
CAPDET	4,948,779	1,475,480	942,216	3,072,253
Vendor Quotes	399,878	3,314,930	319,206	670,158



	4646 Chem Precip	4646 2-stage Chem Precip and Sand Filtration	4671 Chem Precip	4671 2-stage Chem Precip
Questionnaire	910,000	315,000	1,837,000	363,000
WWC	1,355,505	231,728	1,864,219	686,360
CAPDET	585,855	99,036	515,859	466,848
Vendor Quotes	860,867	222,135	361,623	151,889

Therefore, the benchmark analysis demonstrated that the WWC cost program consistently developed capital and O&M costs which are considered acceptable estimates of actual costs when compared to questionnaire responses. Whereas, both CAPDET and vendor quotes were determined not to be as accurate or consistent in estimating capital and O&M costs for these technologies.

The following criteria was used in order to evaluate the costing options and to select the appropriate option for developing the IWC Industry costing methodology:

- Does the model contain costing modules representative of the various wastewater technologies in use or planned for use in the IWC Industry?
- Can the program produce costs in the expected flow range experienced in this industry?
- Can the model be adapted to cost entire treatment trains used in the IWC Industry?
- Is sufficient documentation available regarding the assumptions and sources of data so that costs are credible and defensible?
- Is the model capable of providing detailed capital and operation and maintenance costs with unit costing breakdowns?
- Is the program capable of altering the default design criteria in order to accurately represent actual design criteria indicative of the IWC Industry?

### **7.1.3      *Selection of Final Cost Models***

Based upon the results of the benchmark analysis and an evaluation using the criteria above, the WWC costing program was selected for costing the majority of the treatment technologies. It was determined that the WWC produces reliable capital and O&M costs for a wide range of treatment technologies. As demonstrated on Table 7-1, WWC program costs were consistently accurate in predicating both capital and O&M costs for those wastewater treatment systems at the selected BPT/BAT facilities. Capital costs predicted by CAPDET for these various treatment systems were typically less consistent and were either much higher or lower than Questionnaire provided costs. O&M costs developed with CAPDET were typically low compared to Questionnaire costs. In addition, CAPDET could not cost all of the technologies needed for the IWC Industry and was

determined not to be as accurate in predicting costs in the low flow range that characterize the IWC industry. Vendor quotes for both capital and O&M costs in general were much lower than Questionnaire costs. Therefore, CAPDET and vendor quotes (except as provided for below) were not used for costing.

The WWC computer-based costing program best satisfies the selection criteria presented above. The program can cost a wide range of typical and innovative treatment unit operations and can combine these unit operations to develop system costs. Since the WWC program is a computer based program, it readily allows for the repeated development of costs for a number of facilities. The program utilizes cost modules which can accommodate the range of flows and design input parameters needed to cost the IWC Industry. Costs developed by this program are based upon a number of sources, including actual construction and operation costs, as well as published data. Costs are presented in a breakdown summary table which contains unit costs and totals. Finally, the WWC program is adaptable to cost unit operations based upon specified design criteria, as well as flow rate. Certain unit operations are costed strictly based upon the input of flow rate, whereas other unit operations are costed based upon a combination of flow rate and design loadings or component size. The Design Criteria Guidelines spreadsheet is used in conjunction with the program to aid in determining particular treatment component design input parameters. This spreadsheet is based upon design default values, which can readily be modified in order to develop costs based upon particular design parameters common in the IWC Industry.

However, there were particular instances where the WWC program did not produce reliable cost information, such as for multi-media filtration and sludge dewatering facilities. WWC program costs for these technologies were excessively high as compared to industry provided costs in the 308 Questionnaire. For these technologies, vendor quotes were more accurate in predicating costs and, therefore, were used to provide costs.

## 7.2

### *ENGINEERING COSTING METHODOLOGY*

This section presents the costing methodology used to develop treatment technology and BPT/BAT and PSES option costs for the IWC Industry. Additional costs to comply with this regulation, such as monitoring costs, are presented in a latter discussion in Section 7.4 of this chapter.

### 7.2.1 *Treatment Costing Methodology*

The following discussion presents a detailed summary of the technical approach used to estimate treatment technology costs for each in-scope facility in the IWC database. For each facility in the database and for each proposed option, EPA developed total capital and annual operation and maintenance treatment costs to upgrade existing wastewater treatment system, or to install new treatment technologies, in order to comply with the long term averages (LTAs). Facilities were costed primarily using the WWC costing program. Vendor cost curves, as developed in the CWT industry study, were used for multimedia filtration and sludge dewatering costing. Table 7-2 presents a breakdown of the costing method used for each treatment technology.

**Table 7-2. Breakdown of Costing Method by Treatment Technology**

<b>Treatment Technology</b>	<b>Cost Using WWC Program</b>	<b>Cost Using Vendor Quotes<sup>1</sup></b>	<b>Key Design Parameter(s)</b>
Flocculation, Mixing & Pumping	X		Flow rate
Chemical Feed System	X		Flow rate & POI Metals
Primary & Secondary Clarification	X		Flow rate
Multimedia Filtration		X	Flow rate
Sludge Filter Press		X	Flow rate

(1) Cost curves developed using vendor quotes in the CWT guideline effort.

In using the WWC computer model to develop treatment technology costs, the first step was to use the Design Criteria Guidelines spreadsheet to develop input parameters for the computer costing program. Actual pollutant loadings from the facility were used whenever possible. If pollutant loadings were not available for a particular parameter, EPA used an estimated concentration developed based on combined waste stream loadings or loadings from similar facilities. The facility's baseline flow rate and the regulatory option LTAs were also used in the design of the unit operation. Certain key design parameters, such as total suspended solids, are used directly in the WWC program, and accompanying Design Criteria Guidelines spreadsheet, to design the various treatment unit operations, such as a clarifier. Selected pollutant of concern (POC) metals were used to assist in the design of BPT/BAT chemical precipitation systems. These metals typically impose a large requirement for the various precipitating agents, thereby governing the chemical feed system design. A more detailed discussion of individual treatment technology costing and their design parameters is presented in Section 7.3. The design parameters from the Design Criteria Guidelines spreadsheet were next used as input for the WWC costing program to develop the installed capital and O&M costs.

Individual treatment component costs were developed by the WWC program by using the corresponding module provided by the program for that particular technology. Technology-specific design parameters were input into the WWC program. The WWC program then calculated both installed capital costs and annual O&M costs. Treatment technology costs developed by the WWC costing program were corrected to 1992 costs using the Engineering News Record (ENR) published indexes. After the installed capital and annual O&M costs were developed for each facility, selected cost factors, as shown in Table 7-3, were applied to the results to develop total capital and O&M costs. Capital costs developed by the program include the cost of the treatment unit and some ancillary equipment associated with that technology (see Section 7.3 for further information on particular items costed for each technology). O&M costs for treatment chemicals, labor, materials, electricity, and fuel are included in the computer program O&M costs.

**Table 7-3. Additional Cost Factors**

Type	Factor	% of Capital Cost
Capital	Site Work & Interface Piping	18
	General Contractor Overhead	10
	Engineering	12
	Instrumentation & Controls	13
	Buildings	6
	Site Improvements	10
	Legal, Fiscal, & Administrative	2
	Interest During Construction	9
	Contingency	8
	Retrofit (if necessary)	20
O&M	Taxes & Insurance	2 <sup>1</sup>


- (1) 2 percent of total capital costs, which includes WWC computer costs and capital costs listed above.

### **7.2.2 Option Costing Methodology**

The following discussion presents a detailed summary of the technical approach used to estimate the BPT/BAT and PSES option costs for each in-scope facility in the IWC database. Zero discharge facilities were not costed for any of the regulatory options. The costing methodology used to develop facility-specific BPT/BAT and PSES option compliance costs is presented graphically on the flow diagram in Figure 7-1.

For each proposed BPT/BAT and PSES regulatory option, it was first determined whether a facility was complying with the LTAs of each pollutant considered for regulation. None of the facilities were in compliance with the LTAs, and were therefore assigned additional equipment and/or upgrade costs to achieve compliance with that option. The next step was to determine whether a

Figure 7-1. Option-Specific Costing Logic Flow Diagram



facility had already installed treatment unit operations capable of complying with the LTAs. If a facility already had BPT/BAT, PSES or equivalent treatment installed, the facility was only assigned costs for treatment system upgrades.

For facilities that did not have BPT/BAT or PSES treatment systems or equivalent, costs were developed for the additional unit operations and/or system upgrades necessary to meet each LTA. Facilities which were already close to compliance with the LTAs were costed for upgrades in order to achieve BPT/BAT levels. Upgrade costs were developed using the WWC costing program whenever possible, and included either additional equipment to be installed on existing unit processes, expansion of existing equipment, or operational changes. Examples of upgrade costs include such items as a new or expanded chemical feed system, or improved or expanded sedimentation capabilities. If a facility had no treatment system, or one that could not achieve desired levels with upgrades or minor additions, an entire BPT/BAT treatment system was costed for that facility.

Once all of the individual treatment technology requirements for each facility were established, individual capital and O&M treatment technology costs were developed as previously described above in Section 7.2.1. In order to estimate the total compliance cost for a regulatory option it is necessary to sum all of the individual component treatment technology costs. Table 7-4 presents each of the proposed regulatory options in the IWC Industry and the corresponding treatment technologies costed for each.

### **7.3            *TREATMENT TECHNOLOGIES COSTING***

The following sections describe how costs were developed for the BPT/BAT/PSES treatment technologies. Specific assumptions are discussed for each treatment technology regarding the equipment used, flow ranges, input and design parameters, and design and cost calculations. Table 7-2, previously referenced, presented the selected costing method which was used to cost each of the treatment technologies used in the proposed BPT/BAT and PSES options. The following subsections present a detailed discussion on how each of the treatment technologies presented in Table 7-3 were costed. Costs are presented as physical/chemical wastewater treatment costs, and sludge treatment and disposal costs.

Table 7-4. Regulatory Option Wastewater Treatment Technology Breakdown

BPT/BCT /BAT/PSES OPTION	BPT/BCT/BAT/PSES OPTION DESCRIPTION	TREATMENT CODE COMPONENTS	WWC #
A	Two-stage Chemical Precipitation & SludgeDewatering	pumping	92
		rapid mix tank	104
		sodium bisulfite feed system	42
		flocculation	72
		sodium hydroxide feed system	45
		primary clarification	118
		pumping	92
		rapid mix tank	104
		hydrochloric acid feed system	46
		flocculation	72
		ferric chloride feed system	40
		polymer feed	43
		rapid mix tank	104
		sodium hydroxide feed system	45
		secondary clarification	118
		sludge dewatering	NA
B	Two-stage Chemical Precipitation, MMF & SludgeDewatering	pumping	92
		rapid mix tank	104
		sodium bisulfite feed system	42
		flocculation	72
		sodium hydroxide feed system	45
		primary clarification	118
		pumping	92
		rapid mix tank	104
		hydrochloric acid feed system	46
		flocculation	72
		ferric chloride feed system	40
		polymer feed	43
		rapid mix tank	104
		sodium hydroxide feed system	45
		secondary clarification	118
		multi-media filter	NA
		sludge dewatering	NA

NA = Technology costed using vendor cost curves from CWT study.

### **7.3.1**

#### ***Physical/Chemical Wastewater Treatment Technology Costs***

Table 7-4 presents a breakdown of the WWC treatment modules used in costing each treatment technology for each of the proposed regulatory options. The following sections present a description of costs for each physical/chemical wastewater treatment technology used in the proposed regulation. Capital and O&M cost curves were developed for specific technologies and system components. These curves, which represent cost as a function of flow rate or other system design parameter, were developed using a commercial statistical software package (SlideWrite Plus Version 2.1). First, costs were developed using the WWC program for each technology or component using as a design basis five different flow rates or other system design parameters (depending upon the governing design parameter). For instance, a technology costed on the basis of flow would have costs developed by the WWC program at 0.01 million gallons per day (MGD), 0.05 MGD, 0.1 MGD, 0.5 MGD, and 1.0 MGD. Ranges for the five selected points to cost were based upon a review of the flow or technology design parameters for all facilities in the database and were selected in order to bracket the range from low to high. Next, these five data points (flow/design parameter and associated cost) were entered into the commercial statistical software program. Cost curves to model the total capital and O&M costs were then developed by the program using curve fitting routines. A second order natural log equation format was used to develop all curves. All cost curves yielded total capital and O&M costs, unless otherwise noted.

#### **7.3.1.1**

##### **Chemical Feed Systems**

The following section presents the methodology used to calculate the chemical addition feed rates used with each applicable regulatory option. Table 7-5 presents a breakdown of the design process used for each type of chemical feed. Chemical costs presented in Table 7-6 were taken from the September 1992 Chemical Marketing Reporter.

For facilities with existing chemical precipitation systems, an evaluation was made as to whether the system was achieving the regulatory option LTAs. If the existing system was achieving LTAs, no additional chemical costs were necessary. However, if the facility was not achieving the

**Table 7-5. Chemical Addition Design Method**

Chemical	Basis for Design	
	Stoichiometry	Reference <sup>1</sup> (mg/L)
Hydrochloric Acid	X	2.0
Sodium Hydroxide	X	
Polymer		
Sodium Bisulfate	X	75
Ferric Chloride		

(1) Source: Industrial Water Pollution Control, 2nd Edition (Reference X).

**Table 7-6. Treatment Chemical Costs**

Treatment Chemical	Cost <sup>1</sup>
Ferric Chloride	\$200/ton
Hydrochloric Acid	\$72/ton
Polymer	\$2.25/lb
Sodium Bisulfate	\$230/ton
Sodium Hydroxide	\$350/ton

(1) Source: 1992 Chemical Marketing Reporter

LTAs for an option, the facility was costed for an upgrade to the chemical precipitation system. First, the stoichiometric requirements were determined for each metal to be removed to the LTA level. If the current feed rates were within the calculated feed rates no additional costs were calculated. For facilities currently feeding less than the calculated amounts, the particular facility was costed for an

upgrade to add additional precipitation chemicals, such as a coagulant, or expand their existing chemical feed system to accommodate larger dosage rates.

Facilities without an installed chemical precipitation system were costed for an entire metals precipitation system. The chemical feed rates used at a particular facility for either an upgrade or a new system were based upon stoichiometric requirements, pH adjustments, and buffering ability of the raw influent.

In developing the CWT proposed industry guideline, EPA's analysis led the agency to conclude that the stoichiometric requirements for chemical addition far outweighed the pH and buffer requirements. It was determined that 150 percent of the stoichiometric requirement would sufficiently accommodate for pH adjustment and buffering of the solution. An additional 50 percent of the stoichiometric requirement was included to react with metals not on the POC list. Finally, an additional 10 percent was added as excess. Therefore, a total of 210 percent of the stoichiometric requirement was used in developing costs.

### **Sodium Hydroxide Feed Systems**

The stoichiometric requirement for sodium hydroxide to remove a particular metal is based upon the generic equation:

$$lb_{treatment\ chemical} = \left( \frac{lb_{M\ removed}}{year} \right) \left( \frac{valence_M}{MW_M} \right) \left( \frac{MW_{treatment\ chemical}}{valence_{Na/Ca}} \right)$$

where, M is the target metal and MW is the molecular weight.

The calculated amounts of sodium hydroxide to remove a pound of each of the selected metal pollutants of concern are presented in Table 7-7. For indirect dischargers, only those metals which were determined to pass through a POTW were used in determining the stoichiometric requirements. The other metals present in the wastewater will be accommodated for by the additional 110 percent of the stoichiometric requirement. Sodium hydroxide chemical feed system costs were developed for many facilities using the WWC costing program. Actual facility loadings were used to establish the sodium hydroxide dosage requirement. WWC unit process 45 was used to develop capital and O&M

**Table 7-7. Sodium Hydroxide Requirements for Chemical Precipitation**

Pollutant	Dosage Rate
	Sodium Hydroxide (lb/lb metal removed)
Aluminum	4.45
Antimony	1.64
Arsenic	2.67
Boron	11.10
Cadmium	0.71
Chromium	2.31
Copper	1.26
Iron	2.15
Lead	0.77
Manganese	2.91
Mercury	0.40
Molybdenum	2.50
Selenium	2.03
Silver	0.74
Tin	1.35
Titanium	3.34

costs for sodium hydroxide feed systems. The capital and O&M cost curves developed for sodium hydroxide feed systems, based upon the calculated dosages, are presented as Equations 7-1 and 7-2,<sup>3</sup> respectively.

$$\ln(Y) = 10.653 - 0.184\ln(X) + 0.040\ln(X)^2 \quad (7-1)$$

$$\ln(Y) = 8.508 - 0.0464\ln(X) + 0.014\ln(X)^2 \quad (7-2)$$

where:

X = Dosage Rate (lb/day), and

Y = Cost (1992 \$)

Figures 7-2 and 7-3 graphically present the sodium hydroxide feed system capital and O&M cost curves, respectively.

Cost for a sodium hydroxide feed system are estimated using the WWC unit process cost number 45. Costs are based on sodium hydroxide dosage rates between 10-10,000 lb/day, with dry sodium hydroxide used at rates less than 200 lb/day, and liquid sodium hydroxide used at higher feed rates. The costing program assumes that dry sodium hydroxide (98.9 percent pure) is delivered in drums and mixed to a 10 percent solution on-site. A volumetric feeder is used to feed sodium hydroxide to one of two tanks; one for mixing the 10 percent solution, and one for feeding. Two tanks are necessary for this process because of the slow rate of sodium hydroxide addition due to the high heat of solution. Each tank is equipped with a mixer and a dual-head metering pump, used to convey the 10 percent solution to the point of application. Pipe and valving is required to convey water to the dry sodium hydroxide mixing tanks and between the metering pumps and the point of application.

A 50 percent sodium hydroxide solution is purchased, premixed and delivered by bulk transport for feed rates greater than 200 lb/day. The 50 percent solution contains 6.38 pounds of sodium hydroxide per gallon, which is stored in fiberglass reinforced polyester tanks designed to a hold 15 day capacity. Dual-head metering pumps are used to convey the liquid solution to the point of application, and a standby metering pump is provided in all systems. The storage tanks are located indoors, since 50 percent sodium hydroxide begins to crystallize at temperatures less than 54°F.

### **Ferric Chloride Feed Systems**

Ferric chloride feed systems were costed using the WWC unit process 40. Costs were based upon a dosage rate of 75 mg/l of ferric chloride. The capital and O&M cost curves developed for

Figure 7-2  
Sodium Hydroxide Capital Cost Curve





Figure 7-3  
Sodium Hydroxide O&M Cost Curve



ferric chloride feed systems are based upon the calculated dosage and are presented as Equations 7-3 and 7-4, respectively.

$$\ln(Y) = 11.199 - 0.136\ln(X) + 0.054\ln(X)^2 \quad (7-3)$$

$$\ln(Y) = 8.808 - 0.408\ln(X) + 0.074\ln(X)^2 \quad (7-4)$$

where:

X = Dosage Rate (lb/hr), and

Y = Cost (1992 \$)

Figures 7-4 and 7-5 graphically present the ferric chloride feed system capital and O&M cost curves, respectively. Costs for ferric chloride feed facilities are based on storage and feeding a 43 percent solution of ferric chloride with a weight of 12 pounds per gallon (5.2 lbs dry ferric chloride/gallon). The solution is stored in covered fiberglass reinforced polyester tanks designed to hold a 15 day supply. Cost estimates include dual-head metering pumps (one standby) with materials suitable for ferric chloride and 150 feet of stainless steel pipe and associated valves. Automatic or feed back controls are excluded.

### **Sodium Bisulfite Feed Systems**

Sodium bisulfite feed systems were costed using the WWC unit process 42. Costs were based upon a stoichiometric requirement of 2.81 mg/l of sodium bisulfite per 1 mg/l of total chromium. The capital and O&M cost curves developed for sodium bisulfite feed systems are based upon the calculated dosage and are presented as Equations 7-7 and 7-8, respectively.

$$\ln(Y) = 10.822452 - 0.010997\ln(X) + 0.038691\ln(X)^2 \quad (7-7)$$

$$\ln(Y) = 8.418772 + 0.51824\ln(X) + 0.039838\ln(X)^2 \quad (7-8)$$

where:

X = Dosage Rate (lb/hr), and

Y = Cost (1992 \$)

Figure 7-4  
 Ferric Chloride Capital Cost Curve





Figure 7-5  
 Ferric Chloride O&M Cost Curve



Figures 7-6 and 7-7 graphically present the sodium bisulfite feed system capital and O&M cost curves, respectively.

A 5 minute detention period is provided in the dissolving tank. Fifteen days of storage is included using mild steel storage hoppers which are located indoors. Sodium bisulfite is conveyed pneumatically from bulk delivery trucks to the hoppers, with the blower located on the delivery truck. Hopper costs include dust collectors. Bag loaders are used on the feeder in systems too small for bulk systems. Volumetric feeders are used for all installations. Solution tanks are located directly beneath the storage hoppers. Conveyance from the solution tanks to the point of application is by dual-head diaphragm metering pumps.

### **Hydrochloric Acid Feed Systems**

Hydrochloric acid is necessary to neutralize the waste stream or adjust the waste stream for chemical treatment. The amount necessary was calculated using the following equation.

$$mg/L \ H_2SO_4 = (10^{-initial \ pOH} - 10^{-final \ pOH}) \left( \frac{mol \ OH^-}{1 \ L} \right) \left( \frac{1 \ mol \ H_2SO_4}{2 \ mol \ H^+} \right) \left( \frac{98,000 \ mg}{1 \ mol \ H_2SO_4} \right)$$

To allow for solution buffering, 10 percent excess acid was added.

Hydrochloric acid feed systems were costed using the WWC unit process 46. The capital and O&M cost curves developed for hydrochloric acid feed systems, based upon the calculated feed rate, are presented as Equations 7-9 and 7-10, respectively.

$$\ln(Y) = 10.431273 - 0.196812\ln(X) + 0.044247\ln(X)^2 \quad (7-9)$$

$$\ln(Y) = 7.630396 + 0.312305\ln(X) - 0.002419\ln(X)^2 \quad (7-10)$$

where:

X = Feed Rate (gpd), and

Y = Cost (1992 \$)

Figures 7-8 and 7-9 graphically present the hydrochloric acid feed system capital and O&M cost curves, respectively.

Figure 7-6  
Sodium Bisulfite Capital Cost Curve




Figure 7-7  
Sodium Bisulfite O&M Cost Curve




Figure 7-8  
Hydrochloric Acid Capital Cost Curve





Figure 7-9  
Hydrochloric Acid O&M Cost Curve



Costs are based on systems capable of metering concentrated acid from a storage tank directly to the point of application. For feed rates up to up to 200 gpd, the concentrated acid is delivered in drums and stored indoors. At higher flow rates, the acid is delivered in bulk and stored outdoors in fiberglass reinforced polyester tanks. Acid is stored for 15 days, and a standby metering pump is included for all installations.

### **Polymer Feed Systems**

WWC unit process 34 was used to cost for polymer feed systems. Polymer dosage rate in lb/hr was calculated based upon a target concentration of 2 mg/l using the facility's flow rate. Although this module is designed to cost for a liquid alum feed system, costs generated by this module were determined to be more reasonable and accurate in developing polymer system costs than the WWC unit process 43 for polymer feed systems. The capital and O&M unloaded cost curves developed for polymer feed systems are presented as Equations 7-11 and 7-12, respectively.

$$\ln(Y) = 10.539595 - 0.13771\ln(X) + 0.052403\ln(X)^2 \quad (7-11)$$

$$\ln(Y) = 9.900596 + 0.99703\ln(X) + 0.00019\ln(X)^2 \quad (7-12)$$

where:

X = Dosage Rate (lb/hr), and

Y = Cost (1992 \$)

Figures 7-10 and 7-11 graphically present the polymer feed system capital and O&M cost curves, respectively.

Polymer is stored for 15 days in fiberglass reinforced polyester tanks. For smaller installations, the tanks are located indoors and left uncovered, and for larger installations the tanks are covered and vented, with insulation and heating provided. Dual-head metering pumps deliver the polymer from the storage tank and meter the flow to the point of application. Feed costs include 150 feet of 316 stainless steel pipe, along with fittings and valves, for each metering pump. A standby metering pump is included for each installation.

# Figure 7-10 Polymer Feed Capital Cost Curve





Figure 7-11  
Polymer Feed O&M Cost Curve



### 7.3.1.2 Pumping

Wastewater pumping costs were estimated using WWC unit process 92, and are based on flow rate. The capital and O&M cost curves developed for pumping are presented as Equations 7-13 and 7-14, respectively.

$$\ln(Y) = 10.048 + 0.167\ln(X) - 0.001\ln(X)^2 \quad (7-13)$$

$$\ln(Y) = 7.499 + 0.024\ln(X) + 0.0429\ln(X)^2 \quad (7-14)$$

where:

X = Flow Rate (gpm), and

Y = Cost (1992 \$)

Figures 7-12 and 7-13 graphically present the pumping capital and O&M cost curves, respectively.

### 7.3.1.3 Rapid Mix Tanks

Capital and O&M costs for rapid mix tanks were estimated using the WWC unit process 104 and are based on reinforced concrete basins. The capital and O&M cost curves developed for rapid mix tanks based upon flow rate are presented as Equations 7-15 and 7-16, respectively.

$$\ln(Y) = 12.234467 - 0.677898\ln(X) + 0.078143\ln(X)^2 \quad (7-15)$$

$$\ln(Y) = 10.730231 + 0.614141\ln(X) + 0.083221\ln(X)^2 \quad (7-16)$$

where:

X = Flow Rate (MGD), and

Y = Cost (1992 \$)

Figures 7-14 and 7-15 graphically present the rapid mix tank capital and O&M cost curves, respectively.

Common wall construction is assumed for multiple basins. Costs include vertical shaft, variable speed turbine mixers with 304 stainless steel shafts, paddles, and motors. Costs are based

Figure 7-12  
Wastewater Pumping Capital Cost Curve




Figure 7-13  
Wastewater Pumping O&M Cost Curve




Figure 7-14  
Mix Tank Capital Cost Curve





Figure 7-15  
Mix Tank O&M Cost Curve



on a G value (G is the mean temporal velocity gradient which describes the degree of mixing; i.e., the greater the value of G the greater the degree of mixing) of 300 (3 ft-lbs/sec/cu. ft.) and a water temperature of 15°C. The energy requirements are a function of G value, water temperature, and an overall mechanism efficiency of 70 percent.

#### 7.3.1.4 Flocculation

A cost curve was developed for flocculation using the WWC cost program. WWC unit process 72 was used. Costs for flocculation were based upon a function of flow at a hydraulic detention time of 20 minutes. The capital and O&M cost curves developed for flocculation are presented as Equations 7-17 and 7-18, respectively.

$$\ln(Y) = 11.744579 + 0.633178\ln(X) - 0.015585\ln(X)^2 \quad (7-17)$$

$$\ln(Y) = 8.817304 + 0.533382\ln(X) + 0.002427\ln(X)^2 \quad (7-18)$$

where:

X = Flow Rate (MGD), and

Y = Cost (1992 \$)

Figures 7-16 and 7-17 graphically present the flocculation capital and O&M cost curves, respectively. Cost estimates for flocculation basins are based on rectangular-shaped, reinforced concrete structures with a depth of 12 feet and length-to-width ratio of 4:1. Horizontal paddle flocculators were used in costing because they are less expensive and more efficient. Manufactured equipment costs are based on a G value (G is the mean temporal velocity gradient which describes the degree of mixing; i.e., the greater the value of G the greater the degree of mixing) of 80. Cost estimates for drive units are based on variable speed drives for maximum flexibility, and although common drives for two or more parallel basins are often utilized, the costs are based on individual drives for each basin.

Energy requirements are based on a G value 80 and an overall motor/mechanism efficiency of 60 percent. Labor requirements are based on routine operation and maintenance of 15 min/day/basin and a 4 hour oil change every 6 months.

# Figure 7-16 Flocculation Capital Cost Curve





Figure 7-17  
Flocculation O&M Cost Curve



### 7.3.1.5 Primary Clarification

Cost curves were developed for primary clarification using the WWC cost program. WWC unit process 118 for a rectangular basin with a 12 foot side wall depth was used. Costs for primary clarification were based upon a function of flow rate, using an overflow rate of 900 gallons per day per square feet in calculating tank size. The capital and O&M cost curves developed for primary clarification are presented as Equations 7-19 and 7-20, respectively.

$$\ln(Y) = 12.517967 + 0.575652\ln(X) + 0.009396\ln(X)^2 \quad (7-19)$$

$$\ln(Y) = 10.011664 + 0.268272\ln(X) + 0.00241\ln(X)^2 \quad (7-20)$$

where:

X = Flow Rate (MGD), and

Y = Cost (1992 \$)

Figures 7-18 and 7-19 graphically present the primary clarification capital and O&M cost curves, respectively.

Estimated costs are based on rectangular basins with a 12 foot side water depth (SWD), and chain and flight sludge collectors. Costs for the structure assumed common wall construction, and include the chain and flight collector, collector drive mechanism, weirs, the reinforced concrete structure complete with inlet and outlet troughs, a sludge sump, and sludge withdrawal piping.

### 7.3.1.6 Secondary Clarification

Cost curves were developed for secondary clarification using the WWC cost program. WWC unit process 118 for a rectangular basin with a 12 foot side wall depth, and chain and flight collectors was used. Costs for secondary clarification were based upon a function of flow rate, using an overflow rate of 600 gallons per day per square feet in calculating tank size. The capital and O&M cost curves developed for secondary clarification are presented as Equations 7-21 and 7-22, respectively.

# Figure 7-18 Primary Clarifier Capital Cost Curve





Figure 7-19  
Primary Clarifier O&M Cost Curve



$$\ln(Y) = 12.834601 + 0.688675\ln(X) + 0.035432\ln(X)^2 \quad (7-21)$$

$$\ln(Y) = 10.197762 + 0.339952\ln(X) + 0.015822\ln(X)^2 \quad (7-22)$$

where:

X = Flow Rate (MGD), and

Y = Cost (1992 \$)

Figures 7-20 and 7-21 graphically present the secondary clarification capital and O&M cost curves, respectively. Costs for the structure assumed common wall construction, and include the chain and flight collector, collector drive mechanism, weirs, the reinforced concrete structure complete with inlet and outlet troughs, a sludge sump, and sludge withdrawal piping. Yard piping to and from the clarifier is not included in the above costs, but accounted for by the engineering cost factors.

#### 7.3.1.7 Multimedia Filtration

A capital cost curve, as a function of flow rate, was developed for a multimedia filtration system using vendor supplied quotes. The cost curve used in this study was developed as part of the CWT effluent guidelines effort. The capital cost curve developed for multimedia filtration is presented as Equation 7-23.

$$\ln(Y) = 12.265 + 0.658\ln(X) + 0.036\ln(X)^2 \quad (7-23)$$

where:

X = Flow Rate (MGD), and

Y = Capital Cost (1992 \$)

O&M costs for filter operation were estimated as 50 percent of the capital cost. Figure 7-22 graphically presents the multimedia filtration capital cost curve.

The total capital costs for the multimedia filtration systems represent equipment and installation costs. The total construction cost includes the costs of the filter, instrumentation and

# Figure 7-20 Secondary Clarifier Capital Cost Curve




Figure 7-21  
Secondary Clarifier O&M Cost Curve





Figure 7-22  
Multimedia Filtration Capital Cost Curve



controls, pumps, piping, and installation. The operation and maintenance costs include energy usage, maintenance, labor, taxes, and insurance.

### **7.3.2      *Sludge Treatment and Disposal***

The method of developing sludge treatment and disposal costs are presented in the following sections.

#### **7.3.2.1      Plate and Frame Pressure Filtration**

Regulatory costs for sludge dewatering were developed using cost curves from the CWT effluent guideline effort. Costs are for a sludge dewatering system using a plate and frame pressure filter, and are based upon flow rate. Only facilities without installed sludge treatment were costed.

The capital and O&M cost curves developed for a plate and frame filter press sludge dewatering are presented as Equations 7-24 and 7-25, respectively.

$$\ln(Y) = 15.022877 + 1.1199216\ln(X) + 0.063001\ln(X)^2 \quad (7-24)$$

$$\ln(Y) = 12.52046 + 0.713233\ln(X) + 0.066701\ln(X)^2 \quad (7-25)$$

where:

X = Flow (MGD), and

Y = Cost (1992 \$)

Figures 7-23 and 7-24 graphically present the plate and frame sludge dewatering capital and O&M cost curves, respectively. For facilities with a flow rate of less than 1,500 gallons per day, the O&M costs were estimated as 50 percent of the capital cost.

The components of the plate and frame pressure filtration system include: filter plates, filter cloth, hydraulic pumps, pneumatic booster pumps, control panel, connector pipes, and support platform. Equipment and operational costs were obtained from manufacturers' recommendations. The capital cost equation was developed by adding installation, engineering, and contingency costs to the vendors' equipment costs. The O&M costs were based on estimated electricity usage,

# Figure 7-23

## Sludge Dewatering Capital Cost Curve





Figure 7-24  
Sludge Dewatering O&M Cost Curve



maintenance, labor, taxes and insurance, and filter cake disposal costs. The labor requirement for the plate and frame pressure filtration system was approximated at 30 minutes per cycle per filter press.

#### **7.3.2.2 Filter Cake Disposal Costs**

Filter cake was costed for off-site disposal at a landfill. A facility's filter cake generation was calculated using the difference between the facility's loadings and allowable effluent concentration. A facility's total influent loading was calculated by taking the sum of the average metals and TSS concentrations multiplied by the baseline flow. Effluent concentrations were developed similarly using the LTAs for each option. Then, the sludge generation in the treatment system was calculated as the influent loading minus the amount in effluent loading, converted to an annual amount (lbs/yr). The amount of treatment chemicals added to the system (based upon BPT/PSES option) was also included in the calculation of sludge generation. The amount of total sludge generated in the treatment system was then converted to a wet weight basis assuming 35 percent solids filter cake. Off-site disposal costs were estimated at \$0.19/lb and was based upon the medium cost reported by IWC facilities in questionnaire responses. This cost includes transportation, handling, conditioning, and disposal of the cake. Costs are based upon a filter cake of 35 percent solids.

#### **7.4 *ADDITIONAL COSTS***

In order to complete the costing for each proposed regulatory option, costs other than treatment component costs were developed. These additional costs are required in order to accommodate for other costs associated with the development of the guideline. The following additional costs were included in the total guideline option costs for each facility, as needed:

- retrofit
- monitoring
- RCRA permit modifications
- land costs

Each of these additional costs are further discussed and defined in the following sections. Total facility compliance costs under each proposed BPT/BAT and PSES option were developed by adding individual treatment technology costs with these additional costs.

Final capital costs developed for each facility were then amortized using a 7 percent interest rate over 15 years. This annualized capital cost was then added to the annual O&M cost to develop a total annual cost for each guideline option.

#### **7.4.1      *Retrofit and Upgrade Costs***

A retrofit cost factor was applied when additional equipment or processes were needed to be added to existing systems. Retrofit costs cover the need for system modifications and components, such as piping, valves, controls, etc., which are necessary in order to connect new treatment units and processes to an existing treatment facility. An upgrade cost factor was also applied to allow for existing treatment systems to be enhanced to provide sufficient treatment capability. The combined retrofit and upgrade cost factor was estimated at 25 percent of the installed capital cost of the equipment.

#### **7.4.2      *Land Costs***

Land costs provide for the value of the land requirements needed for the installation of the proposed treatment technology. Land costs were estimated based upon the expected land requirements for the proposed new treatment units. Land size increments of either 0.5, 1 or 2 acres were used depending on the expected size of the required treatment system.

Land costs vary greatly across the country depending upon the region and state. Therefore, a national average would not be appropriate for costing purposes. State-specific unit land costs (\$/acre) were developed for each state. These state-specific unit land costs were based upon the average land costs for suburban sites in each state and were obtained from the 1990 Guide to Industrial and Real Estate Office Markets Survey. Costs were corrected to 1992 dollars using engineering cost factors.

According to the survey, unimproved sites are the most desirable location for development and are generally zoned for industrial usage. State-specific unit land costs were developed by

averaging the reported unimproved site survey data for the various size ranges (zero to 10 acres, 10 to 100 acres, and greater than 100 acres). Regional averages were used for states which did not have data provided. Hawaii was not used in developing regional average costs, due to extremely high costs. Table 7-8 presents the developed state-specific unit land costs used in costing. Facility land costs in the proposed regulatory options varied from \$11,500 to \$237,628.

#### **7.4.3      *RCRA Permit Modification Costs***

A cost associated with the modification of an existing RCRA Part B permit was included for all hazardous waste facilities requiring an upgrade or additional treatment processes. Legal, administrative, public relations, monitoring, and engineering fees are included in this cost. This cost was added to the installed capital for the new or modified equipment. Permit modification costs were estimated at \$50,000 for the initial new or modified equipment, with an additional \$10,000 for each new or modified piece of equipment. A permit modification cost of \$50,000 was also provided for facilities not requiring new or modified equipment in order to allow for permit modifications due to operational changes imposed by this regulation. Facility costs for permit modification in the proposed regulatory options ranged from \$50,000 to \$130,000.

#### **7.4.4      *Monitoring Costs***

Costs were developed for the monitoring of treatment system effluent. Costs were developed for both direct and indirect dischargers and were based upon the following assumptions:

- Monitoring costs are based on the number of outfalls through which wastewater is discharged. The costs associated with a single outfall is multiplied by the total number of outfalls to arrive at the total cost for a facility. The estimated monitoring costs are incremental to the costs already incurred by the facility.
- The capital costs for flow monitoring equipment are included in the estimates.

**Table 7-8. State Land Costs<sup>1</sup>**

State	Land Cost (1992 \$/acre)	State	Land Cost (1992 \$/acre)
Alabama	24,595	Nebraska	26,659
Alaska <sup>2</sup>	87,593	Nevada	39,204
Arizona	49,790	New Hampshire	57,238
Arkansas	17,170	New Jersey	96,598
California	325,000	New Mexico	29,083
Colorado	47,045	New York	118,814
Connecticut	58,570	North Carolina	36,590
Delaware	58,806	North Dakota <sup>2</sup>	22,127
Florida	68,335	Ohio	15,744
Georgia	78,408	Oklahoma	26,267
Hawaii	1,176,120	Oregon	54,886
Idaho <sup>2</sup>	87,593	Pennsylvania	34,892
Illinois	39,204	Rhode Island <sup>2</sup>	64,608
Indiana	22,764	South Carolina	23,000
Iowa	9,670	South Dakota <sup>2</sup>	22,127
Kansas	7,605	Tennessee	22,543
Kentucky	31,363	Texas	51,488
Louisiana	61,158	Utah <sup>2</sup>	87,593
Maine	21,170	Vermont <sup>2</sup>	64,608
Maryland	121,532	Virginia	43,124
Massachusetts	64,687	Washington	68,764
Michigan	14,740	West Virginia <sup>2</sup>	51,133
Minnesota	22,738	Wisconsin	18,818
Mississippi	14,113	Wyoming <sup>2</sup>	87,593
Missouri	43,124	Washington, DC	188,179
Montana <sup>2</sup>	87,593		

(1) Source: 1990 Guide to Industrial and Real Estate Office Markets Survey.

(2) No data available for State, regional average used.

- Sample collection costs (equipment and labor) and sample shipment costs are not included in the estimates because it is assumed that the facility is already conducting these activities as part of its current permit requirements.

Based upon a review of current monitoring practices at IWC facilities, many conventional and non-conventional parameters, as well as metals, are already being monitored on a routine basis. Therefore, monitoring costs were developed based upon daily monitoring of TSS and weekly monitoring of metals. Current compliance monitoring for existing facilities is generally less than the frequency used for estimating the monitoring costs of this proposal. Table 7-9 presents the monitoring costs per sample type for the IWC Industry.

**Table 7-9. Analytical Monitoring Costs**

Pollutants	Cost/Sample (\$)¹
TSS	6.00
Metals	35.00/metal

Notes:

(1) Cost based on 1995 analytical laboratory costs adjusted to 1992 dollars.

## 7.5 WASTEWATER OFF-SITE DISPOSAL COSTS

An evaluation was conducted to determine whether it would be more cost effective for low flow facilities to have their IWC wastewaters hauled off-site and treated/disposed at a centralized waste treatment facility, as opposed to on-site treatment. Total annual costs for new or upgraded wastewater treatment facilities were compared to the costs for off-site treatment at a CWT facility. Off-site disposal costs were estimated at \$0.25 per gallon of wastewater treated. Transportation costs were added to the off-site treatment costs at a rate of \$3.00 per loaded mile using an average distance of 250 miles to the treatment facility. Transportation costs were based upon the use of a 5,000-gallon tanker truck load. Facilities which treat their wastewaters off-site are considered zero

dischargers and hence do not incur ancillary costs such as residual disposal, monitoring and land, except for permit modification costs. For regulatory costing, the lower of the two costs were used; on-site verses off-site treatment. Table 7-10 presents the facilities which were costed using off-site treatment.

**Table 7-10. IWC Facilities Costed for Off-Site Disposal**

<b>Facility ID#</b>	<b>Flow (gpd)</b>	<b>BPT/PSES Option A and B Cost (\$/yr)</b>
5037	96	23,448
5624	28	10,727

## **7.6 COSTS FOR REGULATORY OPTIONS**

The following sections present the treatment costs for complying with the proposed IWC guideline for the BPT/BAT, PSES, NSPS, and PSNS options.

### **7.6.1 BPT/BAT Costs**

Two BPT/BAT options were proposed based upon the treatment technology sampled at the selected BPT/BAT facility. Engineering costs for these two BPT/BAT options are presented below.

#### **7.6.1.1 BPT/BAT Option A: Two-stage Chemical Precipitation**

BPT/BAT Option A consists of a two-stage chemical precipitation treatment system using sodium hydroxide in the first precipitation stage with ferric chloride and sodium hydroxide in the second stage. Sodium bisulfite is used at the head of the treatment system for chromium removal.

Sludge dewatering is also provided in this option. Table 7-11 presents the total capital and O&M costs for this option. This table also presents the total amortized annual cost for each facility.

#### **7.6.1.2      BPT/BAT Option B: Two-stage Chemical Precipitation and Multimedia Filtration**

BPT/BAT Option B is BPT/BAT Option A with the addition of a multimedia filter at the end of the treatment process. BPT/BAT Option B consists of a two-stage chemical precipitation treatment system using sodium hydroxide in the first precipitation stage with ferric chloride and sodium hydroxide in the second stage. Sodium bisulfite is used at the head of the treatment system for chromium removal. A multimedia filter is provided at the end of the treatment system to polish the effluent. Sludge dewatering is also provided in this option. Table 7-12 presents the total capital and O&M costs for this option. This table also presents the total amortized annual cost for each facility.

#### **7.6.2      PSES Costs**

Two PSES options were proposed based upon the technology sampled at the selected BPT/BAT facility. These two PSES options are equivalent to the two BPT/BAT options presented above. Engineering costs for these two PSES options are presented below.

##### **7.6.2.1      PSES Option A: Two-stage Chemical Precipitation**

PSES Option A consists of a two-stage chemical precipitation treatment system using sodium hydroxide in the first precipitation stage with ferric chloride and sodium hydroxide in the second stage. Sodium bisulfite is used at the head of the treatment system for chromium removal. Sludge dewatering is also provided in this option. This PSES option is equivalent to BPT/BAT Option A. Table 7-11 (previously referenced) presents the total capital and O&M costs for this option. This table also presents the total amortized annual cost for each facility.

Table 7-11. Summary of Costs - BPT/BCT/BAT/PSES Option A

ID#	DISCHARGE STATUS	AVERAGE FLOW RATE (gpd)	CAPITAL COSTS (\$)					TOTAL CAPITAL	AMORTIZED TOTAL CAPITAL* (SYR)	O & M COSTS (SYR)				TOTAL ANNUAL COST (SYR)
			EQUIPMENT	RETROFIT & UPGRADE	PERMIT MODIFICATION	LAND				EQUIPMENT	SOLIDS DISPOSAL	MONITORING	TOTAL O & M	
5716	direct	144,290	543,715	135,929	90,000	61,158	830,802	91,218	106,874	8,382	28,554	143,810	235,028	
5737	direct	174,360	0	0	50,000	0	50,000	5,490	0	0	27,458	27,458	32,948	
5761	direct	510,490	880,521	220,130	90,000	193,198	1,383,849	151,939	178,681	23,543	27,108	229,332	381,271	
5765	direct	47,340	716,975	0	120,000	237,638	1,074,603	117,986	164,028	29,684	17,670	211,382	329,367	
5782	direct	114,010	496,348	124,087	90,000	23,000	733,435	80,527	100,143	6,679	18,288	125,110	205,638	
5797	direct	135,580	528,301	132,075	90,000	51,488	801,864	88,040	104,742	6,124	18,570	129,436	217,476	
5798	direct	1,007,640	661,474	165,369	70,000	102,976	999,819	109,775	138,227	48,025	27,046	213,298	323,072	
5824	direct	28	0	0	50,000	0	50,000	5,490	0	0	0	5,238	10,727	
5720	indirect	113,870	1,123,175	0	120,000	45,530	1,288,705	141,493	254,706	77,802	31,310	363,818	505,311	
5775	indirect	111,860	501,686	125,422	90,000	34,892	752,000	82,566	100,874	20,430	25,850	147,154	229,719	
5037	indirect	96	0	0	50,000	0	50,000	5,490	0	0	0	17,958	23,448	
INDUSTRY TOTALS			5,452,195	903,011	910,000	749,870	8,015,076	880,012	1,148,275	220,669	221,851	1,613,994	2,494,006	
DIRECT TOTALS			3,827,334	777,590	650,000	669,448	5,924,372	650,464	792,695	122,437	164,694	1,085,063	1,735,528	
INDIRECT TOTALS			1,624,861	125,422	260,000	80,422	2,090,705	229,548	355,580	98,232	57,160	528,930	758,478	

\* Assuming 7% interest over a fifteen year period.

NOTE: Due to low flow, costs for 5037 and 5624 were calculated based on off-site disposal cost

Table 7-12. Summary of Costs - BPT/BCT/BAT/PSES Option B

ID#	DISCHARGE STATUS	AVERAGE FLOW RATE (gpd)	CAPITAL COSTS (\$)				TOTAL CAPITAL	ANORTIZED TOTAL CAPITAL* (\$/YR)	O & M COSTS (\$/YR)				TOTAL ANNUAL COST (\$/YR)
			EQUIPMENT	RETROFIT & UPGRADE	PERMIT MODIFICATION	LAND			EQUIPMENT	SOLIDS DISPOSAL	MONITORING	O & M	
5716	direct	144,290	611,635	152,909	100,000	61,158	925,701	101,637	140,834	9,572	28,554	178,960	280,597
5737	direct	171,360	0	0	50,000	0	50,000	5,490	0	0	27,458	27,458	32,948
5761	direct	510,490	880,521	220,130	90,000	193,198	1,383,849	151,939	178,681	27,681	27,108	233,470	385,409
5765	direct	47,340	756,822	0	130,000	237,628	1,124,450	123,459	183,952	30,162	17,670	231,784	355,242
5782	direct	114,010	496,348	124,087	90,000	23,000	733,435	80,527	100,143	6,684	18,288	125,115	205,642
5797	direct	135,580	528,301	132,075	90,000	51,488	801,864	88,040	104,742	7,179	18,570	130,491	218,531
5798	direct	1,007,640	874,679	218,670	80,000	102,916	1,276,325	140,131	244,830	50,603	27,046	322,479	462,612
5624	direct	28	0	0	50,000	0	50,000	5,490	0	0	0	5,238	10,727
5720	indirect	113,870	1,183,508	0	130,000	45,530	1,358,898	149,200	284,802	78,952	31,310	395,065	544,264
5775	indirect	111,860	501,686	125,422	90,000	34,892	752,000	82,566	100,874	21,457	25,850	148,181	230,747
5037	indirect	96	0	0	50,000	0	50,000	5,490	0	0	0	17,958	23,448
INDUSTRY TOTALS			5,833,360	973,292	930,000	749,870	8,506,522	933,970	1,338,857	232,291	221,854	1,816,198	2,750,169
DIRECT TOTALS			4,148,306	847,871	680,000	669,448	6,345,625	696,716	953,181	131,882	164,694	1,254,995	1,951,710
INDIRECT TOTALS			1,685,054	125,422	270,000	80,422	2,160,897	237,255	385,676	100,409	57,160	561,204	798,459

\* Assuming 7% interest over a fifteen year period.

NOTE: Due to low flow, costs for 5037 and 5624 were calculated based on off-site disposal cost

#### **7.6.2.2 PSES Option B: Two-stage Chemical Precipitation and Multimedia Filtration**

PSES Option B consists of a two-stage chemical precipitation treatment system using sodium hydroxide in the first precipitation stage with ferric chloride and sodium hydroxide in the second stage. Sodium bisulfite is used at the head of the treatment system for chromium removal. A multimedia filter is provided at the end of the treatment system. Sludge dewatering is also provided in this option. This PSES option is equivalent to BPT/BAT Option B. Table 7-12 (previously referenced) presents the total capital and O&M costs for this option. This table also presents the total amortized annual cost for each facility.

#### **7.6.3 *New Source Performance Standards Costs***

The proposed New Source Performance Standards (NSPS) for the IWC Industry is equivalent to the limitations proposed for BPT/BCT/BAT Option B. Therefore, NSPS consists of a two-stage chemical precipitation treatment system using sodium hydroxide in the first precipitation stage with ferric chloride and sodium hydroxide in the second stage. Sodium bisulfite is used at the head of the treatment system for chromium reduction. A multimedia filter is provided at the end of the treatment system to polish the effluent. Sludge dewatering is also provided in this option. NSPS costs were estimated using an industry average flow rate of approximately 214,500 gpd and loadings similar to the representative BPT/BAT facility (see Section X.0). The total NSPS amortized annual cost is \$527,322 assuming an average facility daily flow of 214,500 gpd. A breakdown of the NSPS capital and O&M costs are presented on Table 7-13.

#### **7.6.4 *Pretreatment Standards for New Sources Costs***

The proposed Pretreatment Standards for New Sources (PSNS) for the IWC Industry is equivalent to the limitations proposed for PSES Option A. This option is also equivalent to BPT, BCT, and BAT Option A. Therefore, PSNS consists of a two-stage chemical precipitation treatment system using sodium hydroxide in the first precipitation stage with ferric chloride and sodium hydroxide in the second stage. Sodium bisulfite is used at the head of the treatment system for chromium reduction. Sludge dewatering is also provided in this option. PSNS costs were estimated

Table 7-13. Summary of Costs - NSPS/PSNS

TYPE	AVERAGE FLOW RATE (gpd)	CAPITAL COSTS (\$)					AMORTIZED TOTAL CAPITAL* (\$/YR)	O & M COSTS (\$/YR)				TOTAL ANNUAL COST (\$/YR)
		EQUIPMENT	RETROFIT & UPGRADE	PERMIT MODIFICATION	LAND	TOTAL CAPITAL		EQUIPMENT	SOLIDS DISPOSAL	MONITORING	TOTAL O & M	
NSPS	214,506	1,500,598	0	130,000	149,176	1,869,774	205,291	278,658	12,063	31,310	322,030	527,322
PSNS	214,506	1,506,698	0	120,000	149,176	1,775,874	194,981	236,708	11,165	31,310	279,183	474,164

\* Assuming 7% interest over a fifteen year period.

using an industry average flow rate of approximately 214,500 gpd and loadings similar to the representative BPT/BAT facility (see Section X.0). The total PSNS amortized annual cost is \$474,164 assuming an average facility flow of 214,500 gpd. A breakdown of the PSNS capital and O&M costs are presented on Table 7-13, referenced above.

## **SECTION 8**

### **DEVELOPMENT OF LIMITATIONS AND STANDARDS**

This section describes various waste treatment technologies and their costs, pollutants proposed for regulation, and pollutant reductions associated with the different treatment technologies evaluated for the proposed effluent limitations guidelines and standards for the Industrial Waste Combustor (IWC) Industry. The limitations and standards discussed in this section are Best Practicable Control Technology Currently Available (BPT), Best Conventional Pollutant Control Technology (BCT), Best Available Technology Economically Achievable (BAT), New Source Performance Standards (NSPS), Pretreatment Standards for Existing Sources (PSES), and Pretreatment Standards for New Sources (PSNS).

#### **8.1            *ESTABLISHMENT OF BPT***

Generally, EPA bases BPT upon the average of the best current performance (in terms of pollutant removals in treated effluent) by facilities of various sizes, ages, and unit processes within an industry subcategory. The factors considered in establishing BPT include: (1) the total cost of applying the technology relative to pollutant reductions, (2) the age of process equipment and facilities, (3) the processes employed and required process changes, (4) the engineering aspects of the control technology, (5) non-water quality environmental impacts such as energy requirements, air pollution, and solid waste generation, and (6) such other factors as the Administrator deems appropriate (Section 304(b)(2)(B) of the Act). As noted, BPT technology represents the average of the best existing performances of facilities within the industry. EPA looks at the performance of the best operated treatment systems and calculates limitations from some level of average performance of these "best" facilities. For example, in the BPT limitations for the OCPSF Category, EPA identified "best" facilities on a BOD performance criteria of achieving a 95 percent BOD removal or a BOD effluent level of 40 mg/l (52 FR 42535, November 5, 1987). When existing performance is uniformly inadequate, EPA may require a higher level of control than is currently in place in an industrial category if EPA determines that the technology can be practically applied. BPT may be transferred from a different subcategory or category. However, BPT normally focuses on end-of-

process treatment rather than process changes or internal controls, except when these technologies are common industry practice.

The cost/effluent reduction inquiry for BPT is a limited balancing one, committed to EPA's discretion, that does not require the Agency to quantify effluent reduction benefits in monetary terms. (See, e.g., *American Iron and Steel v. EPA*, 526 F. 2d 1027 (3rd Cir., 1975.)) In balancing costs against the effluent reduction benefits, EPA considers the volume and nature of discharges expected after application of BPT, the general environmental effects of pollutants, and the cost and economic impacts of the required level of pollution control. In developing guidelines, the Act does not require or permit consideration of water quality problems attributable to particular point sources, or water quality improvements in particular bodies of water. Therefore, EPA has not considered these factors in developing the proposed limitations. (See *Weyerhaeuser Company v. Costle*, 590 F. 2d 1011 (D.C. Cir. 1978)).

EPA concluded that the wastewater treatment performance of the facilities it surveyed was, with very limited exceptions, inadequate and that only two facilities are using best practicable, currently available technology. Even at these two facilities, only one had a significant amount of pollutants at "treatable levels". Thus, the proposed BPT effluent limitations will be based on the data from this one treatment system only.

As pointed out previously, IWC facilities burn highly variable wastes that, in many cases, are process residuals and sludges from other point source categories. The wastewater produced in combustion of these wastes contains a wide variety of metals. Chemical precipitation for these metals at a single pH is not adequate treatment for metals removal from such a highly variable waste stream. EPA's review of existing permit limitations for the direct dischargers show that, in most cases, the dischargers are subject to "best professional judgment" concentration limitations which were developed from guidelines for facilities treating and discharging much more specific waste streams (e.g., OCPSF limitations).

In determining BPT, EPA evaluated metals precipitation as the principal treatment practice within the IWC Industry. Nine of the eleven facilities in the Industry use some type of metals precipitation as a means for waste treatment. The precipitation techniques used by facilities varied in the treatment chemicals used and in the number of stages of precipitation used.

The two currently available treatment systems for which the EPA assessed performance for BPT are:

- *Option A : Primary Precipitation, Solid-Liquid Separation, Secondary Precipitation, and Solid-Liquid Separation.* Under Option A, BPT limitations would be based upon two stages of chemical precipitation, each followed by some form of separation and sludge dewatering. The pH levels used for the two stages of chemical precipitation would be different in order to promote optimal removal of metals because different metals are preferentially removed at different pH levels. In addition, the first stage of chemical precipitation is preceded by chromium reduction, when necessary. In some cases, BPT limitations would require the current treatment technologies in place to be improved by use of increased quantities of treatment chemicals and additional chemical precipitation/sludge dewatering systems.
- *Option B : Primary Precipitation, Solid-Liquid Separation, Secondary Precipitation, Solid-Liquid Separation, and Sand Filtration.* The second option evaluated for BPT for Industrial Waste Combustor facilities would be based on the same technology as Option A with the addition of sand filtration at the end of the treatment train.

The Agency is proposing to adopt BPT effluent limitations for 11 pollutants based on Option B for the Industrial Waste Combustor Industry. These limitations were developed based on an engineering evaluation of the average level of pollutant reduction achieved through application of the best practical control technology currently available for the discharges of the regulated pollutants. The proposed daily maximum and monthly average BPT limitations for the IWC Industry are presented in Table 8-1. Long-term averages, daily variability factors, and monthly variability factors for Option B are also presented in Table 8-1. A combination of two different methodologies was used in the development of the variability factors (monthly and daily) for this option. Specifically, pollutant-specific variability factors were calculated and used when a metal pollutant was detected a sufficient number of times in the effluent sampling data. However, when a metal pollutant could not be calculated using the effluent sampling data, a group-level variability factor was used. The

group-level variability factor is the median of the pollutant-level variability factors calculated for the entire group of metals found in significant concentrations in the IWC Industry. See Section 5.2.2, Tables 5-2, 5-3, and 5-4 for a complete list of the metals included in the analysis. The *Statistical Support Document of Proposed Effluent Limitations Guidelines and Standards for Industrial Waste Combustors* (EPA 821-B-97-008) provides more detailed information on the development of the limitations for this option.

**Table 8-1. BPT Effluent Limitations (mg/l)**

<b>Pollutant or Pollutant Parameter</b>	<b>Long-Term Average (mg/l)</b>	<b>Daily Variability Factor (Rounded)</b>	<b>Monthly Variability Factor (Rounded)</b>	<b>Maximum for Any One Day (mg/l)</b>	<b>Monthly Average (mg/l)</b>
<b>Conventional Pollutants</b>					
<b>TSS</b>	5.84	4.2	1.3	24.3	7.46
<b>pH</b>					(1)
<b>Priority and Non-Conventional Pollutants</b>					
<b>Arsenic</b>	0.00827	8.3	2.0	0.0166	0.0162
<b>Cadmium</b>	0.0220	6.2	2.2	0.137	0.0493
<b>Chromium</b>	0.0100	2.0	1.3	0.0205	0.0130
<b>Copper</b>	0.0103	2.2	1.3	0.0224	0.0131
<b>Lead</b>	0.0468	2.0	1.3	0.0957	0.0606
<b>Mercury</b>	0.00200	2.0	1.3	0.00409	0.00259
<b>Silver</b>	0.00500	2.0	1.3	0.0102	0.00648
<b>Titanium</b>	0.00738	6.0	2.2	0.0442	0.0159
<b>Zinc</b>	0.0243	2.2	1.5	0.0532	0.0354

(1) Within the range 6.0 to 9.0 pH units.

EPA's tentative decision to base BPT limitations on Option B treatment reflects primarily an

evaluation of three factors: the degree of effluent reduction attainable, the total cost of the proposed treatment technologies in relation to the effluent reductions achieved, and potential non-water quality benefits. No basis could be found for identifying different BPT limitations based on age, size, process or other engineering factors. Neither the age nor the size of the IWC facility will significantly affect either the character or treatability of the wastes or the cost of treatment. Further, the treatment process and engineering aspects of the technologies considered have a relatively insignificant effect because in most cases they represent fine tuning or add-ons to treatment technology already in use. These factors consequently did not weigh heavily in the development of these guidelines.

The demonstrated effluent reductions attainable through the Option B control technology represent the BPT performance attainable through the application of demonstrated treatment measures currently in operation in this industry. Option B was chosen for the following reasons. First, these removals are demonstrated by a facility and can readily be applied to all facilities. The adoption of this level of control would represent a significant reduction in pollutants discharged into the environment (from 181,000 to 54,000 pounds of TSS and metals). Second, the Agency assessed the total cost of water pollution controls likely to be incurred for Option B in relation to the effluent reduction and determined these costs were economically reasonable.

EPA estimated the cost of installing Option A and B BPT technologies at the direct discharging facilities. The pretax total estimated annualized cost in 1992 dollars is approximately \$1.736 million (if BPT is Option A) and approximately \$1.952 million (if BPT is Option B). EPA concluded the cost of installation of either of these control technologies is clearly economically achievable. EPA's assessment shows that none of the direct discharging facilities will experience a line closure as a result of the installation of the necessary technology.

The Agency proposes to select Option B because, EPA concluded that the use of sand filtration as the final treatment step is the best practicable treatment technology currently in operation for the industry. Consequently, effluent levels associated with this treatment option would represent BPT performance levels. Also, Option A was rejected because the greater removals obtained through the addition of sand filtration at Option B were obtained at a relatively insignificant increase in costs over Option A.

## 8.2 *BCT*

EPA is proposing BCT equivalent to the BPT guidelines for the conventional pollutants covered under BPT. In developing BCT limits, EPA considered whether there are technologies that achieve greater removals of conventional pollutants than proposed for BPT, and whether those technologies are cost-reasonable according to the BCT Cost Test. EPA identified no technologies that can achieve greater removals of conventional pollutants than proposed for BPT that are also cost-reasonable under the BCT Cost Test, and accordingly, EPA proposes BCT effluent limitations equal to the proposed BPT effluent limitations guidelines and pretreatment standards.

## 8.3 *BAT*

EPA is proposing BAT effluent limitations for the Industrial Waste Combustor Industry based upon the same technologies evaluated and proposed for BPT. The proposed BAT effluent limitations would control identified priority and non-conventional pollutants discharged from facilities. EPA has not identified any more stringent treatment technology option which it considered to represent BAT level of control applicable to facilities in this industry. EPA considered and rejected zero discharge as possible BAT technology for the reasons explained below.

## 8.4 *NSPS*

As previously noted, under Section 306 of the Act, new industrial direct dischargers must comply with standards which reflect the greatest degree of effluent reduction achievable through application of the best available demonstrated control technologies. Congress envisioned that new treatment systems could meet tighter controls than existing sources because of the opportunity to incorporate the most efficient processes and treatment systems into plant design. Therefore, Congress directed EPA to consider the best demonstrated process changes, in-plant controls, operating methods and end-of-pipe treatment technologies that reduce pollution to the maximum extent feasible.

EPA is proposing NSPS that would control the same conventional, priority, and non-conventional pollutants proposed for control by the BPT effluent limitations. The technologies used

to control pollutants at existing facilities are fully applicable to new facilities. Furthermore, EPA has not identified any technologies or combinations of technologies that are demonstrated for new sources that are more effective than those used to establish BPT/BCT/BAT for existing sources. Therefore, EPA is proposing NSPS limitations that are identical to those proposed for BPT/BCT/BAT.

EPA is specifically considering whether it should adopt BPT/BAT and NSPS of zero discharge, since so many facilities are currently not generating or not discharging any wastewater as a result of Industrial Waste Combustor operations (see Section 3 of this document). There are two primary means of achieving zero discharge: the use of dry scrubbing operations or off-site disposal of Industrial Waste Combustor wastewater. EPA evaluated the cost for facilities to dispose of Industrial Waste Combustor wastewater off site and found it was less expensive than on-site treatment of the wastewater for only three of the eleven facilities. EPA also evaluated the cost for facilities to burn the IWC wastewater streams they generated and found that it was also significantly more costly than wastewater treatment. EPA did not evaluate the cost for all facilities to replace their wet scrubbing systems with dry scrubbing systems, as the wet scrubbing systems have been established as the best performers (according to the HWC proposed regulation) for removing acid gases and dioxins from effluent gas streams. Also, dry scrubbing systems have the adverse affect of generating an unstable solid to be disposed of in a landfill, as opposed to the stable solids generated by wastewater treatment of air pollution control wastewater. Given the apparent environmental superiority of wet versus dry scrubbers, EPA has decided a zero discharge requirement could have unacceptable non-water quality effects. EPA also did not evaluate the cost for all facilities to recycle Industrial Waste Combustor wastewater, as EPA discovered that only certain types of air pollution control systems working in conjunction with one another are able to accomplish total recycle of wastewater. Thus, new air pollution control systems would have to be costed for all facilities along with recycling systems.

Overall, zero discharge is not being proposed as BPT/BAT because EPA believes that the cost to facilities to change current air pollution control systems are too high. Also, zero discharge is not being proposed as BPT/BAT or NSPS because the change may cause unacceptable non-water quality impacts.

Indirect dischargers in the Industrial Waste Combustor Industry, like the direct dischargers, accept for treatment wastes containing many priority and non-conventional pollutants. As in the case of direct dischargers, indirect dischargers may be expected to discharge many of these non-combustible low-volatility pollutants to POTWs at significant mass and concentration levels. EPA estimates that the three identified indirect dischargers annually discharge approximately 49,000 pounds of metals to POTWs.

Section 307(b) requires EPA to promulgate pretreatment standards to prevent pass-through of pollutants from POTWs to waters of the U.S. or to prevent pollutants from interfering with the operation of POTWs. EPA is establishing PSES for this industry to prevent pass-through of the same pollutants controlled by BAT from POTWs to waters of the U.S.

EPA considered the same two regulatory options as in the BPT/BCT/BAT analysis to reduce the discharge of pollutants by Industrial Waste Combustor facilities. The Agency is proposing to adopt PSES pretreatment standards based on Option A for the Industrial Waste Combustor Industry. The technology for Options A and B are the same except that Option A does not require the use of sand filtration as the last treatment step.

In assessing PSES, EPA considered the age, size, process, other engineering factors, and non-water quality impacts pertinent to the facilities treating wastes in this subcategory. No basis could be found for identifying different PSES standards based on age, size, process or other engineering factors.

The Agency is proposing pretreatment standards for existing sources (PSES) for all priority and non-conventional pollutants regulated under BPT/BAT. The proposed daily maximum and monthly average PSES pretreatment standards for the IWC Industry are presented in Table 8-2. Long-term averages, daily variability factors and monthly variability factors for Option A are also presented in Table 8-2. A combination of two different methodologies was used in the development of the variability factors (monthly and daily) for this option. Specifically, pollutant-specific variability factors were calculated and used when a metal pollutant was detected a sufficient number of times in the effluent sampling data. However, when a metal pollutant could not be calculated using the effluent sampling data, a group-level variability factor was used. The group-level variability factor

is the median of the pollutant-level variability factors calculated for the entire group of metals found in significant concentrations in the IWC Industry. See Section 5.2.2, Tables 5-2, 5-3, and 5-4 for a complete list of the metals included in the analysis. The *Statistical Support Document of Proposed Effluent Limitations Guidelines and Standards for Industrial Waste Combustors* (EPA 821-B-97-008) provides more detailed information on the development of the pretreatment standards for this option. These standards would apply to existing facilities in the Industrial Waste Combustor Industry that indirectly discharge wastewater to publicly-owned treatment works (POTWs). PSES set at these points would prevent pass-through of pollutants and help control sludge contamination.

**Table 8-2. PSES Pretreatment Standards (mg/l)**

<b>Pollutant or Pollutant Parameter</b>	<b>Long-Term Average (mg/l)</b>	<b>Daily Variability Factor (Rounded)</b>	<b>Monthly Variability Factor (Rounded)</b>	<b>Maximum for Any One Day (mg/l)</b>	<b>Monthly Average (mg/l)</b>
<b>Arsenic</b>	0.00952	3.4	1.8	0.0323	0.0172
<b>Cadmium</b>	0.0623	7.8	2.6	0.484	0.160
<b>Chromium</b>	0.0100	2.0	1.3	0.0203	0.0130
<b>Copper</b>	0.0196	3.5	1.6	0.0684	0.0322
<b>Lead</b>	0.0477	2.0	1.3	0.0968	0.0620
<b>Mercury</b>	0.00264	2.0	1.3	0.00536	0.00343
<b>Silver</b>	0.00949	2.0	1.3	0.0193	0.0123
<b>Titanium</b>	0.00389	3.3	1.5	0.0131	0.00614
<b>Zinc</b>	0.122	2.0	1.3	0.248	0.159

EPA estimated the cost and economic impact of installing Option A and B PSES technologies at the indirect discharging facilities. The pretax total estimated annualized cost in 1992 dollars is approximately \$758,000 (if PSES is Option A) and approximately \$798,000 (if PSES is Option B). EPA concluded the cost of installation of either of these control technologies is clearly economically achievable. EPA's assessment shows that only one of the indirect discharging facilities will experience

a line closure as a result of the installation of the necessary technology.

EPA is not, however, proposing PSES based on Option B for the following reasons. EPA has determined that, after achievements of Option A treatment levels, metal pollutants do not pass through in amounts that would justify requiring the additional Option B treatment step, sand filtration. The additional removals obtained by sand filtration are small, less than 57 lb.eq. per year discharged to receiving streams. POTW removals for the regulated pollutants range from 59 percent to 90 percent. The total additional removals associated with the Option B technology represents less than one percent of total lb.eq. removals. Consequently, requiring PSES limits based on the Option B technology is not justified by the small quantity of pollutants involved.

## 8.6 *PSNS*

Section 307(c) of the Act requires EPA to promulgate pretreatment standards for new sources (PSNS) at the same time it promulgates new source performance standards (NSPS). New indirect discharging facilities, like new direct discharging facilities, have the opportunity to incorporate the best available demonstrated technologies, process changes, in-facility controls, and end-of-pipe treatment technologies.

As set forth in Section 5.3 of this document, EPA determined that all of the pollutants selected for regulation for the Industrial Waste Combustor Industry pass-through POTWs. The same technologies discussed previously for BAT, NSPS, and PSES are available as the basis for PSNS.

EPA is proposing that pretreatment standards for new sources be set equal to PSES for priority and non-conventional pollutants. The Agency is proposing to establish PSNS for the same priority and non-conventional pollutants as are being proposed for PSES. EPA considered the cost of the proposed PSNS technology for new facilities. EPA concluded that such costs are not so great as to present a barrier to entry, as demonstrated by the fact that currently operating facilities are using these technologies. The Agency considered energy requirements and other non-water quality environmental impacts and found no basis for any different standards than the selected PSNS.

## 8.7 *COST OF TECHNOLOGY OPTIONS*

The Agency estimated the cost for Industrial Waste Combustor facilities to achieve each of

the proposed effluent limitations and standards. All cost estimates in this section are presented in 1992 dollars. The cost components reported in this section represent estimates of the investment cost of purchasing and installing equipment, the annual operating and maintenance costs associated with that equipment, additional costs for discharge monitoring, and costs for facilities to modify existing RCRA permits. The following sections present costs for BPT, BCT, BAT and PSES.

#### **8.7.1        *Proposed BPT Costs***

The Agency estimated the cost of implementing the proposed BPT effluent limitations guidelines and pretreatment standards by calculating the engineering costs of meeting the required effluent limitations for each direct discharging IWC. This facility-specific engineering cost assessment for BPT began with a review of present waste treatment technologies. For facilities without a treatment technology in place equivalent to the BPT technology, the EPA estimated the cost to upgrade its treatment technology, and to use additional treatment chemicals to achieve the new discharge standards. The only facilities given no cost for compliance were facilities with the treatment in place prescribed for the option. Details pertaining to the development of the technology costs are included in Section 7. The capital expenditures for the process change component of proposed BPT are estimated to be \$ 6.3 million with annual O&M costs of \$1.3 million for the eight facilities under Regulatory Option B, which is: *Primary Precipitation, Solid-Liquid Separation, Secondary Precipitation, Solid-Liquid Separation, and Sand Filtration.*

#### **8.7.2        *Proposed BCT/BAT Costs***

The Agency estimated that there would be no cost of compliance for implementing proposed BCT/BAT, because the technology is identical to BPT and the costs are included with proposed BPT.

#### **8.7.3        *Proposed PSES Costs***

The Agency estimated the cost for implementing proposed PSES with the same assumptions and methodology used to estimate cost of implementing BPT. The capital expenditures for the process change component of PSES are estimated to be \$2.1 million with annual O&M costs of \$528

thousand for the three facilities under Regulatory Option A, which is: *Primary Precipitation, Solid-Liquid Separation, Secondary Precipitation, and Solid-Liquid Separation.*

## **8.8            *POLLUTANT REDUCTIONS***

### **8.8.1            *Conventional Pollutant Reductions***

EPA has calculated how much the adoption of the proposed BPT/BCT limitations would reduce the total quantity of conventional pollutants that are discharged. To do this, the Agency developed an estimate of the long-term average (LTA) loading of TSS that would be discharged after the implementation of BPT. Next, the BPT/BCT LTA for TSS was multiplied by 1992 wastewater flows for each direct discharging facility in the industry to calculate BPT/BCT mass discharge loadings for TSS for each facility. The BPT/BCT mass discharge loadings were subtracted from the estimated current loadings to calculate the pollutant reductions for each facility. The Agency estimates that the proposed regulations will reduce TSS discharges by approximately 120,000 pounds per year for the eight facilities under Regulatory Option B. The current discharges and BPT/BCT discharges for TSS are listed in Table 8-3.

### **8.8.2            *Priority and Non-conventional Pollutant Reductions***

#### **8.8.2.1            *Methodology***

The proposed BPT, BCT, BAT and PSES, if promulgated, will also reduce discharges of priority and non-conventional pollutants. Applying the same methodology used to estimate conventional pollutant reductions attributable to application of BPT/BCT control technology, EPA has also estimated priority and non-conventional pollutant reductions for each facility. Because EPA has proposed BAT limitations equivalent to BPT, there are obviously no further pollutant reductions associated with BAT limitations.

Current loadings were estimated using the questionnaire data supplied by the industry, data collected by the Agency in the field sampling program, facility POTW permit information and facility

NPDES permit information. For many facilities, data were not available for all pollutants of concern or without the addition of other non-IWC wastewater. Therefore, methodologies were developed to estimate current performance for the industry (see Section 4.4 of this document).

In the construction of the plant-specific pollutant by pollutant loadings, in any case where the technology option generated an estimated pollutant loading in excess of the current loading, the option loading was set equal to the current loading. The rationale for the adoption of this methodology is consistency with and similarity to the "anti-backsliding" provisions. Also, a well designed and operated treatment system should not increase pollutant loadings above current practice. (It should be noted in the situation described above, no removal of the specific pollutant at the specific plant is achieved under the technology option).

#### **8.8.2.2 Direct Discharges (BPT/BAT)**

The Agency estimates that proposed BPT/BAT regulations will reduce direct discharges of priority and non-conventional pollutants by approximately 6,800 pounds per year for the eight facilities under Regulatory Option B. The current discharges and BPT/BCT discharges for priority and non-conventional pollutants are listed in Table 8-3.

#### **8.8.2.3 PSES Effluent Discharges to POTWs**

The Agency estimates that proposed PSES regulations will reduce indirect discharges of priority and non-conventional pollutants to POTWs by approximately 47,000 pounds per year for the three facilities under Regulatory Option A. The current discharges and BPT/BCT discharges for priority and non-conventional pollutants are listed in Table 8-4.

**Table 8-3. Direct Discharge Loads (in lbs.)**


Pollutant Name	CAS NO	Current Load	Option A Load	Option B Load
Total Suspended Solids	C-009	157,365	69,675	37,698
Aluminum	7429905	1,221	1,007	945
Antimony	7440360	3,907	1,770	1,631
Arsenic	7440382	372	45	41
Boron	7440428	10,446	10,089	10,209
Cadmium	7440439	368	276	108
Chromium	7440473	375	65	65
Copper	7440508	682	127	67
Iron	7439896	803	677	403
Lead	7439921	659	215	214
Manganese	7439965	1,028	1,013	1,028
Mercury	7439976	27	9	8
Molybdenum	7439987	1,527	1,527	1,527
Selenium	7782492	175	121	84
Silver	7440224	181	58	32
Tin	7440315	354	207	200
Titanium	7440326	291	26	47
Zinc	7440666	1,116	549	157
Total		180,897	87,455	54,463

Note: One facility is expected to ship wastewater off site for disposal. The facility has a current load of 3 lbs. and has been assigned 0 lbs. in the option loads.

**Table 8-4. Indirect Discharge Loads (in lbs.)**

<b>Pollutant Name</b>	<b>CAS NO</b>	<b>Current Load</b>	<b>Option A Load</b>	<b>Option B Load</b>
<b>Aluminum</b>	7429905	3,518	67	55
<b>Antimony</b>	7440360	97	4	4
<b>Arsenic</b>	7440382	1,192	3	3
<b>Boron</b>	7440428	1,148	581	590
<b>Cadmium</b>	7440439	482	21	8
<b>Chromium</b>	7440473	30,074	3	3
<b>Copper</b>	7440508	6,059	7	3
<b>Iron</b>	7439896	1,383	373	44
<b>Lead</b>	7439921	1,935	16	16
<b>Manganese</b>	7439965	102	62	62
<b>Mercury</b>	7439976	49	1	1
<b>Molybdenum</b>	7439987	199	83	83
<b>Selenium</b>	7782492	74	18	9
<b>Silver</b>	7440224	46	3	2
<b>Tin</b>	7440315	277	11	11
<b>Titanium</b>	7440326	277	1	3
<b>Zinc</b>	7440666	1,663	42	8
<b>Total</b>		48,574	1,298	904

Note: One facility is projected to cease combustion operations while the facility will remain open (a line closure). The facility has a current load of 42,159 lbs. and has been assigned 0 lbs. in the option loads. Another facility is expected to ship wastewater off site for disposal. The facility has a current load of 7 lbs. and has been assigned 0 lbs. in the option loads.



## **SECTION 9**

### **NON-WATER QUALITY IMPACTS**

Section 304(b) and 306 of the Clean Water Act require EPA to consider non-water quality environmental impacts (including energy requirements) associated with effluent limitations and guidelines. Pursuant to these requirements, EPA has considered the possible effect of the proposed Industrial Waste Combustors (IWC) BPT, BCT, BAT, NSPS, PSES, and PSNS regulations on air pollution, solid waste generation, and energy consumption. In evaluating the environmental impacts across all media, it has been determined that the impacts discussed below are minimal and are justified by the benefits associated with compliance with the IWC regulations.

During IWC wastewater treatment, the pollutants of concern are either removed from the wastewater stream, concentrated, or destroyed. If the pollutants are removed, they are either transferred from the wastewater stream to another medium (e.g., VOC emissions to the atmosphere) or end up as a treatment residual, such as sludge. Subsequent removal of pollutants to another media and the disposition of these wastewater treatment residuals result in non-water quality impacts. Non-water quality impacts evaluated for the IWC Industry regulations include air pollution and solid waste generation.

Wastewater treatment also results in other, non-water, non-residual, impacts. These impacts are the consumption of energy used to power the wastewater treatment equipment.

#### **9.1        *AIR POLLUTION***

IWC facilities treat wastewater streams which contain very low concentrations of volatile organic compounds (VOCs). These concentrations for most organic pollutants are typically below treatable levels. This is due to the nearly total destruction of organic pollutants in the original wastes through the combustion process, which prevents many of these pollutants from being detected in wastewaters and from being released into the atmosphere and affecting air quality. Losses through fugitive emission is not expected to be significant as most of the organics present in the IWC wastewater typically have low volatility. While the wastewater streams usually pass through collection units, cooling towers, and treatment units that are open to the atmosphere, this exposure

is not expected to result in any significant volatilization of VOCs from the wastewater.

Since there are no significant air emissions generated by the proposed treatment technologies, EPA believes that there are essentially no adverse air quality impacts anticipated as a result of the IWC regulations.

## 9.2 *SOLID WASTE*

Several of the wastewater treatment technologies used to comply with the proposed IWC regulations generate a solid waste. The costs for disposal of these waste residuals were included in the compliance cost estimates prepared for the regulatory options.

The solid waste treatment residual generated as a result of implementation of these regulations is filter cake from chemical precipitation processes. In the proposed BPT/PSES wastewater treatment trains of the IWC Industry, hydroxide and ferric chloride precipitation of metals generates a sludge residual. For BPT/BAT Option B, backwash from the multi-media filter is recirculated back to the treatment system prior to the chemical precipitation processes, therefore all solids are removed from the proposed treatment process in the clarifiers. This sludge is dewatered, and the resultant filter cake is typically disposed of off site into a landfill. It is expected that the filter cake generated from chemical precipitation will contain high concentrations of metals. As a result, this filter cake may be a RCRA hazardous waste. Depending upon the wastewater usage and the resultant characteristics of the sludge, the sludge generated at a particular facility may be either a listed or characteristic hazardous waste, pursuant to 40 CFR 261 regulations (Identification and Listing of Hazardous Waste). These filter cakes are considered to be a characteristic hazardous waste based upon toxicity when the waste exceeds allowable standards based upon the Toxicity Characteristic Leaching Procedure or exhibits other hazardous characteristics as defined under 40 CFR 261 Subpart C (e.g., ignitability, corrosivity, or reactivity). Filter cake may also be considered a RCRA listed waste (e.g., waste which are hazardous based upon definition as per 40 CFR 261 Subpart D) depending upon the types of wastewater produced by the combustion process and whether it is in contact with the wastes being combusted or residuals from the combustion process. EPA evaluated the cost of disposing hazardous and non-hazardous filter cake. In the IWC economic evaluation, contract hauling for off-site disposal in a Subtitle C or D landfill was the method costed.

It is estimated that compliance with the proposed BPT/PSES Options would result in the disposal of 1.276 million pounds of hazardous and non-hazardous filter cake. The estimated filter cake generation rate by combustor type is presented in Table 9-1 below.

**Table 9-1. Filter Cake Generation for the IWC Industry**

Combustor Type	Filter Cake Generated million pounds/year		
	Indirect	Direct	Total
<b>BIFs</b>	0.529	0	0.529
<b>Incinerators</b>	0	0.747	0.747
<b>Total</b>	0.529	0.747	1.276

EPA believes that the disposal of this filter cake would not have an adverse effect on the environment or result in the release of pollutants in the filter cake to other media. The disposal of these wastes into controlled Subtitle D or C landfills are strictly regulated by the RCRA program. New landfills are required to meet lining requirements to prevent the release of contaminants and to capture leachate. Landfill capacity throughout the country can readily accommodate the additional solid waste expected to be generated by the institution of this regulation. For costing purposes, it was assumed that these solid wastes would be considered hazardous and will be disposed of into permitted RCRA landfills with appropriate treatment of these filter cakes prior to disposition to achieve compliance with applicable RCRA Land Ban treatment requirements (e.g., stabilization) pursuant with 40 CFR 268 regulations, if necessary.

### **9.3 ENERGY REQUIREMENTS**

In each of the proposed regulatory options, operation of wastewater treatment equipment results in the consumption of energy. This energy is used to power pumps, mixers, and other equipment components, to power lighting and controls, and to generate heat. Since the two

regulatory options are comparable with the exception of the multi-media filter, Option B was used in determining the most conservative estimate of energy usage for the IWC Industry. The proposed IWC Option B would require the consumption of 1,790 thousand kilowatt-hours per year of electricity for both direct and indirect dischargers. This is the equivalent of 1003 barrels per year of #2 fuel oil, as compared with the 1992 rate of consumption in the United States of 40.6 million barrels per year. Option B, with the highest energy demand, represents an increase in the production or importation of oil of  $2.5 \times 10^{-5}$  percent annually. Based upon this relatively low increase in oil consumption, EPA believes that the implementation of this regulation would cause no substantial impact to the oil industry.

In 1992, approximately 2,797.2 billion kilowatt hours of electric power were generated in the United States. The additional energy consumption requirements for Option B, which has the greatest energy demand of the two options, corresponds to approximately  $6.1 \times 10^{-7}$  percent of the national requirements. This increase in energy requirements to implement the BPT/PSES technologies will result in an air emissions impact from electric power generating facilities. It is expected that air emissions parameters generated by electric producing facilities, such as particulates,  $\text{NO}_x$  and  $\text{SO}_2$ , will be impacted. This increase in air emissions is expected to be directly proportional to the increase in energy requirements, or in the case of Option B approximately  $6.1 \times 10^{-7}$  percent. EPA believes this additional increase in air emissions from electric generating facilities to be minimal and will result in no substantial impact to air emissions or detrimental results to air quality.

# APPENDIX A

US EPA\ Incinerators Analytical Database

a011.inci.pgmlib(R064GW3)

## Range of Pollutant Inluent Concentrations of the Pooled Daily Data from the Three 5-Day EPA Sampling Episodes for all Analytes

Analyte	CAS_NO	Meas. Type <sup>1</sup>	Mean	Min	Max	Unit
ACENAPHTHENE	83329	ND	14.83	10.00	35.56	UG/L
ACENAPHTHYLENE	208968	ND	14.83	10.00	35.56	UG/L
ACEPHATE	30560191	ND	30.53	20.00	71.00	UG/L
ACETOPHENONE	98862	NC	15.47	10.00	35.56	UG/L
ACIFLUORFEN	50594666	ND	15.27	10.00	35.56	UG/L
ACRYLONITRILE	107131	ND	50.00	49.94	50.00	UG/L
ALACHLOR	15972608	ND	0.31	0.20	0.71	UG/L
ALDRIN	309002	ND	0.31	0.20	0.71	UG/L
ALPHA-BHC	319846	ND	0.08	0.05	0.18	UG/L
ALPHA-CHLORDANE	5103719	ND	0.15	0.10	0.36	UG/L
ALPHA-TERPINEOL	98555	ND	14.83	10.00	35.56	UG/L
ALUMINUM	7429905	NC	897.59	13.60	2538.00	UG/L
AMENABLE CYANIDE	C-025	ND	10.00	10.00	10.00	UG/L
AMMONIA AS NITROGEN	7664417	NC	14312.40	100.00	75000.00	UG/L
ANILINE	62533	ND	14.83	10.00	35.56	UG/L
ANILINE, 2,4,5-TRIMETHYL-	137177	ND	29.66	20.00	71.12	UG/L
ANTHRACENE	120127	ND	14.83	10.00	35.56	UG/L
ANTIMONY	7440360	NC	268.16	7.80	958.80	UG/L
ARAMITE	140578	ND	74.14	50.00	177.80	UG/L
ARSENIC	7440382	NC	166.41	4.60	827.20	UG/L
ATRAZINE	1912249	ND	15.27	10.00	35.56	UG/L
AZINPHOS ETHYL	2642719	ND	3.05	2.00	7.10	UG/L
AZINPHOS METHYL	86500	ND	3.19	1.00	5.00	UG/L

<sup>1</sup> Measurement type ND means that the pollutant was not detected at any data point. Measurement type NC means that the pollutant was detected for at least one data point.

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
BARIUM	7440393	NC	237.70	43.10	613.00	UG/L
BENFLURALIN	1861401	ND	0.31	0.20	0.71	UG/L
BENZANTHRONE	82053	ND	74.14	50.00	177.80	UG/L
BENZENE	71432	ND	10.00	9.99	10.00	UG/L
BENZENETHIOL	108985	ND	14.83	10.00	35.56	UG/L
BENZIDINE	92875	ND	74.14	50.00	177.80	UG/L
BENZO(A)ANTHRACENE	56553	ND	14.83	10.00	35.56	UG/L
BENZO(A)PYRENE	50328	ND	14.83	10.00	35.56	UG/L
BENZO(B)FLUORANTHENE	205992	ND	14.83	10.00	35.56	UG/L
BENZO(GHI)PERYLENE	191242	ND	29.66	20.00	71.12	UG/L
BENZO(K)FLUORANTHENE	207089	ND	14.83	10.00	35.56	UG/L
BENZOIC ACID	65850	ND	74.14	50.00	177.80	UG/L
BENZONITRILE, 3,5-DIBROMO-4-HYDROXY-	1699845	ND	74.14	50.00	177.80	UG/L
BENZYL ALCOHOL	100516	ND	14.83	10.00	35.56	UG/L
BERYLLIUM	7440417	ND	0.93	0.30	1.50	UG/L
BETA-BHC	319857	ND	0.15	0.10	0.36	UG/L
BETA-NAPHTHYLAMINE	91598	ND	74.14	50.00	177.80	UG/L
BIPHENYL	92524	ND	14.83	10.00	35.56	UG/L
BIPHENYL, 4-NITRO	92933	ND	14.83	10.00	35.56	UG/L
BIS(2-CHLOROETHOXY)METHANE	111911	ND	14.83	10.00	35.56	UG/L
BIS(2-CHLOROETHYL) ETHER	111444	ND	14.83	10.00	35.56	UG/L
BIS(2-CHLOROISOPROPYL) ETHER	108601	ND	14.83	10.00	35.56	UG/L
BIS(2-ETHYLHEXYL) PHTHALATE	117817	NC	22.57	10.00	53.05	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
BISMUTH	7440699	NC	205.14	0.10	887.00	UG/L
BOD 5-DAY	C-002	NC	9960.00	1000.00	53000.00	UG/L
BORON	7440428	NC	1604.60	918.00	3760.00	UG/L
BROMACIL	314409	ND	1.53	1.00	3.56	UG/L
BROMODICHLOROMETHANE	75274	ND	10.00	9.99	10.00	UG/L
BROMOMETHANE	74839	ND	50.00	49.94	50.00	UG/L
BROMOXYNIL OCTANOATE	1689992	ND	0.76	0.50	1.78	UG/L
BUTACHLOR	23184669	ND	0.76	0.50	1.78	UG/L
BUTYL BENZYL PHTHALATE	85687	ND	14.83	10.00	35.56	UG/L
CADMIUM	7440439	NC	312.19	1.80	2616.00	UG/L
CALCIUM	7440702	NC	293146.00	8140.00	1270000.00	UG/L
CAPTAFOI	2425061	ND	3.05	2.00	7.10	UG/L
CAPTAN	133062	ND	1.53	1.00	3.56	UG/L
CARBAZOLE	86748	ND	29.66	20.00	71.12	UG/L
CARBON DISULFIDE	75150	ND	10.00	9.99	10.00	UG/L
CARBOPHENOTHION	786196	ND	1.53	1.00	3.56	UG/L
CERIUM	7440451	NC	507.47	1.00	1000.00	UG/L
CHEMICAL OXYGEN DEMAND (COD)	C-004	NC	343140.00	67000.00	1036000.00	UG/L
CHLORFENVINPHOS	470906	ND	3.05	2.00	7.10	UG/L
CHLORIDE	16887006	NC	6833746.67	1010000.00	17002400.00	UG/L
CHLOROACETONITRILE	107142	ND	10.00	9.99	10.00	UG/L
CHLOROBENZENE	108907	ND	10.00	9.99	10.00	UG/L
CHLOROBENZILATE	510156	ND	1.53	1.00	3.56	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
CHLOROETHANE	75003	ND	50.00	49.94	50.00	UG/L
CHLOROFORM	67663	ND	10.00	9.99	10.00	UG/L
CHLOROMETHANE	74873	ND	50.00	49.94	50.00	UG/L
CHLORONEB	2675776	ND	1.53	1.00	3.56	UG/L
CHLOROPROPYLATE	5836102	ND	15.27	10.00	35.56	UG/L
CHLOROTHALONIL	1897456	ND	0.31	0.20	0.71	UG/L
CHLORPYRIFOS	2921882	ND	3.05	2.00	7.10	UG/L
CHROMIUM	7440473	NC	127.17	5.80	529.20	UG/L
CHRYSENE	218019	ND	14.83	10.00	35.56	UG/L
CIS-PERMETHRIN	61949766	ND	3.05	2.00	7.10	UG/L
CIS-1,3-DICHLOROPROPENE	10061015	ND	10.00	9.99	10.00	UG/L
COBALT	7440484	NC	10.50	2.30	35.24	UG/L
COPPER	7440508	NC	1786.69	8.50	10554.00	UG/L
COUMAPHOS	56724	ND	7.64	5.00	17.78	UG/L
CROTONALDEHYDE	4170303	ND	50.00	49.94	50.00	UG/L
CROTOXYPHOS	7700176	ND	146.80	99.00	352.04	UG/L
DACTHAL (DCPA)	1861321	ND	0.08	0.05	0.18	UG/L
DALAPON	75990	NC	0.53	0.20	1.06	UG/L
DEF	78488	ND	3.05	2.00	7.10	UG/L
DELTA-BHC	319868	ND	0.08	0.05	0.18	UG/L
DEMETON A	8065483A	ND	3.05	2.00	7.10	UG/L
DEMETON B	8065483B	ND	3.05	2.00	7.10	UG/L
DI-N-BUTYL PHTHALATE	84742	ND	14.83	10.00	35.56	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
DI-N-OCTYL PHTHALATE	117840	ND	14.83	10.00	35.56	UG/L
DI-N-PROPYLNITROSAMINE	621647	ND	29.66	20.00	71.12	UG/L
DIALLATE A	2303164A	ND	3.05	2.00	7.10	UG/L
DIALLATE B	2303164B	ND	3.05	2.00	7.10	UG/L
DIAZINON	333415	ND	3.05	2.00	7.10	UG/L
DIBENZO(A,H)ANTHRACENE	53703	ND	29.66	20.00	71.12	UG/L
DIBENZOFURAN	132649	ND	14.83	10.00	35.56	UG/L
DIBENZOTHIOPHENE	132650	ND	14.83	10.00	35.56	UG/L
DIBROMOCHLOROMETHANE	124481	ND	10.00	9.99	10.00	UG/L
DIBROMOMETHANE	74953	ND	10.00	9.99	10.00	UG/L
DICAMBA	1918009	NC	0.32	0.20	0.71	UG/L
DICHLOFENTHION	97176	ND	3.05	2.00	7.10	UG/L
DICHLONE	117806	ND	3.05	2.00	7.10	UG/L
DICHLORPROP	120365	NC	7.66	1.00	47.00	UG/L
DICHLORVOS	62737	ND	7.64	5.00	17.78	UG/L
DICOFOL	115322	ND	1.53	1.00	3.56	UG/L
DICROTOPHOS	141662	ND	5.00	5.00	5.00	UG/L
DIELDRIN	60571	ND	0.06	0.04	0.14	UG/L
DIETHYL ETHER	60297	ND	50.00	49.94	50.00	UG/L
DIETHYL PHTHALATE	84662	ND	14.83	10.00	35.56	UG/L
DIMETHOATE	60515	ND	1.86	1.00	3.56	UG/L
DIMETHYL PHTHALATE	131113	ND	14.83	10.00	35.56	UG/L
DIMETHYL SULFONE	67710	ND	14.83	10.00	35.56	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
DINOSEB	88857	NC	0.87	0.50	2.63	UG/L
DIOXATHION	78342	ND	5.00	5.00	5.00	UG/L
DIPHENYL ETHER	101848	ND	14.83	10.00	35.56	UG/L
DIPHENYLAMINE	122394	ND	14.83	10.00	35.56	UG/L
DIPHENYLDISULFIDE	882337	ND	29.66	20.00	71.12	UG/L
DISULFOTON	298044	ND	3.05	2.00	7.10	UG/L
DYSPROSTIUM	7429916	NC	67.17	0.10	100.00	UG/L
ENDOSULEAN I	959988	ND	0.15	0.10	0.36	UG/L
ENDOSULEAN II	33213659	ND	1.53	1.00	3.56	UG/L
ENDOSULEAN SULEFATE	1031078	ND	0.15	0.10	0.36	UG/L
ENDRIN	72208	ND	0.31	0.20	0.71	UG/L
ENDRIN ALDEHYDE	7421934	ND	0.15	0.10	0.36	UG/L
ENDRIN KETONE	53494705	ND	0.15	0.10	0.36	UG/L
EPN	2104645	ND	3.05	2.00	7.10	UG/L
ERBIUM	7440520	ND	66.70	0.10	100.00	UG/L
ETHALFLURALIN	55283686	ND	0.15	0.10	0.36	UG/L
ETHANE, PENTACHLORO-	76017	ND	29.66	20.00	71.12	UG/L
ETHION	563122	ND	3.05	2.00	7.10	UG/L
ETHOPROP	13194484	ND	3.05	2.00	7.10	UG/L
ETHYL CYANIDE	107120	ND	10.00	9.99	10.00	UG/L
ETHYL METHACRYLATE	97632	ND	10.00	9.99	10.00	UG/L
ETHYL METHANESULFONATE	62500	ND	29.66	20.00	71.12	UG/L
ETHYLBENZENE	100414	ND	10.00	9.99	10.00	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
ETHYLENETHIOUREA	96457	ND	29.66	20.00	71.12	UG/L
ETRIDIAZOLE	2593159	ND	0.10	0.10	0.10	UG/L
EUROPIUM	7440531	NC	68.07	0.10	100.00	UG/L
FAMPHUR	52857	ND	7.64	5.00	17.78	UG/L
FENARIMOL	60168889	ND	0.31	0.20	0.71	UG/L
FENSULFOTHION	115902	ND	7.64	5.00	17.78	UG/L
FENTHION	55389	ND	3.05	2.00	7.10	UG/L
FLUORANTHENE	206440	ND	14.83	10.00	35.56	UG/L
FLUORENE	86737	ND	14.83	10.00	35.56	UG/L
FLUORIDE	16984488	NC	82620.53	16500.00	360000.00	UG/L
GADOLINIUM	7440542	NC	236.22	0.50	500.00	UG/L
GALLIUM	7440553	NC	236.12	0.50	500.00	UG/L
GAMMA-BHC	58899	ND	0.08	0.05	0.18	UG/L
GAMMA-CHLORDANE	5103742	ND	0.08	0.05	0.18	UG/L
GERMANIUM	7440564	NC	335.79	0.50	500.00	UG/L
GOLD	7440575	ND	100.33	1.00	200.00	UG/L
HAFNIUM	7440586	NC	500.92	1.00	1000.00	UG/L
HEPTACHLOR	76448	ND	0.15	0.10	0.36	UG/L
HEPTACHLOR EPOXIDE	1024573	ND	0.08	0.05	0.18	UG/L
HEXACHLOROBENZENE	118741	ND	14.83	10.00	35.56	UG/L
HEXACHLOROBUTADIENE	87683	ND	14.83	10.00	35.56	UG/L
HEXACHLOROCYCLOPENTADIENE	77474	ND	14.83	10.00	35.56	UG/L
HEXACHLOROETHANE	67721	ND	14.83	10.00	35.56	UG/L

## US EPA\ Incinerators Analytical Database

a011.inci.pgmlib(R064GW3)

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
HEXACHLOROPROPENE	1888717	ND	29.66	20.00	71.12	UG/L
HEXAMETHYLPHOSPHORAMIDE	680319	ND	2.00	2.00	2.00	UG/L
HEXANOIC ACID	142621	ND	14.83	10.00	35.56	UG/L
HEXAVALENT CHROMIUM	18540299	NC	18.67	10.00	76.00	UG/L
HOLMIUM	7440600	NC	336.78	0.50	500.00	UG/L
INDENO(1,2,3-CD) PYRENE	193395	ND	29.66	20.00	71.12	UG/L
INDIUM	7440746	NC	512.02	1.00	1000.00	UG/L
IODINE	7553562	NC	1943.00	500.00	3840.00	UG/L
IODOMETHANE	74884	ND	10.00	9.99	10.00	UG/L
IRIDIUM	7439885	NC	609.97	1.00	1708.00	UG/L
IRON	7439896	NC	2904.13	149.00	10838.00	UG/L
ISOBUTYL ALCOHOL	78831	ND	10.00	9.99	10.00	UG/L
ISODRIN	465736	ND	0.15	0.10	0.36	UG/L
ISOPHORONE	78591	ND	14.83	10.00	35.56	UG/L
ISOPROPALIN	33820530	ND	0.31	0.20	0.71	UG/L
ISOSAFROLE	120581	ND	14.83	10.00	35.56	UG/L
KEPONE	143500	ND	1.53	1.00	3.56	UG/L
LANTHANUM	7439910	NC	68.18	0.10	100.00	UG/L
LEAD	7439921	NC	1613.89	2.10	13248.00	UG/L
LEPTOPHOS	21609905	ND	3.05	2.00	7.10	UG/L
LITHIUM	7439932	NC	231.26	79.00	532.80	UG/L
LONGIFOLENE	475207	ND	74.14	50.00	177.80	UG/L
LUTETIUM	7439943	NC	66.78	0.10	100.00	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
M-XYLENE	108383	ND	10.00	9.99	10.00	UG/L
MAGNESIUM	7439954	NC	7435.80	1140.00	20400.00	UG/L
MALACHITE GREEN	569642	ND	14.83	10.00	35.56	UG/L
MALATHION	121755	ND	3.05	2.00	7.10	UG/L
MANGANESE	7439965	NC	114.72	4.00	388.00	UG/L
MCPA	94746	NC	115.60	50.00	399.20	UG/L
MCPP	7085190	NC	375.68	50.00	2594.00	UG/L
MERCURY	7439976	NC	21.06	0.20	115.36	UG/L
MERPHOS	150505	ND	3.58	2.00	7.10	UG/L
MESTRANOL	72333	ND	29.66	20.00	71.12	UG/L
METHAPYRILENE	91805	ND	14.83	10.00	35.56	UG/L
METHOXYCHLOR	72435	ND	0.31	0.20	0.71	UG/L
METHYL CHLORPYRIFOS	5598130	ND	3.05	2.00	7.10	UG/L
METHYL METHACRYLATE	80626	ND	10.00	9.99	10.00	UG/L
METHYL METHANESULFONATE	66273	ND	29.66	20.00	71.12	UG/L
METHYL PARATHION	298000	ND	3.05	2.00	7.10	UG/L
METHYL TRITHION	953173	ND	5.00	5.00	5.00	UG/L
METHYLENE CHLORIDE	75092	ND	10.00	9.99	10.00	UG/L
METRIBUZIN	21087649	ND	0.15	0.10	0.36	UG/L
MEVINPHOS	7786347	ND	7.64	5.00	17.78	UG/L
MIREX	2385855	ND	0.31	0.20	0.71	UG/L
MOLYBDENUM	7439987	NC	336.68	4.60	1024.40	UG/L
MONOCROTOPHOS	6923224	NC	2.00	2.00	2.00	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
N-DECANE	124185	ND	14.83	10.00	35.56	UG/L
N-DOCOSANE	629970	ND	14.83	10.00	35.56	UG/L
N-DODECANE	112403	ND	14.83	10.00	35.56	UG/L
N-EICOSANE	112958	ND	14.83	10.00	35.56	UG/L
N-HEXACOSANE	630013	NC	20.41	10.00	92.91	UG/L
N-HEXADECANE	544763	ND	14.83	10.00	35.56	UG/L
N-NITROSODI-N-BUTYLAMINE	924163	ND	14.83	10.00	35.56	UG/L
N-NITROSODIETHYLAMINE	55185	ND	14.83	10.00	35.56	UG/L
N-NITROSODIMETHYLAMINE	62759	ND	74.14	50.00	177.80	UG/L
N-NITROSODIPHENYLAMINE	86306	ND	29.66	20.00	71.12	UG/L
N-NITROSOMETHYLETHYLAMINE	10595956	ND	14.83	10.00	35.56	UG/L
N-NITROSOMETHYLPHENYLAMINE	614006	ND	146.80	99.00	352.04	UG/L
N-NITROSOMORPHOLINE	59892	ND	14.83	10.00	35.56	UG/L
N-NITROSOPIPERIDINE	100754	ND	14.83	10.00	35.56	UG/L
N-OCTACOSANE	630024	NC	21.81	10.00	95.71	UG/L
N-OCTADECANE	593453	ND	14.83	10.00	35.56	UG/L
N-TETRACOSANE	646311	ND	14.83	10.00	35.56	UG/L
N-TETRADECANE	629594	ND	14.83	10.00	35.56	UG/L
N-TRIACONTANE	638686	NC	16.53	10.00	46.21	UG/L
N,N-DIMETHYLFORMAMIDE	68122	ND	14.83	10.00	35.56	UG/L
NALED	300765	ND	8.64	5.00	17.78	UG/L
NAPHTHALENE	91203	ND	14.83	10.00	35.56	UG/L
NEODYMIUM	7440008	NC	246.75	0.50	500.00	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
NICKEL	7440020	NC	134.26	4.50	327.00	UG/L
NIOBIUM	7440031	NC	525.87	29.25	1000.00	UG/L
NITRATE/NITRITE	C-005	NC	2650.93	360.00	4560.00	UG/L
NITROBENZENE	98953	ND	14.83	10.00	35.56	UG/L
NITROFEN	1836755	ND	0.31	0.20	0.71	UG/L
NORFLURAZON	27314132	NC	1.59	1.00	4.08	UG/L
O+P XYLENE	136777612	ND	10.00	9.99	10.00	UG/L
O-ANISIDINE	90040	ND	14.83	10.00	35.56	UG/L
O-CRESOL	95487	ND	14.83	10.00	35.56	UG/L
O-TOLUIDINE	95534	ND	14.83	10.00	35.56	UG/L
O-TOLUIDINE, 5-CHLORO-	95794	ND	14.83	10.00	35.56	UG/L
OCDD	3268879	NC	0.00	0.00	0.00	UG/L
OCDF	39001020	NC	0.00	0.00	0.00	UG/L
OIL AND GREASE	C-036	NC	5066.67	5000.00	6000.00	UG/L
OSMIU4	7440042	NC	67.19	0.10	100.00	UG/L
P-CHLOROANILINE	106478	ND	14.83	10.00	35.56	UG/L
P-CRESOL	106445	ND	14.83	10.00	35.56	UG/L
P-CYMEKE	99876	ND	14.83	10.00	35.56	UG/L
P-DIMETHYLAMINOAZOBENZENE	60117	ND	29.66	20.00	71.12	UG/L
P-NITROANILINE	100016	ND	74.14	50.00	177.80	UG/L
PALLADIUM	7440053	ND	333.50	0.50	500.00	UG/L
PARATHION (ETHYL)	56382	ND	3.05	2.00	7.10	UG/L
PCB 1016	12674112	ND	1.53	1.00	3.56	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
PCB 1221	11104282	ND	1.53	1.00	3.56	UG/L
PCB 1232	11141165	ND	1.53	1.00	3.56	UG/L
PCB 1242	53469219	ND	1.53	1.00	3.56	UG/L
PCB 1248	12672296	ND	1.53	1.00	3.56	UG/L
PCB 1254	11097691	ND	1.53	1.00	3.56	UG/L
PCB 1260	11096825	ND	1.53	1.00	3.56	UG/L
PENDAMETHALIN	40487421	ND	0.76	0.50	1.78	UG/L
PENTACHLOROBENZENE	608935	ND	29.66	20.00	71.12	UG/L
PENTACHLORONITROBENZENE (PCNB)	82688	ND	0.08	0.05	0.18	UG/L
PENTACHLOROPHENOL	87865	ND	74.14	50.00	177.80	UG/L
PENTAMETHYLBENZENE	700129	ND	14.83	10.00	35.56	UG/L
PERTHANE	72560	ND	15.27	10.00	35.56	UG/L
PERYLENE	198550	ND	14.83	10.00	35.56	UG/L
PHENACETIN	62442	ND	14.83	10.00	35.56	UG/L
PHENANTHRENE	85018	ND	14.83	10.00	35.56	UG/L
PHENOL	108952	NC	17.11	10.00	44.16	UG/L
PHENOL, 2-METHYL-4,6-DINITRO-	534521	ND	29.66	20.00	71.12	UG/L
PHENOTHIAZINE	92842	ND	74.14	50.00	177.80	UG/L
PHORATE	298022	ND	3.05	2.00	7.10	UG/L
PHOSHET	732116	ND	7.64	5.00	17.78	UG/L
PHOSPHAMIDON E	297994	ND	7.64	5.00	17.78	UG/L
PHOSPHAMIDON Z	23783984	ND	7.64	5.00	17.78	UG/L
PHOSPHORUS	7723140	NC	32480.80	3210.00	225800.00	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
PICLORAM	1918021	ND	0.76	0.50	1.78	UG/L
PLATINUM	7440064	NC	528.11	1.00	1000.00	UG/L
POTASSIUM	7440097	NC	77743.00	1310.00	195400.00	UG/L
PRASEODYMIUM	7440100	NC	927.87	1.00	3910.00	UG/L
PRONAMIDE	23950585	ND	14.83	10.00	35.56	UG/L
PROPACHLOR	1918167	ND	0.15	0.10	0.36	UG/L
PROPANIL	709988	ND	1.53	1.00	3.56	UG/L
PROPAZINE	139402	ND	1.53	1.00	3.56	UG/L
PYRENE	129000	ND	14.83	10.00	35.56	UG/L
PYRIDINE	110861	ND	14.83	10.00	35.56	UG/L
RESORCINOL	108463	ND	74.14	50.00	177.80	UG/L
RHENIUM	7440155	NC	615.13	205.00	1000.00	UG/L
RHODIUM	7440166	NC	670.22	1.00	1000.00	UG/L
RONNEL	299843	ND	3.05	2.00	7.10	UG/L
RUTHENIUM	7440188	NC	504.65	1.00	1000.00	UG/L
SAFROLE	94597	ND	14.83	10.00	35.56	UG/L
SAMARIUM	7440199	NC	336.92	0.50	500.00	UG/L
SCANDIUM	7440202	NC	66.75	0.10	100.00	UG/L
SELENIUM	7782492	NC	102.82	2.30	429.20	UG/L
SILICON	7440213	NC	15414.00	5380.00	28100.00	UG/L
SILVER	7440224	NC	98.92	1.00	390.80	UG/L
SIMAZINE	122349	ND	12.22	8.00	28.46	UG/L
SODIUM	7440235	NC	3443333.33	6400.00	11250600.00	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CHS_NO	Meas. Type	Mean	Min	Max	Unit
SQUALENE	7683649	ND	146.80	99.00	352.04	UG/L
STROBANE	8001501	ND	7.64	5.00	17.78	UG/L
STRONTIUM	7440246	NC	630.23	100.00	2280.00	UG/L
STYRENE	100425	ND	14.83	10.00	35.56	UG/L
SULFOTEP	3689245	ND	4.05	2.00	7.10	UG/L
SULFUR	7704349	NC	400788.06	2145.00	1078240.00	UG/L
SULPROFOS	35400432	ND	3.05	2.00	7.10	UG/L
TANTALUM	7440257	NC	333.89	0.50	500.00	UG/L
TELLURIUM	13494809	ND	667.00	1.00	1000.00	UG/L
TEPP	107493	ND	5.00	5.00	5.00	UG/L
TERBACIL	5902512	ND	3.05	2.00	7.10	UG/L
TERBIUM	7440279	NC	342.22	0.50	500.00	UG/L
TERBUFOS	13071799	ND	3.05	2.00	7.10	UG/L
TERBUTHYLAZINE	5915413	ND	7.64	5.00	17.78	UG/L
TETRACHLOROETHENE	127184	ND	10.00	9.99	10.00	UG/L
TETRACHLOROMETHANE	56235	ND	10.00	9.99	10.00	UG/L
TETRACHLORVINPHOS	22248799	ND	3.05	2.00	7.10	UG/L
THALLIUM	7440280	NC	9.19	1.20	20.00	UG/L
THIANAPHTHENE	95158	ND	14.83	10.00	35.56	UG/L
THIOACETAMIDE	62555	ND	29.66	20.00	71.12	UG/L
THIOXANTHE-9-ONE	492228	ND	29.66	20.00	71.12	UG/L
THORIUM	7440291	NC	512.90	1.00	1000.00	UG/L
THULIUM	7440304	NC	333.98	0.50	500.00	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
TIN	7440315	NC	665.88	14.50	6046.00	UG/L
TITANIUM	7440326	NC	777.71	5.00	4474.20	UG/L
TOKUTHION	34643464	ND	2.00	2.00	2.00	UG/L
TOLUENE	108883	ND	10.00	9.99	10.00	UG/L
TOLUENE, 2,4-DIAMINO-	95807	ND	146.80	99.00	352.04	UG/L
TOTAL CYANIDE	57125	NC	17.93	10.00	105.00	UG/L
TOTAL DISSOLVED SOLIDS	C-010	NC	12815853.33	158000.00	32641200.00	UG/L
TOTAL ORGANIC CARBON (TOC)	C-012	NC	10485.33	10000.00	16000.00	UG/L
TOTAL PHENOLS	C-020	NC	93.20	50.00	681.00	UG/L
TOTAL PHOSPHORUS	14265442	NC	1088.60	10.00	4460.00	UG/L
TOTAL SULFIDE (IODOMETRIC)	18496258	NC	28261.33	1000.00	103200.00	UG/L
TOTAL SUSPENDED SOLIDS	C-009	NC	122553.33	4000.00	522000.00	UG/L
TOXAPHENE	8001352	ND	7.64	5.00	17.78	UG/L
TRANS-PERMETHRIN	61949777	ND	3.05	2.00	7.10	UG/L
TRANS-1,2-DICHLOROETHENE	156605	ND	10.00	9.99	10.00	UG/L
TRANS-1,3-DICHLOROPROPENE	10061026	ND	10.00	9.99	10.00	UG/L
TRANS-1,4-DICHLORO-2-BUTENE	110576	ND	50.00	49.94	50.00	UG/L
TRIADINEFON	43121433	ND	1.53	1.00	3.56	UG/L
TRIBROMOMETHANE	75252	ND	10.00	9.99	10.00	UG/L
TRICHLORFON	52686	ND	7.64	5.00	17.78	UG/L
TRICHLOROETHENE	79016	ND	10.00	9.99	10.00	UG/L
TRICHLOROFLUOROMETHANE	75694	ND	10.00	10.00	10.00	UG/L
TRICHLORONATE	327980	ND	3.05	2.00	7.10	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
TRICRESYLPHOSPHATE	78308	ND	15.27	10.00	35.56	UG/L
TRIFLURALIN	1582098	ND	0.15	0.10	0.36	UG/L
TRIMETHYLPHOSPHATE	512561	ND	2.00	2.00	2.00	UG/L
TRIPHENYLENE	217594	ND	14.83	10.00	35.56	UG/L
TRIPROPYLENEGLYCOL METHYL ETHER	20324338	ND	146.80	99.00	352.04	UG/L
TUNGSTEN	7440337	NC	649.28	93.20	1000.00	UG/L
URANIUM	7440611	NC	1096.71	10.10	2670.00	UG/L
VANADIUM	7440622	NC	107.67	2.60	488.20	UG/L
VINYL ACETATE	108054	ND	50.00	49.94	50.00	UG/L
VINYL CHLORIDE	75014	ND	10.00	9.99	10.00	UG/L
YTTERBIUM	7440644	NC	68.46	0.10	100.00	UG/L
YTTRIUM	7440655	ND	4.33	3.00	5.00	UG/L
ZINC	7440666	NC	3718.81	89.75	12310.00	UG/L
ZIRCONIUM	7440677	NC	67.89	0.10	100.00	UG/L
1-BROMO-2-CHLOROBENZENE	694804	ND	14.83	10.00	35.56	UG/L
1-BROMO-3-CHLOROBENZENE	108372	ND	14.83	10.00	35.56	UG/L
1-CHLORO-3-NITROBENZENE	121733	ND	74.14	50.00	177.80	UG/L
1-METHYLFLUORENE	1730376	ND	14.83	10.00	35.56	UG/L
1-METHYLPHENANTHRENE	832699	ND	14.83	10.00	35.56	UG/L
1-NAPHTHYLAMINE	134327	ND	14.83	10.00	35.56	UG/L
1-PHENYLNAPHTHALENE	605027	ND	14.83	10.00	35.56	UG/L
1,1-DICHLOROETHANE	75343	ND	10.00	9.99	10.00	UG/L
1,1-DICHLOROETHENE	75354	ND	10.00	9.99	10.00	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
1,1,1-TRICHLOROETHANE	71556	ND	10.00	9.99	10.00	UG/L
1,1,1,2-TETRACHLOROETHANE	630206	ND	10.00	9.99	10.00	UG/L
1,1,2-TRICHLOROETHANE	79005	ND	10.00	9.99	10.00	UG/L
1,1,2,2-TETRACHLOROETHANE	79345	ND	10.00	9.99	10.00	UG/L
1,2-DIBROMO-3-CHLOROPROPANE	96128	ND	29.66	20.00	71.12	UG/L
1,2-DIBROMOETHANE	106934	ND	10.00	9.99	10.00	UG/L
1,2-DICHLOROBENZENE	95501	ND	14.83	10.00	35.56	UG/L
1,2-DICHLOROETHANE	107062	ND	10.00	9.99	10.00	UG/L
1,2-DICHLOROPROPANE	78875	ND	10.00	9.99	10.00	UG/L
1,2-DIPHENYLHYDRAZINE	122667	ND	29.66	20.00	71.12	UG/L
1,2,3-TRICHLOROBENZENE	87616	ND	14.83	10.00	35.56	UG/L
1,2,3-TRICHLOROPROPANE	96184	ND	10.00	9.99	10.00	UG/L
1,2,3-TRIMETHOXYBENZENE	634366	ND	14.83	10.00	35.56	UG/L
1,2,4-TRICHLOROBENZENE	120821	ND	14.83	10.00	35.56	UG/L
1,2,4,5-TETRACHLOROBENZENE	95943	ND	14.83	10.00	35.56	UG/L
1,2:3,4-DIEPOXYBUTANE	1464535	ND	29.66	20.00	71.12	UG/L
1,3-BUTADIENE, 2-CHLORO	126998	ND	10.00	9.99	10.00	UG/L
1,3-DICHLORO-2-PROPANOL	96231	ND	14.83	10.00	35.56	UG/L
1,3-DICHLOROBENZENE	541731	ND	14.83	10.00	35.56	UG/L
1,3-DICHLOROPROPANE	142289	ND	10.00	9.99	10.00	UG/L
1,3,5-TRITHIANE	291214	ND	74.14	50.00	177.80	UG/L
1,4-DICHLOROBENZENE	106467	ND	14.83	10.00	35.56	UG/L
1,4-DINITROBENZENE	100254	ND	29.66	20.00	71.12	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
1,4-DIOXANE	123911	ND	10.00	9.99	10.00	UG/L
1,4-NAPHTHOQUINONE	130154	ND	146.80	99.00	352.04	UG/L
1,5-NAPHTHALENEDIAMINE	2243621	ND	146.80	99.00	352.04	UG/L
1234678-HPCDD	35822469	NC	0.00	0.00	0.00	UG/L
1234678-HPCDF	67562394	NC	0.00	0.00	0.00	UG/L
123478-HXCDD	39227286	ND	0.00	0.00	0.00	UG/L
123478-HXCDF	70648269	ND	0.00	0.00	0.00	UG/L
1234789-HPCDF	55673897	ND	0.00	0.00	0.00	UG/L
123678-HXCDD	57653857	ND	0.00	0.00	0.00	UG/L
123678-HXCDF	57117449	ND	0.00	0.00	0.00	UG/L
12378-PECDD	40321764	ND	0.00	0.00	0.00	UG/L
12378-PECDF	57117416	ND	0.00	0.00	0.00	UG/L
123789-HXCDD	19408743	ND	0.00	0.00	0.00	UG/L
123789-HXCDF	72918219	ND	0.00	0.00	0.00	UG/L
2-(METHYLTHIO) BENZOTHAZOLE	615225	ND	14.83	10.00	35.56	UG/L
2-BUTANONE	78933	ND	50.00	49.94	50.00	UG/L
2-CHLOROETHYL VINYL ETHER	110758	ND	10.00	9.99	10.00	UG/L
2-CHLORONAPHTHALENE	91587	ND	14.83	10.00	35.56	UG/L
2-CHLOROPHENOL	95578	ND	14.83	10.00	35.56	UG/L
2-HEXANONE	591786	ND	50.00	49.94	50.00	UG/L
2-ISOPROPYLNAPHTHALENE	2027170	ND	14.83	10.00	35.56	UG/L
2-METHYLBENZOTHAZOLE	120752	ND	14.83	10.00	35.56	UG/L
2-METHYLNAPHTHALENE	91576	ND	14.83	10.00	35.56	UG/L

## Listing of SCC Data General Summary Statistics


Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
2-NITROANILINE	88744	ND	14.83	10.00	35.56	UG/L
2-NITROPHENOL	88755	ND	29.66	20.00	71.12	UG/L
2-PHENYLNAPHTHALENE	612942	ND	14.83	10.00	35.56	UG/L
2-PICOLINE	109068	ND	74.14	50.00	177.80	UG/L
2-PROPANONE	67641	ND	50.00	49.94	50.00	UG/L
2-PROPEN-1-OL	107186	ND	10.00	9.99	10.00	UG/L
2-PROPENAL	107028	ND	50.00	49.94	50.00	UG/L
2-PROPENENITRILE, 2-METHYL-	126987	ND	10.00	9.99	10.00	UG/L
2,3-BENZOFLUORENE	243174	ND	14.83	10.00	35.56	UG/L
2,3-DICHLOROANILINE	608275	ND	14.83	10.00	35.56	UG/L
2,3-DICHLORONITROBENZENE	3209221	ND	74.14	50.00	177.80	UG/L
2,3,4,6-TETRACHLOROPHENOL	58902	ND	29.66	20.00	71.12	UG/L
2,3,6-TRICHLOROPHENOL	933755	ND	14.83	10.00	35.56	UG/L
2,4-D	94757	NC	1.80	1.00	3.56	UG/L
2,4-DB	94826	NC	3.43	2.00	10.46	UG/L
2,4-DICHLOROPHENOL	120832	ND	14.83	10.00	35.56	UG/L
2,4-DIMETHYLPHENOL	105679	ND	14.83	10.00	35.56	UG/L
2,4-DINITROPHENOL	51285	ND	74.14	50.00	177.80	UG/L
2,4-DINITROTOLUENE	121142	ND	14.83	10.00	35.56	UG/L
2,4,5-T	93765	NC	0.35	0.20	0.71	UG/L
2,4,5-TP	93721	NC	0.42	0.20	1.25	UG/L
2,4,5-TRICHLOROPHENOL	95954	ND	14.83	10.00	35.56	UG/L
2,4,6-TRICHLOROPHENOL	88062	ND	14.83	10.00	35.56	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
2,6-DI-TERT-BUTYL-P-BENZOQUINONE	719222	ND	146.80	99.00	352.04	UG/L
2,6-DICHLORO-4-NITROANILINE	99309	ND	146.80	99.00	352.04	UG/L
2,6-DICHLOROPHENOL	87650	ND	14.83	10.00	35.56	UG/L
2,6-DINITROTOLUENE	606202	ND	14.83	10.00	35.56	UG/L
234678-HXCDF	60851345	ND	0.00	0.00	0.00	UG/L
23478-PCDF	57117314	ND	0.00	0.00	0.00	UG/L
2378-TCDD	1746016	ND	0.00	0.00	0.00	UG/L
2378-TCDF	51207319	ND	0.00	0.00	0.00	UG/L
3-CHLOROPROPENE	107051	ND	10.00	9.99	10.00	UG/L
3-METHYLCHOLANTHRENE	56495	ND	14.83	10.00	35.56	UG/L
3-NITROANILINE	99092	ND	29.66	20.00	71.12	UG/L
3,3'-DICHLOROBENZIDINE	91941	ND	74.14	50.00	177.80	UG/L
3,3'-DIMETHOXYBENZIDINE	119904	ND	74.14	50.00	177.80	UG/L
3,6-DIMETHYLPHENANTHRENE	1576676	ND	14.83	10.00	35.56	UG/L
4-AMINOBIPHENYL	92671	ND	14.83	10.00	35.56	UG/L
4-BROMOPHENYL PHENYL ETHER	101553	ND	14.83	10.00	35.56	UG/L
4-CHLORO-2-NITROANILINE	89634	ND	29.66	20.00	71.12	UG/L
4-CHLORO-3-METHYLPHENOL	59507	ND	14.83	10.00	35.56	UG/L
4-CHLOROPHENYLPHENYL ETHER	7005723	ND	14.83	10.00	35.56	UG/L
4-METHYL-2-PENTANONE	108101	ND	50.00	49.94	50.00	UG/L
4-NITROPHENOL	100027	ND	74.14	50.00	177.80	UG/L
4,4'-DDD	72548	ND	0.31	0.20	0.71	UG/L
4,4'-DDE	72559	ND	0.15	0.10	0.36	UG/L

## Listing of SCC Data General Summary Statistics

Analyte	CAS_NO	Meas. Type	Mean	Min	Max	Unit
4,4'-DDT	50293	ND	0.15	0.10	0.36	UG/L
4,4'-METHYLENEBIS(2-CHLOROANILINE)	101144	ND	29.66	20.00	71.12	UG/L
4,5-METHYLENE PHENANTHRENE	203645	ND	14.83	10.00	35.56	UG/L
5-NITRO-O-TOLUIDINE	99558	ND	14.83	10.00	35.56	UG/L
7,12-DIMETHYLBENZ(A)ANTHRACENE	57976	ND	14.83	10.00	35.56	UG/L



## APPENDIX B

## ACRONYMS AND DEFINITIONS

**Administrator** -- The Administrator of the U.S. Environmental Protection Agency

**Agency** -- The U.S. Environmental Protection Agency

**BAT** -- The best available technology economically achievable, as described in Sec. 304(b)(2) of the CWA.

**BCT** -- The best conventional pollutant control technology, as described in Sec. 304(b)(4) of the CWA.

**BOD<sub>5</sub>** -- Biochemical oxygen demand - Five Day. A measure of biochemical decomposition of organic matter in a water sample. It is determined by measuring the dissolved oxygen consumed by microorganisms to oxidize the organic contaminants in a water sample under standard laboratory conditions of five days and 70°C. BOD<sub>5</sub> is not related to the oxygen requirements in chemical combustion.

**Boiler** -- means an enclosed device using controlled flame combustion and having the following characteristics:

(1) (i) The unit must have physical provisions for recovering and exporting thermal energy in the form of steam, heated fluids, or heated gases; and

(ii) The unit's combustion chamber and primary energy recovery section(s) must be of integral design. To be of integral design, the combustion chamber and the primary energy recovery section(s) (such as waterwalls and superheaters) must be physically formed into one manufactured or assembled unit. A unit in which the combustion chamber and the primary energy recovery section(s) are joined only by ducts or connections carrying flue gas is not integrally designed; however, secondary energy recovery equipment (such as economizers or air preheaters) need not be physically formed into the same unit as the combustion chamber and the primary energy recovery section. The following units are not precluded from being boilers solely because they are not of integral design: process heaters (units that transfer energy directly to a process stream), and fluidized bed combustion units; and

(iii) While in operation, the unit must maintain a thermal energy recovery efficiency of at least 60 percent, calculated in terms of the recovered energy compared with the thermal value of the fuel; and

(iv) The unit must export and utilize at least 75 percent of the recovered energy, calculated on an annual basis. In this calculation, no credit shall be given for recovered heat used internally in the same unit. (Examples of internal use are the preheating of fuel or combustion air, and the driving of induced or forced draft fans or feedwater pumps); or

(2) The unit is one which the Regional Administrator has determined, on a case-by-case basis, to be a boiler, after considering the standards in Section 260.32.

**BPT** -- The best practicable control technology currently available, as described in Sec. 304(b)(1) of the CWA.

**Captive** -- Used to describe a facility that only accepts waste generated on site and/or by the owner operator at the facility.

**Centralized waste treatment facility** -- Any facility that treats any hazardous or non-hazardous industrial wastes received from off-site by tanker truck, trailer/roll-off bins, drums, barge, pipeline, or other forms of shipment. A "centralized waste treatment facility" includes 1) a facility that treats waste received from off-site exclusively and 2) a facility that treats wastes generated on-site as well

as waste received from off-site.

**Clarification** -- A treatment designed to remove suspended materials from wastewater--typically by sedimentation.

**Clean Water Act (CWA)** -- The Federal Water Pollution Control Act Amendments of 1972 (33 U.S.C. 1251 et seq.), as amended, *inter alia*, by the Clean Water Act of 1977 (Public Law 95-217) and the Water Quality Act of 1987 (Public Law 100-4).

**Closed** -- A facility or portion thereof that is currently not receiving or accepting wastes and has undergone final closure.

**Combustion Unit** -- A device for waste treatment which uses elevated temperatures as the primary means to change the chemical, physical, biological character or composition of the waste. Examples of combustion units are incinerators, fuel processors, boilers, industrial furnaces, and kilns.

**Commercial facility** -- Facilities that accept waste from off-site for treatment from facilities not under the same ownership as their facility. Commercial operations are usually made available for a fee or other remuneration. Commercial waste treatment does not have to be the primary activity at a facility for an operation or unit to be considered "commercial."

**Conventional pollutants** -- The pollutants identified in Sec. 304(a)(4) of the CWA and the regulations thereunder (biochemical oxygen demand (BOD<sub>5</sub>), total suspended solids (TSS), oil and grease, fecal coliform, and pH).

**Direct discharger** -- A facility that discharges or may discharge treated or untreated pollutants into waters of the United States.

**Disposal** -- Intentional placement of waste or waste treatment residual into or on any land where the material will remain after closure. Waste or residual placed into any water is not defined as disposal, but as discharge.

**Effluent** -- Wastewater discharges.

**Effluent limitation** -- Any restriction, including schedules of compliance, established by a State or the Administrator on quantities, rates, and concentrations of chemical, physical, biological, and other constituents which are discharged from point sources into navigable waters, the waters of the contiguous zone, or the ocean. (CWA Sections 301(b) and 304(b).)

**EA** -- Economic Analysis

**EPA** -- The U.S. Environmental Protection Agency.

**Facility** -- A facility is all contiguous property owned, operated, leased or under the control of the same person. The contiguous property may be divided by public or private right-of-way.

**Hazardous Waste** -- Any waste, including wastewaters defined as hazardous under RCRA, Toxic Substances Control Act (TSCA), or any state law.

**Incinerator** -- means any enclosed device that:

- (1) Uses controlled flame combustion and neither meets the criteria for classification as a boiler, sludge dryer, or carbon regeneration unit, nor is listed as an industrial furnace; or
- (2) Meets the definition of infrared incinerator or plasma arc incinerator.

**Indirect discharger** -- A facility that discharges or may discharge pollutants into a publicly-owned treatment works.

**Industrial Furnace** -- means any of the following enclosed devices that are integral components of manufacturing processes and that use thermal treatment to accomplish recovery of materials or energy:

- (1) Cement kilns
- (2) Lime kilns
- (3) Aggregate kilns
- (4) Phosphate kilns
- (5) Coke ovens
- (6) Blast furnaces
- (7) Smelting, melting and refining furnaces (including pyrometallurgical devices such as cupolas, reverberator furnaces, sintering machine, roasters, and foundry furnaces)
- (8) Titanium dioxide chloride process oxidation reactors
- (9) Methane reforming furnaces
- (10) Pulping liquor recovery furnaces
- (11) Combustion devices used in the recovery of sulfur values from spent sulfuric acid
- (12) Halogen acid furnaces (HAFs) for the production of acid from halogenated hazardous waste generated by chemical production facilities where the furnace is located on the site of a chemical production facility, the acid product has a halogen acid content of at least 3 percent, the acid product is used in a manufacturing process, and except for hazardous waste burned as fuel, hazardous waste fed to the furnace has a minimum halogen content of 20 percent as generated.
- (13) Such other devices as the Administrator may, after notice and comment, add to this list on the basis of one or more of the following factors:
  - (I) The design and use of the device primarily to accomplish recovery of material products;
  - (ii) The use of the device to burn or reduce raw materials to make a material product;
  - (iii) The use of the device to burn or reduce secondary materials as effective substitutes for raw materials, in processes using raw materials as principal feedstocks;
  - (iv) The use of the device to burn or reduce secondary materials as ingredients in an industrial process to make a material product;
  - (v) The use of the device in common industrial practice to produce a material product; and,
  - (vi) Other factors, as appropriate.

**Industrial Waste** -- Hazardous or non-hazardous waste generated from industrial operation. This definition excludes refuse and infectious wastes.

**Industrial Waste Combustor facility** -- Any thermal unit that burns any hazardous or non-hazardous industrial wastes received from off-site from facilities not under their same corporate structure or subject to the same ownership. This term includes the following: a facility that burns waste received from off-site exclusively as well as a facility that burns wastes generated on-site and waste received from off-site. Examples of a commercial industrial waste combustor facility include: rotary kiln incinerators, cement kilns, lime kilns, aggregate kilns, boilers, etc.

**Industrial Waste Combustor wastewater** -- Water used in air pollution control systems of industrial waste combustion operations or water used to quench flue gas or slag generated as a result of industrial waste combustion operations.

**Intracompany** -- A facility that treats, disposes, or recycles/recovers wastes generated by off-site facilities under the same corporate ownership. The facility may also treat on-site generated wastes. If any waste from other facilities not under the same corporate ownership is accepted for a fee or other remunerations, the facility is considered commercial.

**LTA** -- Long-term Average. For purposes of the effluent guidelines, LTAs are defined as average

pollutant levels achieved over a period of time by a technology option. LTAs were used in developing the limitations and standards in today's proposed regulation.

**Minimum level** -- The level at which an analytical system gives recognizable signals and an acceptable calibration point.

**Municipal Facility** -- A facility which is owned or operated by a municipal, county, or regional government.

**New Source** -- "New source" is defined at 40 CFR 122.2 and 122.29.

**Non-conventional pollutants** -- Pollutants that are neither conventional pollutants nor priority pollutants listed at 40 CFR Section 401.

**Non-detect value** -- A concentration-based measurement reported below the sample specific detection limit that can reliably be measured by the analytical method for the pollutant.

**Non-hazardous waste** -- All waste not defined as hazardous under federal or state law.

**Non-water quality environmental impact** -- An environmental impact of a control or treatment technology, other than to surface waters.

**NPDES** -- The National Pollutant Discharge Elimination System authorized under Sec. 402 of the CWA. NPDES requires permits for discharge of pollutants from any point source into waters of the United States.

**NSPS** -- New Source Performance Standards

**OCPSF** -- Organic Chemicals, Plastics, and Synthetic Fibers Manufacturing Effluent Guideline.

**Off-site** -- "Off-site" means outside the boundaries of a facility.

**On-site** -- "On-site" means within the boundaries of a facility.

**Outfall** -- The mouth of conduit drains and other conduits from which a facility effluent discharges into receiving waters.

**Point Source Category** -- A category of sources of water pollutants.

**POTW or POTWs** -- Publicly-owned treatment works, as defined at 40 CFR 403.3(o).

**Pretreatment Standard** -- a regulation that establishes industrial wastewater effluent quality as required for discharge to a POTW. (CWA Section 307(b).)

**Priority Pollutants** -- The pollutants designated by EPA as priority in 40 CFR Part 423 Appendix A.

**Process wastewater** -- "Process Wastewater" is defined at 40 CFR 122.2.

**PSES** -- Pretreatment standards for existing sources of indirect discharges, under Sec. 307(b) of the CWA.

**PSNS** -- Pretreatment standards for new sources of indirect discharges, under Sec. 307(b) and (c) of the CWA.

**RCRA** -- Resource Conservation and Recovery Act (PL 94-580) of 1976, as amended.

**Residuals** -- The material remaining after a natural or technological process has taken place, e.g., the sludge remaining after initial wastewater treatment.

**Sewage Sludge** -- Sludge generated by a sewage treatment plant or POTW.

**Sludge** -- The accumulated solids separated from liquids during processing.

**Small business** -- Businesses with annual sales revenues less than \$6 million. This is the Small Business Administration definition of small business for SIC code 4953, Refuse Systems (13 CFR Ch.1, § 121.601)

**Solids** -- For the purpose of this notice, a waste that has a very low moisture content, is not free-

flowing, and does not release free liquids. This definition deals with the physical state of the waste, not the RCRA definition.

**Treatment** -- Any activity designed to change the character or composition of any waste so as to prepare it for transportation, storage, or disposal; render it amenable for recycling or recovery; or reduce it in volume.

**TSS** -- Total Suspended Solids. A measure of the amount of particulate matter that is suspended in a water sample. The measure is obtained by filtering a water sample of known volume. The particulate material retained on the filter is then dried and weighed.

**Waste Receipt** -- Wastes received for combustion.

**Wastewater treatment system** -- A facility, including contiguous land and structures, used to receive and treat wastewater. The discharge of a pollutant from such a facility is subject to regulation under the Clean Water Act.

**Waters of the United States** -- The same meaning set forth in 40 CFR 122.2

**Zero discharge** -- No discharge of pollutants to waters of the United States or to a POTW. Also included in this definition are discharge of pollutants by way of evaporation, deep-well injection, off-site transfer and land application.

