

EPA-520/3-75-003

PRELIMINARY ENVIRONMENTAL ANALYSIS OF A GENERIC FUEL REPROCESSING FACILITY



U.S. ENVIRONMENTAL PROTECTION AGENCY

Office of Radiation Programs

EPA Review Notice

This report has been reviewed by the EPA and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the EPA, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

Copies are available on written request, as supply permits, from:

U.S. Environmental Protection Agency
Office of Radiation Programs
Washington, D.C. 20460

OFFICE OF RADIATION PROGRAMS
ENVIRONMENTAL PROTECTION AGENCY
TASK ORDER NO. 68-01-1121

PRELIMINARY
ENVIRONMENTAL ANALYSIS OF A GENERIC FUEL
REPROCESSING FACILITY

R. Cooperstein, R. C. Erdmann, R. R. Fullwood
SAI Services
May 1974



SCIENCE APPLICATIONS, LA JOLLA, CALIFORNIA
ALBUQUERQUE • ANN ARBOR • ARLINGTON • BOSTON • CHICAGO • HUNTSVILLE • LOS ANGELES
PALO ALTO • ROCKVILLE • SUNNYVALE • TUCSON


1651 Old Meadow Road, Suite 620, McLean, Virginia 22101

FOREWORD

The Office of Radiation Programs carries out a national program designed to evaluate the exposure of man to ionizing and nonionizing radiation, and to promote the development of controls necessary to protect the public health and safety and assure environmental quality.

Office of Radiation Programs technical reports allow comprehensive and rapid publishing of the results of intramural and contract projects. The reports are distributed to groups who have known interests in this type of information such as the Nuclear Regulatory Commission, the Energy Research & Development Administration, and State radiation control agencies. These reports are also provided to the National Technical Information Service in order that they may be readily available to the scientific community and to the public.

Comments on this analysis as well as any new information would be welcomed; they may be sent to the Director, Technology Assessment Division (AW-559), Office of Radiation Programs, U.S. Environmental Protection Agency, Washington, D.C. 20460.

A handwritten signature in dark ink, appearing to read "W. D. Rowe", is positioned above the printed name and title.

W. D. Rowe, Ph.D.
Deputy Assistant Administrator
for Radiation Programs

PREFACE

Nuclear power has become a principal option to satisfy the national need for a clean, safe and reliable energy supply. As a result, the generation of light-water-cooled nuclear power reactors, using enriched uranium fuel, is experiencing rapid growth. This increase in nuclear power reactors will require similar growth in the associated aspects of the fuel cycle such as mining and milling of uranium ore, production of nuclear fuel material, manufacture of fuel elements, shipping, reprocessing of spent fuel elements and waste disposal activities. To date, the controlled and accidental releases of relatively small amounts of radioactivity from operating nuclear power and reprocessing plants have been maintained well below specified limits. However, these operations may impinge to a greater extent on the environment as a result of their anticipated growth.

Projections of the Civilian Nuclear Power Program indicate that the nuclear economy will expand to about 153 gigawatts by 1980 and to about 735 gigawatts by the year 2000. Economic analyses by the AEC and by commercial investors have concluded that generation of electric power by nuclear plants requires reprocessing of spent fuel to recover residual fissile materials for re-use in new fuel elements. Approximate total fuel reprocessing rates in metric tons per year could reach 3500 in 1980 and increase to 15,000 in the year 2000. The total radioactivity due to beta emitters in the accumulated wastes will increase from 210 megacuries (1970) to 18,800 megacuries in 1980 and to 209,000 megacuries in 2000.

The number of reprocessing plants that will be required is a function of the individual plant designs assumed and the amount of spent fuel to be processed. It is assumed, for this study, that one aqueous separations plant will be required for each 1500 metric tons of LWR fuel. A plant of this size should be capable of processing fuel from about 50 power reactors since each typical 1000 MWe LWR will discharge approximately 30 metric tons of fuel each year.

Reprocessing involves destroying the integrity of the spent fuel elements to permit dissolution and separation of the fuel from its metal cladding prior to chemical separation of the useful fissile materials from waste products by some adaptation of the Purex solvent extraction process. Destruction of the integrity of the fuel elements which had been maintained through the cycle in the reactor represents the main source of radioactivity from the nuclear power industry which could potentially enter the environment.

The Environmental Protection Agency, whose charter is to assure protection of the environment by systematic abatement and control of pollution, sponsored a program through its Office of Radiation Programs to perform an environmental analysis study of a generic fuel reprocessing facility in order to project what effects accidents, in such a facility, of potential environmental risk significance, may have on the public health and safety.

This report discusses the probabilities and consequences of hypothetical but credible accidents that could occur in the operation of a generic LWR fuel reprocessing plant which could have potential environmental impacts.

In preparing this report technical data was obtained from numerous sources, nevertheless as might be expected for an analysis of this type, "hard data" were not available in most cases and the authors were required to assume "best judgment values." The limitations which this type of approach places on these data and analysis should be recognized. However, it is our feeling that the methodology and approach used in this report are applicable to environmental analyses at fuel reprocessing plants, and that the information presented despite its limitations is the best available at this time.

SUMMARY

A generic reprocessing plant for light-water-reactor spent fuel utilizing the Purex process has been synthesized from a review of existing plants and those under construction. This model is used to develop a quantitative description of the probability of occurrence of a spectrum of potentially credible accidents and resultant radioactive releases during its operation. The results can be used to determine the potential impact on the environment.

It is concluded from evaluation of the generic design, systems and components that the most probable off-site release pathway that could endanger the public health and safety would be via airborne releases through the ventilation system in the event of accidents.

The postulated credible accidents considered include explosions during various unit operations involving different sources of radioactivity, fires, criticality, loss of cooling to the high level liquid waste facility and accidents which could derive from the occurrence of natural events such as earthquakes, tornadoes and floods.

Accidents which might occur during normal operation were emphasized over those that might occur during shutdown or neptunium batch processing conditions. In addition, no releases during decommissioning or start-up operations were analyzed.

If, during an accident large releases of noble gases or tritium were noted, these were not assessed because they

would normally be released in reprocessing spent fuel. The installation of noble gas collectors, to minimize krypton releases for example, were examined briefly. While such systems exist in the laboratory, production-scale systems are presently not available. Therefore the risk tradeoff between continual release of such gases and possible accidental release of stored quantities of such gases, after some period of radioactive decay, was not conducted.

Hypothetical accident probabilities are estimated by fault tree analysis of the model plant's safety and confinement systems during operation. The expected responses to hypothesized operating transients and postulated accidents, including natural events, are evaluated. Realistic assumptions based upon existing process technology and experience are used in the evaluations to determine the consequent radioactive releases.

If a processing modification is incorporated into the reprocessing cycle it will be a relatively simple matter to estimate the likelihood of releases from such a change for comparison with those documented herein. Thus, a measure of the level of acceptability of a processing change from a release or safety viewpoint is evident from this work.

In such a generic analysis, it is not possible to make a detailed account of the operational and design data which would be pertinent to an in-depth safety analysis. We have attempted, where possible, to utilize existing failure data supplementing this with estimates of how such an incident during processing might take place. Our considerations included types of instrumentation used, human behavior and

design. Thus, our results may be suspect in that errors in design, etc., may have been overlooked. Barring these anomalies, the accuracy of our results may vary within a factor of 10 or less from the true situation.

The ventilation system (scrubbers, HEPA filters) played a very prominent role in decreasing the consequences of many of the accidents releasing nonvolatile species. If such releases are determined to be excessive, one should consider installation of additional release mitigating equipment as a positive means of removing hazardous airborne substances.

Since the spent fuel to be reprocessed has substantially less decay heat compared to when it is housed in a reactor, the concerns of decay heat removal at a reprocessing plant, while real are not severe. Interruptions of power for effecting the latter, can be more readily tolerated. Even so, auxiliary power generation equipment is available to provide plant power during emergencies.

Based upon fault tree analysis and consequence calculations, consequence/likelihood plots are drawn for selected isotopes including ruthenium, iodine, plutonium, and other representative actinides and fission products.

By selecting the dominant accidents from these plots and by applying a simplified meteorological case, the dose in rems as a function of distance for a number of pertinent isotopes are plotted utilizing likelihood as a parameter. These data permit quantification of accident impact on the environment for a generic reprocessing plant.

It is recognized by EPA that this report presents only an initial analysis of the potential environmental impact of accidents at a generic LWR fuel reprocessing facility. There remain further analyses which could be completed, using this technique, for both a generic facility and for any specific facility design sited at a particular location. Extensions of the current study to derive population dose estimates and predictions of the health effects which could result from these exposures are examples of two such possible additional studies.

TABLE OF CONTENTS

| | <u>PAGE</u> |
|---|-------------|
| PREFACE..... | |
| FOREWORD..... | i |
| SUMMARY..... | iv |
| I. INTRODUCTION..... | 1 |
| II. DESCRIPTION OF THE GENERIC FUEL REPROCESSING PLANT AND CONTROLS..... | 7 |
| 1. Plant Description..... | 7 |
| 2. Comparison of Potential Hazards in a Reprocessing Plant and a Nuclear Power Plant..... | 11 |
| 3. Process Description and Radioactive Release Controls..... | 14 |
| 4. Radioactivity Confinement..... | 28 |
| 5. Administrative Controls..... | 29 |
| 6. Auxiliary Plant Systems and Controls..... | 33 |
| a. Ventilation and Off-Gas System..... | 33 |
| b. Water Supply..... | 34 |
| c. On-Site Electrical Power..... | 37 |
| d. Compressed Air Supply..... | 38 |
| e. Steam Supply..... | 38 |
| III. FAULT TREE CONSTRUCTION OF ACCIDENT SEQUENCES..... | 40 |
| 1. Background..... | 40 |
| 2. Fault Tree Symbolic Language..... | 42 |
| 3. Construction of the Fault Tree for a Nuclear Fuel Reprocessing Plant..... | 44 |
| IV. ACCIDENT ANALYSIS..... | 57 |
| 1. General..... | 57 |
| 2. History of Accidents in Reprocessing..... | 57 |
| 3. Postulated Accidents..... | 59 |
| a. Criticality in a Process Vessel..... | 60 |

TABLE OF CONTENTS (Cont'd)

| | <u>PAGE</u> |
|--|-------------|
| IV. 3. Postulated Accidents (Cont'd) | |
| b. Fire..... | 64 |
| 1. Solvent Fires..... | 66 |
| 2. Ion-Exchange Resin Fires..... | 67 |
| c. Explosion..... | 68 |
| d. Fuel Receiving and Storage Accidents..... | 75 |
| e. Waste Storage Accidents..... | 77 |
| f. Natural Phenomena Events..... | 79 |
| V. CONSEQUENCES OF ACCIDENTS..... | 82 |
| 1. HAW Concentrator Explosion..... | 83 |
| 2. Solvent Fire in Plutonium Extraction Cycle..... | 87 |
| 3. Solvent Fire in the Codecontamination Cycle..... | 89 |
| 4. Explosion in the LAW Concentrator..... | 92 |
| 5. Ion Exchange Resin Fire..... | 95 |
| 6. Nuclear Criticality Incident..... | 98 |
| 7. Explosion in the HAF Tank..... | 99 |
| 8. Waste Calciner Explosion..... | 101 |
| 9. Fuel Receiving and Storage Accident..... | 101 |
| VI. RISK ASSESSMENT..... | 105 |
| 1. Release Likelihood Spectra..... | 105 |
| 2. Dose Quantification..... | 113 |
| 3. Site Related Events..... | 124 |
| REFERENCES..... | 128 |
| APPENDIX A - Summary Table describing Basic Operations, Process Functions and Chemical Reactions in the Generic Spent Fuel Reprocessing Plant..... | A-1 |
| APPENDIX B - Fault Trees Used in Risk Assessment..... | B-1 |
| APPENDIX C - Descriptions of Accidents Experienced in the Nuclear Energy Field and Chem- ical Industry Relating to Anticipated Credible Events at a Fuel Reprocessing Plant..... | C-1 |

As of June 1, 1973, there were 33 operating reactors, 56 being built and 80 additional reactors on order. Based on nuclear power projections of 300,000 MWe by 1985, additional fuel reprocessing capability is needed to provide for the recovery of fissile material remaining in spent fuel elements¹. The two existing fuel reprocessing plants, Nuclear Fuel Services and the Midwest Fuel Recovery Plant, have combined capacities for reprocessing the spent fuel discharges from the equivalent of about 35 1000 MWe light water cooled power reactors (1050 MTU/year). The Barnwell Nuclear Fuel Plant, under construction, will have a capacity for reprocessing an additional 1500 MTU/year of spent LWR fuel bringing the total annual reprocessing capacity to only 2550 MTU/year. This will be insufficient capacity for the industry within the balance of this decade thereby requiring the construction of added capability to ensure smooth, economical and timely operation of the nuclear fuel cycle for the anticipated energy requirements.

In the operation of a nuclear power reactor, the buildup of fission products and the depletion of fissile material (U-235 and Pu) requires that for maximum utilization of the fuel, the reactor operator must periodically replace about one-third of the fuel elements and redistribute the remaining partially spent fuel elements throughout the reactor core. The discharged spent fuel elements still contain between one-third and one-fourth of the U-235 in the fuel prior to irradiation and part of the fissile Pu that was produced from U-238. The fuel reprocessing plant recovers the unused fissile material so that it can be recycled in reactor reload fuel. Reprocessing also permits separation and removal

of the fission products from the fissile material for conversion into an acceptable form for long term isolation from the biosphere.

The sequential process of transforming uranium ore into usable fuel for nuclear power reactors and the operations to recover unused values of uranium as well as the plutonium and other desirable isotopes produced during irradiation in the reactors constitute the "nuclear fuel cycle"². These operations are generally performed at separate installations in various parts of the country, depending for the most part upon the economics of transportation. The specific components comprising the LWR supporting fuel cycle are shown in Figure I-1, page 3, and include the following:

- a) Mining uranium ore
- b) Milling and refining ore to produce uranium concentrates (U_3O_8)
- c) Production of uranium hexafluoride (UF_6) from uranium concentrates to provide feed for isotopic enrichment
- d) Isotopic enrichment of uranium hexafluoride to attain reactor enrichment requirements using the gaseous diffusion process
- e) Fabrication of nuclear reactor fuel including:
converting UF_6 to uranium dioxide (UO_2), pelletizing, encapsulating in rods and assembling fuel elements




FIGURE I-1
Nuclear Fuel Cycle - Light Water Reactors
Uranium Dioxide Fueled - No Plutonium Recycle

- f) Reprocessing irradiated fuel and converting uranium to UF_6 for recycle through the gaseous diffusion plant for re-enrichment
- g) Radioactive waste management of high level and other than high level wastes, including long-term storage of wastes
- h) Transportation activities associated with moving materials to and from each of the above operations.

Uranium milling and refining (beneficiation of raw uranium ore into U_3O_8) is usually done near the mines to avoid the cost penalty involved in shipping the comparatively low value ore over long distances. Uranium ore is refined into U_3O_8 for shipment in drums to a "conversion" plant where it is converted into uranium hexafluoride (UF_6). Uranium in the UF_6 gaseous state is required as feed material for subsequent "enrichment" in the gaseous diffusion process.

Uranium hexafluoride, although refined as to total uranium content, still contains less than 1% of the fissionable isotope U-235 after "conversion". To be suitable for fabrication into fuel elements for modern power reactors, it must be "enriched" to approximately 2% to 5% U-235 (depending upon the specific design requirements of individual reactors). Thus, UF_6 is fed into enrichment plants where the U-235 isotope is upgraded to the required content.

After enrichment, the gaseous UF_6 is converted into a metallic oxide (UO_2) for fabrication into fuel elements

which, together with control rods, structure and moderating components, form the nuclear reactor core.

In the reactor, fuel elements initiate and sustain the controlled fissioning "chain reaction" which produces vast quantities of heat necessary to generate electricity via the steam-powered turbine generators. On the average, one pound of slightly enriched uranium produces approximately 3.2 million kilowatt hours (KWH) of electricity. This compares with about 2.2 million pounds of coal required to generate the equivalent electricity.

During irradiation in the reactor, various fission products are created which tend to lower reactivity over time through absorption of neutrons. Excessive accumulation of fission products and burn-up of U-235 impair the chain reaction and eventually shut down the reactor. Irradiated fuel, therefore, must be replaced periodically after being only partially consumed. As the fuel is irradiated in the reactor core, part of the fertile uranium isotope U-238 is converted to plutonium, a portion of which undergoes fission thereby contributing to the reactor's heat output. The remaining plutonium and other fission products stay intact and become potential byproducts and waste residues.

Economic considerations favor the recovery of the fissile material remaining in the spent fuel elements. The net value of this residual fissile material, after allowing for the costs associated with reprocessing, waste disposal and related transportation services, amounts to about \$50,000 per metric ton of irradiated fuel. Thus, during each year a 1500 MTU capacity reprocessing plant is operated at full capacity, it will reclaim fissile material having a net

worth of about \$75,000,000. Moreover, by recovery of fissile material, such a plant will conserve natural resources equivalent to about a million and one-half tons of uranium ore each year³.

Reprocessing accomplishes the objectives of:

- a. reclaiming the unused uranium and plutonium for subsequent recycling into replacement fuel
- b. extracting valuable isotopes such as neptunium and separating the waste fission products from the reusable fissile material
- c. concentrating the fission products and associated irradiated wastes to permit safer, less complicated handling for permanent storage and more economical storage that will result in a minimal impact on the environment.

This study is concerned with determining the probability of accidents associated with a generic light-water reactor irradiated fuel reprocessing plant and the consequences of these accidents to the environment. This analysis will permit a quantitative risk comparison with other parts of the nuclear fuel cycle and to other risks accepted by society. The study is limited to developing the accident risk envelope for a generic reprocessing plant that could impact on the environment. Fault tree analyses are used for the accident probability predictions. Only those trees needed in the development of the risk envelope are evaluated although a complete set of trees is presented to serve as an aid for future work in risk assessments of fuel reprocessing facilities.

II. DESCRIPTION OF THE GENERIC FUEL REPROCESSING PLANT AND CONTROLS

Public health and safety is a principal concern in reprocessing spent irradiated fuel to a similar extent as for nuclear power reactors. In fact, the reprocessing plant may be a greater source of radioactivity in effluents than a reactor⁴. Thus, adequate safety margins are included in the design of reprocessing plants to prevent accidents and to assure that acceptable protection systems will function reliably to mitigate the consequences of accidents, if they should occur, because of multiple system failures or noncompliance with procedures provided to prevent accidents⁵⁻⁷.

The function of a fuel reprocessing plant is to recover the residual fuel materials, uranium and plutonium, in a form suitable for reuse and to isolate radioactive wastes for storage and ultimate permanent disposal. The basic elements of reprocessing are illustrated in Figure II-1, page 8. This simplified flow diagram is generally applicable to any of the process techniques which have been applied for spent fuel reprocessing. The generic reprocessing technique for this study is the Purex process, a solvent extraction process, which has been in use for two decades in this country and is in use in other countries where spent fuels are processed⁸.

1. Plant Description

The following assumptions are made regarding the generic plant:

- the facility would be sited in conformance with AEC siting criteria as expressed in Part 100, Title 10 of the U.S. Code of Federal Regulations (10 CFR 100)⁹.
- sufficient water supply would be available for plant operation




FIGURE II-1
Fuel Reprocessing - Generic Flow Diagram

- it would have a processing rate of 5 metric tons of heavy metal (uranium and plutonium) per day of spent fuel from light-water power reactors
- the major facilities on the site would be:
 1. fuel receiving and storage facility
 2. main processing building housing the reprocessing, product storage and waste solidification equipment
 3. radioactive-area-ventilation-air filtration and discharge system
 4. high level radioactive liquid waste storage
 5. offices
 6. warehouse and shops
 7. steam-generating plant
 8. cooling towers
 9. a retention basin
 10. product conversion facilities

All processing equipment and systems for processing irradiated fuel elements, except for waste tank facilities, will be housed in the process, fuel receiving, and storage station building by the nature of the radiochemical operation. Because of the radioactivity that must be handled, many of the process systems must be heavily shielded; the equipment must be operated, and some of it must be maintained from stations that are remote from the equipment itself. Thus, as illustrated in Figure II-2, page 10, the facility is likely to be a massive concrete structure. This particular building was the proposed Atlantic Richfield Reprocessing Center which has the basic features of the Hanford and Barnwell Nuclear Fuel Plants¹⁰.

The model plant for this study is synthesized from the features of the three plants scheduled to be operational by the mid-1970's. These are the Barnwell Nuclear Fuel Plant (BNFP), the Nuclear Fuel Services Plant (NFS) and the Midwest Fuel Recovery Plant (MFRP). Their respective reprocessing capacities are 1500, 750 and 300 metric tons per year of low-enrichment uranium fuels irradiated in light-water power reactors⁵⁻⁷. The assumed model most closely resembles the BNFP because




FIGURE II-2
ARC PROCESS BUILDING

of its larger capacity, which is used for the purpose of estimating the fractional releases of radioactive materials for the accidents considered. This choice is based on the belief that future plants will be designed for such a capacity to effect low unit processing costs. High capacity, small volume equipment will be used to minimize plant inventory of both reactor fuel and process reagents thereby ensuring a greater degree of overall safety and economy. Future plants may have different characteristics from those used in this study; however, it is expected that the derived quantities of radionuclides that could be released in potential credible accidents will remain unchanged or decrease as a result of advancing technology¹¹.

2. Comparison of Potential Hazards in a Reprocessing Plant and a Nuclear Power Plant

Performance criteria for engineered safety in reprocessing plants are based upon those proposed for nuclear reactors (Appendix A, 10 CFR 50; Code of Federal Regulations⁹) although the function and design of reprocessing plants are significantly different. Potential hazards in a separations facility differ considerably from those anticipated in power reactors due to the specific conditions found in the reprocessing plant. Examples of these differences follow:

- The potential for a nuclear criticality is very low in a reprocessing plant albeit fissionable isotopes are present in quantity and are separated and purified in the course of operations. The use of soluble and fixed poisons, favorable geometry, concentration control and mass control mitigates the possibility of nuclear criticality where a nuclear chain reaction could take place.

- Fuel reprocessing operations are generally of such a nature that the rate of approach of critical parameters (concentration, temperature, acidity, etc.) to prescribed upper limits will be relatively slow compared to power reactors. Although reliable instrumentation and control provisions are required, very rapid response is not necessary. The effect of exceeding prescribed operating limits does not usually present an immediate hazard.
- The cladding, which serves as the primary barrier to fission product escape from fuel in a reactor, must be breached in the reprocessing operation to recover the fissile materials. The potential hazard from having mobile radioactive materials in plant process systems, however, is relatively low since the systems do not contain large amounts of stored energy (like power reactor primary coolant systems) which could provide the driving force of radioactivity dispersal.
- In some instances, plant process streams will be corrosive. System failure due to corrosion with subsequent radionuclide releases may not be severe for the streams are doubly contained for leak tightness and operate at low pressures.
- Flammable and/or chemically reactive materials are used in fuel reprocessing operations. Well developed technologies, however, are used for assuring that potential hazards from use of such materials are appropriately controlled.
- The potential hazards from loss of plant cooling capability are low due to the lower stored energy levels of the limited fissile inventory in process which has

already undergone extended decay times. Emergency power supply availability will enhance safety assurance by providing positive off-gas release control and continuity of process condition surveillance and safe shutdown conditions. Continuous cooling is not critical although necessary for high level wastes which are stored on an interim basis. Cooling is used to avoid boiling in the high level liquid wastes and/or overheating of the containment vessels. Overheating could compromise the integrity of the storage tanks resulting in uncontrolled releases of waste fission products to the environment.

- Fuel reprocessing operations are performed at low temperatures - limited to normal boiling points at atmospheric pressure - and at low pressures - limited by subatmospheric pressure maintained in the process system.
- Fission product wastes produced during irradiation of power reactor fuel are separated in the reprocessing plant and large quantities of these materials must be stored and controlled. Process operations are performed to reduce the volumes of solutions of such wastes to more manageable volumes which will not be released to local water courses. Alternatively, the wastes will be converted to low mobility forms (solids) for safe on-site retention until transferred to authorized permanent disposal facilities.
- Off-gas treatment processes and controlled effluent releases are required to assure that gaseous products which are not amenable to immobilization are not released from the plant at rates exceeding prescribed limits.

The Purex process basically involves solutions and as such makes the recovery of tritium especially difficult.

3. Process Description

The overall process function is to recover the contained uranium and plutonium from spent fuel assemblies. The Purex solvent extraction process will be used to separate the latter from fission products. To accomplish the overall function, several processes must be used. They are described in the following and are illustrated by the simplified block diagram in Figure II-3, page 15, which is the particular flow diagram for the BNFP facility. For comparative purposes, the block diagrams for the MFRP and NFS processes are illustrated in Figures II-4 and II-5, pages 16 and 17. Principal similarities and differences among the commercial plants and the assumed model are listed in Tables II-1 and II-2, pages 18 and 19.

- Fuel Receipt and Storage. Irradiated fuel assemblies arrive at the reprocessing plant in shielded casks. These are monitored for outside contamination, cleaned, removed from the carriers and submerged in a pool of water for unloading the fuel assemblies. The cask is opened, the fuel assemblies removed and placed in storage canisters. The canisters are moved to a fuel storage pool where they are held until the fuel is scheduled for reprocessing.
- Mechanical Disassembly. When scheduled for reprocessing, the fuel assembly is remotely transferred to a mechanical facility where it is sheared, as rods or as fuel bundles, into short lengths to expose the fuel to the dissolvent.




FIGURE II-3
Simplified Flow Diagram of BNFP Process⁷





FIGURE II-4

MFRP GE PROCESS⁶

General Electric's proposed Aqua-fluor process makes use of aqueous and fluoride volatility fuel recovery technologies. The process uses well-demonstrated fuel recovery techniques including fuel shearing and leaching, solvent extraction, anion exchange, calcination, fluorination, and uranium hexafluoride distillation. Anion exchange is used in the recovery and purification of plutonium and neptunium. Uranium will be converted to the volatile uranium hexafluoride (UF_6) and purified to make it suitable for toll enrichment. The high level liquid wastes will be converted to solid form and stored temporarily on-site in a water-filled concrete storage basin.

FIGURE II-5

NUCLEAR FUEL SERVICES, INC., SPENT FUEL PROCESS⁵



PROCESS DESCRIPTION

Spent nuclear fuel is transported from the reactor site to the reprocessing plant in shielded casks. The casks are unloaded underwater and the fuel assemblies are stored prior to reprocessing.

The fuel is transferred from the storage pool to a mechanical processing cell where end-fitting hardware is removed and the fuel is sheared into small pieces. The pieces are collected in a canister, which is placed in a dissolver, where the fuel values and fission products are dissolved in nitric acid. (The insoluble cladding materials—hulls—are monitored to establish completeness of dissolution of fuel values and buried in the plant's radioactive waste burial ground.) The dissolver solution is subjected to solvent extraction with a mixture of tributyl phosphate and a diluent to separate the majority of the fission products from the contained uranium and plutonium values. The plutonium and uranium are then separated by solvent extraction techniques and the resulting plutonium and uranium streams are subjected to solvent extraction purification to remove the remaining fission products.

The uranium product stream is concentrated by evaporation and subjected to a final decontamination with silica gel, resulting in a uranyl nitrate solution product. The plutonium product stream is subjected to an ion exchange treatment to effect both the concentration and further decontamination of the plutonium—yielding the final plutonium nitrate solution product.

Liquid waste is subjected to evaporation, neutralized and stored in underground liquid waste tanks.

TABLE II-1
PRINCIPAL SIMILARITIES OF THE MODEL SEPARATIONS FACILITY
COMPARED TO OTHER COMMERCIAL REPROCESSING FACILITIES

| <u>Comparison Item</u> | <u>Model</u> | <u>BNFP</u> | <u>NFS</u> | <u>MFRB</u> |
|--------------------------------|---|---|---|---|
| Fuel Unloading and Storage | Underwater | Underwater | Underwater | Underwater |
| Headend Process | Chop-Leach | Chop-Leach | Chop-Leach | Chop-Leach |
| Stored Fuel Criticality Safety | Spacing | Spacing | Spacing | Spacing |
| Fuel Chopping | Mechanical Shear | Mechanical Shear | Mechanical Shear | Mechanical Shear |
| Fuel Dissolution Material | Nitric Acid | Nitric Acid | Nitric Acid | Nitric Acid |
| Fuel Dissolution Technique | Semicontinuous | Semicontinuous | Batch | Semicontinuous |
| Fuel Dissolution Equipment | Baskets in Dissolvers | Baskets in Dissolvers | Baskets in Dissolvers | (No Similarity) Leaching trough |
| Solvent Cleanup | Alternate Contact with Sodium Carbonate and Nitric Acid Solutions | Alternate Contact with Sodium Carbonate and Nitric Acid Solutions | Alternate Contact with Sodium Carbonate and Nitric Acid Solutions | Alternate Contact with Sodium Carbonate and Nitric Acid Solutions |
| Final Exhaust Filters | Roughing and HEPA | Roughing and HEPA | Deep Fiberglass and HEPA | (No Similarity) Sand Filter |

TABLE II-2
PRINCIPAL DIFFERENCES OF THE MODEL SEPARATIONS FACILITY
COMPARED TO OTHER COMMERCIAL REPROCESSING PLANTS

| Comparison Item | Model | BNFP Separations Facility | NFS | MFRP |
|---|---|--|--|---|
| Location | Compliance with 10 CFR 100 | South Carolina | New York | Illinois |
| Design Capacity | 5 MTU/day | 5 MTU/day | 3 MTU/day | 1 MTU/day |
| Shearing | Entire fuel elements including end fittings | Entire fuel elements including end fittings | End fittings may be removed before shearing | Pins removed from fuel elements before shearing pins only |
| Criticality Control During Dissolution | Soluble poison | Soluble poison | Geometric limitations | Geometric limitations |
| Fuel Dissolution Technique | Semicontinuous | Semicontinuous | Batch | Semicontinuous |
| Fuel Dissolution Equipment | Baskets in Dissolvers | Baskets in Dissolvers | Baskets in Dissolvers | Vibratory Leacher Tray |
| HA Contactor | Centrifugal Contactor | Centrifugal Contactor | Pulse Column | Pulse Column |
| Partitioning | Ion Exchange | Electropulse column | Solvent extraction with chemical valence adjustment | Ion exchange |
| Interim High-Level Waste Storage Form | Acidic solution (1-5 molar) | Acidic solution (1-5 molar) | Acidic solution | Calcined solid |
| Iodine Removal from Process Off-gas | Mercuric Nitrate Iodine Scrubbers plus Iodine Silver Zeolite Adsorption Bed | Mercuric Nitrate Iodine Scrubbers plus Iodine Silver Zeolite Adsorption Beds | Mercuric nitrate scrubbers plus sil- ver zeolite adsorption beds. | Sodium Hydroxide Scrubbers. Heated Silver Zeolite |
| Process Vent Filters | Roughing and HEPA | Roughing and HEPA | Multiple HEPA | Packed Fiberglass Filter |
| Final Exhaust Filters | Roughing and HEPA | Roughing and HEPA | Deep Bed Fiberglass plus HEPA | Sand Filter |
| Feed Clarification | Centrifuge | Centrifuge | None | None |
| Tritium Disposal | As vapor up stack | As vapor up stack | As water to creek | As vapor up stack |
| Uranium Product Form | Hexafluoride | Nitrate solution | Hexafluoride | Hexafluoride |
| Liquid Effluent | Noncontaminated | Noncontaminated | Contaminated | Noncontaminated |

The fuel segments fall into or are fed into a dissolver vessel.

Fuel Dissolution. The segmented fuel containing the plutonium, neptunium and fission products formed during irradiation, as well as unspent uranium is dissolved out of the cladding hulls with nitric acid to form the feed for subsequent remote liquid-liquid solvent extraction steps. After dissolution, the undissolved cladding hulls, made of zirconium, zirconium alloys or stainless steel, are separated from the solution, rinsed, monitored for residual fissile material and transferred to a protected interim vault storage area. Gases generated during the dissolutions are channeled to an off-gas treatment system. This system contains decontaminating units such as condensers, scrubbers, chemical traps for iodine removal and particulate filters which remove radioactive gases and particulates other than inert gas, e.g., Kr-85 and tritium, to levels below allowable release limits before being exhausted to the atmosphere. Nitrogen oxides formed during the dissolutions are also retained by the ventilation treatment system to minimize their release to the atmosphere.

- Solvent Extraction. The chemically adjusted aqueous feed solution is then subjected to a Purex-type extraction. It is contacted countercurrently in a centrifugal contactor with an organic solution of tributyl phosphate (TBP) dissolved in normal paraffin hydrocarbon diluent (dodecane). The organic solution preferentially extracts the tetravalent plutonium and hexavalent uranium, leaving about 95% of the fission products in the aqueous solution. The organic solution from the extraction passes through

a scrubbing column where it is washed with additional nitric acid solution. This step removes about 96% of the residual extracted fission products from the organic product solution. The wash solution is recycled back to the centrifugal contactor. The aqueous solution leaving the codecontamination cycle contains about 99.8% of the fission products from the initially dissolved solution. It is routed to a high level waste treatment system where it is concentrated for protected interim liquid waste storage and/or calcined to an immobile solid form, loaded into specially designed containers and transferred to protected storage facilities for ultimate authorized off-site disposal. A simplified block diagram illustrating the solvent extraction cycle is shown in Figure II-6, page 22.

- Product Separation. Anion exchange or electrochemical reduction is used to partition plutonium and uranium into separate streams following the codecontamination step. In the former operation, solution from the solvent extraction system concentrator is fed through a cooler to a series of semicontinuous ion exchange contactors, in an ion-exchange cell, where the plutonium is sorbed on the resin as anionic $\text{Pu}(\text{NO}_3)^{-}$ and subsequently removed as a nitrate solution for concentration and loadout. Alternatively, the organic solution from the codecontamination step can be passed through a partitioning column where tetravalent plutonium is electrochemically reduced to the less extractable trivalent state. The reduced plutonium is then stripped into an aqueous nitric acid solution containing hydrazine as a holding reductant. The organic uranium containing solution is then stripped into acidified water. Electrochemical reduction and solvent extractions eliminate the need for chemical




FIGURE II-6
SOLVENT EXTRACTION CYCLE

additions for valence adjustment and the use of ion-exchange resin columns. The quantities of waste to be subsequently handled and disposed of, are also reduced. In this analysis, the former unit operation is reviewed for its accident potential.

- Uranium Purification and Recovery. The aqueous uranium strip solution is concentrated and its acidity is adjusted prior to resubjecting it to another partitioning cycle and filtration through a silica gel bed for final concentration loadout as uranyl nitrate solution. The operations remove additional residual fission products and plutonium further ensuring that the uranium solution meets product specifications for reuse in the fuel cycle. The nitrate solution is ultimately shipped as such or converted to UF_6 in an associated facility prior to shipment for reuse in the fuel cycle.

- Plutonium Purification and Recovery. Plutonium in the aqueous stream may be cyclically converted to anionic $Pu(NO_3)_6^{--}$ and sorbed on strong base anion exchange resin while the associated uranium and fission products are washed out in the raffinate. The sorbed plutonium from the last purification cycle is eluted as nitrate solution, concentrated and stored pending conversion to plutonium dioxide for use in plutonium recycle or breeder reaction fuel elements. Alternatively, the aqueous plutonium stream leaving the partitioning column may be reoxidized to the extractable tetravalent state and subjected to additional extraction-scrubbing sequences as described above to further decontaminate the product solution from fission products. The final plutonium nitrate solution, after concentration, is analyzed and stored in geometrically favorable tanks until it is converted in the Plutonium

Product Facility to the solid oxide form for storage and/or off-site shipment.

- Organic Solvent Systems. The organic solvent waste streams from the decontamination and partition cycles are washed successively with dilute aqueous solutions of sodium carbonate, followed by nitric acid and neutralized by sodium carbonate to remove organic degradation products by extraction or precipitation. Precipitated solids are removed by filtration. As required, fresh TBP or diluent is added to maintain the TBP concentration and the total solvent inventory.

Liquid Waste Treating and Storage. The aqueous raffinate streams from the plutonium and uranium cycles are reprocessed for residual fissile material content by extraction into TBP organic solution which is recycled back to the decontamination cycle for recovery. The aqueous raffinate, essentially depleted of radioactive materials, is then concentrated in the low level waste concentrator. The radioactive waste streams from all the solvent extraction cycles are concentrated in the high-level or low-level waste concentrators to recover nitric acid and water for reuse in the process while reducing the waste volumes to be stored in appropriate waste facilities; miscellaneous waste streams containing salts, minimal fission products and no appreciable fissile material are acidified and concentrated. The concentrator bottoms are stored in appropriate waste tanks for ultimate disposal at a federal repository and the condensed overheads are vaporized to the stack.

- Process Off-Gas Treatment. In order to maintain near-atmospheric internal working pressures, with very few exceptions, all of the process equipment pieces - vessels, extractors, condensers, etc. - are vented to one or more process vent systems. The vent gases are treated by scrubbing with circulating mercuric nitrate solution to remove radioactive iodine, then treated in an absorber to convert nitrogen oxides to nitric acid suitable for recycling. The dissolver off-gas and vessel off-gas streams are combined and passed through a second decontamination train which includes an iodine scrubber unit, iodine adsorber beds and a series of high efficiency filter banks before being released to the stack. Thus, the relatively small amounts of radioactivity including most of the remaining radioiodine are removed from the vent gases prior to discharge, via a stack, to the atmosphere. The vent gases will probably contain most of the tritium as a result of operations in the acid recovery system. Virtually all of the tritium from the original fuel follows the water phase, as tritiated water, to the waste system and thence to the process condensates derived during evaporation-acid recovery operations. In early process designs, this material was discharged to the environment following evaporative and chemical treatments, for removal of entrained non-volatile activity. Current design approaches recycle process condensates in the process, as process water, with evaporation of a small-volume remainder of the condensate to discharge tritium to the atmosphere via the off-gas system and the stack.

The gaseous wastes from a reprocessing plant include a ventilation air, which is indirectly exposed to the process, besides the process off-gases which are directly exposed to the process and which contain some volatile radionuclides. Both systems are shown by Figure II-7, page 27. In this block diagram, the process building is shown schematically as the large block on the left. The building operating spaces are divided into four zones of ventilation control, with corresponding increasing levels of potential contamination by radioactivity, and increasing degrees of access control requirements. As plotted on the diagram, the building ventilation system is engineered to maintain pressure differentials between zones such that the air flow is always toward the zone of greater potential contamination. The Zone 1 spaces, shown at a slightly positive air pressure, include offices, lunchrooms, etc., and no special radiological control measures are required. Examples of Zone 2 spaces include parts of the analytical laboratories. The potential for radioactive contamination is low, but controlled access is required. Zone 3 spaces include plutonium product loadout spaces, other spaces of the analytical laboratories, etc. Access is supervised. Zone 4 spaces are those which are expected to be routinely contaminated, such as process cells. The negative pressure in Zone 4 is typically an inch of water.

A relatively large volume of air continuously flows through the process building zones, through an efficient filtration system, and to the atmosphere via a stack.




FIGURE II-7
OFF-GAS AND VENTILATION WASTES

With the exception of incoming fuel shipments and the transfer of solid scrap to burial, all radioactive material handled in the operation of the plant is located in an exclusion area. All processing equipment and systems for processing irradiated fuel elements, except for waste tank facilities, may be housed in the process and fuel receiving and storage station building as exemplified in the isometric drawing, Figure II-2, page 10. A summary of the process functions and chemical reactions involved in reprocessing is given in Appendix A.

4. Radioactivity Confinement

The general concept of radioactivity confinement used in the generic plant analysis has been used for many years and has performed reliably in plants processing LWR fuels decayed for half a year or more.

The reprocessing facility design and process flow operations include multiple methods and systems to insure control of radioactive material so that in-plant and off-site exposures exceeding allowable limits, are not experienced throughout the life of the plant under normal operating conditions and routine maintenance. Confinement is based upon the use of one or more of the following:

- Barriers to confine radioactive materials in the plant which include process piping and equipment, building structures, casks and storage tanks.
- Channeling to confine the flow of fluid within fixed barriers or direct it through fixed barriers by pressure differentials or by gravity. Channeling is used to direct potentially contaminated fluids away from plant personnel and/or points of uncontrolled release toward a treatment system or point of controlled release.

- Treatment to remove radioactive material from fluids or gases discharged to the environment so that established limits are not exceeded.
- Burial to confine certain non-mobile radioactive solid wastes within the site boundaries.

The methods used, depending upon the mobility, quantity, type and intensity of the associated radioactivity for the unit operation involved, are shown in Table II-3, page 30.

Accidental radioactive releases, as measured by an increase in off-site radiation level, could follow three pathways: release to liquid effluents, release to ground water and release to the atmosphere. The confinement and ventilation systems in fuel reprocessing plants remove particulates of non-volatiles dispersed under accidental conditions and liquid releases to such an extent that off-site environmental risks are dominated by airborne releases of volatile and semi-volatile materials only. Therefore, the airborne release pathway was the major one considered for evaluations of the off-site environmental risks from potential accidents in the plant operations. Secondary emphasis was placed on liquid releases to the ground. A radioactive material flow diagram for a reprocessing plant, as exemplified by BNFP, is shown schematically in Figure II-8, page 31.

5. Administrative Controls

The operation of a radiochemical separations plant is in most respects like the operation of any large chemical plant except for the complications introduced by the radioactive nature of the process materials. Working with radioactive materials necessitates adherence to extensive government regulations for their control. These are found

TABLE II-3
CONFINEMENT

| | Confinement Method Used | | |
|---|-------------------------|----------|-----------|
| | Barriers | | Treatment |
| | Single | Multiple | |
| a. Pool Water | x | | x |
| b. Fuel Elements-Undamaged | | x | |
| c. Fuel Elements-Damaged | x | | x |
| <u>Process</u> | | | |
| d. Fluids | | x | x |
| e. Solids | x | | x |
| <u>Product</u> | | | |
| f. Uranium (Storage & Shipping) | x | | |
| g. Plutonium & Neptunium | | x | x |
| * h. Plutonium & Neptunium (Storage & Shipping) | | x | |
| <u>Waste</u> | | | |
| i. High Level Liquid | | x | x |
| * j. Intermediate Liquid | | x | x |
| * k. Low Level Liquid with Tritium | x | | x |
| l. Other Low Level Liquid | x | | x |
| m. Solids (Hulls & Equipment) in cell | x | | x |
| * n. Hulls during Transport | | x | |
| * o. Contaminated Equipment & Solid | | | |
| * Radioactive Wastes during Transport | x(1) | x(1) | |

- * (1) Number of barriers will be dependent upon the radiation level of the material. If the radiation level is high, shielding will be provided during transport.

BNFP RADIOACTIVE MATERIAL FLOW

31




FIGURE II-8

under Code of Federal Regulations, Title 10, Chapter I⁹. These regulations serve as minimum limits for operational safety.

The principles upon which criticality safety and radioactive contamination controls are based, are implemented in plant design and plant operation. In addition, however, administrative responsibilities are assigned to specific individuals or groups, at the plant, for plant functions to assure that the reprocessing plant is operated and maintained under the full range of normal and potential accident conditions without risk to public health and safety.

The daily functioning of the fuel reprocessing plant is governed by an on-site organization which is self-sufficient in regard to assuring public, plant personnel and facility safety on a day-to-day basis. Functional components in this organization include engineering, production, safety and analytical services, employee and community relations and financial groups. These licensed personnel have specific qualifications for overseeing criticality and radiation safety, accountability for special nuclear materials, plant operation, plant maintenance, plant assistance and plant services which include decontamination and waste disposal operations. The on-site staff assure that all safety-related activities are performed in accordance with established procedures. Reviews and audits of plant safety are performed at appropriate intervals both on an internal and independent basis for compliance with prescribed requirements.

A criticality-safety control committee appointed by management establishes the limits on the operating variables that have a bearing on criticality safety. This committee,

composed of representatives from all the functioning groups, reviews proposed changes in equipment or in operating procedure. The committee's approval is required before any change is implemented.

Radiation survey inside the plant as well as in the site environs within a radius of up to 50 miles verifies the effectiveness of contamination control.

Through a system of checks and balances among the functional components in carrying out their daily operations of the plant, the maintenance of performance records, the institution of training programs and testing of personnel to assure their ability to discharge safety-related responsibilities and the performance of audits at regular intervals, plant safety under all normal and abnormal operation conditions as well as full compliance with license and regulatory requirements are further assured.

6. Auxiliary Plant Systems and Controls

a. Ventilation and Off-Gas System

In the generic plant, only gaseous and solid radioactive wastes will eventually leave the site. No radioactive liquid effluents will be exposed to the environment.

The primary effluent that could have an impact on the environment during operation of the facility is the gaseous effluent from the stack. This was discussed briefly in an earlier section and in more detail in the following.

The gaseous effluent from the main stack consists of building ventilation air, vaporized process condensate and the off-gases from the dissolver and vessel off-gas treatment system. The building ventilation exhaust air is routed through at least two stages of high efficiency (HEPA) filters prior to discharge to the atmosphere. Excess process condensate is decontaminated by evaporation and condensation. The decontaminated water is recycled to the process or alternatively may be revaporized and discharged to the atmosphere via the 100-meter tall stack. The dissolver off-gases (DOG) are routed through a treatment train consisting of a condenser, knock-out pot, iodine scrubber and an NO_2 absorber. The NO_2 absorber is designed to recover 70 percent of the NO_x as 45 percent nitric acid. The treated dissolver off-gas, which still contains residual amounts of NO_x and iodine, is further treated through the vessel off-gas treatment system (VOG) which also collects gases vented from various other process or storage vessels. The VOG treatment system consists of a condenser, knock-out pot, iodine scrubber, pre-filter, iodine absorber and a two-stage high efficiency (HEPA) filter. The stack is equipped with samplers, monitors and alarms which identify the amounts of radioactivity in the effluent. The system is illustrated in Figure II-9. The expected radioactive release from use of the treatment systems shown in Figure II-9 in processing high-exposure spent fuel (average annual fuel exposure of 32,000 MWD/MTU at 40 MW/MTU) cooled 180 days from reactor discharge, and processed at the rate of 1500 MTU/year is listed in Table II-4, page 36.

b. Water Supply

Water must be provided for process streams, for makeup water for closed loop cooling systems, for cooling towers




FIGURE II-9
 SEPARATIONS FACILITY EFFLUENT TREATMENT SYSTEM⁷

TABLE II -4

ESTIMATED AVERAGE RADIOACTIVE EFFLUENTS
(curies/sec) - Separations Plant Main Stack

| Stream No. | 1 | 2 | 3 | 4 | 5 | 6 | 7 | Total To Stack |
|---------------------|---------|---------|---------|---------|---------|---------|---------|----------------|
| ⁰ H-3 | 3.6E-3 | -- | -- | 1.4E-2 | -- | 3.6E-3 | 1.4E-2 | 1.8E-2 |
| ⁰ Kr-85 | 4.3E-1 | -- | -- | -- | -- | 4.3E-1 | -- | 4.3E-1 |
| Sr-89 | 2.0E-6 | 1.0E-5 | 2.0E-5 | 4.1 | 1.1E-3 | 6.5E-9 | 1.1E-9 | 7.6E-9 |
| ⁰ Sr-90 | 2.3E-6 | 1.2E-5 | 2.3E-5 | 4.8 | 1.3E-3 | 7.6E-9 | 1.3E-9 | 8.0E-9 |
| Y-90 | 2.3E-6 | 1.2E-5 | 2.3E-5 | 4.8 | 1.3E-3 | 7.6E-9 | 1.3E-9 | 8.0E-9 |
| Y-91 | 4.2E-6 | 2.1E-5 | 4.2E-5 | 8.7 | 2.4E-3 | 1.4E-8 | 2.3E-9 | 1.6E-8 |
| Zr-95 | 7.4E-6 | 3.8E-5 | 7.4E-5 | 15.4 | 4.2E-3 | 2.4E-8 | 4.0E-9 | 2.0E-8 |
| Nb-95 | 1.4E-5 | 7.1E-5 | 1.4E-4 | 29 | 7.9E-3 | 4.6E-8 | 7.6E-9 | 9.3E-8 |
| Ru-103 | 2.2E-6 | 1.1E-5 | 2.2E-5 | 4.6 | 1.3E-3 | 7.2E-9 | 1.2E-9 | 8.4E-9 |
| Ru-106 | 1.3E-5 | 6.7E-5 | 1.3E-4 | 28 | 7.4E-3 | 4.3E-8 | 7.2E-9 | 9.0E-8 |
| ⁰ I-129 | 1.4E-8 | -- | -- | 0.1E-8 | 4.1E-8 | 1.4E-10 | 1.1E-9 | 1.5E-9 |
| ⁰ I-131 | 1.1E-9 | -- | -- | 9.3E-7 | 9.3E-7 | 1.1E-9 | 1.1E-9 | 1.2E-6 |
| ⁰ Cd-114 | 5.0E-6 | 2.6E-5 | 5.0E-5 | 11 | 2.9E-3 | 1.7E-8 | 2.4E-9 | 1.9E-8 |
| ⁰ Cd-117 | 3.2E-6 | 1.6E-5 | 3.2E-5 | 6.7 | 1.0E-3 | 1.0E-8 | 1.7E-9 | 1.2E-8 |
| Co-141 | 1.4E-6 | 7.3E-5 | 1.4E-5 | 3.0 | 0.1E-4 | 4.7E-9 | 7.8E-10 | 9.5E-9 |
| Co-144 | 2.2E-5 | 1.1E-4 | 2.2E-4 | 46 | 1.3E-2 | 7.2E-8 | 1.2E-8 | 8.4E-8 |
| Pm-147 | 4.0E-6 | 2.0E-5 | 4.0E-5 | 8.3 | 2.2E-3 | 1.3E-8 | 2.2E-9 | 1.9E-8 |
| U-234 | 4.3E-11 | 2.4E-10 | 2.2E-12 | 4.4E-11 | 2.2E-12 | 4.4E-14 | 2.2E-14 | 7.0E-14 |
| U-235 | 4.2E-13 | 2.4E-12 | 2.2E-14 | 4.4E-9 | 2.2E-10 | 4.4E-16 | 2.2E-16 | 7.0E-16 |
| U-238 | 9.9E-12 | 5.8E-11 | 5.4E-13 | 1.1E-7 | 5.4E-9 | 1.4E-10 | 5.4E-19 | 2.0E-14 |
| ⁰ Pu-238 | 1.0E-7 | 2.8E-7 | 1.1E-8 | 2.2E-3 | 5.6E-5 | 7.9E-11 | 5.3E-11 | 1.3E-10 |
| ⁰ Pu-239 | 9.0E-9 | 2.5E-8 | 9.9E-10 | 2.0E-4 | 9.0E-6 | 7.3E-12 | 4.8E-12 | 1.2E-11 |
| ⁰ Pu-240 | 1.6E-8 | 4.6E-8 | 1.8E-9 | 3.6E-4 | 9.1E-6 | 1.2E-11 | 8.7E-12 | 2.1E-11 |
| ⁰ Pu-241 | 4.2E-6 | 1.2E-5 | 4.5E-7 | 9.1E-2 | 2.3E-3 | 3.3E-9 | 2.2E-9 | 9.5E-9 |
| Pu-242 | 8.6E-11 | 2.4E-10 | 9.5E-12 | 1.9E-6 | 4.8E-8 | 6.0E-14 | 4.6E-14 | 1.1E-13 |
| ⁰ Am-241 | 0.7E-9 | 4.3E-8 | 0.7E-8 | 1.4E-2 | 4.3E-6 | 2.8E-11 | 4.3E-12 | 3.2E-11 |
| Am-242 | 1.7E-10 | 8.4E-10 | 1.7E-9 | 2.7E-4 | 8.4E-8 | 9.9E-13 | 8.4E-14 | 6.3E-13 |
| ⁰ Cm-242 | 1.0E-6 | 5.1E-6 | 1.0E-5 | 1.7 | 5.1E-4 | 3.2E-9 | 5.1E-10 | 3.7E-9 |
| Cd-243 | 6.7E-10 | 3.4E-9 | 6.7E-9 | 1.1E-3 | 3.4E-7 | 2.1E-12 | 3.4E-13 | 2.9E-12 |
| ⁰ Cd-244 | 1.1E-7 | 5.4E-7 | 1.1E-6 | 1.8E-1 | 5.4E-5 | 3.4E-10 | 5.4E-11 | 3.9E-10 |

*Quantitatively and Biologically Significant.

Short lived decay products are also present in equilibrium quantities.

For Peak Releases, multiply Krypton and Iodine values in Stream 07 by 2.2, and remaining values in Streams 07 and 00 by 1.2.

ACTIVITY BASIS: SPECIFIC POWER - 40 kw/kg
 COOLING TIME - 180 days
 FUEL ACTIVITY - 32,000 MWd/MTU
 PRODUCTION RATE - 1,500 MTU/Yr.

RELEASE BASIS: 1000 Kr-85 & H-3 Released
 Iodine Decontamination Factor = 1,000
 DOG/VOG Decontamination Factor = 10 and Filter Efficiency = 99.99
 HAW/Vaporizer Decontamination Factor = 10¹²
 GPP/Vaporizer Decontamination Factor = 10⁶
 Pu Product Recovery = 99%
 Pu Loss to Waste = 1%

Average source during reprocessing is assumed to be 1000 times peak. Values are based on instantaneous rate averaged over a calendar year.

NOTE: 1E-10 = 1 x 10⁻¹⁰

and for the fuel storage pools. In addition, water must be provided as backup for the plant fire water system, emergency cooling for the HLLW storage facilities, for the emergency utility area, and for the 76°F cooling loop.

In the generic plant, it is assumed that water will be available from deep wells on the site. (At BNFP, water is obtained from three deep wells. Normal cooling is by circulation through the cooling tower but the wells can supply straight-through cooling emptying into a pond which serves as an emergency reservoir. The BNFP pond is a 15-acre pond having a capacity of 60 million gallons of water.)⁷ Recirculation, for several months, with such a pond is possible by means of an emergency diesel-powered pump. Redundant pumps are connected to separate emergency busses with automatic start features as a back-up safety measure.

c. On-Site Electrical Power

The loss of on-site electrical power, if sustained, could lead to an unsafe plant condition. To minimize this possibility, consideration is given to a high reliability source of off-site power. Should off-site power fail, standby diesel powered generators will come on and assume priority loads. These and day-tank fuel supplies are located in structures designed to meet earthquake and tornado criteria^{5,6,7}. An uninterruptable source of ac power is used to supply power to the process control equipment and to provide control for starting the diesel generators. A 24V dc battery supply provides a highly reliable supply of power for monitors and some control functions.

d. Compressed Air Supply

Oil free compressed air is required for process control, instrumentation and starting the emergency diesel powered generators. It is used for air lifts, air pulsers for the extraction column operations, for air circulation as in the high-level liquid waste storage tanks, and for air purging of radiolytic hydrogen concentrations, generated during plant operation, to prevent formation of potentially explosive concentrations.

The generic plant is provided with two air compressors to provide a doubly redundant supply of air. These compressors are provided with pressure relief valves as a precaution in the event of failure of the pressure cut-off switch. Accumulator tanks located at critical locations about the plant are equipped with reverse flow check valves in their feed lines so compressor failure or pipe failure will not necessarily result in immediate pressure failure. As an example, the emergency diesels have accumulator tanks capable of 5 starts without resupply.

e. Steam Supply

Steam is used for process transfer jets, process heating, space heating, steam turbines, decontamination, deaerator heating and stripping, and yard steam tracing.

In general, it is not a critical service except for two aspects: the high-level liquid waste transfer and the control of steam pressure (100 psig) and hence the temperature (270°F). To inhibit the possibility of a "red-oil" explosion which requires approaching a threshold temperature as one of

the conditions, the steam pressure is limited to 40 psig in the solvent extraction operations and subsequent processing of the effluent streams containing organic solvents. Redundant pressure regulators are used to maintain the maximum allowable process temperatures during the various unit operations.

The generic plant, having a large quantity of high-level liquid waste, has an emergency steam generator for emergency liquid waste transfer which is designed to earthquake acceleration criteria and is housed in an enclosure built to tornado criteria.

III. FAULT TREE CONSTRUCTION OF ACCIDENT SEQUENCES

1. Background

Quantitative safety analysis has been developing rapidly due to the requirements of the space program and to the growth in size and numbers of nuclear power reactors. The techniques which have developed in these disciplines are used in this study for the analysis of hypothetical nuclear fuel reprocessing accidents and therefore a brief review of the development of reactor safety analysis will be presented.

The accident potential in nuclear power reactors has been recognized for some time. Safety analysis of nuclear power reactors has been approached by designing them for protection against the maximum credible accident (MCA). Later, in a desire for more realism, the design basis accident(s) (DBA) was defined and mitigated against. Currently there is a desire to present accidents on a numerical risk basis so that comparisons can be made with risks already accepted by society. Early work in probabilistic reactor accident assessment was done by Mulvihill¹², Garrick et al¹³, Farmer¹⁴ and Otway and Erdmann¹⁵. All of these authors except Farmer used fault tree analysis for the calculation of accident probabilities. This work is actively continuing under AEC sponsorship. To date, the most complete descriptions of reactor risk are provided by Otway and Erdmann¹⁵ and Starr¹⁶ who place these risks in perspective by comparisons with other social risks. The present work provides a similar safety analysis for a generic nuclear fuel reprocessing plant.

The central problem of probabilistic safety analysis is the representation of a complex system such as a fuel reprocessing plant in a form suitable for safety analysis. A plant is represented by construction, plumbing, electrical drawings, process flow charts, etc.; these must be synthesized into a unified description of the plant accident spectrum which is suitable for probabilistic analysis. This synthesis can be done through the use of fault trees.

Engineering for safety is not a new concept. Common examples are pressure relief valves on a boiler, or the safety on a loaded firearm. In both of these examples two simultaneous events must occur for an accident to result. Early safety engineering was usually done after the fact of an accident to prevent its recurrence. And in fact, the beginning of probabilistic safety was concerned with analyzing after-the-fact missile misfirings. Nuclear safety engineering has introduced a new aspect; namely, the calculation of the occurrence probability of accidents that in many cases have never occurred, or have never occurred with the safety system being analyzed.

Normally, reasoning proceeds from cause to effect; this process, when applied to safety, is called failure mode and effects analysis. This method proceeds by a series of "what if" statements to the final undesired event but generates many final results that are not of particular interest.

Fault tree analysis begins with a final result that is significant and proceeds back through the system identifying causes. In a certain sense, time is going backwards


in the logic of developing the tree. In this manner, many extraneous paths that would be generated by a failure-mode and effects analysis are eliminated and only those paths that lead to the top event are generated.

The logical structure dictated by the form of the fault tree prescribes the manner in which the probabilities must be combined to yield both the probability of the top node (final hazard event), and the probability of individual event sequences.

The overall accuracy of event sequence prediction, therefore, depends directly upon both the availability and quality of the basic probability data .

2. Fault Tree Symbolic Language

Fault tree analysis is basically a two-state Boolean logic and as such uses the operation of logical addition often referred to as logical "or" ("union").




$$A + B = C$$

Truth Table

| A | B | C |
|---|---|---|
| 1 | 0 | 1 |
| 0 | 1 | 1 |
| 0 | 0 | 0 |
| 1 | 1 | 1 |

Thus if A or B have a true input, the output is true. In the case of fault trees, true corresponds to failure. If either of the inputs A or B are in the failed state the gate output is in the failed state.

Another logical operation is logical multiplication and is referred to as logical "and" ("intersection").



$$A \cdot B = C$$

Truth Table

| A | B | C |
|---|---|---|
| 1 | 0 | 0 |
| 0 | 1 | 0 |
| 0 | 0 | 0 |
| 1 | 1 | 1 |

Thus if A and B are true, the output is true and two safety systems must simultaneously fail to get system failure. In the earlier example of a loaded firearm, the pulling of the trigger, and the safety being off must both occur for the weapon to fire.

Other logical operations have been defined and are used by safety analysts. In this report, care has been used to avoid other operations because: they usually can be represented by combinations of "and" and "or" gates, for reasons of clarity and because these operations are the only ones that can be directly treated in existing fault tree computer programs.


The accident events are represented by a square which describes the event logically represented by a gate.



A circle is used to represent an event for which probability-of-occurrence data is available. Hence it represents a terminal event requiring no further development.



A diamond is used to represent an event which is not further developed because it is not believed to be of significance or adequate information is unavailable.



The triangle is used as a linking symbol.



LINK IN



LINK OUT

A triangle, always to the right of an event rectangle, represents a linking out and indicates that the whole tree should be transferred over to the linking-in connection which is always at bottom center of the link-in point. The linking operation is used to avoid repetitious drawing and space limitations. In this report, the link-in rectangle may give information by further specifying the tree being linked-into. In this way a general repeated tree is particularized for a specific application. This procedure is similar to a subroutine calling sequence which transfers parameters to the subroutine calculation.

3. Fault Tree Construction for a Nuclear Fuel Reprocessing Plant

A chemical plant is a very complex entity in both its architecture and processing operations. Correspondingly a fault tree modeling the safety analysis of the plant is also highly complex. To systematize and maintain control over the completion of the safety modeling a procedure for fault tree construction known as Leak Path Analysis was used.¹⁷ Briefly,

the method enumerates the intersection of barrier failures encountered in tracing all paths from radioactive sources to the environment. The union of these Leak Paths forms the top event - the uncontrolled release of radiation (URR) to the environment. This very large equation is both unwieldy and contains redundancies but when factored into most compact form (terms appearing only once) or as close thereto as can be achieved, it is suitable for conversion to a fault tree of the plant. This is performed by the replacement of intersection operations by the fault tree symbol AND and similarly union by OR.


The top of a fault tree constructed in this manner is shown in figure III-1. The modes of release are air and liquid pathways. Solid pathways were not considered.

The release by liquid pathways was developed in a series of fault trees for qualitative evaluation of critical paths but based on historical data from high level liquid waste storage¹⁸ was not further analysed and the event is now "diamond-off" on the fault tree.

Similarly, an investigation of risks under neptunium processing failed to identify consequences as severe as those which could occur during normal processing. Since neptunium processing is performed about once a year, the probability is correspondingly reduced and the risks are not further considered.

An investigation of URR during shutdown did not reveal risks comparable to normal operation and was therefore excluded from detailed analysis.

Figure III-1
Generic Reprocessing Plant: Top of Tree



Release by air pathways under normal plant operation is divided into normal and reverse air flow because reverse air flow allows particulate from cells such as the PPC to impact the environment without any high efficiency filtering. In the investigation it was found that reverse air flow cannot occur by equipment failure alone. There is one exception, however, the air pulser can in principle result in a higher pressure in the process cells than outside the building. Considering the reverse flow ventilation damper, the redundant protection for maintaining normal air flow, the interlock on the pulser and the volume of building and site of air flow, this mechanism was determined to be ineffective and was not pursued. Fault trees were constructed for the reverse air flow diamonded events shown in Figure III-1 but are not included because they were not numerically evaluated and void in the risk assessment.

A tornado is a natural event that can result in reverse air flow from its depressurization and this is included in the tornado analysis. Because of the uncertainty of failure modes under tornado conditions, little value is derived from the reverse flow fault trees.

The fault tree development continues with the linking tree NFR (figure III-2). The failure probability of 10^{-2} /yr or 10^{-3} /yr for single and double HEPA filters respectively are from references 19 and 20. This is the probability of the filter having a particulate transmission greater than design specification. Clogging of the filters was not considered to be a failure mode for present purposes.

The event URR in RPC is developed in figure III-3. The releases from this are further divided into those due to




Figure III-2

Generic Reprocessing Plant: Ventilation System Fault Tree

LIST OF EQUIPMENT

10-C-101 01 DISSOLVER
10-C-102 02 DISSOLVER
10-C-103 03 DISSOLVER

01-D-000 HCU KIAS POT

10-D-400 01 DISSOLVER HEATED/COOLED
10-D-401 02 DISSOLVER HEATED/COOLED
10-D-402 03 DISSOLVER HEATED/COOLED
04-D-001 HCU CONCENTRATED DISSOLVER
01-D-000 HCU CONCENTRATED

10-D-104 01 DISSOLVER DRYED POT
10-D-105 02 DISSOLVER DRYED POT
10-D-106 03 DISSOLVER DRYED POT

03-D-001A/D MAINTENANCE CHILING PUMP
03-D-001B/D MAINTENANCE CHILING PUMP
03-D-001 CHILING PUMP

03-Y-001 FUEL TRANSFER COMPACTED
03-Y-002 FUEL TRANSFER COMPACTED COMP
10-Y-101 TRANSFERRED FUEL PUMPED
10-Y-102 MAINTENANCE CHANG DO-TOM
10-Y-103 CASSET MANIPULING CRANE
10-Y-104 POWER MANIPULATOR
10-Y-100A/D DISSOLVER CASSET STORAGE CASE

10-Y-107 FUEL TRANSFER TADLE
00-Y-001 DISSOLVER CASSET DUMPER
00-Y-002 HULL MONITOR
00-Y-003 DUMP JET CASE
00-Y-004 DUMP JET CASE
03-Y-005 PASS THROUGH PORT

07-V-000 SHIELDING WINDOW
07-V-001 SHIELDING WINDOW
07-V-002 SHIELDING WINDOW
07-V-003 SHIELDING WINDOW

07-V-010A/D PERIODICALLY SLIDE O PLUG
07-V-010B/D DITTO
07-V-010C/D DITTO
07-V-010D/H DITTO

07-V-021 SHIELDING WINDOW

14-Y-101 SHEAR

14-Y-104 SHEAR SUPPORT FRAME
14-Y-105 SHEAR FEED MAGAZINE
14-Y-106 SHEAR MAG. TRANSITION DECT.
14-Y-107 SHEAR FEED CHAIN O MAGAZINE
14-Y-108 SHEAR FEED DAB DRIVE UNIT

10-Y-102 DIVERTOR
10-Y-103 DIVERTOR DRIVE UNIT




Figure III-3

Generic Reprocessing Plant:

Fault Tree For URR in the Remote Process Cell

solvent fire, aqueous solutions and zirconium hull fires. The aqueous solution spill is developed to material failure from chemical, physical and natural phenomena. Statement of the use of water (aqueous) seals for confining the gaseous products within the plumbing boundary is expressed explicitly even though the probability of occurrence is one for about 1 psig overpressure.

In the design of the fault trees for the reprocessing plant, it was decided to present the generic tree for the occurrences in that cell. This is further supplemented by the list of equipment present in the cell. In order to evaluate the accident probability in that cell, repeated applications of the tree to encompass all the equipment given in the list must be performed. This reduces the repetitive complexity of the trees and helps to maintain a better perspective over the details.

The data base used in evaluating figure III-3 and the other trees included in this report comes from many sources. It should first be stated that there are no evaluated data bases for nuclear fuel reprocessing plants, therefore failure rate data from similar equipment in similar environments must be used.

Probably the best source of component data would be from chemical plants using solutions of similar acidity. Accidents are reported to the Manufacturing Chemists Association²¹ but there is no reporting of component failure and there are no compilations of this data.

Some component failures and all accidents are reported to the USAEC but there is no systematic compilation of this data. The body of this data is for nuclear reactors, an example of which is a recent analysis of pipe rupture occurrences. Using data reported in 1972, it is found that the log mean pipe failure rate for PWR and BWRs is

$$1.6 \times 10^{-5}/\text{yr-ft.}$$

Similar data is available in the General Electric Pipe Rupture Study series.²² The report GEAP-10207-25 contains pipe break data for both nuclear and fossil power plants.

Anyakora et al²³ have published instrument failure rate data on chemical plants in Great Britain in three environmental categories. Their work is summarized in a compilation by Powers and Tompkins.²⁴ Additional British data is contained in the useful text by Bourne and Green²⁵ and the article by Bourne.²⁶

Data on U.S. instruments can be found in MIL-HDBK-217A²⁷ and in the recent IEEE survey of industrial plants.²⁸ Data on the reliability of fire prevention systems may be found in the paper by Miller.²⁹

General collections embracing electrical, instrumentation and plumbing failure rates are found in the publications by Garrick et al³⁰ and Atomics International memo.³¹ A very useful recent nuclear plant reliability evaluation is that due to Erdmann et al.³²

The probabilities for natural phenomena are quite uncertain and subject to the siting of the generic plant. A probability of $10^{-7}/\text{yr}$ is estimated for exceeding the design

basis earthquake by a factor of 2 in acceleration. This is based upon an unpublished study prepared in connection with an environmental impact analysis for a plant in Richland, Washington. The probability of 10^{-5} /yr for a design basis tornado is from an unpublished study of a plant in Oklahoma.

Using these data, the fault tree of III-3 can be evaluated. The linking tree steam explosion needed for the bottom left hand event is presented in figure III-4. This steam explosion is presented as the intersection of pressure buildup, the failure of pressure relief devices and operator failure. In some portions of the plant where aqueous seals are used, a damaging explosion is not possible. The seal will blow and some of the entrapped radioactivity will constitute a small release within that cell.

Figure III-5, a red oil explosion shows the elements that must be present to result in such a reaction: the presence of heavy ions, excess acidity, organic solvent, excessive temperature and the failure of the operator to correct the upset condition. These events are developed into subsidiary trees as required.

Figure III-6 shows the fault tree for a criticality accident. This is developed in a general way and some care must be exercised in applying it to assure that all the failure modes are indeed possible. The valve failures shown were originally intended to be developed into subsidiary trees to include possible common mode problems. Because these were not found, chemical plant failure rate values were used. The failure rate for instrument power used in figure




Figure III-4

Generic Reprocessing Plant: Fault Tree for Steam Explosion Accident.





Figure III-5
Generic Reprocessing Plant:
Fault Tree for Red Oil Explosion

Figure III-6.

Generic Reprocessing Plant:
Fault Tree for Criticality Accident
in Process Cell



III-6 was taken from the Final Safety Analysis Report for the uninterruptable instrument power system in the Monticello power plant.³³ This also agrees with other data on d.c. system power.

This completes the failure probability analysis that began with figure III-3. The analysis continues by reference to figure III-2 and picking up another process cell. The complete collection of fault trees used in this report are presented in Appendix B.

IV. ACCIDENT ANALYSIS

1. General

A fuel reprocessing plant represents a substantial potential release source for radioactivity because of the presence of fissile material and fission products, the use of organic solvents and the handling of quantities of radioactivity in aqueous solutions. Because of the redundant safety systems designed into the plant and the inherent nature of the process, however, it is believed that most of the potential accidents have a low probability of occurrence.

Anticipated operational accidents are considered to be situations in which only one independent failure, human or equipment, is involved. Environmental radioactive releases from such events would be expected to be less than those allowable by 10 CFR 20 although the technical specifications on releases may be exceeded. An upper limit accident is considered to be a situation resulting from multiple operator errors, from multiple equipment malfunctions or from stresses imposed by natural phenomena which may have noticeable potential environmental consequences.

2. History of Accidents in Reprocessing

Most of the accidents that have occurred during irradiated fuel reprocessing operations took place at AEC installations when the industry was in its infancy. These experiences, in general, might not correspond with anticipated commercial plant experience. The Nuclear Fuel Services plant at West Valley, New York is the only commercial light water irradiated

fuel reprocessing plant which has operated in this country. It had 6 years of operation before it suspended operation for modification to allow higher throughput⁵. Reprocessing experience that has been applied and operated on a production basis in the U.S. employing essentially the same process technologies, however, is greater than 100 plant-years¹⁰.

A literature survey was made to accumulate a data base of accidents which were categorized into types of accidents for the nuclear energy and related chemical processing industries. The survey showed that they do happen in spite of safety precautions that have been taken. The data base provided guidance in the evaluation of the safety features assumed for the generic reprocessing plant too. Specific descriptions of the accident circumstances from the survey are presented in Appendix C.

The types of accidents which have occurred or are probable during reprocessing operations, according to the literature, are categorized as follows:

- a) Criticality accidents
- b) Fires
- c) Explosions
- d) Fuel receiving and storage accidents
- e) Waste storage accidents
- f) Natural phenomena events.

These are discussed in the following section.

3. Postulated Accidents; Bases for Selection
in the Hazards Analysis

Accident situations selected for analysis were hypothesized from a review of reprocessing experiences, the design of the generic reprocessing plant and the unit operations involved in the process. The accidents selected are believed to have the most severe consequences in terms of potential exposure to the environment. These events, of low probability, are credible only if one assumes simultaneous failure of engineered safety features and where pertinent, compromise of administrative procedures established as safety barriers. The types of incidents considered are those most likely to result in the dispersion of radioactivity beyond the primary confinement. These include:

- Nuclear criticality - a solution criticality in a process vessel in the Remote Process Cell
- Fires involving solvent and process equipment; a fire in leached zirconium alloy cladding was also considered. The consequences of such an incident, however, were found to have a negligible potential environmental impact
- Explosions involving different types of radioactivity sources
- Fuel receiving and storage maloperation
- Loss of cooling to the high level waste facility
- Earthquake and tornado consequences on the model reprocessing plant's structures and systems containing the normal inventory of design basis fuel were also reviewed and evaluated.

The potential accidents are discussed in the following in terms of malfunctions or errors required for the accident to occur, the probabilities of their occurring, the protective measures available and the off-site consequences that could result from such accidental releases.

a. Criticality Accidents

In the 30 years of the nuclear age, representing 432 plant-years, there have been 30 criticality accidents in the U.S.^{34,35}. Most of these occurred in experimental facilities; some of the early accidents are attributable to the limited understanding of nuclear energy at the time. There have been no criticality accidents since 1968. Seven of the accidents which occurred were in solution systems which could exist in a fuel reprocessing plant. The balance of the incidents involved conditions that would not be encountered in a reprocessing facility. A summary of the relevant accidents is presented in Table IV-1, page 61. The tabulated incidents occurred during reprocessing operations but not at a production facility. However, they provide anticipated general characteristics for criticality accidents which could occur in a processing plant's solution systems. These are summarized as follows:

1. The number of fissions in such an event would be less than 10^{20}
2. The accident would have to be sustained over many minutes to produce a fission yield approaching 10^{20} fissions

TABLE IV-1

Solution Criticality Accidents^{34,35}

| DATE | LOCATION | ACTIVE MATERIAL | GEOMETRY | TOTAL FISSIONS | CAUSE | PHYSICAL DAMAGE |
|-------------------|---|--|--|------------------------|---|-----------------|
| June 16, 1953 | Y-12 Processing Plant, Oak Ridge, Tenn. | 2.5 kg ²³⁵ U UO ₂ (NO ₃) ₂ in 56 liters H ₂ O | Cylinder concrete reflected below | 1.3 x 10 ¹⁸ | Wash water added to UO ₂ (NO ₃) ₂ solution | None |
| December 30, 1958 | LASL, New Mexico Pu Processing Plant | 3.27 kg Pu PuO ₂ (NO ₃) ₂ in ~ 168 liters H ₂ O | Cylinder water reflected below | 1.5 x 10 ¹⁷ | Agitator created critical geom- etry | None |
| October 16, 1959 | Chemical Proces- sing Plant Idaho Reactor | 34.5 kg ²³⁵ U ~800 liters H ₂ O-UO ₂ (NO ₃) ₂ | Cylinder concrete reflected below | ~4 x 10 ¹⁹ | Solution siphoned from safe to unsafe geometry | None |
| January 25, 1961 | Chemical Proces- sing Plant Idaho Reactor Testing Area | 8 kg ²³⁵ U UO ₂ (NO ₃) ₂ in 40 liters H ₂ O | Cylinder | 6 x 10 ¹⁷ | Solution pumped from safe to unsafe geometry | None |
| April 7, 1962 | Hanford Works, Richland, Wash. | 1.55 kg Pu | Cylinder unreflected | 8 x 10 ¹⁷ | Concentrated solution incorrectly siphoned | None |
| July 24, 1964 | The Wood River Junction, R.I. scrap recovery facility | 2.64 kg ²³⁵ U in UO ₂ (NO ₃) ₂ | Cylinder unreflected | 1.3 x 10 ¹⁷ | Concentrated solution poured into unsafe geometry. Addi- tional moderation in tank | None |
| Jan. 30, 1968 | Y-12 Processing Plant - Oak Ridge, Tenn. | 3.3 Kg U-233 UO ₂ (NO ₃) ₂ in 20 ltr. water | Sphere water reflected | 1.1 x 10 ¹⁶ | Solution surged from safe to unsafe geometry | None |

3. The rate of energy release would be too low to be explosive, i.e., no shock front generation would be anticipated
4. The event would be associated with a change from normal procedures
5. The environmental impact would be very small; total property loss would be less than \$70,000 as indicated from the incidents which occurred.

Criticality incidents have typically resulted in initial bursts of less than 10^{18} fissions followed in some instances by subsequent bursts of less than 3×10^{16} fissions per second. Little or no damage resulted to the confinement equipment from the criticality events.

In this analysis, a criticality is assumed to occur in the Remote Process Cell. The assumptions concerning the radioactive release are discussed in section V on consequences. Accidental criticality in fuel receiving and storage operations is unlikely because the areas where these operations are performed are designed to be subcritical with unirradiated fuel of 5% enrichment. Light water reactor fuel is normally enriched to less than 4%. After a burnup of 30,000 MWD/tonne the enrichment is reduced to less than 3%. Fission products generated in the irradiation also contribute neutron poisons in the elements thereby further reducing their fuel worth.

Criticality in the Remote Process Cell could accidentally occur by overfilling a dissolver through a failure to

switch the diverter chute. Depending on geometry, this would have to occur in conjunction with a reduction in neutron poison and failure of monitoring instruments.

In the multi-batch dissolution process if the filter (40 mesh) fails or is eliminated it is possible to transfer plutonium fines to the dissolver transfer tank and to the accountability tank. Accidental transfer of fines to the HAF feed tank is minimized or eliminated by centrifugal clarification of the feed after it leaves the accountability tank.

Some possibility of criticality exists in the centrifuge. This is made unlikely by an interlock on excessive current to prevent further operation if it is loaded with more than 1.5 kg of insoluble fines.

Following centrifugal contacting and concentration of uranium and plutonium, criticality is inhibited by controlling the concentrations of fissile material in the solutions. Criticality could result from the formation of an excessive fissile material concentration due to out-of-specification process control coincident with the failure of the concentration monitors. As an example, the dilute aqueous plutonium stream (1BP) is continuously monitored for plutonium concentration. The density is also checked by the analysis of grab samples. In addition to these monitors, neutron monitors are mounted on the HS column (scrubber) and the 1B electropulse column (product separation) to warn of excessive plutonium concentration.

A criticality accident could occur in this part of the process from a failure of process control that results in

higher-than-normal fissile material concentrations in solution concurrently with multiple monitoring failures or it could result from administrative error by processing higher enrichment fuel under specifications normally used for lower uranium enrichment.

Criticality in product loadout is also possible. It would be of higher consequence in the plutonium loadout area than in the uranium loadout area. Criticality is avoided by density control, neutron monitoring, use of equipment having favorable geometry, and fixed neutron poisons. The formation of plutonium polymers is controlled by keeping the solution greater than 1 M acid. The plutonium product is stored in product tanks of favorable geometry designed to earthquake and tornado criteria both as to integrity and position.

Criticality in product loadout could result from failure of concentration control coincident with monitor failure. It could result from plutonium polymer formation coincident with monitor and acid control failure. It could result from flooding of the plutonium product cell or greater than design basis earthquake or tornado.

b. Fires

Three postulated incidents involving dispersal of radioactive material through the agency of fire have been analyzed. One involves a contaminated solvent, assumed to contain a substantial loading of iodine along with plutonium and fission products. Another involves a solvent fire in the plutonium extraction cycle. The third fire evaluated is

assumed to occur with the ion-exchange resin during product purification.

A fire involving leached hulls (chopped cladding containing residual fuel material) was initially considered too. Experience in six years of shearing and handling the leached zirconium hulls indicated a very low probability of a major fire in this material⁵. More than 95% of the radioactivity associated with the leached hulls is induced radioactivity and is an integral part of the metal itself. In order for this radioactivity to escape, the metal itself must burn, potentially producing volatile particulates. The remainder of the radioactivity associated with the hulls is fission product and transuranic species in the form of refractory oxides. All of this radioactivity which remains with the hulls failed to be removed from the hulls during several hours of vigorous boiling in nitric acid and subsequent washing. In order for a hull fire to occur, there would have to be source of ignition of sufficient energy to initiate an active fire in the zirconium hulls which would either go undiscovered, or not respond to firefighting efforts using dry chemical extinguishing agents. There have been instances under which leached zirconium hulls have glowed but at no time has this ever affected more than a small fraction of the hulls nor has it ever resulted in anything more active than a transient glowing of the few hulls involved. The probability of such an event going unnoticed is small also, as there is an operator present at the viewing window of the hull inspection and canning station whenever they are being handled. In comparison to the hypothetical solvent fire, a zirconium fire results in lower potential off-site releases and the heat release in

such an incident is estimated to be approximately 5% that for the postulated solvent fire³⁶.

1. Solvent Fires

Codecontamination is the operation which removes most of the fission products and other undesirable impurities from solutions of uranium and plutonium without separating the uranium and plutonium components. Partitioning is the operation in which the uranium is separated from the plutonium (neptunium). Solvent extraction cycles, employing 30 volume percent tributyl phosphate (TBP) in a normal paraffinic hydrocarbon (dodecane) as the water immiscible solvent, is used for these operations in conjunction with various chemical adjustments. Because of the moderate flash point of the organic solvent, 70°C, there is a potential for the occurrence of solvent fires during these processing steps due to upsets or system leaks. Operating temperatures are held below the 70°C flash point by temperature controls and flow rates are monitored to avoid spills and to maintain the desired compositions in all feed and discharge streams of the equipment used in these processing steps. This applies to the use of anion exchange resin columns or electrochemical reductions for the partitioning steps.

A solvent fire could result from a failure of temperature control which would allow the flash point to be reached. Loss of temperature control could be caused by failure of the temperature sensor, temperature control servo or mixing valve failure. Leaks or spills due to process control upsets or pipe rupture under earthquake conditions could result in a solvent fire if failure of sump level sensors to

solvent accumulations on the cell floors occurred.

2. Ion Exchange Resin Fires

Ion exchange resin columns are used to partition plutonium, uranium and/or neptunium into separate streams while providing for additional fission product decontamination following the initial codecontamination step. Potential auto-thermal resin-nitrate reaction in these ion exchange columns can be prevented in this processing step by limiting the temperature to less than 135°C and by avoiding contact of the material with oxidizing agents.

A resin fire could result from failure of process control to limit the acidity as monitored by specific gravity measurement of the feed streams. Monitoring is done continuously and alarmed on high density indication. Failure of such alarms and monitors to indicate a potentially hazardous condition could lead to a resin fire.

Failure of temperature control to maintain the resin temperature to less than 135°C could also result in a resin-nitrate reaction. Temperature regulation is performed by sensors with servo controls. Thus, anything that can upset this control, such as failure of the sensor or the servo-mechanism, could lead to excessive heating and an incident.

Low pressure steam is commonly used for heating purposes in reprocessing plants. Under upset conditions such that the process came into temperature equilibrium with the steam, a temperature of 135°C could be attained which could lead to the onset of a resin-nitrate reaction.

If the resin beds were highly loaded with plutonium, radioactive heating could augment the temperature of the bed. This could occur in the plutonium purification and recovery operation carried out in the plutonium product cell. Failure to remove the product from loaded resins in the event of a plant shutdown would also be conducive to initiating such an incident.

Mitigating safeguards, i.e., the use of heavy bar grids to inhibit the expulsion of resin from the columns and pressure relief instrumentation, are incorporated in the equipment design to minimize the consequences of such an event.

Advancing reprocessing technology may preclude the need for utilizing ion exchange resins in separations operations. The occurrence of such an accident was therefore excluded from consideration in this analysis.

c. Explosions

Postulated incidents involving the dispersion of radioactivity by explosions in process equipment are analyzed. Explosions considered included the following:

- an explosion in the high aqueous feed tank (HAF)
- an explosion in the high aqueous waste concentrator (HAW concentrator)
- an explosion in the low aqueous waste concentrator (LAW concentrator)
- an explosion in the silver zeolite iodine adsorber
- an explosion in the waste calciner
- an explosion in the plutonium product calciner.

An explosion in the high aqueous feed tank could conceivably be caused by ignition of an explosive mixture of radioactively generated hydrogen in the air above the liquid.

An explosion in the HAW or LAW concentrator could conceivably be caused by ignition of an explosive mixture of radiolytically generated hydrogen in the air above the liquid in the evaporator or a "red-oil" explosion. An explosion in the silver zeolite iodine adsorber could result from the formation of silver azide due to the presence of excess ammoniacal material in the off-gases. A waste calciner explosion could also conceivably occur from the excessive presence of hydrogen and/or "red-oil" in the equipment used in this unit operation.

An explosion in the plutonium product calciner could conceivably result from ignition of an explosive mixture of hydrogen which may be used in the process of decomposing the intermediate plutonium oxalate product or from an accelerated decomposition of moist oxalate crystalline material.

These circumstances are normally precluded from developing by means of both design and operational safety features; multiple failures of these protective systems could conceivably lead to the incidents noted.

"Red-oil" is a material that can be formed from a heavy metal nitrate, e.g., uranium, and/or nitric acid solutions mixed with tributyl phosphate solvent at temperatures exceeding 135°C ^{37,38}. The exact nature of the reaction of tributyl phosphate (TBP) with hot concentrated solutions of heavy metal nitrates and nitric acid has not been determined. However, under optimum conditions, the reaction becomes explosive and oxides of nitrogen are evolved. Although Purex-process conditions do not approach those

giving rise to such a reaction, safeguards are provided in the concentration of uranium, plutonium and nitric acid solutions to prevent their accidental occurrence. One method of avoiding an explosion is to keep the evaporation temperature below 135°C, the minimum temperature at which the reaction occurs. Another method is to remove the TBP from the aqueous stream prior to evaporation by steam stripping the aqueous stream.

In order for a "red-oil" explosion to occur, several independent instrument control failures and administrative failures would have to precede the occurrence. The code-contamination column would have to be out of control dumping solvent with the high aqueous waste (HAW) stream for a number of hours without being noticed or corrected; the controller for the reduction of 150 psig steam (181°C) to less than 40 psig steam (131°C) would have to malfunction; the relief valve which restricts the low pressure steam would have to fail to operate; the pressure controller on the steam to the evaporator heating coils would have to malfunction, causing steam pressure to rise above 40 psig, and not be noticed for an extended period of time, and the evaporator bottoms product would have to be substantially overconcentrated while all the normal indicators of this condition either malfunction or are ignored. Given these conditions, an explosion involving complexes of a heavy metal, TBP and nitric acid is possible.

Radiolysis of aqueous solutions results in the production of hydrogen and oxygen. Thus, all process streams would be expected to evolve hydrogen. It is estimated that 3 ft³ of hydrogen (STP) per 10⁶ BTU of fission product heat in

acid waste and $10 \text{ ft}^3/10^6$ BTU in alkaline waste is formed by radiolysis¹¹. The combustion threshold of hydrogen in air occurs at 4% concentration. To avoid reaching this hydrogen concentration, dilution of the off-gases with continuously flowing air is used in the processing operations. The HAF storage tank, the HAW and LAW concentrators and the high and intermediate level liquid waste systems have the highest potential for such an explosion due to hydrogen gas accumulation as a result of failure of the air purge system. Such a failure would constitute a common mode failure to all the systems.

To reduce the likelihood of air flow failure, the plant is designed with redundant air flow features which have been discussed under special safety systems. These systems include redundant ventilation blowers with a spare blower in reserve, emergency electrical power, air reservoirs and spare air compressors.

A hydrogen explosion might occur as a result of failures in the process ventilation system such as two DOG/VOG blowers failing together or their power failing, filter blockages, ventilation control failure such that air flow balancing dampers are closed and failure of emergency compressed air which could result in a hydrogen explosion in the HLLW or ILLW storage tanks if the waste is not stored under self-boiling conditions.

The process off-gas system, composed of the Dissolver Off-Gas (DOG) and Vessel Off-Gas (VOG) systems removes iodine, particulate radioactive contaminants and nitrogen oxides which are volatilized during the fuel segment dissolution and subsequent processing steps. These off-gases are then combined with the ventilation air, filtered through two stages of HEPA off-gas filters and discharged through the stack.

Silver zeolite sorbents are incorporated in the subsystem scrubbing trains to further restrict volatile radioiodine releases to the environment. (39)

An explosion in the waste calciner facility can be postulated on essentially the same basis as the high level waste concentrator explosion for the calciner would be fed from the HAW concentrator. The calciner, however, operates at a much higher temperature than the concentrator ($>450^{\circ}\text{C}$). This would tend to increase the quantity of ruthenium that could be volatilized during an accident by about a factor of 10 over the amount that could be volatilized from a HAW concentrator explosion⁴⁰⁻⁴³. Aside from this variation and the fact that the equipment employed in this operation, having a small holdup which would limit the probability of such an incident, the results of a waste calciner explosion should be essentially the same as for the HAW concentrator explosion analysis.

An explosion in the plutonium product concentrator can be postulated on essentially the same basis as the high level waste concentrator explosion. The hydrogen generation rate from a plutonium product solution, however, is much lower than from a high level waste solution. Hoover and Ingalls⁴⁴ quote a hydrogen generation rate for plutonium as 0.05-0.06 ml/day/gram Pu-239 at the probable nitric acid concentration range anticipated in the evaporator concentrate. Increasing this generation rate by an order of magnitude, to reflect the higher specific activity of design basis plutonium, and assuming an equilibrium quantity of process solution of 10 liters at 200 grams per liter of plutonium, the rate of hydrogen generation in the evaporator would be about 50 ml per hour. At a volume free space in the evaporator of 38 liters, at least 30 hours would be required to reach the minimum lower explosive limit of hydrogen content, disregarding the flow of

instrument air to the probes. (This in itself would be sufficient to keep all hydrogen generated at a concentration below the lower explosive limit for the equipment has a small holdup capacity.)

Although the plutonium product concentration explosion is highly improbable, it has been evaluated as an upper limit accident for the inventory of the plutonium in the concentrator is large - 2,000 grams or 23,000 total curies at the time of the postulated explosion³⁶. Using the same assumptions as were employed to analyze the high activity waste evaporator explosion, the radioactivity release is calculated to be 1.5×10^{-2} curies.

A criticality and/or explosion accident during conversion of plutonium nitrate to oxide powder is also considered to be highly improbable. In this operation, plutonium nitrate in solution from anion exchange or evaporation is precipitated as the oxalate. This product is filtered and washed. The wet oxalate crystals are dried at 400°C for a fixed period and then calcined at 750°C also for a fixed period, in a slow stream of air or hydrogen. To ensure criticality control, fissile concentration controls and favorable geometry with fixed poisons are employed in the operations. Batch sizes of solids processed are always maintained subcritical. The product powder is screened, sampled, weighed and sealed in metal containers for subsequent shipment or storage.

The governing radioactive material that could be released to the environment due to such an accident would be in a

particulate form. Decomposition of plutonium oxalate to oxide results in particles having an indicated Mass Median Diameter of 8-12 microns⁴⁵. Oxide particles were found to be 26 to 68% of the size of their precursor. These measurements were made under laboratory conditions; plant oxide produced under accident conditions will probably be coarser. Mishima et al, report fractional releases up to 1% of the source when heating either the oxalate or partially oxidized oxalate in an updraft of air⁴⁶. Their finely divided, free flowing powder was composed of spheres with a Mass Median Diameter of 32 microns. As much as 0.9% of the plutonium used in the source was made airborne during a 1-hour period at temperatures up to 1000°C and air velocities up to 100 cm/sec (~2.5mph).

For the postulated accident, it is assumed that in the startup of the calcining furnace, hydrogen is introduced before the air is displaced with nitrogen, violating the procedure and resulting in a hydrogen-air explosion. The oxalate batch size being calcined is assumed to contain the equivalent of 3 kg of Pu. Overpressurization of the furnace will not be enough to destroy the furnace. Consequently, the explosion would be directed toward the ends of the furnace. The powder is assumed to be entrained at a windspeed of 20 mph. At this condition, up to 15% of the solids would be expected to be airborne into the ventilation exhaust system. The airborne powder particles' size is so large that the filtering efficiency of the three stages of HEPA filters in series would be almost 100%. A filter release factor of 8×10^{-9} is assumed²⁰.

If the furnace does explode, at most the surrounding glove box might rupture and powder would be ejected into the room. This would create a temporary internal contamination problem in the building. However, the size of the particles would be too large to cause a sizeable external release of radioactivity. It is assumed a 1% release to the exhaust ventilation system could occur. The anticipated stack releases for the cases discussed are as follows for a Pu mixture having a specific activity of 14.1 Ci/g¹⁹.

1. Furnace intact, direct release to vent system:

$$(3000 \text{ g Pu}) (0.15) (8 \times 10^{-9}) = 3.6 \times 10^{-6} \text{ g Pu} \approx 5.1 \times 10^{-5} \text{ Ci}$$

2. Furnace explodes with release to room:

$$(3000 \text{ g Pu}) (0.01) (8 \times 10^{-9}) = 2.4 \times 10^{-7} \text{ g Pu} \approx 3.4 \times 10^{-6} \text{ Ci}$$

The off-site release from such incidents will have insignificant environmental impact even under the worst dispersion conditions for the HEPA filters will reduce these values by a factor of $>10^3$.

d. Fuel Receiving and Storage Area Accident

An accident in the fuel receiving and storage area resulting in the release of radioactivity that could have an environmental impact is a credible event. The consequences of an uncontrolled release in this plant area could be serious although the probability of such an occurrence would be small. Consideration of such an event was made in this analysis.

Based on regulatory standards and requirements for package design, quality assurance and handling and monitoring procedures, the probability of a cask being breached is low⁴⁷.

A hypothetical incident which may bound a variety of events as to the nature and the magnitude of a release in the fuel receiving and storage area is assumed for this evaluation and is described as follows:

In shipment, it is assumed that the spent fuel cask loses its heat removal capability. The spent fuel rods self-heat due to fission product decay heating to a temperature approaching 1225°C. This causes cladding failure and release of a large fraction of the more volatile fission products to the hermetically sealed, dry cask cavity. After receipt of the shipping cask at the reprocessing plant, it is transferred to the cask unloading pool in the fuel receiving and storage area where it is opened. On opening the cask, mobile radioactive species are expelled from the cask cavity as a stream of bubbles which rise to the pool surface. Some of the fission products released in the cask cavity will plate out on the cask's internal surface; some will remain in the pool water. The balance of the fission products - primarily volatile species - will be airborne within the building area and are assumed to pass through the vessel off-gas system. Of the fission products in the spent fuel cask inventory, it is assumed that

all of the noble gases, tritium, halogens, cesium, strontium and ruthenium in the breached elements are released to the unloading pool.^{48,49} For this evaluation, the airborne release of the noble gases and tritium is neglected since they are accepted as normal releases to the atmosphere. Ninety percent of the halogens (essentially iodine), ruthenium and cesium and all of the strontium expelled from the cask are conservatively assumed to remain in the pool water. The balance are airborne and pass through the vessel off-gas system.

Table IV-3 lists the anticipated release data for the radioactive species involved.

e. Leakage of Fission Products From High Level Waste Tanks

High level wastes will be stored on an interim basis in high integrity tanks as solutions, with the radiolytic heat removed by heat transfer to a cooling water system. As a safety device for the eventuality of failure of the cooling system water supply, provision is included for venting the storage tanks to the atmosphere via an off-gas system designed for a total decontamination factor, boiling waste to atmosphere, of at least 1×10^{10} .^{36,40,41} Because of the defenses in depth which would be operative - high integrity design of the cooling water supply system, tank-saucer-vault containment design, a failure and/or

TABLE IV-3 (50,51)
Anticipated Releases - Fuel Receiving
And Storage Area Incident

| <u>Group</u> | <u>Isotope:</u> | <u>Ci/Tonne</u> | <u>Source/4.5 tonne</u> <u>Shipment</u> | <u>Fraction</u> <u>Released</u> |
|--------------|-----------------|----------------------|--|------------------------------------|
| Ru: | Ru-103 | 1.2×10^5 | $5.4 (10^5)$ | 10% |
| | Ru-106 | 6.1×10^5 | $27.4 (10^5)$ | |
| I: | I-129 | 3.6×10^{-2} | $16.2 (10^{-2})$ | 10% |
| | I-131 | 1.6 | 7.2 | |
| OFP* | Cs-134 | 2.4×10^5 | $10.8 (10^5)$ | 10% |
| | Cs-137 | 1.2×10^5 | $5.4 (10^5)$ | |

* Other Fission Products

accident in this part of the facility which could have an environmental impact is not expected. Tank storage of high level wastes has been accomplished safely over the 25 years since they began to be generated, despite the fact that some leaks have occurred (see Appendix C). Extensive measurements at the leak locations show that the material released has remained in the vicinity of the tanks. It is anticipated that developing technology will incorporate additional capability to detect and contain any leakage that might occur.

f. Natural Phenomena Incidents

The reprocessing plant is designed, evaluated and constructed to criteria and guidelines accepted as adequate to provide reasonable assurance that the plant could be operated without undue risk to the health and safety of the public⁵³. These criteria include requirements that the structures, systems and components important to safety, be designed to withstand the effects of natural phenomena (earthquakes and tornadoes). The design bases that satisfy the natural phenomena criteria reflect:

- Appropriate consideration of the most severe of the natural phenomena that has historically been reported for the site and the surrounding area
- Appropriate combinations of the effects of normal and accident conditions with the effects of natural phenomena
- The importance of the safety functions performed.

Because (1) operating and accident stresses are lower, (2) process parameters cannot change as rapidly, and (3) consequences of any failure are generally less severe for fuel

reprocessing operations, no plant components have performance requirements that are critical to safety assurance in the same sense as power reactor safety system response or cooling continuity requirements. Protection against uncontrolled release of radioactive materials is assured by maintaining the mechanical and structural integrity of relatively passive confinement and off-gas treatment facilities and of certain monitoring and control system components. No violent expulsion of process materials would be anticipated in the event of a natural phenomenon incident as system components are not highly stressed during operation. Operating loads are accounted for in design and construction because system components and interconnections are generally of small size (over 90% of the process piping is less than 2 inches in diameter) and relatively thick-walled as a result of corrosion allowances provided. The availability of multiple confinement barriers further assures that radioactive materials escaping from the primary process systems or from effluent collection, treatment or disposal facilities are monitored and controlled so as not to result in uncontrolled releases to the environment⁵⁻⁷.

An earthquake may negate some or all of the confinement of individual systems but will have little, if any, direct dispersive mechanisms.

The potential off-site exposures from such an event would be much less than one percent of the accident exposure guideline³⁶.

The plant structure will also protect the radioactive inventory from the effect of a design basis tornado. The Class 1 Ventilation System which ventilates the cells and the

emergency cooling system for potentially self-boiling solutions will maintain the process in a safe shutdown condition. The inventories of the plant areas which have a potential for release during or subsequent to a design basis tornado would be negligible. Although the tornado has great potential for releasing radioactivity, it has great potential for dispersing the release thereby mitigating the consequences. The maximum potential off-site releases and exposures would be well within the guidelines³⁶.

V. Consequences of Accidents

For the purpose of demonstrating the degree of inherent safety of the generic reprocessing plant and its confinement systems, the credible consequences of operational upsets and of stresses which might be imposed by the design basis natural phenomena were selected in evaluating the postulated accidents. The accidents examined are those believed to have the most severe consequences in terms of potential exposure to the environment. These accidents are events of low probability which are credible only if one assumes simultaneous failure of engineered safety features and where pertinent, administrative procedures established as safety barriers are bypassed.

For each accident probability sequence, there is, at that point in the reprocessing operations, a corresponding consequence of radioactivity dispersal beyond the primary confinement. These source term release values have been calculated for generic reprocessing plant accidents using realistic values for many of the fault tree branches discussed in Section III and Appendix B.

The types of accidents considered were discussed in Section IV. The cases examined are listed in Table V-1. Some of these accidents could appear in more than one location on a fault tree or on several fault trees. The physical assumptions used in the analyses are generally based upon the design of the Barnwell Nuclear Fuel Plant.⁷

TABLE V-1
Postulated Reprocessing Plant Accidents Examined

HAW Concentrator Explosion
 Solvent Fire in the Plutonium Extraction Cycle
 Solvent Fire in the Co-Decontamination Cycle*
 Explosion in the LAW Concentrator
 Ion Exchange Resin Fire*
 Nuclear Criticality Incident
 Explosion in the HAF Tank
 Waste Calciner Explosion
 Fuel Receiving and Storage Accident

*Accident Examined Was In The Neptunium Recovery Cycle

Accident releases might be initiated in any of the number of process cells in the reprocessing plant. Airborne releases would obviously have to pass through the plant's ventilation system prior to escaping to the environment. In the realistic calculations the following measured filter efficiencies were used in developing the source terms:^{19,20}

| | |
|----------------------------|-------|
| First HEPA filter removes | 99.9% |
| Second HEPA filter removes | 99.0% |
| Third HEPA filter removes | 94.0% |
| Fourth HEPA filter removes | 83.0% |

The accidents listed in Table V-1 are considered in detail in the following:

1. HAW Concentrator Explosion

The assumptions and results for this accident as calculated in the Barnwell SAR⁷ are given in Table V-2.

TABLE V-2

SAR Source Calculation HAW Concentrator Explosion (Barnwell)

| Group* | Isotope | Ci/Tonne | X SF | X RF | X EF = Ci Released |
|--------|---------|----------------------|----------------------|----------------------|--------------------|
| Ru: | Ru-103 | 1.2×10^5 | 1.0 | 1.0×10^{-3} | 1.05 |
| | Ru-106 | 6.1×10^5 | | | |
| Zr-Nb: | Zr-95 | 3.5×10^5 | 1.0 | 4.6×10^{-7} | 1.05 |
| | Nb-95 | 6.5×10^5 | | | |
| I: | I-129 | 3.6×10^{-2} | 8.3×10^{-2} | 1.0 | 1.05 |
| | I-131 | 1.6 | | | |
| OFPT: | Sr-89 | 9.0×10^4 | 1.0 | 4.6×10^{-7} | 1.05 |
| | Sr-90 | 8.4×10^4 | | | |
| | Y-90 | 8.4×10^4 | | | |
| | Y-91 | 1.9×10^5 | | | |
| | Cs-134 | 2.4×10^5 | | | |
| | Cs-137 | 1.2×10^5 | | | |
| | Ce-141 | 7.9×10^4 | | | |
| | Ce-144 | 8.8×10^5 | | | |
| | Pm-147 | 1.4×10^5 | | | |
| | Am-241 | 250. | | | |
| | Am-242 | 4.0 | | | |
| | Cm-242 | 4.4×10^4 | | | |
| | Cm-243 | 34.0 | | | |
| | Cm-244 | 5.7×10^3 | | | |
| Pu: | Pu-238 | 4.3×10^3 | 0.01 | 4.6×10^{-7} | 1.05 |
| | Pu-239 | 3.2×10^2 | | | |
| | Pu-240 | 6.3×10^2 | | | |
| | Pu-241 | 1.7×10^5 | | | |
| | Pu-242 | 3.6 | | | |
| | | | | | |

Release Factor:

Non-volatile fraction dispersed:

Concentrator volume = 600 liters of solution.
 Cell volume = 2850 m^3 ; dispersion = 100 mg/m^3
 Total solution dispersed = 0.285 kg of concentrate
 Density of concentrate = 1.4 kg/l
 Fraction of concentrate dispersed = 3.3×10^{-4}
 Dispersion passing through filter = 0.14 mg/m^3
 Filter factor = 1.4×10^{-3}

| Element | Non-Volatile Fraction Dispersed | X Filter Factor | + Volatile Fraction | = RF |
|---------|---------------------------------|----------------------|---------------------|----------------------|
| Ru | 3.3×10^{-4} | 1.4×10^{-3} | 1×10^{-3} | 1.0×10^{-3} |
| Zr-Nb | 3.3×10^{-4} | 1.4×10^{-3} | 0 | 4.6×10^{-7} |
| I | 0 | | 1.0 | 1.0 |
| OFPT | 3.3×10^{-4} | 1.4×10^{-3} | 0 | 4.6×10^{-7} |
| Pu | 3.3×10^{-4} | 1.4×10^{-3} | 0 | 4.6×10^{-7} |

Equivalence Factor:

EF = 600 liters of concentrate/5679/MTU = 1.05 MTU

Since the HAW Concentrator is in the Remote Process Cell (RPC), there are 2 HEPA filters in series before stack release. To carry out a realistic calculation one needs the non-volatile release fraction which is $(2850 \text{ m}^3 \text{ cell volume}) / (100 \text{ mg/m}^3)$, the denominator being a representative density.³ This yields a release factor $\text{RF} = 3.33 \times 10^{-4}$ for non-volatiles. In addition 100% of the iodine and 0.1% of the ruthenium are volatilized. With these data the following releases are calculated.

TABLE V-3

Volatile Source From HAW Concentrator Explosion

| <u>Group</u> | <u>Ci/tonne</u> | <u>X</u> | <u>SF</u> | <u>X EF + Volatile Fraction</u> | <u>Volatile Sources</u> |
|--------------|-----------------|----------|-----------|---------------------------------|-------------------------|
| | | | | | <u>Ci</u> |
| RU-103 | 1.2E5 | 1 | 1.05 | 1.0E-3 | 1.26E2 |
| Ru-106 | 6.1E5 | 1 | 1.05 | 1.0E-3 | 6.41E2 |
| I-129 | 3.6E-2 | 8.3E-2 | 1.05 | 1.0 | 3.14E-3 |
| I-131 | 1.6E0 | 8.3E-2 | 1.05 | 1.0 | 1.39E-1 |

* Note: 1E5 = 1×10^5

Table V-4

Non-Volatile Source From HAW Concentrator Explosion

| Group | Isotope | Ci/Tonne | X | SF | X | EF | X | RF | No Filter Working | One Filter Working | Two Filters Working |
|-------|---------|----------|---|--------|---|------|---|--------|----------------------|-----------------------|------------------------|
| Ru: | | | | 1.0 | | 1.05 | | 3.3E-4 | | | |
| | Ru-103 | 1.2E5 | | | | | | | 4.16E1 | 4.16E-2 | 4.16E-4 |
| | Ru-106 | 6.1E5 | | | | | | | 2.12E2 | 2.12E-1 | 2.12E-3 |
| Zr-Nb | | | | 1.0 | | 1.05 | | 3.3E-4 | | | |
| | Zr-95 | 3.5E5 | | | | | | | 1.21E2 | 1.21E-1 | 1.21E-3 |
| | Nb-95 | 6.5E5 | | | | | | | 2.25E2 | 2.25E-1 | 2.25E-3 |
| I: | | | | 8.3E-2 | | 1.05 | | 0 | | | |
| | I-129 | 3.6E-2 | | | | | | | 0 | 0 | 0 |
| | I-131 | 1.6E0 | | | | | | | 0 | 0 | 0 |
| OFFT: | | | | 1.0 | | 1.05 | | 3.3E-4 | | | |
| | Sr-89 | 9.0E4 | | | | | | | 3.12E1 | 3.12E-2 | 3.12E-4 |
| | Sr-90 | 8.4E4 | | | | | | | 2.91E1 | 2.91E-2 | 2.91E-4 |
| | Y-90 | 8.4E4 | | | | | | | 2.91E1 | 2.91E-2 | 2.91E-4 |
| | Y-91 | 1.9E5 | | | | | | | 6.63E1 | 6.63E-2 | 6.63E-4 |
| | Cs-134 | 2.4E5 | | | | | | | 8.33E1 | 8.33E-2 | 8.33E-4 |
| | Cs-137 | 1.2E5 | | | | | | | 4.17E1 | 4.17E-2 | 4.17E-4 |
| | Ce-141 | 7.9E4 | | | | | | | 2.74E1 | 2.74E-2 | 2.74E-4 |
| | Ce-144 | 8.8E5 | | | | | | | 3.05E2 | 3.05E-1 | 3.05E-3 |
| | Pm-147 | 1.4E5 | | | | | | | 4.81E1 | 4.81E-2 | 4.81E-4 |
| | Am-241 | 250.0E0 | | | | | | | 8.67E-2 | 8.67E-5 | 8.67E-7 |
| | Pm-242 | 4.0E0 | | | | | | | 1.39E-3 | 1.39E-6 | 1.39E-8 |
| | Cm-242 | 4.4E4 | | | | | | | 1.52E1 | 1.52E-2 | 1.52E-4 |
| | Cm-243 | 34.0E0 | | | | | | | 1.18E-2 | 1.18E-5 | 1.18E-7 |
| | Cm-244 | 5.7E3 | | | | | | | 1.98E-0 | 1.98E-3 | 1.98E-5 |
| Pu: | | | | 0.01 | | 1.05 | | 3.3E-4 | | | |
| | Pu-238 | 4.3E3 | | | | | | | 1.49E0 | 1.49E-3 | 1.49E-5 |
| | Pu-239 | 3.2E2 | | | | | | | 1.11E-1 | 1.11E-4 | 1.11E-6 |
| | Pu-240 | 6.3E2 | | | | | | | 2.18E-1 | 2.18E-4 | 2.18E-6 |
| | Pu-241 | 1.7E5 | | | | | | | 5.9E1 | 5.9E-2 | 5.9E-4 |
| | Pu-242 | 3.6E0 | | | | | | | 1.25E-3 | 1.25E-6 | 1.25E-8 |

* Note: 1.2E5 = 1×10^5

2. Solvent Fire in Pu Extraction Cycle

The Barnwell SAR⁷ calculation is given below.

TABLE V-5

SOLVENT FIRE IN THE Pu SOLVENT EXTRACTION CYCLE

| <u>Group</u> | <u>Isotope:</u> * | <u>Ci/Tonne</u> | <u>X</u> | <u>SF</u> | <u>X</u> | <u>RF</u> | <u>X</u> | <u>EF = Ci Release</u> |
|--------------|-------------------|---------------------|----------|-----------|----------|--------------------|----------|------------------------|
| Pu: | Pu-238 | 4.3x10 ³ | | 1.0 | | 1x10 ⁻⁴ | | 0.034 0.015 |
| | Pu-239 | 3.2x10 ² | | 1.0 | | 1x10 ⁻⁴ | | 0.034 0.001 |
| | Pu-240 | 6.3x10 ² | | 1.0 | | 1x10 ⁻⁴ | | 0.034 0.002 |
| | Pu-241 | 1.7x10 ⁵ | | 1.0 | | 1x10 ⁻⁴ | | 0.034 0.58 |
| | Pu-242 | 3.6 | | 1.0 | | 1x10 ⁻⁴ | | 0.034 1.3x10 |
| | | | | | | | | |

* Other radioisotopes are considered to be negligible relative to plutonium.

Equivalence Factor:

- Organic consumed = 14 liters
- Processing rate = 0.208 MTU/hr
- 3AP normal flow = 85 l/hr = 409 l/MTU

$$EF = \frac{14 \text{ l}}{409 \text{ l/MTU}} = 0.034 \text{ MTU}$$

Release Factor:

$$\begin{aligned} \text{Pu dispersed} &= 1\% \\ \text{Filter release} &= 1\% \\ RF &= (.01)(.01) = 1 \times 10^{-4} \end{aligned}$$

This incident would occur in the Plutonium Product Cell (PPC). There are 3 HEPA filters in series before stack release. The calculation yielded the following data:

TABLE V-6

Solvent Fire in the Pu Extraction Cycle

| Group | Isotope:* | Ci/Tonne | X | SF | X | EF | Fraction Dispersed | Stack Release Curies | | | |
|-------|-----------|-------------------|---|-----|---|-------|--------------------|----------------------|--------------------|---------------------|-----------------------|
| | | | | | | | | No Filter Working | One Filter Working | Two Filters Working | Three Filters Working |
| Pu: | | | | | | | | | | | |
| | Pu-238 | 4.3×10^3 | | 1.0 | | 0.034 | .01 | 1.46E0* | 1.46E-3 | 1.46E-5 | 8.76E-7 |
| | Pu-239 | 3.2×10^2 | | 1.0 | | 0.034 | .01 | 1.09E-1 | 1.09E-4 | 1.09E-6 | 6.54E-8 |
| α | Pu-240 | 6.3×10^2 | | 1.0 | | 0.034 | .01 | 2.14E-1 | 2.14E-4 | 2.14E-6 | 1.28E-7 |
| | Pu-241 | 1.7×10^5 | | 1.0 | | 0.034 | .01 | 5.77E1 | 5.77E-2 | 5.77E-4 | 3.46E-5 |
| | Pu-242 | 3.6 | | 1.0 | | 0.034 | .01 | 1.22E-3 | 1.22E-6 | 1.22E-8 | 7.32E-10 |

* 1.46E0 = 1.46×10^0

(Neptunium Recovery Campaign)

The Barnwell⁷ Calculation is given in Table V-7.

TABLE V-7 - SAR Results

| Group ^o | Isotope ^o | Cl/Tonne | DF ^{oo} | SF | RP | EP | Cl Released |
|--------------------|----------------------|----------------------|------------------|-------|--------------------|-------|----------------------|
| Ru: | ¹⁰¹ Ru | 1.2×10^0 | 0.16 | 0.01 | 0.10 | 0.085 | 1.69 |
| | ¹⁰⁰ Ru | 6.1×10^0 | 0.73 | | | | 38 |
| Zr-Nb: | ⁹⁴ Zr | 3.9×10^0 | 0.14 | 0.01 | 1×10^{-6} | 0.085 | 4.1×10^{-6} |
| | ⁹⁰ Nb | 6.9×10^0 | 0.14 | | | | 7.7×10^{-6} |
| I: | ¹³⁰ I | 3.6×10^{-2} | 1.0 | 0.04 | 1.0 | 0.085 | 1.2×10^{-6} |
| | ¹³¹ I | 1.6 | 0.032 | | | | 1.8×10^{-6} |
| OFPT: | ⁹⁰ Sr | 9.0×10^0 | 0.20 | 0.001 | 1×10^{-6} | 0.085 | 1.9×10^{-6} |
| | ⁹⁰ Sr | 6.4×10^0 | 1.0 | | | | 7.2×10^{-6} |
| | ⁹⁰ Y | 6.4×10^0 | 1.0 | | | | 7.2×10^{-6} |
| | ⁹¹ Y | 1.9×10^0 | 0.23 | | | | 3.6×10^{-6} |
| | ¹⁰⁰ Co | 2.4×10^0 | 0.79 | | | | 1.7×10^{-6} |
| | ¹⁰⁰ Co | 1.2×10^0 | 0.96 | | | | 1.0×10^{-6} |
| | ¹⁰¹ Co | 7.9×10^0 | 0.13 | | | | 6.4×10^{-6} |
| | ¹⁰⁰ Co | 8.8×10^0 | 0.66 | | | | 9.0×10^{-6} |
| | ¹⁰⁷ Pm | 1.4×10^0 | 0.90 | | | | 1.1×10^{-6} |
| | ⁸⁸ Am | 290. | 1.0 | | | | 2.1×10^{-6} |
| | ⁸⁸ Am | 4.0 | 1.0 | | | | 3.4×10^{-6} |
| | ⁸⁸ Am | 4.4×10^0 | 0.43 | | | | 1.6×10^{-6} |
| | ⁸⁸ Am | 34.0 | 0.99 | | | | 2.9×10^{-6} |
| | ⁸⁸ Am | 5.7×10^0 | 1.0 | | | | 4.8×10^{-6} |
| | ⁸⁸ Am | | | | | | |
| Pu: | ²⁴⁰ Pu | 4.3×10^0 | 1.0 | 0.01 | 1×10^{-6} | 0.085 | 3.6×10^{-6} |
| | ²⁴⁰ Pu | 3.2×10^0 | 1.0 | | | | 2.7×10^{-6} |
| | ²⁴⁰ Pu | 6.3×10^0 | 1.0 | | | | 9.4×10^{-6} |
| | ²⁴⁰ Pu | 1.7×10^0 | 1.0 | | | | 1.9×10^{-6} |
| | ²⁴⁰ Pu | 3.6 | 1.0 | | | | 2.7×10^{-6} |

^oOFPT = Other fission products and transuranium elements.

^{oo}DF = Decay Factor; corrects for simultaneous accumulation and decay of stored waste for one year before Np recovery campaign.

Release Factor:

990 filter efficiency.

10 of contaminants in burned organic dispersed.

100 of Ru and 1000 of I volatilizes and passes out the stack.

| Element | Fraction Dispersed | Fraction Passing Filter | Volatile Fraction | RP |
|---------|--------------------|-------------------------|-------------------|--------------------|
| Ru | 0.01 | 0.01 | 0.10 | 0.10 |
| Zr-Nb | 0.01 | .01 | - | 1×10^{-6} |
| I | - | - | 1.0 | 1.0 |
| OFPT | 0.01 | 0.01 | - | 1×10^{-6} |
| Pu | 0.01 | 0.01 | - | 1×10^{-6} |

Equivalence Factor:

Area of the HILC = 1080 ft².

Total burned = 100 gallons = 378 liters.

HAF = 2260 liters/MTU during Np campaign.

HAF/HAX = 0.51 during Np campaign.

HAX = HAF = 4431 liters/MTU.

EF = $\frac{378 \text{ liters}}{4431 \text{ liters/MTU}}$ = 0.085 MTU

This incident takes place in the High Intermediate Level Cell (HILC). There are 2 HEPA filters before stack release. The volatile releases are given in Table V-8 and the non-volatile releases are given in Table V-9.

TABLE V-8
VOLATILE RELEASES

| <u>Group</u> | <u>Isotope</u> | <u>Ci/Tonne</u> | <u>X</u> | <u>DF</u> | <u>X</u> | <u>SF</u> | <u>X</u> | <u>EF</u> | <u>Volatile Fraction</u> | <u>Stack Release Ci</u> |
|--------------|----------------|----------------------|----------|-----------|----------|-----------|----------|-----------|--------------------------|-------------------------|
| Ru: | Ru-103 | 1.2×10^5 | | 0.16 | | 0.01 | | 0.085 | 0.1 | 1.63EO* |
| | Ru-106 | 6.1×10^5 | | 0.73 | | | | | | 3.78E1 |
| I: | I-129 | 3.6×10^{-2} | | 1.0 | | 0.04 | | 0.085 | 1.0 | 1.22E-4 |
| | I-131 | 1.6 | | 0.032 | | | | | | 1.74E-4 |

* 1.63EO = 1.63×10^0

TABLE V-9

NON-VOLATILE RELEASES

| Group | Isotope | Ci/Tonne | X | DF** | X | SF | X | EF | Fraction Dispersed | Stack Release Ci | | |
|--------|---------|----------------------|---|-------|---|-------|---|-------|--------------------|------------------|------------------|-------------------|
| | | | | | | | | | | No Filter Works | One Filter Works | Two Filters Works |
| Ru: | | | | | | 0.01 | | 0.085 | | 1.63E-1 | 1.63E-4 | 1.63E-6 |
| | Ru-103 | 1.2x10 ⁵ | | 0.16 | | | | | .01 | 1.63E-1 | 1.63E-4 | 1.63E-6 |
| | Ru-106 | 6.1x10 ⁵ | | 0.73 | | | | | | 3.78E0 | 3.78E-3 | 3.78E-5 |
| Zr-Nb: | | | | | | 0.01 | | 0.085 | | | | |
| | Zr-95 | 3.5x10 ⁵ | | 0.14 | | | | | .01 | 4.17E-1 | 4.17E-4 | 4.17E-6 |
| | Nb-95 | 6.5x10 ⁵ | | 0.14 | | | | | | 7.74E-1 | 7.74E-4 | 7.74E-6 |
| I: | | | | | | 0.04 | | 0.085 | | | | |
| | I-129 | 3.6x10 ⁻² | | 1.0 | | | | | 0 | 0 | 0 | 0 |
| | I-131 | 1.6 | | 0.032 | | | | | | 0 | 0 | 0 |
| OFPT; | | | | | | 0.001 | | 0.085 | | | | |
| | Sr-89 | 9.0x10 ⁴ | | 0.20 | | | | | .01 | 1.53E-2 | 1.53E-5 | 1.53E-7 |
| | Sr-90 | 8.4x10 ⁴ | | 1.0 | | | | | | 7.13E-2 | 7.13E-5 | 7.13E-7 |
| | Y-90 | 8.4x10 ⁴ | | 1.0 | | | | | | 7.13E-2 | 7.13E-5 | 7.13E-7 |
| | Y-91 | 1.9x10 ⁵ | | 0.23 | | | | | | 3.71E-2 | 3.71E-5 | 3.71E-7 |
| | Cs-134 | 2.4x10 ⁵ | | 0.79 | | | | | | 1.61E-1 | 1.61E-4 | 1.61E-6 |
| | Cs-137 | 1.2x10 ⁵ | | 0.96 | | | | | | 9.78E-2 | 9.78E-5 | 9.78E-7 |
| | Ce-141 | 7.9x10 ⁴ | | 0.13 | | | | | | 8.74E-3 | 8.74E-6 | 8.74E-8 |
| | Ce-144 | 8.8x10 ⁵ | | 0.66 | | | | | | 4.94E-1 | 4.94E-4 | 4.94E-6 |
| | Pm-147 | 1.4x10 ⁵ | | 0.90 | | | | | | 1.07E-1 | 1.07E-4 | 1.07E-6 |
| | Am-241 | 250. | | 1.0 | | | | | | 2.12E-4 | 2.12E-7 | 2.12E-9 |
| | Am-242 | 4.0 | | 1.0 | | | | | | 3.4 E-6 | 3.4 E-9 | 3.4 E-11 |
| | Cm-242 | 4.4x10 ⁴ | | 0.43 | | | | | | 1.6 E-2 | 1.6 E-5 | 1.6 E-7 |
| | Cm-243 | 34.0 | | 0.99 | | | | | | 2.86E-5 | 2.86E-8 | 2.86E-10 |
| | Cm-244 | 5.7x10 ³ | | 1.0 | | | | | | 4.84E-3 | 4.84E-6 | 4.84E-8 |
| Pu: | | | | | | 0.01 | | 0.085 | | 3.65E-2 | 3.65E-5 | 3.65E-7 |
| | Pu-238 | 4.3x10 ³ | | 1.0 | | | | | .01 | 2.72E-3 | 2.72E-6 | 2.72E-8 |
| | Pu-239 | 3.2x10 ² | | 1.0 | | | | | | 5.35E-3 | 5.35E-6 | 5.35E-8 |
| | Pu-240 | 6.3x10 ² | | 1.0 | | | | | | 1.44E0 | 1.44E-3 | 1.44E-5 |
| | Pu-241 | 1.7x10 ⁵ | | 1.0 | | | | | | 3.06E-5 | 3.06E-8 | 3.06E-10 |
| | Pu-242 | 3.6 | | 1.0 | | | | | | | | |

4.

Explosion in the LAW ConcentratorThe Barnwell⁷ calculation is given in Table V-10.TABLE V-10 - SAR Results

| Group ^a | Isotope: | Ci/Tonne | X | SF | X | RF | LF | Ci Released |
|--------------------|----------|----------------------|---|--------------------|---|----------------------|-----|----------------------|
| Ru: | Pu-103 | 1.2x10 ⁵ | | 0.02 | | 0.001 | 3.5 | 8.6 |
| | Ru-106 | 6.1x10 ⁵ | | | | | | 43.0 |
| Zr-Nb: | Zr-95 | 3.5x10 ⁵ | | 0.02 | | 1.1x10 ⁻⁷ | 3.5 | .0028 |
| | Nb-95 | 6.5x10 ⁵ | | | | | | .0052 |
| I: | I-129 | 3.6x10 ⁻² | | 0.032 | | 1.0 | 3.5 | 4.0x10 ⁻³ |
| | I-131 | 1.6 | | | | | | 0.18 |
| OFPT: | | | | 0.002 | | 1.1x10 ⁻⁷ | 3.5 | |
| | Sr-89 | 9.0x10 ⁴ | | | | | | 7.0x10 ⁻⁵ |
| | Sr-90 | 8.4x10 ⁴ | | | | | | 6.6x10 ⁻⁵ |
| | Y-90 | 6.4x10 ⁴ | | | | | | 6.6x10 ⁻⁵ |
| | Y-91 | 1.9x10 ⁵ | | | | | | 1.5x10 ⁻⁴ |
| | Cs-134 | 2.4x10 ⁵ | | | | | | 1.8x10 ⁻⁴ |
| | Cs-137 | 1.2x10 ⁵ | | | | | | 9.4x10 ⁻⁵ |
| | Ce-141 | 7.9x10 ⁴ | | | | | | 6.2x10 ⁻⁵ |
| | Ce-144 | 8.8x10 ⁵ | | | | | | 6.9x10 ⁻⁴ |
| | Pm-147 | 1.4x10 ⁵ | | | | | | 1.1x10 ⁻⁴ |
| | Am-241 | 250. | | | | | | Nil |
| | Am-242 | 4.0 | | | | | | Nil |
| | Cm-242 | 4.4x10 ⁴ | | | | | | 3.5x10 ⁻⁵ |
| | Cm-243 | 34.0 | | | | | | 2.7x10 ⁻⁷ |
| | Cm-244 | 5.7x10 ³ | | | | | | 4.5x10 ⁻⁶ |
| Pu: | | | | 9x10 ⁻⁴ | | 1.1x10 ⁻⁷ | 3.5 | |
| | Pu-238 | 4.3x10 ³ | | | | | | 1.5x10 ⁻⁶ |
| | Pu-239 | 3.2x10 ² | | | | | | 1.1x10 ⁻⁷ |
| | Pu-240 | 6.3x10 ² | | | | | | 2.2x10 ⁻⁷ |
| | Pu-241 | 1.7x10 ⁵ | | | | | | 6.0x10 ⁻⁵ |
| | Pu-242 | 3.6 | | | | | | Nil |

^aOFPT = Other fission products and transuranium elements.Release factor:

Non-volatile fraction dispersed:

Concentrator volume = 1500 liters of concentrate
 Cell volume = 1510 m³
 Aerosol content = 100 mg/m³
 Concentrate dispersed = 1.5x10⁵ mg = 0.15 kg
 Concentrate density = 1.3 kg/l
 Non-volatile fraction dispersed = 8x10⁻⁵
 Dispersion passing through filter = 0.14 mg/m³
 Filter factor = 1.4 x 10⁻³

| Element | Non-Vol. Fraction Dispersed x | Filter Factor | Volatile Fraction | R _f |
|---------|-------------------------------------|----------------------|----------------------|----------------------|
| Ru | 8x10 ⁻⁵ | 1.4x10 ⁻³ | .001 | 0.001 |
| Zr-Nb | 8x10 ⁻⁵ | 1.4x10 ⁻³ | 0 | 1.1x10 ⁻⁷ |
| I | 8x10 ⁻⁵ | 1.4x10 ⁻³ | 1.0 | 1.0 |
| OFPT | 8x10 ⁻⁵ | 1.4x10 ⁻³ | 0 | 1.1x10 ⁻⁷ |
| Pu | 8x10 ⁻⁵ | 1.4x10 ⁻³ | 0 | 1.1x10 ⁻⁷ |

Equivalence factor:

Concentration = 99 L/m³ = 432 L/M³ (Non-volatile Pu 10-1)
 EF = 1.4 RTU

The LAW concentrator is in the High Intermediate Level Cell (HILC) and there are 2 HEPA filters prior to stack release. Table V-11 lists the volatile releases and Table V-12 lists the non-volatile releases.

TABLE V-11

VOLATILE RELEASES

| <u>Group</u> | <u>Isotope</u> | <u>Ci/Tonne</u> | <u>X</u> | <u>SF</u> | <u>X</u> | <u>EF</u> | <u>Volatile Fraction</u> | <u>Stack Release Ci</u> |
|--------------|----------------|----------------------|----------|-----------|----------|-----------|--------------------------|-------------------------|
| Ru: | | | | 0.02 | | 3.5 | .001 | |
| | Ru-103 | 1.2×10^5 | | | | | | 8.4E0 |
| | Ru-106 | 6.1×10^5 | | | | | | 4.27E1 |
| I: | | | | 0.032 | | 3.5 | 1.0 | |
| | I-129 | 3.6×10^{-2} | | | | | | 4.03E-3 |
| | I-131 | 1.6 | | | | | | 1.79E-1 |

*8.4E0 = 8.4×10^0

TABLE V-12

NON-VOLATILE RELEASES

| Group* | Isotope: | Ci/Tonne | X | Stack Release Ci | | Fraction Dispersed | No Filter Works | One Filter Works | Two Filters Works |
|--------|----------|----------------------|--------------------|------------------|------------|--------------------|-----------------|------------------|-------------------|
| | | | | SF | EF | | | | |
| Ru: | Ru-103 | 1.2×10^5 | 0.02 | 3.5 | $8.0E-5^*$ | | $6.72E-1$ | $6.72E-4$ | $6.72E-6$ |
| | Ru-106 | 6.1×10^5 | | | | | | | |
| Zr-Nb: | Zr-95 | 3.5×10^5 | 0.02 | 3.5 | $8.0E-5$ | | $1.96E0$ | $1.96E-3$ | $1.96E-5$ |
| | Nb-95 | 6.5×10^5 | | | | | | | |
| I: | I-129 | 3.6×10^{-2} | 0.032 | 3.5 | 0 | | 0 | 0 | 0 |
| | I-131 | 1.6 | | | | | | | |
| OFPT: | | | 0.002 | 3.5 | $8.0E-5$ | | | | |
| | Sr-89 | 9.0×10^4 | | | | | | | |
| | Sr-90 | 8.4×10^4 | | | | | | | |
| | Y-90 | 8.4×10^4 | | | | | | | |
| | Y-91 | 1.9×10^5 | | | | | | | |
| | Cs-134 | 2.4×10^5 | | | | | | | |
| | Cs-137 | 1.2×10^5 | | | | | | | |
| | Ce-141 | 7.9×10^4 | | | | | | | |
| | Ce-144 | 8.8×10^5 | | | | | | | |
| | Pm-147 | 1.4×10^5 | | | | | | | |
| | Am-241 | 250. | | | | | | | |
| | Am-242 | 4.0 | | | | | | | |
| | Cm-242 | 4.4×10^4 | | | | | | | |
| | Cm-243 | 34.0 | | | | | | | |
| | Cm-244 | 5.7×10^3 | | | | | | | |
| Pu: | | | 9×10^{-4} | 3.5 | $8.0E-5$ | | | | |
| | Pu-238 | 4.3×10^3 | | | | | | | |
| | Pu-239 | 3.2×10^2 | | | | | | | |
| | Pu-240 | 6.3×10^2 | | | | | | | |
| | Pu-241 | 1.7×10^5 | | | | | | | |
| | Pu-242 | 3.6 | | | | | | | |

* $8.0E-5 = 8.0 \times 10^{-5}$

5.

Ion Exchange Resin Fire (Neptunium Recovery Campaign)The Barnwell⁷ Calculation is given in Table V-13.TABLE V-13SAR Results

| <u>Isotope</u> | <u>Source Activity,</u> <u>Ci/tonne</u> | <u>x</u> | <u>SF</u> | <u>x</u> | <u>RF</u> | <u>x</u> | <u>EF</u> = | <u>Activity Released,</u> <u>Ci</u> |
|----------------|--|----------|----------------------|----------|----------------------|----------|-------------|--|
| Ru-103 | 1.24×10^5 | | 3.0×10^{-6} | | 5.1×10^{-2} | | 5 | 9.49×10^{-2} |
| Ru-106 | 7.22×10^5 | | 3.0×10^{-6} | | 5.1×10^{-2} | | 5 | 0.552 |
| Zr-95 | 3.58×10^5 | | 6.6×10^{-6} | | 1.0×10^{-3} | | 5 | 1.18×10^{-2} |
| Nb-95 | 6.82×10^5 | | 6.6×10^{-6} | | 1.0×10^{-3} | | 5 | 2.25×10^{-2} |
| I-129 | 3.55×10^{-2} | | 3.1×10^{-7} | | .50 | | 5 | 2.75×10^{-8} |
| I-131 | 1.6 | | 3.1×10^{-7} | | .50 | | 5 | 1.24×10^{-6} |
| Sr-89 | 8.2×10^4 | | 1.0×10^{-8} | | 1.0×10^{-3} | | 5 | 4.10×10^{-6} |
| Sr-90 | 8.2×10^4 | | 1.0×10^{-8} | | 1.0×10^{-3} | | 5 | 4.10×10^{-6} |
| Cs-134 | 1.79×10^5 | | 1.0×10^{-8} | | 1.0×10^{-3} | | 5 | 8.95×10^{-6} |
| Cs-137 | 1.25×10^5 | | 1.0×10^{-8} | | 1.0×10^{-3} | | 5 | 6.25×10^{-6} |
| Ba-137m | 1.10×10^5 | | 1.0×10^{-8} | | 1.0×10^{-3} | | 5 | 5.50×10^{-6} |
| Ce-144 | 5.6×10^5 | | 1.0×10^{-8} | | 1.0×10^{-3} | | 5 | 2.80×10^{-5} |
| Cm-242 | 4.0×10^4 | | 1.0×10^{-8} | | 1.0×10^{-3} | | 5 | 2.00×10^{-6} |
| Cm-244 | 4.9×10^3 | | 1.0×10^{-8} | | 1.0×10^{-3} | | 5 | 2.45×10^{-7} |
| Np-238 | 6.38 | | 0.95 | | 1.0×10^{-3} | | 5 | 3.03×10^{-2} |
| Pu-238 | 4.37×10^3 | | 5.0×10^{-4} | | 1.0×10^{-3} | | 5 | 1.09×10^{-2} |
| Pu-239 | 3.2×10^2 | | 5.0×10^{-4} | | 1.0×10^{-3} | | 5 | 8.00×10^{-4} |
| Pu-240 | 6.3×10^2 | | 5.0×10^{-4} | | 1.0×10^{-3} | | 5 | 1.58×10^{-3} |
| Pu-241 | 1.6×10^5 | | 5.0×10^{-4} | | 1.0×10^{-3} | | 5 | 0.40 |

| <u>Element</u> | <u>Non-Volatile Fraction</u> <u>Passing Filter</u> | <u>Volatile</u> <u>+ Fraction</u> | <u>=</u> | <u>RF</u> |
|----------------|---|--------------------------------------|----------|----------------------|
| Ru | 9.0×10^{-4} | .05 | | 5.1×10^{-2} |
| Zr-Nb | 1.0×10^{-2} | 0 | | 1.0×10^{-3} |
| I | 0 | .50 | | .50 |
| Sr, Ce, Cs, | | | | |
| Ba, Cm | 1.0×10^{-3} | 0 | | 1.0×10^{-3} |
| Pu | 1.0×10^{-3} | 0 | | 1.0×10^{-3} |
| Np | 1.0×10^{-3} | 0 | | 1.0×10^{-3} |

Equivalence Factor (EF)

$$EF = (5MTU/day) (1 \text{ day}) = 5MTU$$

The accident occurs in the Plutonium Product Cell (PPC) where there are three HEPA's in series before stack release. 10% of the Ru and 100% of the I are volatilized during the burning. The results are given below for the volatile and non-volatile releases. These results are included for completeness. They are not included in risk assessment considerations since it is anticipated that this unit operation will not be used in the reprocessing plants under consideration.

TABLE V-14

VOLATILE SOURCE

| <u>Isotope</u> | <u>Source Activity Ci/tonne</u> | X | <u>SF</u> | X | <u>EF</u> | <u>Volatile Fraction</u> | <u>Stack Release Ci</u> |
|----------------|-------------------------------------|---|----------------------|---|-----------|------------------------------|-----------------------------|
| Ru-103 | 1.24×10^5 | | 3.0×10^{-6} | | 5 | .05 | $9.3\text{E}-2^*$ |
| Ru-106 | 7.22×10^5 | | 3.0×10^{-6} | | 5 | .05 | $5.42\text{E}-1$ |
| I-129 | 3.55×10^{-2} | | 3.1×10^{-7} | | 5 | .5 ⁺ | $2.75\text{E}-8$ |
| I-131 | 1.6 | | 3.1×10^{-7} | | 5 | .5 | $1.24\text{E}-6$ |

* $9.3\text{E}-2 = 9.3 \times 10^{-2}$

+ Reference 5

TABLE V-15 NON-VOLATILE SOURCE

| Isotope | Source Activity Ci/tonne | SF | EF | Fraction Dispersed | Stack Release Ci | | | |
|---------|-----------------------------|----------------------|----|-----------------------|--------------------|---------------------|---------------------|----------------------|
| | | | | | No Filter Works | One Filter Works | Two Filters Work | Three Filte: Work |
| Ru-103 | 1.24×10^5 | 3.0×10^{-6} | 5 | .45 | $8.37\text{E}-1^*$ | $8.37\text{E}-4$ | $8.37\text{E}-6$ | $5.02\text{E}-7$ |
| Ru-106 | 7.22×10^5 | 3.0×10^{-6} | 5 | .45 | 4.87EO | $4.87\text{E}-3$ | $4.87\text{E}-5$ | $2.92\text{E}-6$ |
| Zr-95 | 3.58×10^5 | 6.6×10^{-6} | 5 | .5 | 5.91EO | $5.91\text{E}-3$ | $5.91\text{E}-5$ | $3.54\text{E}-6$ |
| Nb-95 | 6.82×10^5 | 6.6×10^{-6} | 5 | .5 | 1.13EO | $1.13\text{E}-2$ | $1.13\text{E}-4$ | $6.78\text{E}-6$ |
| I-129 | 3.55×10^{-2} | 3.1×10^{-7} | 5 | 0 | 0 | 0 | 0 | 0 |
| I-131 | 1.6 | 3.1×10^{-7} | 5 | 0 | 0 | 0 | 0 | 0 |
| Sr-89 | 8.2×10^4 | 1.0×10^{-8} | 5 | .5 | $2.05\text{E}-3$ | $2.05\text{E}-6$ | $2.05\text{E}-8$ | $1.23\text{E}-9$ |
| Sr-90 | 8.2×10^4 | 1.0×10^{-8} | 5 | .5 | $2.05\text{E}-3$ | $2.05\text{E}-6$ | $2.05\text{E}-8$ | $1.23\text{E}-9$ |
| Cs-134 | 1.79×10^5 | 1.0×10^{-8} | 5 | .5 | $4.48\text{E}-3$ | $4.48\text{E}-6$ | $4.48\text{E}-8$ | $2.69\text{E}-9$ |
| Cs-137 | 1.25×10^5 | 1.0×10^{-8} | 5 | .5 | $3.13\text{E}-3$ | $3.13\text{E}-6$ | $3.13\text{E}-8$ | $1.88\text{E}-9$ |
| Ba-137m | 1.10×10^5 | 1.0×10^{-8} | 5 | .5 | $2.75\text{E}-3$ | $2.75\text{E}-6$ | $2.75\text{E}-8$ | $1.65\text{E}-9$ |
| Ce-144 | 5.6×10^4 | 1.0×10^{-8} | 5 | .5 | $1.40\text{E}-2$ | $1.40\text{E}-5$ | $1.40\text{E}-7$ | $8.40\text{E}-9$ |
| Cm-242 | 4.0×10^4 | 1.0×10^{-8} | 5 | .5 | $1.0 \text{ E}-3$ | $1.0 \text{ E}-6$ | $1.0 \text{ E}-8$ | $6.0 \text{ E}-10$ |
| Cm-244 | 4.9×10^3 | 1.0×10^{-8} | 5 | .5 | $1.18\text{E}-4$ | $1.18\text{E}-7$ | $1.18\text{E}-9$ | $7.08\text{E}-11$ |
| Np-238 | 6.38 | 0.95 | 5 | .5 | 1.52E1 | $1.52\text{E}-2$ | $1.52\text{E}-4$ | $9.12\text{E}-6$ |
| Pu-238 | 4.37×10^3 | 5.0×10^{-4} | 5 | .5 | 5.47EO | $5.47\text{E}-3$ | $5.47\text{E}-5$ | $3.28\text{E}-6$ |
| Pu-239 | 3.2×10^2 | 5.0×10^{-4} | 5 | .5 | $4.0\text{E}-1$ | $4.0\text{E}-4$ | $4.0\text{E}-6$ | $2.40\text{E}-7$ |
| Pu-240 | 6.3×10^2 | 5.0×10^{-4} | 5 | .5 | $7.88\text{E}-1$ | $7.88\text{E}-4$ | $7.88\text{E}-6$ | $4.37\text{E}-7$ |
| Pu-241 | 1.6×10^5 | 5.0×10^{-4} | 5 | .5 | 2.0E2 | $2.0\text{E}-1$ | $2.0\text{E}-3$ | $1.20\text{E}-4$ |

* $8.37\text{E}-1 = 8.37 \times 10^{-1}$

6. Nuclear Criticality Incident

The Barnwell⁷ results for a criticality incident in the Remote Process Cell (RPC) are given in Table V-16.

TABLE V-16

SAR Results

NUCLEAR CRITICALITY INCIDENT (10^{10} Fissions)

| <u>Isotope</u> | <u>Activity Released,* Ci@t=0</u> |
|----------------|---------------------------------------|
| I-131(8.05d) | 0.75 |
| I-132(2.4h) | 3.30 |
| I-133(20.5h) | 18.0 |
| I-134(52.5m) | 450. |
| I-135(6.68hr) | 48.0 |
| Xe-135m(15m) | 395. |
| Xe-138(17m) | 1050. |
| Kr-87(1.3h) | 112. |
| Kr-83m(1.86h) | 13.5 |
| Kr-88(2.8h) | 69.5 |
| Kr-85m(4.4h) | 18.5 |
| Xe-135(9.2h) | 36.4 |
| Xe-133m(2.3d) | 0.20 |
| Xe-133(5.27d) | 2.70 |
| Xe-131m(12.0d) | 6.0×10^{-2} |
| Kr-85(10.4y) | 2.0×10^{-3} |

*The iodine is assumed to be volatile. Of the amount generated, 1% is assumed to be released to the vent system, the rest remaining in solution.

7. Explosion in the HAF Tank

This accident is assumed to occur in the High Level Cell (HLC). The consequences of this accident have been evaluated assuming that there is only one HEPA filter before stack release. The release data are given in Tables V-17 and V-18.

Note: It is more likely that for present and future plant designs that at least two filters will be in line between the HLC and the stack.

TABLE V-17

VOLATILE SOURCE

| <u>Group</u> | <u>Isotope</u> | <u>Ci/Tonne</u> | <u>Split Factor</u> | <u>Equivalence Factor</u> | <u>Volatile Fraction</u> | <u>Stack Release Ci</u> |
|--------------|----------------|----------------------|---------------------|---------------------------|--------------------------|-------------------------|
| Ru: | | | 1.0 | 4 | .001 | |
| | Ru-103 | 1.2×10^5 | | | | 4.8E2* |
| | Ru-106 | 6.1×10^5 | | | | 2.44E3 |
| I: | | | 0.1 | 4 | 1.0 | |
| | I-129 | 3.6×10^{-2} | | | | 1.4E-2 |
| | I-131 | 1.6 | | | | 6.4E-1 |

$$*4.8E2 = 4.8 \times 10^2$$

TABLE V-18 NON-VOLATILE SOURCE

| Group | Isotope | Ci/Tonne | Split Factor | Equivalence Factor | Fraction Dispersed | Stack Release Ci No Filter Works | One Filter Works |
|--------|---------|----------------------|--------------|--------------------|--------------------|-------------------------------------|------------------|
| Ru: | Ru-103 | 1.2×10^5 | 1.0 | 4 | $5.9\text{E}-6^*$ | 2.83E0 | 2.83E-3 |
| | Ru-106 | 6.1×10^5 | | | | 1.44E1 | 1.44E-2 |
| ZR-Nb: | Zr-95 | 3.5×10^5 | 1.0 | 4 | $5.9\text{E}-6$ | 8.26E0 | 8.26E-3 |
| | Nb-95 | 6.5×10^5 | | | | 1.53E1 | 1.53E-2 |
| I: | I-129 | 3.6×10^{-2} | 0.5 | 4 | 0 | 0 | |
| | I-131 | 1.6 | | | | 0 | |
| OFPT: | Sr-89 | 9.0×10^4 | 1.0 | 4 | $5.9\text{E}-6$ | 2.12E0 | 2.12E-3 |
| | Sr-90 | 8.4×10^4 | | | | 1.98E0 | 1.98E-3 |
| | Y-90 | 8.4×10^4 | | | | 1.98E0 | 1.98E-3 |
| | Y-91 | 1.9×10^5 | | | | 4.48E0 | 4.48E-3 |
| | Cs-134 | 2.4×10^5 | | | | 5.66E0 | 5.66E-3 |
| | Cs-137 | 1.2×10^5 | | | | 2.83E0 | 2.83E-3 |
| | Ce-141 | 7.9×10^4 | | | | 1.86E0 | 1.86E-3 |
| | Ce-144 | 8.8×10^5 | | | | 2.08E1 | 2.08E-2 |
| | Pm-147 | 1.4×10^5 | | | | 3.31E0 | 3.31E-3 |
| | Am-241 | 250. | | | | 5.90E-3 | 5.90E-6 |
| | Am-242 | 4.0 | | | | 9.45E-5 | 9.45E-8 |
| | Cm-242 | 4.4×10^4 | | | | 1.04E0 | 1.04E-3 |
| | Cm-243 | 34.0 | | | | 8.03E-4 | 8.04E-7 |
| | Cm-244 | 5.7×10^3 | | | | 1.35E-1 | 1.35E-4 |
| | | | | | | | |
| | | | | | | | |
| Pu: | Pu-238 | 4.3×10^3 | 1.0 | 4 | $5.9\text{E}-6$ | 1.02E-1 | 1.02E-4 |
| | Pu-239 | 3.2×10^2 | | | | 7.55E-3 | 7.55E-6 |
| | Pu-240 | 6.3×10^2 | | | | 1.49E-2 | 1.49E-5 |
| | Pu-241 | 1.7×10^5 | | | | 4.01E0 | 4.01E-3 |
| | Pu-242 | 3.6 | | | | 8.50E-5 | 8.50E-8 |

* $5.9\text{E}-6 = 5.9 \times 10^{-6}$

8. Waste Calciner Explosion

The calciner would be fed from the High Aqueous Waste (HAW) concentrator. It would probably be located in the same cell area, which in the case of Barnwell, is the Remote Process Cell (RPC). The calciner operates at several hundred degrees Celsius and this would raise the amount of Ru volatilized during an accident by about a factor of 10 over the HAW concentrator explosion results. Aside from this variation, the results of a waste calciner explosion would be essentially what they were in the HAW concentrator explosion analysis.

9. Fuel Receiving and Storage Accident

Incidents that release radioactivity in the receiving and storage area are varied. A scenario which may bound many similar incidents in the nature and magnitude of the release was chosen for evaluation.

While being shipped the spent fuel cask has lost its heat removal capability. The fuel rods fail the clad and release a large fraction of the more volatile fission products. When the cask is opened in the receiving and storage area it will be submerged in water. The cask interior may be dry and thus, much of the fission activity leaves the cask in a large stream of bubbles that rise to the surface. Some of the fission products will have plated out on the cask interior walls and some will remain in the pool water. The released products will either enter the Fuel Receiving and Storage area (FRS) atmosphere or they may enter the DOG/VOG system.

Table V-19 lists some expected release data for Ru and I. The tritium and noble gas releases are neglected as being part of the normally accepted release. The material quantities used were taken from the data for rail shipments given in Table V-20.

TABLE V-19
Expected Release Data^{50,51}

| <u>Group</u> | <u>Isotope:</u> | <u>Ci/Tonne</u> | <u>Source/4.5 tonne Shipment train</u> | <u>Building Fraction Released</u> | <u>Ci Released</u> |
|--------------|-----------------|----------------------|--|---|------------------------|
| Ru: | | | | | |
| | Ru-103 | 1.2×10^5 | 5.4×10^5 | 10% | 5.4E4 |
| | Ru-106 | 6.1×10^5 | 27.4×10^5 | | 2.74E5 |
| I: | | | | | |
| | I-129 | 3.6×10^{-2} | 16.2×10^{-2} | 10% | 1.62E-2 |
| | I-131 | 1.6 | 7.2 | | 7.2 E-1 |
| OFF* | | | | | |
| | Cs-134 | 2.4×10^5 | 10.8×10^5 | 1% | 1.08E4 |
| | Cs-137 | 1.2×10^5 | 5.4×10^5 | | 5.4E3 |

*OFF = Other Fission Products

TABLE V-20

Volatile Isotope Activity in Spent Fuel Shipments⁵⁰

| <u>Isotope</u> | <u>Type of Shipment</u> | <u>MTU per Shipment</u> | <u>Total Activity per Shipment</u> | <u>% Released To Plenum</u> | <u>Activity In Plenum</u> |
|----------------|-----------------------------|-----------------------------|--|---------------------------------|-------------------------------|
| Kr-85 | Truck | 0.45 | 4350 | 17 | 740 |
| H-3 | Truck | | 187 | 1 | 1.87 |
| I-131 | Truck | | 0.64 | 2.3 | 0.015 |
| Kr-85 | Rail | 4.5 | 43,500 | 17 | 7400 |
| H-3 | Rail | | 1,870 | 1 | 18.7 |
| I-131 | Rail | | 6.4 | 2.3 | 0.15 |
| Kr-85 | Water | 18 | 174,000 | 17 | 29,600 |
| H-3 | Water | | 7,480 | 1 | 75 |
| I-131 | Water | | 25.6 | 2.3 | 0.59 |

The probability of cask heat transfer failure during shipment was estimated at 10^{-3} to 10^{-4} per shipment. With approximately 250 shipments per year, this became 2.5×10^{-1} to 2.5×10^{-2} per year likelihood. We chose 10^{-1} per year for a 4.5 tonne delivery of failed fuel.

Prior to the cask being opened it was assumed that 100% of the I, 10% of the Ru and 1% of the Cs was volatile. The amount that rises through the pool after the cask is opened under water was assumed as 10% of what was initially volatile for the Ru and I and 0.1% for the Cs.

The released gases subsequently pass through an iodine scrubber (VOG) and then through 2 HEPA filters. It was assumed that 7% of the Ru, 0.01% of the I and 0.1% of the Cs would pass through the iodine scrubber. It was also assumed that the passage through the iodine scrubber would cause the volatiles to become non-volatile. Hence the HEPA filter failure probabilities are taken as 10^{-2} and 10^{-3} per demand, as previously noted. Table V-21 presents the results. Noble gases were considered as normal releases.

TABLE V-21

FUEL RECEIVING AND STORAGE ACCIDENT

| Isotope | Ci in a 4.5 tonne Shipment | | Amt. in Cask Atmosphere Before Release | | Amt. in FRSS Atmos. after Cask is Opened | | Amt. After Iodine Scrubber | Amt. After 1 Filter | Amt. After 2 Filter |
|---------|----------------------------|--------|--|--------|--|---------------|----------------------------|---------------------|---------------------|
| Ru 103 | 5.4×10^5 | (.10)* | 5.4E4 | (.1)* | 5.4E3 | (.07)* | 3.78E2 | 3.78E-1 | 3.78E-3 |
| Ru 106 | 2.74×10^6 | (.10) | 2.74E5 | (.1) | 2.74E4 | (.07) | 1.92E3 | 1.92E0 | 1.92E-2 |
| I 129 | 1.62×10^{-1} | (1.0) | 1.62E-1 | (.1) | 1.62E-2 | (10^{-4}) | 1.62E-6 | 1.62E-6 | 1.62E-6 |
| I 131 | 7.2 | (1.0) | 7.2E0 | (.1) | 7.2E-1 | (10^{-4}) | 7.2E-5 | 7.2E-5 | 7.2E-5 |
| Cs 134 | 1.08×10^6 | (.01) | 1.08E4 | (.001) | 1.08E1 | (10^{-3}) | 1.08E-2 | 1.08E-5 | 1.08E-7 |
| Cs 137 | 5.4×10^5 | (.01) | 5.4E3 | (.001) | 5.4E0 | (10^{-3}) | 5.4E-3 | 5.4E-6 | 5.4E-8 |

* Fraction available for release

VI. Risk Assessment

1. Release Likelihood Spectra

To quantify the risk from a generic reprocessing plant requires the synthesis of accident likelihoods and their consequences. In Section 3, a number of fault trees keyed to each process cell were constructed. While these fault trees are generic in nature they do indicate the complications that are required in order to have an accident and also indicate the probable likelihood of such an event. In Section 5, the consequences from each of these accident sequences identified in the fault trees are evaluated. In this section, the results of Sections 3 and 5 are combined to produce a spectrum of release likelihood curves for a variety of isotopes.

Since there are 10 to 15 accidents that were considered, an alphabetical code is employed in plotting up the data for accident identification. This alphabetical code is given in Table VI-1. Also shown in Table VI-1 are the number of HEPA filters normally found between the process cell of interest and the final exhaust stack. Both the process cell and the fault trees that were utilized to evaluate the likelihood of the incident occurring in the cell are given in the table as well as the probability of occurrence of the incident.

Figures VI-1 through VI-5 are plots of the data for the classes of isotopes considered. Iodine and ruthenium are

TABLE VI-1

ACCIDENTS CONSIDERED IN PRESENT ANALYSIS

| <u>ACCIDENT</u> | <u>LOCATION</u> | <u>NO. OF HEPA FILTERS</u> | <u>TREES</u> | <u>LIKELIHOOD/YEAR</u> |
|---|--------------------------|--------------------------------|---------------|------------------------|
| A. HAW Conc Explosion | RPC | 2 | RPC, S, RO | 10^{-5} |
| B. Solvent Fire Pu Extraction Cycle | PPC | 3 | PPC, SF | 10^{-6} |
| C. Solvent Fire Codecontamination Cycle | HILC | 2 | HILC, SF | 10^{-6} |
| D. LAW Conc Explosion | ILC | 2 | ILC, S, RO | 10^{-4} |
| E. Ion Exchange Resin Fire (Not Plotted) | PPC | 3 | PPC, IER | 10^{-4} |
| 106 F. Criticality Incident | Various (RPC Typical) | - 2 | RPC, CP | 10^{-5} |
| G. HAF Tank Explosion | HLC | 1* | HLC, H | 10^{-5} |
| H. Waste Calciner Explosion | (RPC) | 2 | RPC, S, RO, H | 10^{-6} |
| I. Fuel Receiving and Storage Accident | FRSS | | FRS | 10^{-1} |

* The analysis presented in this report assumes that there is only one HEPA filter between HLC and stack. However, it is more likely that for present and future plant designs that at least two filters will be in line between HLC and the stack.




Figure VI -1 IODINE RELEASES ANTICIPATED FOR THE
HYPOTHETICAL ACCIDENTS ANALYZED




Figure VI-2 RUTHENIUM RELEASES ANTICIPATED FOR THE HYPOTHETICAL ACCIDENTS ANALYZED




Figure VI-3 NON-VOLATILE ACTINIDE RELEASES ANTICIPATED
FOR THE HYPOTHETICAL ACCIDENTS ANALYZED




Figure VI-4 PLUTONIUM RELEASES ANTICIPATED FOR
THE HYPOTHETICAL ACCIDENTS ANALYZED




Figure VI-5 OTHER NONVOLATILE FISSION PRODUCT RELEASES ANTICIPATED FOR THE HYPOTHETICAL ACCIDENTS ANALYZED

plotted separately because of their expected importance in the analysis. The other three curves identify the actinide releases, the plutonium releases and the remaining fission products which are all nonvolatile. Only I^{131} is plotted for the criticality incident in the RPC.

To obtain the abscissa values shown in the figures it was necessary to calculate or obtain from the literature a probability of HEPA filter failure. We have found that a probability of failure of 10^{-2} per demand for the first filter is realistic. If more than one filter occurs in the series then we have assumed that an additional factor of ten is needed for the likelihood of complete filter bank failure. That is for two or three HEPA filters in series the probability of failure would be 10^{-3} per demand. In the case of volatile releases the filters are not assumed to work at all. Hence, in the case of iodine and partially in the case of ruthenium the filters do not work because of the volatile nature of the release.

The likelihood values in the figures are then the products of the numbers in Table VI-1 with the probability of filter failure. For example in Figure VI-3, the probability of a HAF tank explosion occurring is 10^{-5} /year. When the filter is working this appears as G_1 for Am^{241} and as G_c for Cm^{242} at the 10^{-5} vertical line. When the filter is failed these two points are shifted to the 10^{-7} /year line, as seen in the figure, in which the probability of filter failure of 10^{-3} /demand has been factored. Since these curves are plotted on log/log paper the points that appear furthest from the origin are those of most significance. For example in the iodine curve, Figure VI-1, the points G_1 and D_1 dominate the spectrum. These figures therefore graphically indicate those accidents of most significance.

2. Dose Quantification

We have selected some of the data given in Figures VI-1 through VI-5 and have calculated the likelihood of receiving a certain dose at a given distance from the generic reprocessing plant site. To do this we utilized the following simplified meteorological model.⁵⁵ For a puff release following an accident we have

$$D = Q \cdot K \cdot (X/Q) \quad (6.1)$$

where

Q is the source strength in curies

K is a dose conversion factor in rem meters³/curie second

D is the received dose in rem

and where

$$(X/Q) = [\pi \bar{u} \sigma_y \sigma_z]^{-1} \exp - [(y^2/2\sigma_y^2) + (h^2/2\sigma_z^2)] \quad (6.2)$$

with

h = release height or stack height in meters

y = cross wind or off centerline distance in meters

\bar{u} = average wind speed in meters/second

σ_y = cloud horizontal dispersion with distance, in meters

σ_z = cloud vertical dispersion with distance, in meters.

The following data were used in this analysis

h = 100 meters

\bar{u} = 2 meters/second

y = 0.

Based upon data given in reference 1 for Category D turbulence, Table VI-2 was developed for (X/Q) as a function of distance from the plant site. K values, obtained from reference 56 are listed in Table VI-3.

TABLE VI-2

Category D Meteorology Parameters

| Distance From Source [Meters] | σ_y | σ_z | (X/Q) [sec/meter ³] h=0, y=0 | (X/Q) [sec/meter ³] h=100 meters, y=0 |
|-------------------------------------|------------|------------|--|---|
| 100 | 6. | 5. | 5.32E-3 [*] | 0 |
| 500 | 30. | 19. | 2.79E-4 | 2.76E-10 |
| 1,000 | 55. | 32. | 9.0 E-5 | 6.74E-7 |
| 5,000 | 220. | 90. | 8.06E-6 | 4.29E-6 |
| 10,000 | 400. | 114. | 3.50E-6 | 2.38E-6 |
| 50,000 | 1500. | 310. | 3.43E-7 | 3.25E-7 |
| 100,000 | 2700. | 420. | 1.41E-7 | 1.37E-7 |

^{*} 5.32E-3 = 5.32 x 10⁻³

TABLE VI-3

Isotopic Dose Conversion Factors (1)

| <u>Group</u> | <u>Isotope</u> | <u>K factors</u> <u>$\left[\frac{\text{rem m}^3}{\text{Ci sec}}\right]$</u> | <u>Group</u> | <u>Isotope</u> | <u>K factors</u> <u>$\left[\frac{\text{rem m}^3}{\text{Ci sec}}\right]$</u> |
|--------------|----------------|---|--------------|----------------|---|
| Ru: | | | OFPT: | | |
| | Ru-103 | 15.9 | | Sr-89 | 47.6 |
| | Ru-106 | 238 | | Sr-90 | 238 |
| Zr-Nb: | | | | Y-90 | |
| | Zr-95 | 47.6 | | Y-91 | 47.6 |
| (2) | Nb-95 | 15.9 | | Cs-134 | 119 |
| I: | | | | Cs-137 | 95 |
| | I-129 | $4.73(10^5)$ | | Ce-141 | 9.5 |
| | I-131 | $8.5(10^4)$ | | Ce-144 | 238 |
| (3) | | | | Pm-147 | 15.9 |
| | I-131 | $1.6(10^5)$ | | Am-241 | $9.52(10^4)$ |
| | | $3.8(10^2)$ | | Am-242 | |
| | | | | Cm-242 | $6.47(10^4)$ |
| | | | | Cm-243 | |
| | | | | Cm-244 | $1.26(10^5)$ |
| | | | Pu: | | |
| | | | | Pu-238 | $3.81(10^5)$ |
| | | | | Pu-239 | $3.81(10^5)$ |
| | | | | Pu-240 | $3.81(10^5)$ |
| | | | | Pu-241 | $3.81(10^2)$ |
| | | | | Pu-242 | $3.81(10^5)$ |

- (1) Conversion factors for dose to lung from inhalation of insoluble particles except for iodine for which the organ of reference is the thyroid.
- (2) Ingestion of milk by infant.
- (3) Inhalation by adult.




Figure VI-6a RUTHENIUM DOSE AT DISTANCE FOR A CERTAIN LIKELIHOOD




Figure VI-6b RUTHENIUM DOSE AT DISTANCE FOR A LIKELIHOOD OF $10^{-3} / \text{YR}$




Figure VI-6c RUTHENIUM DOSE AT DISTANCE FOR A LIKELIHOOD OF $10^{-4}/YR$




Figure VI-7 CESIUM DOSE AT DISTANCE FOR SEVERAL LIKELIHOODS




Figure VI-8 LUNG DOSE FROM PLUTONIUM VS DISTANCE
FOR SEVERAL LIKELIHOODS




Figure VI-9 CURIUM DOSE AT DISTANCE FOR SEVERAL LIKELIHOODS




Figure VI-10a THYROID DOSE FROM IODINE-129 VS DISTANCE




Figure VI-13b THYROID DOSE FROM TOBIN-1000 vs. DISTANCE

By inspecting Figures VI-1 through VI-5 those points that provided the larger releases with the higher probabilities were used as source terms to generate the doses at distance given in Figures VI-6 through VI-10. The isotopes plotted were ruthenium 103 & 106, cesium 134 & 137, plutonium 238 & 241, curium 242 & 244, and iodine 129 & 131. Any of the other isotopes could be plotted in a similar manner.

The distance where the largest dose occurs is approximately 5,000 meters from the plant and this appears to be common for each of the isotopes examined. Category D meteorology is perhaps that which occurs with the highest frequency. A more pessimistic, less likely meteorology could, of course, lead to a series of different dose/distance curves.

Inspection of the results presented in this chapter indicate that incidents involving the high activity feed tank and the fuel receiving and storage cask, dominate much of the release data for non-plutonium releases. Plutonium releases are most evident in ion exchange resin fires and in the high activity waste concentrator and waste calciner explosions. Other incidents, such as low activity waste concentration explosions, contribute to a lesser extent.

3. Site Related Events

It is difficult in a generic study to utilize actual site related data in the accident analysis. We have assumed that the generic plant would be built to withstand foreseeable

site related events. Listed in Table VI-4 are several severe phenomena whose occurrence might damage a portion of the plant. While we cannot do a specific failure analysis for these initiating events, the following statements appear appropriate.

Were a severe tornado to strike a reprocessing plant it might initiate the following failures:

- a. loss of offsite electric power
- b. filter failure
- c. missile penetration of a portion of the building
- d. stack structural failure, either partial or complete
- e. possible loss of storage pool water.

There appears to be practically no way in which a tornado can cause the process cell walls to fail. The loss of electric power or storage pool water are expected to be temporary in nature. The possible release of excess radioactivity due to filter failure or stack collapse will be counteracted by the extensive turbulence and dispersion caused by the tornado itself. Hence little radiological risk is expected from tornado induced events.

An earthquake can cause the following malfunctions:

- a. possible structural failure
- b. loss of offsite electric power
- c. internal piping failures
- d. stack collapse
- e. loss of pool water.

TABLE VI-4

Selected Natural Event Data

| <u>Event</u> | <u>Frequency of Occurrence</u> ^{19,57,58} |
|--|--|
| Tornado ¹⁹ | $6(10^{-4})/\text{yr.}$ |
| Earthquake ¹⁹ Intensity IX | $10^{-5}/\text{yr.}$ |
| Meteorites ⁵⁷ | $10^{-9}/\text{yr.}$ |
| Airplane Impact ⁵⁸ | $10^{-6}/\text{yr.}$ |

The incident of importance here is the piping failure possibility. This event could cause releases to occur in many of the cells simultaneously. Building collapse is not expected to occur even during severe earth tremors. The releases would probably be liquid in nature and consequently would not contribute significantly to airborne releases. Moreover the frequency of 10^{-5} /year is about the same as the process cell incidents. Hence the earthquake induced releases will not impact the upper limit process cell accidents to any noticeable extent.

Airplane or meteorite impact with subsequent fire would cause local process cell failure. However these likelihoods are smaller than cell initiated events and are therefore not significant.

REFERENCES

1. "Environmental Statement Related to Construction and Operation of Barnwell Nuclear Fuel Plant", U.S. AEC Docket No. 50-332, January, 1974.
2. "Environmental Survey of The Nuclear Fuel Cycle", U.S. AEC, Fuels and Materials, Directorate of Licensing, November, 1972.
3. Allied-Gulf Nuclear Services, Inc., "Barnwell Nuclear Fuel Plant Environmental Report", U.S. AEC Docket No. 50-332, October, 1971.
4. J. A. McBride, "Reprocessing, Transportation and Waste Management", presented at the Atomic Industrial Forum workshop on "The End of the Fuel Cycle", Chicago, Illinois, August 22-25, 1971.
5. "Nuclear Fuel Services, Inc., Safety Analysis Report, Reprocessing Plant, West Valley, New York, 1973."
6. General Electric Co., NEDO-10178, "Final Safety Analysis Report - Midwest Fuel Recovery Plant", U.S. AEC Docket No. 50-268, December, 1970.
7. Allied-Gulf Nuclear Services, Inc., "Safety Analysis Report - Barnwell Nuclear Fuel Plant", U.S. AEC Docket No. 50-332, October, 1973.
8. E. R. Irish and W. H. Reas, "The Purex Process - A Solvent Extraction Reprocessing Method for Irradiated Uranium", HW-49483A, April 8, 1957.
9. Code of Federal Regulations: Title 10, Office of Federal Register, National Archives and Records Service, General Services Administration, Washington, D.C., 1971.
10. H. C. Rathvon, "Reprocessing Techniques and Their Licensing and Regulatory Framework", presented at the Atomic Industrial Forum workshop on "The End of the Cycle", Chicago, Illinois, August 22-25, 1971.
11. "Siting of Fuel Reprocessing Plants and Waste Management Facilities", ORNL-4451, Oak Ridge National Laboratory, Oak Ridge, Tenn., July 1970, p. 4-5.

REFERENCES (Cont'd)

12. R. J. Mulvihill, "A Probabilistic Methodology for the Safety Analysis of Nuclear Power Reactors", PRC-R-657, Planning Research Corporation, February 1966.
13. B. J. Garrick, W. C. Gekler, L. Goldfisher, R. H. Karcher, B. Shimizer and J. H. Wilson, "Reliability Analysis of Nuclear Power Plant Protective Systems", HN-190, Holmes and Narver, May, 1967.
14. F. R. Farmer, "Siting Criteria - A New Approach in Containment and Siting of Nuclear Power Reactors", IAEA Report STI/PUB/154, Symposium Proceedings, pp. 303-329, Vienna, Austria, 1967.
15. H. J. Otway and R. C. Erdmann, "Reactor Siting and Design From a Risk Viewpoint", Nuclear Engineering and Design, 13, 365, (1970).
16. C. Starr, "Benefit-Cost Relationships in Socio-Technical Systems", IAEA-SM-146/47, Symposium on Environmental Aspects of Nuclear Power Stations, U.N. Headquarters, N.Y., August 14, 1970.
17. R. R. Fullwood and R. C. Erdmann, "On the Use of Leak Path Analysis in Fault Tree Construction for Fast Reactor Safety", Fast Reactor Safety Meeting, Beverly Hills, California, April 2-4, 1974.
18. W. L. Lennemann, "Management of Radioactive Wastes from AEC Fuel-Reprocessing Operations", "Nuclear Safety 14, 5 September-October, 1973.
19. J. M. Selby et al, "Considerations in the Assessment of the Consequences of Effluents From Mixed Oxide Fuel Fabrication Plants", BNWL-1697, June, 1973.
20. N. Hotland and J. L. Russell, Jr., "Adequacy of Ventilation Exhaust Filtering System for New Plutonium Facilities", C. F. Braun and Co., CONF. 720823, 1972.
21. "Case Histories of Accidents in the Chemical Industry", Manufacturing Chemists Association, Inc., Washington, D.C., Volumes 1-3 and Supplements.

REFERENCES (Cont'd)

22. "Reactor Primary Coolant System Rupture Study", GEAP 10207 et seq., General Electric Company.
23. S. N. Anyakora, G. F. M. Engel and F. P. Lees, "Some Data on the Reliability of Instruments in the Chemical Environment," *The Chemical Engineer*, November, 1971.
24. G. J. Powers, F. C. Tompkins, Jr., "Fault Tree Synthesis for Chemical Processes," AIChE Annual Meeting, Philadelphia, Pa., November, 1973.
25. A. E. Green and A. J. Bourne, "Reliability Technology," Wiley-Interscience, New York, New York, 1972.
26. A. J. Bourne, "Reliability Assessment of Technological Systems," N.W. Center of Institute of Electrical Engineering, October, 1971.
27. "Reliability Stress and Failure Rate Data for Electronic Equipment", Department of Defense, MIL-HDBK-217A, 1965.
28. W. H. Dickinson et al, "Reliability Survey of Industrial Plants", presented at Industrial and Commercial Power Systems Technical Conference, IEEE, Atlanta, Georgia, May 14-16, 1973.
29. M. J. Miller, "The Reliability of Fire Protection Systems", AIChE, Loss Prevention Symposium, Philadelphia, Pa., November 11-15, 1973.
30. B. J. Garrick, B. Shimizer, W. C. Gekler, and J. H. Wilson, "Collection of Reliability Data at Nuclear Power Plants", Holmes and Narver, Inc., HN-199, December, 1968.
31. Liquid Metal Engineering Center, "Failure Data Handbook for Nuclear Power Facilities", LMEC-Memo-69-7, August 15, 1969.
32. R. C. Erdmann, D. Okrent, P. Godbout and K. A. Solomon, "Fault Tree Analysis of Reactor Safety Systems with Application to the Residual Heat Removal System of a BWR", paper V-47 in Conference on Mathematical Models and Computational Techniques for Analysis of Nuclear Systems", USAEC-CONF. 730414-P2, Ann Arbor, Michigan, April 9-11, 1973.

REFERENCES (Cont'd)

33. Northern States Power Co., "Final Safety Analysis Report, Monticello Nuclear Generating Plant", USAEC Docket No. 50-263, 1969.
34. "Operational Accidents and Radiation Exposure Experience Within the USAEC 1943-1970", U.S. AEC WASH-1192, 1971.
35. J. A. McBride et al, "Safety Aspects of U. S. Fuel Reprocessing", Third International Conference on the Peaceful Uses of Atomic Energy, Paper A/Conf. 28/P/278 (1964).
36. Nuclear Fuel Services, Inc., "Safety Analysis Report, NFS Reprocessing Plant, West Valley, N.Y.", U.S. AEC Docket No. 50-201, Volume II, 1973.
37. G. M. Nichols, "Decomposition of the Tributyl Phosphate - Nitrate Complexes", USAEC Report DP-526, E.I. DuPont de Nemours and Co., Savannah River Laboratory, November, 1960.
38. T. J. Colvin, Jr., G. M. Nicols and T. H. Siddall, "TNX Evaporator Incident January 13, 1953", U.S.AEC Report DP-25, E.I. DuPont de Nemours and Co., Savannah River Laboratory, May 15, 1953.
39. E. R. Irish, "Separations Plant Silver Reactor Incident", HW-57048, September 15, 1958.
40. L. T. Lakey and J. R. Bower, "ICPP Waste Calcining Facility Safety Analysis Report" IDO-14620, December 1, 1963.
41. G. E. Lohse and R. E. Commander, "Initial Operation of the Idaho Waste Calcining Facility and Radioactive Feed", Proceedings of the Symposium on the Solidification and Long-Term Storage of Highly Radioactive Wastes, Richland, Wash., Feb. 14-18, 1966, U.S. AEC CONF-660208, 1966.
42. K. J. Schneider, editor, "Waste Solidification Program, Process Technology-Pot, Spray and Phosphate Glass Solidification Processes", BNWL-1073, August 16, 1969.

REFERENCES (Cont'd)

43. A. G. Blasewitz, editor, "Fixation of Radioactive Residues", BNWL-1074, Quarterly Progress Report, February-April 1969.
44. D. A. Hoover and W. B. Ingalls, "Study of Polyethylene Bottles as Containers for Plutonium Nitrate", Proceedings of the 2nd International Conference on Packaging and Transportation of Radioactive Materials, Union Carbide/U.S. AEC CONF-681001 (1968).
45. P. E. Potter, "Studies of the Sintering Behavior of Plutonium Oxide", AERE-R-4729, Metallurgical Division, AERE, Harwell, England, September, 1964.
46. J. Mishima et al, "Plutonium Release Studies, III. Release from Pu Bearing Powders", BNWL-786, July, 1968.
47. "Environmental Survey of Transportation of Radioactive Materials to and from Nuclear Plants", U. S. AEC Report, December, 1972.
48. G. W. Parker, J. W. Martin and G. E. Creek, "Fission Product Release from Reactor Grade UO_2 by Oxidation, Diffusion and Melting", ORNL-CF-60-12-14.
49. G. W. Parker et al, "Fuel Element Decomposition Products", TID-7627, Seventh AEC Air Cleaning Conference, October 10-12, 1961.
50. J. H. Goode and V. C. A. Vaughen, "Experiments on the Behavior of Tritium During Head-End Processing of Irradiated Reactor Fuels", ORNL-TM-2793, February, 1970.
51. "The Safety of Nuclear Power Reactors and Related Facilities", U.S. AEC Report WASH-1250, July, 1973.
52. J. E. Mendel and J. L. McElroy, "Waste Solidification Program, Volume 10, Evaluation of Solidified Waste Products", BNWL-1666, July, 1972.

REFERENCES (Cont'd)

53. Code of Federal Regulations: Title 10, Office of Federal Register, National Archives and Records Service, General Services Administration, Washington, D.C., Appendix A of 10 CFR Part 50 "General Design Criteria of Nuclear Power Plants"; Appendix B to 10 CFR 50, "Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants"; Appendix A to 10 CFR Part 100, "Seismic and Geologic Criteria for Nuclear Power Plants".
54. Letter from Mr. G. E. Kley, Special Assistant to the Director, USAEC Division of Operational Safety, October 4, 1973 on safety-related incidents in nuclear reprocessing and fabrication facilities for 1971 and 1972.
55. D. H. Slade, editor, "Meteorology and Atomic Energy", USAEC, DRDT 1968.
56. "Environmental Analysis of the Uranium Fuel Cycle", EPA-520/9-73-003-D, U.S. Environmental Protection Agency, Office of Radiation Programs, October, 1973.
57. "Probability and Consequences of Airplane Crashes into Populated Areas", K. Solomon, R. C. Erdmann, D. Okrent. UCLA, (1974).
58. "Estimate of the Hazards to a Nuclear Reactor from the Random Impact of Meteorites", K. Solomon, R. C. Erdmann, D. Okrent, UCLA, (1974).

APPENDIX A

Summary Table Describing the Basic Operations, Process Functions and Chemical Reactions in the Generic Spent Fuel Reprocessing Plant (Modeled after BNFP).

| <u>PROCESS STEP</u> | <u>FUNCTION AND PRINCIPAL CHEMICAL REACTIONS</u> | <u>DESCRIPTION</u> |
|--------------------------------|--|--|
| Cask receiving and handling | Receipt and preparation of shipping cask for unload- ing | Cask and carrier will be monitored for outside contamination and washed to remove outside dirt. The cask will be removed and the condition of fuel and coolant determined by temperature, pressure, and coolant radioactivity measurements. The cask will be vented to the vessel off- gas system and the primary coolant replaced, if necessary. The cask will be placed in the cask unloading pool where the lid will be removed and fuel elements unloaded re- motely under water shield. Empty casks will be decontam- inated, monitored, and returned to customer. |
| Fuel storage and transfer | Storage of fuel elements until dissolution | Fuel element identity will be confirmed and the elements placed in storage canisters in the storage pool. Pool water will be circulated through heat exchangers, inorganic ion exchange beds, and filters to remove fuel decay heat and radioactive contaminants. Elements will be remotely transferred from the pool to the feed mechanism of shear. |
| Shear | Preparation of fuel for dissolution | Fuel elements will be mechanically chopped into small segments, exposing oxide fuel inside the element to dis- solution while outside cladding (stainless steel or zircaloy) will remain undissolved. |

| <u>PROCESS STEP</u> | <u>FUNCTION AND PRINCIPAL CHEMICAL REACTIONS</u> | <u>DESCRIPTION</u> |
|--|--|---|
| Dissolution and feed preparation | Conversion of the fuel to a liquid solution | The chopped fuel elements will be contacted with hot, concentrated nitric acid which will convert uranium, plutonium, and most of the fission products to soluble nitrate salts. Undissolved cladding (hulls) will remain in dissolver basket. Gases generated during dissolution will be channeled to off-gas treatment system. Nitrate salt solution will be transferred to tanks for sampling measurement and final acid adjustment. |
| Dissolution | $3\text{UO}_2 + 8\text{HNO}_3 \xrightarrow{<8\text{M}} 3\text{UO}_2(\text{NO}_3)_2 + 4\text{H}_2\text{O} + 2\text{NO}$ $\text{UO}_2 + 4\text{HNO}_3 \xrightarrow{>8\text{M}} \text{UO}_2(\text{NO}_3)_2 + 2\text{H}_2\text{O} + 2\text{NO}_2$ <p>FISSION PRODUCTS + x HNO₃ +</p> $\text{F.P. } (\text{NO}_3)_x + y\text{H}_2\text{O} + z\text{NO}$ $\text{PuO}_2 + 4\text{HNO}_3 \longrightarrow \text{Pu}(\text{NO}_3)_4 + 2\text{H}_2\text{O}$ $\text{NO} + 2\text{HNO}_3 \xrightarrow{>8\text{M}} 3\text{NO}_2 + \text{H}_2\text{O}$ | |
| Solids handling and waste | Disposal of undissolved cladding hulls | The cladding hulls will be rinsed and transferred by shielded trailer to a burial ground. Intermittently, or in case of abnormalities during dissolution, batches of hulls will be checked for complete dissolution of plutonium and uranium. |
| Co-decontamination and partition cycle | Separation of the plutonium and uranium from the bulk of the fission products and partitioning of the plutonium from the uranium | Adjusted aqueous feed solution and tributyl phosphate (TBP) diluted in a normal paraffin hydrocarbon will be mixed counter-currently in a bank of centrifugal contactors. The organic solution, which preferentially extracts the |

| <u>PROCESS STEP</u> | <u>FUNCTION AND PRINCIPAL CHEMICAL REACTIONS</u> | <u>DESCRIPTION</u> |
|----------------------------|--|--|
| Extraction | $\text{UO}_2^{++} + 2\text{NO}_3^- + 2\text{TBP}$ $\xrightarrow{n\text{-C}_{12}\text{H}_{26}} \text{UO}_2(\text{NO}_3)_2 \cdot 2\text{TBP}$ $\text{Pu}^{+4} + 4\text{NO}_3^- + 2\text{TBP} \xrightarrow{n\text{-C}_{12}\text{H}_{26}} \text{Pu}(\text{NO}_3)_4 \cdot 2\text{TBP}$ $\text{PuO}_2^{++} + 2\text{NO}_3^- + 2\text{TBP}$ $\xrightarrow{n\text{-C}_{12}\text{H}_{26}} \text{PuO}_2(\text{NO}_3)_2 \cdot 2\text{TBP}$ | <p>nitrate complexes of tetravalent plutonium and hexavalent uranium, will exit from the centrifugal contactor and pass through a pulsed scrub column where an aqueous nitric acid solution will remove extracted fission products from the organic stream. The organic stream will pass through a partitioning column where plutonium will be reduced to the inextractable trivalent state and stripped into another aqueous nitric acid stream containing hydrazine. The organic stream will pass through another column where the uranium will be stripped into acidified water. (Alternatively, anion exchange would be used for partitioning plutonium and uranium into separate streams)</p> |
| Reduction and Partitioning | $\text{Pu}_{\text{aq}}^{+4} + 1\text{e}^- \longrightarrow \text{Pu}_{\text{aq}}^{+3}$ $\text{UO}_{2\text{aq}}^{++} + 2\text{e}^- + 4\text{H}^+ \longrightarrow \text{U}_{\text{aq}}^{+4} + 2\text{H}_2\text{O}$ $\text{U}_{\text{aq}}^{+4} + 2\text{Pu}_{\text{aq}}^{+4} + 2\text{H}_2\text{O} \longrightarrow \text{UO}_{2\text{aq}}^{++} + 2\text{Pu}^{+3} + 4\text{H}^+$ $\text{N}_2\text{H}_4 + 2\text{HNO}_2 \longrightarrow \text{N}_2 + \text{N}_2\text{O} + 3\text{H}_2\text{O}$ | |
| Stripping | $\text{UO}_2(\text{NO}_3)_2 \cdot 2\text{TBP} + \text{H}_2\text{O} + 2\text{H}^+ \longrightarrow \text{UO}_{2\text{aq}}^{++} + 2\text{HNO}_3 + \text{H}_2\text{O} + 2\text{TBP}$ | |
| Second uranium cycle | Further decontamination of uranium from fission products | Nitric acid will be added to the aqueous strip stream containing the uranium, and the uranyl nitrate complex will again be preferentially extracted by another TBP solution in a pulsed column. Before leaving the column, |

| <u>PROCESS STEP</u> | <u>FUNCTION AND PRINCIPAL CHEMICAL REACTIONS</u> | <u>DESCRIPTION</u> |
|--|--|---|
| Uranium silica gel, product storage | Final decontamination and disposition of uranium | the organic stream will be scrubbed successively with strong and dilute nitric acid solutions which remove extracted ruthenium and zirconium-niobium, respectively. Uranium will be stripped from the organic stream in another column, using acidified water, and this solution will be subsequently concentrated by evaporation. Concentrated uranium solution will be passed through silica gel beds to remove traces of zirconium-niobium. Uranyl nitrate product solution will be analyzed and stored in tanks until shipment. |
| Second and third plutonium cycle, storage, and shipping | Final decontamination and disposition of plu- tonium | Plutonium in aqueous stream leaving partitioning column will be reoxidized to the extractable tetravalent state, which will be preferentially extracted into the TBP organic stream in a pulsed column. In the same column, |
| Oxidation | $\text{Pu}^{+3} + 2\text{NO}_2 + \text{H}^+ \longrightarrow$ $\text{Pu}^{+4} + \text{HNO}_3 + \text{NO}$ | the organic stream will be scrubbed successively with strong and dilute nitric acid solutions, which will remove |
| Extraction | $\text{Pu}^{+4} + 4\text{NO}_3^- + 2\text{TBP} \xrightarrow{n\text{-C}_{12}\text{H}_{26}} \text{Pu}(\text{NO}_3)_4 \cdot 2\text{TBP}$ | extracted ruthenium and zirconium-niobium, respectively. The organic stream will pass through a strip column where |
| Reduction and Stripping | $\text{Pu}_{\text{aq}}^{+4} + 1\text{e}^- \longrightarrow \text{Pu}_{\text{aq}}^{+3}$ $\text{UO}_2^{++} + 2\text{e}^- + 4\text{H}^+ \longrightarrow \text{U}_{\text{aq}}^{+4} + 2\text{H}_2\text{O}$ | plutonium will be reduced to inextractable trivalent state, which will transfer to the aqueous stream of dilute nitric acid and hydrazine. The extraction-stripping |

| PROCESS STEP | FUNCTION AND PRINCIPAL CHEMICAL REACTIONS | DESCRIPTION |
|-------------------------|--|---|
| Scrubbing | $\begin{array}{l} \text{U}^{+4}_{\text{aq}} + 2\text{Pu}^{+4}_{\text{aq}} + 2\text{H}_2\text{O} \longrightarrow \\ \text{UO}_2^{++} + 2\text{Pu}^{+3} + 4\text{H}^+ \\ \text{TBP} + \text{UO}_2^{++} + 2\text{NO}_3^- \xrightarrow{\text{n-C}_4\text{H}_{10}} \\ \text{UO}_2(\text{NO}_3)_2 \cdot 2\text{TBP} \end{array}$ | <p>sequence will be repeated in the third plutonium cycle for further decontamination. A TBP scrub stream will remove residual uranium from the plutonium aqueous stream as it leaves the last strip column. Plutonium concentration will be accomplished by maintaining a high ratio of organic to aqueous flow in the strip columns. Final plutonium nitrate solution will be washed with an organic stream of normal paraffin hydrocarbon (diluent for TBP) to remove traces of TBP and phosphate. Product solution will be analyzed and stored in tanks until shipment. Solvent streams leaving plutonium cycles will pass through a strip column to remove residual inextractable species of uranium and plutonium and will be recycled to the co-decontamination cycle.</p> |
| No. 1 solvent system | Removal of degradation products from solvent | Organic solvent stream from co-decontamination and partition cycle will be washed successively with dilute aqueous |
| Carbonate wash | $\begin{array}{l} \text{Na}_2\text{CO}_3 + 2(\text{C}_2\text{H}_5)_2\text{HPO}_4 \longrightarrow \\ 2(\text{C}_2\text{H}_5)_2\text{NaPO}_4 + \text{H}_2\text{CO}_3 \\ 2\text{RCH}_2\text{NO}_2 \rightleftharpoons 2\text{RCH} = \text{NOOH} + \\ \text{Na}_2\text{CO}_3 \longrightarrow 2\text{RCH} = \text{NOONa} + \\ \text{H}_2\text{CO}_3 \end{array}$ | <p>solutions of sodium carbonate, nitric acid, and sodium carbonate (or sodium hydroxide) to remove organic degradation products by extraction or precipitation; precipitated solids will be removed by a filter. Fresh TBP or diluent (normal paraffin hydrocarbon) will be added,</p> |

PROCESS STEPFUNCTION AND PRINCIPAL
CHEMICAL REACTIONSDESCRIPTION

No. 2 solvent
system

Removal of degradation
products from solvent

as required, to maintain proper TBP concentration or
total solvent inventory.

Liquid waste
treating and
storage

Disposal of liquid
waste streams with
minimum residual waste
volume for storage.

Organic solvent stream from second uranium cycle will be
treated similarly to No. 1 system, except the second
alkaline wash will be omitted.

Acid reduction

$C_{12}H_{22}O_{11} + 18.2 HNO_3 \longrightarrow$
 $12CO_2 + 14.9 NO + 3.3 NO_2 +$
 $20.1 H_2O$


The highly radioactive waste stream from the co-decontamina-
tion cycle will be concentrated by evaporation; acidity of
the concentrated bottoms will be reduced to permit long-
term storage in stainless steel tanks by reacting with a
sugar solution; overheads will be fed to the low-activity
evaporator for further decontamination. Most of the re-
maining nitric acid waste streams containing low levels
of fission products, uranium, and plutonium will be con-
centrated in the low-activity waste evaporator; concentrated
bottoms will be recycled to the co-decontamination cycle;
overheads will be condensed and fed to the acid recovery
system. Miscellaneous waste streams, containing salts,
low levels of fission products and no appreciable uranium
or plutonium, will be acidified and concentrated in the
general-purpose evaporator; bottoms will be stored; over-
heads will be monitored for radioactivity content and then


| <u>PROCESS STEP</u> | <u>FUNCTION AND PRINCIPAL CHEMICAL REACTIONS</u> | <u>DESCRIPTION</u> |
|--|--|--|
| Nitric acid recovery and storage | Recovery of nitric acid and reduction of nitrogen oxides release to the en- vironments. | discharged. Overheads from LAW evaporator will contain most of the tritium (as tritiated water) and some undestroyed nitric acid from the process; they will be condensed and fed to the fractionator which concentrates nitric acid. Re- covered acid will be stored and used in make-up of various acid streams; overheads containing tritiated water will be monitored for radioactivity (other than tritium) and released to the stack. |
| Off-gas treating | Removal of radioactive and other pollutants from gaseous effluents | Off-gas from dissolver will pass through a scrubber where radioactive iodine will be removed by contact with dilute aqueous solution of nitric acid and mercurous/mercuric nitrate; it will subsequently pass through an acid ab- sorber where nitrogen oxides will be removed. Dissolver off-gas and vessel off-gas streams will be combined, passed through another mercurous/mercuric nitrate scrubber, an iodine adsorber bed, and a high-efficiency filter before release to the stack. |
| Iodine Scrub | $^{210}\text{Hg}(\text{NO}_3)_2 + 4\text{I}^- \longrightarrow \text{HgI}_2 + 2\text{NO}_3^-$ $^{210}\text{Hg}(\text{NO}_3)_2 + 3\text{I}^- \longrightarrow \text{HgI}_2 + 2\text{NO}_3^-$ $^{210}\text{Hg}/\text{I}_2 \text{ mole ratio } \gg 4$ | |

Appendix B: Fault Trees Used in Risk Assessment


| <u>Page</u> | <u>Description</u> | <u>Abbreviation</u> |
|-------------|--|---------------------|
| B-1 | Top of the Reprocessing Plant Fault Tree | --- |
| B-2 | URR Normal Airflow | NFR |
| B-3 | URR in Fuel Receiving and Storage | FRS |
| B-4 | URR in Remote Process Cell | RPC |
| B-5 | URR in High-Level Cell | HLC |
| B-6 | URR in High Intermediate-Level Cell | HILC |
| B-7 | URR in Intermediate Level Cell | ILC |
| B-8 | URR in Plutonium Process Cell | PPC |
| B-9 | URR in Plutonium Loadout Cell | PLC |
| B-10 | URR from High-Level Liquid Waste Tank | LPS, WTV, WTS |
| B-11 | Failure of Heat Transfer from HLLW | HT |
| B-12 | Failure to Institute Emergency Reflood | ER |
| | Dissolver Off-Gas System | DOG |
| | Vessel Off-Gas System | VOG |
| B-13 | Cooling Water Failure | WS |
| | Dissolver and Vessel Off-Gas Common System | VD |
| B-14 | URR from Resin Reaction | RRR |
| B-15 | Solvent Fire in Partition and Purification | SF |
| B-16 | Red Oil Explosion | RO |
| B-17 | Steam Explosion | S |
| B-18 | Criticality Accident in Process Cell | CP |
| B-19 | Controller Fails Unsafe | C |
| | Failure of Personnel Intervention | PI |
| | On-Site Power Failure | OSP |
| B-20 | Acid Fraction Overhead | AFO |
| | Pump Failure | P |

Top of the Reprocessing Plant Fault Tree





B-2



URR in Fuel Receiving and Storage

LIST OF EQUIPMENT

19-C-101 01 DISSOLVER
10-C-102 02 DISSOLVER
19-C-103 03 DISSOLVER

01-D-400 HCU KIAS POT

10-E-100 01 DISSOLVER HEATER/COOLER
10-E-100 02 DISSOLVER HEATER/COOLER
10-E-104 03 DISSOLVER HEATER/COOLER
01-E-401 HCU CONCENTRATOR DISSOLVER
01-E-400 HCU CONCENTRATOR

19-D-150 01 DISSOLVER SCREEN POT
19-D-150 02 DISSOLVER SCREEN POT
19-D-150 03 DISSOLVER SCREEN POT

00-D-001/00 MAINTENANCE CELLING PLUG
00-D-001/00 MAINTENANCE CELLING PLUG
00-D-001 SHIELDING BOOR

00-Y-000 FUEL TRANSFERRED CECUTIVES
00-Y-000 FUEL TRANSFERRED CECUTIVES CING
10-Y-101 TRANSFERRED FUEL PUMPER
10-Y-100 MAINTENANCE CORDS 35-700
10-Y-100 CASKET MANIPULATING CORDS
10-Y-100 POWER MANIPULATOR
10-Y-100/00 DISSOLVER CASKET OPERATOR CORDS

10-Y-107 FUEL TRANSFER TADLE
00-Y-001 DISSOLVER CASKET SHUTTER
00-Y-000 NULL MACHINER
00-Y-011 SHUTTER JET CORD
00-Y-012 SHUTTER JET CORD
00-Y-000 PASS THROUGH PONT

07-V-000 SHIELDING DISSOLVER
07-V-000 SHIELDING DISSOLVER
07-V-000 SHIELDING DISSOLVER
07-V-000 SHIELDING DISSOLVER

07-V-000/00 PERIODICALLY PLUGGED O PLUG
07-V-000/00 DITTO
07-V-000/00 DITTO
07-V-000/00 DITTO


07-V-001 SHIELDING DISSOLVER

10-Y-101 SHEAR

10-Y-100 SHEAR SUPPORT FRAME
10-Y-100 SHEAR FEED CASKET
10-Y-100 SHEAR CASK. TRANSFERRED CASKET
10-Y-107 SHEAR FEED CASK O CASKET
10-Y-100 SHEAR FEED CASK SHUTTER UNIT


10-Y-102 DISSOLVER
00-Y-103 DISSOLVER CASKET UNIT
10-Z-101 FUEL TRANSFERRED HATCH

DISSOLVER CASKET UNIT



URR in Remote Process Cell

B-5

16 A :53 24701 UGE

URR in High-Level Cell

EQUIPMENT LIST


| | |
|--------|--------------------------|
| 2-1-20 | NO COLUMN |
| 2-1-21 | NO COLUMN |
| 2-1-22 | NO COLUMN |
| 2-1-23 | NO CENTRIFUGAL CONTACTOR |
| 2-1-24 | NO ELECTROCELL |
| 2-1-25 | NO COLUMN |
| 2-1-26 | NO COLUMN |
| 2-1-27 | NO COLUMN |
| 2-1-28 | NO COLUMN |
| 2-1-29 | NO COLUMN |

| | |
|--------|----------------------|
| 2-1-30 | NO RECYCLE TANK |
| 2-1-31 | NO DECANTER |
| 2-1-32 | NO DECANTER |
| 2-1-33 | NO GASEOUS FEED TANK |
| 2-1-34 | NO HEAD POT |

| | |
|---------|-------------|
| 2-1-35 | NO HEAD POT |
| 2-1-36 | NO HEAD POT |
| 2-1-37 | NO HEAD POT |
| 2-1-38 | NO HEAD POT |
| 2-1-39 | NO HEAD POT |
| 2-1-40 | NO HEAD POT |
| 2-1-41 | NO HEAD POT |
| 2-1-42 | NO HEAD POT |
| 2-1-43 | NO HEAD POT |
| 2-1-44 | NO HEAD POT |
| 2-1-45 | NO HEAD POT |
| 2-1-46 | NO HEAD POT |
| 2-1-47 | NO HEAD POT |
| 2-1-48 | NO HEAD POT |
| 2-1-49 | NO HEAD POT |
| 2-1-50 | NO HEAD POT |
| 2-1-51 | NO HEAD POT |
| 2-1-52 | NO HEAD POT |
| 2-1-53 | NO HEAD POT |
| 2-1-54 | NO HEAD POT |
| 2-1-55 | NO HEAD POT |
| 2-1-56 | NO HEAD POT |
| 2-1-57 | NO HEAD POT |
| 2-1-58 | NO HEAD POT |
| 2-1-59 | NO HEAD POT |
| 2-1-60 | NO HEAD POT |
| 2-1-61 | NO HEAD POT |
| 2-1-62 | NO HEAD POT |
| 2-1-63 | NO HEAD POT |
| 2-1-64 | NO HEAD POT |
| 2-1-65 | NO HEAD POT |
| 2-1-66 | NO HEAD POT |
| 2-1-67 | NO HEAD POT |
| 2-1-68 | NO HEAD POT |
| 2-1-69 | NO HEAD POT |
| 2-1-70 | NO HEAD POT |
| 2-1-71 | NO HEAD POT |
| 2-1-72 | NO HEAD POT |
| 2-1-73 | NO HEAD POT |
| 2-1-74 | NO HEAD POT |
| 2-1-75 | NO HEAD POT |
| 2-1-76 | NO HEAD POT |
| 2-1-77 | NO HEAD POT |
| 2-1-78 | NO HEAD POT |
| 2-1-79 | NO HEAD POT |
| 2-1-80 | NO HEAD POT |
| 2-1-81 | NO HEAD POT |
| 2-1-82 | NO HEAD POT |
| 2-1-83 | NO HEAD POT |
| 2-1-84 | NO HEAD POT |
| 2-1-85 | NO HEAD POT |
| 2-1-86 | NO HEAD POT |
| 2-1-87 | NO HEAD POT |
| 2-1-88 | NO HEAD POT |
| 2-1-89 | NO HEAD POT |
| 2-1-90 | NO HEAD POT |
| 2-1-91 | NO HEAD POT |
| 2-1-92 | NO HEAD POT |
| 2-1-93 | NO HEAD POT |
| 2-1-94 | NO HEAD POT |
| 2-1-95 | NO HEAD POT |
| 2-1-96 | NO HEAD POT |
| 2-1-97 | NO HEAD POT |
| 2-1-98 | NO HEAD POT |
| 2-1-99 | NO HEAD POT |
| 2-1-100 | NO HEAD POT |

| | |
|---------|-----------|
| 2-1-101 | NO HEATER |
| 2-1-102 | NO COOLER |
| 2-1-103 | NO COOLER |
| 2-1-104 | NO COOLER |
| 2-1-105 | NO COOLER |
| 2-1-106 | NO COOLER |
| 2-1-107 | NO COOLER |
| 2-1-108 | NO COOLER |
| 2-1-109 | NO COOLER |
| 2-1-110 | NO COOLER |
| 2-1-111 | NO COOLER |
| 2-1-112 | NO COOLER |
| 2-1-113 | NO COOLER |
| 2-1-114 | NO COOLER |
| 2-1-115 | NO COOLER |
| 2-1-116 | NO COOLER |
| 2-1-117 | NO COOLER |
| 2-1-118 | NO COOLER |
| 2-1-119 | NO COOLER |
| 2-1-120 | NO COOLER |
| 2-1-121 | NO COOLER |
| 2-1-122 | NO COOLER |
| 2-1-123 | NO COOLER |
| 2-1-124 | NO COOLER |
| 2-1-125 | NO COOLER |
| 2-1-126 | NO COOLER |
| 2-1-127 | NO COOLER |
| 2-1-128 | NO COOLER |
| 2-1-129 | NO COOLER |
| 2-1-130 | NO COOLER |
| 2-1-131 | NO COOLER |
| 2-1-132 | NO COOLER |
| 2-1-133 | NO COOLER |
| 2-1-134 | NO COOLER |
| 2-1-135 | NO COOLER |
| 2-1-136 | NO COOLER |
| 2-1-137 | NO COOLER |
| 2-1-138 | NO COOLER |
| 2-1-139 | NO COOLER |
| 2-1-140 | NO COOLER |
| 2-1-141 | NO COOLER |
| 2-1-142 | NO COOLER |
| 2-1-143 | NO COOLER |
| 2-1-144 | NO COOLER |
| 2-1-145 | NO COOLER |
| 2-1-146 | NO COOLER |
| 2-1-147 | NO COOLER |
| 2-1-148 | NO COOLER |
| 2-1-149 | NO COOLER |
| 2-1-150 | NO COOLER |


| | |
|---------|-----------|
| 2-1-151 | NO COOLER |
| 2-1-152 | NO COOLER |
| 2-1-153 | NO COOLER |
| 2-1-154 | NO COOLER |
| 2-1-155 | NO COOLER |
| 2-1-156 | NO COOLER |
| 2-1-157 | NO COOLER |
| 2-1-158 | NO COOLER |
| 2-1-159 | NO COOLER |
| 2-1-160 | NO COOLER |
| 2-1-161 | NO COOLER |
| 2-1-162 | NO COOLER |
| 2-1-163 | NO COOLER |
| 2-1-164 | NO COOLER |
| 2-1-165 | NO COOLER |
| 2-1-166 | NO COOLER |
| 2-1-167 | NO COOLER |
| 2-1-168 | NO COOLER |
| 2-1-169 | NO COOLER |
| 2-1-170 | NO COOLER |
| 2-1-171 | NO COOLER |
| 2-1-172 | NO COOLER |
| 2-1-173 | NO COOLER |
| 2-1-174 | NO COOLER |
| 2-1-175 | NO COOLER |
| 2-1-176 | NO COOLER |
| 2-1-177 | NO COOLER |
| 2-1-178 | NO COOLER |
| 2-1-179 | NO COOLER |
| 2-1-180 | NO COOLER |
| 2-1-181 | NO COOLER |
| 2-1-182 | NO COOLER |
| 2-1-183 | NO COOLER |
| 2-1-184 | NO COOLER |
| 2-1-185 | NO COOLER |
| 2-1-186 | NO COOLER |
| 2-1-187 | NO COOLER |
| 2-1-188 | NO COOLER |
| 2-1-189 | NO COOLER |
| 2-1-190 | NO COOLER |
| 2-1-191 | NO COOLER |
| 2-1-192 | NO COOLER |
| 2-1-193 | NO COOLER |
| 2-1-194 | NO COOLER |
| 2-1-195 | NO COOLER |
| 2-1-196 | NO COOLER |
| 2-1-197 | NO COOLER |
| 2-1-198 | NO COOLER |
| 2-1-199 | NO COOLER |
| 2-1-200 | NO COOLER |



URR in High Intermediate-Level Cell

EQUIPMENT LIST


| | |
|----------|---|
| 40-D-400 | NO ₂ ABSORBER |
| 44-C-550 | AC FRACTIONATOR |
| 42-C-40 | SOLVENT BATCH STRIPPING TACK |
| 42-D-428 | SOLVENT DRYER FEED TACK |
| 42-C-406 | LOW CONCENTRATOR FEED TACK |
| 42-D-434 | LAO CHECK TACK |
| 42-C-440 | SOLVENT DRYER QUENCH POT |
| 42-D-440 | 42-D-406 HEAD POT |
| 42-C-446 | LAO HEAD POT |
| 42-D-44 | 42-C-440 HEAD POT |
| 45-D-432 | VACUUM DRAINER TACK |
| 45-D-44 | VESSEL OFF-GAS AC POT |
| 45-D-472 | NO ₂ ABSORBER BOTTOMS HEAD POT |
| 44-D-540 | AT CHLORIDE REMOVAL HEAD POT |
| 42-D-600 | RECOVERED ACID STORAGE TACK |
| 42-E-602 | LAO CONCENTRATOR REBOILER |
| 42-E-46 | LAO CONCENTRATOR |
| 45-E-45 | VESSEL OFF-GAS CONDENSER |
| 45-E-43 | OFF-GAS HEATER (ELECT) |
| 45-E-432 | OFF-GAS HEATER (ELECT) |
| 44-E-504 | ACID FRACTIONATOR REBOILER |
| 44-E-55 | ACID FRACTIONATOR CONDENSER |
| 44-E-53C | RECOVERED ACID COOLER |
| 42-F-40 | GASTE SOLVENT BURNER |
| 45-H-425 | NO 1 HODINE SCRUBBER |
| 45-H-428 | NO 2 HODINE SCRUBBER |
| 00-D-010 | SAMPLER VALVE POT |
| 00-D-011 | SAMPLER VALVE POT |
| 00-D-017 | SAMPLER VALVE POT |
| 00-D-027 | SAMPLER VALVE POT |
| 00-D-047 | SAMPLER VALVE POT |



URR in Intermediate Level Cell

[illegible]

| TIME | DESCRIPTION |
|-------|-------------|
| 00:00 | START |
| 00:01 | START |
| 00:02 | START |
| 00:03 | START |
| 00:04 | START |
| 00:05 | START |
| 00:06 | START |
| 00:07 | START |
| 00:08 | START |
| 00:09 | START |
| 00:10 | START |
| 00:11 | START |
| 00:12 | START |
| 00:13 | START |
| 00:14 | START |
| 00:15 | START |
| 00:16 | START |
| 00:17 | START |
| 00:18 | START |
| 00:19 | START |
| 00:20 | START |
| 00:21 | START |
| 00:22 | START |
| 00:23 | START |
| 00:24 | START |
| 00:25 | START |
| 00:26 | START |
| 00:27 | START |
| 00:28 | START |
| 00:29 | START |
| 00:30 | START |
| 00:31 | START |
| 00:32 | START |
| 00:33 | START |
| 00:34 | START |
| 00:35 | START |
| 00:36 | START |
| 00:37 | START |
| 00:38 | START |
| 00:39 | START |
| 00:40 | START |
| 00:41 | START |
| 00:42 | START |
| 00:43 | START |
| 00:44 | START |
| 00:45 | START |
| 00:46 | START |
| 00:47 | START |
| 00:48 | START |
| 00:49 | START |
| 00:50 | START |
| 00:51 | START |
| 00:52 | START |
| 00:53 | START |
| 00:54 | START |
| 00:55 | START |
| 00:56 | START |
| 00:57 | START |
| 00:58 | START |
| 00:59 | START |
| 01:00 | START |



URR in Plutonium Process Cell

700-720 C W EXPANSION TANK
700-737 C W EXCHANGER
700-790A/B C W CIRCULATION PUMPS

PLUTONIUM NITRATE STORAGE

36A-301 PUMP GLOVE BOX #1
36A-302 PUMP GLOVE BOX #2
36A-303 VALVE GLOVE BOX #1
36A-304 VALVE GLOVE BOX #2
36A-305 SAMPLE GLOVE BOX #1
36A-306 SAMPLE GLOVE BOX #2
36A-307 P4 LOADOUT GLOVE BOX
36A-308 MAINTENANCE GLOVE BOX


36D-308A THRU F PLUTONIUM NITRATE STORAGE TANKS
36D-309A THRU F PLUTONIUM NITRATE STORAGE TANKS
36D-310A THRU F PLUTONIUM NITRATE STORAGE TANKS
36D-311A THRU F PLUTONIUM NITRATE STORAGE TANKS
36D-312A THRU F PLUTONIUM NITRATE STORAGE TANKS
36D-313A THRU F PLUTONIUM NITRATE STORAGE TANKS
36D-314A THRU F PLUTONIUM NITRATE STORAGE TANKS
36D-315A THRU F PLUTONIUM NITRATE STORAGE TANKS
36D-316 50 LTR NITRATE SAMPLE TANK
36D-317 10 LTR NITRATE MEASURING TANK

36G-300 P.N.S. TRANSFER PUMP
36G-309 P.N.S. TRANSFER PUMP
36G-310 P.N.S. TRANSFER PUMP
36G-311 P.N.S. TRANSFER PUMP
36G-312 PKLO TRANSFER PUMP
36G-313 P.N.S. TRANSFER PUMP
36G-314 P.N.S. TRANSFER PUMP
36G-315 P.N.S. TRANSFER PUMP
36G-316 PNLO TRANSFER PUMP
36G-317 SUMP PUMP PN CELL #1
36G-318 SUMP PUMP PN CELL #2


75B-750A/S TANK VAULT COOLING UNIT
75B-751 TANK VAULT COOLING UNIT

75K-750 PNLO GLOVE BOX INLET FILTER
75K-751 PNLO GLOVE BOX EXH FILTER
75K-752 PUMP GLOVE BOX INLET FILTER
75K-753 PUMP GLOVE BOX EXH. FILTER
75K-754 PUMP GLOVE BOX INLET FILTER
75K-755 PUMP GLOVE BOX INLET FILTER
75K-756 PUMP GLOVE BOX EXH. FILTER
75K-757 PUMP GLOVE BOX INLET FILTER
75K-758 VALVE GLOVE BOX INLET FILTER
75K-759 VALVE GLOVE BOX EXH. FILTER
75K-760 VALVE GLOVE BOX INLET FILTER
75K-761 VALVE GLOVE BOX INLET FILTER
75K-762 VALVE GLOVE BOX EXH. FILTER
75K-763 VALVE GLOVE BOX INLET FILTER
75K-764 SAMPLE GLOVE BOX EXH. FILTER
75K-765 SAMPLE GLOVE BOX INLET FILTER
75K-766 SAMPLE GLOVE BOX EXH. FILTER
75K-767 SAMPLE GLOVE BOX INLET FILTER
75K-768A/D TANK VAULT RECIRCUL. FILTER
75K-769 EMERGENCY INLET FILTER


800-8108 SAMPLE VALVE POT
800-8106 SAMPLE VALVE POT
800-8107 SAMPLE VALVE POT
800-8108 SAMPLE VALVE POT
800-8109 SAMPLE VALVE POT
800-8110 SAMPLE VALVE POT
800-8111 SAMPLE VALVE POT
800-8112 SAMPLE VALVE POT






URR in Plutonium Loadout Cell




URR from High-Level Liquid Waste Tank




Failure of Heat Transfer from HLLW



Failure to Institute Emergency Reflood





Cooling Water Failure




Dissolver and Vessel Off-Gas Common System

URR from Resin Reaction







Solvent Fire in Partition and Purification




Red Oil Explosion




Steam Explosion




Criticality Accident in Process Cell




Controller Fails Unsafe




Failure of Personnel Intervention



On-Site Power Failure



Acid Fraction Overhead



Pump Failure

APPENDIX C

Descriptions of Accidents Experienced in the Nuclear
Energy Field and Chemical Industry Relating to Anticipated
Credible Events at a Fuel Reprocessing Plant.

This Appendix reviews the types of accidents which have occurred in AEC operational activities relating to operations performed at a nuclear fuels reprocessing plant. The information is drawn from AEC field office reports as described in USAEC Report WASH-1192³⁴ and supplemental information supplied by the USAEC Division of Operational Safety.⁵⁴ There is a tendency to emphasize exposures and contamination from criticality incidents in discussions concerning radiation hazards because of the AEC's involvement. These occurrences, however, are in the minority in the overall picture of potential environmental impact. By far, the majority of potential incidents which could occur during activities at a fuel reprocessing plant, that might have an environmental impact are comparable, in kind, to those occurring in the chemical industry. To broaden the statistical base for accident probability estimates for this study, available relevant accident case histories from the chemical industry are also included in this Appendix.²¹ These case histories, covering the period 1951 through 1972 are voluntarily submitted to the Manufacturing Chemists Association for publication in an endeavor to improve plant safety in the industry. This compilation, to be sure, is not complete. It does, however, indicate the types of accidents that have occurred in the operation of a reprocessing plant or related facility and was utilized in selecting the hypothetical accidents considered in this study.

The abbreviations used for the USAEC field offices are as follows:

| | |
|----|-------------------------------|
| AL | Albuquerque Operations Office |
| BH | Brookhaven Office |

| | |
|--------|---|
| CH | Chicago Operations Office |
| GJ | Grand Junction Office |
| HA | Hanford Operations Office |
| ID | Idaho Operations Office |
| LAR | Lockland Aircraft Reactors Office |
| NV | Nevada Operations Office |
| NY | New York Operations Office |
| OR | Oak Ridge Operations Office |
| PNR | Pittsburgh Naval Reactors Office |
| RL | Richland Operations Office (Formerly HA) |
| SAN | San Francisco Operations Office |
| SNR | Schenectady Naval Reactors Office |
| SR | Savannah River Operations Office |
| SNPO-C | Space Nuclear Propulsion Office-Cleveland |
| SNPO-N | Space Nuclear Propulsion Office-Nevada |

1. Criticality Accidents

a. Oak Ridge, Tenn., June 16, 1958

A nuclear accident occurred in a 55-gallon stainless steel drum in a processing area in which enriched uranium is recovered from various materials by chemical methods in a complex of equipment. This recovery process was being remodeled at the time of the accident.

The incident occurred while they were draining material thought to be water from safe 5-inch storage pipes into an unsafe drum.

Eight employees were in the vicinity of the drum carrying out routine plant operations and maintenance. A chemical operator was participating in the leak testing which inadvertently set off the reaction. He was within three to six feet of the drum, while the other seven employees were from 15 to 50 feet away.

Using special post hoc methods for determining the neutron and gamma exposures of the employees involved, it was estimated that the eight men received: 461 rem, 428 rem, 413 rem, 341 rem, 298 rem, 86 rem, 86 rem, and 29 rem.

Area contamination was slight, with decontamination costs amounting to less than \$1,000.

During this incident 1.3×10^{18} fissions occurred.

b.

Los Alamos, N. Mex., Dec. 30, 1958

The chemical operator introduced what was believed to be a dilute plutonium solution from one tank into another known to contain more plutonium in emulsion. Solids containing plutonium were probably washed from the bottom of the first tank with nitric acid and the resultant mixture of nitric acid and plutonium-bearing solids was added to the tank containing the emulsion. A criticality excursion occurred immediately after starting the motor to a propeller type stirrer at the bottom of the second tank.

The operator fell from the low stepladder on which he was standing and stumbled out of the door into the snow. A second chemical operator in an adjoining room had seen a flash, which probably resulted from a short circuit when the motor to the stirrer started, and went to the man's assistance. The accident victim mumbled he felt as though he was burning up. Because of this, it was assumed that there had been a chemical accident with a probable acid or plutonium exposure. There was no realization that a criticality accident had occurred for a number of minutes. The quantity of plutonium which actually was present in the tank was about ten times more than was supposed to be there at any time during the procedure.

The employee died 35 hours later from the effects of a radiation exposure with the whole-body dose calculated to be 12,000 rem ±.

Two other employees received radiation exposure of 134 and 53 rem, respectively. Property damage was negligible. (See TID-5360, Suppl. 2, p. 30; USAEC Serious Accidents Issue #143, 1-22-59.)

c. Idaho Falls, Idaho, Oct. 16, 1959

A nuclear incident occurred in a process equipment waste collection tank when an accidental transfer was made of about 200 liters of uranyl nitrate solution, containing about 34 kilograms of enriched uranium (91 percent U^{235}), from critically safe process storage tanks to a geometrically unsafe tank through a line formerly used for waste transfers.

Limited visual inspections and test indicated that no significant property damage or loss resulted beyond the approximately \$60,000 cost to recover contaminated uranium solution resulting from the incident.

Of the 21 personnel directly involved in this incident, seven received external exposures to radiation. The exposures were 8, 6, 3.95, 1.50, 1.38, 1.17, and 1.17 rem. Two individuals also received external exposures to the skin of 50 rem and 32 rem. No medical treatment was required for the 21 personnel involved.

d. Idaho Falls, Idaho, Jan. 25, 1961

A nuclear excursion of approximately 6×10^{17} fissions occurred in a first-cycle product evaporator at a chemical processing plant. The criticality accident resulted when

a solution of enriched uranyl nitrate accidentally surged from a geometrically safe section of the evaporator into the upper critically unsafe, vapor disengagement section. The accident occurred behind thick concrete walls in a processing cell which is part of the first cycle for processing highly radioactive spent-fuel elements.

Personnel response to the radiation alarms and the evacuation signal was prompt and orderly.

Analyses of badges from 65 individuals indicated a maximum exposure of 55 millirem gamma and 0 beta. The maximum thermal neutron exposure detected in the badges analyzed was less than 10 millirem. Analyses of nuclear accident dosimeters indicated that there was negligible fast neutron flux associated with personnel exposures.

The radioactivity released to the atmosphere as a result of the accident was about twice normal background when it left the area. Loss of \$6,000 resulted from cleanup of the incident.

e. Richland, Wash., Apr. 7, 1962

An unplanned nuclear excursion occurred in a plutonium processing facility because of the inadvertent accumulation of approximately 1500 grams of plutonium in 45-50 liters of dilute nitric acid solution in a 69-liter glass transfer tank. The sequence of events which led to the accumulation of the plutonium in the tank cannot be stated positively. However, it is believed that, when a tank valve was opened, the solution from another process vessel overflowed to a

sump and was drawn into the transfer tank through a temporary line between this tank and the sump.

When the excursion occurred, radiation and evacuation alarms sounded. All but three employees left the building immediately, according to well-prepared and well-rehearsed evacuation plans. Fortunately, they were not in close proximity to the involved system nor in a high radiation field.

The course of the nuclear reaction involved initial criticality (10^{16} fissions); a subsidence; one or more later peaks; and after approximately one-half hour, a declining rate of fission, which terminated in a subcritical condition 37 hours later. The total number of fissions was approximately 8×10^{17} .

Of the 22 persons in the building at the time, only four employees, those who were in the room with the system, were hospitalized for observation. Three of them were the system operators, who were in close proximity to the excursion, and who received estimated radiation doses of 110, 43, and 19 rem. None of them showed symptoms definitely referable to their radiation exposures. The fourth was sent to the hospital only because he was in the room at the time of the incident.

Some fission product activity, airborne via the vent system and the exhaust stack, was detected in the atmosphere for a brief period after the accident. The physical damage amounted to less than \$1,000.

f. Wood River Junction, R.I., July 24, 1964

Because of startup difficulties an unusually large amount of highly enriched uranium-contaminated trichloroethane (TCE) had accumulated at United Nuclear's Scrap Recovery Plant. The recovery was by mixing the TCE with a sodium carbonate solution. On the day of the incident the process was shifted to an 18 in. dia. by 25 in. deep tank to try to catch up with the backlog. The plant evaporator failed resulting in a plug of uranium nitrate crystals in the converting line. This plug was dissolved with steam and the concentrated solution was drained into a polyethylene bottle. This bottle was mistaken for trichlorethane and the operator poured it into the tank of solution. Criticality was reached in a burst of 10^{17} fissions creating a flash of light. 1/5 of the solution was ejected and the operator knocked to the floor. He ran to the emergency building 200 yards away but having received about 10,000 rad, died 49 hours later.

Later two men entered the area to drain the solution into safe containers. When the stirrer was turned off, the geometry change resulted in a second criticality of $2-3 \times 10^{16}$ fissions and these men received 60 and 100 rads.

g. Oak Ridge, Tenn., Jan. 30, 1968

Unexpected criticality was achieved in a volume of an aqueous solution of a salt of U^{233} during a series of routine critical experiments in progress in a well-shielded assembly area of a critical experiments facility. The

criticality-radiation alarm system functioned as designed, the evacuation of personnel from the building was prompt and orderly, and the excursion was terminated expeditiously by a negative coefficient of reactivity and was prevented from recurring by the action of the safety devices. The fission yield was 1.1×10^{16} . Gamma-ray sensitive personnel dosimeters read immediately following the excursion showed no direct exposure greater than 5 mr to any person present. There was no property damage or loss of fissile materials. An estimated 100 cm^3 of solution (15 g of U) were spilled when a rubber-stoppered connection immediately above the sphere was dislocated.

The purpose of the particular experiment in progress was to establish the critical concentration of a sphere of the solution of uranyl nitrate surrounded by a thick water reflector. In the course of approaching criticality by incremental additions of solution, a small volume of air was observed entrapped in a flexible transparent tube. Supercriticality occurred during an attempt, by remote manipulation of liquid levels, to remove the air.

2.

Fires

| <u>Year</u> | <u>Reporting AEC Field Office</u> |
|-------------|---------------------------------------|
|-------------|---------------------------------------|

1959

OR

Multiple circuit breaker failure led to severe electrical fire. Property damage \$86,000. No exposures.

LAR

Electrical fire due to severe arcing on the lineside of heater breakers. Property damage \$30,000. No exposures.

1960

HA

Fire and explosion in pyrophoric metal contents of a chemical dissolver, off-gas filter, and related process equipment. Contamination spread to cell, canyon and crane. Cause(s) of the accident not established. Property damage \$250,443. No exposures.

1962

OR

Fire occurred in ventilation system, probable cause electrical spark. Property damage \$24,700. No exposures.

HA

Air ventilation equipment failure. Property damage \$10,000. No exposures.

OR

Explosion and fire in cell. Property damage \$2,900,000. No exposures.

1963

OR

Fire (definite cause undetermined) originated in building exhaust system and was confined to laboratory hoods and exhaust system; smoke damaged building. Property damage \$43,400. No exposures.

RL

Fire (definite cause undetermined) in plutonium purification facility. Pu contamination in immediate area of fire. Firemen received slight skin contamination, readily removed. Costs related directly to fire \$85,400; decontamination costs \$251,300; overhead related to direct losses \$60,300.

2. Fires (Continued)

| <u>Year</u> | <u>Reporting AEC Field Office</u> | |
|-------------|---------------------------------------|--|
| 1964 | SR | Fire (definite cause undetermined) occurred around an anion exchange column in hot canyon. Fire caused airborne contamination to crane used for remote maintenance. Water to quench fire damaged electric motors. Property damage \$21,000. |
| 1965 | RL | During an aluminum jacket dissolution in a dissolver, an exothermic reaction involving ammonia and/or hydrogen occurred with an electric heater, through which these gases were accidentally vented. The reaction, which continued for 3 hours, totally destroyed the heater. Property damage \$7,200. No exposures. |
| 1966 | SR | A fire occurred when a drying oven overheated. Faulty loading blocked the thermostat sensing element, causing it to indicate erroneously low temperature and call for additional heat. Property damage (\$6,000) was confined to the room of origin. No exposures. |
| | OR | A fire, of undetermined cause, occurred in a laboratory. It was confined to one hood and a section of ductwork because of the successful operation of a sprinkler head, a fire damper in the exhaust system and other fire protection controls. Property damage \$5,500. No exposures. |
| 1968 | RL | An electrical short circuit and the resulting power arc in the main electrical switchgear damaged two breakers extensively, when the lights went out and the building ventilation stopped. Emergency actions were taken to preclude any contamination spread. Operations were curtailed for two and one-half days while repairs were being made. Property damage \$34,000. No exposures. |

2. Fires (Continued)

Case History No. - Manufacturing Chemists Association

| | |
|------|--|
| 41 | "Static Spark Flashes "Empty" Styrene Drum" |
| 129 | Fire Due to Static Spark - Benzene |
| 141 | Toluene Vapors - Flash Fire |
| 150 | Escape of Vapor From Condenser |
| 255 | Ignition of Solvent Vapors - Employee Burned |
| 341 | Solvent Fire |
| 348 | Electric Mixer Fires Solvent |
| 612 | Waste Solvent Fire |
| 643 | Flash Fire in Exhaust Duct |
| 699 | Toluene - Static Fire |
| 701 | "Boil Over" - Flash Fire |
| 1025 | Flammable Solvents - Electric Motor |
| 1217 | Kerosene Vapor Flash - Synthesis Kettle |
| 1234 | Zirconium Fines Flash Fire |
| 1966 | "Static" Ignition of Flammable Solvent |
| 1970 | Solvent-Vapor Flash Fire |

3. Explosions

Year Reporting AEC
Field Office

| | | |
|------|----|--|
| 1959 | SR | Gasket on head of secondary condenser in unit failed. Relief valve vented open due to overpressure. 4-5T of H ₂ S gas released to atmosphere. \$7,000 property damage. No exposures. |
| | HA | Plutonium glovebox explosion. \$9,500. property damage. No exposures. |
| | HA | Autoclave explosion. Property damage \$4,000. No exposures. |
| | AL | Drybox explosion. Property damage \$1,933. No exposures. |
| | OR | Chemical explosion in innercycle evaporator. Property damage \$350,000. No exposures. |
| | OR | An explosion occurred in a digester. Property damage \$10,000+. No exposures. |
| 1960 | OR | Hydrogen gas explosion occurred in gas furnace enclosure in metal plant. Property damage \$5,000. One employee suffered serious injuries. |
| | OR | Explosion occurred in a uranium sintering furnace located in a foundry. Major structural damage to furnace and buildings. Property damage \$20,000. No exposures. |
| | AL | The accidental discharge of radioactive material into a room occurred as a result of pressure buildup in a drybox. This was due to an inlet solenoid being locked in the open position and a venting solenoid being closed due to a malfunction. The pressure built up to a point that one of the drybox gloves blew out, thereby releasing radioactive particulate material into the room. Property damage \$31,360. Eleven persons received minor exposures. |

3. Explosions (Continued)

| <u>Year</u> | <u>Reporting AEC Field Office</u> | |
|-------------|---------------------------------------|---|
| 1961 | AL | Pressure buildup in closed caustic scrubber system forced airborne radioactive material into room. Property damage \$4,016. One employee received 71 rem exposure to bone. Area contaminated. |
| 1963 | ID | Low-level spread of plutonium contamination from glovebox. Property damage \$25,451. No exposures. |
| 1964 | AL | Chemical explosion in metal hood when methanol vapors reached flash-point. Two sets of gloves were shredded by the explosion. Contamination spread in operating area. Property damage \$34,922. Three employees received slight contamination. |
| 1965 | RL | An explosion occurred in a boiler during an attempt to relight the oil-fired burner with a kerosene torch after the automatic re-ignition system failed to function. Property damage \$75,000. No exposures. |
| | RL | Plutonium contamination spread following an explosion and fire occurring in a glovebox when cleaning fluid ignited. Ten employees left the building immediately. Prompt showering easily removed all skin contamination. One employee received 10% of a maximum permissible body burden (bone) of Pu-239 by inhalation. Contamination did not spread outside the building. About 90% of the cost (\$76,800) was incurred for decontamination. |

3. Explosions (Continued)

Year Reporting AEC
 Field Office

1965 AL

An explosion and fire occurred when acetone fumes from a "cocoon" used in a glovebox paint-stripping operation, contacted a hot muffle furnace in another part of the glovebox line. Plutonium contamination spread to adjacent rooms and the second floor. 12 employees required skin decontamination; none received internal radiation exposures. Property damage costs (\$23,253) was for decontamination of facilities.

CH

An explosion resulting from the ignition of a hydrogen-air mixture, the hydrogen apparently evolved from nickel-iron batteries, occurred in the equipment airlock joining a reactor building and a fuel cycle facility. No radioactive material was involved. Property damage \$22,600.

AL

An undetermined small quantity of Pu-238 was released when a double-contained vessel, nearly full of drybox sieved material exploded, dispersing a quantity of the waste material into the laboratory. Property damage \$19,100. No exposures.

Case History No. - Manufacturing Chemists Association

| | |
|------|--|
| 103 | Nitrating Operation Explosion |
| 116 | Storage Battery Explosion |
| 128 | Nitrogen Peroxide - Cyclohexane Mix Explosion |
| 131 | Nitric Acid - Waste disposal Ex- plosion |
| 163 | Reaction in Solvent Recovery Tank |
| 223 | Laboratory Explosion - No Injuries |
| 258 | Explosion - Ignited by Vacuum Cleaner |
| 347 | Hydrogen dessicator - Drainage Trench Explosion |
| 569 | Runaway Nitration Reaction |
| 576 | Hydrogen Compressor - Explosion |
| 611 | Oil Vapor Explosion |
| 678 | Explosion in Nitrobenzene Recovery Kettle |
| 679 | Unsafe "Fail Safe" Flame Safety Device |
| 703 | Explosion in Vent Stack - Static Gen- eration |
| 859 | Spilled Four Gallons Solvent on Lab- oratory Floor - Fire |
| 880 | Chemical Fire - Azido Compound |
| 976 | Silver Complex Detonation |
| 987 | Explosion and Fire - Lead Azide |
| 988 | Tank Explosion |
| 1048 | Explosion - Silver Oxide |

3. Explosions (Continued)

Case History No. - Manufacturing Chemists Association

| | |
|------|---|
| 1068 | Gas Explosion - lighting Burner |
| 1097 | Explosion - Hydrogen gas vent stack |
| 1105 | Americium Solution Shipping Container Explosion |
| 1188 | Hazardous Solvent Causes Explosion in a Plutonium Fuels Laboratory Glovebox (Furnace) |
| 1310 | Flammable Vapor Explosion - Slurry Mix Tank |
| 1311 | Nitration Explosion - Organic Intermediate Mixed with Nitric and Sulfuric Acids |
| 1496 | Drums burst from internal pressure - Accumulation of Hydrogen within |
| 1499 | Tank Rupture - Organic Material Nitrated with Nitric Acid |
| 1554 | Ammoniacal Silver Nitrate Explosion |
| 1733 | Laboratory Explosion - Silver Nitrate, Ammonium Hydroxide, Alcohol Silvering Solution |
| 1957 | Disposal of Deposits of Metal Azides |
| 1958 | Mix Tank Explosion |

4. Fuel Receiving & Storage

| <u>Year</u> | <u>Reporting AEC Field Office</u> | |
|-------------|---------------------------------------|---|
| 1960 | SR | During shipment of irradiated fuel elements, 30 to 40 gallons of contaminated water leaked from the cask. \$24,000 cost due to decontamination of area. No exposures. |
| 1964 | CH | Broken valve on autoclave, housed in lead shipping cask, allowed contaminated water to seep out of cask during transit, contaminating container and truck floor. No property damage. |
| 1967 | RL | A diesel locomotive collided with a cask car during coupling operations, due to the inattention of the diesel's engineer. The cost of \$5,124 was for repairing the locomotive; the cask car was not damaged. No exposures. |

5. Waste and Product Storage

| <u>Year</u> | <u>Reporting AEC Field Office</u> | |
|-------------|---------------------------------------|--|
| 1959 | SR | Leaking compression fitting. \$20,000 damage. No exposures. |
| | SR | Solution leaked from the loosened flange during maintenance work on a waste evaporator in hot canyon, vaporized and contaminated crane. Property damage \$129,324. No exposures. |
| | SR | Loose contaminated particles on the lid of a waste burial box were scattered by the wind, contaminating the ground, locomotive and spacer car. Property damage \$5,200. No exposures. |
| 1960 | SR | Contaminated cooling water discharged from canyon onto floor. Property damage \$250,000 (due to decontamination). No overexposures. |
| 1961 | HA | Uranyl nitrate (1355 lbs. of depleted uranium) lost to ground when tank trailer was overfilled due to misunderstanding between regular operators and their lunch relief. Property damage \$13,000. No exposures. |
| | HA | Approximately 1,089 pounds of depleted uranium lost to chemical sewer in plant. Property damage \$9,000. No exposures. |
| 1963 | AL | Leak in line carrying high-level plutonium solution caused contamination of building and equipment. Property damage \$8,364. No exposures. |
| | AL | Spill of contaminated nitric acid solution. Property damage \$5,662. No exposures. |

5.

Waste and Product Storage (Continued)

| <u>Year</u> | <u>Reporting AEC Field Office</u> |
|-------------|---------------------------------------|
|-------------|---------------------------------------|

| | |
|------|----|
| 1964 | CH |
|------|----|

Clean water, being used to test two new waste tanks, was contaminated by condensation from contaminated vent line connected to one tank. Water subsequently drained onto asphalt surface, contaminating it and drainage ditch. Property damage \$6,075. No exposures.

ID

During steam flushing to remove radioactive contamination from pipelines to permit tie-in to new lines, leak developed in hose coupling. Contaminated fluid and steam issuing from leak were rapidly dispersed by high wind over approximately 10 acres. Majority of \$12,884 cost due to cleanup.

SR

Leaking nitric acid corroded canyon cell equipment beyond repair. Property damage \$6,000. No exposures.

| | |
|------|----|
| 1965 | AL |
|------|----|

While attempting to activate a product transfer line, contaminated acid solution was sprayed out of a flanged union that had not been tightened. Three contaminated employees were readily decontaminated. Property damage \$7,557 for decontamination and for replacing contaminated equipment.

SR

Process water (2400 lbs) was lost when it leaked through an unseated sleeve. Property damage \$33,600. No exposures.

SR

Process water (700 lbs) was lost when it leaked through an unseated sleeve. Property damage \$9,800. No exposures.

SR

A cooling coil in a vessel developed a leak and allowed contaminated solution from a tank to enter the cooling water system when the coil was pressurized. The cost for cleaning the system and associated work was \$19,500. No exposures.

5. Waste and Product Storage (Continued)

| <u>Year</u> | <u>Reporting AEC Field Office</u> |
|-------------|---------------------------------------|
|-------------|---------------------------------------|

| | | |
|------|----|--|
| 1966 | RL | An estimated 420 lbs. of uranium solution were lost to radioactive waste through a milling tank overflow, caused by the failure of a normally closed supply line valve. Property damage \$7,200. No exposures. |
|------|----|--|

| | | |
|--|----|--|
| | RL | During the repair of an air circulation valve, approximately 10 gallons of high-level radioactive waste solution were spilled onto the floor. Three employees, wearing protective clothing, were sprayed with droplets of the solution, but were readily decontaminated. Property damage \$19,746. |
|--|----|--|

| | | |
|--|----|--|
| | RL | Less than 5 grams of concentrated plutonium nitrate solution spilled on the elevator floor when a product receiver assembly overturned and the lid of the inner container came off. Cost for decontamination was \$13,443. No exposures. |
|--|----|--|

| | | |
|------|----|---|
| 1967 | AL | Abandoned storage vessels inside a stainless steel glovebox were being flushed with 7-9N nitric acid to recover plutonium nitrate. During this operation, the air monitor alarmed, and the odor of nitric oxide fumes was detected. Shortly thereafter, a puddle of dark liquid (plutonium nitrate solution) was seen on the floor under the glovebox. The solution had leaked from one of the storage vessels into the glovebox well and thence onto the floor of the room. 3 contaminated personnel were readily decontaminated by showering; the cost for decontamination of the storage vessel area was \$16,465. |
|------|----|---|

5. Waste and Product Storage (Continued)

Year Reporting AEC
Field Office

1967 SR

Radioactive liquid waste was stored in an underground tank. The pipeline for the concentrate entered the storage tank through a shielded riser, extending from the top of the tank to approximately one foot above ground. Access plugs were sealed with mastic compounds. The inlet pipe entered the riser horizontally below ground and terminated with a valve near the center of the riser. When the riser became plugged with concentrate crystals below the inlet line, the liquid flow reversed and forced its way through the access plugs. Approximately 13 curies of radioactive liquid waste, primarily cesium, were released to plant streams but sampling showed that radioactivity concentration standards were not exceeded in streams beyond the plant boundary. The cost for decontamination of ground in the vicinity of the tank was \$49,179. No exposures.

1969 SR

Approximately 20 millicuries of airborne radioactive contamination (mostly curium-244) were released via an exhaust stack and were spread by a northeasterly wind across the roof of a building and along a line leading from the main entrance of the building to a parking lot. The level of radioactivity on the roof was 4×10^7 d/m/100cm² and on vehicles inside the area fence 1.5×10^4 d/m/100cm². The highest level of activity outside the area was approximately 5000 d/m/100cm². All activity was contained within the plant's boundary. The cost for decontamination was \$37,506. No radiation exposures.

SR

Acidic waste solution (approximately 8200 pounds), which was being processed for neptunium-237 and plutonium-238 recovery, was lost when inadvertently transferred to an underground waste system due to a leaking valve in the stream supply to a transfer jet. Property damage \$32,000. No exposures.

5. Waste and Product Storage (Continued)

| <u>Year</u> | <u>Reporting AEC Field Office</u> |
|-------------|---------------------------------------|
|-------------|---------------------------------------|

| | |
|------|----|
| 1970 | SR |
|------|----|

A solution containing 20 grams of curium-244 and americium-243 was transferred by mistake to the waste system. Property damage \$124,523. No exposures.

| | |
|--|----|
| | RL |
|--|----|

Minor cerium-cesium contamination resulted from a routine change of a stack filter in the 300 area. Over 200 employee's shoes were checked and none were found to be contaminated. Walkways and roadways were washed down; no radioactivity was found in surveys beyond the 300 area. No property damage; no exposures.

5. Waste and Product Storage (Continued)

Case History No. - Manufacturing Chemists Association

| | |
|------|--|
| 254 | Pressure Build-Up in Pfandler Kettle Operation |
| 298 | Collapse of 20,000 gallon S.S. Tank |
| 1088 | Implosion in Still During Cleaning Operation |
| 1498 | Gross Leakage of Plutonium Nitrate Solution from Stored Polyethylene Bottles |
| 1716 | Dry Radioactive Waste Unloading Incident - Localized Radioactive Dust Escape |

6. Natural Phenomena

| <u>Year</u> | <u>Reporting AEC Field Office</u> | |
|-------------|---------------------------------------|---|
| 1959 | OR | Lightning damaged transformer. Property damage \$6,500. No exposures. |
| | SR | Lightning damaged two 750 KVA transformers. Property damage \$13,750. No exposures. |
| | LAR | Wind damage to aluminum side wall of building. Property damage \$7,500. No exposures. |
| | SR | Hurricane damaged water dam. Property damage \$50,000. No exposures. |
| 1960 | SR | During an electrical storm, lightning struck two 200-hp pump motors in an out-of-door pump pit. \$6,000 cost for rewinding of burned out motors. No exposures. |
| | OR | During violent storm, severe power system disturbance caused oil circuit breaker failure. Property damage \$18,132. No exposures. |
| | AL | High-velocity winds caused circuit breaker failure in substation, resulting in fire readily controlled by fire extinguisher. Property damage \$8,200. No exposures. |
| 1963 | PNR | Severe winds during electrical storm damaged roofs, stacks, ventilation ducts, trees and fences. Property damage \$9,400. No exposures. |
| 1965 | CH | Four transformers were damaged by lightning. Property damage \$35,000. No exposures. |
| | CH | Lightning caused the destruction of a breaker and the burning of a cubicle. Property damage \$8,000. No exposures. |
| | AL | Repeated lightning strikes damaged transformers. Property damage \$5,400. |

6. Natural Phenomena

| <u>Year</u> | <u>Reporting AEC Field Office</u> | |
|-------------|---------------------------------------|--|
| 1966 | AL | Roofing destroyed by high winds. Property damage \$47,000. No exposures. |
| 1967 | AL | A severe wind and hailstorm, with winds in the range of 80 to 100 miles per hour and hailstones the size of oranges, caused extensive roof and other structural damage to numer- ous buildings, disrupted utilities, demolished a warehouse wall, leveled security fencing and caused severe vehicle damage. Property damage \$1,872,000. No exposures. |
| 1970 | SR | Water supply lines, drainlines and traps, water-jacketed equipment, heating and cooling coils, instruments, gages, and fire sprinkler lines froze in numerous plant locations during a period of extremely low temperatures, unusual and unexpected in the area. Property damage \$38,200. No exposures. |

U.S. ENVIRONMENTAL PROTECTION AGENCY

Washington, D.C. 20460

OFFICIAL BUSINESS

Return this sheet to above address, if you
do NOT wish to receive this material ☐
or if change of address is needed ☐ (indi-
cate change, including ZIP code).



POSTAGE AND FEES PAID
U.S. ENVIRONMENTAL PROTECTION
AGENCY

EPA-335

THIRD CLASS BULK RATE