

SN 16544.010

Test Number FA-7

Union Carbide Corporation
Ferroalloys Division
Ashtabula, Ohio

by

T. E. Eggleston/R. N. Allen

June 1972

RESOURCES RESEARCH, INC.

A SUBSIDIARY OF TRW INC.

WESTGATE PARK • 7600 COLSHIRE DRIVE • McLEAN, VIRGINIA 22101

Contract Number CPA 70-81

SN 16544.010

Test Number ~~72~~ 72-PC-07

Union Carbide Corporation

Ferroalloys Division

Ashtabula, Ohio

by

T. E. Eggleston/R. N. Allen

June 1972

Resources Research, Inc.
A Subsidiary of TRW Inc.
Westgate Park
7600 Colshire Drive
McLean, Virginia 22101

Contract Number CPA 70-81

I. TABLE OF CONTENTS

	Page
II. INTRODUCTION	3
III. SUMMARY OF RESULTS, Part I	6
SUMMARY OF RESULTS, Part II	14
IV. PROCESS DESCRIPTION	20
V. LOCATION OF SAMPLING POINTS	24
VI. PROCESS OPERATION	30
VII. SAMPLING PROCEDURES	31
VIII. DISCUSSION, Part I	32
A. Results	32
B. Operating Conditions	34
C. Test Conditions	35
DISCUSSION, Part II	40
A. Results	40
B. Operating Conditions	41
C. Test Conditions	42
IX. APPENDIX	45
A. Complete Particulate Results with Example Calculations	
B. Complete Gaseous Results with Example Calculations	
C. Complete Operation Results	
D. Field Data	
E. Sampling Procedures	
F. Laboratory Report	
G. Test Logs	
H. Related Reports	
I. Project Participants and Titles	

LIST OF TABLES

<u>Table No.</u>	<u>Title</u>	<u>Page</u>
1.	Furnace 20 - Overall Emissions and Collection Efficiency	6
2.	Furnace 20 - Summary of Results - Hood Exhaust	8
3.	Furnace 20 - Summary of Results - Tapping Exhaust	11
4.	Furnace 20 - Summary of Results - Scrubber Exhaust	12
5.	Scrubber Water Solids	13
6.	Furnace 13- Overall Emissions and Collection Efficiency	14
7.	Furnace 13 - Summary of Results - Hood Exhaust	16
8.	Furnace 13 - Summary of Results - Tapping Exhaust	18
9.	Furnace 13 - Summary of Results - Scrubber Exhaust	19

LIST OF FIGURES

<u>Figure No.</u>	<u>Title</u>	<u>Page</u>
1.	Block Diagram - Sample Locations	5
2.	Process Flow Diagram - Furnace 20	21
3.	Process Flow Diagram - Furnace 13	22
4.	Furnace 20 - Sample Location Layout	26
5.	Furnace 20 - Sample Point Locations	27
6.	Furnace 13 - Sample Location Layout	28
7.	Furnace 13 - Sample Point Locations	29

II. INTRODUCTION

Source emission tests are being performed on a series of electric furnace installations, known as reactive metals or ferroalloys, for the Office of Air Programs, Environmental Protection Agency. This report covers the tests performed at the Union Carbide Corporation Plant, Ashtabula, Ohio during the weeks of February 14-25, 1972. The tests at these facilities include grain loading measurements and carbon monoxide determinations.

Emissions for this particular plant were determined for a 50 percent ferro silicon furnace (#20) and a calcium carbide furnace (#13). These units have similar collection and abatement equipment with gases being taken directly from the furnace cover into high pressure drop scrubbers (#20 , Chemico Venturi; #13, Buffalo Forge). In addition, each furnace is equipped with a fugitive fume hood located over the furnace, to which is connected several ducts which carry the gases directly to the atmosphere. A separate hood and duct system carried tapping fumes directly to the atmosphere.

In each installation the scrubber exhaust was provided with one port for sampling. The fugitive fume hood ducts had four ports spaced for equal area sampling. The tapping exhaust had one port. The circular scrubber exhaust is 14 inches in diameter. The ducts venting the fugitive fume hood varies in size, but are all approximately 4 feet x 4 feet. The

tapping exhausts are 52 inch diameter circular ducts. Sample point locations for both furnaces are shown in Figure 1. Further detailed diagrams and descriptions are included in Sections IV and V (Process Description and Location of Sampling Points).

Three samples were taken at each sampling location. Since no scrubber inlet sampling points were accessible or satisfactory, water samples were taken from the scrubber discharges for solids analysis, to determine collection efficiency.

During these surveys particulate matter was sampled using a standard EPA train as described in Appendix E-1. Combustion gases were measured using an Orsat analyzer. Carbon monoxide was determined by using a continuously indicating infrared analyzer. The overall survey for the two furnaces included 36 particulate emission runs, 5 Orsat measurements, 7 scrubber water samples, and continuous carbon monoxide measurements at 4 locations for a total period of 4-1/2 hours.




Figure 1. BLOCK DIAGRAM - SAMPLE LOCATIONS
FURNACE NOS. 20 & 13

III. SUMMARY OF RESULTS

(Part I - Furnace No. 20)

Shown below, in Table 1, are the results and averages for testing emissions from Furnace 20, along with corresponding collection efficiency, using the complete EPA sample train.

TABLE 1

Overall Summary of Emissions and Collection Efficiency

<u>Date</u>	<u>Run No.</u>	<u>Location</u>	<u>Filterable Particulate lbs/hr</u>	<u>Total Particulate lbs/hr</u>	<u>Average Total lbs/hr.</u>	<u>Percent Efficiency</u>
2/15/72	One	Hood	* 86.1	* 95.7		
2/16/72	Two	Hood	569.2	602.5	429.4	None
2/16/72	Three	Hood	457.7	516.5		
2/16/72	Four	Hood	136.1	169.1		
2/17/72	One	Scrubber	—	86.1	35.2	88.
2/17/72	Two	Scrubber	—	11.2		
2/17/72	Three	Scrubber	—	8.29		
2/17/72	One	Tapping	100.9	105.2	90.8**	None
2/17/72	Two	Tapping	55.2	76.6		
2/18/72	Three	Tapping	89.6	90.7		
2/17/72	One	Scrubber Water	—	278.4	248.3	—
2/17/72	Two	Scrubber Water	—	218.2		

* Two of three ducts sampled, NOT USED in percent efficiency.

** Tapping normally occurs only for about 15 minutes during each 75-90 minute cycle.

Some rather wide variations in results were experienced. This is felt to have been the result of several factors, including process operation.

The relatively poor overall performance of the scrubbers is influenced by two factors. Kerosine is injected in the gas stream prior to the blower and was thus measured as an emission. The primary reason, however, is the loss of fumes directly to the atmosphere. The scrubber is 88% efficient on those fumes that are routed to it, but only 39% of the total furnace fumes/hour are routed to the control system, thus the overall efficiency is only 34%.

The relatively poor efficiency of the scrubbers includes an emission of kerosine that is injected into the gas stream prior to the blower. Due to the loss of fumes directly to the atmosphere, from the hood ducts, the overall efficiency of the furnace fume collection (excluding tapping) was only 34.8 percent.

Particulate emission summaries for Furnace 20 are shown in Tables 2 through 4 on the following pages. Table 5 shows the results for total particulate in the scrubber water effluent. Flue gas conditions are included, and percent particulate matter in the impinger train has been calculated where possible.

Flue gas conditions appeared stable in the scrubber exhaust, but varied widely at other locations. Carbon monoxide levels in the south hood duct were rather variable. The general range was 50-75 ppm, with peaks to 130 ppm. Fume capture of the hood was estimated to be greater than 95 percent but the tapping exhaust was only about 75 percent. The reliability of results was considered to be only fair.

TABLE 2

Furnace 20 SUMMARY OF RESULTS North Duct From Fugitive Fume Hood

Run Number	NHE-1	NHE-2	NHE-3	NHE-4		
Date	2-15-72	2-16-72	2-16-72	2-16-72		
Stack Flow Rate - SCFM * dry	50003	51327	47977	54208		
% Water Vapor - % Vol.	.78	.23	1.12	.99		
% CO ₂ - Vol % dry	.20	.20	.20	.20		
% O ₂ - Vol % dry	20.60	20.60	20.60	20.60		
% Excess air @ sampling point	4409	4409	4409	4409		
SO ₂ Emissions - ppm dry	NA	_____	_____	_____		
NO _x Emissions - ppm dry	NA	_____	_____	_____		
<u>Particulates</u>						
<u>Probe, Cyclone, & Filter Catch</u>						
gr/SCF* dry	.0948	.4231	.0543	.0776		
gr/CF @ Stack Conditions	.0831	.3584	.0438	.0699		
lbs./hr.	40.6	186.1	22.3	36.0		
Particulate from impinger train (% of total)	8.1	6.1	52.9	30.0		
<u>Total Catch</u>						
gr /SCF * dry	.1032	.4507	.1154	.1108		
gr /CF @ Stack Conditions	.0905	.3818	.0931	.0998		
lbs./hr.	44.2	198.3	47.4	51.5		

* 70°F, 29.92" Hg

TABLE 2 (con't)

Furnace 20 SUMMARY OF RESULTS Center Duct From Fugitive Fume Hood

Run Number	CHE-2	CHE-3	CHE-4			
Date	2-16-72	2-16-72	2-16-72			
Stack Flow Rate - SCFM * dry	54566	52086	55521			
% Water Vapor - % Vol.	.94	1.73	2.12			
% CO ₂ - Vol % dry	.20	.20	.20			
% O ₂ - Vol % dry	20.60	20.60	20.60			
% Excess air @ sampling point	4409	4409	4409			
SO ₂ Emissions - ppm dry	_____	_____	_____			
NO _x Emissions - ppm dry	_____	_____	_____			
<u>Particulates</u>						
<u>Probe, Cyclone, & Filter Catch</u>						
gr/SCF* dry	.3373	.3583	.0774			
gr/CF @ Stack Conditions	.3022	.3077	.0695			
lbs./hr.	157.7	159.9	36.8			
Particulate from impinger train (% of total)	4.3	15.1	28.1			
<u>Total Catch</u>						
gr /SCF * dry	.3525	.4223	.1076			
gr /CF @ Stack Conditions	.3159	.3626	.0966			
lbs./hr.	164.9	188.5	51.2			

* 70°F, 29.92" Hg

TABLE 2 (con't)

Furnace 20 SUMMARY OF RESULTS South Hood From Fugitive Fume Hood

Run Number	SHE-1	SHE-2	SHE-3	SHE-4		
Date	2-15-72	2-16-72	2-16-72	2-16-72		
Stack Flow Rate - SCFM * dry	48160	46570	43443	45208		
% Water Vapor - % Vol.	.72	.75	1.29	1.57		
% CO ₂ - Vol % dry	.20	.20	.20	.20		
% O ₂ - Vol % dry	20.60	20.60	20.60	20.60		
% Excess air @ sampling point	4409	4409	4409	4409		
SO ₂ Emissions - ppm dry	NA	—	—	—		
NO _x Emissions - ppm dry	NA	—	—	—		
<u>Particulates</u>						
<u>Probe, Cyclone, & Filter Catch</u>						
gr/SCF* dry	.1102	.5648	.7399	.1633		
gr/CF @ Stack Conditions	.0981	.4724	.5760	.1412		
lbs./hr.	45.5	225.4	275.5	63.3		
Particulate from impinger train (% of total)	11.6	5.8	1.8	4.7		
<u>Total Catch</u>						
gr /SCF * dry	.1247	.5996	.7537	.1713		
gr /CF @ Stack Conditions	.1110	.5015	.5867	.1481		
lbs./hr.	51.5	239.3	280.6	66.4		

* 70°F, 29.92" Hg

TABLE 3

Furnace 20 SUMMARY OF RESULTS Tapping Exhaust

Run Number	ATE-1	ATE-2	ATE-3			
Date	2-17-72	2-17-72	2-18-72			
Stack Flow Rate - SCFM * dry	31709	31216	30137			
% Water Vapor - % Vol.	.73	2.72	2.83			
% CO ₂ - Vol % dry	.02	.02	.02			
% O ₂ - Vol % dry	20.50	20.50	20.50			
% Excess air @ sampling point	3195	3195	3195			
SO ₂ Emissions - ppm dry	NA	_____	_____			
NO _x Emissions - ppm dry	NA	_____	_____			
<u>Particulates</u>						
<u>Probe, Cyclone, & Filter Catch</u>						
gr/SCF* dry	.3715	.2062	.3467			
gr/CF @ Stack Conditions	.3161	.1693	.2806			
lbs./hr.	100.9	55.2	89.6			
Particulate from impinger train (% of total)	4.1	28.0	1.3			
<u>Total Catch</u>						
gr /SCF * dry	.3872	.2865	.3512			
gr /CF @ Stack Conditions	.3295	.2353	.2842			
lbs./hr.	105.2	76.6	90.7			

* 70°F, 29.92" Hg

TABLE 4

Furnace 20 SUMMARY OF RESULTS Scrubber Exhaust

Run Number	ASE-1	ASE-2	ASE-3			
Date	2-17-72	2-17-72	2-17-72			
Stack Flow Rate - SCFM * dry	11,736	11,383	11,383			
% Water Vapor - % Vol.	0	2.51	2.55			
% CO ₂ - Vol % dry	1.5	1.5	1.5			
% O ₂ - Vol % dry	6.0	6.0	6.0			
% Excess air @ sampling point	25	25	25			
SO ₂ Emissions - ppm dry	NA	—	—			
NO _x Emissions - ppm dry	NA	—	—			
<u>Particulates</u>						
<u>Probe, Cyclone, & Filter Catch</u>						
gr/SCF* dry	0.667	0.088**	0.062**			
gr/CF @ Stack Conditions	0.618	0.079**	0.056**			
lbs./hr.	67.09	8.58**	6.05**			
<u>Total Catch</u>						
gr /SCF * dry	0.856	0.115	0.085			
gr /CF @ Stack Conditions	0.913	0.119	0.088			
lbs./hr.	86.1	11.2	8.25			

*70°F, 29.92" Hg

**Filter After Silica Gel Impinger

TABLE 5
Solids In Scrubber Water Effluent

Furnace No. 20

Location	Date	Time	<u>lbs solids</u> <u>gallon</u>	Water Flow, GPM	<u>lbs solids</u> <u>hour</u>	Furnace Total
North Scrubber	2-17-72	1400-1420	1.636×10^{-3}	422	41.4	278.4*
South Scrubber	2-17-72	1400-1420	1.308×10^{-2}	302	237.0	
North Scrubber	2-17-72	1545-1630	4.557×10^{-3}	422	115.4	218.2*
South Scrubber	2-17-72	1545-1630	5.676×10^{-3}	302	102.8	

*See Discussion

Furnace No. 13

Location	Date	Time	<u>lbs solids</u> <u>gallon</u>	Water Flow, GPM	<u>lbs solids</u> <u>hour</u>
Scrubber	2-23-72	0900-0950	2.632×10^{-2}	450	710.6
Scrubber	2-24-72	1015-1105	3.003×10^{-2}	450	810.8
Scrubber	2-24-72	1525-1615	2.023×10^{-2}	450	546.2

SUMMARY OF RESULTS
(Part 2 - Furnace No. 13)

Shown below, in Table 6, are the results and averages of testing emissions from Furnace 13, along with corresponding collection efficiency, using the complete EPA sample train.

TABLE 6
Overall Summary of Emissions and Collection Efficiency

<u>Date</u>	<u>Run No.</u>	<u>Location</u>	<u>Filterable Particulate lbs/hr</u>	<u>Total Particulate lbs/hr</u>	<u>Average Total lbs/hr.</u>	<u>Percent Efficiency</u>
2/22/72	One	Hood	* 65.4	69.0	63.2	None
2/23/72	Two	Hood	46.5	57.9		
2/23/72	Three	Hood	49.9	68.5		
2/23/72	One	Scrubber	—	0.577	0.488	99.9
2/24/72	Two	Scrubber	—	0.423		
2/24/72	Three	Scrubber	—	0.464		
2/23/72	One	Tapping	52.4	53.6	49.7**	None
2/24/72	Two	Tapping	47.2	50.2		
2/24/72	Three	Tapping	44.4	45.2		
2/24/72	One	Scrubber Water	—	710.6	689.2	—
2/24/72	Two	Scrubber Water	—	810.8		
2/24/72	Three	Scrubber Water	—	546.2		

* Three of four ducts sampled, NOT USED in averages.
** Tapping continuously.

Fairly wide variations were noted in some of the results but this was expected due to the configuration of ducts and sample locations. The efficiency of the scrubber was excellent, but this result was not masked by kerosine, as with tests on Furnace 20. The overall furnace fume collection (excluding tapping exhaust) was 91.5 percent.

Particulate emission summaries for Furnace No. 13 are shown in tables on the following pages. Flue gas conditions are included, and percent particulate matter in the impinger train has been calculated where possible. Table 5 shows the results for total particulate in the scrubber water effluent.

Flue gas conditions were stable in the scrubber exhaust, but were very erratic and unstable at other locations. Carbon monoxide levels, in the hood duct measured, were extremely variable across the area of the traverse. They ranged from 50 ppm, to greater than 500 ppm. The tapping exhaust was more stable and was generally in the range of 35 ppm, with occasional peaks to 150 ppm. Fume capture was greater than 95 percent for the entire system.

TABLE 7

Furnace 13 SUMMARY OF RESULTS Fugitive Fume Hood Ducts (Northeast, Northwest)

Run Number	NEH-1	NEH-2	NEH-3	NWH-1	NWH-2	NWH-3
Date	2-22-72	2-23-72	2-23-72	2-22-72	2-23-72	2-23-72
Stack Flow Rate - SCFM * dry	11483	11990	13363	63573	61544	61761
% Water Vapor - % Vol.	.31	.52	1.06	.37	.19	.62
% CO ₂ - Vol % dry	1.00	1.00	1.00	1.00	1.00	1.00
% O ₂ - Vol % dry	20.70	20.70	20.70	20.70	20.70	20.70
% Excess air @ sampling point	16197	16197	16197	16197	16197	16197
SO ₂ Emissions - ppm dry	NA	_____	_____	_____	_____	_____
NO _x Emissions - ppm dry	NA	_____	_____	_____	_____	_____
<u>Particulates</u>						
<u>Probe, Cyclone, & Filter Catch</u>						
gr/SCF* dry	.1609	.0792	.0791	.0374	0.0180	.0205
gr/CF @ Stack Conditions	.1456	.0758	.0722	.0343	0.0170	.0190
lbs./hr.	15.8	8.1	9.1	20.4	9.5	10.8
Particulate from impinger train (% of total)	2.1	8.1	7.7	9.4	7.2	12.8
<u>Total Catch</u>						
gr /SCF * dry	.1644	.0862	.0857	.0413	.0194	.0235
gr /CF @ Stack Conditions	.1487	.0825	.0783	.0378	.0183	.0219
lbs./hr.	16.2	8.9	9.8	22.5	10.2	12.5

* 70°F, 29.92" Hg

TABLE 7 (con't)

Furnace 13 SUMMARY OF RESULTS Fugitive Fume Hood Ducts (Southeast, Southwest)

Run Number	SEH-2	SEH-3	SWH-1	SWH-2	SWH-3	
Date	2-23-72	2-23-72	2-22-72	2-23-72	2-23-72	
Stack Flow Rate - SCFM * dry	33383	31652	67973	64308	60239	
% Water Vapor - % Vol.	.59	.53	.14	.06	.73	
% CO ₂ - Vol % dry	1.00	1.00	1.00	1.00	1.00	
% O ₂ - Vol % dry	20.70	20.70	20.70	20.70	20.70	
% Excess air @ sampling point	16197	16197	16197	16197	16197	
SO ₂ Emissions - ppm dry	NA	_____	_____	_____	_____	
NO _x Emissions - ppm dry	NA	_____	_____	_____	_____	
<u>Particulates</u>						
<u>Probe, Cyclone, & Filter Catch</u>						
gr/SCF* dry	.0460	.0366	.0502	.0285	.0390	
gr/CF @ Stack Conditions	.0457	.0357	.0508	.0295	.0389	
lbs./hr.	13.2	9.9	29.2	15.7	20.1	
Particulate from impinger train (% of total)	9.8	4.4	3.5	35.1	43.7	
<u>Total Catch</u>						
gr /SCF * dry	.0510	.0383	.0520	.0439	.0693	
gr /CF @ Stack Conditions	.0506	.0373	.0526	.0454	.0692	
lbs./hr.	14.6	10.4	30.3	24.2	35.8	

* 70°F, 29.92" Hg

TABLE 8

Furnace 13 SUMMARY OF RESULTS Tapping Exhaust

Run Number	BTE-1	BTE-2	BTE-3			
Date	2-23-72	2-24-72	2-24-72			
Stack Flow Rate - SCFM * dry	29613	29011	27590			
% Water Vapor - % Vol.	.38	1.12	3.75			
% CO ₂ - Vol % dry	1.00	1.00	1.00			
% O ₂ - Vol % dry	20.80	20.80	20.80			
% Excess air @ sampling point	1733333	1733333	1733333			
SO ₂ Emissions - ppm dry	NA	_____	_____			
NO _x Emissions - ppm dry	NA	_____	_____			
<u>Particulates</u>						
<u>Probe, Cyclone, & Filter Catch</u>						
gr/SCF* dry	.2066	.1897	.1877			
gr/CF @ Stack Conditions	.1858	.1660	.1539			
lbs./hr.	52.4	47.2	44.4			
Particulate from impinger train (% of total)	2.2	6.0	1.9			
<u>Total Catch</u>						
gr /SCF * dry	.2113	.2018	.1914			
gr /CF @ Stack Conditions	.1900	.1766	.1569			
lbs./hr.	53.6	50.2	45.2			

* 70°F, 29.92" Hg

TABLE 9

Furnace 13 SUMMARY OF RESULTS Scrubber Exhaust

Run Number	BSE-1	BSE-2	BSE-3			
Date	2-23-72	2-24-72	2-24-72			
Stack Flow Rate - SCFM * dry	1585	1585	1585			
% Water Vapor - % Vol.	1.83	1.28	0.98			
% CO ₂ - Vol % dry	1.5	1.5	1.5			
% O ₂ - Vol % dry	6.0	6.0	6.0			
% Excess air @ sampling point	12.5	12.5	12.5			
SO ₂ Emissions - ppm dry	_____	_____	_____			
NO _x Emissions - ppm dry	_____	_____	_____			
<u>Particulates</u>						
<u>Probe, Cyclone, & Filter Catch</u>						
gr/SCF* dry	0.040	0.020	0.031			
gr/CF @ Stack Conditions	0.037	0.019	0.029			
lbs./hr.	0.533	0.266	0.413			
<u>Total Catch</u>						
gr /SCF * dry	0.0425	0.0311	0.0342			
gr /CF @ Stack Conditions	0.0449	0.0328	0.0361			
lbs./hr.	0.577	0.423	0.464			


* 70°F, 29.92" Hg

IV. PROCESS DESCRIPTION

Ferroalloys and calcium carbide are produced in submerged arc electric furnaces. The facilities under consideration in this report are semi-closed furnaces, with covers, hooding and scrubber cleaning systems to reduce the emission of fumes and dust following collection. Figures 2 and 3 are process flow diagrams indicating the actual furnaces under test in this survey.


The electric arc is employed as a concentrated source of heat. Appropriate ores are added to the surface of the furnace through mechanized equipment and chutes. Additional carbon in the form of coke, wood chips, etc., is an integral part of the furnace mixes, along with specialized fluxes, etc. The mix for Furnace 20 is gravity fed from chutes to the semi-covered furnace through an annular space around the electrodes. There is no mechanical stoking for this furnace design.

The very high temperatures produced initiate a reaction in the bottom of the furnaces and form a layer of metal which is tapped at appropriate times. As the ores and carbonaceous materials gradually settle to the bottom of the furnace, the heat, in conjunction with a lack of oxygen, react with the oxide ores in order to remove oxygen and thus produce the elemental metal. The units under examination in this survey were semi-closed units where the gases containing carbon monoxide were recovered and passed through high energy water scrubbing systems. However, some gas escaped and burned around each of the electrodes.



*Sample Points

Figure 2. PROCESS FLOW DIAGRAM FURNACE 20 (SIDE VIEW)



NOTE: NEH & SEH hoods have SWH & NWH hoods located immediately behind them.

*Sample Points

Figure 3. PROCESS FLOW DIAGRAM NO. 13 FURNACE (SIDE VIEW)

Furnace 20 is designed for a nominal 40 to 50 megawatt load, and produces hard cast 50 percent ferro silicon metal using Soderburg type electrodes. Gases and fumes from normal operation are passed through two Chemico Venturi scrubbers at pressure drops of 70-80 inches of water. Fumes missed by this collection system are picked up by a secondary hood, and passed directly to the atmosphere.

Tapping fumes are collected by a separate hood and exhausted to the atmosphere. The furnace is tapped for about 15 minutes per cycle of 1 hour-15 minutes to 1 hour-30 minutes. Molten metal and slag pour into ladles, and the fumes produced in this operation are drawn off by the separate tapping exhaust system. The slag is removed from the ladle and disposed of by various means. Molten product is poured into molds, after which it is broken into usable sizes.

Furnace 13 is a unit of some 24 megawatt capacity and produces 80-85% grade calcium carbide using prebaked electrodes. The fume collection system is similar to that on Furnace 20 except that the scrubber system is a pair of parallel Buffalo Forge scrubbers, with only one on line, and one as spare. The tapping operation is continuous and the hood over this area directs all fumes directly to the atmosphere. The molten product pours directly into molds, is cooled, and dumped from the molds in an automatic operation.

V. LOCATION OF SAMPLING POINTS

Sample ports were selected during a presurvey inspection trip, and approved by the EPA Project Officer. As described below, most locations were chosen not by normal criteria, but rather because they were the only possible or usable locations.

Furnace 20

Furnace 20 emission streams included one scrubber exhaust sample location with a single port, three hood duct sample points having four ports each, one tapping exhaust duct with a single port, and two water collection points in the scrubber sump area. The scrubber port was in the middle of a long straight run of pipe. Due to the high pressure and high carbon monoxide content in this stack, a sealed port/probe assembly was constructed. Only one point was sampled.

The three hood ducts were each provided with four ports, spaced for equal area sampling, with six equal area points sampled per port. A total of 24 equal areas were sampled per duct. These locations were the only possible points available, but were located only 1 or 2 equivalent diameters downstream from the hood inlets. There was a long straight run after the sample points although axial flow fans were only about ten feet above the test location.



The tapping exhaust stack had one sample port, and twelve equal area points were sampled. This location was in a short straight section

between two approximately 30° bends. Only the scrubber exhaust location met the normal EPA criteria for sample point location. Water samples were taken before and after the weir in the scrubber sump area. Figures 4 and 5 show dimensions and details for these locations.

Furnace 13

Furnace 13 emission flows included one scrubber exhaust sample port, which was essentially identical in location to its counterpart on Furnace 20. There were four hood duct sample locations each having four ports, one tapping exhaust location with a single port, and one water collection location in the scrubber sump area. Each of the hood duct ports was sampled at six equal area points for a total of 24 equal areas sampled per duct. Ports were placed in the only usable locations, which were less than one equivalent diameter from an upstream expansion and/or bend and only one or two diameters from downstream bends and fans. The tapping exhaust sample port was located in a straight section between two approximately 30° bends, both within two stack diameters of the test port. Water samples were taken after the weir in the sump area. Figures 6 and 7 show the physical conditions at these locations.


ATE
TAPPING
EXHAUST DUCT



PLAN VIEW


ASE
SCRUBBER
EXHAUST

Figure 4. FURNACE 20 SAMPLE LOCATION LAYOUT



SIDE VIEW OF FUGITIVE FUME HOOD DUCTS

TOP VIEW - TAPPING EXHAUST



TOP VIEW - SCRUBBER EXHAUST




Figure 5. SAMPLE POINT LOCATIONS NO. 20 FURNACE






Figure 6. FURNACE 13 SAMPLE LOCATION LAYOUT



SIDE VIEW = FUGITIVE FUME HOOD DUCTS

TOP VIEW - TAPPING EXHAUST



TOP VIEW - SCRUBBER EXHAUST




Figure 7. SAMPLE POINT LOCATIONS NO. 13 FURNACE

VI. PROCESS OPERATION

All sampling was carried out while the processes were believed to be running normally. There were periods with furnace "blows" or minor process load variations but these are normal conditions and are rapidly corrected.

Appendix C tabulates the available operating data. There were some fluctuations in the furnace loads during testing, but these were considered to be within normal operating conditions. Tapping was conducted as often as necessary, depending upon the total power input to Furnace 20; and continuously for Furnace 13.

VII. SAMPLING PROCEDURES

Test methods were in accordance with standard methods as published in the Federal Register, Volume 36, Number 159, Part II, August 17, 1971. See Appendix E for pertinent sections of this publication.

Deviations from the above methods were as follows.

1. With the exception of the ASE and BSE locations, sample port locations did not meet location criteria.
(Reason: Used only available locations.)
2. At the ASE location, sample times were 30 minutes or less at a single point, with no pitot or temperature traverse. For samples ASE-2 & 3, the filter was placed after the silica gel impinger.
(Reason: The location and equipment available necessitated the above actions.)
3. Sampling time at the tapping exhausts (ATE & BTE) was approximately 15 minutes.
(Reason: Covered tapping period of one furnace cycle, fumes not being emitted during remainder of cycle.)
4. Sampling time was reduced to less than 2 hours on all fugitive fume hood samples except NHE-1, CHE-1 and SHE-1.
(Reason: Necessary to conform to furnace schedule and available sampling time.)

Carbon monoxide was sampled directly into an MSA Lira Model 200* infra-red analyzer and results were recorded continuously on a strip chart recorder.

It was impossible to obtain samples of gases and fumes prior to the scrubbers. Composite samples of water effluent were therefore obtained from each scrubber, along with inlet water to the system.

*Mention of a specific company or product does not constitute endorsement by EPA.

VIII. DISCUSSION

(Part I - Furnace No. 20)

A. RESULTS

Collection Efficiency (#20)

If collection efficiency is based upon total emissions from the furnace (except tapping fumes), the collection efficiency for this unit is computed to be approximately 35%. The results used to compute this figure varied widely from point to point, and from sample to sample.

Scrubber efficiency, based only on the scrubber water effluent solids and the scrubber exhaust samples, is considerably higher, averaging 88%. The true efficiency is probably higher due to two factors. One of three exhaust samples is significantly higher than the others and raises the average emission from 9.8 lbs/hr to 35.2 lbs/hr. Probably the most significant factor is that kerosine is introduced into the gas stream as part of the normal process, and is therefore captured by the sample train and measured as a particulate emission.

It is conceivable that the blank collected for No. 20 furnace scrubber is in error. It is unusually high, and the blank from No. 13 furnace scrubber is considerably lower. If the blank from No. 13 furnace is used, the solids removal average becomes 493 lbs/hour, which raises the average scrubber efficiency to 93 percent.

Emissions (#20)

Emissions from the overall process were high due to poor capture of fumes by the primary cover as shown in Figure 2. This left large amounts of fumes to be collected by the hood, which exhausted directly to the atmosphere. The overall fume capture for the furnace, except the tapping fumes, appeared to be greater than 95 percent at all times.

Sample results of emissions from the scrubber are believed to be high because of the kerosine injection. The first sample, ASE-1, was immediately clogging, therefore the regular glass fiber filter was moved for future scrubber samples. Instead of being placed prior to the impinger train it was placed after the silica gel impinger. This is probably the reason for the large drop in particulate results after the initial sample.

Particulate Versus Total Catch (#20)

No inlet gas samples were taken so that the percent condensibles could be determined at the scrubber location. Three tapping exhaust samples averaged 11% and ranged from approximately 1% to 28% condensibles. Percent condensibles in the eleven hood samples ranged from 2% to 53% and averaged 15%. Because of the configuration of the sampling train the scrubber exhaust fractions could not be measured separately. An oily residue in the samples of the fugitive fume escaping from around the electrodes may explain part of the variation encountered. This material has not been noticed in any previous sampling of open furnace emissions. It is postulated that some sort of destructive distillation from incomplete combustion may be taking place as mix is placed around the electrode opening.

Flue Gas Conditions (#20)

Flue gas measurements were variable on the hood and tapping exhausts, but not extremely so.

Gaseous Emissions (#20)

As has been noted in the past, the hood gases had low carbon dioxide and high oxygen concentrations due to dilution. Results were indicative only for measurement of system leakage.

Low level carbon monoxide measurements in the hood exhausts were relatively low with occasional peaks, probably due to normal process variations.

Gases collected by the cover, and scrubbed by the venturi, however, were very low in carbon dioxide due to lack of combustion. The carbon monoxide level was well above the calibrated scale of the Orsat, and at Furnace 13 was estimated to be approximately 65 percent.

B. OPERATING CONDITIONS

Scrubber System (#20)

During the test period ASE-1 the north scrubber effluent water had a very low solids content, while water leaving the south scrubber had a very high solids content. During the test period ASE-2 the solids content was close to equal. During both tests, however, the average was similar. This would indicate that some operational variation was involved. With both gaseous effluents going into the common exhaust stack, this should

not be expected to create any problem with results. No ASE-3 samples were available.

Furnace No. 20

Considerable down time was experienced with this furnace, but no shutdowns occurred during actual testing. Furnace load varied from 40,000 kw to 52,000 kw during the testing. These load variations were said to be typical of the operation of this furnace. Although the load variations, etc. may have been perfectly normal, it is suspected that the poor duplication of results was largely due to changes in furnace operation. Sampling locations, and conditions, were far worse at Furnace 13 but the uniformity of results was much better.

Each sample run on the hood exhausts was carefully scheduled to include one tapping cycle near the middle of that test period.

C. TEST CONDITIONS

Safety (#20)

Due to the nature of the operation, and the indoor location of the sampling locations, a potential hazard of carbon monoxide build-up was present. This condition was monitored both by Union Carbide and RRI personnel.

The only location to experience levels in excess of 50 ppm CO (A.C.G.I.H. Threshold Limit Value) was the area of the scrubber sample port during sampling. This area was blocked off and monitored during testing, with one man constantly available to assist the operator, if needed, while he entered the area to take sample readings.

At the exhaust hood locations, an automatic hopper-type feed car was in operation within inches of our equipment at times. It therefore had to be watched, and special care taken, at all times.

Hood Ducts (#20)

The sample locations did not meet normal minimum EPA requirements. The ports were only one or two equivalent pipe diameters downstream from a bend in the duct. No preliminary temperature or velocity checks could be made due to the furnace being down prior to the first sample.

Some delay was encountered on sample CHE-1 while waiting for an experimental sampling device (being demonstrated for EPA) to finish at the port that was due to be sampled. In addition, all trains were shut down during the first sample in order to reduce filter plugging. Smaller nozzles were employed to reduce the sampling rate.

The first set of hood exhaust samples was repeated, after it was found that a heating element short of some kind had caused a cracked probe in sample CHE-1.

Tapping Duct (#20)

The tapping hood and ductwork did not appear to capture any more than 75 percent of escaping fumes during the tapping operation. At times, even less than this was captured.

Samples were taken only during tapping, and thus were limited to about 15 minutes duration. A twelve point traverse, at one minute per point, was conducted, with the points repeated until the tap was completed. The sample location was fair in that there was about one stack diameter upstream, and several diameters downstream, clear of bends or obstructions. Sampling rates were less than isokinetic during the first test due to too large a nozzle diameter. The nozzle had been selected on the basis of a preliminary velocity traverse, and was deliberately on the large side, to provide maximum sample volume in the short tapping period. Changes in flue gas conditions occurred so that a smaller nozzle was required, to achieve isokinetic conditions on subsequent tests.

Scrubber Exhaust (#20)

The scrubber exhaust presented a unique sampling situation. Exhaust gases contained carbon monoxide concentrations well in excess of 50 percent under a positive pressure of several pounds per square inch. In addition, kerosine vapors and droplets were mixed with these fumes.

Sampling was accomplished using a special, glass lined probe, friction-fitted into a steel plug, and sealed with a special pipe joint sealant. This assembly was then screwed into a long nipple attached to the exhaust stack, which was equipped with a gate valve. After sealing the probe, the gate valve was opened and the probe slipped into the gas stream. The probe was then attached to a standard sampling train.

After the first run, the filter was moved due to plugging, thus some particulate was probably trapped in the silica gel. Estimated flue gas

volume was used, as supplied by Union Carbide. A long straight section of stack on both sides of the sample port should have allowed reasonably good flow patterns for single, center point sampling. This was considered necessary because, the possibility of CO leaks endangering test personnel dictated that the probe not be moved any more than necessary.

Scrubber Water (#20)

Scrubber water flow rate data was supplied by Union Carbide. A water sample was not taken during Run No. 3 due to the non-availability of a Union Carbide gas man to escort the RRI sampler to the sample location. Composite water samples were taken in small amounts, at approximately five minute intervals during samples ASE-1 and 2, from each of the scrubber sump areas.

Power (#20)

No problems were encountered with lack of sufficient power during the tests on Furnace 20.

Filter Plugging (#20)

Filter plugging was a problem with the first test run on the hood exhaust ducts. Trains were shut down early in the run to change nozzles. The problem was not encountered thereafter. A possible cause was the oily like substance found in the impinger water (during analysis) of all the hood exhaust samples. Some were worse than others, but all had the residue. This oily substance also complicated the analyses, in that the samples were very difficult to stabilize in weight.

The filter in sample ASE-1, scrubber exhaust, plugged almost immediately. The cause was almost assuredly the high kerosine content in the stack gases which was injected into the blower to keep the vanes from fouling. The filter was removed as mentioned previously.

Miscellaneous (#20)

Due to lack of an appropriate location for equipment storage and preparation inside the plant buildings, a large van type truck was rented. This presented problems due to the cold weather encountered. Even with space heaters some freezing of liquids was encountered.

Handling of glassware was made difficult because the cold necessitated wearing gloves much of the time. Breakage was encountered, that was directly related to the cold working conditions.

One of the source sampling trains presented some minor mechanical problems in operation, but they were soon overcome.

DISCUSSION

(Part 2 - Furnace No. 13)

A. RESULTS

Collection Efficiency (#13)

Basing the collection efficiency on total emissions from the furnace (except tapping fumes) the efficiency of this unit was computed to be approximately 92%. Consideration must be given to the % fume that goes to the scrubber versus the total fumes. 86% of the fumes went to the scrubber. The actual scrubber, when considered alone, was very effective. The average calculated efficiency was 99.9%.

Emissions (#13)

Atmospheric emissions from this furnace were considerably lower than for Furnace 20. Although the power usage was only about half, this was a completely different product, and this furnace produced slightly more fumes. However, the cover and scrubber system was removing a greater share of the total dust load created by the furnace. Based upon emissions and water effluent solids Furnace 13 was producing a dust load of about 800 lbs/hr and Furnace 20 was producing about 700 lbs/hr. No. 20 scrubber emissions were ignored due to the high kerosine content.

The secondary hood appeared to be catching far less fumes which was most likely due partly to the charging method and the apparently good capture by the cover. Overall fume capture, including tapping, was very good.

Particulate Versus Total Catch (#13)

Results of Furnace 13 emissions were similar to those of Furnace 20, except that the tapping exhaust was more uniform, ranging from approximately 2% to 6% condensibles.

Flue Gas Conditions (#13)

Temperature and flow measurements on the tapping exhaust were stable but the velocity profile was variable. The hood exhausts displayed very wide and erratic changes in velocity and temperature, as explained in the Test Conditions section.

Gaseous Emissions (#13)

Orsat analysis was essentially the same as Furnace 20. An Orsat analysis was made of the scrubber exhaust gas to determine the approximate carbon monoxide content. This was off normal scale, in the range of 65%. This analysis was used in calculations for both furnaces.

Carbon monoxide gas from this process is either used for heating in the lime kiln, or burned when emitted to the atmosphere. The carbon monoxide emissions were low, with occasional peaks, in the tapping exhaust, but were very erratic and variable in the southeast hood duct. This is explained in the Test Conditions section of the Discussion.

B. OPERATING CONDITIONS

Scrubber System (#13)

No unusual conditions were observed or recorded.

Furnace No. 13

Very little down time was experienced with this furnace, and none was experienced during actual test periods. Furnace load was 21,500 kw to 24,000 kw. This was a continuous tap furnace, which would aid in producing a more uniform operation.

C. TEST CONDITIONS

Safety (#13)

Similar problems concerning carbon monoxide, as those experienced with Furnace 20, were experienced at this location. In addition, an overhead crane was operating over the hood and tapping exhaust sample locations. This required personnel to move each time it passed over.

Dust levels were extremely high in the hood and tapping exhaust sampling areas, frequently requiring the use of dust respirators.

Exposed electrodes were located within 3-5 feet of two of the hood exhaust sampling locations. This necessitated extreme care when in the area, especially when handling the metal jacketed pitobe assemblies.

Union Carbide had a man present at all times while RRI personnel were working in the operating areas of No. 13 furnace.

Hood Ducts (#13)

The hood duct sampling ports on this furnace were located in the only available locations. These locations were totally inadequate for good

representative sampling in ducts. Serious doubt must be expressed about the accuracy of these eleven samples in spite of the repeatability achieved.

The reasons given for this doubt are:

1. Many indications point to the uneven flow at these points.
2. Velocities were very erratic.
3. Positive, zero and negative velocities were experienced in close proximity to each other.
4. Temperatures varied widely from point to point, indicating an uneven, unmixed gas stream.
5. The carbon monoxide measurements on the southwest hood (Appendix B) graphically show the eddied, non-uniform nature of the stack gas.
6. In addition, some ports could not be reached due to pipes blocking access.

Sample ports on the northeast and southeast fugitive fume hood ducts were on a diagonal, thus requiring a platform of four different heights. The platforms supplied were very unstable. This, coupled with very close working quarters, contributed to one probe being broken at the southeast hood location and a corresponding loss of sample SEH-1. These conditions, combined with the safety factors previously mentioned, make these hood locations a "textbook example" of what sampling locations should not be.

Unfortunately there was no other choice, and, although the representativeness of the sample may be in some doubt, the reproducibility was much better than for Furnace 20.

Tapping Duct (#13)

The tapping duct location and operation, allowed normal sampling periods to be used at this location.

Scrubber Exhaust (#13)

The scrubber exhaust on Furnace 13 was identical to the one on Furnace 20. The only difference in procedure was that RRI personnel gathered flow data by a readout on the Union Carbide computer during the tests.

Scrubber Water (#13)

Scrubber water flow was supplied by Union Carbide. RRI personnel took measurements on the weir during the BSE test series that generally confirmed the numbers supplied, but the weir was very worn and pitted. Composite samples were collected as with No. 20 furnace scrubber.

Power (#13)

No problems were encountered with power during the tests on Furnace 13. However, an initial delay was incurred due to non-availability on the first day of testing.

Filter Plugging (#13)

No unusual conditions were encountered.

Miscellaneous (#13)

The problem of the cold cleanup and preparation area was overcome at this location by moving the van inside the building and renting an 85,000 BTU heater.

IX. APPENDIX

APPENDIX A
COMPLETE PARTICULATE RESULTS WITH EXAMPLE CALCULATIONS


EXAMPLE CALCULATION

% EFFICIENCY

#20 FURNACE SCRUBBER

$$\frac{\text{PARTICULATE REMOVED (B)}}{\text{TOTAL PARTICULATE EMISSIONS (A \& B)}} \times 100 = \% \text{ REMOVAL EFFICIENCY}$$

$$\frac{248.3 \text{ lb/hr}}{248.3 \text{ lb/hr} + 35.2 \text{ lb/hr}} \times 100 = 87.6\%$$



SAMPLE PARTICULATE CALCULATIONS
#20 FURNACE
SHE-1

1. Volume of dry gas sampled at standard conditions - 70°F, 29.92" Hg, ft³.

$$V_{m_{std}} = \frac{17.7 \times V_m \left(\frac{P_B + P_m}{13.6} \right)}{(T_m + 460)} = \text{Ft.}^3 =$$

$$\frac{17.7 \times 78.41 \left(28.90 + \frac{1.51}{13.6} \right)}{(88.4 + 460)} = 73.4$$

2. Volume of water vapor at 70°F and 29.92" Hg, Ft.³

$$V_{w_{gas}} = 0.0474 \times V_w = \text{ft.}^3$$

$$0.0474 \times 11.2 = 0.53$$

3. % moisture in stack gas

$$\%M = \frac{100 \times V_{w_{gas}}}{V_{m_{std}} + V_{w_{gas}}} = \%$$

$$\frac{100 \times 0.53}{73.4 + 0.53} = .72$$

4. Mole fraction of dry gas

$$M_d = \frac{100 - \%M}{100}$$

$$\frac{100 - .72}{100} = 0.993$$

5. Average molecular weight of dry stack gas

$$M W_d = (\%CO_2 \times \frac{44}{100}) + (\%O_2 \times \frac{32}{100}) + (\%N_2 \times \frac{28}{100})$$

$$(0.20 \times \frac{44}{100}) + (20.60 \times \frac{32}{100}) + (79.20 \times \frac{28}{100}) = 28.86$$

6. Molecular weight of stack gas

$$M W = M W_d \times M_d + 18 (1 - M_d)$$

$$28.86 \times 0.993 + 18(1-0.993) = 28.78$$

7. Stack velocity @ stack conditions, fpm

$$V_s = 4350 \times \sqrt{\frac{\text{AVERAGE}}{P_s \times M W}} \left[\frac{1}{P_s \times M W} \right]^{1/2} = \text{fpm}$$

$$4350 \times \sqrt{\text{Average}} \left[\frac{1}{28.90 \times 28.78} \right]^{1/2} = 3687$$

8. Stack gas volume @ standard conditions, SCFM

$$Q_s = \frac{0.123 \times V_s \times A_s \times M_d \times P_s}{(T_s + 460)} = \text{SCFM}$$

$$\frac{0.123 \times 3687 \times 2112 \times .993 \times 28.90}{(111 + 460)} = 48,160$$

9. Percent isokinetic

$$\%I = \frac{1032 \times (T + 460) \times V_{m \text{ STD}}}{V_s \times T_t \times P_s \times M_d \times (D_n)^2} = \%$$

$$\frac{1032 \times (111 + 460) \times 73.4}{3687 \times 120 \times 28.90 \times .993 \times (0.1875)^2} = 97\%$$

10. Particulate - probe, cyclone, and filter, gr/SCF

$$C_{an} = 0.0154 \times \frac{M_f}{V_{m \text{ std}}} = \text{gr/scf}$$

$$0.0154 \times \frac{525.4}{73.4} = 0.1102$$

11. Particulate total, gr/SCF

$$C_{ao} = 0.0154 \times \frac{M_t}{V_{m \text{ std}}} = \text{gr/SCF}$$

$$0.0154 \times \frac{594.6}{73.4} = 0.1247$$

12. Particulate - probe, cyclone and filter, gr/CF at stack conditions

$$C_{at} = \frac{17.7 \times C_{an} \times P_s \times M_d}{(T_s + 460)} = \text{gr/CF}$$

$$\frac{17.7 \times 0.1102 \times 28.90 \times .993}{(111 + 460)} = 0.0981$$

13. Particulate - total, gr/CF @ stack conditions

$$C_{au} = \frac{17.7 \times C_{ao} \times P_s \times M_d}{(T_x + 460)} = \text{gr/CF}$$

$$\frac{17.7 \times 0.1247 \times 28.90 \times .993}{(111 + 460)} = 0.1110$$

14. Particulate - probe, cyclone filter filter, lb/hr.

$$C_{aw} = 0.00857 \times C_{an} \times Q_s = \text{lb/hr.}$$

$$0.00857 \times 0.1102 \times 48,160 = 45.5$$

15. Particulate - total, lb/hr.

$$C_{ax} = 0.00857 \times C_{ao} \times Q_s = \text{lb/hr.}$$

$$0.00857 \times 0.1247 \times 48,160 = 51.5$$

16. % excess air at sampling point

$$\% \text{ EA} = \frac{100 \times \% \text{ O}_2}{(0.266 \times \% \text{ N}_2) - \% \text{ O}_2} = \%$$

$$\frac{100 \times 20.60}{(0.266 \times 79.20) - 20.60} = 4409$$

EXAMPLE CALCULATIONS

Scrubber Water Solids - Total Solids Collected

No. 20 North Scrubber

Sample NSW-1	10.59×10^{-4}	$\frac{\text{gms}}{\text{ml}}$	sample
less	8.63×10^{-4}	$\frac{\text{gms}}{\text{ml}}$	blank*
	1.96×10^{-4}	$\frac{\text{gms}}{\text{ml}}$	scrubbed from gas

$$1.96 \times 10^{-4} \frac{\text{gms}}{\text{ml}} \times 2.205 \times 10^{-3} \frac{\text{lbs}}{\text{gm}} \times \frac{1}{2.6418 \times 10^{-4} \frac{\text{gal}}{\text{me}}} = 1\text{bs/gallon}$$

$$1.96 \times 10^{-4} \times 8.347 = 0.001636 \text{ lbs/gallon}$$

422 gallons/minute Average flow**

$$422 \text{ gal/min} \times 0.001636 \text{ lbs/gal} \times 60 \text{ min/hr} = 41.42 \text{ lbs/hour removal}$$

$$41.42 \text{ lbs/hour} + 237.0 \text{ lbs hour (South Scrubber)} = 278.42$$

*Value unusually high and suspect.

**NOTE: Water flow supplied by Union Carbide.

NAME OF FIRM UNION CARBIDE

LOCATION OF PLANT -- ASHTABULA #20

TYPE OF PLANT REACTIVE METALS

CONTROL EQUIPMENT SCRUBBER

SAMPLING POINT LOCATIONS NORTH HOOD EXHAUST

POLLUTANTS SAMPLED TOTAL PARTICULATE

TIME OF PARTICULATE TEST

RUN NO NHE-1	DATE 2-15-72	BEGIN 1342	END 1702
RUN NO NHE-2	DATE 2-16-72	BEGIN 1100	END 1239
RUN NO NHE-3	DATE 2-16-72	BEGIN 1335	END 1450
RUN NO NHE-4	DATE 2-16-72	BEGIN 1648	END 1803

PARTICULATE EMISSION DATA

RUN NO.	NHE-1	NHE-2	NHE-3	NHE-4
PB BAROMETRIC PRESSURE INCHES HG ABSOLUTE	28.90	29.48	29.48	29.48
PM ORIFICE PRESSURE DROP, INCHES WATER	1.39	1.37	1.16	1.40
VM VOLUME OF DRY GAS SAMPLED AT METER CONDITIONS, CU.FT.	74.20	56.47	41.36	45.55
TM AVERAGE GAS METER TEMPERATURE, DEG. F	92.9	84.0	85.5	88.5
VMSTD VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS CU.FT.	68.9	54.4	39.7	43.5
VW TOTAL H2O COLLECTED ML., IMPINGERS AND SILICA GEL	11.4	2.7	9.5	9.2
VWGAS VOLUME OF WATER VAPOR COLLECTED. CU.FT. AT STANDARD CONDITIONS	.54	.13	.45	.44
PCTM PERCENT MOISTURE IN THE STACK GAS BY VOLUME	.78	.23	1.12	.99
MD MOLE FRACTION OF DRY GAS	.992	.998	.989	.990
PCTCO2 PERCENT CO2	.20	.20	.20	.20
PCTO2 PERCENT O2	20.60	20.60	20.60	20.60
PCTN2 PERCENT N2	79.20	79.20	79.20	79.20

MWD MOLECULAR WEIGHT OF DRY STACK GAS	28.86	28.86	28.86	28.86
MW MOLECULAR WEIGHT OF STACK GAS	28.77	28.83	28.73	28.75
DELPS VELOCITY HEAD OF STACK GAS, INCHES OF WATER	1.32	1.45	1.34	1.52
TS STACK TEMPERATURE, DEG.F.	117	151	176	110
DPS X (TS + 460)	27.59	29.60	29.01	29.36
PS STACK PRESSURE, IN. HG. ABSOLUTE	28.80	29.30	29.30	29.30
VS STACK VELOCITY AT STACK CONDITIONS, FPM	4170	4431	4350	4400
AS STACK AREA, SQ.IN.	1968	1968	1968	1968
QS STACK GAS VOLUME AT STANDARD CONDITON *SCFM	50003	51327	47977	54208
TT NET TIME OF TEST, MIN.	147	96	72	72
DN SAMPLING NOZZLE DIAMETER, IN.	.1875	.1875	.1875	.1875
PCTI PERCNT ISOKINETIC	67	78	82	80
MF PARTICULATE - PROBE CYCLONE AND FILTER, MG.	424.0	1493.4	139.9	219.1
MT PARTICULATE TOTAL, MG.	461.5	1590.8	297.3	312.8
CAN PARTICULATE PROBE CYCLONE AND FILTER GR/SCF	.0948	.4231	.0543	.0776
CAO PARTICULATE TOTAL GR/SCF	.1032	.4507	.1154	.1108
CAT PARTICULATE PROBE CYCLONE AND FILTER, GR/CF AT STACK COND	.0831	.3584	.0438	.0699
CAU PARTICULATE TOTAL GR/CF AT STACK COND	.0905	.3818	.0931	.0998

CAW PARTICULATE PROBE CYCLONE AND FILTER, LB/HR.	40.6	186.1	22.3	36.0
CAX PARTICULATE TOTAL LB/HR.	44.2	198.3	47.4	51.5
PCTEA PERCENT EXCESS AIR AT SAMPLING PT	4409	4409	4409	4409

[

NAME OF FIRM UNION CARBIDE

LOCATION OF PLANT -- ASTABULA #20

TYPE OF PLANT REACTIVE METALS

CONTROL EQUIPMENT SCRUBBER

SAMPLING POINT LOCATIONS CENTER HOOD EXHAUST, A TAPPING EXHAUST

POLLUTANTS SAMPLED TOTAL PARTICULATE

TIME OF PARTICULATE TEST

RUN NO ATE-1	DATE 2-17-72	BEGIN 1348	END 1405
RUN NO ATE-2	DATE 2-17-72	BEGIN 1639	END 1655
RUN NO ATE-3	DATE 2-18-72	BEGIN 1014	END 1026
RUN NO CHE-2	DATE 2-16-72	BEGIN 1100	END 1246
RUN NO CHE-3	DATE 2-16-72	BEGIN 1440	END 1557
RUN NO CHE-4	DATE 2-16-72	BEGIN 1655	END 1818

PARTICULATE EMISSION DATA

RUN NO.	ATE-1	ATE-2	ATE-3	CHE-2	CHE-3	CHE-4
PB BAROMETRIC PRESSURE	29.30	29.30	29.50	29.48	29.48	29.48
INCHES HG ABSOLUTE						
PM ORIFICE PRESSURE	.88	.79	2.11	1.12	1.07	1.16
DROP, INCHES WATER						
VM VOLUME OF DRY GAS	7.32	6.94	8.88	46.40	32.75	36.97
SAMPLED AT METER CONDITIONS, CU.FT.						
TM AVERAGE GAS METER	73.2	85.0	79.6	90.3	96.7	91.8
TEMPERATURE, DEG. F						
VMSTD VOLUME OF DRY	7.1	6.6	8.6	44.1	30.8	35.1
GAS SAMPLED AT STANDARD CONDITIONS CU.FT.						
VW TOTAL H2O COLLECTED	1.1	3.9	5.3	8.8	11.4	16.0
ML., IMPINGERS AND SILICA GEL						
VWGAS VOLUME OF WATER	.05	.18	.25	.42	.54	.76
VAPOR COLLECTED. CU.FT. AT STANDARD CONDITIONS						
PCTM PERCENT MOISTURE	.73	2.72	2.83	.94	1.73	2.12
IN THE STACK GAS BY VOLUME						

MD MOLE FRACTION OF DRY GAS	.993	.973	.972	.991	.983	.979
PCTCO2 PERCENT CO2	.20	.20	.20	.20	.20	.20
PCTO2 PERCENT O2	20.50	20.50	20.50	20.60	20.60	20.60
PCTN2 PERCENT N2	79.48	79.48	79.48	79.20	79.20	79.20
MWD MOLECULAR WEIGHT OF DRY STACK GAS	28.82	28.82	28.82	28.86	28.86	28.86
MW MOLECULAR WEIGHT OF STACK GAS	28.74	28.53	28.52	28.75	28.67	28.63
DELPs VELOCITY HEAD OF STACK GAS, INCHES OF WATER	.48	.48	.46	.89	.86	.93
TS STACK TEMPERATURE, DEG.F.	145	154	167	117	140	109
DPS X (TS + 460)	16.84	17.12	16.83	22.55	22.47	22.83
PS STACK PRESSURE, IN. HG. ABSOLUTE	29.30	29.30	29.50	29.48	29.60	29.48
VS STACK VELOCITY AT STACK CONDITIONS, FPM	2525	2575	2523	3369	3356	3419
AS STACK AREA, SQ.IN.	2124	2124	2124	2601	2601	2601
QS STACK GAS VOLUME AT STANDARD CONDITON *SCFM	31709	31216	30137	54566	52086	55521
TT NET TIME OF TEST, MIN.	17	16	12	96	72	72
DN SAMPLING NOZZLE DIAMETER, IN.	.2500	.1875	.2500	.1875	.1875	.1875
PCTI PERCNT ISOKINETIC	57	102	103	79	77	82

MF PARTICULATE - PROBE	172.1	88.6	194.5	966.3	716.2	176.2
CYCLONE AND FILTER, MG.						
MT PARTICULATE TOTAL,	179.4	123.1	197.0	1010.0	844.0	244.9
MG.						
CAN PARTICULATE PROBE	.3715	.2062	.3467	.3373	.3583	.0774
CYCLONE AND FILTER GR/SCF						
CAO PARTICULATE TOTAL	.3872	.2865	.3512	.3525	.4223	.1076
GR/SCF						
CAT PARTICULATE PROBE	.3161	.1693	.2806	.3022	.3077	.0695
CYCLONE AND FILTER, GR/CF AT STACK COND						
CAU PARTICULATE TOTAL	.3295	.2353	.2842	.3159	.3626	.0966
GR/CF AT STACK COND						
CAW PARTICULATE PROBE	100.9	55.2	89.6	157.7	159.9	36.8
CYCLONE AND FILTER, LB/HR.						
CAX PARTICULATE TOTAL	105.2	76.6	90.7	164.9	188.5	51.2
LB/HR.						
PCTEA PERCENT EXCESS	3195	3195	3195	4409	4409	4409
AIR AT SAMPLING PT						

[

NAME OF FIRM UNION CARBIDE

LOCATION OF PLANT -- ASHTABULA #20

TYPE OF PLANT REACTIVE METALS

CONTROL EQUIPMENT SCRUBBER

SAMPLING POINT LOCATIONS SOUTH HOOD EXHAUST

POLLUTANTS SAMPLED TOTAL PARTICULATE

TIME OF PARTICULATE TEST

RUN NO SHE-1	DATE 2-15-72	BEGIN 1350	END 1712
RUN NO SHE-2	DATE 2-16-72	BEGIN 1055	END 1309
RUN NO SHE-3	DATE 2-16-72	BEGIN 1442	END 1605
RUN NO SHE-4	DATE 2-16-72	BEGIN 1657	END 1816

PARTICULATE EMISSION DATA

RUN NO.	SHE-1	SHE-2	SHE-3	SHE-4
PB BAROMETRIC PRESSURE INCHES HG ABSOLUTE	28.90	29.48	29.48	29.48
PM ORIFICE PRESSURE DROP, INCHES WATER	1.51	1.12	.99	1.14
VM VOLUME OF DRY GAS SAMPLED AT METER CONDITIONS, CU.FT.	78.41	59.40	39.85	41.51
TM AVERAGE GAS METER TEMPERATURE, DEG. F	88.4	77.3	77.8	76.2
VMSTD VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS CU.FT.	73.4	57.8	38.8	40.5
VW TOTAL H2O COLLECTED ML., IMPINGERS AND SILICA GEL	11.2	9.2	10.7	13.6
VWGAS VOLUME OF WATER VAPOR COLLECTED. CU.FT. AT STANDARD CONDITIONS	.53	.44	.51	.64
PCTM PERCENT MOISTURE IN THE STACK GAS BY VOLUME	.72	.75	1.29	1.57
MD MOLE FRACTION OF DRY GAS	.993	.993	.987	.984
PCTCO2 PERCENT CO2	.20	.20	.20	.20
PCTO2 PERCENT O2	20.60	20.60	20.60	20.60
PCTN2 PERCENT N2	79.20	79.20	79.20	79.20
MWD MOLECULAR WEIGHT OF DRY STACK GAS	28.86	28.86	28.86	28.86

MW MOLECULAR WEIGHT OF STACK GAS	28.78	28.77	28.72	28.69
DELPS VELOCITY HEAD OF STACK GAS, INCHES OF WATER	1.06	1.05	.99	.97
TS STACK TEMPERATURE, DEG.F.	111	159	202	134
DPS X (TS + 460)	24.44	25.40	25.43	23.82
PS STACK PRESSURE, IN. HG. ABSOLUTE	28.90	29.48	29.48	29.48
VS STACK VELOCITY AT STACK CONDITIONS, FPM	3687	3794	3803	3563
AS STACK AREA, SQ.IN.	2112	2112	2112	2112
QS STACK GAS VOLUME AT STANDARD CONDITON *SCFM	48160	46570	43443	45208
TT NET TIME OF TEST, MIN.	120	96	72	72
DN SAMPLING NOZZLE DIAMETER, IN.	.1875	.1875	.1875	.1875
PCTI PERCNT ISOKINETIC	97	99	95	95
MF PARTICULATE - PROBE CYCLONE AND FILTER, MG.	525.4	2121.5	1862.3	429.6
MT PARTICULATE TOTAL, MG.	594.6	2252.2	1896.9	450.7
CAN PARTICULATE PROBE CYCLONE AND FILTER GR/SCF	.1102	.5648	.7399	.1633
CAO PARTICULATE TOTAL GR/SCF	.1247	.5996	.7537	.1713
CAT PARTICULATE PROBE CYCLONE AND FILTER, GR/CF AT STACK COND	.0981	.4724	.5760	.1412
CAU PARTICULATE TOTAL GR/CF AT STACK COND	.1110	.5015	.5867	.1481
CAW PARTICULATE PROBE CYCLONE AND FILTER, LB/HR.	45.5	225.4	275.5	63.3
CAX PARTICULATE TOTAL LB/HR.	51.5	239.3	280.6	66.4
PCTEA PERCENT EXCESS AIR AT SAMPLING PT	4409	4409	4409	4409

SOURCE TESTING CALCULATION FORMS

Test No. ASENo. Runs Name of Firm Union CarbideLocation of Plant Ashtabula #20Type of Plant Reactive MetalsControl Equipment ScrubberSampling Point Locations Scrubber ExhaustPollutants Sampled Total Particulate

Time of Particulate Test:

Run No. ASE-1 Date 2-17-72 Begin 1406 End 1410Run No. ASE-2 Date 2-17-72 Begin 1543 End 1606Run No. ASE-3 Date 2-17-72 Begin 1637 End 1707Run No. Date Begin End PARTICULATE EMISSION DATA

Run No.	ASE-1	ASE-2	ASE-3			
P _b barometric pressure, "Hg Absolute	29.30	29.30	29.30			
P _m orifice pressure drop, "H ₂ O	1.5	1.5	1.5			
V _m volume of dry gas sampled @ meter conditions, ft. ³	1.73	14.08	18.74			
T _m Average Gas Meter Temperature, °F	52	63	71			
V _m Volume of Dry Gas Sampled @ std. Standard Conditions, ft. ³	1.76	14.01	18.37			
V _w Total H ₂ O collected, ml., Impingers & Silica Gel.	-1.2	7.5	10.2			
V _w Volume of Water Vapor Collected gas ft. ³ @ Standard Conditions*	-0.057	0.36	0.48			

* 70°F, 29.92" Hg.

PARTICULATE EMISSION DATA (CONT'D)

Run No.	ASE-1	ASE-2	ASE-3	Orsat		
%M -% Moisture in the stark gas by volume	0	2.51	2.55			
M _d - Mole fraction of dry gas	1.0	.97	.97			
% CO ₂	_____	_____	_____	1.5		
% O ₂	_____	_____	_____	6.0		
% N ₂	_____	_____	_____	30.0		
M W _d - Molecular weight of dry stack gas	28.44	28.44	28.44			
M W - Molecular weight of stack gas	28.44	28.08	28.03			
Δ P _s - Velocity Head of stack gas, In.H ₂ O	_____	_____	_____			
T _s - Stack Temperature, °F	~100	~100	~100			
√Δ P _s X(T _s + 460)	_____	_____	_____			
P _s - Stack Pressure,"Hg.Absolute	_____	_____	_____			
V _s - Stack Velocity @ stack conditions, fpm	10,290	10,290	10,290			
A _s - Stack Area, in. ²	153.9	153.9	153.9			
Q _s - Stack Gas Volume @ Standard Conditions, *SCFM	11.736	11.383	11.383			
T _t - Net Time of Test, min.	4	23	30			
D _n - Sampling Nozzle Diameter,in.	0.25	0.25	0.25			
%I - Percent isokinetic	_____	_____	_____			
m _f - Particulate - probe,cyclone and filter, mg.	76.2	80.4	73.9			
m _t - Particulate - total, mg	97.8	104.4	101.4			
C _{an} - Particulate - probe,cyclone, and filter, gr/SCF	0.667	0.088	0.062			
C _{ao} - Particulate - total, gr/SCF	0.856	0.115	0.085			
C _{at} - Particulate - probe,cyclone, and filter, gr/cf @ stack conditions	0.618	0.079	0.056			

PARTICULATE EMISSION DATA (cont'd)

Run No.	ASE-1	ASE-2	ASE-3	Orsat		
C _{au} - Particulate, total, gr/cf @ stack cond.	0.913	0.119	0.088			
C _{aw} - Particulate, probe, cyclone, and filter, lb/hr.	67.09	8.58	6.05			
C _{ax} - Particulate - total, lb/hr.	86.1	11.2	8.29			
% EA- % Excess air @ sampling point	_____	_____	_____	12.5		

* 70°F, 29.92" Hg.

NAME OF FIRM UNION CARBIDE

LOCATION OF PLANT -- ASHTABULA #13

TYPE OF PLANT REACTIVE METALS

CONTROL EQUIPMENT SCRUBBER

SAMPLING POINT LOCATIONS NORTH WEST HOOD, NORTH EAST HOOD

POLLUTANTS SAMPLED TOTAL PARTICULATE

TIME OF PARTICULATE TEST

RUN NO NEH-1	DATE 2-22-72	BEGIN 1413	END 1533
RUN NO NEH-2	DATE 2-23-72	BEGIN 859	END 1020
RUN NO NEH-3	DATE 2-23-72	BEGIN 1218	END 1339
RUN NO NWH-1	DATE 2-22-72	BEGIN 1412	END 1533
RUN NO NWH-2	DATE 2-23-72	BEGIN 854	END 1012
RUN NO NWH-3	DATE 2-23-72	BEGIN 1218	END 1336

PARTICULATE EMISSION DATA

RUN NO.	NEH-1	NEH-2	NEH-3	NWH-1	NWH-2	NWH-3
PB BAROMETRIC PRESSURE INCHES HG ABSOLUTE	30.00	29.68	29.68	30.00	29.68	29.68
PM ORIFICE PRESSURE DROP, INCHES WATER	1.00	1.00	1.00	2.12	1.94	1.96
VM VOLUME OF DRY GAS SAMPLED AT METER CONDITIONS, CU.FT.	39.61	39.78	41.19	53.93	52.02	53.86
TM AVERAGE GAS METER TEMPERATURE, DEG. F	73.5	67.9	71.3	79.1	79.2	80.7
VMSTD VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS CU.FT.	39.5	39.7	40.8	53.4	50.9	52.6
VW TOTAL H2O COLLECTED ML., IMPINGERS AND SILICA GEL	2.6	4.4	9.2	4.2	2.0	6.9
VWGAS VOLUME OF WATER VAPOR COLLECTED. CU.FT. AT STANDARD CONDITIONS	.12	.21	.44	.20	.09	.33
PCTM PERCENT MOISTURE IN THE STACK GAS BY VOLUME	.31	.52	1.06	.37	.19	.62
MD MOLE FRACTION OF DRY GAS	.997	.995	.989	.996	.998	.994

PCTC02 PERCENT C02	1.00	1.00	1.00	1.00	1.00	1.00
PCT02 PERCENT 02	20.70	20.70	20.70	20.70	20.70	20.70
PCTN2 PERCENT N2	78.30	78.30	78.30	78.30	78.30	78.30
MWD MOLECULAR WEIGHT OF DRY STACK GAS	28.99	28.99	28.99	28.99	28.99	28.99
MW MOLECULAR WEIGHT OF STACK GAS	28.95	28.93	28.87	28.95	28.97	28.92
DELP5 VELOCITY HEAD OF STACK GAS, INCHES OF WATER	.05	.05	.06	1.63	1.47	1.52
TS STACK TEMPERATURE, DEG.F.	125	86	109	118	94	101
DPS X (TS + 460)	4.95	4.86	5.67	30.44	28.36	28.94
PS STACK PRESSURE, IN. HG. ABSOLUTE	30.00	29.68	29.68	30.00	29.68	29.68
VS STACK VELOCITY AT STACK CONDITIONS, FPM	731	722	842	4494	4207	4297
AS STACK AREA, SQ.IN.	2499	2499	2499	2223	2223	2223
QS STACK GAS VOLUME AT STANDARD CONDITON *SCFM	11483	11990	13363	63573	61544	61761
TT NET TIME OF TEST, MIN.	72	73	73	72	72	69
DN SAMPLING NOZZLE DIAMETER, IN.	.1875	.1875	.1875	.1875	.1875	.1875

PCTI PERCNT ISO KINETIC	431	409	378	94	92	99
MF PARTICULATE - PRØBE CYCLØNE AND FILTER, MG.	412.9	204.1	209.6	129.7	59.4	69.9
MT PARTICULATE TØTAL, MG.	421.8	222.2	227.3	143.1	64.0	80.4
CAN PARTICULATE PRØBE CYCLØNE AND FILTER GR/SCF	.1609	.0792	.0791	.0374	.0180	.0205
CAØ PARTICULATE TØTAL GR/SCF	.1644	.0862	.0857	.0413	.0194	.0235
CAT PARTICULATE PRØBE CYCLØNE AND FILTER, GR/CF AT STACK CØND	.1456	.0758	.0722	.0343	.0170	.0190
CAU PARTICULATE TØTAL GR/CF AT STACK CØND	.1487	.0825	.0783	.0378	.0183	.0219
CAW PARTICULATE PRØBE CYCLØNE AND FILTER, LB/HR.	15.8	8.1	9.1	20.4	9.5	10.8
CAX PARTICULATE TØTAL LB/HR.	16.2	8.9	9.8	22.5	10.2	12.5
PCTEA PERCENT EXCESS AIR AT SAMPLING PT	16197	16197	16197	16197	16197	16197

NAME OF FIRM UNION CARBIDE
 LOCATION OF PLANT -- ASHTABULA #13
 TYPE OF PLANT REACTIVE METALS
 CONTROL EQUIPMENT SCRUBBER

SAMPLING POINT LOCATIONS SOUTH WEST HOOD EXHAUST, SOUTH EAST HOOD EXHAUST

POLLUTANTS SAMPLED TOTAL PARTICULATE

TIME OF PARTICULATE TEST

RUN NO SEH-2	DATE 2-23-72	BEGIN 851	END 1010
RUN NO SEH-3	DATE 2-23-72	BEGIN 1221	END 1341
RUN NO SWH-1	DATE 2-22-72	BEGIN 1415	END 1531
RUN NO SWH-2	DATE 2-23-72	BEGIN 855	END 1010
RUN NO SWH-3	DATE 2-23-72	BEGIN 1228	END 1343

PARTICULATE EMISSION DATA

RUN NO.	SEH-2	SEH-3	SWH-1	SWH-2	SWH-3
PB BAROMETRIC PRESSURE INCHES HG ABSOLUTE	29.68	29.68	30.00	29.68	29.68
PM ORIFICE PRESSURE DROP, INCHES WATER	.42	1.19	2.20	1.89	1.73
VM VOLUME OF DRY GAS SAMPLED AT METER CONDITIONS, CU.FT.	22.39	36.21	54.32	51.76	49.44
TM AVERAGE GAS METER TEMPERATURE, DEG. F	51.9	62.7	73.2	71.1	79.0
VMSTD VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS CU.FT.	23.0	36.5	54.4	51.4	48.4
VW TOTAL H2O COLLECTED ML., IMPINGERS AND SILICA GEL	2.9	4.1	1.6	.6	7.5
VWGAS VOLUME OF WATER VAPOR COLLECTED. CU.FT. AT STANDARD CONDITIONS	.14	.19	.08	.03	.36
PCTM PERCENT MOISTURE IN THE STACK GAS BY VOLUME	.59	.53	.14	.06	.73
MD MOLE FRACTION OF DRY GAS	.994	.995	.999	.999	.993
PCTCO2 PERCENT CO2	1.00	1.00	1.00	1.00	1.00
PCTO2 PERCENT O2	20.70	20.70	20.70	20.70	20.70
PCTN2 PERCENT N2	78.30	78.30	78.30	78.30	78.30

MWD MOLECULAR WEIGHT OF DRY STACK GAS	28.99	28.99	28.99	28.99	28.99
MW MOLECULAR WEIGHT OF STACK GAS	28.92	28.93	28.97	28.98	28.91
DELP'S VELOCITY HEAD OF STACK GAS, INCHES OF WATER	.34	.31	1.79	1.57	1.43
TS STACK TEMPERATURE, DEG.F.	66	76	61	47	61
DPS X (TS + 460)	13.04	12.59	30.41	28.07	27.16
PS STACK PRESSURE, IN. HG. ABSOLUTE	29.68	29.68	29.80	29.68	29.60
VS STACK VELOCITY AT STACK CONDITIONS, FPM	1937	1868	4502	4164	4039
AS STACK AREA, SQ.IN.	2499	2499	2148	2148	2148
QS STACK GAS VOLUME AT STANDARD CONDITON *SCFM	33383	31652	67973	64308	60239
TT NET TIME OF TEST, MIN.	63	63	72	72	72
DN SAMPLING NOZZLE DIAMETER, IN.	.1875	.2500	.1875	.1875	.1875
PCTI PERCNT ISOKINETIC	99	93	86	86	87
MF PARTICULATE - PROBE CYCLONE AND FILTER, MG.	68.7	86.8	177.3	95.2	122.4
MT PARTICULATE TOTAL, MG.	76.2	90.7	183.7	146.7	217.7
CAN PARTICULATE PROBE CYCLONE AND FILTER GR/SCF	.0460	.0366	.0502	.0285	.0390
CAO PARTICULATE TOTAL GR/SCF	.0510	.0383	.0520	.0439	.0693
CAT PARTICULATE PROBE CYCLONE AND FILTER, GR/CF AT STACK COND	.0457	.0357	.0508	.0295	.0389
CAU PARTICULATE TOTAL GR/CF AT STACK COND	.0506	.0373	.0526	.0454	.0692

CAW PARTICULATE PROBE CYCLONE AND FILTER, LB/HR.	13.2	9.9	29.2	15.7	20.1
CAX PARTICULATE TOTAL LB/HR.	14.6	10.4	30.3	24.2	35.8
PCTEA PERCENT EXCESS AIR AT SAMPLING PT	16197	16197	16197	16197	16197

LOG,X
LOGOFF.

NAME OF FIRM UNION CARBIDE

LOCATION OF PLANT -- ASHTABULA #13

TYPE OF PLANT REACTIVE METALS

CONTROL EQUIPMENT SCRUBBER

SAMPLING POINT LOCATIONS B TAP EXHAUST

POLLUTANTS SAMPLED TOTAL PARTICULATE

TIME OF PARTICULATE TEST

RUN NO BTE-1	DATE 2-23-72	BEGIN 1530	END 1630
RUN NO BTE-2	DATE 2-24-72	BEGIN 903	END 1003
RUN NO BTE-3	DATE 2-24-72	BEGIN 1034	END 1134

PARTICULATE EMISSION DATA

RUN NO.	BTE-1	BTE-2	BTE-3
PB BAROMETRIC PRESSURE INCHES HG ABSOLUTE	29.68	29.30	29.30
PM ORIFICE PRESSURE DROP, INCHES WATER	1.65	1.64	1.61
VM VOLUME OF DRY GAS SAMPLED AT METER CONDITIONS, CU.FT.	41.04	41.15	41.37
TM AVERAGE GAS METER TEMPERATURE, DEG. F	81.9	88.8	103.5
VMSTD VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS CU.FT.	40.0	39.0	38.2
VW TOTAL H2O COLLECTED ML., IMPINGERS AND SILICA GEL	3.2	9.3	31.4
VWGAS VOLUME OF WATER VAPOR COLLECTED. CU.FT. AT STANDARD CONDITIONS	.15	.44	1.49
PCTM PERCENT MOISTURE IN THE STACK GAS BY VOLUME	.38	1.12	3.75
MD MOLE FRACTION OF DRY GAS	.996	.989	.963
PCTCO2 PERCENT CO2	1.00	1.00	1.00
PCTO2 PERCENT O2	20.80	20.80	20.80
PCTN2 PERCENT N2	78.20	78.20	78.20
MWD MOLECULAR WEIGHT OF DRY STACK GAS	28.99	28.99	28.99

MW MOLECULAR WEIGHT OF STACK GAS	28.95	28.87	28.58
DELP'S VELOCITY HEAD OF STACK GAS, INCHES OF WATER	.39	.38	.38
TS STACK TEMPERATURE, DEG.F.	122	126	149
DPS X (TS + 460)	15.04	15.01	15.16
PS STACK PRESSURE, IN. HG. ABSOLUTE	29.68	29.30	29.30
VS STACK VELOCITY AT STACK CONDITIONS, FPM	2231	2245	2280
AS STACK AREA, SQ.IN.	2124	2124	2124
QS STACK GAS VOLUME AT STANDARD CONDITON *SCFM	29613	29011	27590
TT NET TIME OF TEST, MIN.	60	60	60
DN SAMPLING NOZZLE DIAMETER, IN.	.2500	.2500	.2500
PCTI PERCNT ISOKINETIC	97	97	100
MF PARTICULATE - PROBE CYCLONE AND FILTER, MG.	536.0	481.0	465.8
MT PARTICULATE TOTAL, MG.	548.1	511.7	475.0
CAN PARTICULATE PROBE CYCLONE AND FILTER GR/SCF	.2066	.1897	.1877
CAO PARTICULATE TOTAL GR/SCF	.2113	.2018	.1914
CAT PARTICULATE PROBE CYCLONE AND FILTER, GR/CF AT STACK COND	.1858	.1660	.1539
CAU PARTICULATE TOTAL GR/CF AT STACK COND	.1900	.1766	.1569
CAW PARTICULATE PROBE CYCLONE AND FILTER, LB/HR.	52.4	47.2	44.4
CAX PARTICULATE TOTAL LB/HR.	53.6	50.2	45.2
PCTEA PERCENT EXCESS AIR AT SAMPLING PT	1733333	1733333	1733333

REPORT NO.

PAGE

OF

PAGES

SOURCE TESTING CALCULATION FORMS

Test No. BSENo. Runs Name of Firm Union CarbideLocation of Plant Ashtabula #13Type of Plant Reactive MetalsControl Equipment ScrubberSampling Point Locations Scrubber ExhaustPollutants Sampled Total Particulate

Time of Particulate Test:

Run No. BSE-1 Date 2-23-72 Begin 1520 End 1620Run No. BSE-2 Date 2-24-72 Begin 0855 End 0955Run No. BSE-3 Date 2-24-72 Begin 1010 End 1110Run No. Date Begin End PARTICULATE EMISSION DATA

Run No.	BSE-1	BSE-2	BSE-3			
P_b barometric pressure, "Hg Absolute	29.30	29.68	29.68			
P_m orifice pressure drop, "H ₂ O	1.0	1.0	1.0			
V_m volume of dry gas sampled @ meter conditions, ft. ³	38.32	35.32	36.11			
T_m Average Gas Meter Temperature, °F	71	86	94			
V_m Volume of Dry Gas Sampled @ std. Standard Conditions, ft. ³	38.00	34.06	34.32			
V_w Total H ₂ O collected, ml., Impingers & Silica Gel.	15.0	9.2	7.1			
$V_{w\text{ gas}}$ Volume of Water Vapor Collected ft. ³ @ Standard Conditions*	0.71	0.44	0.34			

* 70°F, 29.92" Hg.

PARTICULATE EMISSION DATA (cont'd)

Run No.	BSE-1	BSE-2	BSE-3			
C _{au} - Particulate, total, gr/cf @ stack cond.	0.0449	0.0328	0.0361			
C _{aw} - Particulate, probe, cyclone, and filter, lb/hr.	0.533	0.266	0.413			
C _{ax} - Particulate - total, lb/hr.	0.566	0.415	0.455			
% EA- % Excess air @ sampling point	_____	_____	_____	12.5		

* 70°F, 29.92" Hg.

PARTICULATE EMISSION DATA (CONT'D)

Run No.	BSE-1	BSE-2	BSE-3			
%M - % Moisture in the stack gas by volume	1.83	1.28	0.98			
M _d - Mole fraction of dry gas	.99	.99	.99			
% CO ₂	—	—	—	1.5		
% O ₂	—	—	—	6.0		
% N ₂	—	—	—	30.0		
M W _d - Molecular weight of dry stack gas	28.44	28.44	28.44			
M W - Molecular weight of stack gas	28.34	28.34	28.34			
Δ P _s - Velocity Head of stack gas, In.H ₂ O	—	—	—			
T _s - Stack Temperature, °F	~100	~100	~100			
$\sqrt{\Delta P_s \times (T_s + 460)}$	—	—	—			
P _s - Stack Pressure, "Hg. Absolute	—	—	—			
V _s - Stack Velocity @ stack conditions, fpm	1403	1403	1403			
A _s - Stack Area, in. ²	153.9	153.9	153.9			
Q _s - Stack Gas Volume @ Standard Conditions, *SCFM	1554	1554	1554			
T _t - Net Time of Test, min.	60	60	60			
D _n - Sampling Nozzle Diameter, in.	0.25	0.25	0.25			
%I - Percent isokinetic	—	—	—			
m _f - Particulate - probe, cyclone and filter, mg.	98.1	44.3	69.4			
m _t - Particulate - total, mg	104.8	68.8	76.2			
C _{an} - Particulate - probe, cyclone, and filter, gr/SCF	0.040	0.020	0.031			
C _{ao} - Particulate - total, gr/SCF	0.0425	0.0311	0.0342			
C _{at} - Particulate - probe, cyclone, and filter, gr/cf @ stack conditions	0.037	0.019	0.029			

APPENDIX B

COMPLETE GASEOUS RESULTS WITH EXAMPLE CALCULATIONS

The following are tracings from the recorder connected to the infrared carbon monoxide analyzer showing the carbon monoxide levels.

Scale divisions X 50 = ppm CO.

CALIBRATING @
238 PPM

65
FEET
REMAINING

2/16/72


UC ASHTABUKA

Chart Speed 1 inch/min

Scale Divisions

x 50 = ppm CO

11:30 a.m.



BRUSH INSTRUMENTS

16

South Hood
#20 Furnace

B-4


- 1456 RETURN TO
AMBIENT AIR


- 7453 Sampling
~~SHF~~ SHF

- AMBIENT




South Hood
#20 Furnace





South West Hood
Continued From
Preceding Page

B Port



South West Hood
2/23/72

0

1

2

3

4

5

6


7

B TAP
1" MIN
2-23-72

B Tap Exhaust
#13 Furnace
2/23/72

1535

B-9



B Tap Exhaust
Continued From
Preceding Page

ORSAT FIELD DATA

20 Furnace

Location Center Hood Exhaust Comments:

Date 2-18-72

Time 0930

Operator GONZALEZ

Test	(CO ₂) Reading 1	(O ₂) Reading 2	(CO) Reading 3
1	0.2	20.8	20.8
2	0.2	20.7	20.7
AVG	0.2	20.8	20.8

ORSAT FIELD DATA

Location #20 Furnace
TAPING EXHAUST
Date 2-18-72
Time 0930
Operator GONZALEZ

Comments:

Test	(CO ₂) Reading 1	(O ₂) Reading 2	(CO) Reading 3
1	0.02	20.7	20.7
2	0.03	20.9	20.8
3	0.02	20.6	20.7
AVG	0.02	20.7	20.7

ORSAT FIELD DATA

13 Furnace
 Location South West Hood Comments:
 Date 2-23-72
 Time P.M.
 Operator GONZALEZ

Test	(CO ₂) Reading 1	(O ₂) Reading 2	(CO) Reading 3
1	0.0	20.7	20.7
2	0.0	20.6	20.7
3	0.0	20.7	20.7
AUG	0.0	20.7	20.7

ORSAT FIELD DATA

13 Furnace

Location TAPPING EXHAUST Comments:

Date 2-23-72

Time P.M.

Operator GONZALEZ

Test	(CO ₂) Reading 1	(O ₂) Reading 2	(CO) Reading 3
1	0.0	20.8	20.8
2	0.0	20.8	20.8
AUG	0.0	20.8	20.8

ORSAT FIELD DATA

Location Furnace #13
Scrubber exhaust
 Date 2-23-72
 Time P.M.
 Operator GONZALEZ

Comments:

Test	(CO ₂) Reading 1	(O ₂) Reading 2	(CO) Reading 3
1	1.5	7.5	±70.0
			off scale - estimated val.

VELOCITY TRAVERSE FIELD DATA

Plant U.C. AshlandTest BSE-3Location Scrubber #13Date 2/24/72Operator B.M. Brown

(UNION CARBIDE)

FLOW FROM COMPUTER every five minutes

Clock Time	Point	ACFM AP, in. H₂O	Stack Temp., °C	Stack Pres., in. Hg	ΔP x (T+460)**	√ΔP x (T+460)*
1010		01496	36			
1015		01509	36			
1020		01551	36			
1025		01523	36			
1030		01545	36			
1035		01480	36			
1040		01537	36			
1045		01471	38			
1050		01481	38			
1055		01480	37			
1100		01432	37			
Avg		1500	37			

** - Calculation columns, not Field data

Comments:

NCAP-29 (12/67)

$$1500 \times \frac{29.30}{29.92} \times \frac{273 + 37}{273 + 20} = 1554$$

APPENDIX C

COMPLETE OPERATION RESULTS WITH EXAMPLE CALCULATIONS

FURNACE NO. 20 OPERATING DATA

<u>DATE</u>	<u>TESTING PLACE</u>	<u>TESTING TIME</u>	<u>AVERAGE FURNACE KW DURING TEST</u>	<u>TAPHOLE OPEN TIME DURING TEST</u>
2-15-72	Hood	1330-1715	50200 KW	1355-1410 1500-1515 1615-1630 1730-1755
2-16-72	Hood	1100-1300 1430-1615 1645-1830	48700 KW 52300 KW 50000 KW	1150-1210 1430-1445 1535-1555 1650-1720
2-17-72	Taphole Duct Scrubber	1348-1405 1640-1655 1406-1410 1543-1606 1637-1707	40500 KW 39500 KW 40500 KW 39500 KW 39500 KW	1345-1410 1645-1655 1345-1410 Not Open 1645-1655
2-18-72	Taphole Duct	1014-1026	42000 KW	1020-1040

PRODUCT MADE: 50% FeSi (Hard Cast)

AVG. WATER FLOWS: North Scrubber - 422 GPM
South Scrubber - 302 GPM

TWLopuszynski:clj

FURNACE NO. 13 OPERATING DATA


<u>DATE</u>	<u>TEST PLACE</u>	<u>TIME</u>	<u>ACCURATE * AVG. FURNACE LOAD (KW)</u>
2-22-72	Hood	1410-1530	22,800
2-23-72	Hood	1215-1345	23,000
	Hood	0850-1030	21,500
	Scrubber Exhaust	1520-1620	24,000
2-24-72	Scrubber Exhaust	855- 955	23,800
	Scrubber Exhaust	1010-1110	23,500
2-23-72	Tap Exhaust	1530-1630	24,000
2-24-72	Tap Exhaust	903-1003	23,800
2-24-72	Tap Exhaust	1034-1134	23,300

* In general, strip charts read approximately 500 KW low.

PRODUCT MADE: CaC2 (80-85% Grade)

WATER FLOW: Maximum - 490 GPM
Minimum - 324 GPM
Average - 450 GPM


KJKnapp:clj



MADE IN U.S.A.

EDWARDS & KELCEY


IN



3 JANUARY

INDIANAPOLIS, IND., U.S.A.

8 9.



MADE IN U.S.A.

11/23

26/3/72


11/23

5/3

10/23

26/4/72

9/23



APPENDIX D

FIELD DATA

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Uw. H. 4

%CO₂ 12%O₂ 20.6

AS - 1968

MF - 42480

MT. 461.5

Ambient Temp °F 65

Bar. Press. "Hg 28.9

Assumed Moisture % 22

Heater Box Setting, °F 250

Probe Tip Dia., In. ^{changed 7/6 Apr 7} 1.250Plant ~~Ashtabula~~ #20

Run No. # N # 13-1

Sample Box No. 2

Location North ~~Exhaust~~

Meter Box No. 4

Date 2-15-72

Probe Length 5'

Operator ~~Baxley~~ BAXLEY

Probe Heater Setting 60

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
Hole #1	13:42	636.5				78	74	6	250	55	28.8	100
NGH-1	13:47	639.8	1.40	1.15	1.15	78	74	6		55		100
2	13:52	643.2	1.40	1.15	1.15	86	74	6		55		100
3	13:57	645.9	1.40	1.15	1.15	92	74	4		65		130
4	14:02	648.8	1.50	1.10	1.10	94	78	5		65		110
5	14:07	651.6	1.30	1.95	1.95	98	80	5		65		128
6	14:10	654.3	1.30	1.45	1.45	76	80	7		65		125
7	15:15	657.8	"	"	"	"	"	"		"		"
Hole #2-1	15:20	657.8	1.70	1.90	1.90	80	80	15		60		160
2	15:25	661.5	1.70	1.90	1.90	100	82	21		60		160
3	15:30	664.6	1.50	1.65	1.65	100	82	22		60		132
4	15:35	668.8	1.40	1.60	1.60	104	82	25		60		130
5	15:40	670.6	1.30	1.40	1.40	104	81	25		60		125
6	15:45	673.3	1.20	1.35	1.25	104	86	25		65		135
7	16:00	676.7	1.20	"	"	"	"	"		"		"
Hole #3-1	16:05	676.7	1.50	1.70	1.70	90	86	3		20		135
2	16:10	679.5	1.50	1.70	1.70	90	86	5		20		140
3	16:15	683.1	1.30	1.40	1.40	92	86	5		65		115
4	16:20	686.1	1.10	1.25	1.25	100	85	6		60		100
5	16:25	689.2	1.10	1.25	1.25	110	70	6		60		105
Start 6	16:30	691.9	1.10	1.25	1.25	114	92	6		60		95
Start 7	16:32	691.9	"	"	"	"	"	"		"		"
Hole #4-1	16:37	695.4	1.40	1.60	1.60	110	92	7		60		100
2	16:42	698.2	1.40	1.60	1.60	112	94	9	✓	60	✓	90

[illegible]

Comments:

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

V_w - 2.7%CO₂ 12%O₂ 20.6

AS - 1968

mf - 1,4934

MT 1590.8

Ambient Temp °F 39°

Bar. Press. "Hg 29.48

Assumed Moisture % 2

Heater Box Setting, °F 250°

Probe Tip Dia., In. 3/16 .1875

1 of 2 sheets
ashtray #20

Plant ~~AKKON~~ Ash Ohio

Run No. NME-2

Sample Box No. 2

Location North Hood Exhaust

Meter Box No. 4

Date 2-16-72

Probe Length 5'

Operator BAXLEY

Probe Heater Setting 60°

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
NCE-②	11:00	717.02										
1	11:04	719.44	1.60	1.75	1.75	60	60	4	250	60	29.3	92°
2	11:08	723.54	1.80	2.00	2.00	68	60	5		60		110
3	11:12	725.46	1.80	2.00	2.00	78	60	5		60		170
4	11:16	728.10	1.60	1.75	1.75	84	62	5		60		115
5	11:20	730.20	1.50	1.65	1.65	90	64	5		60		108
Stop	6 11:24	733.32	1.40	1.55	1.55	90	64	5		60		125
Start	11:25	733.32										
NCE-②	1 11:29	736.19	1.90	2.05	2.05	92	70	6		60		160
2	11:33	739.05	1.90	2.05	2.05	94	70	6		60		188
ADT	3 11:37	741.84	1.80	1.45	1.45	98	74	8		60		210
NOMA	4 11:41	743.70	1.50	1.25	1.25	100	76	7		60		175
5	11:45	745.37	1.30	1.10	1.10	100	76	6		60		170
Stop	6 11:49	746.60	1.30	1.10	1.10	102	76	6		60		170
Start	11:50	746.60										
NCE-②	1 11:54	749.05	1.30	1.10	1.10	96	78	8		60		168
2	11:58	751.35	1.60	1.35	1.35	96	78	10		60		150
3	12:02	753.62	1.50	1.25	1.25	98	80	11		60		255
4	12:06	755.74	1.20	.90	.90	100	80	11		60		128
5	12:10	757.87	1.20	1.05	1.05	100	80	11		60		130
Stop	6 12:14	760.09	1.20	1.05	1.05	102	80	12		60		120
Start	12:15	760.09										
NCE-②	1 12:19	762.50	1.40	1.25	1.25	102	80	12		60		135
2	12:23	764.78	1.40	1.25	1.25	102	80	14	✓	60	✓	145

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes. or 4 or 3.

Uw 9.5
%CO₂ .2
%O₂ 20.6
As - 1968
ME - 1399
MT 297.3

Plant ASH Tabula H2ORun No. 144-3Location NORTH HOOD SummitDate 2-16-72Operator BAXLEYSample Box No. 2Meter Box No. 4Probe Length 5'Probe Heater Setting 60Ambient Temp °F 40Bar. Press. "Hg 29.48Assumed Moisture % 2%Heater Box Setting, °F 250Probe Tip Dia., In. 3/16" 250

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START												
NCE-3	13:35	773.55										
1	13:38	775.06	1.80	1.26	1.76	68	68	1	250	60	29.3	155
2	13:41	776.77	1.50	1.40	1.40	68	68	3		60		165
3	13:44	778.85	1.70	1.55	1.55	80	68	3		60		162
4	13:47	780.59	1.70	1.50	1.50	84	68	4		60		150
5	13:50	782.50	1.60	1.45	1.45	90	70	5		60		145
STOP												
6	13:53	784.25	1.30	1.20	1.20	94	70	5		60		140
START												
NCE-3-1	13:57	786.04	1.50	1.30	1.30	94	72	5		60		175
2	14:00	787.94	1.70	1.45	1.45	98	74	5		60		175
3	14:03	789.98	1.80	1.50	1.50	100	76	5		60		200
4	14:06	791.60	1.40	1.15	1.15	102	78	5		60		200
5	14:09	793.24	1.20	.98	.98	104	78	5		60		170
STOP												
6	14:12	794.89	1.20	.98	.98	104	80	5		60		160
START												
NCE-3-1	14:13	794.89										
2	14:16	796.52	1.50	1.25	1.25	104	80	5		60		132
3	14:19	798.66	1.50	1.25	1.25	106	80	5		60		145
4	14:22	800.40	1.50	1.25	1.25	102	78	5		60		155
5	14:25	802.12	1.50	1.25	1.25	102	76	6		60		140
6	14:28	803.87	1.10	.94	.94	102	76	6		60		180
STOP												
6	14:31	805.58	1.10	.94	.94	104	76	6		60		170
START												
NCE-3-1	14:32	805.58										
2	14:35	807.35	1.40	1.20	1.20	100	74	6		60		190
3	14:38	808.95	1.40	1.20	1.20	100	74	6		60		210

[illegible]

Comments:

NCAP-37 (12/67)

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Uw. 9.2

CO₂ 1.2

CO 20.6

As - 1968

Mc - 219.2

MT. 312.8

Ambient Temp °F 40

Bar. Press. "Hg 29.48

Assumed Moisture % 22

Heater Box Setting, °F 250

Probe Tip Dia., In. 3/16" .250

Plant ~~Ashtabula~~ Ashitabula

Run No. NHE-4

Sample Box No. 2

Location North Head Exp

Meter Box No. 4

Date 8-16-72

Probe Length 5'

Operator ~~Sandley~~ BAXLEY

Probe Heater Setting 60%

SPARK	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
NHE-4	11:48	815.02										
Left	11:51	816.80	1.20	.98	.98	90	72	1	250	60	29.3	90
Right	11:54	818.77	1.80	1.50	1.50	94	72	2		60		110
A	11:57	820.87	2.00	1.85	1.85	96	74	3		60		100
	12:00	823.04	1.90	1.80	1.80	94	74	3		60		104
	12:03	825.42	1.90	1.80	1.80	96	74	3		60		105
STOP	12:06	827.28	1.70	1.60	1.60	96	74	3		60		120
START	12:07	827.28										
	12:10	829.29	1.80	1.70	1.70	96	74	3		60		118
NHE-4-2	12:13	831.40	1.90	1.50	1.80	96	74	3		60		125
	12:16	833.52	1.80	1.70	1.70	98	76	3		60		125
B	12:19	835.52	1.60	1.50	1.50	100	78	3		60		132
	12:22	837.41	1.40	1.35	1.35	100	80	3		60		112
STOP	12:25	839.27	1.40	1.35	1.35	102	82	3		60		115
START	12:26	839.27										
NHE-4-1	12:29	841.42	1.40	1.30	1.30	100	80	3		60		90
	12:32	843.15	1.70	1.50	1.50	100	80	3		60		110
	12:35	845.50	1.60	1.40	1.40	102	82	3		60		105
C	12:38	847.90	1.40	1.30	1.30	102	82	3		60		105
	12:41	848.90	1.20	1.10	1.10	102	82	3		60		95
STOP	12:44	850.65	1.20	1.10	1.10	102	84	3		60		95
START	12:45	850.65										
NHE-4-1	12:48	852.50	1.50	1.35	1.35	100	82	3		60		95
D	12:51	854.44	1.50	1.35	1.35	100	82	3		60		110

D-8

Comments:

NCAP-37 (12/67)

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

U_w 8.8
%CO₂ .2
%O₂ 20.6
AS - 2601
MF - 9643
MT₀ 1010
450

Ambient Temp °F

Bar. Press. "Hg

Assumed Moisture %

Heater Box Setting, °F

Probe Tip Dia., In.

Plant Astabadula #20Run No. CHE-2Location center hood exhaustDate 2/16/72Operator AverySample Box No. GI-2Meter Box No. GI-2Probe Length 5'Probe Heater Setting 200°F

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	1100	60.695				75	75		250	75	29.48	
A-1	1104	62.2	.50	.64	.64	75	75	4.0				110
A-2	1108	63.9	.65	.82	.82	75	75	7.0				110
A-3	1112	65.65	.68	.86	.86	75	70	7.0				105
A-4	1116	67.90	.25	.95	.95	86	75	6.0				110
A-5	1120	69.93	.95	1.2	1.2	85	80	6.0				100
A-6	1124	71.6	.95	1.2	1.2	85	80	6.0				100
START	1130	71.6	START									
A-1	1134	73.6	.85	1.07	1.07	85	80	5.5				
B-1	1134	73.6	.85	1.07	1.07	85	80	5.5		80		100
B-2	1138	75.8	.75	.95	.9	85	80	5.5				105
B-3	1142	77.17	.72	.92	.92	85	80	6.0				115
B-4	1146	79.01	.79	1.0	1.0	90	85	6.0				115
B-5	1150	81.1	.95	1.2	1.2	90	85	7.0				115
START	1154	83.23	1.1	1.35	1.35	95	90	8.0				150
START	1155	83.23	START									
C-1	1159	85.2	.75	1.2	1.2	95	90	7.5		80		110
C-2	1203	87.0	.85	1.0	1.0	95	90	7.5				115
C-3	1207	88.93	.78	.99	.99	100	75	7.5				120
C-4	1211	90.72	.80	1.0	1.0	100	95	8.0				125
C-5	1215	92.69	.97	1.25	1.25	100	75	9.5				120
START	1219	94.90	1.2	1.5	1.5	100	75	12.0				130

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Uw H₂O
90CO₂ 2.2
90O₂ 20.6
As - 260.1
mf - 0.7162
MT 844.0

Ambient Temp °F 55°Bar. Press. "Hg 29.44Assumed Moisture % 3Heater Box Setting, °F 250Probe Tip Dia., In. 3/16 .1175Plant Astabilator #20Run No. CHE-3Location Center hood exhaustDate 2/16/77Operator AVERYSample Box No. GI-2Meter Box No. GI-2Probe Length 5' pyrexProbe Heater Setting 200°F

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	1440	107.155				80	80		2.50	70	29.0	
A-1	1443	108.12	.40	.52	.52	80	80	2.0				130
A-2	1446	109.30	.59	.75	.75	85	80	2.5				140
A-3	1449	110.54	.63	.80	.80	85	80	3.0				135
A-4	1452	111.84	.73	.93	.93	90	85	4.5				140
A-5	1455	113.20	.79	1.0	1.0	90	85	5.0				135
A-6	1458	114.66	.85	1.1	1.1	95	90	5.5				145
START	1500	114.66										
B-1	1503	116.00	.74	.94	.94	95	90	5.0				130
B-2	1506	117.34	.70	.90	.90	95	90	5.0				135
B-3	1509	118.67	.68	.87	.87	100	95	5.5				160
B-4	1512	120.05	.75	.96	.96	100	95	6.0				145
B-5	1515	121.46	.85	1.08	1.08	100	95	6.5				170
Stop B-6	1518	123.12	1.1	1.37	1.37	100	100	7.5				155
START	1520	123.12										
C-1	1523	124.60	.90	1.15	1.15	100	95	6.5				130
C-2	1526	126.06	.80	1.0	1.0	100	95	6.5				135
C-3	1529	127.44	.72	.91	.91	100	95	6.5				135
C-4	1532	128.84	.75	.96	.96	105	100	7.0				145
C-5	1535	130.33	.95	1.2	1.2	105	100	8.0				130
Stop C-6	1538	131.975	1.1	1.37	1.37	105	100	9.0	↓	↓	↓	145

D-12

NCAP-37 (12/67)

CHIE - 3
Page 2 of 2

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Uw 16.0
%CO₂ 2
%O₂ 20.6
As - 2601
MF - 1742
MT 244.9

Ambient Temp °F 58

Bar. Press. "Hg 29.48

Assumed Moisture % 32

Heater Box Setting, °F 250

Probe Tip Dia., In. 3/16 .1875

Plant Astabella Hc RfmRun No. CHE-4Location Center Hood ExhaustDate 2/16/72Operator AverySample Box No. GF-1Meter Box No. GITProbe Length 5' PyrexProbe Heater Setting 200°F

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	1655	141.787				80	80					
D-1	1658	143.30	.90	1.15	1.15	85	80	2.0	250	70°	29.48	95
D-2	1701	145.55	1.2	1.5	1.5	85	80	4.5				105
D-3	1704	146.65	1.1	1.37	1.37	85	85	4.0				110
D-4	1707	148.23	1.1	1.37	1.37	90	85	4.0				110
D-5	1710	149.88	1.1	1.37	1.37	90	85	4.0				110
Stop D-6	1713	151.60	1.2	1.5	1.5	90	85	4.5				110
START	1715	151.60										
C-1	1718	153.22	1.1	1.37	1.37	90	85	4.5				100
C-2	1721	154.70	.85	1.06	1.06	90	85	4.0				110
C-3	1724	156.12	.80	1.0	1.0	95	90	4.0				100
C-4	1727	157.68	.95	1.2	1.2	95	90	4.0				105
C-5	1730	159.40	1.2	1.5	1.5	95	90	5.0				105
Stop C-6	1733	161.50	1.3	1.65	1.65	95	90	5.0				125
START	1738	161.50										
B-1	1741	162.90	.80	1.0	1.0	95	90	3.5				125
B-2	1744	164.40	.80	1.0	1.0	95	90	3.5				125
B-3	1747	165.83	.80	1.0	1.0	95	90	3.5				110
B-4	1750	167.20	.75	.95	.95	95	90	3.5				105
B-5	1753	168.75	.80	1.0	1.0	95	90	3.5				110
Stop B-6	1756	170.36	1.15	1.3	1.3	100	95	4.0				105

D-14

NCAP-37 (12/67)

CH E-4
Page 2 of 2

Pat A -- D

left → right facing duct,

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Plant 20, Pohlabula #20Run No. SHE-1Location SOUTH-HORN EXHAUSTDate 2/15/72Operator + PatchellSample Box No. 3Meter Box No. 3Probe Length 5'Probe Heater Setting 60%Uw 11.2CO₂ 0.2O₂ 20.6As - 211.2MF - 525.4MT - 574.6Ambient Temp °F 60Bar. Press. "Hg 28.9Assumed Moisture % 2.0Heater Box Setting, °F 250Probe Tip Dia., In. .1875

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	13:50	008.51	1.10	4.0	4.0	74	70	14	250	57	29.9	110
A-1	15	-	1.05	3.9	3.9	86	70	16	-	53	-	110
STOP	14:00	021.60	1.05	3.9	3.9	86	70	20	-	55	-	130
START	15:00	-	1.00	1.23	1.23	70	70	7	-	55	-	140
waiting	15	-	.87	1.08	1.08	80	70	10	-	55	-	130
going	20	-	.76	.90	.90	80	70	9	-	55	-	130
away	25	-	.80	.96	.96	80	70	10	-	55	-	120
STOP	30	STOP 31.9	.80	.96	.96	82	70	10	-	55	-	120
START	15:35	031.9	.23	.28	.28	82	72	6	-	55	-	110
B-1	40	-	1.3	1.6	1.6	86	74	15	-	55	-	110
-2	45	-	1.3	1.6	1.6	88	74	16	-	60	-	120
-3	50	-	.85	1.05	1.05	92	76	15	-	60	-	120
-4	55	-	.80	1.00	1.00	100	82	15	-	60	-	110
-5	16:00	-	1.00	1.20	1.00	100	82	17	-	75	-	120
STOP	05	48.70	1.00	1.20	1.00	100	82	17	-	75	-	120
START	16:10	048.70	1.3	1.6	1.6	100	80	6	-	70	-	120
B-1	15	-	1.4	1.6	1.7	100	80	7	-	65	-	120
-2	20	-	1.2	1.5	1.5	100	80	7	-	65	-	110
-3	25	-	1.2	1.5	1.5	100	82	8	-	65	-	110
-4	30	-	.95	1.15	1.15	106	82	9	-	70	-	110
-5	35	-	.95	1.15	1.15	108	84	9	-	70	-	110
STOP	40	-	.95	1.15	1.15	108	84	9	-	70	-	100

SHE-1 page 2 of 2

[illegible]

Comments:

NCAP-37 (12/67)

Pl. A → D

left to right facing dust

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Uw. 9.2
%CO₂ .2
%O₂ 20.6
As - 2112
MF - 2,121.5
MT 2,252.2

Plant W/O Asitabala #20Run No. SH-E-2Location South Hood ExhaustDate 2/16/72Operator GONZALESSample Box No. 3Meter Box No. 3Probe Length 5'Probe Heater Setting 60Ambient Temp °F 52Bar. Press. "Hg 29.48Assumed Moisture % 2Heater Box Setting, °F 200Probe Tip Dia., In. .1875

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	1055	087.00	.80	1.00	1.00	58	58	5	200	60	29.48	170
A-1	59		1.10	1.2	1.2	64	58	7		60		170
-2	1103		1.10	1.2	1.2	72	58	7		60		180
-3	07		.78	.90	.90	76	58	5		60		120
-4	11		.50	1.10	1.10	80	62	7		60		100
-5	16 STOP		.90	1.10	1.10	86	62	8		60		120
...	...	...	...	...	...	...	...	...	...	...	...	110
24 START			.80	.95	.95	86	62	7		60		110
STOP -6	28 STOP	102.61	.80	.95	.95	86	62	7		60		110
START	1133	112.61	.55	.67	.67	88	66	6		60		170
B-1	37		1.4	1.7	1.7	88	66	10		60		140
-2	41		1.2	1.2	1.2	88	66	10		65		160
-3	45		1.0	1.1	1.1	88	66	10		65		190
-4	49		.85	.82	.82	90	68	11		65		300
-5	53		.95	.95	.95	90	70	14		65		200
STOP -6	57		.95	.95	.95	90	72	14		65		210
START	1201		.80	.80	.80	90	72	13		65		190
C-1	05		.78	.80	.80	90	72	15		65		200
-2	09 STOP START 1228		1.5	1.6	1.6	90	72	24		65		200
-3	1232		1.2	1.3	1.3	90	72	6		65		200
-4	36		1.0	1.1	1.1	90	72	6		65		210
-5	40		.90	1.0	1.0	90	72	6		65		140
STOP -6	44		.90	1.0	1.0	90	72	7		65		150

changed filter to filter glass broken (too high vacuum)


SHE-2 Page 2 of 2

[illegible]

Comments:

NCAP-37 (12/67)

Parts A → D
South → North



Duct
diagram

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Plant Wt. Ashtabula #20Run No. SHE-3Location South Wood ExhaustDate 2/16/72Operator Tommy GonzalezSample Box No. 4Meter Box No. 3Probe Length 5'Probe Heater Setting 60%

Uw. 10.7
CO₂ 2.2
O₂ 20.6
As - 2112
MF - 1,8623
MT 1,896.9

Ambient Temp °F 55Bar. Press. "Hg 29.48Assumed Moisture % 2Heater Box Setting, °F 290Probe Tip Dia., In. 3/16 .1875

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	1442	146.48	.97	1.1	1.1	68	64	5	200	65	29.48	120
A-1	45		1.2	1.3	1.3	68	64	5		65		130
-2	48		.95	1.0	1.0	74	68	4.5		60		180
-3	51		.60	.65	.65	76	68	4		60		180
-4	54		.65	.71	.71	80	68	3.5		60		160
-5	57		.72	.79	.79	80	68	4.0		60		150
STOP-6	1500		.72	.78	.78	80	68	4.0		60		190
START	1503	68	.95	.99	.99	82	70	8.0		60		130
B-1	06		1.3	1.40	1.40	82	70	8.0		60		170
-2	09		1.3	1.40	1.40	84	70	8.0		60		200
-3	12		.90	1.0	1.0	84	70	7.0		60		210
-4	15		.78	.75	.75	86	70	6.0		65		240
-5	18		.92	.88	.88	86	70	7.0		65		250
STOP-6	21	166.25	.92	.88	.88	86	70	7.0		65		240
START	1523		.95	.89	.89	86	70	10.0		65		290
C-1	1528		1.4	1.4	1.4	86	70	11.0		65		190
-2	31		1.3	1.1	1.1	86	70	13.0		65		280
-3	34		1.1	1.0	1.0	86	70	14.0		65		285
-4	37		.95	.92	.92	86	70	15.0		65		265
-5	40		.92	.90	.90	86	70	15.0		65		260
STOP-6	43		.92	.90	.90	86	70	15.5		65		235

SAC-3 Page 2 of 2

b-20

NCAP-37 (12/67)

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Plant W/C Ash Tabula #20Run No. SHE-4Location Sully Wood ExhaustDate 2/16/72Operator Pat PatchellSample Box No. 3Meter Box No. 3Probe Length 5Probe Heater Setting 60Uw 136%CO₂ 0.2%O₂ 20.6As - 2112MF - 4294Ambient Temp °F 58Bar. Press. "Hg 29.48Assumed Moisture % 2Heater Box Setting, °F 200Probe Tip Dia., In. 1/16, 1875

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	1657	186.58	.76	.75	.75	64	64	3.5	200	50	29.48	170
A-1	1700		1.2	1.2	1.2	66	64	4.5		50		180
-2	03		.90	.95	.95	72	68	5.0		50		170
-3	06		.80	.87	.87	76	66	5.0		50		185
-4	09		.70	.75	.75	76	66	5.5		50		180
-5	12		.65	.70	.70	78	68	5.5		55		170
Stop-6	15		.70	.70	.75	80	68	5.5		55		160
START	1717		.65	.70	.70	80	68	5.5		55		170
B-1	20		1.2	1.4	1.4	80	68	6.5		55		120
-2	23		1.1	1.3	1.3	82	68	6.5		55		120
-3	26		.85	1.05	1.05	86	68	6.0		55		120
-4	29		.70	.86	.86	86	68	5.5		55		110
-5	32		.80	1.00	1.00	86	68	6.0		55		115
Stop-6	35		.80	1.00	1.00	86	68	6.0		55		115
START	1738		.55	.68	.68	86	68	5.0		55		100
C-1	41		1.3	1.6	1.6	86	68	7.5		55		110
-2	44		1.2	1.45	1.45	86	68	7.5		55		130
-3	47		.95	1.2	1.2	90	68	6.0		55		140
-4	50		.85	1.05	1.05	90	68	6.0		55		110
-5	53		.95	1.2	1.2	90	68	7.0		55		130
Stop-6	56		.95	1.2	1.2	90	68	7.0		55		120

pg 2 of 2

0-22

Comments:

NCAP-37 (12/67)

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Plant

Run No.

Location

Date _____

Operator

Sample Box No.

Meter Box No.

Probe Length

Probe Heater Setting

Ambient Temp °F

Bar. Press. "Hg

Assumed Moisture %

Heater Box Setting.

Probe Tip Dia., In.

[illegible]

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Uw. 3.9
%CO₂ .02
%O₂ 20.5
AS 2124
MF- 0886
MT. 123.1

Ambient Temp °F 50

Bar. Press. "Hg 29.3

Assumed Moisture % 1.6

Heater Box Setting, °F 250

Probe Tip Dia., In. ~~3/16~~ 3/16-183

Plant Asiatic

Run No. ATE-2

Location Tap Exhaust

Date 2/17/72

Operator: AL-14

Sample Box No. GI-I

Meter Box No. *GI-7*

Probe Length

Probe Heater Setting 50%

[illegible]

PARTICULATE FIELD DATA:

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

20
Plant Astapula 6/1/72
Run No. ATE-3
Location Tap E. 1/2 Sec. 1
Date 2/18/72
Operator A. J. Avery AVERY

Sample Box No.

Meter Box No.

Probe Length

Probe Heater Setting

Vw 5,3
%CO₂ .02

 $900_2 \text{ } 20.5$

AS - 2124

MF - 1945

Ambient Temp

Bar. Press. "Hg 29.6

Assumed Moisture % 120

Heater Box Setting, °F 250°

Probe Tip Dia., In. 1/4 (.250)

[illegible]

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

U.W.
70°C/2
90°C/2
A5
MF
MT

Plant UC ASHTABULARun No. ASE-1Location #20 SCRUBBERDate 2/17/72Operator Ernestine / M. J. HallSample Box No. Rec 4Meter Box No. Rec 4Probe Length specialProbe Heater Setting 0Ambient Temp °F 58Bar. Press. "Hg 29.30Assumed Moisture % 10Heater Box Setting, °F 100Probe Tip Dia., In. 1/4"

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
ASE-1	1406	860.63	NONE	1.5	1.5	52	52	4	100	50	2.16	~100
	1410	862.36	USED	1.5	—	52	52	20	↓	50	—	—
		1.73			1.5	52	52	12				
ASE-2 NO FILTER USED												
1	1543	862.46	NONE	1.5	1.5	52	52	3	100		2.16	~100
1	1546	862.46	USED	1.5	—	52	60	—	↓			
1	1553	862.88		1.5	1.5	52	52	10				
1	1603	874.85		1.5	1.5	—	—	18		50		
1	1606	876.94		1.5	1.5	61	80	20		50		
		14.08			1.5	57.2	68.6	11.00	↓			
ASE-3												
1	1637	876.67	NONE	1.5	1.5	60	62	3	100	50	2.16	~100
1	1647	883.20	USED	1.5	1.5	63	76	5	↓	52		
1	1651	889.50		1.5	1.5	66	74	6		52		
1	1701	895.41		1.5	1.5	—	81	11		52		
		18.74			1.5	64.5	77.25	6.25	↓	52		
						70.88						

PARTICULATE CLEANUP SHEET

Date: 2/15/22

CLEANUP SHEET
Plant: ~~Urtica~~ *Castanopsis* #20

Run number: NOE-1

Location of sample port: North Head

Operator: Sander & Bernie

Barometric pressure: 29.5

Sample box number: 8

Ambient temperature: 70

Impinger H₂O

Volume after sampling 387 ml Container No. WHE-1 Ether-chloroform extraction
Impinger prefilled with 400 ml Extra No. _____ of impinger water 2.7 mg
Volume collected - 13 ml Impinger water residue 25.9 mg

Impingers and back half of filter, acetone wash: Container No. NHE-1
Extra No. Weight results 8.9 mg

Dry probe and cyclone catch: Container No. _____
Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and
front half of filter,
acetone wash: Container No. NHE-1
Extra No. _____ Weight results 67.9 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.	Filter particulate weight	mg
000161	NO. 8				
0.1767	Box 2				
000105	01733				
Total particulate weight				424.0	mg
TOTAL " PR Cyclone & Filter				461.5	

Silica Gel

Weight after test: 212.1

Weight before test: 187.7

Moisture weight collected: 24.4

Moisture total 24.4 gm

Container number: NO. 8 1 Rec. 2 2. 8 3. 8 4.

Sample number: NHE-1 Analyze for:

Method determination:

Comments:

Prepared by 12/10/22

PARTICULATE CLEANUP SHEET

Date: 2-16-72 Plant: Alley Ohio
 Run number: NHE-2 Location of sample port: North of Exhaust
 Operator: Landy & Barnie Barometric pressure: 29.5 Hood
 Sample box number: 2 Ambient temperature: 70

Impinger H₂O

Volume after sampling 380ml Container No. NHE-2 Ether-chloroform extraction
 Impinger prefilled with 400ml Extra No. _____ of impinger water 1.2 mg
 Volume collected 20ml Impinger water residue 79.2 mg

Impingers and back half of filter, acetone wash: Container No. NHE-2
 Extra No. _____ Weight results 17.0 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. NHE-2
 Extra No. _____ Weight results 235.5 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.	
<u>000254</u>	<u>NHE-2</u>			
				Filter particulate weight <u>1257.9</u> mg
				Total particulate weight <u>1493.4</u> mg
				TOTAL " <u>Ph Cyclone & filter</u> <u>1590.8</u>

Silica Gel

Weight after test: 201.1
 Weight before test: 183.8
 Moisture weight collected: 17.3 Moisture total 17.3 gm
 Container number: 1. 8 2. _____ 3. _____ 4. _____

Sample number: NHE-2 Analyze for: _____

Method determination: _____

Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2-16-72 Plant: ASH/THD/12 Ohio
 Run number: NHE-3 Location of sample port: North choke box
 Operator: Sandy + Bonnie Barometric pressure: 29.48
 Sample box number: 2 Ambient temperature: 38

Impinger H₂O

Volume after sampling 392 ml Container No. NHE-3 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 2.2 mg
 Volume collected -8 ml Impinger water residue 150.5 mg

Impingers and back half of filter, acetone wash: Container No. NHE-3
 Extra No. _____ Weight results 4.7 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. NHE-3
 Extra No. _____ Weight results 139.9 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.	
<u>1000 259</u>	<u>WT-0.6792</u>	_____	_____	
_____	_____	_____	_____	Filter particulate weight <u>1005.5</u> mg
_____	_____	_____	_____	
Total particulate weight				<u>139.9</u> mg
TOTAL " PR cyclone & filter				<u>297.3</u>

Silica Gel

Weight after test: 208.0
 Weight before test: 190.5
 Moisture weight collected: 17.5 Moisture total 17.5 gm
 Container number: 1. 8 2. _____ 3. _____ 4. _____

Sample number: NHE-3 Analyze for: _____

Method determination: _____

Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2-16-72 Plant: H-20
 Run number: NHE-4 Location of sample port: North House
 Operator: Sander J. B. [unclear] Barometric pressure: 29.5
 Sample box number: 2 Ambient temperature: 38°

Impinger H₂O

Volume after sampling 394 ml Container No. NHE-4 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 0.9 mg
 Volume collected 6 ml Impinger water residue 87.5 mg

Impingers and back half of filter, acetone wash: Container No. NHE-4
 Extra No. _____ Weight results 5.3 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. NHE-4
 Extra No. _____ Weight results 49.7 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>000247</u>	<u>NHE-4</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Filter particulate weight 169.4 mg
 Total particulate weight 219.1 mg
 TOTAL " PR cyclone & filter 312.8

Silica Gel

Weight after test: 201.7
 Weight before test: 186.5
 Moisture weight collected: 15.2 Moisture total 15.2 gm
 Container number: 1. NHE-4 2. _____ 3. _____ 4. _____

Sample number: NHE-4 Analyze for: _____
 Method determination: _____
 Comments: _____

GI 2

PARTICULATE CLEANUP SHEET

Date: 2/15/72 Plant: HE - 2
 Run number: CHE-2 Location of sample port: Center Head
 Operator: _____ Barometric pressure: 28.9
 Sample box number: 10 INUV Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 394 ml Container No. CHE-2 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 6.2 mg
 Volume collected -6 ml Impinger water residue 28.7 mg

Impingers and back half of filter, acetone wash: Container No. CHE-2
 Extra No. _____ Weight results 8.8 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. CHE-2
 Extra No. _____ Weight results 76.6 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>00055</u>	<u>0.6835</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
Filter particulate weight <u>889.7</u> mg			
Total particulate weight <u>966.3</u> mg			
TOTAL 1. PR cyclone & filter <u>1010.0</u>			

Silica Gel

Weight after test: 188.8
 Weight before test: 174.0
 Moisture weight collected: 14.8 Moisture total 14.8 gm
 Container number: 1. 1.0 2. 2.0 3. 3.0 4. 4.0

Sample number: CHE-2 Analyze for: _____
 Method determination: _____
 Comments: _____

Innov-2

PARTICULATE CLEANUP SHEET

Date: 2/16/72
Run number: CHE-3
Operator: HUEY
Sample box number: 10

Plant: ASHTABULA #20
Location of sample port: CENTRAL Hood
Barometric pressure: 28.90
Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 3 ml Container No. CHE-3 Ether-chloroform extraction
Impinger prefilled with 400 ml Extra No. _____ of impinger water 0 mg
Volume collected _____ ml Impinger water residue 102.8 mg

Impingers and back half of filter, acetone wash: Container No. CHE-3
Extra No. _____ Weight results 25.0 mg

Dry probe and cyclone catch: Container No. _____
Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. CHE-3
Extra No. _____ Weight results 87.2 mg

Filter Papers and Dry Filter Particulate

Filter number Container no. Filter number Container no.

000252 0.6749

Filter particulate weight 629.0 mg

~~PR~~ particulate weight 176.2 mg

TOTAL " PR cyclone & filter 244.9

Silica Gel

Weight after test: 193.5

Weight before test: 183.5

Moisture weight collected: 10.0

Moisture total 10.0 gm

Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: CHE-3 Analyze for: _____

Method determination: _____

Comments: _____

Bo. # 11

PARTICULATE CLEANUP SHEET

Date: 2/16/72 Plant: Astakula #20
Run number: 2nd Run CHE-4 Location of sample port: Central Hood
Operator: _____ Barometric pressure: 29.60
Sample box number: Inson - I Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 406 ml Container No. CHE-4 Ether-chloroform extraction
Impinger prefilled with 400 ml Extra No. _____ of impinger water 0.9 mg
Volume collected 6 ml Impinger water residue 58.1 mg

Impingers and back half of
filter, acetone wash:

Container No. CHE-4
Extra No. _____ Weight results 9.7 mg

Dry probe and cyclone catch:

Container No. _____
Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and
front half of filter,
acetone wash:

Container No. CHE-4
Extra No. _____ Weight results 50.7 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>000257</u>	<u>0.6821</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Filter particulate weight 125.5 mg
Total particulate weight 176.2 mg
TOTAL " PR Cyclone & Filter 244.9

Silica Gel

Weight after test: 197.6
Weight before test: 187.6
Moisture weight collected: 10.0 Moisture total 10.0 gm
Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: CHE-4 Analyze for: _____

Method determination: _____

Comments: _____

WATCH FOR GLASS IN THE
PARTICULATE CLEANUP SHEET AFTER FILTER WASH

Date: 2/16/72 Plant: #20010, Ashfield
Run number: SHE-2 Location of sample port: South Hood
Operator: CEG Barometric pressure: 28.90
Sample box number: 3 Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 392 ml Container No. SHE-2 Ether-chloroform extraction
Impinger prefilled with 400 ml Extra No. _____ of impinger water 26.9 mg
Volume collected - 8 ml Impinger water residue 87.3 mg

Impingers and back half of filter, acetone wash: Container No. SHE-2
Extra No. _____ Weight results 16.5 mg

Dry probe and cyclone catch: Container No. _____
Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. SHE-2
Extra No. _____ Weight results 293.0 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.	
<u>4 1/2" 000256</u>	<u>0.6708</u>	_____	_____	
<u>4 1/2" 000258</u>	<u>0.6991</u>	_____	_____	
_____	_____	_____	_____	Filter particulate weight <u>1828.5</u> mg
Total particulate weight				<u>2121.5</u> mg
TOTAL " Per Cyclone & Filter				<u>2252.2</u>

Silica Gel

Weight after test: 198.2
Weight before test: 181.0
Moisture weight collected: 17.2 Moisture total 17.2 gm
Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: SHE-2 Analyze for: _____

Method determination: _____

Comments: _____

RAC 4

PARTICULATE CLEANUP SHEET

Date: 2/15/72 Plant: VC ASHTABULA #20
Run number: SHE-3 Location of sample port: SawTh Hood
Operator: P. J. D. J. Barometric pressure: 28.90
Sample box number: 2 Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 393 ml Container No. SHE-3 Ether-chloroform extraction
Impinger prefilled with 400 ml Extra No. _____ of impinger water 2.6 mg
Volume collected, -7 ml Impinger water residue 22.8 mg

Impingers and back half of filter, acetone wash: Container No. SHE-3
Extra No. _____ Weight results 9.2 mg

Dry probe and cyclone catch: Container No. _____
Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. SHE-3
Extra No. _____ Weight results 202.2 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>000110</u>	<u>0.1245</u>	_____	_____
<u>000251</u>	<u>0.6634</u>	_____	_____
_____	_____	_____	_____

Filter particulate weight 1660.1 mg
Total particulate weight 1862.3 mg
TOTAL 11 Per Cyclone & Filter 1896.9

Silica Gel

Weight after test: 200.3
Weight before test: 182.6
Moisture weight collected: 17.7 Moisture total 17.7 gm
Container number: 1. RAC4 2. _____ 3. _____ 4. _____

Sample number: SHE-3 Analyze for: _____

Method determination: _____

Comments: _____

RAC #3

WATCH FOR GLASS AFTER THE FILTER
ON SHE #2
PARTICULATE CLEANUP SHEET

Date: _____ Plant: H.E. Ash. #20
Run number: SHE 4 Location of sample port: South Hood
Operator: _____ Barometric pressure: 28.90
Sample box number: RAC #3 Ambient temperature: 50°F
SAMPLE BOX #5
Impinger H₂O

Volume after sampling 402ml Container No. SHE-4 Ether-chloroform extraction
Impinger prefilled with 400 ml Extra No. _____ of impinger water 0.7 mg
Volume collected 2 ml Impinger water residue 15.7 mg

Impingers and back half of filter, acetone wash: Container No. SHE-4
Extra No. _____ Weight results 4.7 mg

Dry probe and cyclone catch: Container No. _____
Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. SHE-4
Extra No. _____ Weight results 67.9 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.	Filter particulate weight
<u>000253</u>	<u>06542</u>	_____	_____	<u>361.7</u> mg
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
Total particulate weight				<u>429.6</u> mg
TOTAL " PR cyclone & filter				<u>450.7</u>

Silica Gel

Weight after test: 194.8 _____
Weight before test: 183.2 _____
Moisture weight collected: 11.6 _____ Moisture total 11.6 gm
Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: SHE-4 Analyze for: _____
Method determination: _____
Comments: _____

GI #2: Loaded 2/16/72

PARTICULATE CLEANUP SHEET

Date: 2-16-72 Plant: ASH #20
Run number: ~~ATE-1~~ ATE-1 Location of sample port: TAP 67
Operator: _____ Barometric pressure: 29.1
Sample box number: #10 Ambient temperature: 50°

Impinger H₂O

Volume after sampling 394 ml Container No. ATE-1 Ether-chloroform extraction
Impinger prefilled with 400 ml Extra No. _____ of impinger water 0.7 mg
Volume collected -6 ml Impinger water residue 0 mg

Impingers and back half of filter, acetone wash: Container No. ATE-1
Extra No. _____ Weight results 6.6 mg

Dry probe and cyclone catch: Container No. _____
Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. ATE-1
Extra No. _____ Weight results 13.7 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>000115</u>	<u>0.1755</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Filter particulate weight 158.4 mg
Total particulate weight 172.1 mg
TOTAL " PB Cyclone & Filter 179.4

Silica Gel

Weight after test: 194.2
Weight before test: 187.1
Moisture weight collected: 7.1 Moisture total 7.1 gm
Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: ATE-1 Analyze for: _____

Method determination: _____

Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2/17/72 Plant: ~~WFO~~ ASHTABULA #20
 Run number: ATE-2 Location of sample port: TAP EXHAUST
 Operator: ALERY Barometric pressure: 29.1
 Sample box number: 9 Ambient temperature: 50°

Impinger H₂O

Volume after sampling 400 ml Container No. ATE-2 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 0.2 mg
 Volume collected 0 ml Impinger water residue 0 mg

Impingers and back half of filter, acetone wash: Container No. ATE-2
 Extra No. _____ Weight results 34.3 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. ATE-2
 Extra No. _____ Weight results 7.0 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.	
<u>000250</u>	<u>0.6782</u>			
				Filter particulate weight <u>81.6</u> mg
				Total particulate weight <u>88.6</u> mg
				TOTAL " PR cyclone & filter <u>123.1</u>

Silica Gel

Weight after test: 190.1
 Weight before test: 186.2
 Moisture weight collected: 3.9 Moisture total 3.9 gm
 Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: ATE-2 Analyze for: _____

Method determination: _____

Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2/18/72 Plant: ASHTABULA #20
 Run number: ATE-3 Location of sample port: JAY EXHAUST
 Operator: _____ Barometric pressure: 29.1
 Sample box number: No. 11 Ambient temperature: 50°

Impinger H₂O

Volume after sampling 402 ml Container No. ATE-3 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 0.1 mg
 Volume collected 0 ml Impinger water residue 0 mg

Impingers and back half of filter, acetone wash: Container No. ATE-3
 Extra No. _____ Weight results 2.4 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. ATE-3
 Extra No. _____ Weight results 18.7 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.	
<u>000231</u>	<u>0.6960</u>	_____	_____	
_____	_____	_____	_____	Filter particulate weight <u>175.8</u> mg
_____	_____	_____	_____	Total particulate weight <u>194.5</u> mg
TOTAL				PR cyclone & filter <u>197.0</u>

Silica Gel

Weight after test: 187.5
 Weight before test: 182.2
 Moisture weight collected: 5.3 Moisture total 5.3 gm
 Container number: 1. 11 2. _____ 3. _____ 4. _____

Sample number: ATE-3 Analyze for: _____

Method determination: _____

Comments: _____

RAC #4 2/16/72

PARTICULATE CLEANUP SHEET

Date: _____ Plant: THE ASHTABULA #20
 Run number: ASE-1 Location of sample port: scrubber exhaust
 Operator: _____ Barometric pressure: 29.10
 Sample box number: #2 Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 326 ml Container No. ASE-1 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 1.8 mg
 Volume collected 24 ml Impinger water residue 1.3 mg

Impingers and back half of filter, acetone wash: Container No. ASE-1
 Extra No. _____ Weight results 18.5 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. ASE-1
 Extra No. _____ Weight results 65.4 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>00250</u>	<u>0.6192</u>	_____	_____
<u>00159</u>	<u>0.1787</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Filter particulate weight 10.8 mg
 Total particulate weight 76.2 mg
 TOTAL " PR cyclone & filter 92.8

Silica Gel

Weight after test: 180.5
 Weight before test: 177.7
 Moisture weight collected: 2.8 Moisture total 2.8 gm
 Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: ASE-1 Analyze for: _____
 Method determination: _____
 Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2-16-72 Plant: SE 2000H #20
 Run number: ASE-2 Location of sample port: Scrubber Exhaust
 Operator: _____ Barometric pressure: 29.10
 Sample box number: 7 Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 400 ml Container No. ASE-2 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 22.1 mg
 Volume collected 00 ml Impinger water residue 1.9 mg

Impingers and back half of filter, acetone wash: Container No. ASE-2
 Extra No. _____ Weight results X mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. ASE-2
 Extra No. _____ Weight results 77.2 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.	
<u>000147</u>	<u>0.17212</u>			
				Filter particulate weight <u>3.2</u> mg
				Total particulate weight <u>80.4</u> mg
				TOTAL <u>11</u> PR cyclone & filter <u>104.4</u>

Silica Gel

Weight after test: 196.5
 Weight before test: 122.0
 Moisture weight collected: 7.5 Moisture total 7.5 gm
 Container number: 1. Pac 4 2. _____ 3. _____ 4. _____

Sample number: ASE-2 Analyze for: _____
 Method determination: _____
 Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2-16-72 Plant: ASHTABULA H 20
 Run number: ASE-3 Location of sample port: Scrubber Exhaust
 Operator: _____ Barometric pressure: 29.1
 Sample box number: 1A Rac No. 2 Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 400 ml Container No. ASE-3 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 24.8 mg
 Volume collected 0 ml Impinger water residue 2.7 mg

Impingers and back half of filter, acetone wash: Container No. ASE-3
 Extra No. _____ Weight results X mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. ASE-3
 Extra No. _____ Weight results 69.5 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>000108</u>	<u>WT 0.1775</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
Filter particulate weight			<u>4.4</u> mg
Total particulate weight			<u>73.9</u> mg
TOTAL " PR cyclone & filter			<u>101.4</u>

Silica Gel

Weight after test: 198.0 _____
 Weight before test: 187.8 _____
 Moisture weight collected: 10.2 _____ Moisture total 10.2 gm
 Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: ASE-3 Analyze for: _____
 Method determination: _____
 Comments: _____

FLANCE #13

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

VW - 2.6
 %CO₂ 0.0 A
 %O₂ 20.7
 KS
 As - 2499
 ach MF - 4129
 MT - 4218

Page 18 1/2

Plant ~~HE~~ Ash Tabula #13

Ambient Temp °F **45°**

Run No. **NEH-1**

Sample Box No. 4

Bar. Press. "Hg 30.0

Location: NORTH EAST HOOD Calhoun Meter Box

Meter Box No. 2

Assumed Moisture % 3%

Date 2/22/72

Probe Length 5

Heater Box Setting, °F 250

Date 2/22/72
Operator ~~Air Force~~ Patchell

Probe Heater Setting 5090

Probe Tip Dia., In. $\frac{3}{16}$ " 1825

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	1413	979.65	none	1.0	1.0		Start					
A-1	1416	980.90	.0	1.0	1.0	58	56	4	250	50	30.0	120
-2	1419	982.64	.0	1.0	1.0	62	56	4		50		110
-3	1422	984.20	.09	1.0	1.0	66	57	4		50		105
-4	1425	985.85	.08	1.0	1.0	70	58	4		50		105
-5	1428	987.60	.06	1.0	1.0	74	59	4		50		100
Step 6	1431	989.16	.06	1.0	1.0	74	60	4		50		95
START	1434	989.16	Port B									
B-1	1437	990.89	.09	1.0	1.0	76	62	4		50		150
-2	1440	992.54	.10	1.0	1.0	79	62	4		50		145
-3	1443	994.20	.10	1.0	1.0	79	64	4		50		128
-4	1446	995.77	.09	1.0	1.0	82	65	4		50		11
-5	1449	997.50	.08	1.0	1.0	84	66	4		50		106
Step 6	1452	999.24	.00	1.0	1.0	84	67	4		50		97
START	1454	999.24	Port C									
C-1	1457	000.90	.04	1.0	1.0	84	68	4		55		180
2	1500	002.57	.12	1.0	1.0	85	69	4		55		168
3	1503	004.27	.06	1.0	1.0	86	70	4		55		132
4	1506	005.93	.06	1.0	1.0	87	71	4		55		118
5	1509	007.61	.05	1.0	1.0	88	72	4		55		120
Step 6	1512	009.21	.05	1.0	1.0	86	72	4		55		115
Continued on next page												

[illegible]

Comments:

NCAP-37 (12/67)

UC ash
Run 1
North East
2/22/72

A. B. C. D.

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Plant WE ASHTABUGEN #13Run No. NEH-2Sample Box No. RAC 4Location NORTH EAST Wood ExhaustDate 2/23/72Probe Length 6'Operator PAUL H. REYNOLDSProbe Heater Setting 50%

U_W 4.4
%CO₂ 0.0
%O₂ 20.7
A_s - 2499
M_F - 2041
M_T - 2222

Ambient Temp °F 55Bar. Press. "Hg 29.68Assumed Moisture % 2%Heater Box Setting, °F 250Probe Tip Dia., In. 3/16, .1875

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	0859	019.45	Start						250		29.68	60
A-1	0902	021.10	.01	1.0	1.0	55	52	4		50		50
-2	0905	022.72	.05	1.0	1.0	58	53	4		50		45
-3	0908	024.34	.06	1.0	1.0	62	53	4		50		68
-4	0911	025.95	.07	1.0	1.0	65	54	4		50		83
-5	0914	027.63	.07	1.0	1.0	67	54	4		50		78
Step-6	0917	029.28	.07	1.0	1.0	68	55	4		50		90
START	0919	29.28	Part B									118
B-1	0922	030.94	.07	1.0	1.0	70	57	4		50		130
-2	0925	032.59	.08	1.0	1.0	72	58	4		50		123
-3	0928	034.24	.09	1.0	1.0	73	58	4		50		100
-4	0931	035.88	.09	1.0	1.0	76	59	4		50		75
-5	0934	037.54	.08	1.0	1.0	77	60	4		50		80
Step-6	0937	039.20	.06	1.0	1.0	77	61	4		50		
START	0941	39.20	Part C									140
C-1	0944	040.84	.07	1.0	1.0	72	63	4		50		140
-2	0947	042.52	.07	1.0	1.0	78	63	4		50		118
-3	0950	044.18	.05	1.0	1.0	80	64	4		50		98
-4	0953	045.84	.05	1.0	1.0	81	65	4		50		85
-5	0957	047.49	.05	1.0	1.0	82	66	4		50		78
Step-6	1000	049.19	.04	1.0	1.0	82	66	4		50		78

Continue Page-2

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Plant ~~is~~ *Astilbe* #13

Run No. **NEH-3**

Location *North East #13*

Dzta 2/23/72

Operator Patchell/Mr Reynolds

Sample Box No. *Rac 4*

Meter Box No. Pac 2

Probe Length 6'

Probe Heater Setting **60%**

Vw. 9.2

 σ_{CO_2} 0.0

200, 20.7

As - 2499

ME - 2094

MT- 2273

Ambient Temp °F 55

Bar. Press. "Hg 29.68

Assumed Moisture % 2

Heater Box Setting, °F 250

Probe Tip Dia., In. 3/16 .1875

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
one point #3 for hole A												
A-1	1218	059.31	Start	1.0		55	55					62
-2	1222	614.2	.08		.98	60	55	4"	250	50	29.68	120
-3	1224	6247	.08		.98	60	55	4		50		120
-4	1227	64.19	.08		.99	64	55	4		50		100
-5	1230	65.79	.08		.99	69	55	4		50		110
-6	1233	67.44	.08		.99	69	55	4		50		130
Start	1236	69.23	.08		.99	70	55	4		50		0
B-1	1239	69.23	Pitot B									108
-2	1242	070.97	.06		1.0	74	59	4		55		122
-3	1245	072.65	.09		1.0	75	59	4		55		140
-4	1248	074.33	.09		1.0	77	61	4		55		125
-5	1251	075.99	.08		1.0	79	62	4		55		90
-6	1254	077.70	.07		1.0	80	63	4		55		80
Start	1258	080.28	.08		1.0	82	64	4		55		70
C-1	1301	80.28	Pitot C									110
-2	1304	081.93	.08		1.0	80	66	4		55		150
-3	1307	083.62	.09		1.0	81	66	4		55		130
-4	1310	085.27	.06		1.0	82	67	4		55		108
-5	1313	086.97	.06		1.0	84	68	4		55		91
-6	1316	088.59	.05		1.0	86	69	4		55		78
Stop	1319	090.19	.05		1.0	86	70	4		55		80
V Cont on next page (2)												

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Plant Azadirachta ~~sp.~~ ~~R/1~~ #13

Run No. NW H-1

Sample Box No. GI-2

Location North west hood Exhaust

Meter Box No. 67-

Date Avery

Probe Length 5' pyrex

Operator 2122/72

Probe Heater Setting 5070

Ambient Temp °F 55

Bar. Press. "Hg 30.0

Assumed Moisture % 3

Heater Box Setting, °F 250

Probe Tip Dia., In. 3/16, 1825

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
Start	1412	223.20										
A-1	1415	224.73	.60	.87	.87	60	60	5.5	250	55	30.0	75
A-2	1418	226.63	1.1	1.6	1.6	65	65	8.0				95
A-3	21	228.89	1.6	2.3	2.3	70	70	12.5				100
A-4	24	231.20	1.6	2.3	2.3	70	70	12.5				110
A-5	27	233.60	1.7	2.4	2.3	75	75	12.5				100
Step A-6	1430	235.47	1.0	1.46	1.46	75	75	8.0				120
Start	1437	235.47										
C-1	1440	237.76	1.6	2.3	2.3	70	70	12.5				110
C-2	1443	240.06	1.5	2.1	2.1	70	70	11.0				85
C-3	46	242.38	2.2	3.0	2.3	70	70	12.5				115
C-4	49	244.66	2.2	3.0	2.3	70	70	12.5				125
C-5	52	247.06	2.1	2.95	2.3	70	70	12.5				120
C-6	55	249.40	1.6	2.3	2.3	75	75	12.5				120
C-6	58	251.75	1.6	2.3	2.3	75	75	12.5				125
C-5	1501	254.09	1.6	2.3	2.3	80	80	12.5				125
C-4	1504	256.44	2.1	2.95	2.3	80	80	12.5				125
C-3	07	258.80	2.2	3.0	2.3	85	85	12.5				130
C-2	10	261.18	2.1	2.95	2.3	85	85	12.5				130
Step 1	1513	263.81	1.6	2.3	2.3	85	85	12.5				130

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Plant Astobula ~~flm~~ #13Run No. NWH - 2Sample Box No. GI-2Location North-West Wind ExhaustMeter Box No. GIDate 2/23/72Probe Length 5' PyrexOperator AVERYProbe Heater Setting 50%

UW - 2.0
%CO₂ - 0.0
%O₂ - 20.7
AS - 2223
MF - 954
MT - 1640

Ambient Temp °F 50Bar. Press. "Hg 29.68Assumed Moisture % 2%Heater Box Setting, °F 250Probe Tip Dia., In. 3/16, 1875

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	8:54	277.20				50	50		250	55	29.68	
A-1	8:57	278.63	.60	.83	.83	55	55	5.0				65
A-2	9:00	280.60	1.3	1.75	1.75	55	55	5.0				65
A-3	9:03	282.92	1.7	2.3	2.3	60	60	12.0				65
A-4	9:06		1.8	2.4	2.3	60	60	12.0				65
A-5	9:09	287.62	1.7	2.3	2.3	65	65	12.0				80
A-6	9:12	289.60	.95	1.3	1.3	65	65	7.0				80
START	9:14	289.66										
C-1	9:18	291.50	1.2	1.6	1.6	70	70	7.0				90
C-2	9:20	293.75	1.8	2.4	2.35	75	75	12.0				85
C-3	9:23	296.13	1.9	2.5	2.35	75	75	12.0				80
C-4	9:26	298.51	1.8	2.4	2.3	80	80	12.0				90
C-5	9:29		1.5	2.0	2.0	80	80	9.5				90
C-6	9:32	302.85	1.3	1.75	1.75	80	80	8.0				95
C-6	9:35	304.91	1.3	1.75	1.75	85	80	8.0				15
C-5	9:38	302.10	1.5	2.0	2.0	85	80	9.0				95
C-4	9:41		1.3	2.3	2.3	90	85	12.0				105
C-3	9:44	311.88	1.9	2.5	2.3	90	85	12.0				110
C-2	9:47	314.31	1.9	2.5	2.3	95	90	12.0				105
STOP	9:50	316.36	1.3	1.75	1.75	95	90	8.0				110

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Vw 6.9
 %CO₂ 0.0
 %O₂ 20.7
 AS - 2223
 MA - 699
 MT - 804
 Ambient Temp

Ambient Temp °F

Bar. Press. "Hg 29.68

Assumed Moisture % 3

Heater Box Setting, °F 250

Probe Tip Dia., In.

Plant *Astobula* #13

Run No. NW H - 3

Location North west Hood

Date 2/23/72

Operator Avery

Sample Box No. GI-2 #16

Meter Box No. GI

Probe Length 5' Pyrex

Probe Heater Setting 50%

[illegible]

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Plant W/B, Chtabula #13Run No. SEH-2Sample Box No. 2Location South East hood ExhaustMeter Box No. 3Date 2/23/72Probe Length 5'Operator GonzalesProbe Heater Setting 70Vw 2.9

10/2

%CO₂ 0.0%O₂ 20.7AS - 2499MF 68.7MT 76.2Ambient Temp °F 40Bar. Press. "Hg 29.68Assumed Moisture % 2Heater Box Setting, °F 250Probe Tip Dia., In. 3/16 .1875

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	0851	246.94	.22	.26	.26	38	38	1.5	250	50	29.68	45
A-1	54		.34	.43	.43	40	40	1.5				70
-2	57		.37	.46	.46	40	40	2.0				60
-3	0900		.38	.47	.47	44	40	2.0				60
-4	03		.40	.50	.50	46	40	2.0				60
-5	06		.40	.50	.50	48	40	2.0				60
-6	09		.40	.50	.50	48	40	2.0				60
START	0912		.22	.26	.26	52	42	1.5				50
B-1	15		.34	.43	.43	52	44	2.0				50
-2	18		.44	.54	.54	56	46	2.0				100
-3	21		.45	.56	.56	62	48	2.0				100
-4	24		.45	.56	.56	64	50	2.0				80
-5	27		.40	.50	.50	66	50	2.0				70
-6	30		.40	.50	.50	68	52	2.0				70
START	0932		.25	.31	.31	68	52	2.0				70
C-1	35		.43	.53	.53	64	52	2.0				85
-2	38		.35	.43	.43	66	52	2.0				80
-3	41		.15	.19	.19	66	52	1.5				60
-4	44		.20	.25	.25	62	50	1.5				60
-5	47		.40	.50	.50	62	50	2.0				40
-6	50		.40	.50	.50	62	50	2.0				50

2 7 2

D-56

NCAP-37 (12/67)

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Plant ~~SEH~~, Ashtray #13

Run No. SEH-3

Location South East Exhaust

Date 2/23/72

Operator Douglas

Sample Box No. 2

Meter Box No. 3

Probe Length 5'

Probe Heater Setting 70

U.W. 4.1 1 of 2

O₂ 0.0CO₂ 20.7

AS -2499

MF - 868

MT - 90.7

Ambient Temp °F 42

Bar. Press. "Hg 29.68

Assumed Moisture % 2

Heater Box Setting, °F 250

Probe Tip Dia., In. 1/4, 250

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	1221	269.33	.25	.96	.96	42	42	3.0	250	60	29.68	70
A-1	24		.28	1.10	1.10	46	44	3.0				90
-2	27		.33	1.30	1.30	48	46	3.5				110
-3	30		.34	1.31	1.31	52	50	3.5				90
-4	33		.33	1.30	1.30	58	54	3.5				85
-5	36		.30	1.15	1.15	60	56	3.0				50
-6	39		.30	1.15	1.15	60	56	3.0				50
START	1241		.23	.82	.82	68	60	2.5				95
B-1	44		.33	1.30	1.30	64	60	3.5				105
-2	47		.38	1.45	1.45	64	60	4.0				100
-3	50		.40	1.55	1.55	66	62	4.0				95
-4	53		.40	1.55	1.55	72	68	4.0				105
-5	56		.36	1.40	1.40	74	70	3.5				80
-6	59		.36	1.40	1.40	74	70	3.5				80
START	1302		.25	.97	.97	68	68	3.0				110
C-1	05		.42	1.60	1.60	70	68	4.0				80
-2	08		.34	1.32	1.32	74	72	3.5				70
-3	11		.13	.52	.52	74	70	3.0				70
-4	14		.26	.98	.98	70	68	3.0				50
-5	17		.42	1.60	1.60	70	66	3.5				50
-6	20		.42	1.60	1.60	68	66	3.5				55

202

D-58

NCAP-37 (12/67)

PARTICULATE FIELD DATA

4 holes
A B C D
Left to right
A B C D

Inlet
61" wide
36" deep

VERY IMPORTANT -- FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Plant Alloy ASTabula #13Run No. SWH-1Sample Box No. 2Location South West Hood ExhaustMeter Box No. 4Date 2-22-72Probe Length 5'Operator BAXLEYProbe Heater Setting 6070Ambient Temp °F 45°Bar. Press. "Hg 30.0Assumed Moisture % 3%Heater Box Setting, °F 250°Probe Tip Dia., In. 3/16" .1875

U_w 1.6
%CO₂ 0.0
%O₂ 20.7
As - 2148
Mf - 1723
Mt - 1837

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	14:15	898.26										
3	14:18	900.00	1.30	1.60	1.60	50	50	3.0	250	50	29.9	40
A-9	14:21	902.02	2.00	2.40	2.40	50	50	4.0		50		40
15	14:24	904.42	2.10	2.60	2.60	64	50	5.0		50		40
21	14:27	906.95	2.10	2.60	2.60	70	50	5.0		50		40
27	14:30	909.40	2.10	2.60	2.60	72	50	5.0		50		40
STOP 33	14:33	911.82	1.90	2.30	2.30	80	54	5.0		50		40
START	14:34	911.82										
3	14:37	914.22	1.90	2.30	2.30	84	58	5.0		50		40
9	14:40	916.74	2.20	2.70	2.70	86	60	5.0		50		42
B-15	14:43	919.30	2.20	2.70	2.70	88	60	5.0		50		48
21	14:46	921.90	2.10	2.60	2.60	90	60	5.0		50		50
27	14:49	924.38	2.00	2.40	2.40	92	60	4.5		50		50
STOP 33	14:52	926.82	1.80	2.20	2.20	92	62	4.0		50		53
START	14:53											
3	14:56	928.07	1.70	2.10	2.10	92	62	4.0		50		46
9	14:59	931.12	1.90	2.30	2.30	92	62	3.5		50		48
C-15	15:02	933.33	1.80	2.20	2.20	92	62	3.5		50		50
21	15:05	935.65	1.80	2.20	2.20	94	62	4.0		50		70
27	15:08	937.80	1.60	2.00	2.00	94	66	4.0		50		77
STOP 33	15:11	940.03	1.60	2.00	2.00	96	66	4.0		50		90
START	15:13											
3	15:16	942.10	1.30	1.60	1.60	96	66	3.5		55		85
D-9	15:19	944.00	1.30	1.60	1.60	96	66	3.5	✓	55	✓	80

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

U_w - .6
%CO₂ - 2.0
%O₂ - 19.7
AS - 2148
MF - 952
MT - 1467

Plant ASTRO-13 #13Run No. SWH-2Location Lowest Head ExhaustDate 2-23-72Operator BAXLEYSample Box No. 3Meter Box No. 4Probe Length 5'Probe Heater Setting 60Ambient Temp °F 50Bar. Press. "Hg 29.68Assumed Moisture % 3Heater Box Setting, °F 250Probe Tip Dia., In. 3/16" 11875

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	0855	953.09										
3	0858	955.04	1.40	1.70	1.70	50	50	4.5	250	50	29.68	30
9	0901	957.14	1.60	1.95	1.95	58	50	4.5		50		30
15	0904	959.25	1.70	2.00	2.00	64	50	5.0		50		30
21	0907	961.50	1.70	2.00	2.00	68	50	5.0		50		30
27	0910	963.73	1.80	2.20	2.20	74	54	5.2		50		30
STOP 33	0913	966.02	1.70	2.00	2.00	76	54	5.0		50		35
START	0914	966.02										
3	0917	968.30	1.70	2.00	2.00	78	56	5.0		50		30
9	0920	970.60	2.00	2.45	2.45	82	56	6.0		50		32
15	0923	973.10	2.00	2.45	2.45	84	56	6.0		50		32
21	0926	975.60	2.00	2.45	2.45	88	58	6.0		50		32
27	0929	978.00	1.80	2.20	2.20	88	58	5.5		50		40
STOP 33	0932	980.27	1.70	2.00	2.00	90	60	5.0		50		40
START	0933	980.27										
3	0936	982.16	1.10	1.30	1.30	92	62	3.5		50		45
9	0939	984.20	1.00	1.20	1.20	92	62	4.0		50		42
15	0942	986.31	1.50	1.80	1.80	92	62	4.0		50		42
21	0945	988.40	1.40	1.70	1.70	92	62	4.5		50		50
27	0948	990.46	1.40	1.70	1.70	92	64	4.5		50		55
STOP 33	0951	992.42	1.20	1.45	1.45	92	64	4.0		50		68
START	0952	992.42										
3	0955	994.30	1.10	1.30	1.30	92	64	4.0		50		75
9	0958	996.35	1.40	1.70	1.70	92	64	4.5	✓	50	✓	65

(2 of 2 sheets)

Comments:

NCAP-37 (12/67)

Left to right

A B C D

(1 of 2 sheets)

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Uw. 7.5
%CO₂ 0.0
%O₂ 20.7
As - 2148
MF - 1224
MT. 2177

Plant ASHTADURA #13Run No. SWH-3Location So. West Hood InletDate 2-23-72Operator BaxleySample Box No. 3Meter Box No. 4Probe Length 5'Probe Heater Setting 60Ambient Temp °F 115Bar. Press. "Hg 29.68Assumed Moisture % 3Heater Box Setting, °F 250Probe Tip Dia., In. 3/16" 1875

SWH-3 Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
START	12:28	10.72										
A-3	12:31	12.58	1.10	1.35	1.35	62	54	4.0	250	50	29.6	40
9	12:34	14.64	1.60	1.95	1.95	72	54	5.5		50		42
A	15	12:37	16.80	1.60	1.95	78	56	5.5		50		42
21	12:40	18.96	1.60	1.95	1.95	80	56	6.0		50		42
27	12:43	21.15	1.60	1.95	1.95	86	56	6.0		50		42
STOP 33	12:46	23.14	1.30	1.60	1.60	88	58	5.0		50		45
START	12:47	23.14										
B-3	12:50	25.26	1.50	1.80	1.80	90	58	5.5		50		45
9	12:53	27.56	1.90	2.20	2.20	94	60	6.5		50		45
15	12:56	29.91	1.90	2.20	2.20	96	60	6.5		50		45
B	21	12:59	32.23	1.80	2.15	96	62	6.0		50		50
27	13:02	34.14	1.10	1.35	1.35	98	64	4.5		50		50
STOP 33	13:05	36.21	1.50	1.80	1.80	100	66	5.5		50		50
START	13:06	36.21										
C-3	13:09	38.08	1.10	1.35	1.35	100	66	4.5		50		50
9	13:12	40.08	1.40	1.70	1.70	102	66	5.0		50		50
15	13:15	42.19	1.50	1.80	1.80	102	66	5.5		50		50
C	21	13:18	44.26	1.40	1.70	102	68	5.0		50		60
27	13:21	46.33	1.40	1.70	1.70	102	70	5.0		50		75
STOP 33	13:24	48.32	1.30	1.55	1.55	102	70	5.0		50		90
START	13:25	48.32										
D-3	13:28	50.17	1.10	1.35	1.35	102	70	4.5		50		75
9	13:31	52.25	1.40	1.70	1.70	102	70	5.0	✓	50	✓	75

VERY IMPORTANT - FILL IN ALL BLANKS

Stack
dis gram
+ dis layer
from part

Uw, 9.3
NoCO₂ 0.0
PO₂ 20.8
AS 2124
MF 0481.0
MT 511.7

Plant Asfobolus ~~W. & A. m.~~

Run No. BTE-2

Location B Tap Exh.

Date 2/24/22

Operator Avery

Sample Box No. 6I-1

Meter Box No. 61

Probe Length 5' 0452x

Probe Heater Setting 50%

Ambient Temp °F 24 → 80

Bar. Press. "Hg 29.3

Assumed Moisture % 1%

Heater Box Setting, °F 250

Probe Tip Dia., In. 4.250

[illegible]

PARTICULATE FIELD DATA

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

$$U_w = 31.4$$
$$\%CO_2 \dots 0.0$$

% O₂ 20.8

As 2124

MF - 0.4658

MT 0.4750

Ambient Temp °F 80

Bar. Press. "Hg 29.3

Assumed Moisture % /

Heater Box Setting, °F 250

Probe Tip Dia., In. 1/4 .250

Plant Astablula #13 ~~W. J. J. J.~~

Run No. BT 3

Location B ~~Top~~ Exhaust.

Date 2/24/72

Operator *Avery*

Sample Box No. 6-2

Meter Box No. 65-2

Probe Length 5' pyrex

Probe Heater Setting 50%

[illegible]

Read and record at the start of each test point or, if single point sampling, read and record every 5 minutes.

Ambient Temp °F 65

Sample Box No. 4

Bar. Press. "Hg 29.34

Meter Box No. 2

Assumed Moisture % 1

Probe Length *Special*

Heater Box Setting, °F. 200

✓Probe Heater Setting ~~20~~

Probe Tip Dia., In. $\frac{1}{4}$ "

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
BSE-1	15:20	100.40										
	15:30	106.32		1.00	1.00	60	60	5.0	100	50	2.7 in	~100
	15:40	112.55		1.00	1.00	72	60	5.5				
	15:50	118.40		1.00	1.00	80	65	6.0				
	16:00	123.30		1.00	1.00	80	70	6.0		40		
	16:10	130.65		1.00	1.00	80	70	7.0				
	16:20	138.72		1.00	1.00	80	70	8.0	✓	✓		
		<u>38.32</u>			1.00	75.33	65.83	6.25				
						70.58						

VERY IMPORTANT - FILL IN ALL BLANKS

Plant HSkTabo/a

Ambient Temp °F 78

Run No. BSE-2 and 3

Sample Box No. 342

Bar. Press. "Hg 29.64

Location ~~Co. 1st~~ Scrubber

Meter Box No. 2

Assumed Moisture % 10

Date 2-24-72

Probe Length *Special*

Heater Box Setting, °F 100

Operator ~~Jerry J. Baxley~~ BAXLEY

Probe Heater Setting 

Probe Tip Dia., In. $\frac{1}{4}$ "

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F
				Desired	Actual	Inlet	Outlet					
BSE-2	08:55	136.72										
	09:05	142.36		1.00	1.00	78	78	4.0	100	50	2.16	~100
	09:15	148.50		1.00	1.00	84	78	4.0				
	09:25	154.38		1.00	1.00	90	78	4.0				
	09:35	160.22		1.00	1.00	96	78	4.0				
	09:45	166.13		1.00	1.00	100	82	4.0				
	09:55	172.04		1.00	1.00	104	84	4.0	✓	✓		
		35.32			1.00	92	79.66	4.0				
						85.83						
BSE-3	10:10	172.14										
	10:20	178.12		1.00	1.00	92	86	4.0	100	60	2.16	~100
	10:30	184.10		1.00	1.00	98	86	4.5				
	10:40	190.10		1.00	1.00	102	86	5.0				
	10:50	196.14		1.00	1.00	104	86	5.5				
	11:00	202.25		1.00	1.00	106	86	6.0				
	11:10	208.35		1.00	1.00	106	86	6.0	✓	✓		
		36.11			✓ 1.00	101.33	86	5.16				
						93.67						

PARTICULATE CLEANUP SHEET

Impinger H₂O

RAC #4

PARTICULATE CLEANUP SHEET

Date: 2-22-72 Plant: ~~ASH~~ Ash #13
 Run number: NEH 2 Location of sample port: North East Hood
 Operator: Jim Gordon Barometric pressure: 29.80
 Sample box number: #4 Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 393 ml Container No. NEH-2 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 0 mg
 Volume collected -7 ml Impinger water residue 7.4 mg

Impingers and back half of filter, acetone wash: Container No. NEH-2
 Extra No. _____ Weight results 10.7 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. NEH-2
 Extra No. _____ Weight results 58.0 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>000 230</u>	<u>0.6870</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
		Filter particulate weight	<u>146.1</u> mg
		_____ particulate weight	<u>204.1</u> mg
		<u>TOTAL</u>	<u>PR cyclone & filter</u> <u>222.2</u>

Silica Gel

Weight after test: 191.3
 Weight before test: 179.9
 Moisture weight collected: 11.4 Moisture total 11.4 gm
 Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: NEH-2 Analyze for: _____

Method determination: _____

Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2/23/72 Plant: NEH Ash # 13
 Run number: NEH-3 Location of sample port: NE
 Operator: Jim Barometric pressure: 29.80
 Sample box number: 4 Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 996 ml Container No. NEH-3 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water _____ mg
 Volume collected 29 ml Impinger water residue 4.3 mg

Impingers and back half of filter, acetone wash: Container No. NEH-3
 Extra No. _____ Weight results 13.4 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. NEH-3
 Extra No. _____ Weight results 51.2 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>000227</u>	<u>.6769</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
		Filter particulate weight	<u>158.4</u> mg
		Total particulate weight	<u>209.6</u> mg
		TOTAL	<u>227.3</u>

PR cyclone & filter

Silica Gel

Weight after test: 202.4
 Weight before test: 199.2
 Moisture weight collected: 13.2 Moisture total 13.2 gm
 Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: NEH-3 Analyze for: _____
 Method determination: _____
 Comments: _____

Box # 16
PARTICULATE CLEANUP SHEET

Date: 2/22/72 Plant: Astakula ~~13~~ #13
Run number: NW H-1 Location of sample port: North West tank
Operator: Avery Barometric pressure: 29.90
Sample box number: GI-2 Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 390 ml Container No. NW H-1 Ether-chloroform extraction
Impinger prefilled with 400 ml Extra No. _____ of impinger water 0.4 mg
Volume collected -10 ml Impinger water residue 6.5 mg

Impingers and back half of filter, acetone wash: Container No. NW H-1
Extra No. _____ Weight results 6.5 mg

Dry probe and cyclone catch: Container No. _____
Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. NW H-1
Extra No. _____ Weight results 59.2 mg

Filter Papers and Dry Filter Particulate

Filter number	Weight Container no.	Filter number	Container no.	
<u>000235</u>	<u>0.6666</u>	_____	_____	
_____	_____	_____	_____	
_____	_____	_____	_____	
				Filter particulate weight <u>20.5</u> mg
				Total particulate weight <u>129.7</u> mg
		<u>total</u>	<u>" PR gelene 2.2061</u>	<u>143.1</u>

Silica Gel

Weight after test: 198.4
Weight before test: 184.2
Moisture weight collected: 14.2 Moisture total 14.2 gm
Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: NW H-1 Analyze for: _____

Method determination: _____

Comments: _____

Box 16

PARTICULATE CLEANUP SHEET

Date: 2/23/72Plant: Astakula #13Run number: NWH-2Location of sample port: north west HoodOperator: Avery

Barometric pressure: _____

Sample box number: GI-2

Ambient temperature: _____

Impinger H₂OVolume after sampling 304 mlContainer No. NWH-2

Ether-chloroform extraction

Impinger prefilled with 400 ml

Extra No. _____

of impinger water _____ 0 mg

Volume collected -16 ml

Impinger water residue _____ 0 mg

Impingers and back half of
filter, acetone wash:Container No. NWH-2

Extra No. _____

Weight results _____ 4.6 mg

Dry probe and cyclone catch:

Container No. _____

Extra No. _____

Weight results _____ mg

Probe, cyclone, flask, and
front half of filter,
acetone wash:Container No. NWH-2

Extra No. _____

Weight results _____ 27.4 mg

Filter Papers and Dry Filter Particulate

Filter number

Container no.

Filter number

Container no.

0002460.6790

Filter particulate

weight _____ 32.0 mg

Total particulate weight

_____ 59.4 mg

total" PR epine 8.20m64.0

Silica Gel

Weight after test:

201.2

Weight before test:

187.2

Moisture weight collected:

14.0

Moisture total _____ 14.0 gm

Container number:

1. _____ 2. _____ 3. _____ 4. _____

Sample number: NWH-2

Analyze for: _____

Method determination: _____

Comments: _____

Box #16

PARTICULATE CLEANUP SHEET

Date: 2/23/72Plant: Astabula #13Run number: NWH-3Location of sample port: north west HarbOperator: AvryBarometric pressure: 29.75Sample box number: GE-2

Ambient temperature: _____

Impinger H₂OVolume after sampling 394 mlContainer No. NWH-3

Ether-chloroform extraction

Impinger prefilled with 400 ml

Extra No. _____

of impinger water 0 mgVolume collected 6 mlImpinger water residue 0 mgImpingers and back half of
filter, acetone wash:Container No. NWH-3

Extra No. _____

Weight results 10.5 mg

Dry probe and cyclone catch:

Container No. _____

Extra No. _____

Weight results _____ mg

Probe, cyclone, flask, and
front half of filter,
acetone wash:Container No. NWH-3

Extra No. _____

Weight results 38.5 mgFilter Papers and Dry Filter Particulate

Filter number Container no.

Filter number Container no.

000229 0.6920_____

_____Filter particulate
weight 36.4 mgTotal particulate weight69.9 mgtotal " PR cyclone & filter80.4Silica Gel

Weight after test:

197.8

Weight before test:

184.9

Moisture weight collected:

12.9Moisture total 12.9 gm

Container number:

1. _____ 2. _____ 3. _____ 4. _____

Sample number: NWH-3

Analyze for: _____

Method determination: _____

Comments: _____

RAC-3
2-23-72

PARTICULATE CLEANUP SHEET

Date: ~~SEH-2~~
Run number: ~~SEH-2~~
Operator: SEH-2
Sample box number: 2

Plant: Ashtabola #13
Location of sample port: So East Hood
Barometric pressure: 29.9°
Ambient temperature: 50°

Impinger H₂O

Volume after sampling 396 ml Container No. SEH-2 Ether-chloroform extraction
Impinger prefilled with 400 ml Extra No. _____ of impinger water 2.2 mg
Volume collected -4 ml Impinger water residue 1.7 mg

Impingers and back half of filter, acetone wash: Container No. SEH-2
Extra No. _____ Weight results 3.6 mg

Dry probe and cyclone catch: Container No. _____
Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. SEH-2
Extra No. _____ Weight results 28.8 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>000119</u>	<u>0.1753</u>	_____	_____
<u>000120</u>	<u>0.6774</u>	_____	_____
<u>000236</u>	<u>0.6749</u>	_____	_____

Filter particulate weight 39.9 mg
Total particulate weight 68.7 mg
TOTAL in PR cyclone & filter 76.2

Silica Gel

Weight after test: 188.2 195.1
Weight before test: 188.2 195.1
Moisture weight collected: 6.9 Moisture total 6.9 gm
Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: SEH-2 Analyze for: _____

Method determination: _____

Comments: _____

RAC-2

PARTICULATE CLEANUP SHEET

Date: 2-23-72 Plant: ASATAVOLA #13
 Run number: SEH-3 Location of sample port: So Cont. Hord
 Operator: ell Barometric pressure: 29.90
 Sample box number: 6 Ambient temperature: 50°

Impinger H₂O

Volume after sampling 394 ml Container No. SEH-3 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 0 mg
 Volume collected -6 ml Impinger water residue 0 mg

Impingers and back half of filter, acetone wash: Container No. SEH-3
 Extra No. _____ Weight results 3.9 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. SEH-3
 Extra No. _____ Weight results 32.0 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.	Filter particulate weight
<u>000226</u>	<u>0.6762</u>	_____	_____	<u>54.8</u> mg
_____	_____	_____	_____	<u>86.8</u> mg
_____	_____	_____	_____	<u>90.7</u> mg
Total particulate weight				
<u>TOTAL</u>				<u>PR cyclone & filter</u>

Silica Gel

Weight after test: 186.2
 Weight before test: 176.1
 Moisture weight collected: 10.1 Moisture total 10.1 gm
 Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: SEH-3 Analyze for: _____

Method determination: _____

Comments: _____

RHC:2

PARTICULATE CLEANUP SHEET

Date: 2-22-72 Plant: ASHTADOLZ #13
 Run number: SWH-1 Location of sample port: Se vent Hood
 Operator: Sandy Barometric pressure: 29.80
 Sample box number: 13 Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 384 ml Container No. SWH-1 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 0.9 mg
 Volume collected -16 ml Impinger water residue 0 mg

Impingers and back half of filter, acetone wash: Container No. SWH-1
 Extra No. _____ Weight results 5.5 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. SWH-1
 Extra No. _____ Weight results 73.0 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>000232</u>	<u>WT 0.6775</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
Filter particulate weight			<u>104.3</u> mg
Total particulate weight			<u>177.3</u> mg
TOTAL			<u>183.7</u>

Silica Gel

Weight after test: 185.2
 Weight before test: 177.6
 Moisture weight collected: 17.6 Moisture total 17.6 gm
 Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: SWH-1 Analyze for: _____

Method determination: _____

Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2-23-72

Plant: Ashtrite #13

Run number: SWH-2

Location of sample port: *So west Hand*

Operator: Handley

Barometric pressure: 29.80

Sample box number: 013

Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 384 ml

Container No. SW#2 Ether-chloroform extraction

Impinger prefilled with 400 ml

Extra No. _____ of impinger water 0.8 mg

Volume collected -16 ml

Impinger water residue 0 mg

Impingers and back half of filter, acetone wash:

Container No. SWA-2

Extra No.	Weight results	50.7	mg
-----------	----------------	------	----

Dry probe and cyclone catch:

Container No.

Extra No.	Weight results	mo
1	100	100
2	100	100
3	100	100
4	100	100
5	100	100
6	100	100
7	100	100
8	100	100
9	100	100
10	100	100
11	100	100
12	100	100
13	100	100
14	100	100
15	100	100
16	100	100
17	100	100
18	100	100
19	100	100
20	100	100
21	100	100
22	100	100
23	100	100
24	100	100
25	100	100
26	100	100
27	100	100
28	100	100
29	100	100
30	100	100
31	100	100
32	100	100
33	100	100
34	100	100
35	100	100
36	100	100
37	100	100
38	100	100
39	100	100
40	100	100
41	100	100
42	100	100
43	100	100
44	100	100
45	100	100
46	100	100
47	100	100
48	100	100
49	100	100
50	100	100
51	100	100
52	100	100
53	100	100
54	100	100
55	100	100
56	100	100
57	100	100
58	100	100
59	100	100
60	100	100
61	100	100
62	100	100
63	100	100
64	100	100
65	100	100
66	100	100
67	100	100
68	100	100
69	100	100
70	100	100
71	100	100
72	100	100
73	100	100
74	100	100
75	100	100
76	100	100
77	100	100
78	100	100
79	100	100
80	100	100
81	100	100
82	100	100
83	100	100
84	100	100
85	100	100
86	100	100
87	100	100
88	100	100
89	100	100
90	100	100
91	100	100
92	100	100
93	100	100
94	100	100
95	100	100
96	100	100
97	100	100
98	100	100
99	100	100
100	100	100

Probe, cyclone, flask, and
front half of filter,
acetone wash:

Container No. SWH-2

Extra No. Weight results 44.8 mg

Filter Papers and Dry Filter Particulate

Filter number Container no.

Filter number Container no.

~~000-120~~¹²⁰ W.F. ~~1776~~¹⁷⁷⁶

W. F. 1776
O. 1776

000236 0.6749

0.6749

Filter particulate weight 50.4 mg

~~Total~~ particulate weight 95.2 mg

TOTAL	"	PR on leave \$ 711.7	146.7
-------	---	----------------------	-------

Silica Gel

Weight after test: 194.8

Weight before test: 179,4 ~~185,2~~

Moisture weight collected: 15.4

Moisture total 15.4 gm

Container number: 1. 2. 3. 4.

Sample number: SWH-2 Analyze for: _____

Method determination:

Comments: _____

RAC-3

PARTICULATE CLEANUP SHEET

Date: 2-23-72 Plant: Ashtabula #13
 Run number: SWH-3 Location of sample port: So west Head
 Operator: Sandy Barometric pressure: 29.80
 Sample box number: 13 Ambient temperature: 45°F

Impinger H₂O

Volume after sampling 390 ml Container No. SWH-3 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 12.8 mg
 Volume collected -10 ml Impinger water residue 64.7 mg

Impingers and back half of filter, acetone wash: Container No. SWH-3
 Extra No. _____ Weight results 17.8 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. SWH-3
 Extra No. _____ Weight results 53.2 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>.000234</u>	<u>WT 0.6667</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
		Filter particulate weight	<u>69.2</u> mg
		Filter particulate weight	<u>122.4</u> mg
		TOTAL	<u>191.6</u> mg

PR Ashtabula #13 filter 217.7

Silica Gel

Weight after test: 200.9
 Weight before test: 183.4
 Moisture weight collected: 17.5 Moisture total 17.5 gm
 Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: SWH-3 Analyze for: _____

Method determination: _____

Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2/23/72 Plant: Astabula #13
Run number: BTE-1 Location of sample port: Top Exhaust
Operator: Amey Barometric pressure: 29.8
Sample box number: GE-2 Box 17 Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 394 ml Container No. BTE-1 Ether-chloroform extraction
Impinger prefilled with 402 ml Extra No. _____ of impinger water 0.1 mg
Volume collected -16 ml Impinger water residue 0.8 mg

Impingers and back half of filter, acetone wash: Container No. BTE-1
Extra No. _____ Weight results 11.2 mg

Dry probe and cyclone catch: Container No. _____
Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. BTE-1
Extra No. _____ Weight results 140.6 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>000239</u>	<u>0.6932</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
		Filter particulate weight	<u>395.4</u> mg
		Total particulate weight	<u>536.0</u> mg
		<u>Total</u> <u>PR cyclone & filter</u>	<u>548.1</u>

Silica Gel

Weight after test: 198.3
Weight before test: 185.5
Moisture weight collected: 12.8 Moisture total 12.8 gm
Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: BTE-1 Analyze for: _____

Method determination: _____

Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2/23/72 Plant: Ashtabula #13
 Run number: BTE-2 Location of sample port: #3 Top Exhaust
 Operator: _____ Barometric pressure: 29.80
 Sample box number: GI-1 #17 Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 392 ml Container No. BTE-2 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 0.5 mg
 Volume collected -8 ml Impinger water residue 4.7 mg

Impingers and back half of filter, acetone wash: Container No. BTE-2
 Extra No. _____ Weight results 25.5 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. BTE-2
 Extra No. _____ Weight results 63.6 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>000228</u>	<u>0.6840</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
			Filter particulate weight <u>417.4</u> mg
			Total particulate weight <u>481.0</u> mg
			<u>total</u> " PR cyclone & probe <u>511.7</u>

Silica Gel

Weight after test: 200.3
 Weight before test: 183.0
 Moisture weight collected: 17.3 Moisture total 17.3 gm
 Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: BTE-2 Analyze for: _____
 Method determination: _____
 Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2-24-72 Plant: Ashtabala # 13
 Run number: BTE-3 Location of sample port: Top Exhaust
 Operator: _____ Barometric pressure: 29.80
 Sample box number: 2 (GI) Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 404 ml Container No. BTE-3 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 0 mg
 Volume collected +4 ml Impinger water residue 0 mg

Impingers and back half of filter, acetone wash: Container No. BTE-3
 Extra No. _____ Weight results 9.2 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. BTE-3
 Extra No. _____ Weight results 99.8 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>1000238</u>	<u>0.6680</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
			Filter particulate weight <u>376.0</u> mg
			Total particulate weight <u>465.8</u> mg
			<u>total</u> " PR cyclone & filter <u>475.0</u>

Silica Gel

Weight after test: 220.0 _____
 Weight before test: 192.6 _____
 Moisture weight collected: 27.4 _____ Moisture total 27.4 gm
 Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: BTE-3 Analyze for: _____

Method determination: _____

Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2-24-72 Plant: Ashita-bula #13
 Run number: BSE-1 Location of sample port: B Scrubber Ex
 Operator: Jim MC Barometric pressure: 29.8
 Sample box number: #4 Ambient temperature: 45°

Impinger H₂O

Volume after sampling 401 ml Container No. BSE-1 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 0 mg
 Volume collected + 1 ml Impinger water residue 0 mg

Impingers and back half of filter, acetone wash: Container No. BSE-1
 Extra No. _____ Weight results 6.7 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. BSE-1
 Extra No. _____ Weight results 26.7 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.
<u>U. 1753</u>	<u>000119</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
Filter particulate weight <u>71.4</u> mg			
Total particulate weight <u>98.1</u> mg			
<u>total</u> " PR cyclone & filter <u>104.8</u>			

Silica Gel

Weight after test: 200.7
 Weight before test: 186.7
 Moisture weight collected: 14.0 Moisture total 14.0 gm
 Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: BSE-1 Analyze for: _____

Method determination: _____

Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2-24-72 Plant: Ashtabula
 Run number: BSE-2 Location of sample port: B. Sample Ep
 Operator: Jim Mc Barometric pressure: 29.8
 Sample box number: #3 Ambient temperature: 45°F

Impinger H₂O

Volume after sampling 396 ml Container No. BSE-2 Ether-chloroform extraction
 Impinger prefilled with 500 ml Extra No. _____ of impinger water _____ mg
 Volume collected -4 ml Impinger water residue _____ mg

Impingers and back half of filter, acetone wash: Container No. BSE-2
 Extra No. _____ Weight results 24.5 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. BSE-2
 Extra No. _____ Weight results 8.6 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.	
000120	0.1776			
<u>000120</u>	<u>0.1776</u>			
				Filter particulate weight <u>35.7</u> mg
				total particulate weight <u>44.3</u> mg
				<u>total</u> " PR cyclone & filter <u>68.8</u>

Silica Gel

Weight after test: 196.4
 Weight before test: 183.2
 Moisture weight collected: 13.2 Moisture total 13.2 gm
 Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: BSE-2 Analyze for: _____
 Method determination: _____
 Comments: _____

PARTICULATE CLEANUP SHEET

Date: 2-24-72 Plant: Ashtabula #13
 Run number: BSE-3 Location of sample port: Scrubber Exhaust
 Operator: _____ Barometric pressure: 29.80
 Sample box number: 4 Ambient temperature: 50°F

Impinger H₂O

Volume after sampling 388 ml Container No. BSE-3 Ether-chloroform extraction
 Impinger prefilled with 400 ml Extra No. _____ of impinger water 0 mg
 Volume collected 12 ml Impinger water residue 0 mg

Impingers and back half of filter, acetone wash: Container No. BSE-3
 Extra No. _____ Weight results 6.8 mg

Dry probe and cyclone catch: Container No. _____
 Extra No. _____ Weight results _____ mg

Probe, cyclone, flask, and front half of filter, acetone wash: Container No. BSE-3
 Extra No. _____ Weight results 4.8 mg

Filter Papers and Dry Filter Particulate

Filter number	Container no.	Filter number	Container no.	
<u>000129</u>	<u>0.1756</u>	_____	_____	
_____	_____	_____	_____	Filter particulate weight <u>64.6</u> mg
_____	_____	_____	_____	Total particulate weight <u>69.4</u> mg
				<u>total</u> <u>10 PR cyclone & filter</u> <u>26.2</u>

Silica Gel

Weight after test: 202.9
 Weight before test: 183.8
 Moisture weight collected: 19.1 Moisture total 19.1 gm
 Container number: 1. _____ 2. _____ 3. _____ 4. _____

Sample number: BSE-3 Analyze for: _____
 Method determination: _____
 Comments: _____

APPENDIX E
STANDARD SAMPLING PROCEDURES

Subpart E—Standards of Performance for Nitric Acid Plants

§ 466.50 Applicability and designation of affected facility.

(a) The provisions of this subpart are applicable to nitric acid plants.

(b) For purposes of § 466.11(e), the entire plant is the affected facility.

§ 466.51 Definitions.

As used in this part, all terms not defined herein shall have the meaning given them in the Act:

(a) "Nitric acid plant" means any facility producing weak nitric acid by either the pressure or atmospheric pressure process.

(b) "Weak nitric acid" means acid which is 50 to 70 percent in strength.

§ 466.52 Standard for nitrogen oxides.

No person subject to the provisions of this subpart shall cause or allow the discharge into the atmosphere of nitrogen oxides in the effluent which are:

(a) In excess of 3 lbs. per ton of acid produced (1.5 Kgm. per metric ton), maximum 2-hour average, expressed as NO_x .

(b) A visible emission within the meaning of this part.

§ 466.53 Emission monitoring.

(a) There shall be installed, calibrated, maintained, and operated, in any nitric acid plant subject to the provisions of this subpart, an instrument for continuously monitoring and recording emissions of nitrogen oxides.

(b) The instrument installed and used pursuant to this section shall have a confidence level of at least 95 percent and be accurate within ± 20 percent and shall be calibrated in accordance with the method(s) prescribed by the manufacturer(s) of such instrument; the instrument shall be calibrated at least once per year unless the manufacturer(s) specifies or recommends calibration at shorter intervals, in which case such specifications or recommendations shall be followed.

(c) The owner or operator of any nitric acid plant subject to the provisions of this subpart shall maintain a file of all measurements required by this subpart and shall retain the record of any such measurement for at least 1 year following the date of such measurement.

§ 466.54 Test methods and procedures.

(a) The provisions of this section are applicable to performance tests for determining emissions of nitrogen oxides from nitric acid plants.

(b) All performance tests shall be conducted while the affected facility is operating at or above the acid production rate for which such facility was designed.

(c) Test methods set forth in the appendix to this part shall be used as follows:

(1) For each repetition the NO_x concentration shall be determined by using Method 7. The sampling location shall be selected according to Method 1 and the sampling point shall be the centroid of

the stack or duct. The sampling time shall be 2 hours and four samples shall be taken during each 2-hour period.

(2) The volumetric flow rate of the total effluent shall be determined by using Method 2 and traversing according to Method 1. Gas analysis shall be performed by Method 3, and moisture content shall be determined by Method 4.

(d) Acid produced, expressed in tons per hour of 100 percent weak nitric acid, shall be determined during each 2-hour testing period by suitable flow meters and shall be confirmed by a material balance over the production system.

(e) For each repetition, nitrogen oxides emissions, expressed in lb./ton of weak nitric acid, shall be determined by dividing the emission rate in lb./hr. by the acid produced. The emission rate shall be determined by the equation, $\text{lb./hr.} = Q \times C$, where Q = volumetric flow rate of the effluent in $\text{ft.}^3/\text{hr.}$ at standard conditions, dry basis, as determined in accordance with § 466.54(d)(2), and $C = \text{NO}_x$ concentration in lb./ft.^3 , as determined in accordance with § 466.54(d)(1), corrected to standard conditions, dry basis.

Subpart F—Standards of Performance for Sulfuric Acid Plants

§ 466.60 Applicability and designation of affected facility.

(a) The provisions of this subpart are applicable to sulfuric acid plants.

(b) For purposes of § 466.11(e) the entire plant is the affected facility.

§ 466.61 Definitions.

As used in this part, all terms not defined herein shall have the meaning given them in the Act:

(a) "Sulfuric acid plant" means any facility producing sulfuric acid by the contact process by burning elemental sulfur, alkylation acid, hydrogen sulfide, organic sulfides and mercaptans, or acid sludge.

(b) "Acid mist" means sulfur acid mist, as measured by test methods set forth in this part.

§ 466.62 Standard for sulfur dioxide.

No person subject to the provisions of this subpart shall cause or allow the discharge into the atmosphere of sulfur dioxide in the effluent in excess of 4 lbs. per ton of acid produced (2 kgm. per metric ton), maximum 2-hour average.

§ 466.63 Standard for acid mist.

No person subject to the provisions of this subpart shall cause or allow the discharge into the atmosphere of acid mist in the effluent which is:

(a) In excess of 0.15 lb. per ton of acid produced (0.075 Kgm. per metric ton), maximum 2-hour average, expressed as H_2SO_4 .

(b) A visible emission within the meaning of this part.

§ 466.64 Emission monitoring.

(a) There shall be installed, calibrated, maintained, and operated, in any sulfuric acid plant subject to the provisions of this subpart, an instrument for continu-

ously monitoring and recording emissions of sulfur dioxide.

(b) The instrument installed and used pursuant to this section shall have a confidence level of at least 95 percent and be accurate within ± 20 percent and shall be calibrated in accordance with the method(s) prescribed by the manufacturer(s) of such instrument, the instrument shall be calibrated at least once per year unless the manufacturer(s) specifies or recommends calibration at shorter intervals, in which case such specifications or recommendations shall be followed.

(c) The owner or operator of any sulfuric acid plant subject to the provisions of this subpart shall maintain a file of all measurements required by this subpart and shall retain the record of any such measurement for at least 1 year following the date of such measurement.

§ 466.65 Test methods and procedures.

(a) The provisions of this section are applicable to performance tests for determining emissions of acid mist and sulfur dioxide from sulfuric acid plants.

(b) All performance tests shall be conducted while the affected facility is operating at or above the acid production rate for which such facility was designed.

(c) Test methods set forth in the appendix to this part shall be used as follows:

(1) For each repetition the acid mist and SO_2 concentrations shall be determined by using Method 8 and traversing according to Method 1. The sampling time shall be 2 hours, and sampling volume shall be 40 ft.^3 corrected to standard conditions.

(2) The volumetric flow rate of the total effluent shall be determined by using Method 2 and traversing according to Method 1. Gas analysis shall be performed by Method 3. Moisture content can be considered to be zero.

(d) Acid produced, expressed in tons per hour of 100 percent sulfuric acid shall be determined during each 2-hour testing period by suitable flow meters and shall be confirmed by a material balance over the production system.

(e) For each repetition, acid mist and sulfur dioxide emissions, expressed in lb./ton of sulfuric acid shall be determined by dividing the emission rate in lb./hr. by the acid produced. The emission rate shall be determined by the equation, $\text{lb./hr.} = Q \times C$, where Q = volumetric flow rate of the effluent in $\text{ft.}^3/\text{hr.}$ at standard conditions, dry basis, as determined in accordance with § 466.65(d)(2), and C = acid mist and SO_2 concentrations in lb./ft.^3 as determined in accordance with § 466.65(d)(1), corrected to standard conditions, dry basis.

APPENDIX—TEST METHODS

METHOD 1—SAMPLE AND VELOCITY TRAVERSES FOR STATIONARY SOURCES

1. Principle and applicability.

1.1 Principle. A sampling site and the number of traverse points are selected to aid in the extraction of a representative sample.

1.2 Applicability. This method should be applied only when specified by the test procedures for determining compliance with

New Source Performance Standards. This method is not intended to apply to gas streams other than those emitted directly to the atmosphere without further processing.

2. Procedure.

2.1 Selection of a sampling site and minimum number of traverse points.

2.1.1 Select a sampling site that is at least eight stack or duct diameters downstream and two diameters upstream from any flow disturbance such as a bend, expansion, contraction, or visible flame. For a rectangular cross section, determine an equivalent diameter from the following equation:

$$\text{equivalent diameter} = 2 \left[\frac{(\text{length})(\text{width})}{\text{length} + \text{width}} \right]$$

equation 1-1

2.1.2 When the above sampling site criteria can be met, the minimum number of traverse points is twelve (12).

2.1.3 Some sampling situations render the above sampling site criteria impractical. When this is the case, choose a convenient sampling location and use Figure 1-1 to determine the minimum number of traverse points.

2.1.4 To use Figure 1-1 first measure the distance from the chosen sampling location to the nearest upstream and downstream disturbances. Determine the corresponding number of traverse points for each distance from Figure 1-1. Select the higher of the two numbers of traverse points, or a greater value, such that for circular stacks the number is a multiple of four, and for rectangular stacks the number follows the criteria of section 2.2.2.

2.2 Cross sectional layout and location of traverse points.

2.2.1 For circular stacks locate the traverse points on two perpendicular diameters according to Figure 1-2 and Table 1-1.




Figure 1-2. Cross section of circular stack showing location of traverse points on perpendicular diameters.




Figure 1-1. Minimum number of traverse points.




Figure 1-3. Cross section of rectangular stack divided into 12 equal areas, with traverse points at centroid of each area.

PROPOSED RULE MAKING

Table 1-1. Location of traverse points in circular stacks
(Percent of stack diameter from inside wall to traverse point)

Traverse point number on a diameter	Number of traverse points on a diameter									
	6	8	10	12	14	16	18	20	22	24
1	4.4	3.3	2.5	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	14.7	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3	29.5	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4	44.7	29.5	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5	59.4	39.3	30.3	23.5	19.4	16.9	14.6	12.9	11.6	10.5
6	74.1	49.0	37.8	29.6	24.5	21.0	18.8	16.5	14.6	13.2
7	88.8	58.7	44.6	34.7	28.3	24.5	21.0	18.8	16.5	15.1
8	93.5	63.4	48.3	37.0	30.6	26.9	23.6	20.4	18.0	16.1
9	98.2	68.1	52.0	40.0	33.6	29.9	26.6	23.3	20.9	19.4
10		72.8	55.9	43.0	36.6	32.9	29.6	26.3	23.9	22.0
11		77.5	59.6	46.0	39.6	35.9	32.6	29.3	26.9	24.5
12		82.2	63.3	49.0	42.6	38.9	35.6	32.3	29.9	27.5
13		86.9	67.0	52.0	45.6	41.9	38.6	35.3	32.9	30.5
14		91.6	70.0	55.0	48.6	44.9	41.6	38.3	35.9	33.5
15		96.3	73.0	58.0	51.6	47.9	44.6	41.3	38.9	36.5
16			77.0	61.0	54.6	50.9	47.6	44.3	41.9	39.5
17			81.7	65.7	59.3	55.6	52.3	49.0	46.6	44.2
18			86.4	70.4	64.0	60.3	57.0	53.7	51.3	48.9
19			91.1	75.1	68.7	65.0	61.7	58.4	56.0	53.6
20			95.8	79.8	73.4	69.7	66.4	63.1	60.7	58.3
21				84.5	78.1	74.4	71.1	67.8	65.4	63.0
22				89.2	82.8	79.1	75.8	72.5	70.1	67.7
23				93.9	87.5	83.8	80.5	77.2	74.8	72.4
24				98.6	92.2	88.5	85.2	81.9	79.5	77.1

2.2.2. For rectangular stacks divide the cross section into as many equal rectangular areas as traverse points, such that the ratio of the length to the width of the elemental area is between one and two. Locate the traverse points at the centroid of each equal area according to Figure 1-3.

3. References. Determining Dust Concentration in a Gas Stream. ASME Performance Test Code #27. New York, 1957.

Devorkin, Howard, et al. Air Pollution Source Testing Manual. Air Pollution Control District, Los Angeles, November 1963.

Methods for Determination of Velocity, Volume, Dust and Mist Content of Gases. Western Precipitation Division of Joy Manufacturing Co. Los Angeles, Bulletin W-P-50. 1968.

Standard Method for Sampling Stacks for Particulate Matter. In: 1971 Book of ASTM Standards, Part 23. Philadelphia, 1971. ASTM Designation D-2928-71.

METHOD 2—DETERMINATION OF STACK GAS VELOCITY (TYPE S PITOT TUBE)

1. Principle and applicability.

1.1 Principle. Stack gas velocity is determined from the gas density and from measurement of the velocity head using a Type S (Stauscheibe or reverse type) pitot tube.

1.2 Applicability. This method should be applied only when specified by the test procedures for determining compliance with New Source Performance Standards. Being a directional instrument, a pitot tube should

not be used in the case of nondirectional flow.

2. Apparatus.

2.1 Pitot tube—Type S (Figure 2-1), or equivalent.

2.2 Differential pressure gauge—Inclined manometer, or equivalent, to measure velocity head to within 10 percent of the minimum value.

2.3 Temperature gauge—Thermocouples, bimetallic thermometers, liquid filled systems, or equivalent, to measure stack temperature to within 1.5 percent of the minimum absolute stack temperature.

2.4 Pressure gauge—Mercury-filled U-tube manometer, or equivalent, to measure stack pressure to within 0.1 in. Hg.

2.5 Barometer—To measure atmospheric pressure to within 0.1 in. Hg.

2.6 Gas analyzer—To analyze gas composition for determining molecular weight.

2.7 Pitot tube—Standard type, to calibrate Type S pitot tube.

3. Procedure.

3.1 Set up the apparatus as shown in Figure 2-1. Make sure all connections are tight and leak free. Measure the velocity head at the traverse points specified by Method 1.

3.2 Measure the temperature of the stack gas. If the total temperature variation with time is less than 50° F., a point measurement will suffice. Otherwise, conduct a temperature traverse.

3.3 Measure the static pressure in the stack.

3.4 Determine the stack gas molecular weight by gas analysis and appropriate calculation as indicated in Method 3.




Figure 2-1. Pitot tube - manometer assembly.

4. Calibration.

4.1 To calibrate the pitot tube, measure the velocity head at some point in a flowing gas stream with both a Type S pitot tube and

a standard type pitot tube with known coefficient. The velocity of the flowing gas stream should be within the normal working range.

15711

$$C_{p\text{ test}} = C_{p\text{ std}} \sqrt{\frac{\Delta P_{\text{std}}}{\Delta P_{\text{test}}}} \quad \text{equation 2-1}$$


4.3 Compare the coefficients of the Type S pitot tube determined first with one leg and

Use Equation 2-2 to calculate the stack gas velocity.

$$V_s = K_s C_s \sqrt{\frac{T_s \Delta p}{P_s M_s}} \quad \text{equation 2-2}$$

M_s = Molecular weight of stack gas, lb./lb.-mole.

OPERATORS



**SCHEMATIC OF STACK
CROSS SECTION**

[illegible]

Figure 2-2. Velocity traverse data.

3.1.1 Set up the equipment as shown in Figure 3-1. Place the probe in the stack at a sampling point and purge the sampling line.

¹ Trade name.

PROPOSED RULE MAKING




Figure 3-1. Grab-sampling train.




Figure 3-2. Integrated gas - sampling train.

3.1.2 Draw sample into the analyzer.

3.2 Integrated sampling.

3.2.1 Evacuate the flexible bag. Set up the equipment as shown in Figure 3-2 with the bag disconnected. Place the probe in the stack and purge the sampling line. Connect the bag, making sure that all connections are tight and that there are no leaks.

3.2.2 Sample at a rate proportional to the stack gas velocity.

3.3 Analysis.

3.3.1 Determine the CO_2 , O_2 , and CO concentrations as soon as possible. Make as many passes as are necessary to give constant readings. If more than 10 passes are necessary, replace the absorbing solution.

3.3.2 For integrated sampling, repeat the analysis until three consecutive runs vary no more than 0.2 percent by volume for each component being analyzed.

4. Calculations.

4.1 Carbon dioxide. Average the three consecutive runs and report result to the nearest 0.1 percent CO_2 .

4.2 Excess air. Use Equation 3-1 to calculate excess air, and average the runs. Report the result to the nearest 0.1 percent excess air.

% EA =

$$\frac{(\% \text{O}_2) - 0.5(\% \text{CO})}{0.264(\% \text{N}_2) - (\% \text{O}_2) + 0.5(\% \text{CO})} \times 100$$

equation 3-1

where:

% EA = Percent excess air.

% O_2 = Percent oxygen by volume, dry basis.

% N_2 = Percent nitrogen by volume, dry basis.

% CO = Percent carbon monoxide by volume, dry basis.

0.264 = Ratio of oxygen to nitrogen in air by volume.

4.3 Dry molecular weight. Use Equation 3-2 to calculate dry molecular weight and average the runs. Report the result to the nearest tenth.

$$M_d = 0.44(\% \text{CO}_2) + 0.32(\% \text{O}_2) + 0.28(\% \text{N}_2 + \% \text{CO})$$

Equation 3-2

where:

M_d = Dry molecular weight, lb./lb.-mole.

% CO_2 = Percent carbon dioxide by volume, dry basis.

% O_2 = Percent oxygen by volume, dry basis.

% N_2 = Percent nitrogen by volume, dry basis.

0.44 = Molecular weight of carbon dioxide divided by 100.

0.32 = Molecular weight of oxygen divided by 100.

0.28 = Molecular weight of nitrogen divided by 100.

5. References

Altshuler, A. P., et al. Storage of Gases and Vapors in Plastic Bags. *Int. J. Air & Water Pollution*. 6:75-81. 1963.

Conner, William D., and J. S. Nader. Air Sampling with Plastic Bags. *Journal of the American Industrial Hygiene Association*. 25:291-297. May-June 1964.

Devorkin, Howard, et al. Air Pollution Source Testing Manual. Air Pollution Control District. Los Angeles. November 1963.

METHOD 4—DETERMINATION OF MOISTURE IN STACK GASES

1. Principle and applicability.

1.1 Principle. Moisture is removed from the gas stream, condensed, and determined gravimetrically.

1.2 Applicability. This method is applicable for the determination of moisture in stack gas only when specified by test procedures for determining compliance with New Source Performance Standards. This method does not apply when liquid droplets are present in the gas stream.²

Other methods such as drying tubes, wet bulb-dry bulb techniques, and volumetric condensation techniques may be used subject to the approval of the Administrator.

2. Apparatus.

2.1 Probe—Stainless steel or Pyrex¹ glass sufficiently heated to prevent condensation and equipped with a filter to remove particulate matter.

2.2 Impingers—Two midjet impingers, each with 30 ml. capacity, or equivalent.

2.3 Ice bath container—To condense moisture in impingers.

2.4 Silica gel tube—To protect pump and dry gas meter.

2.5 Needle valve—To regulate gas flow rate.

2.6 Pump—Leak-free, diaphragm type, or equivalent, to pull gas through train.

2.7 Dry gas meter—To measure to within 1 percent of the total sample volume.

2.8 Rotameter—To measure a flow range from 0 to 0.1 c.f.m.

2.9 Balance—Capable of measuring to the nearest 0.1 g.

2.10 Barometer—Sufficient to read to within 0.1 in. Hg.

2.11 Pilot tube—Type S, or equivalent, attached to probe so that the sampling flow rate can be regulated proportional to the stack gas velocity when velocity is varying with time or a sample traverse is conducted.

3. Procedure.

3.1 Place about 5 ml. distilled water in each impinger and weigh the impinger and contents to the nearest 0.1 g. Assemble the apparatus without the probe as shown in Figure 4-1. Leak check by plugging the inlet to the first impinger and drawing a vacuum. Insure that flow through the dry gas meter is less than 1 percent of the sampling rate.

3.2 Connect the probe, and sample at a constant rate of 0.075 c.f.m. or at a rate proportional to the stack gas velocity not to exceed 0.075 c.f.m. Continue sampling until the dry gas meter registers 1 cu. ft. or until visible liquid droplets are carried over from the first impinger to the second. Record temperature, pressure, and dry gas meter reading as required by Figure 4-2.

3.3 After collecting the sample, weigh the impingers and their contents again to the nearest 0.1 g.

¹ Trade name.

² If liquid droplets are present in the gas stream, assume the stream to be saturated, determine the average stack gas temperature (Method 1), and use a psychrometric chart to obtain an approximation of the moisture percentage.

PROPOSED RULE MAKING

15713

4. Calculations.

4.1 Volume of water collected.

$$V_w = \frac{(W_i - W_f)RT_{std}}{P_{std}M_w} \quad \left(0.0474 \frac{\text{ft}^3}{\text{g}}\right)(W_i - W_f)$$

equation 4-1

where:

V_w = Volume of water vapor collected (standard conditions), cu. ft.

W_i = Final weight of impingers and contents, g.

W_f = Initial weight of impingers and contents, g.

R = Ideal gas constant, 21.83-in. Hg—cu. ft./lb. mole·°R.

T_{std} = Absolute temperature at standard conditions, 530°R.

P_{std} = Pressure at standard conditions, 29.92 in. Hg.

M_w = Molecular weight of water, 18 lb./lb. mole.

4.2 Gas volume.

$$V_{me} = V_m \left(\frac{P_m}{P_{std}} \right) \left(\frac{T_{std}}{T_m} \right) = \left(17.71 \frac{\text{in. Hg}}{\text{in. Hg}} \right) \frac{V_m P_m}{T_m} \quad \text{equation 4-2}$$

where:

V_{me} = Dry gas volume through meter at standard conditions, cu. ft.

V_m = Dry gas volume measured by meter, cu. ft.

P_m = Barometric pressure at the dry gas meter, in. Hg.

P_{std} = Pressure at standard conditions, 29.92-in. Hg.

T_{std} = Absolute temperature at standard conditions, 530°R.

T_m = Absolute temperature at meter (°F + 460), °R.

4.3 Moisture content.

$$B_w = \frac{V_w}{V_w + V_{me}} + B_m = \frac{V_w}{V_w + V_{me}} + (0.025) \quad \text{equation 4-3}$$

where:

B_w = Proportion by volume of water vapor in the gas stream, dimensionless.

V_w = Volume of water vapor collected (standard conditions), cu. ft.

V_{me} = Dry gas volume through meter (standard conditions), cu. ft.

B_m = Approximate volumetric proportion of water vapor in the gas stream leaving the impingers, 0.025.




Figure 4-1. Moisture-sampling train.

LOCATION _____ COMMENTS _____
 TEST _____
 DATE _____
 OPERATOR _____
 BAROMETRIC PRESSURE _____

CLOCK TIME	GAS VOLUME THROUGH METER, (V _m), ft ³	ROTAMETER SETTING, ft ³ /min	METER TEMPERATURE, °F

Figure 4-2. Field moisture determination.

5. References.

Air Pollution Engineering Manual, Danielson, J. A. (ed.). U.S. DHEW, PHS, National Center for Air Pollution Control, Cincinnati, Ohio. PHS Publication No. 999-Ap-40. 1967.

Devorkin, Howard, et al. Air Pollution Source Testing Manual. Air Pollution Control District, Los Angeles, Calif. November 1963.

Methods for Determination of Velocity, Volume, Dust and Mist Content of Gases. Western Precipitation Division of Joy Manufacturing Co., Los Angeles, Calif. Bulletin WP-50. 1968.

METHOD 5.—DETERMINATION OF PARTICULATE EMISSIONS FROM STATIONARY SOURCES

1. Principle and applicability.

1.1 Principle. Particulate matter is withdrawn isokinetically from the source and its weight is determined gravimetrically after removal of uncombined water.

1.2 Applicability. This method is applicable for the determination of particulate emissions from stationary sources only when specified by the test procedures for determining compliance with New Source Performance Standards.

2. Apparatus.

2.1 Sampling train. The design specifications of the particulate sampling train used by EPA (Figure 5-1) are described in APTD-0581. Commercial models of this train are available.

2.1.1 Nozzle—Stainless steel (316) with sharp, tapered leading edge.

2.1.2 Probe—Pyrex glass with a heating system capable of maintaining a gas temperature of 250° F. at the exit end during sampling. When temperature or length limitations are encountered, 316 stainless steel, or equivalent, may be used, as approved by the Administrator.

2.1.3 Pitot tube—Type S, or equivalent, attached to probe to monitor stack gas velocity.

2.1.4 Filter holder—Pyrex¹ glass with heating system capable of maintaining any temperature to a maximum of 225° F.

2.1.5 Impingers—Four impingers connected in series with glass ball joint fittings. The first, third, and fourth impingers are of the Greenburg-Smith design, modified by re-

placing the tip with a 1/2-inch ID glass tube extending to 1/2-inch from the bottom of the flask. The second impinger is of the Greenburg-Smith design with the standard tip.

2.1.6 Metering system—Vacuum gauge, leak-free pump, thermometers capable of measuring temperature to within 5° F., dry gas meter with 2 percent accuracy, and related equipment, or equivalent, as required to maintain an isokinetic sampling rate and to determine sample volume.




Figure 5-1. Particulate-sampling train.

2.1.7 Barometer—To measure atmospheric pressure to ± 0.1 in. Hg.

2.2 Sample recovery.

2.2.1 Probe brush—At least as long as probe.

2.2.2 Glass wash bottles—Two.

2.2.3 Glass sample storage containers.

2.2.4 Graduated cylinder—250 ml.

2.3 Analysis.

2.3.1 Glass weighing dishes.

2.3.2 Desiccator.

2.3.3 Analytical balance—To measure to ± 0.1 mg.

2.3.4 Beakers—250 ml.

¹ Trade name.

2.3.5 Separatory funnels—500 ml. and 1,000 ml.

2.3.6 Trip balance—300 g. capacity, to measure to ± 0.05 g.

2.3.7 Graduated cylinder—25 ml.

3. Reagents.

3.1 Sampling

3.1.1 Filters—Glass fiber, MSA 1106 BH, or equivalent, numbered for identification and preweighed.

3.1.2 Silica gel—Indicating type, 6 to 16 mesh, dried at 175° C. (350° F.) for 2 hours.

3.1.3 Water—Deionized, distilled.

3.1.4 Crushed ice.

3.2 Sample recovery

3.2.1 Water—Deionized, distilled.

3.2.2 Acetone—Reagent grade.

3.3 Analysis

3.3.1 Water—Deionized, distilled.

3.3.2 Chloroform—Reagent grade.

3.3.3 Ethyl ether—Reagent grade.

3.3.4 Desiccant—Drierite,¹ indicating.

4. Procedure.

4.1 Sampling.

4.1.1 After selecting the sampling site and the minimum number of sampling points, determine the stack pressure, temperature, moisture, and range of velocity head.

4.1.2 Preparation of collection train. Weigh to the nearest gram approximately 200 g. of silica gel. Label a filter of proper diameter, desiccate² for at least 24 hours and weigh to the nearest 0.5 mg. in a room where the relative humidity is less than 50 percent. Place 100 ml. of water in each of the first two impingers, leave the third impinger empty, and place approximately 200 g. of preweighed silica gel in the fourth impinger. Save a portion of the water for use as a blank in the sample analysis. Set up the train without the probe as in Figure 5-1. Leak check the sampling train at the sampling site by plugging the inlet to the filter holder and pulling a 15-in. Hg vacuum. A leakage rate not in excess of 0.02 c.f.m. at a vacuum of 15-in. Hg is acceptable. Attach the probe and adjust the heater to provide a gas temperature of about 250° F. at the probe outlet. Turn on the filter heating system. Place crushed ice around the impingers. Add more ice during the run to keep the temperature of the gases leaving the last impinger at 70° F. or less.

4.1.3 Particulate train operation. For each run record the data required on the example sheet shown in Figure 5-2. Take readings at each sampling point at least every 5 minutes; and when significant changes in stack conditions necessitate additional adjustments in flow rate. To begin sampling, position the nozzle at the first traverse point with the tip pointing directly into the gas stream. Immediately start the pump and adjust the flow to isokinetic conditions. Maintain isokinetic sampling throughout the sampling period. Nomographs are available which aid in the rapid adjustment of the sampling rate without other computations. APTD-0578 details the procedure for using these nomographs. Turn off the pump at the conclusion of each run and record the final readings. Remove the probe and nozzle from the stack and handle in accordance with the sample recovery process described in section 4.2.

² Dry using Drierite¹ at 70° $\pm$ 10° F.

15715

AMBIENT TEMPERATURE _____
 BAROMETRIC PRESSURE _____
 ASSUMED MOISTURE, % _____
 HEATER BOX SETTING _____
 PROBE LENGTH, in. _____
 NOZZLE DIAMETER, in. _____
 PROBE HEATER SETTING _____

SCHEMATIC OF STACK CROSS SECTION

TRAVERSE POINT NUMBER	SAMPLING TIME (t), min,	STATIC PRESSURE (P _S), in. Hg.	STACK TEMPERATURE (T _S), °F	VELOCITY HEAD (Δ P _S).	PRESSURE DIFFERENTIAL ACROSS ORIFICE METER (Δ H), in. H ₂ O	GAS SAMPLE VOLUME (Vm), ft ³	GAS SAMPLE TEMPERATURE AT DRY GAS METER		SAMPLE BOX TEMPERATURE, ° F	IMPINGER TEMPERATURE ° F
							INLET (Tm In.), ° F	OUTLET (Tm Out.), ° F		
TOTAL							Avg.	Avg.		
AVERAGE							Avg.			

4.2 Sample recovery. Exercise care in moving the collection train from the test site to the sample recovery area to minimize the loss of collected sample or the gain of extraneous particulate matter. Set aside portions of the water and acetone used in the sample recovery as blanks for analysis. Place the samples in containers as follows:

Container No. 2. Place loose particulate matter and acetone washings from all sample-exposed surfaces prior to the filter in this container and seal. Use a razor blade, brush, or rubber policeman to loosen adhering particles.

Container No. 4. Transfer the silica gel from the fourth impinger to the original container and seal. Use a rubber policeman as an aid in removing silica gel from the impinger.

4.3 Analysis. Record the data required on the example sheet shown in Figure 5-3. Handle each sample container as follows:

Container No. 2. Transfer the acetone washings to a tared beaker and evaporate to dryness at ambient temperature and pressure. Dessicate and dry to a constant weight. Report results to the nearest 0.5 mg.

Container No. 3. Extract organic particulate from the impinger solution with three 25 ml. portions of chloroform. Complete the extraction with three 25 ml. portions of ethyl ether. Combine the ether and chloroform extracts, transfer to a tared beaker and evaporate at 70° F. until no solvent remains. Desiccate, dry to a constant weight, and report the results to the nearest 0.5 mg.

Container No. 4. Weigh the spent silica gel and report to the nearest gram.

PLANT _____

DATE _____

RUN NO. _____

CONTAINER NUMBER	WEIGHT OF PARTICULATE COLLECTED, mg		
	FINAL WEIGHT	TARE WEIGHT	WEIGHT GAIN
1			
2			
3a*			
3b**			
5			
TOTAL			

*3a - ORGANIC EXTRACT FRACTION.

**3b - RESIDUAL WATER FRACTION.

	VOLUME OF LIQUID WATER COLLECTED	
	IMPINGER VOLUME, ml	SILICA GEL WEIGHT, g
FINAL		
INITIAL		
LIQUID COLLECTED		
TOTAL VOLUME COLLECTED		g* ml

* CONVERT WEIGHT OF WATER TO VOLUME BY DIVIDING TOTAL WEIGHT INCREASE BY DENSITY OF WATER. (1 g/ml):

$$\frac{\text{INCREASE, g}}{(1 \text{ g/ml})} = \text{VOLUME WATER, ml}$$

Figure 5-3. Analytical data.

Container No. 5. Transfer the acetone washings to a tared beaker and evaporate to dryness at ambient temperature and pressure. Desiccate, dry to a constant weight, and report the results to the nearest 0.5 mg.

5. Calibration.

Use standard methods and equipment approved by the Administrator to calibrate the orifice meter, pitot tube, dry gas meter, and probe heater.

6. Calculations.

6.1 Sample concentration method.

6.1.1 Average dry gas meter temperature. See data sheet (Figure 5-2).

6.1.2 Dry gas volume. Correct the sample

volume measured by the dry gas meter to standard conditions (70° F., 29.92 in. Hg) by using Equation 5-1.

$$V_{m, std} = V_m \left(\frac{T_{std}}{T_m} \right) \left(\frac{P_{bar} + \frac{\Delta H}{13.6}}{P_{std}} \right) = \left(17.71 \frac{^{\circ}\text{R}}{\text{in. Hg}} \right) (V_m) \left(\frac{P_{bar} + \frac{\Delta H}{13.6}}{P_{std}} \right)$$

equation 5-1

where:

$V_{m, std}$ = Volume of gas sample through the dry gas meter (standard conditions), cu. ft.

V_m = Volume of gas sample through the dry gas meter (meter conditions), cu. ft.

T_{std} = Absolute temperature at standard conditions, 530° R.

T_m = Average dry gas meter temperature, °R.

P_{bar} = Barometric pressure at the orifice meter, in. Hg.

ΔH = Pressure drop across the orifice meter, in. H₂O.

13.6 = Specific gravity of mercury.

P_{std} = Absolute pressure at standard conditions, 29.92 in. Hg.

6.1.3 Volume of Water vapor.

$$V_{w, std} = V_{l, c} \left(\frac{\rho_{H_2O}}{M_{H_2O}} \right) \left(\frac{RT_{std}}{P_{std}} \right) = (0.0474 \frac{\text{cu. ft.}}{\text{ml.}}) V_{l, c}$$

equation 5-2

where:

$V_{w, std}$ = Volume of water vapor in the gas sample (standard conditions), cu. ft.

$V_{l, c}$ = Total volume of liquid collected in impingers and silica gel (see Figure 5-3), ml.

ρ_{H_2O} = Density of water, 1 g./ml.

M_{H_2O} = Molecular weight of water, 18 lb./lb. mole.

R = Ideal gas constant, 21.83 in. Hg-cu. ft./lb. mole-°R.

T_{std} = Absolute temperature at standard conditions, 530° R.

P_{std} = Absolute pressure at standard conditions, 29.92 in. Hg.

6.1.4 Total gas volume.

$$V_{total} = V_{m, std} + V_{w, std}$$

equation 5-3

where:

V_{total} = Total volume of gas sample (standard conditions), cu. ft.

$V_{m, std}$ = Volume of gas through dry gas meter (standard conditions), cu. ft.

$V_{w, std}$ = Volume of water vapor in the gas sample (standard conditions), cu. ft.

6.1.5 Total particulate weight. Determine the total particulate catch from the sum of the weights on the analysis data sheet (Figure 5-3).

6.1.6 Concentration.

$$c_s' = \left(0.0154 \frac{\text{gr.}}{\text{mg.}} \right) \left(\frac{M_a}{V_{total}} \right)$$

equation 5-4

where:

c_s' = Concentration of particulate matter in stack gas (Sample Concentration Method), gr./s.c.f.

M_a = Total amount of particulate matter collected, mg.

V_{total} = Total volume of gas sample (standard conditions), cu. ft.

6.2 Ratio of area method.

6.2.1 Stack gas velocity. Collect the necessary data as detailed in Method 2. Correct the

stack gas velocity to standard conditions (29.92 in. Hg, 530° R.) as follows:

$$V_{std} = V \left(\frac{P}{P_{std}} \right) \left(\frac{T_{std}}{T} \right) = \left(\frac{17.71}{\text{in. Hg}} \right) \left(\frac{V \cdot P}{T} \right) \quad \text{equation 5-5}$$

where:

V_{std} = Stack gas velocity at standard conditions, ft./sec.

$$c_s = \frac{M_s}{Q_s} = \frac{\frac{M_s}{A_s} \cdot \frac{A_s}{V_{std}}}{\frac{M_s}{A_s} \cdot \frac{A_s}{V_{std}}} = \left(2.57 \times 10^{-4} \frac{\text{gr.} = \text{min.}}{\text{mg.} = \text{sec.}} \right) \left(\frac{M_s}{\theta V_{std} A_n} \right) \quad \text{equation 5-6}$$

where:

c_s = Concentration of particulate matter in the stack gas (Ratio of Area Method), gr./s.c.f.

M_s = Particulate mass flow rate through the stack (standard conditions), mass/time.

Q_s = Volumetric flow rate of gas stream through the stack (standard conditions), volume/time.

$$I = \frac{c_s}{c_s'} \times 100 = \frac{T_s \left[\frac{V_{H_2O} R}{M_{H_2O}} + \frac{V_n}{T_n} \left(P_{bar} + \frac{\Delta H}{13.6} \right) \right]}{\theta V_s P_s A_n} \times 100 = \left(\frac{1.667 \text{ min.}}{\text{sec.}} \right) \left[\left(\frac{0.00267 \text{ in. Hg-cu. ft.}}{\text{ml.} \cdot ^\circ \text{R.}} \right) V_{H_2O} + \frac{V_n}{T_n} \left(P_{bar} + \frac{\Delta H}{13.6} \right) \right] T_s \quad \text{equation 5-7}$$

where:

I = Percent of isokinetic sampling.

C_s = Concentration of particulate matter in the stack gas (Ratio of Area Method), gr./s.c.f.

C_s' = Concentration of particulate matter in the stack gas (Sample Concentration Method), gr./s.c.f.

V_{H_2O} = Total volume of liquid collected in impingers and silica gel (see Figure 5-3), ml.

ρ_{H_2O} = Density of water, 1 g./ml.

R = Ideal gas constant, 21.83 in. Hg-cu. ft./lb. mole-°R.

M_{H_2O} = Molecular weight of water, 18 lb./lb. mole.

V_n = Volume of gas sample through the dry gas meter (meter conditions), cu. ft.

T_n = Absolute average dry gas meter temperature (see Figure 5-2), °R.

P_{bar} = Barometric pressure at sampling site, in. Hg.

ΔH = Average pressure drop across the orifice (see Figure 5-2), in. H₂O.

T_s = Absolute average stack gas temperature (see Figure 5-2), °R.

V_s = Stack gas velocity calculated by Method 2, Equation 2-2, ft./sec.

P_s = Absolute stack gas pressure, in. Hg.

P_{std} = Absolute pressure at standard conditions, 29.92 in. Hg.

T_{std} = Absolute temperature at standard conditions, 530° R.

T_s = Absolute stack gas temperature (average), °R.

6.2.2 Concentration.

M_n = Total amount of particulate matter collected by train, mg.

θ = Total sampling time, min.

A_s = Cross-sectional area of stack, sq. ft.

A_n = Cross-sectional area of nozzle, sq. ft.

V_{std} = Stack gas velocity at standard conditions, ft./sec.

6.3 Isokinetic variation.

θ = Total sampling time, min.

V_s = Stack gas velocity calculated by Method 2, Equation 2-2, ft./sec.

P_s = Absolute stack gas pressure, in. Hg.

A_n = Cross-sectional area of nozzle, sq. ft.

6.4 Acceptable results. The following range sets the limit on acceptable isokinetic sampling results:

If 82 percent < 120 percent, the results are acceptable; otherwise, reject the results and repeat the test.

6.5 Average particulate concentration. If the criteria for acceptability are met, calculate the average concentration of particulate in the stack from the following equation:

$$c_s = \frac{\bar{c}_s + c_s'}{2} \quad \text{Equation 5-8}$$

where:

$\bar{c}_s$ = Average particulate concentration in the stack gas, gr./s.c.f.

c_s' = Concentration of particulate matter in the stack gas (Ratio of Area Method), gr./s.c.f.

c_s' = Concentration of particulate matter in the stack gas (Sample Concentration Method), gr./s.c.f.

7. References.

Addendum to Specifications for Incinerator Testing at Federal Facilities. PHS, NCAPC. Dec. 6, 1967.

Martin, Robert M. Construction Details of Isokinetic Source Sampling Equipment. Environmental Protection Agency, APTD-0581. Rom, Jerome J. Maintenance, Calibration, and Operation of Isokinetic Source Sampling Equipment. Environmental Protection Agency, APTD-0576.

Smith, W. S.; R. T. Shigehara, and W. F. Todd. A Method of Interpreting Stack Sampling Data. Paper presented at the 63d Annual Meeting of the Air Pollution Control Association, St. Louis, June 14-19, 1970.

Smith, W. S., et al. Stack Gas Sampling Improved and Simplified with New Equipment. APCA Paper No. 67-119. 1967.

Specifications for Incinerator Testing at Federal Facilities. PHS, NCAPC. 1967.

METHOD 6—DETERMINATION OF SULFUR DIOXIDE EMISSIONS FROM STATIONARY SOURCES

1. Principle and applicability.

1.1 Principle. A gas sample is extracted from the sampling point in the stack, and the acid mist including sulfur trioxide is separated from the sulfur dioxide. The sulfur dioxide fraction is measured by the barium-thorin titration method.

1.2 Applicability. This method is applica-

ble for the determination of sulfur dioxide emissions from stationary sources only when specified by the test procedures for determining compliance with New Source Performance Standards.

2. Apparatus.

2.1 Sampling. See Figure 6-1

2.1.1 Probe—Pyrex¹ glass, approximately 5-6 mm. ID, with a heating system to prevent condensation and a filter to remove particulate matter including sulfuric acid mist.

2.1.2 Midget bubbler—One, with glass wool packed in top to prevent sulfuric acid mist carryover.

2.1.3 Glass wool.

2.1.4 Midget impingers—Three.

2.1.5 Drying tube—Packed with 6 to 16 mesh indicating-type silica gel, or equivalent, to dry the sample.

2.1.6 Pump—Leak-free, vacuum type.

2.1.7 Rate meter—Rotameter, or equivalent, to measure a 0-10 s.c.f.h. flow range.

2.1.8 Dry gas meter—Sufficiently accurate to measure the sample volume within 1 percent.

2.1.9 Pitot tube—Type S, or equivalent, necessary only if a sample traverse is required or if stack gas velocity varies with time.

2.2 Sample recovery.

2.2.1 Glass wash bottles—Two.

2.2.2 Polyethylene storage bottles—To store impinger samples.

2.3 Analysis.

¹ Trade name.




Figure 6-1. SO₂ sampling train.

CARBON MONOXIDE SAMPLING

Stack gas is drawn from the stack through a filter, into an MSA Lira* infrared analyzer. This instrument is mated to a Brush* Chart-strip recorder which reads out directly. The unit is calibrated on-site with a zero calibration gas (nitrogen) and a known span gas (238 ppm carbon monoxide).

SCRUBBER EFFLUENT WATER SAMPLING

Samples of scrubber water were composited in glass jars, as well as inlet (blanks) water samples, then total solids were measured by standard laboratory technique.

*Mention of a specific company or product does not constitute endorsement by EPA.

APPENDIX F
LABORATORY REPORT

Acetone Before Total
WT.

±0.05

SAMPLES

Astapula w/c R/m

Looks
Like
Some
Silica
gel

Beaker NO.	CR	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.		Weight - blank result	Result gms
16		ASE-1	75.9926 75.9275 0.0651	100 ml	75.9938 75.9275 0.0663	75.9938 75.9275 0.0663			0.0663 0.0009 0.0654	0.0654
17		ASE-2	78.5006 78.4153 0.0853	225 ml	78.5012 78.4153 0.0859	78.4982 78.4153 0.0829	78.4971 78.4153 0.0818	78.4961 78.4153 0.0808	78.4953 78.4153 0.0800	0.0791 0.0772 0.0772
18		ASE-3	78.6607 78.5876 0.0731	170 ml	78.6604 78.5876 0.0728	78.6595 78.5876 0.0719	78.6585 78.5876 0.0709	78.6585 78.5876 0.0709	0.0709 2.0014 0.0695	0.0695
19		SWH-1	80.5758 80.5031 0.0727	100 ml	80.5778 80.5031 0.0747	80.5770 80.5031 0.0739	80.5770 80.5031 0.0739		0.0739 0.0009 0.0730	0.0730
20		SWH-2	76.9103 76.8658 0.0445	80 ml	76.9113 76.8658 0.0455	76.9113 76.8658 0.0455			0.0455 0.0007 0.0448	0.0448
21		SWH-3	73.2081 73.1542 0.0539	240 ml	73.2094 73.1542 0.0552	73.2094 73.1542 0.0552			0.0552 0.0020 0.0532	0.0532
22		SEH-2	71.7508 71.7226 0.0282	50 ml	71.7518 71.7226 0.0292	71.7518 71.7226 0.0292			0.0292 0.0004 0.0288	0.0288
23		SEH-3	76.2699 76.2385 0.0314	60 ml	76.2710 76.2385 0.0325	76.2710 76.2385 0.0325			0.0325 0.0005 0.0320	0.0320
24		NEH-1	73.3224 73.2475 0.0749	75 ml	73.3243 73.2475 0.0768	73.3238 73.2475 0.0763	73.3238 73.2475 0.0763		0.0763 0.0006 0.0757	0.0757
25		NEH-2	78.6131 78.5551 0.0580	75 ml	78.6137 78.5551 0.0586	78.6137 78.5551 0.0586			0.0586 0.0006 0.0580	0.0580
26		NEH-3	72.0279 71.9265 0.0514	100 ml	72.0286 71.9265 0.0521	72.0286 71.9265 0.0521			0.0521 0.0009 0.0512	0.0512
27		NWH-1	71.4406 71.3798 0.0608	140 ml	71.4412 71.3798 0.0614	71.4408 71.3798 0.0610	71.4410 71.3798 0.0612	71.4408 71.3798 0.0610	0.0610 0.0012 0.0598	0.0598
28		NWH-2	70.8742 70.8467 0.0275	50 ml	70.8744 70.8467 0.0277	70.8745 70.8467 0.0278	70.8745 70.8467 0.0278		0.0278 0.0004 0.0274	0.0274
29		NWH-3	72.1920 72.1531 0.0389	50 ml	72.1922 72.1531 0.0391	72.1925 72.1531 0.0394	72.1920 72.1531 0.0389		0.0389 0.0004 0.0385	0.0385
30		BTF-1	77.3393 77.1988 0.1405	100 ml	77.3403 77.1988 0.1415	77.3399 77.1988 0.1411	77.3403 77.1988 0.1415		0.1415 0.0009 0.1406	0.1406

Project No. 859 617

Collection Date _____

Analysis Date _____

F-1

#17 78.4944 78.4152
78.4153 0.0791
0.0791

#035

Astakula 4/c R/m

25 Filters #035
Total Wt

SAMPLES

Astabula W/C R/m

CR NO.	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.		gms.
✓ 1	SHE-1 000186	27.8139 0.1770 0.1782	28.4082 28.1691 0.2391	28.4084 28.1691 0.2393	28.4080 28.1691 0.2389	28.4075 28.1691 0.2384	28.4069 28.1691 0.2378	0.2384
✓ 1	SHE-1 000098	28.1691						
✓ 2	SHE-2 000256	27.9201 0.6708 28.5909	29.8868 28.5909 1.2959	29.8863 28.5909 1.2954	29.8860 28.5909 1.2951	29.8858 28.5909 1.2949	29.8859 28.5909 1.2949	1.2949
✓ 3	SHE-2 000258	26.9053 0.6991 27.6044	28.1380 27.6044 0.5336	28.1380 27.6044 0.5336				0.5336
✓ 4	SHE-3 000251	27.6956 0.6634 28.3590	30.0191 28.3590 1.6601	30.0191 28.3590 1.6601				1.6601
✓ 5	SHE-4 000253	25.5403 0.6542 26.1945	26.5559 26.1945 0.3614	26.5562 26.1945 0.3617	26.5556 26.1945 0.3611	26.5562 26.1945 0.3617		0.3617
✓ 6	CHF-2 000255	27.2661 0.6835 27.9496	28.8393 27.9496 0.8897	28.8393 27.9496 0.8897				0.8897
✓ 7	CHF-3 000252	24.7652 0.6749 25.4401	26.0697 25.4401 0.6296	26.0699 25.4401 0.6298	26.0691 25.4401 0.6290	26.0691 25.4401 0.6290		0.6290
✓ 8	CHF-4 000257	25.3394 0.6821 26.0215	26.1470 26.0215 0.1255	26.1470 26.0215 0.1255				0.1255
✓ 9	NHE-1 000161	25.6957 0.1762 25.8719	26.4013 26.0452 0.3561	26.4022 26.0452 0.3570	26.4013 26.0452 0.3561			0.3561
✓ 9	NHE-1 000105	0.1733 26.0452						
✓ 10	NHE-2 000254	27.8393 0.6709 28.5102	29.7694 28.5102 1.2592	29.7700 28.5102 1.2598	29.7681 28.5102 1.2579	29.7689 28.5102 1.2587	29.7681 28.5102 1.2579	1.2579
✓ 11	NHE-3 000259	28.6921 0.6792 29.3713	30.3760 29.3713 1.0047	30.3768 29.3713 1.0055	30.3768 29.3713 1.0055			1.0055
✓ 12	NHE-4 000247	28.2588 0.6821 28.9409	29.1103 28.9409 0.1694	29.1103 28.9409 0.1694				0.1694
✓ 13	ATE-1 000115	28.8060 0.1755 28.9815	29.1401 28.9815 0.1586	29.1403 28.9815 0.1588	29.1399 28.9815 0.1584	29.1399 28.9815 0.1589		0.1584

Project No. 85961.2

Collection Date

Analysis Date

Int 006

g. filters
Total wt. #035

SAMPLES Astabula u/c R/m

NO.	CR	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.		gms
✓ 14		ATE-2 000250	28.4909 0.6782 29.1691	29.2502 29.1691 0.0811	29.2507 29.1691 0.0816	29.2507 29.1691 0.0816			0.0816
✓ 15		ATE-3 000231	26.2652 0.6960 26.9612	27.1370 26.9612 0.1758	27.1370 26.9612 0.1758				0.1758
✓ 16		ASE-1 000159	28.0737 0.1787 28.2524	28.2664 28.2524 0.0140	28.2660 28.2524 0.0136	28.2635 28.2524 0.0111	28.2632 28.2524 0.0108	28.2632 28.2524 0.0108	0.0108
✓ 17		ASE-2 000417	30.4835 0.1721 30.6576	30.6608 30.6576 0.0032	30.6608 30.6576 0.0032				0.0032
✓ 18		ASE-3 000108	26.9317 0.1775 27.1092	27.1131 27.1092 0.0039	27.1136 27.1092 0.0044	27.1134 27.1092 0.0042	27.1136 27.1092 0.0044		0.0044
✓ 19		SEH-1 000232	27.4934 0.6775 28.1709	28.2752 28.1709 0.1043	28.2752 28.1709 0.1043				0.1043
✓ 20		SEH-2 000236	26.2622 0.6749 26.9371	26.9877 26.9371 0.0506	26.9875 26.9371 0.0504	26.9875 26.9371 0.0504			0.0504
✓ 21		SEH-3 000234	23.9231 0.6662 24.5893	24.6585 24.5893 0.0692	24.6585 24.5893 0.0692				0.0692
✓ 22		SEH-2 000233	27.8527 0.6779 28.5306	28.5703 28.5306 0.0397	28.5705 28.5306 0.0399	28.5698 28.5306 0.0392	28.5705 28.5306 0.0399		0.0399
✓ 23		SEH-3 000226	25.3177 0.6762 25.9939	26.0492 25.9939 0.0553	26.0487 25.9939 0.0548	26.0489 25.9939 0.0550	26.0487 25.9939 0.0548		0.0548
✓ 24		NEH-1 000237	26.6753 0.6951 27.3704	27.7082 27.3704 0.3378	27.7079 27.3704 0.3375	27.7076 27.3704 0.3372	27.7076 27.3704 0.3372		0.3372
✓ 25		NEH-2 000230	26.2335 0.6720 26.9105	27.0566 26.9105 0.1461	27.0566 26.9105 0.1461				0.1461
✓ 26		NEH-3 000227	27.2204 0.6769 27.8973	28.0557 27.8973 0.1584	28.0557 27.8973 0.1584				0.1584
✓ 27		NWH-1 000235	28.1453 0.6666 28.8119	28.8822 28.8119 0.0703	28.8824 28.8119 0.0705	28.8819 28.8119 0.0700	28.8824 28.8119 0.0705		0.0705
✓ 28		NWH-2 000246	27.8749 0.6790 28.5539	28.5861 28.5539 0.0322	28.5862 28.5539 0.0323	28.5859 28.5539 0.0320	28.5859 28.5539 0.0320		0.0320

Project No. _____

Collection Date _____

Analysis Date _____

JRA CCF

Total wt. #035

SAMPLES Astabula w/c R/m

✓
✓
✓
✓
✓
✓
✓

859617

Analysis Date

১৫

creb

Acetone After
Total
WT

#035

SAMPLES

Actabula

CR	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.			gms
36	SHE-1	78.9490 78.9395 0.0095	125 ml	78.9497 78.9395 0.0102	78.9497 78.9395 0.0102			0.0102 0.0011 0.0091	0.0091
37	SHE-2	79.3314 79.3150 0.0164	150 ml	79.3325 79.3150 0.0175	79.3328 79.3150 0.0178	79.3328 79.3150 0.0178		0.0178 0.0013 0.0165	0.0165
38	SHE-3	71.9690 71.9605 0.0085	90 ml	71.9707 71.9605 0.0102	71.9705 71.9605 0.0100	71.9705 71.9605 0.0100		0.0100 0.0008 0.0092	0.0092
39	SHE-1	75.6351 75.6313 0.0038	60 ml	75.6365 75.6313 0.0052	75.6365 75.6313 0.0052			0.0052 0.0005 0.0047	0.0047
40	SHE-2	71.6018 71.5937 0.0081	80 ml	71.6030 71.5937 0.0093	71.6032 71.5937 0.0095	71.6032 71.5937 0.0095		0.0095 0.0007 0.0088	0.0088
41	SHE-3	80.1592 80.1346 0.0246	125 ml	80.1607 80.1346 0.0261	80.1607 80.1346 0.0261			0.0261 0.0011 0.0250	0.0250
42	SHE-4	80.0537 80.0448 0.0089	100 ml	80.0551 80.0448 0.0103	80.0554 80.0448 0.0106	80.0554 80.0448 0.0106		0.0106 0.0009 0.0097	0.0097
43	NHE-1	75.7711 75.7629 0.0082	140 ml	75.7730 75.7629 0.0101	75.7730 75.7629 0.0101			0.0101 0.0012 0.0089	0.0089
44	NHE-2	72.3501 72.3334 0.0167	110 ml	72.3513 72.3334 0.0179	72.3513 72.3334 0.0179			0.0179 0.0009 0.0170	0.0170
45	NHE-3	75.2070 75.2020 0.0050	80 ml	75.2081 75.2020 0.0061	75.2082 75.2020 0.0062	75.2084 75.2020 0.0064	75.2074 75.2020 0.0054	0.0054 0.0007 0.0047	0.0047
46	NHE-4	77.9012 77.8970 0.0042	50 ml	77.9027 77.8970 0.0057	77.9027 77.8970 0.0057			0.0057 0.0004 0.0053	0.0053
47	ATE-1	79.2909 79.2851 0.0058	75 ml	79.2923 79.2851 0.0072	79.2923 79.2851 0.0072			0.0072 0.0006 0.0066	0.0066
48	ATE-2	74.8533 74.8194 0.0339	110 ml	74.8544 74.8194 0.0350	74.8546 74.8194 0.0352	74.8546 74.8194 0.0352		0.0352 0.0009 0.0343	0.0343
49	ATE-3	73.3175 73.3145 0.0030	110 ml	73.3178 73.3145 0.0033	73.3178 73.3145 0.0033			0.0033 0.0009 0.0024	0.0024
50	ASE-1	78.0971 78.0789 0.0182	90 ml	78.0982 78.0789 0.0193	78.0979 78.0789 0.0190	78.0988 78.0789 0.0199	78.0982 78.0789 0.0193	0.0193 0.0008 0.0185	0.0185

Project No. 859617

Collection Date

Analysis Date

SAMPLES

Astabula 1/2 R/m

Acetone After
Total
wt.

#035

NO.	CR	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.		gms
51	X	ASE-2 NOT taken	X	X	X	/			X
52	X	ASE-3 NOT taken	X	X	X	/			X
51		SWH-1	79.4487 79.4426 0.0061	110 ml	79.4490 79.4426 0.0064	79.4486 79.4426 0.0060	79.4492 79.4426 0.0066	0.0064 0.0009 0.0055	0.0055
52		SWH-2	72.9987 72.9478 0.0509	90 ml	72.9993 72.9478 0.0515	72.9996 72.9478 0.0518	72.9993 72.9478 0.0515	0.0515 0.0008 0.0507	0.0507
53		SWH-3	76.1793 76.1600 0.0193	180 ml	76.1793 76.1600 0.0193	/		0.0193 0.0015 0.0178	0.0178
54		SEH-2	78.0369 78.0322 0.0047	70 ml	78.0369 78.0322 0.0047	78.0369 78.0322 0.0042		0.0042 0.0006 0.0036	0.0036
55		SEH-3	71.2608 71.2566 0.0042	40 ml	71.2608 71.2566 0.0042	/		0.0042 0.0003 0.0039	0.0039
56		NEH-1	74.7106 74.7018 0.0088	140 ml	74.7106 74.7018 0.0088	/		0.0088 0.0012 0.0076	0.0076
57		NEH-2	78.0031 77.9918 0.0113	75 ml	78.0031 77.9918 0.0113	/		0.0113 0.0006 0.0107	0.0107
58		MEH-3	85.4331 85.4190 0.0141	175 ml	85.4331 85.4190 0.0141	85.4343 85.4190 0.0153	85.4339 85.4190 0.0149	0.0149 0.0015 0.0134	0.0134
59		NWH-1	79.2704 79.2629 0.0075	120 ml	79.2704 79.2629 0.0075	/		0.0075 0.0010 0.0065	0.0065
60		NWH-2	75.9970 75.9924 0.0046	30 ml	75.9968 75.9924 0.0044	75.9923 75.9924 0.0049	75.9973 75.9924 0.0049	0.0049 0.0003 0.0046	0.0046
61		NWH-3	68.1774 68.1667 0.0107	90 ml	68.1780 68.1667 0.0113	68.1791 68.1667 0.0124	68.1780 68.1667 0.0113	0.0113 0.0008 0.0105	0.0105
62		RTE-1	78.1037 78.0924 0.0113	110 ml	78.1045 78.0924 0.0121	78.1054 78.0924 0.0130	78.1045 78.0924 0.0121	0.0121 0.0009 0.0112	0.0112
63		RTE-2	84.7105 84.6840 0.0265	120 ml	84.7110 84.6840 0.0270	84.7115 84.6840 0.0275	84.7105 84.6840 0.0265	0.0265 0.0010 0.0255	0.0255

Project No. 859 617

Collection Date _____

Analysis Date _____

#035

A-fabula W/2 R/jm

0.0063

Collection Date _____

Analysis Date _____

OK.

Silica gel #035
Total wt
gained

SAMPLES Astabula W/c R/m

CR NO.	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.		gms
	SHE-1	413.1 387.9 25.2			/			25.2
	SHE-2	400.6 383.4 17.2			/			17.2
	SHE-3	403.2 385.5 17.7			/			17.7
	SHE-4	396.3 384.7 11.6			/			11.6
	CH E-2	393.0 378.2 14.8			/			14.8
	CH E-3	401.5 385.1 16.4			/			16.4
	CH E-4	400.7 390.7 10.0			/			10.0
	NHE-1	407.9 383.5 24.4			/			24.4
	NHE-2	403.7 386.4 17.3			/			17.3
	NHE-3	409.7 392.2 17.5			/			17.5
	NHE-4	404.7 389.5 15.2			/			15.2
	ATE-1	389.3 382.2 7.1			/			7.1
	ATE-2	393.1 389.2 3.9			/			3.9
	ATE-3	391.8 386.5 5.3			/			5.3
	ASE-1	381.8 379.0 2.8			/			2.8

Project No. 859617

Collection Date _____

Analysis Date _____

Silica gel

#035

Total wt.
gained

SAMPLES

Astabula w/c R/m

NO.	CR	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.		gms
	☐	ACE-2	399.5 392.0 7.5			/			7.5
	☐	ACE-2	397.5 387.3 10.2			/			10.2
	☐	SWH-1	398.3 380.7 17.6			/			17.6
	☐	SWH-2	393.0 377.6 15.4			/			15.4
	☐	SWH-2	397.5 380.0 17.5			/			17.5
	☐	SEH-2	399.1 392.2 6.9			/			6.9
	☐	SEH-3	389.7 379.6 10.1			/			10.1
	☐	NEH-1	386.1 376.7 9.4			/			9.4
	☐	NEH-2	396.8 385.4 11.4			/			11.4
	☐	NEH-3	398.7 385.5 13.2			/			13.2
	☐	NWH-1	398.8 384.6 14.2			/			14.2
	☐	NWH-2	396.5 382.5 14.0			/			14.0
	☐	NWH-3	393.6 380.7 12.9			/			12.9
	☐	BTE-1	391.8 379.0 12.8			/			12.8
	☐	BTE-2	400.3 383.0 17.3			/			17.3

Project No.

859 617

Collection Date

Analysis Date

#035

SAMPLES Astabula W/c R/m

Project No. 859617

Analysis Date _____

SAMPLES

[illegible]

Analysis Date: March 29, 1972

ImE TR.4

Acetone Before
Total
WT

SAMPLES Astabula 1/1 R/m

1035

Beaker NO.	CR	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.		Weight - blank result	gms
1		Acetone Blank	71.6396 71.6386 0.0010	200 ml	71.6403 71.6396 0.0017	71.6403 71.6386 0.0017			0.0017	0.0017
2		SHE-1	71.4307 71.4011 0.0296	160 ml	71.4312 71.4011 0.0301	71.4312 71.4011 0.0301			0.0301 0.0014 0.0287	0.0287
3		SHE-2	76.2093 75.9125 0.2968	450 ml	76.2106 75.9125 0.2980	76.2098 75.9125 0.2973	76.2102 75.9125 0.2977	76.2093 75.9125 0.2968	0.2968 0.0038 0.2930	0.2930
4		SHE-3	79.4508 79.2476 0.2032	200 ml	79.4515 79.2476 0.2039	79.4511 79.2476 0.2035	79.4515 79.2476 0.2039		0.2039 0.0017 0.2022	0.2022
5		SHE-4	79.9484 79.8805 0.0679	100 ml	79.9493 79.8805 0.0688	79.9493 79.8805 0.0688			0.0688 0.0009 0.0679	0.0679
6		CHF-2	79.3371 79.2602 0.0769	100 ml	79.3377 79.2602 0.0775	79.3377 79.2602 0.0775			0.0775 0.0009 0.0766	0.0766
7		CHF-3	71.2935 71.2057 0.0878	175 ml	71.2940 71.2057 0.0883	71.2944 71.2057 0.0887	71.2944 71.2057 0.0887		0.0887 0.0015 0.0872	0.0872
8		CHF-4	74.1666 74.1154 0.0512	125 ml	74.1672 74.1154 0.0518	74.1672 74.1154 0.0518			0.0518 0.0011 0.0507	0.0507
9		NHE-1	74.0100 73.9407 0.0693	210 ml	74.0101 73.9407 0.0694	74.0104 73.9407 0.0697	74.0110 73.9407 0.0703	74.0104 73.9407 0.0697	0.0697 0.0018 0.0679	0.0679
10		NHE-2	80.0851 79.8488 0.2363	175 ml	80.0856 79.8488 0.2368	80.0858 79.8488 0.2370	80.0863 79.8488 0.2375	80.0858 79.8488 0.2370	0.2370 0.0015 0.2355	0.2355
11		NHE-3	75.4144 75.2792 0.1352	175 ml	75.4151 75.2792 0.1359	75.4148 75.2792 0.1356	75.4151 75.2792 0.1359		0.1359 0.0015 0.1344	0.1344
12		NHE-4	75.8138 75.7645 0.0493	100 ml	75.8141 75.7645 0.0496	75.8141 75.7645 0.0496			0.0496 0.0009 0.0497	0.0497
13		ATE-1	75.7704 75.7577 0.0127	60 ml	75.7711 75.7577 0.0134	75.7719 75.7577 0.0142	75.7719 75.7577 0.0142		0.0142 0.0005 0.0137	0.0137
14		ATE-2	77.7567 77.7493 0.0074	90 ml	77.7568 77.7493 0.0075	77.7585 77.7493 0.0092	77.7577 77.7493 0.0084	77.7571 77.7493 0.0078	0.0078 0.0008 0.0070	0.0070
15		ATE-3	75.9083 75.8888 0.0195	125 ml	75.9081 75.8888 0.0193	75.9092 75.8888 0.0204	75.9086 75.8888 0.0198	75.9086 75.8888 0.0198	0.0198 0.0011 0.0187	0.0187

Project No. 859617

Collection Date

Analysis Date

gpa 10/1

H₂O Imp
E/C extract
Total

SAMPLES

Astabula Yc Rm

25 ml
extra
of
chloro

NO.	CR	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.		V. eight - blank Result	gms
95		ASE-1	87.0765 87.0731 0.0034	100	87.0765 87.0731 0.0034				0.0034 0.0016 0.0018	0.0018
96		ASE-2	83.3194 83.2951 0.0243	150	83.3194 83.2951 0.0243	83.3183 83.2951 0.0234	83.3196 83.2951 0.0245		0.0245 0.0024 0.0221	0.0221
97		ASE-3	86.2004 86.1721 0.0283	150	86.1997 86.1721 0.0276	86.1997 86.1721 0.0270	86.2003 86.1721 0.0282	86.1993 86.1721 0.0272	86.1993 86.1721 0.0272	0.0272 0.0024 0.0248
98		SWH-1	82.5119 82.5094 0.0025	100	82.5119 82.5094 0.0025				0.0025 0.0016 0.0009	0.0009
99		SWH-2	81.6393 81.6367 0.0026	110	81.6393 81.6367 0.0026				0.0026 0.0018 0.0008	0.0008
100		SWH-3	81.7148 81.6998 0.0150	125	81.7153 81.6998 0.0155	81.7141 81.6998 0.0143	81.7146 81.6998 0.0148	81.7146 81.6998 0.0148	0.0148 0.0020 0.0128	0.0128
101		SEH-2	83.1211 83.1172 0.0039	125	83.1214 83.1172 0.0042	83.1200 83.1172 0.0028	83.1214 83.1172 0.0042		0.0042 0.0020 0.0022	0.0022
102		SEH-3	84.2722 84.2714 0.0008	110	84.2725 84.2714 0.0011	84.2710 84.2714 0.0006	84.2725 84.2714 0.0011		0.0011 0.0018 0.0003	0
103		SEH-1	82.0410 82.0390 0.0020	100	82.0408 82.0390 0.0018	82.0395 82.0390 0.0005	82.0405 82.0390 0.0015	82.0405 82.0390 0.0015	0.0015 0.0016 0.0001	0
104		SEH-2	80.7699 80.7678 0.0021	100	80.7696 80.7678 0.0018	80.7689 80.7678 0.0011	80.7689 80.7678 0.0011		0.0011 0.0016 0.0005	0
105		SEH-3	85.5136 85.5120 0.0016	100	85.5134 85.5120 0.0014	85.5126 85.5120 0.0006	85.5134 85.5120 0.0014		0.0014 0.0016 0.0002	0
106		SEH-1	85.8148 85.8124 0.0024	115	85.8146 85.8124 0.0022	85.8137 85.8124 0.0013	85.8146 85.8124 0.0022		0.0022 0.0018 0.0004	0.0004
107		SEH-2	89.3923 89.3906 0.0017	110	89.3923 89.3906 0.0017				0.0017 0.0018 0.0001	0
108		SEH-2	86.2284 86.2264 0.0020	100	86.2280 86.2264 0.0016	86.2269 86.2264 0.0005	86.2280 86.2264 0.0016		0.0016 0.0016 0.0000	0
109		SEH-1	78.4910 78.4890 0.0020	100	78.4907 78.4890 0.0017	78.4898 78.4890 0.0008	78.4907 78.4890 0.0017		0.0017 0.0016 0.0001	0.0001

Project No.

859617

Collection Date

Analysis Date

JDA
WAN

SAMPLES

Agaloula

we

22

70 IN PE/C

700

Beaker NO.	CR	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.		Weight blank Result	gms
80		Water blank	86.7123 86.7107 0.0016	100	86.7123 86.7107 0.0016				0.0016	0.0016 100 ml
81		SHE-1	81.7446 81.7360 0.0086	125	81.7443 81.7360 0.0083	81.7450 81.7360 0.0090	81.7450 81.7360 0.0090		0.0090 0.0020 0.0070	0.0070
82		SHE-2	84.2740 84.2450 0.0290	130	84.2734 84.2450 0.0284	84.2740 84.2450 0.0290			0.0290 0.0021 0.0269	0.0269
83		SHE-3	81.0171 81.0124 0.0047	110	81.0173 81.0124 0.0049	81.0173 81.0124 0.0049	81.0168 81.0124 0.0044		0.0044 0.0018 0.0026	0.0026
84		SHE-4	85.6744 85.6718 0.0026	100	85.6741 85.6718 0.0023	85.6741 85.6718 0.0023			0.0023 0.0016 0.0007	0.0007
85		SHE-2	81.0016 80.9930 0.0086	125	81.0012 80.9930 0.0082	81.0009 80.9930 0.0069	81.0012 80.9930 0.0082		0.0082 0.0020 0.0062	0.0062
86		SHE-3	68.3202 68.3175 0.0027	95	68.3195 68.3175 0.0020	68.3190 68.3175 0.0015	68.3199 68.3175 0.0024	68.3190 68.3175 0.0015	0.0015 0.0015 0	0
87		SHE-4	81.7672 81.7645 0.0027	115	81.7672 81.7645 0.0027				0.0027 0.0018 0.0009	0.0009
88		SHE-1	78.8029 78.7986 0.0043	100	78.8029 78.7986 0.0043				0.0043 0.0016 0.0027	0.0027
89		SHE-1	83.0211 83.0181 0.0030	100	83.0209 83.0181 0.0028	83.0209 83.0181 0.0019	83.0209 83.0181 0.0028		0.0028 0.0016 0.0012	0.0012
90		SHE-2	85.8163 85.8125 0.0038	100	85.8163 85.8125 0.0038				0.0038 0.0016 0.0022	0.0022
91		SHE-4	80.6137 80.6116 0.0021	100	80.6141 80.6116 0.0025	80.6132 80.6116 0.0016	80.6141 80.6116 0.0025		0.0025 0.0016 0.0009	0.0009
92		ATJ-1	81.3680 81.3657 0.0023	100	81.3680 81.3657 0.0023				0.0023 0.0016 0.0007	0.0007
93		ATJ-2	85.1560 85.1538 0.0022	100	85.1558 85.1538 0.0018	85.1537 85.1538 0.0001	85.1553 85.1538 0.0017	85.1556 85.1538 0.0018	0.0018 0.0016 0.0002	0.0002
94		ATJ-3	80.1755 80.1738 0.0017	100	80.1755 80.1738 0.0017				0.0017 0.0016 0.0001	0.0001

Project No.

857.617

Collection Date

Analysis Date

TR
WAH

SAMPLES

Asfahula 4/c R/m

Project No.

859617

Collection Date

Analysis Date

(1 of 3)

SAMPLES

NO.	CR	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.		Weight -blank result	gms
115		Water Blank	80.4254 80.4206 0.0048	315	80.4245 80.4206 0.0039	80.4230 80.4206 0.0024	80.4245 80.4206 0.0039	80.4245 80.4206 0.0039	0.0039	0.0039
116		CHE-1	81.2652 81.2050 0.0602	385	81.2585 81.2050 0.0535	81.2619 81.2050 0.0569	81.2624 81.2050 0.0574	81.2619 81.2050 0.0569	0.0048	
117		CHE-2	85.2500 85.1543 0.0957	380	85.2373 85.1543 0.0830	85.2373 85.1543 0.0830	85.2373 85.1543 0.0830	85.2373 85.1543 0.0830	0.0047	
118		SHE-3	85.4222 85.3926 0.0296	400	85.4160 85.3926 0.0234	85.4222 85.3926 0.0296	85.4222 85.3926 0.0296	85.4160 85.3926 0.0234	0.0050	
119		SHE-4	83.5750 83.5535 0.0215	405	83.5708 83.5535 0.0173	83.5750 83.5535 0.0215	83.5742 83.5535 0.0207	83.5710 83.5535 0.0175	0.0050	
120		CHE-2	85.1385 85.1059 0.0326	395	85.1339 85.1059 0.0280	85.1385 85.1059 0.0326	85.1339 85.1059 0.0280	85.1339 85.1059 0.0280	0.0280 0.0049 0.0231	0.0231
121		CHE-3	87.4313 87.3317 0.0996	395	87.4186 87.3317 0.0869	87.4313 87.3317 0.1077	87.4276 87.3317 0.0959	87.4276 87.3317 0.0959	0.0049	
122		CHE-4	83.9246 83.8599 0.0647	385	83.9152 83.8599 0.0553	83.9246 83.8599 0.0647	83.9228 83.8599 0.0629	83.9152 83.8599 0.0553	0.0553 0.0048 0.0505	0.0505
123		NHE-1	82.1534 82.1227 0.0307	385	82.1502 82.1227 0.0275	82.1534 82.1227 0.0307	82.1534 82.1227 0.0307	82.1534 82.1227 0.0307	0.0307 0.0048 0.0259	0.0259
124		NHE-2	82.3561 82.2742 0.0819	385	82.3486 82.2742 0.0744	82.3561 82.2742 0.0819	82.3582 82.2742 0.0840	82.3531 82.2742 0.0789	0.0048	
125		NHE-3	79.3437 79.1908 0.1529	390	79.3276 79.1908 0.1368	79.3562 79.1908 0.1654	79.3461 79.1908 0.1553	79.3406 79.1908 0.1498	0.0048	
126		NHE-4	82.2392 82.1552 0.0840	395	82.2312 82.1552 0.0760	82.2476 82.1552 0.0924	82.2358 82.1552 0.0806	82.2358 82.1552 0.0806	0.0049	
127		ATE-1	83.6034 83.5987 0.0047	395	83.6021 83.5987 0.0034	83.6024 83.5987 0.0037	83.6024 83.5987 0.0037	83.6024 83.5987 0.0037	0.0037 0.0047	0
128		ATE-2	80.3070 80.3032 0.0038	395	80.3059 80.3032 0.0027	80.3066 80.3032 0.0034	80.3055 80.3032 0.0023	80.3039 80.3032 0.0007	0.0027 0.0049	0
129		ATE-3	81.4346 81.4302 0.0044	395	81.4333 81.4302 0.0031	81.4339 81.4302 0.0037	81.4335 81.4302 0.0033	81.4333 81.4302 0.0031	0.0031 0.0049	0

Project No. 559617

Collection Date

Analysis Date

Imp H₂O Remainder (2 of 3)
Total wt.
(continued)

SAMPLES *Astabola*

CR	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.		Weight - blank result	gms
NO.									
116	SH L-1	81.2594 81.2050 0.0544	81.2585 81.2050 0.0535					0.0535 0.0048 0.0487	0.0487
117	-2	85.2422 85.1543 0.0879	85.2378 85.1543 0.0835	85.2383 85.1543 0.0840	85.2378 85.1543 0.0835			0.0835 0.0047 0.0788	0.0788
118	-3	85.4184 85.3926 0.0258	85.4164 85.3926 0.0238	85.4164 85.3926 0.0238				0.0238 0.0050 0.0188	0.0188
119	-4	83.5712 83.5535 0.0177	83.5703 83.5535 0.0168	83.5708 83.5535 0.0173				0.0173 0.0050 0.0123	0.0123
120	CHE-2								
121	-3	87.4240 87.3317 0.0923	87.4201 87.3317 0.0884	87.4216 87.3317 0.0899	87.4214 87.3317 0.0897	87.4216 87.3317 0.0899		0.0899 0.0049 0.0850	0.0850
122	-4								
123	NHE-1								
124	-2	82.3481 82.2742 0.0739	82.3474 82.2742 0.0732	82.3496 82.2742 0.0754	82.3488 82.2742 0.0746	82.3500 82.2742 0.0758	82.3510 82.2742 0.0768	0.0768	
125	-3	79.3332 79.1908 0.1424	79.3325 79.1908 0.1417	79.3344 79.1908 0.1436	79.3342 79.1908 0.1434	79.3364 79.1908 0.1456	79.3389 79.1908 0.1481	0.1481	
126	-4	82.2310 82.1552 0.0758	82.2297 82.1552 0.0745	82.2323 82.1552 0.0771	82.2306 82.1552 0.0754	82.2330 82.1552 0.0778	82.2348 82.1552 0.0796	0.0796	
	control	85.3022 ST-1 85.3034	85.3036 85.3034	85.3034 85.3036					

Project No. _____

Collection Date _____

Analysis Date _____

Imp Remainder (3 of 3)
Total wt.
(cont.)

SAMPLES Astabula

NO.	CR	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.		Weight - blank result	gms
124		NHE-2	82.2742 0.0760	82.3502 0.0760					0.0760 0.0048 0.0712	0.0712
125		NHE-3	79.3370 0.1462	79.3359 0.1451	79.3348 0.1450	79.3366 0.1458	79.3359 0.1451		0.1451 0.0048 0.1403	0.1403
126		NHE-4	82.2342 0.0790	82.2318 0.0766	82.2323 0.0771				0.0771 0.0049 0.0722	0.0722
		Control	85.2022 85.2031	80.3032	85.3037	85.3032				

Project No. _____

Collection Date _____

Analysis Date _____

Imp H₂O remainder
Total

SAMPLES Agtaabula Wp R/m

NO.	CR	LOCATION and SAMPLE NO.		SAMPLE WEIGHT	TIT. ALIQ.	Reading Blank	MG in ALIQ.		gms		
130		ASE-1	88.3037 88.2970 0.0067	395	88.3032 88.2970 0.0062	88.3035 88.2970 0.0065	88.3032 88.2970 0.0062	0.0062 0.0049 0.0013	0.0013		
131		ASE-2	79.7873 79.7787 0.0086	465	79.7867 79.7787 0.0080	79.7864 79.7787 0.0077	79.7864 79.7787 0.0077	0.0077 0.0058 0.0019	0.0019		
132		ASE-3	83.2813 83.2722 0.0091	465	83.2805 83.2722 0.0083	83.2807 83.2722 0.0085	83.2807 83.2722 0.0085	0.0085 0.0058 0.0027	0.0027		
133		SWH-1	81.8743 81.8702 0.0041	385	81.8732 81.8702 0.0030	81.8736 81.8702 0.0034	81.8736 81.8702 0.0034	0.0034 0.0048 —	0		
134		SWH-2	79.5816 79.5762 0.0054	385	79.5806 79.5762 0.0044	79.5810 79.5762 0.0048	79.5810 79.5762 0.0048	0.0048 0.0048 0.0000	0		
135		SWH-3	78.7089 78.6391 0.0698	390	78.7082 78.6391 0.0691	78.7086 78.6391 0.0695	78.7086 78.6391 0.0695	0.0695 0.0048 0.0647	0.0647		
136		SEH-2	85.1968 85.1898 0.0070	385	85.1959 85.1898 0.0061	85.1963 85.1898 0.0065	85.1963 85.1898 0.0065	0.0065 0.0048 0.0017	0.0017		
137		SEH-3	79.7285 79.7242 0.0043	390	79.7277 79.7242 0.0035	79.7283 79.7242 0.0041	79.7285 79.7242 0.0043	0.0043 0.0048 —	0		
138		NEH-1	80.0206 80.0136 0.0070	385	80.0197 80.0136 0.0061	80.0208 80.0136 0.0072	80.0204 80.0136 0.0068	80.0197 80.0136 0.0061	0.0061 0.0048 0.0013	0.0013	
139		NEH-2	85.7838 85.7707 0.0131	380	85.7826 85.7707 0.0119	85.7837 85.7707 0.0130	85.7828 85.7707 0.0121	85.7828 85.7707 0.0121	0.0121 0.0047 0.0074	0.0074	
140		NEH-3	83.6020 83.5915 0.0105	390	83.6012 83.5915 0.0097	83.6018 83.5915 0.0103	83.6009 83.5915 0.0094	83.6006 83.5915 0.0091	83.6006 83.5915 0.0091	0.0091 0.0048 0.0043	0.0043
141		NWH-1	85.4966 85.4838 0.0128	385	85.4951 85.4838 0.0113	85.4963 85.4838 0.0125	85.4958 85.4838 0.0120	85.4951 85.4838 0.0113	0.0113 0.0048 0.0065	0.0065	
142		NWH-2	82.9639 82.9597 0.0042	380	82.9625 82.9597 0.0028	82.9629 82.9597 0.0032	82.9629 82.9597 0.0032	82.9629 82.9597 0.0032	0.0032 0.0047 —	0	
143		NWH-3	81.7884 81.7840 0.0044	395	81.7876 81.7840 0.0036	81.7882 81.7840 0.0042	81.7876 81.7840 0.0036	81.7876 81.7840 0.0036	0.0036 0.0049 —	0	
144		BTE-1	80.5338 80.5271 0.0067	395	80.5328 80.5271 0.0057	80.5334 80.5271 0.0063	80.5328 80.5271 0.0057	80.5328 80.5271 0.0057	0.0057 0.0049 0.0008	0.0008	

Project No. 859 417

Collection Date _____

Analysis Date _____

SAMPLES

[illegible]

JDH

APPENDIX G

TEST LOG

TEST LOGS

No. 20 Furnace

<u>Date</u>	<u>Time</u>	<u>Activity</u>
2/14/72		A.M. Travel P.M. Arrived, Safety Briefing, Unpack and prepare equipment, Furnace No. 20.
2/15/72		A.M. Placed Equipment
	1340-1700	P.M. First Sample - Hood Ducts
2/16/72		A.M. Furnace Down
	1100-1240	Second Sample - Hood Ducts
	1130-1500	Carbon Monoxide Sampling - Hood Duct
	1335-1450	P.M. Third and Fourth Sample - Hood Duct
	1650-1800	
2/17/72		A.M. Furnace Down
	1348-1405	P.M. First Sample - Tapping Exhaust
	1406-1410	First Sample - Scrubber Exhaust and Water Sample
	1639-1655	Second Sample - Tapping Exhaust
	1543-1606	Second and Third Sample - Scrubber Exhaust and Water Sample
	1637-1707	
2/18/72		A.M. Safety Briefing for No. 13 Furnace
		Orsat Analysis - Hood and Tapping Exhausts
	1014-1026	Third Sample - Tapping Exhaust
		Moved equipment to No. 13 Furnace
		P.M. Travel

No. 13 Furnace

<u>Date</u>	<u>Time</u>	<u>Activity</u>
2/21/72		P.M. Travel
2/22/72		A.M. Furnace Down
	1415-1535	P.M. First Sample - Hood Exhausts
2/23/72		A.M. Second Sample - Hood Exhausts
	0900-1020	Third Sample - Hood Exhausts
	1220-1340	

No. 13 Furnace (con't)

	1530-1630	P.M. First Sample - Tapping Exhaust
	1520-1620	First Sample - Scrubber Exhaust and Water
	1230-1600	Carbon Monoxide Sampling - Hood and Tapping Exhausts
2/24/72	0855-0955	A.M. Second and Third Samples - Scrubber Exhaust and Water
	1010-1110	Second and Third Samples - Tapping Exhaust
	0903-1003	P.M. Orsat Analysis - Hood, Tapping and Scrubber Exhausts
	1034-1134	Pack equipment
2/25/72		A.M. Travel

APPENDIX H
RELATED REPORTS

Related reports covering emissions from reactive metals furnaces, under this same contract for the Environmental Protection Agency, are as follows:

<u>Test Number</u>	<u>Survey Location</u>	<u>Emission Control Device</u>	<u>Status</u>
FA-1	Foot Mineral Co., Steubenville, Ohio	None	Issued August 1971
FA-2	Union Carbide Corp., Marietta, Ohio	Venturi Scrubber	Issued October 1971
FA-3	AIRCO, Alloys and Carbide, Niagara Falls, New York	Baghouse	Revised December 1971
FA-4	AIRCO, Alloys and Carbide, Charleston, South Carolina	Electrostatic Precipitator	Issued November 1971
FA-5	Union Carbide Corp., Alloy, W. Va.	Baghouse	Issued June 1972
FA-6	Chromasco Corp., Woodstock, Tennessee	Scrubber	Issued June 1972
FA-7	Union Carbide Corp., Ashtabula, Ohio	Scrubber	This Report

APPENDIX I
PROJECT PARTICIPANTS AND TITLES

R. N. Allen, P. E., Project Manager
T. E. Eggleston, Industrial Hygienist, Crew Leader
C. C. Gonzalez, Chemist
G. A. Cangiano, Engineer
G. B. Patchell, Senior Technician
J. R. Avery, Technician
L. W. Baxley, Technician
B. M. Brown, Technician
J. R. McReynolds, Technician