




A SURVEY OF
ALTERNATE METHODS FOR
COOLING CONDENSER DISCHARGE
WATER

SYSTEM, SELECTION, DESIGN,
AND OPTIMIZATION



WATER POLLUTION CONTROL RESEARCH SERIES

The Water Pollution Control Research Series describes the results and progress in the control and abatement of pollution in our Nation's waters. They provide a central source of information on the research , development, and demonstration activities in the Water Quality Office, Environmental Protection Agency, through inhouse research and grants and contracts with Federal, State, and local agencies, research institutions, and industrial organizations.

Inquiries pertaining to Water Pollution Control Research Reports should be directed to the Head, Project Reports System, Office of Research and Development, Water Quality Office, Environmental Protection Agency, Room 1108, Washington, D. C. 20242.

A SURVEY OF ALTERNATE METHODS
FOR COOLING CONDENSER DISCHARGE WATER

SYSTEM, SELECTION, DESIGN, AND OPTIMIZATION

by

DYNATECH R/D COMPANY
A Division of Dynatech Corporation
Cambridge, Massachusetts 02139

for the
WATER QUALITY OFFICE
ENVIRONMENTAL PROTECTION AGENCY

Project No. 16130 DHS
Contract No. 12-14-477

January, 1971

EPA Review Notice

This report has been reviewed by the Water Quality Office, EPA, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the Environmental Protection Agency, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

TABLE OF CONTENTS

<u>Section</u>		<u>Page</u>
1	INTRODUCTION	1
	1.1 Overall Program Goals	1
	1.2 Scope of Task I	1
	1.3 General Method	3
2	POWER PLANT MODEL	6
	2.1 General Description	6
	2.2 Input Data	6
	2.3 Preparation of Input Data Cards	9
	2.4 Test Data	11
	2.5 Power Plant Calculations in the Main Program	12
	2.6 Program Optimization	17
3	ONCE-THROUGH COOLING	19
	3.1 General Description	19
	3.2 Assumptions	19
	3.3 Basic Equations	20
	3.4 Plume Analysis	22
	3.5 Flow Diagram	27
	3.6 Results	27
4	COOLING POND	35
	4.1 General Description	35
	4.2 Assumptions	35
	4.3 Basic Equations	36
	4.4 Flow Diagram	36
	4.5 Results	36
5	MECHANICAL DRAFT WET COOLING TOWER	44
	5.1 General Description	44
	5.2 Assumptions	44
	5.3 Basic Equations	45
	5.4 Flow Diagram	49
	5.5 Results	49
6	NATURAL DRAFT WET COOLING TOWER	54
	6.1 General Description	54
	6.2 Assumptions	54
	6.3 Basic Equations	55
	6.4 Flow Diagram	56
	6.5 Results	56
	REFERENCES	62
	APPENDIX	65

Section 1

INTRODUCTION

1.1 Overall Program Goals

In December 1968, Dynatech R/D Company undertook a program for the Federal Water Quality Administration (then the FWPCA) with the ultimate aim of performing a survey and economic analysis of alternate methods for cooling condenser discharge water from thermal power plants. The first phase of this program was to consist of a systematic gathering of present state-of-the-art information in the areas of large scale heat rejection equipment, power plant operating characteristics, and total community considerations. The second phase of this program was to consist of work in the areas of:

1. Selection of input parameters and optimization criteria.
2. Limitations and advances in heat rejection units.
3. Extensive modifications of present power cycles.
4. Advanced total community concepts.

This report will document the results of Phase II, Task I of this program.

1.2 Scope of Task I

The first task of the second phase of this program has as an overall goal the quantification of cooling system costs as a function of various parameters, the definition of the interface requirements between the power plant and the cooling system, and the optimization of the total power cost.

A previous task, as reported in July 1969, (Ref. 1) presented, in detail, considerations of alternate methods of transferring large quantities of rejected heat to the atmosphere. The results of this analysis led to the expected conclusion that, for a given heat level and ambient conditions, the size and cost of the heat rejection equipment decreases with an increase in process side temperature. This cost relationship is shown as curve A in Figure 1.1.




Figure 1.1. System Cost Versus Condenser Temperature

A later task, as reported in May 1970 (Ref. 2), described, in detail, the increase in power plant cost as a result of an increase in condenser temperature. This type of relationship is shown as curves B and C in Figure 1.1. Curve B may be thought of as representing an existing power plant forced to operate at a higher than design condenser temperature while curve C represents a possible locus of costs for plants designed for various condenser temperatures.

The goal of this task then is to quantify these curves, and to find a means of obtaining the minimum of the sum of the two costs for a wide range of ambient conditions and power plant parameters.

1.3 General Method

The general method of approach to this task has been the development of a computer program for the calculation of both cooling system and power plant costs and the determination of the minimum total cost for a given set of parameters. To this end, the effect of various design parameters have been studied to determine which have significant effects on the performance of the various cooling schemes and which parameters are important to the calculation of power plant costs. Design equations based on these parameters have been developed for the cooling systems and power plant, and incorporated into a computer program through which the minimum total cost is calculated.

A number of options are open to the user of the program such as full time or part time use of the cooling system, an open or closed cooling system, a specified or "designed" condenser, and variable ambient conditions. Also available is the ability to match projected power plant operation at different capacities over varying time periods.

Part time use of the cooling system is represented in Figure 1.2 and is applicable only to cooling systems that use a water cooled condenser such as cooling towers and cooling ponds.

An open cooling system, or "topping" operation is shown in Figure 1.3 and is again applicable only to cooling systems that use a water cooled condenser.




Figure 1.2. Part Time Use of External Cooling




Figure 1.3. Open or Topping Cooling System (Shown as seasonal operation--can be used as full time open system also)

The water cooled condenser, as part of the external cooling system, may be specified or it will be "designed" by the program. This provides the option, for existing power plants that must have external cooling systems added, of either building an oversized external system to match the existing condenser or rebuilding the condenser such that the external cooling system and the condenser are matched and of minimum cost. Depending on the particular power plant, either method may result in the least overall cost.

Operation of the power plant and the cooling system at various ambient conditions for different periods of time has been provided for in the program. This is because cooling systems are usually designed for adverse and seldom occurring ambient conditions and do not operate under these extreme conditions most of the time. The program accounts for this in that it "designs" a cooling system for a given set of ambient conditions (usually specified as the most severe) but calculates operating costs of both the cooling system and power plant for up to five other sets of ambient conditions with a specified operating time per year for each.

Operation of the power plant at up to five off-design capacities for a specified number of hours per year has been provided in the program and is necessary to simulate actual power plant practice. The disadvantage to this is that plant operating characteristics (heat rate and auxiliary power) often are quite different for off design operation, and therefore must be specified for each capacity used. This is simplified somewhat, however, by available data such as contained in GE 2050B, included in Reference 2.

The remainder of this report, which describes the computer program, is divided into five sections. The first section describes the model of the power plant and the input data that is required. The following sections provide brief descriptions of the input (interface) requirements for each cooling system, review the general computational procedures, and describe the output. The details are obtainable from the program listings themselves (included in the appendix) which contain "comment" cards for ease of interpretation. A glossary of variable names for the whole program is also provided in the Appendix.

Section 2

POWER PLANT MODEL

2.1 General Description

As indicated in Section 1, the total design and optimization program consists of providing a mathematical description of the operating characteristics and system costs of the power plant itself, a similar model for alternative cooling schemes, and a means of interfacing these two subsystems and computing the total cost. Various combinations are then searched to find a minimum cost solution.

The first part of this program contains not only the mathematical description of power plant operation but it is also the control program which provides the interface information between the plant and the cooling system. This is indicated in a generalized flow chart of the program in Figure 2.1.

Basically, the "Power Plant Model" carries out two functions. First, it receives and manipulates all of the required input information to the optimization program. These inputs include such items as plant design capacity, projected load demands, plant efficiency ratings, projected cooling requirements, expected ambient conditions, and relevant economic data. A complete listing is given in Section 2.2. These input data are then manipulated to put the data into a form directly useful in the forthcoming computations. This portion of the model is contained in the first part of the main program.

The second function of the Power Plant Model is accomplished in subroutine PAFCST, an operational subroutine, which simulates power plant operation and provides heat rejection requirements and plant cost information to the cooling system subroutines.

2.2 Input Data

The data describing the power plant and the operation of it are read in the first portion of the program and, in order of input, are as follows:




Figure 2.1

<u>Variable</u>		<u>Description</u>
PSIZE	-	Power plant size--the maximum electrical output of the plant and the size for which the cooling systems are to be designed (Mwe).
CCPKW	-	Power plant capital cost including a standard once through condenser (\$/kw).
ANFCR	-	Annual fixed charge rate (%/yr).
FUCST	-	Fuel cost (¢/million Btu).
PRPAGR	-	Land cost (\$/acre).
NCAPS	-	Number of different plant capacities for which heat rate data is supplied (maximum of 5 excluding design capacity).
CAP(I)	-	Various plant capacities (%/100).
TOTLD(I)	-	Total loading--number of hours per year that the plant operates at each capacity (hrs/yr).
COLPCT(I)	-	Cooling percent--percent of the total operating time at each capacity (TOTLD(I)) that the cooling system is used. (%/100).
NHRPTS(I)	-	Number of heat rate points--the number of condenser pressures and corresponding heat rates to be input for each capacity.
PCMIN(I)	-	Minimum condenser pressure at each capacity (in. Hg.).
PCMAX(I)	-	Maximum condenser pressure at each capacity (in. Hg.).

<u>Variable</u>		<u>Description</u>
HRP(I, J)*	-	Condenser pressure for each heat rate at each capacity (in. Hg.) (do not have to include PCMAX(I) and PCMIN(I))
TURBHR(I, J)* -		Turbine heat rate corresponding to each condenser pressure, HRP(I, J), for each capacity (Btu/kwhr).

The following input data pertain more to the cooling systems than to the power plant but are included here since they are read in the same part of the program as the power plant data.

TDB	-	Design ambient dry bulb temperature ($^{\circ}$ F)
TWB	-	Design ambient wet bulb temperature ($^{\circ}$ F)
TAVH2O	-	Design available water temperature ($^{\circ}$ F)
PCBASE	-	Base condenser pressure--a base average condenser pressure at which the plant would operate if external cooling were not required (in. Hg.).
WIND		Design wind velocity (MPH)
RAD		Design radiation intensity (Btu/ ft^2/day)
NH2O	-	Type of cooling water to be used in the cooling system -1 = Seawater \emptyset = Untreated fresh water +1 = Treated fresh water
NTAMB	-	Number of different ambient temperatures.
TAMDB(I)	-	Various ambient dry bulb temperatures ($^{\circ}$ F)
TAMWB(I)	-	Various ambient wet bulb temperatures ($^{\circ}$ F)

*These values are obtained from General Electric Heat Rate Tables (Ref. 2) or other similar data.

<u>Variable</u>		<u>Description</u>
TAMRV(I)	-	Various river temperature(° F)
AMWIND (I)	-	Various wind velocities (MPH)
AMRAD (I)	-	Various radiation fluxes (Btu/ ft ² / day)
PCTAMB(I, J)	-	Percent of the cooling system use time, COLPCT(I) x TOTLD(I), at each capacity. that the cooling system operates at the specified ambient temperatures, TAMDB(I) and TAMWB(J) (%/100).
WIDTH	-	Width of river or estuary (ft).
NSYSOP	-	Type of cooling system operation 0 = closed cycle operation 2 = topping
NSPCON	-	Whether or not the condenser is specified 0 = no 1 = yes
TDISMX	-	Maximum water discharge temperature (only if topping used) (° F)
UOVALL	-	Overall heat transfer coefficient for the condenser (only if condenser is specified) (Btu/ hr-ft ² -° F).
AREAC	-	Total heat transfer area (only if condenser is specified) (ft ²)
SPFLOW	-	Condenser water flow (only if condenser is specified) (lbm/ hr)
NSUBS(I)	-	Controls which of the cooling subroutines is called. If NSUBS (I) is zero, the <u>I</u> th subroutine is not called.

<u>I</u>	<u>Subroutine</u>
1	Listing of input data (part of main program)
2	Once through cooling (SUBPOLU)
3	Cooling Pond (SUBPOND)
4	Mechanical Draft Wet Tower (SUBMDW)
5	Natural Draft Wet Tower (SUBNOW)

Preparation of input data cards

All cards are required for each set of input conditions, although all cooling options may be run with one set of plant and ambient data. FORTRAN format specifications are shown for each input card required.

Card 1: PSIZE, CCPKW, ANFCR, FUCST, PRPAGR, NCAPS (5F10.0,I10)

Card 2: CAP (I), I = 1,5 (5F10.2)

Card 3: TOTLD (I), I = 1,5 (5F10.0)

Card 4: COLPCT (I), I = 1,5 (5F10.2)

Card 5: NHRPTS (I), I = 1,6 (6I10)

Card 6: PCMIN (I), I = 1,6 (6F10.2)

Card 7: PCMAX (I), I = 1,6 (6F10.2)

Cards 8-X: NNCAP sets (a set for each capacity, plus one if design data are input. See Section 2.4) of two cards each:

card A: HRP (SET NUMBER, J), J = 1,6 (6F10.2)

card B: TURBHR (SET NUMBER, J), J = 1,6 (6F10.0)

Card X + 1: TDB, TWB, TAVH20, PCBASE, WIND, RAD, NH20,
NTAMB (6F10.0,2I10)

Card X + 2: TAMDB (I), I = 1, NTAMB (5F10.0)

Card X + 3: TAMWB(I), I = 1, NTAMB (5F10.0)

Card X + 4: TAMRV (I), I = 1, NTAMB (5F10.0)

Card X + 5: AMWIND (I), I = 1, NTAMB (5F10.0)

Card X + 6: AMRAD (I), I = 1, NTAMB (5F10.0)

Cards X + 7-Y: NCAPS cards each with PCTAMB
(SET NUMBER, J), J = 1, NTAMB (5F10.2)

Card Y + 1: WIDTH, NSYSOP, NSPCON, TDISMX, UOVALL,
AREAC, SPFLOW (F10.0,2I10,4F10.0)

Card Y + 2: NSUBS (I), I = 1,5 (5I10)

2.4 Test Data

Four sets of input data have been used to obtain cooling system costs. These four data sets have been designated SUBD1, SUBD2, SUBD3, and SUBD4. All four sets contain the same power plant data and ambient temperature but each describes a different type of cooling system operation as described below.

- SUBD1 - Condenser is specified and the cooling system is used for topping.
- SUBD2 - Condenser is specified and the cooling system is a closed system.
- SUBD3 - Condenser is "designed" and the cooling system is used for topping.
- SUBD4 - Condenser is "designed" and the cooling system is a closed system.

Listings of these four sets of data are included in the Appendix, and the input data printout, when SUBD1 is used, is shown in Table 2.1.

*Number of cards depends on number of capacities specified.

Table 2.1

-----PRINTOUT OF INPUT DATA-----

PSIZE	CAP \$	ANFCR	FUEL \$	PRPAGR
200	150	.12	10	1000

**CAPACITIES AND CORRESPONDING DATA
(EXTRA VALUES ARE DESIGN DATA)**

CAPACITY -	1.00	.80	.60	.25	0
HRS/YEAR -	5150	1750	800	700	360
PCT COOLING -	.80	.70	.50	.30	.15
MIN P COND -	1.50	1.00	1.00	1.00	1.00
MIN T COND -	91.72	79.04	79.04	79.04	79.04
MAX P COND -	3.50	4.00	4.00	4.50	4.50
MAX T COND -	120.55	125.41	125.41	129.77	129.77
CAPACITY FACTOR =	.82				
COOLING USE FACTOR =	.75				

COND PRESS AND CORRESPONDING DATA AT EACH CAPACITY

CAPACITY = 1.00

PRESSURE -	1.50	2.50	3.50
T HEAT RATE -	7987	8037	8153

CAPACITY = .80

PRESSURE -	1.00	2.00	3.00
T HEAT RATE -	7974	8025	8174

CAPACITY = .60

PRESSURE -	1.00	2.00	3.00	3.50
T HEAT RATE -	8055	8195	8430	8543

CAPACITY = .25

PRESSURE -	1.00	2.00	3.00
T HEAT RATE -	8828	9381	9815

CAPACITY = 0

PRESSURE -	1.00	2.00	3.00
T HEAT RATE -	0	0	0

DESIGN VALUES (CAPACITY = PLANT SIZE)

PRESSURE -	1.50	2.00	2.50	3.00	3.50
T HEAT RATE -	8000	8009	8042	8089	8151

DRY BULB T	WET BULB T	WIND SPEED	RADIATION
85	75	10.0	4000

AVAIL H₂O T TYPE AVAILABLE H₂O

75	-1
BASE P COND	BASE T COND
1.50	91.7

Table 2.1 (Concluded)

VARIABLE AMBIENT TEMPERATURES

DRY BULB -	70	80	85
WET BULB -	60	70	70
RIVER -	60	65	70
WIND	10.0	10.0	10.0
RADIATION	4000	4000	4000

PERCENT OF COOLING SYSTEM TIME AT ABOVE
AMBIENT CONDITIONS

CAP = 1.00 -	.25	.25	.50
CAP = .80 -	.30	.30	.40
CAP = .60 -	.40	.30	.30
CAP = .25 -	.50	.25	.25
CAP = 0 -	0	0	1.00

RIVER WIDTH	TYPE COOLING(2=TOPPING)	COND SPECIFIED(1=YES)
2000	?	1

MAX DISCHARGE TEMP = 85

CONDENSER SPECIFICATIONS
OVERALL U = 350
TUBE AREA = 2.760E 05
H₂O FLOW = 4.200E 07

2.5 Power Plant Calculations in the Main Program

The first calculation that is performed in the main program, after the data are read, is to check that the total load duration hours per year equals 8760 hours (including 0 capacity operation), and that, for each capacity, the total percent of operating time at the various ambient conditions equals 100.

The design relative humidity, RH, and the variable ambient relative humidity, AMBRH(I), are then calculated from the wet bulb and dry bulb temperatures with the use of the Carrier equation (cf Ref. 3).

Following the calculation of the relative humidities is the quadratic curve fit of the heat rate points. The curve fit is necessary to provide continuous heat rate values, at the various plant capacities, for condenser pressures between the specified points. The actual curve fit is in terms of condenser temperature rather than pressure, so that the specified condenser pressure input data is first converted to saturation temperature. Also, immediately following this conversion, the maximum and minimum allowable condenser pressures and the base condenser pressure are converted to corresponding saturation temperatures.

If "design" heat rate data is not included in the input, then the program assumes that the 100 percent plant capacity data is to be used for design. This conversion is performed next in the program. Either 100 percent plant capacity data or "design" data must be specified for the program to run. Both may be specified since it may be desirable to "design" the cooling system to match plant operation under special conditions such as above rated capacity ("valves wide open", overpressure, and/or feedwater heaters shut down - see Ref. 2).

Plant capacity factor and cooling system use factor are calculated from the load data. The capacity factor is a measure of the use of the plant relative to its hypothetical maximum design use,

$$\text{CAPFAC} = \frac{\text{total kwhrs output in year}}{\text{maximum design output}} \\ (\text{plant at full design capacity for 8760 hours})$$

The cooling system use factor is the average percent of plant output that is created while the cooling system is in use,

$$\text{USEFAC} = \frac{\text{kwhrs output with cooling system in use}}{\text{total kwhrs output in year}}$$

The capacity factor is used to adjust capital cost to be in terms of actual output (kwhrs) in a year, and the use factor is used to adjust cooling system operating cost to be in terms of total plant output in a year.

If the computer system on which the program is to be run cannot handle all the code necessary for the main program and each of the subroutines, the subroutines for cooling methods which will not be used can be omitted, and the references to them in the main program deleted.

2.6 Program Optimization

Following preliminary calculations in the main program, control is transferred to one of the operational subroutines, SUBPOLU, SUBPOND, SUBMDW, or SUBNDW, where the optimum cooling system design is determined. The method of optimization used in these subroutines is a complete search of all allowable combinations of the design variables. Obviously, however, when part of the cooling system is specified, such as the condenser, the design variables describing them are not varied.

In the general case, there are two temperatures that are varied to determine the optimum tower, the condenser temperature and the water discharge temperature from the tower or pond. The condenser temperature is set to the lowest possible value and tower costs are calculated for the full range of possible discharge temperatures. The condenser temperature is then increased by 1° F and the calculations made again for the range of discharge temperatures. The process is repeated until the condenser temperature has been increased to its maximum

prescribed value. During the whole process, each time a combination of variables resulted in a tower cost less than the preceding lowest one, the variables were "saved" for future comparison. Therefore, after all combinations have been tried the "saved" combinations will be the least cost and therefore the optimum.

This optimization procedure is shown in more detail in Figures 3.2, 4.1, and 5.3.

2.7 Subroutine PAFCST (Power and Fuel Cost)

This subroutine, which is "called" by the cooling system subroutines, calculates auxiliary power cost, differential fuel cost, and heat rejected from the power plant for operation at a given capacity and condenser temperature.

At each capacity a base heat rate, HRBASE, is first calculated with the quadratic coefficients, HRCOF2(I), HRCOF1(I), and HRCOF0(I), and the base condenser temperature. The actual heat rate is then calculated at the desired condenser temperature and the heat rejected, QREJ calculated by

$$QREJ = (HEATR-3413) \times PSIZE \times CAP(I) \quad (2.1)$$

where HEATR = net heat rate - (Btu/kwhr)
 PSIZE = total rated plant output (Mw)
 CAP(I) = plant capacity of interest (%/100)

Boiler efficiency (stack heat loss) is not included in the above equation since the net heat rate used is defined as the heat added to the steam divided by the net power output.

The differential fuel cost is calculated by

$$\text{DELFC} = \text{FUCST} \times (\text{HEATR} - \text{HRBASE}) \quad (\text{mills/kwhr}) \quad (2.2)$$

where FUCST = fuel cost (¢/million Btu)
 HRBASE = base heat rate (Btu/kwhr)

The auxiliary power cost is calculated by

$$\text{PWCST} = \text{FUCST} \times \text{HEATR} + \frac{\text{CCPKW} \times \text{ANFCR}}{\text{CAPFAC} \times 8.76} \quad (\text{mills/kwhr}) \quad (2.3)$$

where CCPKW = plant capital cost (\$/kw)
 ANFCR = annual fixed charge rate (%/100)
 CAPFAC = capacity factor (%/100)

Section 3

ONCE-THROUGH COOLING

3.1 General Description

The calculations and logic for the design of a once-through cooling are contained in two subroutines, SUBPOLU and COND. Subroutine SUBPOLU contains most of the logic and about half of the cost calculations for this type of cooling. It is divided into two parts, a design section in which the cooling system costs are calculated for the design ambient conditions and power output, and an off-design section in which the operating costs are recalculated using the specified variable capacities and ambient conditions. The condenser may be specified as already existing, in which case the capital cost is not included in the total system cost.

Also included in subroutine SUBPOLU is a calculation and printout of river temperatures downstream of the plant. This includes both mixed river temperatures and plume temperatures, and plume width for a specified river. The equilibrium temperature and plume temperature are determined from data and equations taken from Reference 5.

Subroutine COND, which is also used by other cooling systems requiring a water cooled condenser, contains the basic design and cost calculations for the condenser itself.

3.2 Assumptions

Variables and equations for which numerical assumptions have been made in the subroutine are listed below, so that the cards may be changed if different numerical values are desired.

<u>Variable (sequence or line #)</u>	<u>Comments and/or Recommended Values</u>
<u>Subroutine SUBPOLU</u>	
WIND (255)	
QFLRIV (256)	
DEPTH (257)	
RAD (258)	4000 - 6000
PMPEF (259)	0.8 - 0.85
WCOFA (264)	Should be of the form used in Reference 5
WCOFB (265)	
DT2 (293)	Need not correspond to (not used for) specified condenser
PLAC (306-310)	1.5, 1.25, 1.0 for seawater, untreated fresh, and treated fresh water, respectively.
PHEAD (315)	
COSMAI (319)	Form of equation and percentages both assumed
<u>Subroutine COND</u>	
PMPEF (1252)	0.8 - 0.85
UALL (1257-1261)	420., 340., and 250 correspond to treated fresh water, untreated fresh water, and sea water, respectively.
CONCST (1270)	Form and coefficients of equation assumed.
CHEAD (1276)	35.

3.3 Basic Equations

For the condenser the basic size equation for the total heat transfer area is

$$A_{COND} = \frac{Q_{REJ}}{U_{ALL} \times DTLGM} \quad (3.1)$$

where Q_{REJ} = total heat rejected (Btu/hr)
 U_{ALL} = overall heat transfer coefficient ($Btu/\text{hr}\cdot\text{ft}^2\cdot{}^\circ\text{F}$)
 $DTLGM$ = log mean temperature difference (${}^\circ\text{F}$)

The capital cost equation for the condenser, derived from data in References 7, 12, and 13 is

$$\text{CONCST} = 20. \times (1.05 \times \text{ACOND})^{0.9} \quad (\$) \quad (3.2)$$

Added to this is \$1/GPM for the cost of the water pumps.

The condenser system cost is the sum of the capital cost (capital charge per year) and the pumping costs, which are

$$\text{PPMCST} = \frac{\text{GPM} \times \text{PHEAD} \times 7457 \times \text{PWCST}}{3960 \times \text{PMPEF} \times \text{PSIZE} \times 1000} \quad (\text{mills/kwhr}) \quad (3.3)$$

where PHEAD = assumed frictional pumping head (ft)
 PWCST = power cost (mills/kwhr)
 PMPEF = pump efficiency (%/100)
 PSIZE = plant size (Mw)

The above three equations are contained in the subroutine COND.

In the subroutine SUBPOLU, other costs are added to the condenser system cost. These consist of the inlet and outlet water ducting costs, an additional pumping cost for this ducting, and a differential fuel cost obtained from the subroutine PAFCST, due to power plant operation at a condenser pressure higher than PCBASE.

If the condenser is specified, then, since the inlet water temperature is known, the condenser temperature and outlet water temperature may be determined by simultaneous solution of the following three equations. From the power plant subroutine PAFCST, we get

$$QREJ = f(TC) \quad (3.4)$$

In addition,

$$QREJ = SPFLOW \times (T1 - T2) \times C_p \quad (3.5)$$

where SPFLOW = specified water flow (lbm/hr)
 T1 = outlet water temperature ($^{\circ}$ F)
 T2 = inlet water temperature ($^{\circ}$ F)
 Cp = specific heat of water = 1 (Btu/lbm- $^{\circ}$ F)

and

$$QREJ = UOVALL \times AREAC \times \frac{(T2 - TC) - (T1 - TC)}{\ln \left(\frac{T2 - TC}{T1 - TC} \right)} \quad (3.6)$$

where UOVALL = specified overall heat transfer coefficient (Btu/hr-ft 2 - $^{\circ}$ F)
 AREAC = specified heat transfer area (ft 2)

T1, TC, and QREJ are the only three unknowns, but since the function f of Equation (3.4) is a quadratic curve fit, the simultaneous solution to the three equations is performed by trial and error, in subroutine SUBPOLU.

3.4 Plume Analysis

The final computations performed in subroutine SUBPOLU describe the spread and dissipation of the stream of condenser discharge water, or plume, after it is returned to the flowing river. As was indicated by Edinger and Geyer (Reference 5), even simple limiting models of the spread of warm light water into cold water defy a first-principles analysis at this time. Therefore, the approach taken was to define an arbitrary spreading function which described the increase in plume width with distance downstream of the outfall. This spreading function was prescribed to meet certain physical constraints. These were:

1. the plume width at the outfall was related to the overall width of the river by the ratio of the condenser discharge flow to the undisturbed river flow. That is

$$\frac{PLUMEW}{WIDTH} \text{ (at the outfall)} = \frac{QCON}{QFLRIV} \quad (3.7)$$

where

PLUME	=	width of plume (ft.)
WIDTH	=	total width of river (ft.)
QFLRIV	=	total river flow (ft^3/sec)
QCON	=	condenser discharge flow (ft^3/sec)

2. the spreading rate is of an exponential form.

3. the plume width approaches the total river width smoothly.

A spreading function which satisfies these criteria is

$$\text{PLUMEW} = \text{WIDTH} \times \left[1 - e^{-(A \times XI + C1)} \right] \quad (3.8)$$

where

A = a constant which can be interpreted as an inverse mixing length ($1/\text{miles}$)

XI = distance downstream of the outfall (miles)



$C1$ = a constant evaluated so as to satisfy Equation 3.7
at $XI = 0$.

In order to obtain a reasonable approximation to some plume width data in Reference 5, the mixing length was chosen as $\frac{1}{A} = 2$.

Which yielded the final result

$$\text{PLUMEW} = \text{WIDTH} \times \left[1 - e^{-\left(\frac{XI}{2} + C1 \right)} \right] \quad (3.9)$$

This results in a description which can be interpreted physically according to Figure 3.1, as a two-dimensional unstratified model.



View A-A

Figure 3.1 Schematic of Plume-River Flow

Both streams are subject to heat transfer with the environment and both approach the environmental equilibrium temperature exponentially as derived in Reference 5.

The temperature of the unmixed cold stream, TWREAL, is the easiest to specify since it is by definition unaffected by the plume and simply approaches the equilibrium temperature, TCALC, according to

$$TWREAL = TCALC + (TAVH20 - TCALC) e^{ALPHA1} \quad (3.10)$$

where

TWREAL = unmixed stream temperature ($^{\circ}$ F)

TCALC = equilibrium temperature ($^{\circ}$ F)

TAVH20 = temperature just upstream of plant ($^{\circ}$ F)

ALPHA1 = decay constant

$$= - \frac{XK \times XI}{DENSITY \times DEPTH \times VELREV} \text{ from Reference 5}$$

The temperature of the plume is most easily defined in terms of a mixed river temperature, TXDIST. The hypothetical temperature is the temperature which the river would be at any point if the plume and the unmixed portion were thoroughly mixed. This temperature, which also approaches the environmental equilibrium temperature, can be shown to be

$$TXDIST = TCALC + (TZERO - TCALC) e^{ALPHA1} \quad (3.11)$$

TXDIST = mixed river temperature at any downstream ($^{\circ}$ F)

where TZERO = mixed river temperature at the outfall ($^{\circ}$ F)

Therefore,

$$TZERO = \frac{QCON \times T1 + (QFLRIV - QCON) \times TREAL}{QFLRIV} \quad (3.12)$$

The plume temperature, PLUMT, is then computed on the basis of a simple energy balance from the mixed river temperature (Equation 3.11) and the plume flow rate (assumed proportional to plume width from Equation 3.9). Hence,

$$QFLRIV \times TXDIST = Q_{PLUM} \times PLUMT + (QFLRIV - Q_{PLUM}) TWREAL \quad (3.13)$$

$$\frac{PLUMT - TWREAL}{TXDIST - TWREAL} = \frac{QFLRIV}{Q_{PLUM}} = \frac{WIDTH}{PLUMEW} \quad (3.14)$$

Then from Equation 3.9

$$\frac{PLUMT - TWREAL}{TXDIST - TWREAL} = \frac{\frac{1}{1 - e^{-(XI/2 + C1)}}}{\frac{1}{1 - e^{-(XI/2 + C1)}}} \quad (3.15)$$

where

PLUMT = plume temperature ($^{\circ}$ F)

3.5 Flow Diagram

Figures 3.2 and 3.3 contain the flow diagram for the subroutine SUBPOLU. Some minor calculations and program checks have been omitted for clarity.

3.6 Results

The results using the data of SUBD2 and SUBD4, described in Section 2, are shown in Tables 3.1 and 3.2.

The design values are printed first and consist of the following:

Q REJECT	-	The heat rejected from the plant by the condenser
T CONDENSER	-	The temperature of the condensing steam
CONDENSER		
FLOW	-	The condenser cooling water flow
PUMP POWER	-	The power required to pump the cooling water
EQUILIBRIUM		
TEMP	-	The equilibrium temperature corresponding to the design ambient conditions
RANGE	-	The cooling water temperature rise from inlet to exit.

The design costs are printed next. It should be pointed out here that since the various cooling subroutines use common printing subroutines, PRTDS1, PRTDS2, and PRTOD, there are a few quantities in each print out that are not applicable to the cooling system being described. Zeros (with no decimal point) are usually printed as the value of such quantities and the term "not applicable" will be used when describing the results. An example of such a quantity is the first design cost printed, the CAPITAL COST. The capital cost of the condenser is not printed out but it is included in the condenser system cost, described below.

The OPERATING COST result printed for this subroutine consists only of the extra pumping costs associated with the inlet and outlet water ducting for the condenser. Other pumping costs are included in the condenser system cost.




Figure 3.2 Flow Diagram for Design Portion of SUBPOLU




Figure 3.3 Flow Diagram for Off-Design Portion of SUBPOLU

Table 3.1
ONCE-THROUGH COOLING RESULTS USING SUBD2
(CONDENSER SPECIFIED)

-----STRAIGHT CONDENSER COOLING-----
(WITH UNTREATED FRESH WATER)

THE DESIGN VALUES AND COSTS ARE -

$Q_{REJECT} = 9.181E\ 08 \text{ BTU/HR}$ AT $T_{CONDENSER} = 100$
 CONDENSER FLOW = $1.869E\ 02 \text{ CFS}$ ($4.200E\ 07 \text{ LB/HR}$) PUMP POWER = $1.325E\ 02 \text{ HP}$
 EQUILIBRIUM TEMP = 88 RANGE = 22

CAPITAL COST = 0E 00 DOLLARS
 CONDENSER AND PUMP COST = 0E 00 DOLLARS/KW
 OPERATING COST = .002 MILLS/KW-HR
 MAINTENANCE COST = .000 MILLS/KW-HR
 CONDENSER SYSTEM COST = 0 MILLS/KW-HR
 DIFFERENTIAL FUEL COST = .000 MILLS/KW-HR
 TOTAL SYSTEM COST = .002 MILLS/KW-HR

--RIVER TEMPERATURES--

DISTANCE-MILES	STREAM TEMP DEG.F NO PLANT MIXED	PLUME TEMP.-DEG.F	PLUME WIDTH-MI
0	75.00	75.58	.0101
1.0	75.66	76.21	.1552
2.0	76.29	76.81	.2432
3.0	76.88	77.38	.2965
4.0	77.45	77.92	.3289
5.0	77.98	78.43	.3485
6.0	78.49	78.91	.3604
7.0	78.97	79.37	.3677
8.0	79.42	79.80	.3720
9.0	79.86	80.22	.3747
10.0	80.26	80.61	.3763
20.0	83.35	83.56	.3788

Table 3.1 (Concluded)

VARIABLE AMBIENT CONDITIONS

FOR CAP = 1.00, T WB = 60, AND TC = 92
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

FOR CAP = 1.00, T WB = 70, AND TC = 92
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

FOR CAP = .60, T WB = 60, AND TC = 79
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

FOR CAP = .25, T WB = 60, AND TC = 79
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

FOR CAP = .25, T WB = 70, AND TC = 79
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

FOR CAP = .25, T WB = 70, AND TC = 79

PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

WITH THE VARIOUS AMBIENT TEMPERATURES
THE COSTS ARE -

OPERATING COST = .001 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .000 MILLS/KW-HR

TOTAL SYSTEM COST = .001 MILLS/KW-HR

Table 3.2

ONCE-THROUGH COOLING RESULTS USING SUBD4
("DESIGN" CONDENSER)-----STRAIGHT CONDENSER COOLING-----
(WITH INTREATED FRESH WATER)

THE DESIGN VALUES AND COSTS ARE -

$Q_{REJECT} = 9.454E\ 08 \text{ BTU/HR}$ AT $T_{CONDENSER} = 120$
 $CONDENSER FLOW = 1.059E\ 02 \text{ CFS (2.380E\ 07 LB/HR)}$ PUMP POWER = $7.507E\ 01 \text{ HP}$
 EQUILIBRIUM TEMP = 88 RANGE = 40

CAPITAL COST = .0E 00 DOLLARS
 CONDENSER AND PUMP COST = $5.093E\ 00 \text{ DOLLARS/KW}$
 OPERATING COST = .001 MILLS/KW-HR
 MAINTENANCE COST = .001 MILLS/KW-HR
 CONDENSER SYSTEM COST = .112 MILLS/KW-HR
 DIFFERENTIAL FUEL COST = .014 MILLS/KW-HR

TOTAL SYSTEM COST = .128 MILLS/KW-HR

--RIVER TEMPERATURES--

DISTANCE-MILES	STREAM TEMP DEG.F NO PLANT	PLUME TEMP.-DEG.F MIXED	PLUME WIDTH-MI
0	75.00	75.60	.0057
1.0	75.66	76.23	.1525
2.0	76.29	76.83	.2415
3.0	76.88	77.40	.2955
4.0	77.45	77.93	.3283
5.0	77.98	78.44	.3482
6.0	78.49	78.92	.3602
7.0	78.97	79.38	.3675
8.0	79.42	79.82	.3720
9.0	79.86	80.23	.3746
10.0	80.26	80.62	.3763
20.0	83.35	83.56	.3788

VARIABLE AMBIENT CONDITIONS

FOR CAP = .25, T WB = 60, AND TC = 79
 PC LESS THAN PC MIN = ASSUME PC MIN - CONTINUE

FOR CAP = .25, T WB = 70, AND TC = 79
 PC LESS THAN PC MIN = ASSUME PC MIN - CONTINUE

WITH THE VARIOUS AMBIENT TEMPERATURES
 THE COSTS ARE -

OPERATING COST = .001 MILLS/KW-HR
 DIFFERENTIAL FUEL COST = .004 MILLS/KW-HR

TOTAL SYSTEM COST = .118 MILLS/KW-HR

The MAINTENANCE COST result is a sum of fixed percentages of the specific capital costs, the operating cost, and the condenser system cost. The three percentages are 0.1%, 10% and 1% respectively.

The CONDENSER SYSTEM COST consists of a capital cost (converted to a cost per output basis) and an operating cost, both described in Section 3.2. The condenser system cost is set equal to zero if the condenser is specified. This is true in all the cooling system subroutines. The reason for this is that if an existing condenser is going to be used, its cost should not be part of the optimization process, and also the costs should already be known. When this cost is given (for the "design" condenser case) it represents a total condenser system cost and is not the cost over and above what a specified condenser might cost.

The DIFFERENTIAL FUEL COST is the added cost, due to increased fuel consumption, of operating the plant at a condenser pressure higher than the specified base pressure (input).

The TOTAL SYSTEM COST is the sum of the capital, operating, maintenance, condenser system, and differential fuel costs. This is the cost with which the optimization is performed; the set of variables resulting in the lowest total system cost is considered to be the best.

The river temperatures and plume width were described in Section 3.2 and the printout is self explanatory.

The initial printout for the variable ambient conditions occurs during calculation of the costs for each set of ambient conditions, and are non-fatal error indications. The two messages that occur are that the condenser pressure, PC, is less than the specified (in the input) minimum, PC MIN, or that the discharge temperature, T DIS, exceeds the maximum allowable, T DIS MAX.* The reason for the first type of message is that the trial calculations for the off design (variable ambient conditions) condenser pressure start at the specified minimum condenser pressure for

*This type of message does not occur for the once-through cooling system, but is discussed here for continuity.

each capacity. If the cooling system is able to handle the heat rejected at this first trial point, it means that the actual operating point should be at a lower condenser pressure. However, this point has been specified as the minimum possible pressure, so it is assumed that the plant operates at this pressure and the operating cost is calculated. A large number of such messages may therefore mean that the "design" ambient conditions are too severe compared to the actual variable conditions, or that the minimum allowable condenser pressures have been set too high.

The second type of message, concerning the discharge temperature from an external cooling system, may occur only when the system is used in a topping operation. The message is self explanatory, and may indicate that the "design" ambient conditions are not severe enough relative to the variable conditions. When the situation indicated by the message occurs ($T_{DIS} > T_{DIS\ MAX}$) the program assumes the actual discharge temperature and calculates the operating cost.

The average operating cost and average differential fuel cost for all the variable ambient conditions are calculated and printed out along with a new total system cost. The new modified total system cost is a sum of the original capital, maintenance, and condenser system costs, and the new averaged operating and differential fuel costs.

Section 4
COOLING POND

4.1 General Description

The equations and logic describing the design of a cooling pond are contained in the subroutine SUBPOND. This subroutine "calls" PAFCST for power plant information and COND for condenser specifications. It is possible to have the condenser specified, in which case the cooling pond is sized to match the condenser. If the condenser is not specified, the subroutine "designs" a matched pond and condenser. In both cases, options are available to have the pond used for a topping operation and/or part time use. Pond sizing, in all cases, closely follows the method described in Reference 4.

The subroutine is divided into two sections, a design and an off-design section, similar to the once-through cooling system subroutine.

4.2 Assumptions

Variables and equations for which numerical assumptions have been made in the subroutine are listed below, so that the cards may be changed if different numerical values are desired.

<u>Variable (sequence or line #)</u>	<u>Comment and/or Recommended Values</u>
PMPEF (449)	0.8 - 0.85
WCOFA (452) }	Should be of the form used in Reference 5.
WCOFB (453) }	
DT2 (490)	Need not correspond to (not used for) specified condenser
PHEAD (521)	
COSMAI (526)	Form of equation and percentages both assumed.

4.3 Basic Equations

The equation for determining the size of the cooling pond necessary for given inlet and outlet water temperatures and ambient temperatures is taken from Reference 4.

$$\text{AREAP} = \frac{24 \times \text{ALPHA} \times \text{FLOW}}{\text{XK} \times 43560} \quad (\text{acres}) \quad (4.1)$$

where FLOW = water flow (lbm/hr)
 XK = exchange coefficient ($\text{Btu}/\text{day}\cdot\text{ft}^2\cdot{}^\circ\text{F}$)

ALPHA is defined by the equation

$$\text{ALPHA} = -\text{LOG} \frac{(T_2 - \text{TCALC})}{(T_1 - \text{TCALC})} \quad (4.2)$$

where TCALC = equilibrium temperature (${}^\circ\text{F}$)
 T1 = inlet water temperature (${}^\circ\text{F}$)
 T2 = outlet water temperature (${}^\circ\text{F}$)

The capital cost of the pond is simply

$$\text{CAPCOS} = \text{AREAP} \times \text{PRPAGR} \quad (4.3)$$

where PRPAGR = land and construction cost (\$/acre)

4.4 Flow Diagram

The flow diagram for the subroutine SUBPOND is shown in Figures 4.1 and 4.2.

4.5 Results

The results using the data of all four data sets are shown in Tables 4.1 through 4.4 and are described as follows:

Q REJECT and	
T CONDENSER	- described in Section 3.4
PUMP POWER	- total pumping power required exclusive of condenser
H ₂ O EVAP	- water evaporation rate
COND FLOW	- condenser water flow (lbm/hr)
T IN	- temperature at inlet to pond (exit of condenser) (°F)
RANGE	- ΔT from inlet to exit of pond (°F)
EQUILIBRIUM TEMP	- described in Section 3.4 (°F)
POND AREA	- the designed surface area of the pond
Q REJ POND	- the amount of heat that is transferred from the pond to the atmosphere. (different from total heat rejected only when topping operation)
CAPITAL COST	- the capital cost of the cooling pond, exclusive of the condenser

The remaining data and costs are the same as those described in Section 3.4.




Figure 4.1. Flow Diagram for Design Portion of SUBPOND




Figure 4.2. Flow Diagram for Off-Design Portion of SUBPOND

Table 4.1

COOLING POND RESULTS USING SUBD1
(SPECIFIED CONDENSER, TOPPING)

----- COOLING POND -----

THE DESIGN VALUES AND COSTS ARE -

Q REJECT = 9.181E 08 BTU/HR AT T CONDENSER = 100
FAN POWER = 0E 00 HP PUMP POWER = 8.047E 02 HP
H₂O EVAP = 2.125E 00 CFS (5.199E 05 LB/HR)
H₂O BLOWDOWN = 0E 00 CFS (0E 00 LB/HR)
AIR FLOW RATE = 0E 00 LB/HR
COND FLOW = 4.200E 07 T IN = 97 RANGE = 12
EQUILIBRIUM TEMP = 79 POND AREA = 141 ACRES

Q REJ POND = 5.061E 08 BTU/HR

CAPITAL COST = 1.411E 05 DOLLARS
CONDENSER AND PUMP COST = 0E 00 DOLLARS/KW
OPERATING COST = .007 MILLS/KW-HR
MAINTENANCE COST = .001 MILLS/KW-HR
CONDENSER SYSTEM COST = 0 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .000 MILLS/KW-HR

TOTAL SYSTEM COST = .021 MILLS/KW-HR

VARIABLE AMBIENT CONDITIONS

THE POND IS LARGER THAN NECESSARY FOR 1.00 CAPACITY AND AMBIENT NO. 1
COMPUTING COSTS ASSUMING MOST EFFICIENT CONDITION (PC=PCM_{IN})

THE POND IS LARGER THAN NECESSARY FOR 1.00 CAPACITY AND AMBIENT NO. 2
COMPUTING COSTS ASSUMING MOST EFFICIENT CONDITION (PC=PCM_{IN})

THE POND IS LARGER THAN NECESSARY FOR .60 CAPACITY AND AMBIENT NO. 1
COMPUTING COSTS ASSUMING MOST EFFICIENT CONDITION (PC=PCM_{IN})

THE POND IS LARGER THAN NECESSARY FOR .25 CAPACITY AND AMBIENT NO. 1
COMPUTING COSTS ASSUMING MOST EFFICIENT CONDITION (PC=PCM_{IN})

THE POND IS LARGER THAN NECESSARY FOR .25 CAPACITY AND AMBIENT NO. 2
COMPUTING COSTS ASSUMING MOST EFFICIENT CONDITION (PC=PCM_{IN})

THE POND IS LARGER THAN NECESSARY FOR .25 CAPACITY AND AMBIENT NO. 3
COMPUTING COSTS ASSUMING MOST EFFICIENT CONDITION (PC=PCM_{IN})

WITH THE VARIOUS AMBIENT TEMPERATURES
THE COSTS ARE -

OPERATING COST = .007 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .000 MILLS/KW-HR
TOTAL SYSTEM COST = .020 MILLS/KW-HR

Table 4.2
COOLING POND RESULTS USING SUBD2
(SPECIFIED CONDENSER, CLOSED SYSTEM)

----- COOLING POND -----

THE DESIGN VALUES AND COSTS ARE -

Q REJECT = 9.351E 08 BTU/HR AT T CONDENSER = 115
FAN POWER = 0E 00 HP PUMP POWER = 8.107E 02 HP
H₂O EVAP = 3.438E 00 CFS (8.414E 05 LR/HR)
H₂O BLOWDOWN = 0E 00 CFS (0E 00 LR/HR)
AIR FLOW RATE = 0E 00 LR/HR
COND FLOW = 4.200E 07 T IN = 112 RANGE = 22
EQUILIBRIUM TEMP = 79 PCND AREA = 142 ACRES

CAPITAL COST = 1.417E 05 DOLLARS
CONDENSER AND PUMP COST = 0E 00 DOLLARS/KW
OPERATING COST = .007 MILLS/KW-HR
MAINTENANCE COST = .001 MILLS/KW-HR
CONDENSER SYSTEM COST = 0 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .007 MILLS/KW-HR

TOTAL SYSTEM COST = .027 MILLS/KW-HR

VARIABLE AMBIENT CONDITIONS

WITH THE VARIOUS AMBIENT TEMPERATURES
THE COSTS ARE -

OPERATING COST = .007 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .005 MILLS/KW-HR

TOTAL SYSTEM COST = .025 MILLS/KW-HR

Table 4.3

COOLING POND RESULTS USING SUBD3
("DESIGN" CONDENSER, TOPPING)

----- COOLING PCND -----

THE DESIGN VALUES AND COSTS ARE -

Q REJECT = 9.454E 08 BTU/HR AT T CONDENSER = 120
FAN POWER = 0E 00 HP PUMP POWER = 4.623E 02 HP
H₂O EVAP = 2.564E 00 CFS (6.274E 05 LB/HR)
H₂O BLOWDOWN = 0E 00 CFS (0E 00 LB/HR)
AIR FLOW RATE = 0E 00 LB/HR
COND FLOW = 2.380E 07 T IN = 115 RANGE = 30
EQUILIBRIUM TEMP = 79 PCND AREA = 129 ACRES

Q REJ PCND = 7.074E 08 BTU/HR

CAPITAL COST = 6.432E 05 DOLLARS
CONDENSER AND PUMP COST = 5.093E 00 DOLLARS/KW
OPERATING COST = .004 MILLS/KW-HR
MAINTENANCE COST = .005 MILLS/KW-HR
CONDENSER SYSTEM COST = .091 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .010 MILLS/KW-HR

TOTAL SYSTEM COST = .164 MILLS/KW-HR

VARIABLE AMBIENT CONDITIONS

THE POND IS LARGER THAN NECESSARY FOR .25 CAPACITY AND AMBIENT NO. 1
COMPUTING COSTS ASSUMING MOST EFFICIENT CONDITION (PC=PCM_{IN})

THE POND IS LARGER THAN NECESSARY FOR .25 CAPACITY AND AMBIENT NO. 2
COMPUTING COSTS ASSUMING MOST EFFICIENT CONDITION (PC=PCM_{IN})

WITH THE VARIOUS AMBIENT TEMPERATURES
THE COSTS ARE -

OPERATING COST = .004 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .004 MILLS/KW-HR

TOTAL SYSTEM COST = .158 MILLS/KW-HR

Table 4.4

COOLING POND RESULTS USING SUBD4
("DESIGN" CONDENSER, CLOSED SYSTEM)

----- COOLING POND -----

THE DESIGN VALUES AND COSTS ARE -

Q REJECT = 9.454E 08 BTU/HR AT T CONDENSFR = 120
FAN POWER = 0E 00 HP PUMP POWER = 6.803E 02 HP
H₂O EVAP = 3.514E 00 CFS (8.599E 05 LB/HR)
H₂O BLOWDOWN = 0E 00 CFS, (0E 00 LB/HR)
AIR FLOW RATE = 0E 00 LB/HR
COND FLOW = 3.509E 07 T IN = 115 RANGE = 27
EQUILIBRIUM TEMP = 79 POND AREA = 150 ACRES

CAPITAL COST = 7.487E 05 DOLLARS
CONDENSER AND PUMP COST = 6.277E 00 DOLLARS/KW
OPERATING COST = .006 MILLS/KW-HR
MAINTENANCE COST = .006 MILLS/KW-HR
CONDENSER SYSTEM COST = .114 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .010 MILLS/KW-HR

TOTAL SYSTEM COST = .199 MILLS/KW-HR

VARIABLE AMBIENT CONDITIONS

WITH THE VARIOUS AMBIENT TEMPERATURES
THE COSTS ARE -

OPERATING COST = .006 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .008 MILLS/KW-HR

TOTAL SYSTEM COST = .196 MILLS/KW-HR

Section 5

MECHANICAL DRAFT WET COOLING TOWER

5.1 General Description

The calculations and logic for the design of a mechanical draft cooling system are contained in the subroutine SUBMDW. This subroutine "calls" PAFCST for power plant information and COND for condenser specifications. The condenser may be specified or "designed," the cooling system may be open or closed, and part time or full time use of the cooling system may be specified.

The design method that is used is basically a trial and error procedure in which temperatures are varied over permissible ranges, and the total system cost is calculated for each set of conditions. The set of parameters that represents the lowest total system cost is then chosen.

The subroutine is divided into two sections, a design and an off-design section similar to the once through-cooling system subroutine.

5.2 Assumptions

Variables and equations for which numerical assumptions have been made in the subroutine are listed below, so that the cards may be changed if different numerical values are desired.

<u>Variable (sequence or line #)</u>	<u>Comments and/or Recommended Values</u>
FANEF (668)	0.5 - 0.8
PMPEF (669)	0.8 - 0.85
DT2 (703)	Need not correspond to (for not used) specified condenser
DECKHT (735) PHT(736) } WLOAD (738) CONCR (805) CAPCOS (813)	Constants must correspond to form of equation - Reference 7 2500. cf Reference 1

5.3 Basic Equations

The equations for the size of the cooling tower are based on a calculation of a tower "characteristic," CHAR. Calculation of this characteristic is done with the use of the Tchebycheff (cf Ref. 6) numerical integral approximation, such that

$$\text{CHAR} = \frac{\text{RA}}{4} \times [\text{RDH1} + \text{RDH2} + \text{RHD3} + \text{RHD4}] \quad (5.1)$$

where RA = range = $(T_1 - T_2)$ ($^{\circ}\text{F}$), and the RDH's are defined as follows;

RDH1 - inverse of the difference between saturation enthalpy and actual enthalpy, evaluated at $T_2 + 0.1 \times (T_1 - T_2)$ (lbm/Btu)

RDH2 - inverse of the difference between saturation enthalpy and actual enthalpy, evaluated at $T_2 + 0.4 \times (T_1 - T_2)$ (lbm/Btu)

RDH3 - inverse of the difference between saturation enthalpy and actual enthalpy, evaluated at $T_1 - 0.4 \times (T_1 - T_2)$ (lbm/Btu)

RDH4 - inverse of the difference between saturation enthalpy and actual enthalpy, evaluated at $T_1 - 0.1 \times (T_1 - T_2)$ (lbm/Btu)

where T1 = inlet water temperature ($^{\circ}\text{F}$)

T2 = outlet water temperature ($^{\circ}\text{F}$)

The packing height in the tower required to give this characteristic is calculated by (Ref. 7)

$$PHT = \frac{DECKHT \times (CHAR - 0.7)}{0.103 \times (WART)^{-0.54}} \quad (5.2)$$

where WART = water to air flow ratio

DECKHT = deck spacing (ft)

The capital cost of the tower is calculated by

$$CAPCOS = 3. \times GPMT \times XK(IK) \times CWB \quad (5.3)$$

where GPMT = total water flow rate (gal/min)

XK(IK) = cooling factor obtained from a curve fit of data
of Reference 8, reproduced in Figure 5.1

CWB = wet bulb factor-obtained from Reference 8,
reproduced in Figure 5.2

The coefficient, 3, of Equation (5.3) is an average of data from References 8 and 9.




Figure 5.1. Cooling Factor as a Function of Range and Approach
(Ref. 8)




Figure 5.2. Wet Bulb Factor (Ref. 8)

5.4 Flow Diagram

The flow diagram for the design portion of the subroutine SUBMDW is shown in Figure 5.3. A flow diagram for the off-design portion of the program has not been provided since it would be essentially the same as the off design flow diagram for the cooling pond, Figure 4.2.

5.5 Results

The results using the data of all four data sets are shown in Tables 5.1 through 5.4. The description of the results is the same as contained in Sections 3.4 and 4.4 with the exceptions and additions noted below.

FAN POWER	-	the total fan power required for the tower
H ₂ O BLOWDOWN	-	the required water addition to maintain the specified concentration (cf Ref. 4, pg. 65)
AIR FLOW RATE	-	the total air flow rate through the tower
PRESSURE DROP	-	the air pressure drop across the tower packing (inches of water)
APPROACH	-	the difference between the water outlet temperature from the tower and the wet bulb temperature




Figure 5.3. Flow Diagram for Design Portion of SUBMDW

Table 5.1

MECHANICAL DRAFT TOWER RESULTS USING SUBD1
(SPECIFIED CONDENSER, TOPPING)

----- MECHANICAL DRAFT WET TOWER -----

THE DESIGN VALUES AND COSTS ARE -

Q REJECT = 9.181E 08 BTU/HR AT T CONDENSER = 100
 FAN POWER = 4.770E 02 HP PUMP POWER = 1.068E 03 HP
 H₂O EVAP = 1.955E 00 CFS (4.784E 05 LB/HR)
 H₂O RLCWDDWN = 5.176E-01 CFS (1.267E 05 LB/HR)
 AIR FLOW RATE = 2.679E 07 LR/HR
 PRESSURE DROP = .38 COND FLOW = 4.200E 07
 RANGE = 12 APPROXACH = 10

Q REJ TOWER = 5.061E 08 BTU/HR

CAPITAL COST = 5.612E 05 DOLLARS
 CONDENSER AND PUMP COST = 0E 00 DOLLARS/KW
 OPERATING COST = .014 MILLS/KW-HR
 MAINTENANCE COST = .004 MILLS/KW-HR
 CONDENSER SYSTEM COST = 0 MILLS/KW-HR
 DIFFERENTIAL FUEL COST = .000 MILLS/KW-HR

TOTAL SYSTEM COST = .065 MILLS/KW-HR

VARIABLE AMBIENT CONDITIONS

FOR CAP = 1.00, T WB = 60, AND PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE	TC = 92
FOR CAP = 1.00, T WB = 70, AND PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE	TC = 92
FOR CAP = .60, T WB = 60, AND PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE	TC = 79
FOR CAP = .25, T WB = 60, AND PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE	TC = 79
FOR CAP = .25, T WB = 70, AND PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE	TC = 79
FOR CAP = .25, T WB = 70, AND PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE	TC = 79

WITH THE VARIOUS AMBIENT TEMPERATURES
THE COSTS ARE -

OPERATING COST = .014 MILLS/KW-HR
 DIFFERENTIAL FUEL COST = .000 MILLS/KW-HR
 TOTAL SYSTEM COST = .064 MILLS/KW-HR

Table 5.2

MECHANICAL DRAFT TOWER RESULTS USING SUBD2
(SPECIFIED CONDENSER, CLOSED SYSTEM)

----- MECHANICAL DRAFT WET TOWER -----

DESIGN VALUES AND COSTS ARE -

Q REJECT = 9.431E 08 BTU/HR AT T CONDENSER = 119
FAN POWER = 2.749E 02 HP PUMP POWER = 9.667E 02 HP
H₂O EVAP = 3.527E 00 CFS (8.631E 05 LB/HR)
H₂O RLCWDDWN = 9.646E-01 CFS (2.360E 05 LB/HR)
AIR FLOW RATE = 2.208E 07 LB/HR
PRESSURE DROP = .27 COND FLOW = 4.200E 07
RANGE = 22 APPROACH = 19

CAPITAL COST = 2.631E 05 DOLLARS
CONDENSER AND PUMP COST = 0E 00 DOLLARS/KW
OPERATING COST = .011 MILLS/KW-HR
MAINTENANCE COST = .002 MILLS/KW-HR
CONDENSER SYSTEM COST = 0 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .010 MILLS/KW-HR

TOTAL SYSTEM COST = .045 MILLS/KW-HR

VARIABLE AMBIENT CONDITIONS

FOR CAP = 1.00, T WB = 60, AND PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE	TC = 92
FOR CAP = .25, T WB = 70, AND PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE	TC = 79
FOR CAP = .25, T WB = 70, AND PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE	TC = 79

WITH THE VARIOUS AMBIENT TEMPERATURES
THE COSTS ARE -

OPERATING COST = .011 MILLS/KW-HR
DIFFERENTIAL FUEL COST = -0.000 MILLS/KW-HR

TOTAL SYSTEM COST = .035 MILLS/KW-HR

Table 5.3

MECHANICAL DRAFT TOWER RESULTS USING SUBD3
("DESIGN" CONDENSER, TOPPING)

----- MECHANICAL DRAFT WET TOWER -----

THE DESIGN VALUES AND COSTS ARE -

Q REJECT = 9.454E 08 BTU/HR AT T CONDENSER = 120
FAN POWER = 7.221E 02 HP PUMP POWER = 7.148E 02 HP
H₂O EVAP = 2.650E 00 CFS (6.485E 05 LB/HR)
H₂O BLOWDOWN = 7.235E-01 CFS (1.770E 05 LB/HR)
AIR FLOW RATE = 2.154E 07 LB/HR
PRESSURE DROP = .72 COND FLOW = 2.380E 07
RANGE = 30 APPROACH = 10

Q REJ TOWER = 7.074E 08 BTU/HR

CAPITAL COST = 5.543E 05 DOLLARS
CONDENSER AND PUMP COST = 5.093E 00 DOLLARS/KW
OPERATING COST = .013 MILLS/KW-HR
MAINTENANCE COST = .005 MILLS/KW-HR
CONDENSER SYSTEM COST = .091 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .010 MILLS/KW-HR

TOTAL SYSTEM COST = .166 MILLS/KW-HR

VARIABLE AMBIENT CONDITIONS

FOR CAP = .25, T WB = 60, AND TC = 79
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

FOR CAP = .25, T WB = 70, AND TC = 79
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

WITH THE VARIOUS AMBIENT TEMPERATURES
THE COSTS ARE -

OPERATING COST = .013 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .004 MILLS/KW-HR

TOTAL SYSTEM COST = .159 MILLS/KW-HR

Table 5.4

MECHANICAL DRAFT TOWER RESULTS USING SUBD4
("DESIGN" CONDENSER, CLOSED SYSTEM)

----- MECHANICAL DRAFT WET TOWER -----

THE DESIGN VALUES AND COSTS ARE -

Q REJECT = 9.454E 08 BTU/HR AT T CONDENSER = 120
FAN POWER = 3.953E 02 HP PUMP POWER = 9.780E 02 HP
H₂O EVAP = 3.536E 00 CFS (8.652E 05 LB/HR)
H₂O BLOWDOWN = 9.669E-01 CFS (2.366E 05 LB/HR)
AIR FLOW RATE = 2.459E 07 LB/HR
PRESSURE DROP = .35 COND FLOW = 3.985E 07
RANGE = 24 APPROXIMATE = 16

CAPITAL COST = 5.523E 05 DOLLARS
CONDENSER AND PUMP COST = 6.700E 00 DOLLARS/KW
OPERATING COST = .013 MILLS/KW-HR
MAINTENANCE COST = .005 MILLS/KW-HR
CONDENSER SYSTEM COST = .122 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .010 MILLS/KW-HR

TOTAL SYSTEM COST = .197 MILLS/KW-HR

VARIABLE AMBIENT CONDITIONS

WITH THE VARIOUS AMBIENT TEMPERATURES
THE COSTS ARE -

OPERATING COST = .012 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .000 MILLS/KW-HR

TOTAL SYSTEM COST = .186 MILLS/KW-HR

Section 6

NATURAL DRAFT WET COOLING TOWER

6.1 General Description

The logic and calculations for the design of a natural draft cooling tower system are contained in the subroutine SUBNDW. This subroutine obtains power plant information by "calling" PAFCST, and condenser specifications by "calling" COND. The condenser may be specified or designed, the cooling system may be open or closed, and part time or full time use of the coding system may be specified.

The design method is the same as for the mechanical draft system, in that temperatures are varied over permissible ranges and the total system cost is calculated for each set of conditions. The set of conditions resulting in the lowest total cost is then chosen as the design conditions.

The subroutine is divided into a design and an off-design section similar to other cooling system subroutines.

6.2 Assumptions

Variables and equations for which numerical assumptions have been made in the subroutine are listed below, so that the cards may be changed if different numerical values are desired.

<u>Variable (sequence or line#)</u>	<u>Comment and/or Recommended Values</u>
PMPEF (966)	0.8 - 0.85
HDRMAX (968)	1. - 1.75
DT2 (1002)	Need not correspond to (not used for) specified condenser
WLOAD (1014)	Initial value needed
VIN (1046)	2. - 10.
PPK (1055)	Form of equation and constant - Reference 10
PSP (1057)	Form of equation and constants - Reference 16
TPIX (1059)	
CAPCOS (1069)	
CONCR (1070)	cf Reference 1

6.3 Basic Equations

The equations for the size of the cooling tower are based on a calculation of a tower "characteristic," CHAR, and a tower height, THT, necessary to develop the required pressure differential.

The tower characteristic, CHAR, is calculated in the same manner as for the mechanical draft system, Equation (5.1).

The packing height required in the tower to give this characteristic is calculated by (Ref. 10)

$$PHT = \frac{CHAR}{UNC} \quad (6.1)$$

where UNC is the characteristic per foot of packing and is calculated by

$$UNC = 0.1 \times \left(\frac{1}{WART} \right)^{0.73} \quad (6.2)$$

where WART = ratio of water to air flow rates.

The total tower height required is the sum of the sum of the chimney height required for the pressure differential, the packing height, the height of the spray nozzles above the packing, and the air inlet opening height. This is expressed as

$$THT = \frac{TPDP \times VHDI}{DIN - DOUT} \quad (6.3)$$

where TPDP = total pressure drop (air inlet velocity heads)

VHDI = inlet velocity head (lbf/ft^2)

DIN, DOUT = inlet and exit air density (lbm/ft^3)

The capital cost of the tower is calculated from data on British towers (Ref. 11) modified slightly to reflect United States prices. The resulting equation for the capital is

$$\text{CAPCOS} = 3.4 \times 10^5 \times (\text{HTDIA})^{1.7} \quad (6.4)$$

where HTDIA = height of tower times diameter of tower.

6.4 Flow Diagram

The flow diagram for the design portion of the subroutine SUBNDW is the same as that for the mechanical draft system subroutine SUBMDW, Figure 5.3. The off-design flow diagram is essentially the same as the off-design diagram for the cooling pond system, Figure 4.2. Therefore, neither flow diagram is included in this section.

6.5 Results

The results using the data of all four data sets are shown in Tables 6.1 through 6.4. The description of the results is the same as for the preceding cooling systems with the exceptions noted below.

PRESSURE DROP - total air pressure drop through the tower (lbf/ft^2)

TOWER HEIGHT - total height of the tower including opening and packing (ft)

TOWER
DIAMETER - base diameter of the tower (ft)

TOWER
CHARACTERISTIC - the total tower characteristic (Ref. 6)

In the variable ambient conditions error messages,

CHAR - tower characteristic required

THT - tower height required

A fatal error message may occur within the off-design calculations for closed systems when the cooling system cannot reject the required heat at any condenser temperature between the specified limits. A particular case would be if the condenser temperature and ambient temperatures are the same as the "design" conditions, but the power plant is "operating" slightly off design and is less efficient (the heat rate for 100% capacity is slightly higher than for "design").

Table 6.1
NATURAL DRAFT TOWER RESULTS USING SUBD1
(SPECIFIED CONDENSER, TOPPING)

----- NATURAL DRAFT WET TOWER -----

THE DESIGN VALUES AND COSTS ARE -

Q REJECT = 9.181E 08 BTU/HR AT T CONDENSER = 100
FAN POWER = 0E 00 HP PUMP POWER = 1.454E 03 HP
H₂O EVAP = 3.546E 00 CFS (8.677E 05 LB/HR)
H₂O FLOWDOWN = 9.390E-01 CFS (2.298E 05 LB/HR)
AIR FLOW RATE = 4.859E 07 LB/HR
PRESSURE DROP = 1.2 COND FLOW = 4.200E 07
RANGE = 12 APPROACH = 10
TOWER HEIGHT = 470 TOWER DIAMETER = 315
WATER LOADING = 538 LBM/HR-FT²
TOWER CHARACTERISTIC = 1.38 PACKING HEIGHT=12.41

Q REJ TOWER = 5.061E 08 BTU/HR

CAPITAL COST = 2.573E 06 DOLLARS
CONDENSER AND PUMP COST = 0E 00 DOLLARS/KW
OPERATING COST = .013 MILLS/KW-HR
MAINTENANCE COST = .014 MILLS/KW-HR
CONDENSER SYSTEM COST = 0 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .000 MILLS/KW-HR

TOTAL SYSTEM COST = .242 MILLS/KW-HR

VARIABLE AMBIENT CONDITIONS

FOR CAP = 1.00, T WB = 60, AND TC = 92
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

FOR CAP = 1.00, T WB = 70, AND TC = 92
T DIS EXCEEDS T DIS MAX - CONTINUING

FOR CAP = .80, T WB = 70, AND TC = 85
T DIS EXCEEDS T DIS MAX - CONTINUING

FOR CAP = .80, T WB = 70, AND TC = 90
T DIS EXCEEDS T DIS MAX - CONTINUING

Table 6.1 (Concluded)

FOR CAP = .60, T WR = 60, AND TC = 79
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

FOR CAP = .60, T WB = 70, AND TC = 80
T DIS EXCEEDS T DIS MAX - CONTINUING

FOR CAP = .60, T WB = 70, AND TC = 85
T DIS EXCEEDS T DIS MAX - CONTINUING

FOR CAP = .25, T WB = 60, AND TC = 79
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

FOR CAP = .25, T WB = 70, AND TC = 79
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

FOR CAP = .25, T WR = 70, AND TC = 79
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

WITH THE VARIOUS AMBIENT TEMPERATURES
THE COSTS ARE -

OPERATING COST = .013 MILLS/KW-HR
DIFFERENTIAL FUEL COST = -0.000 MILLS/KW-HR

TOTAL SYSTEM COST = .241 MILLS/KW-HR

Table 6.2
NATURAL DRAFT TOWER RESULTS USING SUBD2
(SPECIFIED CONDENSER, CLOSED SYSTEM)

----- NATURAL DRAFT WET TOWER -----

THE DESIGN VALUES AND COSTS ARE -

Q REJECT = 9.454E 08 BTU/HR AT T CONDENSER = 120
FAN POWER = .0E 00 HP PUMP POWER = 1.200E 03 HP
H₂O EVAP = 3.537E 00 CFS (8.654E 05 LB/HR)
H₂O RLCWDOWN = 9.669E-01 CFS (2.366E 05 LB/HR)
AIR FLOW RATE = 2.114E 07 LB/HR
PRESSURE DROP = 1.5 COND FLOW = 4.200E 07
RANGE = 23 APPROACH = 20
TOWER HEIGHT = 235 TOWER DIAMETER = 207
WATER LOADING = 1250 LBM/HR-FT²
TOWER CHARACTERISTIC = .96 PACKING HEIGHT=15.80

CAPITAL COST = 2.129E 06 DOLLARS
CONDENSER AND PUMP COST = .0E 00 DOLLARS/KW
OPERATING COST = .011 MILLS/KW-HR
MAINTENANCE COST = .012 MILLS/KW-HR
CONDENSER SYSTEM COST = 0 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .010 MILLS/KW-HR

TOTAL SYSTEM COST = .211 MILLS/KW-HR

VARIABLE AMBIENT CONDITIONS

FOR CAP = .25, T WB = 70, AND TC = 79
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

FOR CAP = .25, T WB = 70, AND TC = 79
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

WITH THE VARIOUS AMBIENT TEMPERATURES
THE COSTS ARE -

OPERATING COST = .011 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .008 MILLS/KW-HR

TOTAL SYSTEM COST = .207 MILLS/KW-HR

Table 6.3
NATURAL DRAFT TOWER RESULTS USING SUBD3
("DESIGN" CONDENSER, TOPPING)

----- NATURAL DRAFT WET TOWER -----

THE DESIGN VALUES AND COSTS ARE -

Q REJECT = 9.454E 08 BTU/HR AT T CONDENSER = 120
FAN POWER = .0E 00 HP PUMP POWER = 8.841E 02 HP
H₂O EVAP = 3.542E 00 CFS (8.667E 05 LB/HR)
H₂O BLOWDOWN = 9.669E-01 CFS (2.366E 05 LB/HR)
AIR FLOW RATE = 2.879E 07 LB/HR
PRESSURE DROP = 1.2 COND FLOW = 2.380E 07
RANGE = 30 APPROACH = 10
TOWER HEIGHT = 271 TOWER DIAMETER = 182
WATER LOADING = 911 LBM/HR-FT²
TOWER CHARACTERISTIC = 1.78 PACKING HEIGHT=15.51

Q REJ TOWER = 7.074E 08 BTU/HR

CAPITAL COST = 2.135E 06 DOLLARS
CONDENSER AND PUMP COST = 5.093E 00 DOLLARS/KW
OPERATING COST = .008 MILLS/KW-HR
MAINTENANCE COST = .012 MILLS/KW-HR
CONDENSER SYSTEM COST = .091 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .010 MILLS/KW-HR

TOTAL SYSTEM COST = .300 MILLS/KW-HR

VARIABLE AMBIENT CONDITIONS

FOR CAP = 1.00, T WB = 70, AND TC = 110
T DIS EXCEEDS T DIS MAX - CONTINUING

FOR CAP = .80, T WB = 70, AND TC = 100
T DIS EXCEEDS T DIS MAX - CONTINUING

FOR CAP = .80, T WB = 70, AND TC = 106
T DIS EXCEEDS T DIS MAX - CONTINUING

FOR CAP = .60, T WB = 70, AND TC = 92
T DIS EXCEEDS T DIS MAX - CONTINUING

FOR CAP = .60, T WB = 70, AND TC = 97
T DIS EXCEEDS T DIS MAX - CONTINUING

FOR CAP = .25, T WB = 60, AND TC = 79
PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE

Table 6.3 (Concluded)

FOR CAP = .25, T WB = 70, AND TC = 79
T DIS EXCEEDS T DIS MAX - CONTINUING

FOR CAP = .25, T WB = 70, AND TC = 83
T DIS EXCEEDS T DIS MAX - CONTINUING

WITH THE VARIOUS AMBIENT TEMPERATURES
THE COSTS ARE -

OPERATING COST = .008 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .004 MILLS/KW-HR

TOTAL SYSTEM COST = .293 MILLS/KW-HR

Table 6.4
NATURAL DRAFT TOWER RESULTS USING SUBD4
("DESIGN" CONDENSER, CLOSED SYSTEM)

----- NATURAL DRAFT WET TOWER -----

THE DESIGN VALUES AND COSTS ARE -

Q REJECT = 9.454E 08 BTU/HR AT T CONDENSER = 120
FAN POWER = .0E 00 HP PUMP POWER = 1.140E 03 HP
H₂O EVAP = 3.546E 00 CFS (8.678E 05 LB/HR)
H₂O BLCWDWN = 9.669E-01 CFS (2.366E 05 LB/HR)
AIR FLOW RATE = 3.042E 07 LB/HR
PRESSURE DROP = 1.4 COND FLOW = 2.980E 07
RANGE = 32 APPROACH = 8
TOWER HEIGHT = 315 TOWER DIAMETER = 215
WATER LOADING = 820 LBM/HR-FT²
TOWER CHARACTERISTIC = 2.17 PACKING HEIGHT=21.33

CAPITAL COST = 2.253E 06 DOLLARS
CONDENSER AND PUMP COST = 5.759E 00 DOLLARS/KW
OPERATING COST = .011 MILLS/KW-HR
MAINTENANCE COST = .013 MILLS/KW-HR
CONDENSER SYSTEM COST = .104 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .010 MILLS/KW-HR

TOTAL SYSTEM COST = .326 MILLS/KW-HR

VARIABLE AMBIENT CONDITIONS

WITH THE VARIOUS AMBIENT TEMPERATURES
THE COSTS ARE -

OPERATING COST = .010 MILLS/KW-HR
DIFFERENTIAL FUEL COST = .008 MILLS/KW-HR
TOTAL SYSTEM COST = .323 MILLS/KW-HR

REFERENCES

1. Carey, J. H., Ganley, J. T., and Maulbetsch, J. S., "A Survey and Economic Analysis of Alternate Methods for Cooling Condenser Discharge Water in Thermal Power Plants. Task I Report: Survey of Large-Scale Heat Rejection Equipment," Dynatech Report No. 849, July 21, 1969.
2. Fuller, W. D. and Maulbetsch, J. S., "A Survey and Economic Analysis of Alternate Methods for Cooling Condenser Discharge Water in Thermal Power Plants. Task II Report: Survey of Power Plant Operating Characteristics and Design Criteria," Dynatech Report No. 886, May 26, 1970.
3. Severns, W. H. and Fellows, J. R., Air Conditioning and Refrigeration, Wiley & Sons, Inc., N.Y., 1958.
4. FWPCA, Industrial Waste Guide on Thermal Pollution, September 1968.
5. Edinger, J. E. and Geyer, J. C., "Heat Exchange in the Environment," Edison Electric Institute Publication No. 65-902, 1965.
6. Cooling Tower Institute, Cooling Tower Performance Curves, Millican Press, Ft. Worth, Texas, 1967.
7. Fraas, A. P., and Ozisik, M. N., Heat Exchanger Design, John Wiley & Sons, Inc., N.Y., 1965.
8. Lockhart, F. J., Whitesell, J. M., and Catland, A. C., Jr., "Cooling Towers for the Power Industry," American Power Conference, 1955.
9. Converse, A. O., "Thermal Energy Disposal Methods for the Proposed Nuclear Power Plant at Vernon," Submitted to the State of Vermont, November 1967.
10. Lowe, H. J., and D. G. Christie, "Heat Transfer and Pressure Drop Data on Cooling Tower Packings, and Model Studies of the Resistance of Natural Draught Towers to Airflow," Int. Heat Transfer Conf., 1961, Vol. V-A.
11. Kelly, A. G., and Lawless, N. R., "Economic Sizing of Cooling Towers," Combustion Engineering, August 1962.
12. Bauman, H. C., Fundamentals of Cost Engineering in the Chemical Industry, Reinhold Publishing Co., N.Y., 1964.
13. Perry, J. H., Chemical Engineering Handbook, 3rd Edition, McGraw-Hill Book Co., N.Y., 1960.

14. Goodman, W., "The Evaporative Condenser-Theory and Characteristics," Heating, Piping and Air Conditioning, V.10, No. 3, March 1938.
15. Kays, W.M. and London, A.L., Compact Heat Exchangers, McGraw-Hill Book Co., N.Y., 1958.
16. Risch, R.F., "The Design of a Natural Draught Cooling Tower", London, International Heat Transfer Conference, Denver, 1962.

APPENDIX

Glossary of Variable Names

ACFM	Air Flow Rate (ft^3/min)
ACOND	Condenser Area (ft^2)
AFLR	Air Flow Rate (lbm/hr)
AFLR1	AFLR corresponding to TOTCS1
ALDG	Air Loading (mass velocity) (lbm/ $\text{ft}^2\text{-hr}$)
ALDGE	An Equivalent Air Mass Flow Rate (lbm/hr- ft^2)
ALPACT	The Actual ALPHA
ALPHA	Exponent for Exponential Temperature Decay
ALPHA1	Exponent for Exponential Temperature Decay
AMBDFC (I)	Differential Fuel Cost for Operation at CAP (I) (mills/kwhr)
AMBOPC (I)	Operating Cost at CAP(I) (mills/kwhr)
AMBRH (J)	Off Design Relative Humidities (%/100)
AMRAD	Off Design Absorbed Radiation (Btu/ $\text{ft}^2\text{-day}$)
AMWIND	Off Design Wind Velocity (mph)
ANFCR	Annual Fixed Charge Rate (%/100)
APPR	Approach - temperature difference between outlet water and wet bulb ($^{\circ}\text{F}$)
APPR1	APPR corresponding to TOTCS1
APSAT	Water Vapor Partial Pressure (psi)
AREAC	Condenser Area for Specified Condenser (ft^2)
AREAP	Cooling Pond Area (acre)
AREAP1	AREAP corresponding to TOTCS1
AVDFCS	Average Off Design Differential Fuel Cost (mills/kwhr)
AVOPCS	Average Off Design Operating Cost (mills/kwhr)
AVTCST	Average Off Design Total Cost (mills/kwhr)
BETA	The derivative of the saturation pressure with respect to temperature, evaluated at the equilibrium temperature (psi/ $^{\circ}\text{F}$)
BOWRAT	Bowen Ratio-Ratio of Conduction to Evaporation Heat Transfer
BSA	Base Area of Tower (ft^2)
CAIR	Heat Capacity Rate (Btu/hr $^{\circ}\text{F}$)
CAP(I)	Plant Capacity (%/100)
CAPCOS	Capital Cost (\$)

CAPCS1	CAPCOS corresponding to TOTCS1
CAPFAC	Average Power Plant Capacity Factor (%/100)
CCPKW	Plant Capital Cost (\$/kw)
CHAR	Tower Characteristic
CHAR1	CHAR corresponding to TOTCS1
CHEAD	Friction Pressure Drop in the Condenser (water side)
CKWHRs	Total Power Output per year during which the cooling system is used (kwhr/yr)
CO1	Total Enthalpy Rise of Air Through Tower (Btu/lbm)
COLPCT(I)	Percent of Operating Time, TOTLD(I), that cooling system is used (%/100)
CONCR	Ratio of Circulation Water to Raw-Water Minerals Concentration
CONCST	Condenser Cost (\$)
COSMA1	COSMA1 corresponding to TOTCS1
COSMAI	Maintenance Cost (mills/kwhr)
COSPK1	COSPKW corresponding to TOTCS1
COSPKW	Specific Capital Cost (\$/kw)
CWB	Wet Bulb Factor
DECKHT	Deck Spacing (ft)
DELF1	DELFC corresponding to TOTCS1
DELFC	Differential Fuel Cost (mills/kwhr)
DELHR	Change in Heat Rate (Btu/kwhr)
DELHS	Change in Saturation Enthalpy (Btu/lbm)
DELP	Packing Pressure Drop (inches of water)
DEPTH	Condenser Depth (ft)
DFCOD	Off Design Differential Fuel Cost (mills/kwhr)
DH	Net Heat Transfer Rate from water to air - will be zero when the equilibrium temperature is substituted into its defining equation (Btu/ft ² -day)
DHM, DHP	The Heat Transfer Rate from water to air when the water is 1° F below and above the equilibrium temperature (assumed or actual) (Btu/ft ² -day)
DHPRIM	The Derivative of DH with Respect to Temperature (Btu/day ft ² -° F)
DIA	Tower Diameter (at base) (ft)

DIA1	DIA corresponding to TOTCS1
DIN	Inlet Air Density (lbm/ft ³)
DOUT	Exit Air Density (lbm/ft ³)
DP1	DELP corresponding to TOTCS1
DT1	Condenser Temperature Difference = TC - T2 (° F)
DT2	Condenser Temperature Difference (approach) = TC - T1 (° F)
DTLGM	Log Mean Temperature Difference (° F)
DTRIV	Change in total "mixed" river temperature between upstream and just downstream of condenser (° F)
ECOF	Evaporation Coefficient (Btu/ft ² day mm Hg)
FANEF	Fan Efficiency (%/100)
FCFS	Condenser Flow (ft ³ /sec)
FLOW	Condenser flow (lbm/hr)
FLOW1	FLOW corresponding to TOTCS1
FUCST	Fuel Cost (¢/million Btu)
FUDGE	An Intermediate Cost Factor
GPM	Condenser Flow Rate (gal/min)
GPM1	GPM corresponding to TOTCS1
GPMT	Total Flow Rate (gal/min)
H(T)	Saturation Enthalpy at Temperature T (Btu/lbm)
H1	Saturation Enthalpy corresponding to the Wet Bulb Temperature (Btu/lbm)
H2	Saturation Enthalpy corresponding to TAXT (except SUBEVAP) -- SUBEVAP only - Exit Air Enthalpy (Btu/lbm)
HDR	Ratio of Tower Height to Diameter
HDR1	HOVD Corresponding to TOTCS1
HDRMAX	Specified Maximum HOVD
HEATR	Net heat rate (Btu/kwhr)
HOUT	Saturation Enthalpy corresponding to Outlet Air Temperature (Btu/lbm)
HPF1	HPFAN corresponding to TOTCS1
HPFAN	Fan Power (hp)
HPP1	HPPMP corresponding to TOTCS1
HPPMP	Pumping Power (hp)

HR(I,J)	Net Heat Rate Corresponding to HRP(I,J) (Btu/kwhr)
HRBASE	Base net heat rate corresponding to PCBASE (Btu/kwhr)
HRCOF2(I), HRCOF1(I) HRCOF ϕ (I)	Quadratic Heat Rate Coefficients such that HEAT RATE = HRCOF2(I) \times (TC) ² + HRCOF1(I) \times (TC) + HRCOF ϕ
HRP (I,J)	Condenser Pressure for each Heat Rate Point. THR(I,J) at each CAP(J) (in. Hg.)
HTDIA	Tower Height times Tower Diameter (ft ²)
HWB1	H1 corresponding to TOTCS1
IREAD	Program Read Control Number
ISUB	Program Subroutine Control Number
IRITE	Program Print Out Control Number
IWL	Number of Iterations on WLOAD
NCAPS	Number of Plant Capacities (exclusive of "design" capacity)
NCAPS1	Subscript meaning "Design" Value
NH2O	Type of Cooling Water Used (-1= seawater, 0= untreated fresh water, +1= treated fresh water)
NHRPTS (I)	Number of Heat Rates Input at each CAP(I)
NSPCON	Whether or not Condenser is Specified (0= no, 1= yes)
NSUBS(I)	Subroutine Control Flags
NSYSOP	Type of Cooling System Operation (0= closed cycle, 2= topping)
NTAMB	Number of Ambient Temperatures
NTCOD	An Index of the Condenser Temperature has been Incremented
OPCOD	Off Design Operating Cost (mills/kwhr)
OPCOS	Operating Cost (mills/kwhr)
OPCS1	OPCOS corresponding to TOTCS1
OPHT	Tower Inlet Air Opening Height (ft)
OPHT1	OPHT corresponding to TOTCS1
P(T)	Saturation Pressure a T (psia)
PBAR	Atmospheric Pressure (= 14.696 psi)

PCBASE	Base Condenser Pressure (in. Hg.)
PCMAX(I)	Maximum Condenser Pressure for CAP (I) (in. Hg.)
PCMINT(I)	Minimum Condenser Pressure for CAP (I) (in. Hg.)
PCTAMB (I,J)	Percent of Cooling System Use Time, (COLPCT(J) x TOTLD(J)), at each CAP(I) that the system operates at the specified ambient temperatures (TAMDB(J), TAMWB(J)) (%/100)
PHEAD	Frictional Pumping Head (ft.)
PHT	Packing Height (ft)
PKWA	Packing Pressure drop with zero water flow (velocity heads/ft)
PKWB	Slope of packing pressure drop versus water loading curve (hr ft velocity heads/lbm)
PLAC	Cost of Condenser Cooling Water Ducting (\$/kw)
PLAC1	PLAC corresponding to TOTCS1
PLANA	Tower Plan Area (ft ²)
PLANAA1	PLANAA corresponding to TOTCS1
PLUMEW	Plume Width (ft)
PLUMT	Plume Temperature (° F)
PMPCST	Pumping Cost (mills/kwhr)
PMPEF	Pump Efficiency (%/100)
PPK	Pressure Drop Across Packing (inlet velocity heads)
PPK1	PPK corresponding to TOTCS1
PRPAGR	Cost of Land and Pond Construction (\$/acre)
PSIZE	Rated Plant Output (MW)
PSP	Air Pressure Drop Across Water Spray (inlet velocity heads)
PV	Partial Pressure of Water Vapor (psia)
PWCST	Power cost (for auxiliaries) (mills/kwhr)
QCON	Condenser Water Flow (ft ³ /sec)
QLAT	Latent (evaporation) Heat Transfer (Btu/hr)
QREJ	Heat Rejected by Power Plant (Btu/hr)

QREJT	Heat Rejected by Cooling System (Btu/hr)
QRJ1	QREJ corresponding to TOTCS1
QRJT1	QREJT corresponding to TOTCS1
RA	Condenser or cooling System Range ($^{\circ}$ F)
RA1	RA corresponding to TOTCS1
RAD	Absorbed Radiation (Btu/ ft^2 day)
RDH1	Inverse of the difference between saturation enthalpy and actual enthalpy, evaluated at $T_2 + 0.1 (T_1 - T_2)$ (lbm/Btu)
RDH2	Inverse of the difference between saturation enthalpy and actual enthalpy, evaluated at $T_2 + 0.4 (T_1 - T_2)$ (lbm/Btu)
RDH3	Inverse of the difference between saturation enthalpy and actual enthalpy, evaluated at $T_1 - 0.4 (T_1 - T_2)$ (lbm/Btu)
RDH4	Inverse of the difference between saturation enthalpy and actual enthalpy, evaluated at $T_1 - 0.1 (T_1 - T_2)$ (lbm/Btu)
SPFLOW	Condenser Water Flow Rate for Specified Condenser (lbm/hr)
SPHT	Distance of Spray nozzles above packing (ft.)
SYS1	SYSCST corresponding to TOTCS1
SYSCST	Condenser System Cost (mills/kwhr)
T1	Temperature of Water out of Condenser (into cooling system) ($^{\circ}$ F)
T11	T1 corresponding to TOTCS1
T2	Temperature of Water into Condenser (from cooling system) ($^{\circ}$ F)
T21	T2 corresponding to TOTCS1
TA	Air Temperature ($^{\circ}$ F)
TAMDB(J)	Off Design Dry Bulb Temperature ($^{\circ}$ F)
TAMRV(J)	Off Design River or Estuary Temperature ($^{\circ}$ F)
TAMWB(J)	Off Design Wet Bulb Temperature ($^{\circ}$ F)

TAVH2O	Available Water Temperature ($^{\circ}$ F)
TAXT	Average of Inlet and Outlet Water Temperatures ($^{\circ}$ F)
TAXT1	TAXT corresponding to TOTCS1
TC	Condenser Temperature ($^{\circ}$ F)
TC1	TC corresponding to TOTCS1
TCALC	Equilibrium Temperature ($^{\circ}$ F)
TCALC1	TCALC corresponding to TOTCS1
TCBASE	Base Condenser Temperature ($^{\circ}$ F)
TCMAX(I)	Maximum Condenser Pressure at CAP(I) ($^{\circ}$ F)
TCMIN(I)	Minimum Condenser Temperature at CAP(I) ($^{\circ}$ F)
TDB	Design Dry Bulb Temperature ($^{\circ}$ F)
TDFMIL	Total Differential Fuel Cost for Each Capacity (mills)
TDISMX	Maximum Water Discharge Temperature ($^{\circ}$ F)
TG	An Initial Guess at the Equilibrium Temperature ($^{\circ}$ F)
THR(I, J)	Condenser Saturation Temperature corresponding to HRP(I, J) ($^{\circ}$ F)
THT	Total Tower height (ft)
THT1	THT corresponding to TOTCS1
TKWHR\$	Total Power Output per Year (kwhr/yr)
TNEW	A New Guess at the Equilibrium Temperature ($^{\circ}$ F)
TOPMIL	Total Operating Cost for each Capacity (mills)
TOTCOS	Total System Cost (mills/kwhr)
TOTCS1	The Minimum Total System Cost calculated up to that point in the Program (mills/kwhr)
TOTHP	Total Auxiliary Power Required for Cooling System (hp)
TOTLTD(I)	Hours per year Operating at each corresponding Capacity CAP(I) (hrs/yr)
TOUTS	Saturation Temperature of Outlet Air ($^{\circ}$ F)
TPDP	Total Pressure Drop (inlet velocity heads)
TPDP1	TPDP corresponding to TOTCS1
TPIX	Inlet and exit turning losses plus friction loss (inlet velocity heads)

TURBHR(I,J)	Net Heat Rate corresponding to HRP(I,J) for each CAP(I) (Btu/kwhr)
TWAV	Average Water Temperature ($^{\circ}$ F)
TWB	Design Wet Bulb Temperature ($^{\circ}$ F)
TWREAL	River Temperature XI Downstream from Plant if no heat were added at plant ($^{\circ}$ F)
TXDIST	"Mixed" river temperature XI Downstream from Plant ($^{\circ}$ F)
TZERO	"Mixed" river temperature just downstream of condenser ($^{\circ}$ F)
UA	Heat Transfer Coefficient times Area (Btu/hr $^{\circ}$ F)
UA1	UA corresponding to TOTCS1
UALL	Overall Heat Transfer Coefficient (Btu/hr-ft $^{2-}$ $^{\circ}$ F)
UNC	Characteristic per foot of packing
UOVALL	Overall Heat Transfer Coefficient for Specified Condenser (Btu/hr-ft $^{2-}$ $^{\circ}$ F)
USEFAC	Average Cooling Use Factor (%/100)
VELRIV	River Velocity (ft/day)
VHDI	Inlet Velocity Head (lbf/ft $^{2-}$)
VIN	Air Inlet Velocity (ft/sec)
WACT	Specific Humidity
WART	Ratio of Water Flow to Air Flow
WART1	WART corresponding to TOTCS1
WBDWN	Water Flow Needed for Blowdown (lbm/hr)
WBDWN1	WBDWN corresponding to TOTCS1
WCOFA, WCOFB	Coefficients such that ECOF = WCOFA + WCOFB x WIND
WEVAP	Water Evaporation Rate (lbm/hr)
WEVAP1	WEVAP corresponding to TOTCS1
WIDTH	Width of River or Estuary (ft)
WIND	Wind Speed (mph)
WLMTD	Log Mean Temperature of Cooling Pond ($^{\circ}$ F)
WLOAD	Water Loading (lbm/hr/ft $^{2-}$)
WLOAD1	WLOAD corresponding to TOTCS1
WNEED	Total Makeup Water Required (lbm/hr)

WNEED1	WNEED corresponding to TOTCS1
XI	Distance Downstream from Plant (mi)
XK	Energy Exchange Coefficient (Btu/day ft-° F)
XK (IK)	Cooling Factor defined in Figure 5.1
XK1	XK(IK) corresponding to TOTCS1

PROGRAM LISTINGS

	<u>Page</u>
Main Program	A-11
Subroutine SUBPOLU	A-15
Subroutine SUBPOND	A-19
Subroutine SUBMDW	A-23
Subroutine SUBNDW	A-28
Subroutine PAFCST	A-33
Subroutine COND	A-34
Subroutine PRTDS1	A-35
Subroutine PRTDS2	A-36
Subroutine PRTOD	A-37
Function H(I)	A-38
Function P(T)	A-39
Data SUBD1	A-40
Data SUBD2	A-41
Data SUBD3	A-42
Data SUBD4	A-43

```

PROGRAM MAINFWP
COMMON PSIZE,CCPKW,ANFCR,FUCST,NCAPS,CAP(6),TCTLD(5),
X COLPCT(5),TCMIN(6),PCMIN(6),TCMAX(6),PCMAX(6),
X HRCDF2(6),HRCDF1(6),HRCDF0(6),TDB,TWB,RH,TAVH2C,TCBASE,
X NTAMB,AMBDFC(5),AMBDFC(5),AMBCPC(5),TAMDB(5),TAMWB(5),AMBRH(5),
X TAMRV(5),PCTAMB(5,5),NSYSCP,TDISMX,NSPCON,UCVALL,AREAC,SPFLOW,
X NH2C,WIDTH,PRPAGR,CAPFAC,USEFAC,TKWHRS,IRITE,IREAD,
* AMWIND(5),AMRAD(5),WIND,RAD
DIMENSION NHRPTS(6),HRP(6,6),THR(6,6),TURBHR(6,6),
X HR(6,6),NSUBS(5)
IRITF=31
IREAD=30
200 FORMAT(5F10.0,I10) 00001
201 FORMAT(6F10.2) 00002
202 FORMAT(6F10.0) 00003
203 FORMAT(7I10) 00004
204 FORMAT(6F10.0,2I10) 00005
205 FORMAT(F10.0,2I10,4F10.0) 00006
READ(IREAD,200)PSIZE,CCPKW,ANFCR,FUCST,PRPAGR,NCAPS
NCAPS1=NCAPS+1 00007
READ(IREAD,201)(CAP(I),I=1,5) 00008
READ(IREAD,202)(TCTLD(I),I=1,5) 00009
READ(IREAD,201)(COLPCT(I),I=1,5) 00010
READ(IREAD,203)(NHRPTS(I),I=1,6) 00011
READ(IREAD,201)(PCMIN(I),I=1,6) 00012
READ(IREAD,201)(PCMAX(I),I=1,6) 00013
NNCAP=NCAPS 00014
IF(NHRPTS(NCAPS1) .GT. 0) NNCAP=NNCAP+1 00015
DC 210 I=1,NNCAP 00016
READ(IREAD,201)(HRP(I,J),J=1,6) 00017
210 READ(IREAD,202)(TURBHR(I,J),J=1,6) 00018
C 00019
C 00020
      READ(IREAD,204)TDB,TWB,TAVH2C,PCRASE,WIND,RAD,NH2C,NTAMB 00021
C 00022
      READ(IREAD,202)(TAMDB(I),I=1,NTAMB) 00023
      READ(IREAD,202)(TAMWB(I),I=1,NTAMB) 00024
      READ(IREAD,202)(TAMRV(I),I=1,NTAMB) 00025
      READ(IREAD,202)(AMWIND(I),I=1,NTAMB) 00026
      READ(IREAD,202)(AMRAD(I),I=1,NTAMB) 00027
C 00028
      DC 216 I=1,NCAPS 00029
216 READ(IREAD,201)(PCTAMB(I,J),J=1,NTAMB) 00030
C 00031
      READ(IREAD,205)WIDTH,NSYSCP,NSPCON,TDISMX,UCVALL,AREAC,SPFLOW 00032
      READ(IREAD,203)(NSUBS(I),I=1,5) 00033
C 00034
C 00035
      LOAD DURATION HOURS CHECK - TO STATEMENT 246 00036
      TCTDUR=0.0 00037
      DC 243 I=1,NCAPS 00038
      TOTAM=0.0 00039
C 00040
      PERCENT AMBIENT TIME CHECK - TO STATEMENT 242 00041
      DC 238 J=1,NTAMB 00042
238 TOTAM=TOTAM+PCTAMB(I,J) 00043
      IF( TOTAM .EQ. 1.0) GO TO 242 00044
      WRITE(IRITE,239)I 00045
C 00046
      CALC OF RELATIVE HUMIDITY - RH AND AMBRH 00047
239 FORMAT(* TOT PCT AMBIENT HRS NOT = 1.0 FOR CAP NC#,I2) 00048
      GO TO 500 00049
242 CONTINUE 00050
      TCTDUR=TCTDUR+TCTLD(I) 00051
243 CONTINUE 00052

```

```

IF (TCTDUR .EQ. 8760.) GO TO 246 00063
WRITE(IRITE,244) 00064
244 FORMAT(* TCT LD HRS NOT = 8760 *)
GO TO 500 00065
246 CONTINUE 00066
C 00067
PBAR=14.696 00068
PV=P(TWB)-(((PBAR-P(TWR))*(TDB-TWB))/(2800.-1.3*TWB)) 00069
RH=PV/P(TDB) 00070
DO 20 I=1,NTAMB 00071
20 AMBRH(I)=(P(TAMWB(I))-((PBAR-P(TAMWB(I)))*
X (TAMDR(I)-TAMWB(I)))/(2831.-1.43*TAMWB(I)))/P(TAMDR(I)) 00072
C 00073
C 00074
C QUADRATIC CURVE FIT OF HEAT RATES (TO STATEMENT 00075
NNCAP=NCAPS 00076
CAP(NCAPS1)=1. 00077
IF(NHRPTS(NCAPS1) .GT. 0) NNCAP=NNCAP+1 00078
DO 9 I=1,NNCAP 00079
IF(NHRPTS(I) .GT. 2) GO TO 7 00080
WRITE(IRITE,6)I 00081
6 FORMAT(* LESS THAN 3 HEAT RATES FOR CAP NO #,I2) 00082
GO TO 500 00083
7 X1=0.$X2=0.$X3=0.$X4=0.$XY=0.$X2Y=0.$Y1=0. 00084
M2=NHRPTS(I) 00085
DO 8 J=1,M2 00086
C 00087
HR(I,J)=TURBHR(I,J) 00088
C 00089
C CALC OF TSAT FROM PRESS. (IN. HG) 00090
BLOG=ALOG(HRP(I,J)) 00091
THR(I,J)=79.035793+30.462409*BLOG+1.9740416* 00092
X (BLOG)**2+0.13124035*(BLOG)**3 00093
X1=THR(I,J)+X1 00094
X2=(THR(I,J)**2)+X2 00095
Y1=HR(I,J)+Y1 00096
X3=(THR(I,J)**3)+X3 00097
X4=(THR(I,J)**4)+X4 00098
XY=XY+THR(I,J)*HR(I,J) 00099
8 X2Y=X2Y+(THR(I,J)**2)*HR(I,J) 00100
R=NHRPTS(I) 00101
DEN=X4*(R*X2-X1**2)-X3*(B*X3-X2*X1)+X2*(X3*X1-X2**2) 00102
ANUM=X2Y*(B*X2-X1**2)-X3*(B*XY-X1*Y1)+X2*(XY*X1-Y2*Y1) 00103
BNUM=X4*(B*XY-X1*Y1)-X2Y*(B*X3-X2*X1)+X2*(X3*Y1-Y2*X2) 00104
CNUM=X4*(X2*Y1-XY*X1)-X3*(X3*Y1-XY*X2)+X2Y*(X3*X1-X2**2) 00105
HRCOF2(I)=ANUM/DEN 00106
HRCOF1(I)=BNUM/DEN 00107
HRCOF0(I)=CNUM/DEN 00108
9 CONTINUE 00109
C 00110
C MAKING DESIGN HR = 100PCT CAPACITY HR (IF NOT SPECIFIED) 00111
IF(NHRPTS(NCAPS1) .GT. 0) GO TO 45 00112
DO 40 I=1,NCAPS 00113
IF(CAP(I) .EQ. 1.) GO TO 42 00114
40 CONTINUE 00115
WRITE(IRITE,41) 00116
41 FORMAT(* NO 100 PCT CAPACITY OR DESIGN HR*) 00117
GO TO 500 00118
42 HRCOF2(NCAPS1)=HRCOF2(I) 00119
HRCOF1(NCAPS1)=HRCOF1(I) 00120
HRCOF0(NCAPS1)=HRCOF0(I) 00121
PCMIN(NCAPS1)=PCMIN(I) 00122
PCMAM(NCAPS1)=PCMAM(I) 00123
PCMAM(NCAPS1)=PCMAM(I) 00124

```

```

45 CONTINUE          00125
C
      DO 11 I=1,NCAPS
      BLOG=ALOG(PCMINT(I))          00126
      TCMIN(I)=79.035793+30.462409*BLOG+1.9740416* 00127
      X (BLOG)**2+0.13124035*(BLOG)**3          00128
      BLOG=ALOG(PCMAX(I))          00129
11   TCMAX(I)=79.035793+30.462409*BLOG+1.9740416* 00130
      X (BLOG)**2+0.13124035*(BLOG)**3          00131
      BLOG=ALOG(PCBASE)          00132
      TCRASE=79.035793+30.462409*BLOG+1.9740416* 00133
      X (BLOG)**2+0.13124035*(BLOG)**3          00134
      00135
      00136
      00137
C
C       CALC OF AVG CAPACITY FACTOR AND COOLING USE FACTOR 00138
C
      TKWHRs=0.0          00139
      CKWHRs=0.0          00140
      DO 47 I=1,NCAPS          00141
      TKWHRs=TKWHRs+(CAP(I)*TCTLD(I))          00142
47   CKWHRs=CKWHRs+(CAP(I)*TCTLD(I)*CCLPCT(I))          00143
      CAPFAC=TKWHRs/8760.          00144
      USEFAC=CKWHRs/TKWHRs          00145
C
C
      DO 60 ISUB=1,5          00146
      IF(INSURS(ISUB).EQ.0)GO TO 60          00147
      GO TO (50,70,72,74,76)ISUB          00148
50   WRITE(IRITE,350)PSIZE,CCKW,ANFCR,FUCST,PRPAGR          00149
350  FORMAT(1H1,10X,-----PRINTOUT OF INPUT DATA-----+ 00150
      X /1H04X,#PSIZE    CAP $    ANFCR    FUEL $    PRPAGR#, /, 00151
      X5X,F5.0,F9.0,F8.2,F9.0,F10.0//)          00152
      00153
      00154
C
      WRITE(IRITE,360)(CAP(I),I=1,NCAPS)          00155
      WRITE(IRITE,361)(TCTLD(I),I=1,NCAPS)          00156
      WRITE(IRITE,362)(CCLPCT(I),I=1,NCAPS)          00157
      WRITE(IRITE,363)(PCMINT(I),I=1,NCAPS)          00158
      WRITE(IRITE,364)(TCMIN(I),I=1,NCAPS)          00159
      WRITE(IRITE,365)(PCMAX(I),I=1,NCAPS)          00160
      WRITE(IRITE,366)(TCMAX(I),I=1,NCAPS)          00161
      00162
360   FORMAT(5X,#CAPACITIES AND CORRESPONDING DATA#/,,7X, * (EXTRA V 00163
      XVALUES ARE DESIGN DATA)#/,,3X,#CAPACITY - #,5F7.2)          00164
      00165
361   FORMAT(* HRS/YEAR - #,5F7.0)          00166
362   FORMAT(* PCT COOLING - #,5F7.2)          00167
363   FORMAT(* MIN P COND - #,6F7.2)          00168
364   FORMAT(* MIN T COND - #,6F7.2)          00169
365   FORMAT(* MAX P COND - #,6F7.2)          00170
366   FORMAT(* MAX T COND - #,6F7.2)          00171
C
      WRITE(IRITE,370)CAPFAC,USEFAC          00172
370   FORMAT(5X,#CAPACITY FACTOR =#,F5.2,/5X,#COOLING USE FACTOR =# 00173
      X ,F5.2,//)          00174
C
      WRITE(IRITE,403)          00175
403   FORMAT(5X,#COND PRESS AND CORRESPONDING DATA AT EACH CAPACITY 00176
      X#)
      DC 407 I=1,NCAPS          00177
      WRITE(IRITE,404) CAP(I)          00178
404   FORMAT(/2X,#CAPACITY **#,F4.2)          00179
      00180
      00181
C
      M2=NHRPTS(I)          00182
      WRITE(IRITE,405) (HRP(I,J),J=1,M2)          00183
405   FORMAT(3X,#PRESSURE - #,6F8.?)          00184
      00185
C
      00186

```

```

407 WRITE(IRITE,406) (TURBHR(I,J),J=1,M2) 00187
406 FORMAT(3X,*T HEAT RATE = *.6F8.0) 00188
C
      M2=NHRPTS(NCAPS1) 00189
      IF(M2 .EQ. 0) GO TO 412 00190
      WRITE(IRITE,409)(HRP(NCAPS1,J),J=1,M2) 00191
409  FORMAT(//5X,*DESIGN VALUES (CAPACITY = PLANT SITE)*,,3X, *PR 00192
      XESSURE = *.6F8.2,/ 00193
      WRITE(IRITE,410)(TURBHR(NCAPS1,J),J=1,M2) 00194
410  FORMAT(3X,*T HEAT RATE = *.6F8.0,/ 00195
C
      412  WRITE(IRITE,413)TDB,TWB,WIND,RAD,TAVH2O,NH2O 00196
413  FORMAT(*0    DRY BULB T    WET BULB T    WIND SPEED    RADIATION*/ 00197
      X   F12.0,F14.0,F13.1,F14.0/*0    AVAIL H2O T    TYPE AVAILABLE H2O*/ 00198
      X   F13.0,I16) 00199
C
      WRITE(IRITE,429)PCBASE,TCBASE 00200
429  FORMAT(3X,*BASE P COND    BASE T COND*,/,7X,F6.2,BX,F6.1//) 00201
      WRITE(IRITE,414)(TAMDB(I),I=1,NTAMB) 00202
414  FORMAT(1H14X*VARIABLE AMBIENT TEMPERATURES*,//3X,*DRY BULB - * 00203
      X   5F7.0./) 00204
      WRITE(IRITE,415)(TAMWB(I),I=1,NTAMB) 00205
415  FORMAT(3X,*WET BULB - *,5F7.0./) 00206
      WRITE(IRITE,416)(TAMRV(I),I=1,NTAMB) 00207
416  FORMAT(3X,*RIVER - *,5F7.0./) 00208
      WRITE(IRITE,1417)(AMWIND(I),I=1,NTAMB) 00209
1417 FORMAT(*    WIND*8X,5F7.1) 00210
      WRITE(IRITE,1418)(AMRAD(I),I=1,NTAMB) 00211
1418 FORMAT(*    RADIATION *5F7.0) 00212
C
      WRITE(IRITE,417) 00213
417  FORMAT(//5X,*PERCENT OF COOLING SYSTEM TIME AT ABOVE*,/, 00214
      X 8X,*AMBIENT CONDITIONS*,/) 00215
      DO 418 I=1,NCAPS 00216
418  WRITE(IRITE,419)CAP(I),(PCTAMB(I,J),J=1,NTAMB) 00217
419  FORMAT(/3X,*CAP = *,F4.2,* -*,5F7.2) 00218
C
      WRITE(IRITE,420)WIDTH,NSYSCP,NSPCON 00219
420  FORMAT(//5X,    #RIVER WIDTH    TYPE COOLING(2=TOPPING)    COND S 00220
      XSPECIFIED(1=YES)*,, 5X,F8.0,14X,I2,24X,I2,/ 00221
C
      IF(NSYSCP=2)424,421,424 00222
421  WRITE(IRITE,422)TDISMX 00223
422  FORMAT( 3X,*MAX DISCHARGE TEMP = *,F4.0/) 00224
C
      424  IF(NSPCON=1)428,425,428 00225
425  WRITE(IRITE,426)UCVALL,AREAC,SPFLCW 00226
426  FORMAT(5X,*CONDENSER SPECIFICATIONS*,/, 3X,*OVERALL U = *,F6. 00227
      X0.,/, 3X,*TUBE AREA = *,E9.4,/, 3X,*H2O FLOW = *,F9.4,//) 00228
C
      428  CONTINUE 00229
      GO TO 60 00230
C
      70 CALL SUBPCLU 00231
      GO TO 60 00232
      72 CALL SUBPOND 00233
      GO TO 60 00234
      74 CALL SUBMDW 00235
      GO TO 60 00236
      76 CALL SUBNDW 00237
      60 CONTINUE 00238
      500 END 00239

```

```

SUBROUTINE SUBPGLU          00249
COMMON PSIZE,CCPKW,ANFCR,FUCST,NCAPS,CAP(6),TCTLN(5),COLPCT(5),TC
XMIN(6),PCMINT(6),TCMAX(6)=PCMAX(6),HRCOF2(6),HRCOF1(6),HRCOF0(6),
XTDR,TWB,RH,TAVH20,TCBASE,NTAMB,AMBDFC(5),AMBOPC(5),TAMDB(5),TAMW
XB(5),AMBRH(5),TAMRV(5),PCTAMB(5.5),NSYSCP,TDISMX,NSPCON,UCVALL,A
XREAC,SPFLOW,NH20,WIDTH,PRPAGR,CAPFAC,USEFAC,TKWHRs,IRITE,IREAD
WIND=8.8                    00255
QFLRIV=7000.                00256
DEPTH=10.                   00257
RAD=5580.                   00258
PMPEF=0.8                   00259
TCTCS1=1.E3                 00260
C
C      CALCULATION OF THE EQUILIBRIUM TEMPERATURE, TCALC, TO        00261
C      STATEMENT 1 -- EQUATION TAKEN FROM EDINGER                  00262
C
C      WCCFA=0.           00263
C      WCCFB=15            00264
C      ECCOF=WCCFA+WCCFB*WIND                                     00265
C      TA=TDB           00266
C      TG=TDB           00267
C
7     DH=PAD-1801.*((TG/460.+1.)*#4-ECCOF*51.7*(P(TG)-RH*P(TA)) - .26*ECCO 00269
XF=(TG-TA)                   00270
DHP=RAD-1801.*((TG+1.)/460.+1.)*#4-ECCOF*51.7*(P(TG+1.)-RH*P(TA)) - 00271
X.26*ECCOF*(TG+1.-TA)
DHM=RAD-1801.*((TG-1.)/460.+1.)*#4-ECCOF*51.7*(P(TG-1.)-RH*P(TA)) - 00273
X.26*ECCOF*(TG-1.-TA)
DHPRIM=(DHP-DHM)/2.         00274
IF(ABS(DH)=1.)1,2,2         00275
2     TNEW=TG-DH/DHPRIM      00277
TG=TNEW                      00278
GO TO 7                       00279
1     TCALC=TG               00280
BETA=51.7*(P(TCALC+1.)-P(TCALC-1.))/2. 00281
XK=15.7+(0.26*BETA)*ECCOF 00282
TC=TCMIN(NCAPS+1)            00283
100   CONTINUE                00284
IF(NSPCON=1)30,40,30          00285
40    CALL PAFCST(NCAPS+1,TC,PWCST,DELFC,QREJ) 00286
DT2=(QREJ/SPFLOW)/(EXP(UCVALL*AREAC/SPFLOW)-1.) 00287
DT1=DT2+QREJ/SPFLOW          00288
T1=TC-DT2                     00289
T2=TC-DT1                     00290
IF(NSYSCP=2)41,46,41          00291
41    IF(DT1-(TC-TAVH20))45,45,151 00292
30    DT2=5.                  00293
IF(NSYSCP=2)31,46,31          00294
31    T2=TAVH20                00295
GO TO 51                      00296
46    WRITE(IRITE,50)           00297
50    FORMAT(/#CANNOT HAVE TOPPING WITH STRAIGHT CONDENSER COOLING#) 00298
GO TO 400                     00299
51    CALL PAFCST(NCAPS+1,TC,PWCST,DELFC,QREJ) 00300
45    CALL COND(TC,T2,QREJ,PWCST,DT2,T1,U,A,FLCW,GPM,SYSYST,
* CCSKW)                      00301
RA=T1-T2                      00302
IF(NH20)13,14,15               00303
C      PLAC= COST PER KW FOR WATER DUCTING                         00305
13   PLAC=1.5                 00306
GO TO 16                      00307
14   PLAC=1.25                00308
GO TO 16                      00309
15   PLAC=1.0                 00310

```

```

16  CONTINUE
    IF(NSPCCN.EQ.1)PLAC=0.0
    SYSCST=SYSCST+PLAC*ANFCR/(CAPFAC*8.76)
        ASSUME 5 FT OF PUMPING HEAD (FRICTION)
    PHEAD=5.
    HPPMP=GPM*PHEAD/(3960.*PMPEF)
    CAPCOS=0.0
    OPCOS=(HPPMP*.7457/(PSIZE*1000.))*PWGST
    COSMAI=.001*CAPCOS/(PSIZE*1000.)+.1*OPCOS+.01*SYCST
    TOTCOS=SYSCST+DELFC+OPCOS+COSMAI
    IF(TOTCOS-TOTCS1)154,156,156
156  IF(NSPCCN.EQ.1)GO TO 190
151  TC=TC+1.
    IF(TC-TCMAX(NCAPS+1))100,100,190
154  RA1=RA
    T11=T1
    T21=T2
    SYS1=SYSCST
    CAPCS1=CAPCOS
    COSPK1=COSPKW
    OPCS1=OPCOS
    COSMA1=COSMAI
    PLAC1=PLAC
    HPFL=0.
    HPP1=HPPMP
    DELFI=DELFC
    TCALC1=TCALC
    QRJ1=QRJ
    FLCW1=FLCW
    FCFS=FLCW1/224700.
    GPM1=GPM
    UAI=UA
    TC1=TC
    TOTCS1=TOTCOS
    GO TO 156
190  IF(TOTCS1-1.E3)200,195,200
195  WRITE(IRITE,196)TC,T1,RA
196  FORMAT(13X, *FOR THE GIVEN CONDITIONS A SOLUTION CANNOT BE FOUND
     XD#,13X,TC =#,F5.0, #   T1 =#,F5.0, #   RA =#,F5.0)
     GO TO 400
200  CONTINUE
    WRITE(IRITE,212)
212  FORMAT(*1#15X*----STRAIGHT CONDENSER COOLING----*,1)
    IF(NH2O)220,228,230
220  WRITE(IRITE,197)
197  FORMAT(20X*(WITH SEA WATER)/*/)
    GO TO 23
228  WRITE(IRITE,198)
198  FORMAT(20X*(WITH UNTREATED FRESH WATER)/*/)
    GO TO 23
230  WRITE(IRITE,157)
157  FORMAT(20X*(WITH TREATED FRESH WATER)/*/)
23  WRITE(IRITE,227)QRJ1,TC1,FCFS,FLCW1,HPP1,TCALC1,RA1
227  FORMAT(10X*THE DESIGN VALUES AND COSTS ARE -*//,3X*Q REJECT =
     X#,E9.4,* BTU/HR AT T CONDENSER =#,F4.0//,3X*CONDENSER FLOW =#,E9.
     * 4,* CFS (#E9.
     X4,* LB/HR) PUMP POWER =#,E9.4,* HP#/,3X*EQUILIBRIUM TEMP =#,F4.0
     X,*      RANGE =#,F4.0//)
    CALL PRTDS2(CAPCS1,OPCS1,COSMA1,SYS1,DELFI,TOTCS1,COSPK1)
    WRITE(IRITE,302)
302  FORMAT(//15X*--RIVER TEMPERATURES--*//,
     X1X,14HDISTANCE=MILES,3X,17HSTREAM TEMP DEG.F, 3X,17HPLUME TEMP.-DE
     00311
     00312
     00313
     00314
     00315
     00316
     00317
     00318
     00319
     00320
     00321
     00322
     00323
     00324
     00325
     00326
     00327
     00328
     00329
     00330
     00331
     00332
     00333
     00334
     00335
     00336
     00337
     00338
     00339
     00340
     00341
     00342
     00343
     00344
     00345
     00346
     00347
     00348
     00349
     00350
     00351
     00352
     00353
     00354
     00355
     00356
     00357
     00358
     00359
     00360
     00361
     00362
     00363
     00364
     00365
     00366
     00367
     00368
     00369
     00370
     00371
     00372

```

```

XG,F ,3X,14HPLUME WIDTH-MI,/19X,AHNC PLANT,2X,5HMIXED,///) 00373
C CALC OF PLUME TEMPS AND WIDTH AND RIVER TEMPS- TO STAT 22 00374
VELRIV=(QFLRIV/(WIDTH*DEPTH))*3600.*24. 00375
DTRIV=(QRJ1/QFLRIV)/(3600.*62.4) 00376
TZERO=TAVH20+DTRIV 00377
I=-1 00378
307 I=I+1 00379
IF(I.EQ.11)I=20 00380
XI=I 00381
QC0N=FLCW1/(3600.*62.4) 00382
C1=ALCG(QFLRIV/(QFLRIV-QC0N)) 00383
PLUMEW=WIDTH*(1.-EXP(-(XI/2.+C1))) 00384
ALPHA1=((XK*XI*5280.)/(62.4*DEPTH*VELRIV)) 00385
TXDIST=(TZERO-TCALC)*EXP(ALPHA1)+TCALC 00386
TWREAL=(TAVH20-TCALC)*EXP(ALPHA1)+TCALC 00387
PLUMEW=PLUMEW/5280. 00388
PLUMT=((TXDIST-TWREAL)/(1.-EXP(-(XI/2.+C1))))+TWREAL 00389
WRITE(IRITE,308)XI,TWREAL,TXDIST,PLUMT,PLUMEW 00390
308 FORMAT(6X,F5.1,6X,F6.2,*4X,F6.2,5X,F6.2,11X,F6.4) 00391
IF(I.LT.20)GO TO 307 00392
WRITE(IRITE,330) 00393
330 FORMAT(//15X,#VARIABLE AMBIENT CONDITIONS#/) 00394
IF(NTAMB.EQ.0)GO TO 400 00395
TCPMIL=0.0 00396
TDFMIL=0.0 00397
DO 350 I=1,NCAPS 00398
IF(CAP(I).EQ.0.)GO TO 350 00399
AMBOPC(I)=0.0 00400
AMBDFC(I)=0.0 00401
DO 340 J=1,NTAMB 00402
IF(PCTAMB(I,J).EQ.0.)GO TO 340 00403
TC=TCMIN(I) 00404
NTCCD=0 00405
301 CALL PAFCST(I,TC,PWCST,DFCCD,QREJ) 00406
DT2=(QREJ/FLCW1)/(EXP(UA1/FLCW1)-1.)
DT1=DT2+QREJ/FLCW1 00407
T1=TC-DT2 00408
T2=TC-DT1 00409
IF(T2-TAMRV(J))304,305,310 00410
305 NTCCD=1 00411
GO TO 310 00412
304 TC=TC+1. 00413
NTCCD=1 00414
IF(TC.LT.TCMAX(I))GO TO 301 00415
WRITE(IRITE,309)PCMAX(I),CAP(I),TAMWB(J) 00416
309 FORMAT(//,3X,#CONDENSER PRESS MUST EXCEED THE GIVEN MAX CF#,/ 8 00417
XX,F4.2,* FOR THE CAPACITY CF#,F4.2,* AT T WET BULB =#,F5.0,/,3X,*P 00418
XROGRAM DISCONTINUING#) 00419
GO TO 400 00420
310 IF(NTCCD.GT.0)GO TO 315 00421
WRITE(IRITE,312)CAP(I),TAMWB(J),TC 00422
312 FORMAT(/8X,#FOR CAP =#,F4.2,* T WB =#,F5.0,*, AND TC =#, 00423
XF4.0,/,3X*PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE*) 00424
IF(DFCCD.GT.0.)DFCCD=0.0 00425
315 CONTINUE 00426
CPCCD=(HPP1*.7457/(PSIZE*1000.))*PWCST 00427
AMBOPC(I)=AMBOPC(I)+OPCCD*PCTAMB(J) 00428
AMBDFC(I)=AMBDFC(I)+DFCCD*PCTAMB(J) 00429
340 CONTINUE 00430
TCPMIL=TCPMIL+AMBOPC(I)*TOTLD(I)*COLPCT(I)*CAP(I) 00431
TDFMIL=TDFMIL+AMBDFC(I)*TOTLD(I)*COLPCT(I)*CAP(I) 00432
350 CONTINUE 00433

```

AVOPCS=TOPMIL/TKWHR	00435
AVDFCS=TDFMIL/TKWHR	00436
AVTCST=AVOPCS+AVDFCS+SYS1+COSMA1	00437
CALL PRTCD(AVOPCS,AVDFCS,AVTCST)	00438
400 CONTINUE	00439
RETURN	00440
END	00441

```

SUBROUTINE SUBPOND          00442
COMMON PSIZE,CCPKW,ANFCR,FUCST,NCAPS,CAP(6),TCTLD(5),COLPCT(5),TC
XMIN(6),PCMINT(6),TCMAX(6),PCMAX(6),HRCOF2(6),HRCOF1(6),HRCOFO(6),
XTDB,TWB,RH,TAVH2C,TCBASE,NTAMB,AMBDFC(5),AMBCPC(5),TAMDB(5),TAMW
XB(5),AMBRH(5),TAMRV(5),PCTAMB(5,5),NSYSCP,TDISMX,NSPCON,UCVALL,A
XREAC,SPFLCW,NH2C,WIDTH,PRPAGR,CAPFAC,USEFAC,TKWHRS,TRITE,IREAD,
* AMWIND(5),AMRAD(5),WIND,RAD
PMPEF=0.8                  00448
TOTCS1=1,E3                00449
C      CALC OF EQUILIBRIUM TEMPERATURE 00450
WCCFA=0.                    00451
WCCFB=15.                   00452
ECCF=WCCFA+WCCFB*WIND     00453
TA=TDB                      00454
TG=TDB                      00455
00456
7   DH=RAD-1801.*((TG/460.+1.)*#4-ECCF*51.7*(P(TG)-RH*P(TA)) -.26*ECC
XF*(TG-TA)                 00457
DHP=RAD-1801.*((TG+1.)/460.+1.)*#4-ECCF*51.7*(P(TG+1.)-RH*P(TA)) -
X.26*ECCF*(TG+1.-TA)       00458
DHM=RAD-1801.*((TG-1.)/460.+1.)*#4-ECCF*51.7*(P(TG-1.)-RH*P(TA)) -
X.26*ECCF*(TG-1.-TA)       00459
DHPRIM=(DHP-DHM)/2.         00460
IF(ABS(DH)=1.)1,2,2        00461
2   TNEW=TG-DH/DHPRIM      00462
TG=TNEW                     00463
GO TO 7                      00464
1   TCALC=TG                00465
BETA=51.7*(P(TCALC+1.)-P(TCALC-1.))/2. 00466
XK=15.7+(0.26+BETA)*ECCF  00467
TC=TCMIN(NCAPS+1)           00468
00469
100  CONTINUE               00469
IF(NSPCON=1)30,40,30        00470
40   CALL PAFCST(NCAPS+1,TC,PWCST,DELFC,QREJ) 00471
DT2=(QREJ/SPFLCW)/(EXP(UCVALL*AREAC/SPFLCW)-1.)
DT1=DT2+QREJ/SPFLCW
T1=TC-DT2
IF(NSYSCP=2)44,41,44
41   IF(TDISMX.LT.TCALC)GO TO 197
IF(DT1-(TC-TAVH2C))15,15,42
42   IF(TC-TCMAX(NCAPS+1))13,190,190
13   TC=TC+1
GO TO 40
15   T2=TDISMX
RA=T1-T2
IF(RA.LT.0.)GO TO 190
GO TO 46
44   T2=TC-DT1
IF(T2-TCALC)151,151,45
30   DT2=5.
IF(NSYSCP=2)31,32,31
31   T2=TCALC+1.
GO TO 50
32   IF(TDISMX.LT.TCALC)GO TO 197
T2=TDISMX
50   IF((TC-DT2)=T2)151,151,51
51   CALL PAFCST(NCAPS+1,TC,PWCST,DELFC,QREJ)
IF(NSYSCP=2)45,46,45
45   CALL COND(TC,T2,QREJ,PWCST,DT2,T1,UA,FLOW,GPM,SYSCST,COSPKW)
QREJT=QREJ
GO TO 47
46   CALL COND(TC,TAVH2C,QREJ,PWCST,DT2,T1,UA,FLOW,GPM,SYSCST,COSPKW)
QREJT=QREJ*(T1-T2)/(T1-TAVH2C)

```

```

47   RA=T1-T2          00504
      ALPHA=ALOG((T2-TCALC)/(T1-TCALC)) 00505
      AREAP=24.*ALPHA*FLOW/(XK*43560.) 00506
      ALOG MEAN T DIF BETWEEN AIR AND WATER 00507
      IF(T2-TDB)48,48,49 00508
      48   WLMTD=(T1+T2)/2.-TDB 00509
      GO TO 53 00510
      49   WLMTD=(T1-T2)/ALCG((T1-TDR)/(T2-TDR)) 00511
      C     BOWEN RATIO - RATIO OF CONDUCTION TO EVAPORATION 00512
      C     HEAT TRANSFER - MODIFIED FROM EDINGER AND GEYER 00513
      53   TWAV=(T1+T2)/2. 00514
      BCWRAT=.26*WLMTD/(51.7*(P(TWAV)-RH*P(TDR))) 00515
      QLAT=(QREJT-(.173E-8*((T1+T2)/2.+460.)*#4-RAD/24.)*AREAP* 00516
      * 43560.)/(1.+BCWRAT) 00517
      WEVAP=QLAT/970.3 00518
      GPMT=GPM+WEVAP/(8.34*60.) 00519
      C     ASSUME 30 FT OF PUMPING HEAD (FRICTION) 00520
      PHEAD=30. 00521
      HPPMP=GPMT*PHEAD/(3960.*PMPEF) 00522
      CAPCOS=AREAP*PRPAGR 00523
      DELFC=DELFC*USEFAC 00524
      CPCOS=(HPPMP*.7457/(PSIZE*1000.))*PWCST*USEFAC 00525
      COSMAI=.001*CAPCOS/(PSIZE*1000.)+.1*CPCOS+.01*SYSCST 00526
      TOTCOS=(CAPCOS*ANFCR)/(PSIZE*1000.*CAPFAC*8.76) +CPCOS +COSMAI+SYS 00527
      XCST+DELFC 00528
      IF(TOTCOS-TOTCS1)154,156,156 00529
156   IF(NSPCON.EQ.1)GO TO 157 00530
      IF(NSYSCP.EQ.2)GO TO 151 00531
      T2=T2+1. 00532
      GO TO 50 00533
157   IF(NSYSCP.EQ.2)GO TO 190 00534
151   TC=TC+1. 00535
      IF(TC-TCMAX(NCAPS+1))100,100,190 00536
154   RA1=RA 00537
      AREAPI=AREAP 00538
      T11=T1 00539
      T21=T2 00540
      SYS1=SYSCST 00541
      CAPCS1=CAPCOS 00542
      COSPK1=COSPKW 00543
      CPCS1=CPCOS 00544
      COSMA1=COSMAI 00545
      AFLRI=0. 00546
      HPFL=0. 00547
      HPP1=HPPMP 00548
      DELF1=DELFC 00549
      TCALC1=TCALC 00550
      QRJ1=QREJ 00551
      QRJT1=QREJT 00552
      FLOW1=FLOW 00553
      GPM1=GPM 00554
      UA1=UA 00555
      WEVAPI=WEVAP 00556
      TC1=TC 00557
      TOTCS1=TOTCOS 00558
      GO TO 156 00559
190   IF(TOTCS1-1.E3)200,195,200 00560
195   WRITE(IRITE,196)TC,T1,RA 00561
196   FORMAT(13X,#FOR THE GIVEN CONDITIONS A SOLUTION CANNOT BE FOUND 00562
      XD#,13X,#TC =#,F5.0,# T1 =#,F5.0,# RA =#,F5.0) 00563
      GO TO 400 00564
197   WRITE(IRITE,198) 00565

```

```

198  FFORMAT(/,3X,#MAX DIS T LESS THAN EQUILIBRIUM T#)          00566
     GO TO 400                                                 00567
200  CONTINUE                                               00568
     WRITE(IRITE,212)
212  FORMAT(*1#,15X,----- COOLING POND -----,//, 10X, *THE DESIGN V 00569
      XVALUES AND COSTS ARE -*,//)                                00570
      CALL PRTDS1(QRJ1,TC1,HPP1,WEVAP1,WRDWN1,AFLR1)           00571
      WRITE(IRITE,227)FLOW1,T11,RA1,TCALC1,AREAPI               00572
227  FORMAT(3X,#COND FLOW =#,E9.4,*   T IN =#,F4.0,*    RANGE =# 00573
      X,F4.0,/,3X,#EQUILIBRIUM TEMP =#,F4.0,*    PCND AREA =#,F8.0* 00574
      X* ACRES#)                                              00575
      IF(NSYSOP=2)230,228,230                                 00576
228  WRITE(IRITE,229)QRJT1                                  00577
229  FORMAT(/3X,#Q REJ PCND =#,E9.4,* BTU/HR#)            00578
230  CALL PRTDS2(CAPCS1,CPCS1,COSMA1,SYS1,DELF1,TCTCS1,COSPK1) 00579
      WRITE(IRITE,330)
330  FORMAT(/15X,#VARIABLE AMBIENT CONDITIONS#)            00580
      IF(INTAMB.EQ.0)GO TO 400                               00581
      TDMIL=0.0                                              00582
      TDFMIL=0.0                                              00583
      DO 350 I=1,NCAPS                                     00584
      IF(CAP(I).EQ.0.)GO TO 350                           00585
      AMBCPC(I)=0.0                                         00586
      AMBDFC(I)=0.0                                         00587
      DO 340 J=1,NTAMB                                     00588
      IF(PCTAMB(I,J).EQ.0.)GO TO 340                      00589
      TC=TCMIN(I)
      NTCDD=0
      TA=TAMDB(J)
      TG=TA
      RAD=AMRAD(J)
      ECCF=WCCFA+WCCFB*AMWIND(J)                         00590
20     DH=RAD-1801.* (TG/460.+1.)*#4-ECCF*51.7*(P(TG)-AMBRH(J)+P(TA))- 00591
      X*.26*ECCF*(TG-TA)                                    00592
      DHP=RAD-1801.* ((TG+1.)/460.+1.)*#4-ECCF*51.7*(P(TG+1.)-AMBRH(J)* 00593
      XP(TA))- .26*ECCF*(TG+1.-TA)                        00594
      DHM=RAD-1801.* ((TG-1.)/460.+1.)*#4-ECCF*51.7*(P(TG-1.)-AMBRH(J)* 00595
      XP(TA))- .26*ECCF*(TG-1.-TA)                        00596
      DHPRIM=(DHP-DHM)/2.                                 00597
      IF(ABS(DH)-1.)21,22,22
21     TNEW=TG-DH/DHPRIM                                 00598
      TG=TNEW
      GO TO 20
21     TCALC=TG
      BETAE=51.7*(P(TCALC+1.)-P(TCALC-1.))/2.          00599
      XK=15.7+.26*BETA)*ECCF
      ALPACT=(AREAPI*XK*43560.)/(24.*FLOW1)              00600
301    CALL PAFCST(I,TC,PWCST,DFCDD,QREJ)                00601
      DT2=(QREJ/FLOW1)/(EXP(UA1/FLOW1)-1.)
      DT1=DT2+QREJ/FLOW1
      T1=TC-DT2
      T2=TC-DT1
      IF(NSYSOP=2)316,303,316
316    IF(T2-TCALC)304,304,302
303    IF(T2-TAMRV(J))304,305,306
305    NTCDD=1
      GO TO 306
306    T2=TCALC+(T1-TCALC)/EXP(ALPACT)
      IF(T2-TDISMX)310,310,307
307    WRITE(IRITE,308)CAP(I),TAMWB(J),TC,T2
308    FFORMAT(/8X#FOR CAP =#,F4.2,*, T WB =#,F4.0,* AND TC =# 00620
      X,F4.0,/,3X*T DIS EXCEEDS TDIS MAX - CONTINUING#) 00621

```

```

      GO TO 315                                00628
302  ALPHA=-ALOG((T2-TCALC)/(T1-TCALC))      00629
      IF(ALPHA.LT.ALPACT)GO TO 310            00630
304  TC=TC+1.                                 00631
      NTCOD=1                                  00632
      IF(TC .LT. TCMAX(I))GO TO 301          00633
      WRITE(IRITE,309)CAP(I).J                00634
309  FORMAT(*-***THE PCND IS ESSENTIALLY TOO SMALL FCR#,F4.2,
     * # CAPACITY AND AMBIENT NC.,#,I2/# PROGRAM DISCONTINUING#)
      GO TO 400                                00635
310  IF(INTCCD.GT.0)GO TO 315                00636
      WRITE(IRITE,312)CAP(I).J                00637
312  FORMAT(*OTHE PCND IS LARGER THAN NECESSARY FCR#,F4.2,* CAPACITY#,
     * # AND AMBIENT NC.,#,I2/
     *# COMPUTING CGSTS ASSUMING MOST EFFICIENT CONDITION (PC=PCMINT)*)
      IF(DECOD.GT.0.)DFCCD=0.0                00640
315  CONTINUE                                 00641
      OPCOD=(HPP1*.7457/(PSIZE*1000.))*PWCST 00642
      AMBCPC(I)=AMBCPC(I)+OPCOD*PCTAMB(J)    00643
      AMBDFC(I)=AMBDFC(I)+DFCCD*PCTAMB(J)    00644
340  CONTINUE                                 00645
      TCPMIL=TCPMIL+AMBCPC(I)*TCLLD(I)*COLPCT(I)*CAP(I) 00646
      TDFMIL=TDFMIL+AMBDFC(I)*TCLLD(I)*COLPCT(I)*CAP(I) 00647
350  CONTINUE                                 00648
      AVOPCS=TCPMIL/TKWHR5                    00649
      AVDFCS=TDFMIL/TKWHR5                   00650
      AVTCST=(CAPCS1*ANFCR)/(PSIZE*1000.*CAPFAC*8.76) +AVOPCS+AVDFCS+SYS 00651
      X1=COSMA1                               00652
      CALL_PRTCD(AVOPCS,AVDFCS,AVTCST)        00653
400  CONTINUE                                 00654
      RETURN                                   00655
      END                                     00656
                                         00657
                                         00658
                                         00659

```

```

SUBROUTINE SUBMDW          00660
COMMON PSIZE,CCPKW,ANFCR,FUCST,NCAPS,LAP 10. 00661
X CCLPCT(5),TCMIN(6),PCMIN(6),TCMAX(6),PCMAX(6), 00662
X HRCDF2(6),HRCDF1(6),HRCDF0(6),TDB,TWB,RH,TAVH20,TCBASE, 00663
X NTAMB,AMBDFC(5),AMBGPC(5),TAMDR(5),TAMWB(5),AMPRH(5). 00664
X TAMRV(5),PCTAMB(5,5),NSYSOP,TDISMX,NSPCON,UCVALL,AREAC,SPFLCW, 00665
X NH20,WIDTH,PRPAGR,CAPFAC,USEFAC,TKWHRS,IRITE,IREAD 00666
DIMENSION XK(20)          00667
FANEF=0.8                 00668
PMPEF=0.8                 00669
TCTCS1=1,E3                00670
TC=TCMIN(NCAPS+1)          00671
100  CONTINUE               00672
IF(NSPCON=1)30,40,30        00673
40   CALL PAFCST(NCAPS+1,TC,PWCST,DELFC,QREJ)          00674
DT2=(QREJ/SPFLCW)/(EXP(UCVALL*AREAC/SPFLCW)-1.) 00675
DT1=DT2+QREJ/SPFLCW       00676
T1=TC-DT2                  00677
IF(NSYSOP=2)44,41,44        00678
41   IF(DT1-(TC-TAVH20))15,15,42          00679
42   IF(TC-TCMAX(NCAPS+1))13,190,190        00680
13   TC=TC+1                  00681
GO TC 40                   00682
15   T2=TDISMX               00683
APPR=T2-TWB                00684
IF(APPR.LT.7.)GO TC 190      00685
IF(APPR.GT.20.)GO TC 190      00686
RA=T1-T2                   00687
IF(RA.LT.10.)GO TC 190       00688
GO TC 46                   00689
44   T2=TC-DT1               00690
APPR=T2-TWB                00691
IF(APPR.LT.7.)GO TC 151      00692
IF(APPR.GT.20.)GO TC 190      00693
GO TC 45                   00694
30   IF(NSYSOP=2)31,32,31      00695
31   APPR=7.                  00696
50   T2=TWB+APPR              00697
IF(TC-T2)151,151,51          00698
32   T2=TDISMX               00699
APPR=T2-TWB                00700
IF(APPR.LT.7.)GO TC 190      00701
IF(APPR.GT.20.)GO TC 190      00702
51   DT2=5.                  00703
CALL PAFCST(NCAPS+1,TC,PWCST,DELFC,QREJ)          00704
IF(NSYSOP=2)45,46,45          00705
45   CALL COND(TC,T2,QREJ,PWCST,DT2,T1,UA,FLCW,GPM,SYSCST, 00706
*   CCSPKW)                  00707
QREJT=QREJ                  00708
GO TC 47                   00709
46   CALL COND(TC,TAVH20,QREJ,PWCST,DT2,T1,UA,FLCW,GPM,SYSCST, 00710
*   CCSPKW)                  00711
QREJT=QREJ*(T1-T2)/(T1-TAVH20) 00712
47   RA=T1-T2                  00713
IF(RA.LT.10.)GO TC 151        00714
TAXT=(T1+T2)/2.              00715
H1=H(TWB)                   00716
H2=H(TAXT)                  00717
AFLR=QREJT/(H2-H1)           00718
WACT=RH*(.622*P(TDB))/(14.696-P(TDB)) 00719
APSAT=(WACT*14.696)/(.622+WACT) 00720
DIN=14.696*(14.696-APSAT)/(53.35*(TDB+460.)) 00721

```

```

WART=FLOW/AFLR
T3=T2+.1*RA 00722
T4=T2+.4*RA 00723
T5=T1-.4*RA 00724
T6=T1-.1*RA 00725
CC1=WART*RA 00726
RDH1=1./(H(T3)-H1-.1*CC1) 00727
RDH2=1./(H(T4)-H1-.4*CC1) 00728
RDH3=1./(H(T5)-H2+.4*CC1) 00729
RDH4=1./(H(T6)-H2+.1*CC1) 00730
CHAR=(RA/4.)*(RDH1+RDH2+RDH3+RDH4) 00731

```

```

C
C          PACKING HEIGHT FROM FRAAS + CZISIK - DECK NUMBER 1 00732
C          DECKHT =2. 00733
C          PHT=DECKHT*(CHAR-.07)/(1.103*WART**(-.54)) 00734
C          WATER LOADING = 2500 00735
C          WLOAD=2500. 00736
C          PLANA=FLOW/WLOAD 00737
C          AIR LOADING OR G 00738
C          ALDG=AFLR/PLANA 00739
C          ALDGE=ALDG+3500. 00740

```

```

C          PRESSURE DROP (INCHES OF WATER) FROM FRAAS AND CZTSK 00741
C          DELP=((PHT/DECKHT)*.0675/DIN)*(0.4E-8*ALDG**2+.1E-12*2500.*ALDGE* 00742
C          X*2*2.62) 00743
C          RANGE=RA 00744
C          IK=APPR 00745
C          IF(GPM)210,210,11 00746

```

```

C          CALK OF K FACTOR - LOCKHART ET AL 00747
11     IF(IK=7)370,7,1 00748
1     IF(IK=20)2*2*370 00749
2     IF(IK=10)6,5,5 00750
6     GO TO (8,9),(IK=7) 00751
7     XK(7)=.42626139+.30755494*RANGE-.83222851E-02*RANGE**2+.14 00752
X130379E-03*RANGE**3-.87533682E-06*RANGE**4 00753
GO TO 25 00754
8     XK(8)=.53003286+.26855945*RANGE-.71968070E-02*RANGE**2+.12 00755
X092005E-03*RANGE**3-.73568322E-06*RANGE**4 00756
GO TO 25 00757
9     XK(9)=.27667081+.27125055*RANGE-.75042365E-02*RANGE**2+.12 00758
X884963E-03*RANGE**3-.800219A0E-06*RANGE**4 00759
GO TO 25 00760
5     AA=APPR/2. 00761
Z=0. 00762
IA=AA 00763
AB=IA 00764
IF(AB.EQ.AA)GO TO (10,12,14,16,18,20),(AB=4.) 00765
GO TO (10,12,14,16,18),(AB=4.) 00766

```

```

21     Z=2. 00767
      GO TO (12,14,16,18,20),(AB=4.) 00768
10     XK(10)=.87557520E-01+.25976379*RANGE-,69589515E-02*RANGE**2 00769
X+.11542869E-03*RANGE**3-.69832755E-06*RANGE**4 00770
IF(AB.EQ.AA)GO TO 25 00771
IF(Z=2.)21,23,21 00772
12     XK(12)=.30755983E-02+.22692621*RANGE-.57515664E-02*RANGE**2 00773
X+.89248959E-04*RANGE**3-.50381046E-06*RANGE**4 00774
IF(AB.EQ.AA)GO TO 25 00775
IF(Z=2.)21,23,21 00776
14     XK(14)=-.33616133+.22612638*RANGE-.57931043E-02*RANGE**2 00777
X+.89896029E-04*RANGE**3-.50893025E-06*RANGE**4 00778
IF(AB.EQ.AA)GO TO 25 00779
IF(Z=2.)21,23,21 00780

```

```

16 XK(16)=-.43379805+.20785695*RANGE-,51672632E-02*RANGE**2 00784
  X+.77053656E-04*RANGE**3-.42119093E-06*RANGE**4 00785
  IF(AB.EQ.AA) GO TO 25 00786
  IF(Z-2,)21,23,21 00787
18 XK(18)=-.91434163+.23827008*RANGE-.66801246E-02*RANGE**2 00788
  X+.10604073E-03*RANGE**3-.61338627E-06*RANGE**4 00789
  IF(AB.EQ.AA) GO TO 25 00790
  IF(Z-2,)21,23,21 00791
20 XK(20)=-.12250402E+01+.25793956*RANGE-,7655059E-02*RANGE**2 00792
  X+.12169709E-03*RANGE**3-.70610963E-06*RANGE**4 00793
  IF(AB.EQ.AA) GO TO 25 00794
  IF(Z-2,)21,23,21 00795
23 XK(IK)=(XK(IK-1)+XK(IK+1))/2. 00796
25 CONTINUE 00797
CWB=.7+EXP(4.17-.0767*TWB) 00798
DELHS=QREJT/AFLR 00799
HCUT=H1+DELHS 00800
TCUTS=.99674408E1+.24105952E1*HCUT-.22686654E-1*HCUT**2 + .102553 00801
X04E-3*HCUT**3-.14174090E-6*HCUT**4 00802
QLAT=QREJT-AFLR*.24*(TCUTS-TDB) 00803
WEVAP=QLAT/970.3 00804
CONCR=5. 00805
C WATER FOR BLCWDOWN 00806
WBDWN=(.06*QREJT*62.4)/(500.*7.48*(CONCR-1.)) 00807
WNEED=WEVAP+WBDWN 00808
GPMT=GPM+WNEED/(8.34*60.) 00809
FUDGE=GPMT*XK(IK)*CWB 00810
C LOCKHART SAYS COST = 2*FUDGE BUT CONVERSES COSTS ARE 00811
C ABOUT 2*LOCKHARTS - USE AVG. = 3*FUDGE 00812
CAPCOS=3.*FUDGE 00813
ACFM=AFLR/(60.*DIN) 00814
HPFAN=(ACFM*DELP*5.2)/(33000.*FANE) 00815
HPPMP=GPMT*(PHT+10.)/(3960.*PMPEF) 00816
TCTHP=HPFAN+HPPMP 00817
DELFAC=DELFAC*USEFAC 00818
OPCCS=(TCTHP*.7457/(PSIZE*1000.))*PWCST*USEFAC 00819
COSMAI=.001*CAPCOS/(PSIZE*1000.)+.1*OPCCS+.01*SYSCST 00820
TCTCOS=(CAPCOS*ANFCR)/(PSIZE*1000.*CAPFAC*8.76) +OPCCS 00821
X+COSMAI+SYSCST+DELFAC 00822
IF(TCTCOS-TCTCS)154,156,156 00823
156 IF(NSPCON.EQ.1) GO TO 157 00824
  IF(NSYSCP.EQ.2) GO TO 151 00825
  APPR=APPR+1. 00826
  IF(APPR-20.)50,50,151 00827
157 IF(NSYSCP.EQ.2) GO TO 190 00828
151 TC=TC+1. 00829
  IF(TC-TCMAX(NCAPS+1))100,100,190 00830
154 RAJ=RA 00831
  CHAR1=CHAR 00832
  PHT1=PHT 00833
  PLANAL=PLANA 00834
  AFLR1=AFLR 00835
  DPL=DELP 00836
  APPR1=APPR 00837
  HWBL=H1 00838
  SYS1=SYSCST 00839
  CAPCS1=CAPCOS 00840
  COSPK1=COSPKW 00841
  OPCCS1=OPCCS 00842
  COSMA1=COSMAI 00843
  THPL=TCTHP 00844
  HPF1=HPFAN 00845

```

```

HPP1=HPPMP          00846
DELF1=DELFC          00847
QRJ1=QREJ            00848
QRJT1=QREJT          00849
FLCW1=FLOW           00850
GPM1=GPM             00851
WART1=WART           00852
UA1=UA               00853
WEVAP1=WEVAP          00854
WBDWN1=WBDWN          00855
WNEED1=WNEED          00856
TC1=TC               00857
XK1=XK(IK)           00858
TOTCS1=TOTCOS          00859
GO TO 156            00860
190 IF(TOTCS1-1.E3)200,195,200
195 WRITE(IRITE,196)TC,APPR,RA
196 FORMAT(1X,*FOR THE GIVEN CONDITIONS A SOLUTION CANNOT BE
X FOUND*,/,3X,*TC =*,F5.0,* APPR =*,F5.0,* RA =*,F5.0)
GO TO 400            00861
200 CONTINUE           00862
210 WRITE(IRITE,212)
212 FORMAT(*1#,15X,*----- MECHANICAL DRAFT WET TOWER -----*,//, 10
XX,*THE DESIGN VALUES AND COSTS ARE -*,//)
CALL PRTDS1(QRJ1,TC1,HPP1,WEVAP1,WBDWN1,AFLR1)
WRITE(IRITE,227)DP1,FLCW1,RA1,APPR1
227 FORMAT(3X,*PRESSURE DROP =*,F5.2,* COND FLOW =*,E9.4,/
X 3X*RANGE =*,F4.0,* APPROACH =*,F4.0)
IF(NSYSOP-2)230,228,230
228 WRITE(IRITE,229)QRJT1
229 FORMAT(1X,*Q REJ TOWER =*,E9.4,* BTU/HR*)
230 CALL PRTDS2(CAPCS1,CPCS1,COSMA1,SYS1,DELF1,TOTCS1,COSPK1)
WRITE(IRITE,330)
330 FORMAT(//15X,*VARIABLE AMBIENT CONDITIONS*)
IF(NTAMB.EQ.0)GO TO 400
TOPMIL=0.0            00863
TDFMIL=0.0            00864
DO 350 I=1,NCAPS      00865
IF(CAP(I).EQ.0.)GO TO 350
AMB CPC(I)=0.0         00866
AMB DEC(I)=0.0         00867
DO 340 J=1,NTAMB       00868
IF(PCTAMB(I,J).EQ.0.)GO TO 340
TC=TCMIN(I)
NTCOD=0               00869
301 CALL PAFCST(I,TC,PWCST,DFCCD,QREJ)
DT2=(QREJ/FLCW1)/(EXP(UA1/FLCW1)-1.)
DT1=DT2+QREJ/FLCW1
T1=TC-DT2
T2=TC-DT1
IF(NSYSOP-2)316,303,316
316 IF(T2-TAMWB(J))304,304,302
303 IF(T2-TAMRV(J))304,305,306
305 NTCOD=1
306 T2=TDISMX
IF(T2.GT.TAMWB(J))GO TO 302
WRITE(IRITE,313)TAMWB(J)
313 FORMAT(3X*T DIS MAX LESS THAN(CR =) T WB =*,F4.0,*)
X 3X*REQUIRES NEGATIVE APPROACH - DISCONTINUING*)
GO TO 400            00870
302 TAXT=(T1+T2)/2.
RA=T1-T2              00871

```

```

T3=T2+.1*RA          00908
T4=T2+.4*RA          00909
T5=T1-.4*RA          00910
T6=T1-.1*RA          00911
C01=WART1*RA         00912
H1=H(TAMWB(J))      00913
H2=H(TAXT)           00914
RDH1=1./(H(T3)-H1-.1*C01) 00915
RDH2=1./(H(T4)-H1-.4*C01) 00916
RDH3=1./(H(T5)-H2+.4*C01) 00917
RDH4=1./(H(T6)-H2+.1*C01) 00918
CHAR=(RA/4.)*(RDH1+RDH2+RDH3+RDH4) 00919
IF(CHAR .LT. CHAR1) GO TO 310 00920
IF(NSYSQP-2) 304,307,304 00921
307 WRITE(IRITE,308)CAP(I),TAMWB(J),TC 00922
308 FORMAT(/8X,FOR CAP =#,F4.2,#, T WB =#,F4.0, #, AND 00923
  X TC =#,F4.0,/,3X#T DIS EXCEEDS TDIS MAX - CONTINUING#) 00924
  GO TO 315           00925
304 TC=TC+1.          00926
NTCCD=1              00927
IF(TC .LT. TCMAX(I))GO TO 301 00928
WRITE(IRITE,309)PCMAX(I),CAP(I),TAMWB(J) 00929
309 FORMAT(/,3X,#CONDENSER PRESS MUST EXCEED THE GIVEN MAX OF#,/ A 00930
  XX,F4.2,# FOR THE CAPACITY OF#,F4.2,# AT T WET BULB =#,F5.0,/,3X#· 00931
  XPROGRAM DISCONTINUING#) 00932
  GO TO 400           00933
310 IF(NTCCD.GT.0)GO TO 315 00934
  WRITE(IRITE,312)CAP(I),TAMWB(J),TC 00935
312 FORMAT(/8X,#FOR CAP =#,F4.2,#, T WB =#,F5.0,#, AND 00936
  X TC =#,F4.0,/,3X#PC LESS THAN PC MIN - ASSUME PC MIN - CONTINUE#) 00937
  IF(DFCCD.GT.0.)DFCCD=0.0 00938
315 CCNTINUE          00939
  CPCCD=(THP1*.7457/(PSIZE*1000.))*PWCST 00940
  AMBCPC(I)=AMBCPC(I)+CPCCD*PCTAMB(J) 00941
  AMBDPC(I)=AMBDPC(I)+DFCCD*PCTAMB(J) 00942
340 CCNTINUE          00943
  TCPMIL=TCPMIL+AMBCPC(I)*TCTLD(I)*COLPCT(I)*CAP(I) 00944
  TDFMIL=TDFMIL+AMBDPC(I)*TCTLD(I)*COLPCT(I)*CAP(I) 00945
350 CCNTINUE          00946
  AVOPCS=TOPMIL/TKWHR$ 00947
  AVDFCS=TDFMIL/TKWHR$ 00948
  AVTCST=(CAPCS1*ANFCR)/(PSIZE*1000.*CAPFAC*8.76) +AVOPCS+AVDFCS+SYS 00949
  X1=COSMA1
  CALL PBTOD(AVOPCS,AVDFCS,AVTCST) 00950
  GO TO 400           00951
370 WRITE(IRITE,371) APPR 00952
371 FORMAT(* APPROACH=#,F7.1,# NO CURVES - RUN ABORTED#) 00953
  GO TO 400           00954
400 CCNTINUE          00955
  RETURN             00956
END                 00957

```

```

SUBROUTINE SUBNDW
COMMON PSIZE,CCPKW,ANFCR,FUCST,NCAPS,CAP(6),TOTLD(5),COLPCT(5),TC
XMIN(6),PCMIN(6),TCMAX(6),PCMAY(6),HRCOF2(6),HRCOF1(6),HRCOF0(6),
XTDB,TWB,RH,TAVH2C,TCBASE,NTAMB,AMBDFC(5),AMBOPC(5),TAMDB(5),TAMW
XB(5),AMBRH(5),TAMRV(5),PCTAMB(5,5),NSYSCP,TDISMX,NSPCON,UCVALL,A
XREAC,SPFLOW,NH2O,WIDTH,PRPAGR,CAPFAC,USEFAC,TKWHRS,IRITE,IREAD
PI=3.14159
PMPEF=0.8
TOTCS1=1.E3
HDRMAX=1.5
IWL=0
TC=TCMIN(NCAPS+1)
100 CONTINUE
IF(NSPCCN-1)30,40,30
40 CALL PAFCST(NCAPS+1,TC,PWCST,DELFC,QREJ)
DT2=(QREJ/SPFLOW)/(EXP(UCVALL*AREAC/SPFLOW)-1.)
DT1=DT2+QREJ/SPFLOW
T1=TC-DT2
IF(NSYSCP-2)44,41,44
41 IF(DT1-(TC-TAVH2C))15,15,42
42 IF(TC-TCMAX(NCAPS+1))13,190,190
13 TC=TC+1
GO TO 40
15 T2=TDISMX
APPR=T2-TWB
IF(APPR.LT.7.)GO TO 190
IF(APPR.GT.20.)GO TO 190
RA=T1-T2
IF(RA.LT.10.)GO TO 190
GO TO 46
44 T2=TC-DT1
APPR=T2-TWB
IF(APPR.LT.7.)GO TO 151
IF(APPR.GT.20.)GO TO 190
GO TO 45
30 IF(NSYSCP-2)31,32,31
31 APPR=7.
50 T2=TWB+APPR
IF(TC-T2)151,151,51
32 T2=TDISMX
APPR=T2-TWB
IF(APPR.LT.7.)GO TO 190
IF(APPR.GT.20.)GO TO 190
51 DT2=5.
CALL PAFCST(NCAPS+1,TC,PWCST,DELFC,QREJ)
IF(NSYSCP-2)45,46,45
45 CALL COND(TC,T2,QREJ,PWCST,DT2,T1,UA,FLow,GPM,SYSCST,
* CCPKW)
QREJT=QREJ
GO TO 47
46 CALL COND(TC,TAVH2C,QREJ,PWCST,DT2,T1,UA,FLow,GPM,SYSCST,
* CCPKW)
QREJT=QREJ*(T1-T2)/(T1-TAVH2C)
47 RA=T1-T2
IF(RA.LT.10.)GO TO 151
WLOAD=1250.
IWL=0
INITIAL WATER LOADING 1250 LBM/FT2/HR
48 CONTINUE
BSA=FLow/WLOAD
DIA=SQRTF(4.*BSA/3.14159)
TAXT = AIR EXIT TEMP = FRAAS + CZISIK

```

```

TAXT=(T1+T2)/2. 01021
H1=H(TWR) 01022
H2=H(TAXT) 01023
AFLR=QREJ/(H2-H1) 01024
WART=FLOW/AFLR 01025
C CALC OF CHAR(TOTAL REQUIRED TOWER CHARACTERISTIC) FROM CTI 01026
T3=T2+0.1*RA 01027
T4=T2+0.4*RA 01028
T5=T1-0.4*RA 01029
T6=T1-0.1*RA 01030
CC1=WART*RA 01031
RDH1=1./(H(T3)-H1-0.1*CC1) 01032
RDH2=1./(H(T4)-H1-0.4*CC1) 01033
RDH3=1./(H(T5)-H2+0.4*CC1) 01034
RDH4=1./(H(T6)-H2+0.1*CC1) 01035
CHAR=(RA/4.)*(RDH1+RDH2+RDH3+RDH4) 01036
C UNC = CHAR/FT OF PACKING FROM LOWE + CHRISTIE 01037
UNC=0.1*(1./WART)*0.73 01038
PHT=CHAR/UNC 01039
C WACT = ACTUAL HUMIDITY 01040
WACT=RH*(0.622*P(TDB))/(14.696-P(TDB)) 01041
APSAT=(WACT*14.696)/(0.622*WACT) 01042
DIN=144.* (14.696-APSAT)/(53.35*(TDB+460.)) 01043
DCUT=(144.* (14.696-P(TAXT)))/(53.35*(TAXT+460.)) 01044
C VIN = INLET VELOCITY 01045
VIN=5. 01046
C VHD1 = INLET VEL HEAD 01047
VHD1=(VIN**2)*DIN/64.4 01048
C CPHT=(AELR/3600.)/(PI*DIA*DIN*VIN) 01049
C SPRAY NOZZLES ASSUMED 4 FT ABOVE PACKING 01050
C PPK = DEL P OF PACKING (VEL HEADS/FT) 01051
C ASSUMED LINEAR FUNCTION OF WLOAD - SEE LOWE + CHRISTIE 01052
PKWA=.5 01053
PKWB=2.5E-4 01054
PPK=PHT*(PKWA+PKWB*WLOAD) 01055
C PSP = DEL P OF SPRAY 01056
PSP=0.16*(CPHT*4.)*WART**1.32 01057
C INLET + EXIT TURNING LOSSES + FRICTION LOSS = TPIX VEL. HDS 01058
TPIX=28.5 01059
TPDP=PPK+PSP+TPIX 01060
DEL_P=TPDP*VHD1 01061
THT=DEL_P/(DIN-DCUT) 01062
HDR=THT/DIA 01063
IF(HDR.LE.HDRMAX) GO TO 120 01064
WLOAD=.9*WLOAD 01065
IWL=IWL+1 01066
IF(IWL.LE.10) GO TO 48 01067
120 HTDIA=THT*DIA 01068
CAPCOS=3.4E5*(HTDIA**.17) 01069
CONCR=5. 01070
TCUTS=.99674408E1+.24105952E1*H2-.22686654E-1*H2**2+.10255304E-3 01071
X*H2**3.14174090E-6*H2**4 01072
QLAT=QREJ-AFLR*.24*(TCUTS-TDB) 01073
WEVAP=QLAT/970.3 01074
WBDWN=(.06*QREJ*62.4)/(500.*7.48*(CONCR-1.)) 01075
WNEED=WEVAP+WBDWN 01076
HPPMP=(GPM*(PHT+4.*DPHT))/(3960.*PMPEF) 01077
OPCOS=(HPPMP*.7457/(PSIZE*1000.))*PWCST*USEFAC 01078
DELF_C=DELF_C*USEFAC 01079
COSMAI=.001*CAPCOS/(PSIZE*1000.)+.1*OPCOS+.01*SYSCST 01080
TOTCOS=(CAPCOS*ANFCR)/(PSIZE*1000.*CAPFAC*8.76)+OPCOS 01081
X+COSMAI+SYSCST+DELF_C 01082

```

```

156 IF(TOTCOS-TOTCS1)154,156,156          01083
    IF(NSPCON.EQ.1) GO TO 157             01084
    IF(NSYSOP.EQ.2) GO TO 151             01085
    APPR=APPR+1.                         01086
    IF(APPR-20.)50,50,151                01087
157 IF(NSYSOP.EQ.2) GO TO 190             01088
151 TC=TC+1.                           01089
    IF(TC-TCMAX(NCAPS+1))100,100,190   01090
154 RA1=RA                           01091
    CHAR1=CHAR                         01092
    PHT1=PHT                          01093
    PPK1=PPK                          01094
    AFLR1=AFLR                         01095
    APPR1=APPR                         01096
    HWB1=H1                           01097
    SYS1=SYSCST                        01098
    CAPCS1=CAPCOS                       01099
    COSPK1=COSPKW                      01100
    CPCS1=CPCCOS                        01101
    COSMA1=COSMAI                       01102
    HPF1=0.0                           01103
    HPP1=HPPMP                         01104
    DELF1=DELFc                         01105
    QRJ1=QREJ                           01106
    QRJT1=QREJT                         01107
    FLOW1=FLOW                          01108
    GPM1=GPM                           01109
    WART1=WART                          01110
    UA1=UA                            01111
    WEVAP1=WEVAP                        01112
    WBDWN1=WBDWN                        01113
    WNED1=WNEED                         01114
    TC1=TC                           01115
    DIA1=DIA                          01116
    THT1=THT                          01117
    TAXT1=TAXT                         01118
    CPHT1=CPHT                         01119
    TPDP1=TPDP                         01120
    DP1=DELP                           01121
    TOTCS1=TOTCOS                       01122
    WLCA1=WLCAAD                      01123
    HDR1=HDR                           01124
    GO TO 156                         01125
190 IF(TOTCS1-1,E3)200,195,200          01126
195 WRITE(IRITE,196)TC,APPR,RA          01127
196 FORMAT(1X,*FOR THE GIVEN CONDITIONS A SOLUTION CANNOT BE FOUND* 01128
        XD#,/,3X,*TC =#,F5.0,*      APPR =#,F5.0,*     RA =#,F5.0)* 01129
        GO TO 400                      01130
200 CONTINUE                         01131
    WRITE(IRITE,212)                   01132
212 FORMAT(*1#,15X,*----- NATURAL DRAFT WET TOWER -----,/,10X,* 01133
        XTHE DESIGN VALUES AND COSTS ARE -#,//) 01134
        CALL PRTDS1(QRJ1,TC1,HPF1,HPP1,WEVAP1,WBDWN1,AFLR1) 01135
        WRITE(IRITE,227)DP1,FLOW1,RA1,APPR1,THT1,DIA1,WLCA1,CHAR1,PHT1 01136
227 FORMAT(3X,*PRESSURE DROP =#,F5.1,*      COND FLOW =#,E9.4,/, 3X* 01137
        XRANGE =#,F4.0,*      APPRCACH =#,F4.0,/,3X*TOWER HEIGHT =#,F6.0, 01138
        X *      TOWER DIAMETER =#F5.0/*      WATER LOADING =#F7.0,* LBM/HR-FT2* 01139
        X/*      TOWER CHARACTERISTIC =#F5.2,*      PACKING HEIGHT =#F5.2) 01140
        IF(NSYSOP-2)230,228,230          01141
228 WRITE(IRITE,229)QRJT1              01142
229 FORMAT(1X,*Q REJ TOWER =#,E9.4,* BTU/HR*) 01143
230 CALL PRTDS2(CAPCS1,CPCS1,COSMA1,SYST,DELF1,TOTCS1,COSPK1) 01144

```

```

IF(HDR1,LE,HDRMAX) GO TO 140 01145
WRITE(IRITE,125)HDR1,HDRMAX 01146
125 FORMAT(10 NOTE--H/D=F5.2,* WHICH IS GREATER THAN*, 01147
      X * H/DMAX=F5.2//) 01148
140 CONTINUE 01149
      WRITE(IRITE,330) 01150
330  FORMAT(15X,#VARIABLE AMBIENT CONDITIONS#) 01151
      IF(NTAMB.EQ.0) GO TO 400 01152
      TCPMIL=0.0 01153
      TDFMIL=0.0 01154
      DO 350 I=1,NCAPS 01155
      IF(CAP(I).EQ.0.) GO TO 350 01156
      AMBCPC(I)=0.0 01157
      AMRDFC(I)=0.0 01158
      DO 340 J=1,NTAMB 01159
      IF(PCTAMB(I,J).EQ.0.) GO TO 340 01160
      TC=TCMIN(I) 01161
      NTCCD=0 01162
301  CALL PAFCST(I,TC,PWCST,DFCCD,QREJ) 01163
      DT2=(QREJ/FLOW1)/(EXP(UA1/FLCW1)-1.) 01164
      DT1=DT2+QREJ/FLOW1 01165
      T1=TC-DT2 01166
      T2=TC-DT1 01167
      IF(NSYSQP-2)316,303,316 01168
316  IF(T2-TAMWB(J))304,304,320 01169
303  IF(T2-TAMRV(J))304,305,306 01170
305  NTCCD=1 01171
306  T2=IDIS4X 01172
      IF(T2.GT.TAMWB(J)) GO TO 320 01173
      WRITE(IRITE,313)TAMWB(J) 01174
313  FORMAT(3X*T DIS MAX LESS THAN(CR =) T WB =#,F4.0,, 3X*REQUIR 01175
      XES NEGATIVE APPROACH - DISCONTINUING*)
      GO TO 400 01176
321  IF(NSYSQP-2)304,307,304 01177
307  WRITE(IRITE,308)CAP(I),TAMWB(J),TC 01178
308  FORMAT(8X*FOR CAP =#,F4.2,*, T WB =#,F4.0,*, AND TC =# 01179
      X ,F4.0/3X,*T DIS EXCEEDS T DIS MAX - CONTINUING*) 01180
      GO TO 315 01181
304  TC=TC+1. 01182
      NTCCD=1 01183
      IF(TC .LT. TCMAX(I)) GO TO 301 01184
      WRITE(IRITE,309)PCMAX(I),CAP(I),TAMWB(J) 01185
309  FORMAT(1,3X,*CONDENSER PRESS MUST EXCEED THE GIVEN MAX OF#/, 01186
      XX,F4.2,* FOR THE CAPACITY OF#,F4.2,* AT T WET BULB =#,F5.0,/,3X,*P 01187
      XPROGRAM DISCONTINUING*) 01188
      GO TO 400 01189
320  WACT=AMBRH(J)*(.622*P(TAMD(J)))/(14.696-P(TAMD(J))) 01190
      APSAT=WACT*14.696/(.622+WACT) 01191
      DIN=144.*((14.696-APSAT)/(53.35*(TAMD(J)+460.))) 01192
      TAXT=(T1+T2)/2. 01193
      RA=T1-T2 01194
      H1=H(TAMWB(J)) 01195
      H2=H(TAXT) 01196
      DOUT=(144.*((14.696-P(TAXT)))/(53.35*(TAXT+460.))) 01197
      AFLR=QREJ/(H2-H1) 01198
      VIN=(AFLR/3600.)/(PI*DIA1*OPHT1*DIN) 01199
      WART=FLCW1/AFLR 01200
      PSP=.16*(OPHT+4.)*WART**1.32 01201
      TPDP=PPK1+PSP+TPIX 01202
      VHD1=(VIN**2)*DIN/64.4 01203
      THT=(TPDP*VHD1)/(DIN-DOUT) 01204
      IF(THT-THT1.GT.5.) GO TO 321 01205
      01206

```

```

IF(NTCCD.GT.0) GO TO 315                                01207
WRITE(IRITE,312)CAP(I),TAMWB(J),TC                      01208
312  FCRMAT(/8X,#FOR CAP =#,F4.2,#, T WB =#,F5.0,#, AND TC =#,
      X   F4.0/# PC LESS THAN PC MIN - ASSUME PC MIN = CONTINUE#)
      IF(DFCCD.GT.0.)DFCCD=0.0                            01209
315  CONTINUE                                            01210
      OPCOD=(HPP1*.7457/(PSIZE*1000.))*PWCST            01211
      AMBOPC(I)=AMBOPC(I)+OPCOD*PCTAMB(J)                01212
      AMBDPC(I)=AMBDPC(I)+DFCCD*PCTAMB(J)                01213
340  CONTINUE                                            01214
      TCPMIL=TCPMIL+AMBOPC(I)*TCLD(I)*COLPCT(I)*CAP(I) 01215
      TDFMIL=TDFMIL+AMBDPC(I)*TCLD(I)*COLPCT(I)*CAP(I) 01216
350  CONTINUE                                            01217
      AVOPCS=TCPMIL/TKWHRs                             01218
      AVDFCS=TDFMIL/TKWHRs                            01219
      AVTCST=(CAPCS1*ANFCR)/(PSIZE*1000.*CAPFAC*8.76) +AVOPCS+AVDFCS+SYS 01220
      X1+COSMA1                                         01221
      CALL PRTCD(AVOPCS,AVDFCS,AVTCST)                  01222
      GO TO 400                                         01223
400  CONTINUE                                            01224
      RETURN                                              01225
      END                                                 01226
                                         01227
                                         01228

```

```

SUBROUTINE PAFCST(I,TC,PWCST,DELFC,QREJ)          01229
COMMON PSIZE,CCPKW,ANFCR,FUCST,NCAPS,CAP(6),TCTLD(5),      01230
X CCLPCT(5),TCMIN(6),PCMIN(6),TCMAX(6),PCMAX(6),      01231
X HRCDF2(6),HRCDF1(6),HRCDF0(6),TDB,TWB,RH,TAVH2C,TCBASE, 01232
X NTAMB,AMBDFC(5),AMBCPC(5),TAMDB(5),TAMWB(5),AMRRH(5), 01233
X TAMRV(5),PCTAMB(5,5),NSYSCP,TDISMX,NSPCCN,UCVALL,AREAC,SPFLCW, 01234
X NH2C,WIDTH,PRPAGR,CAPFAC,USEFAC,TKWHRS,IRITE,IREAD      01235
HRBAC=HRCDF2(I)*TCBASE**2+HRCDF1(I)*TCBASE+HRCDF0(I)    01236
HEATR=HRCDF2(I)*TC**2+HRCDF1(I)*TC+HRCDF0(I)           01237
QREJ=(HEATR-3413.)*PSIZE*CAP(I)*1000.                  01238
DELHR=HEATR-HRBASE                                      01239
DELFC=FUCST*DELHR*1.E-5                                01240
PWCST=FUCST*HEATR*1.E-5+(CCPKW*ANFCR)/(CAPFAC*8.76)   01241
RETURN
END                                         01242
                                         01243

```

```

SUBROUTINE CCND(TCOND,TIN,QREJ,PWCST,DT2,TCUT,UA,FLCW,GPM,
*   SYSCST,CCSPKW)
COMMON PSIZE,CCPKW,ANFCR,FUCST,NCAPS,CAP(6),TCLN(5),
X  CLPCT(5),TCMIN(6),PCMİN(6),TCMAX(6),PCMAX(6),
X  HRCOF2(6),HRCOF1(6),HRCOF0(6),TDB,TWB,RH,TAVH20,TCBASE,
X  NTAMB,AMBDFC(5),AMBOPC(5),TAMDR(5),TAMWB(5),AMRRH(5),
X  TAMRV(5),PCTAMB(5,5),NSYSCP,TDISMX,NSPCON,UCVALL,AREAC,SPFLOW,
X  NH2C,WIDTH,PRPAGR,CAPFAC,USEFAC,TKWHRS,IRITE,IREAD
PMPEF=8
IF(NSPCON.EQ.1) GO TO 30
C          VARIATION OF HEAT TRANSFER COEFFICIENT, UALL, WITH TYPE
C          OF WATER
IF(NH2C)20,10,15
10  UALL=340.
GO TO 25
15  UALL=420.
GO TO 25
20  UALL=250.
25  CONTINUE
DT1=TCOND-TIN
TCUT=TCOND-DT2
DELT=TCUT-TIN
C          ALCG MEAN TEMPERATURE DIFFERENCE, LMTD
DTLGM=(DT1-DELT)/(ALCG(DT1/DT2))
ACOND=QREJ/(DTLGM*UALL)
UA=UALL*ACOND
CONCST=20.*(ACOND*1.05)**.9
C          65 PERCENT INCREASE IN MATERIAL COSTS IF SALT WATER USED
IF(NH2C.LT.0) CONCST=CONCST*1.65
FLCW=QREJ/DELT
GPM=FLCW/(8.34*60.)
C          ASSUME 35 FT OF HEAD
CHEAD=35.
PPCST=(GPM*CHEAD*.7457*PWCST)/(3960.*PMPEF*PSIZE*1000.)
C          1 DOLLAR PER GPM FOR COST OF PUMPS
CCSPKW=(CONCST+1.*GPM)/(PSIZE*1.E3)
SYSCST=(CCSPKW*ANFCR)/(CAPFAC*8.76)+PPCST
GO TO 50
30  UA=UCVALL*AREAC
FLCW=SPFLOW
GPM=FLCW/(8.34*60.)
SYSCST=0.0
50  RETURN
END

```

```

SUBROUTINE PRTDS1(QREJ,TC,HPF,HPP,WEV,WBD,AFLR)          01288
COMMON PSIZE,CCPKW,ANFCR,FUCST,NCAPS,CAP(6),TCTLD(5),COLPCT(5),TC
XMIN(6),PCMIN(6),TCMAX(6),PCMAY(6),HRCCF2(6),HRCCF1(6),HRCCFO(6),
XTDR,TWB,RH,TAVH20,TCBASE,NTAMB,AMBDPC(5),AMRCPC(5),TAMDB(5),TAMW
XB(5),AMBRH(5),TAMRV(5),PCTAMB(5,5),NSYSCP,TDISMX,NSPCON,UCVALL,A
XREAC,SPFLOW,NH20,WIDTH,PRPAGR,CAPFAC,USEFAC,TKWHRS,IRITE,IREAD
WEVCFS=WEV/244700.                                       01294
WBDCTS=WBD/244700.                                       01295
WRITE(IRITE,10)QREJ,TC,HPF,HPP,WEVCFS,WEV,WBDCTS,WBD,AFLR   01296
10  FFORMAT(/,3X,#Q REJECT #,E9.4,# BTU/HR AT T CONDENSER #, F5.0 01297
X.,3X,#FAN PCWER #,E9.4,# HP      PUMP PCWER #,E9.4,# HP#,/,3X,# 01298
#H20 EVAP #,E9.4,# CFS (#,E9.4,# LB/HR)#/                 01299
* * H20 BLCWDWN #,E9.4,# CFS (#,E9.4,# LB/HR)#/            01300
* * AIR FLOW RATE #,E9.4,# LB/HR#)                           01301
RETURN                                                    01302
END                                                       01303

```

```

SUBROUTINE PRTDS2(CAPCOS,CPCOS,COSMAT,SYSCOS,DELFC,TOTCOS,COSPKW)      01304
COMMON PSIZE,CCPKW,ANFCR,FUCST,NCAPS,CAP(6),TOTLn(5),COLPCT(5),TC
XMIN(6),PCMINT(6),TCMAX(6),PCMAX(6),HRCOF2(6),HRCOF1(6),HRCOF0(6),
XTDR,TWB,RH,TAVH2C,TCBASE,NTAMB,AMBDFC(5),AMBOPC(5),TAMDB(5),TAMW
XB(5),AMBRH(5),TAMRV(5),PCTAMB(5,5),NSYSCP,TDISMX,NSPCON,UCVAL,A
XREAC,SPFLCW,NH2C,WIDTH,PRPAGR,CAPFAC,USEFAC,TKWHRS,IWRITE,IREAD
  WRITE(IWRITE,10) CAPCOS,COSPKW,CPCOS,COSMAI,SYSCOS,DELFC,TOTCOS
10 FORMAT(10 CAPITAL COST #,E9.4,# DOLLARS#/# CONDENSER AND PUMP
*CCOST #,E9.4,# DOLLARS/KW#/# OPERATING COST #,
X      F6.3,# MILLS/KW-HR#,/, 3X,#MAINTENANCE COST #,F6.3,# MILLS
X/KW-HR#,/, 3X,#CONDENSEP SYSTEM COST #,F6.3,# MILLS/KW-HR#,/, 3X,
X#DIFFERENTIAL FUEL COST #,F6.3,# MILLS/KW-HR#,/, 3X,# TOTAL SYS
XTEM COST #,F6.3,# MILLS/KW-HR#/)

  RETURN
END

```

```

SUBROUTINE PRTCD(CPCCD,DFCCD,TCOD)          01319
COMMON PSIZE,CCPKW,ANFCR,FUCST,NCAPS,CAP(6),TCTLD(5),COLPCT(5),TC
XMIN(6),PCMINT(6),TCMAX(6),PCMAX(6),HRCOF2(6),HRCOF1(6),HRCOF0(6),
XTDB,TWR,RH,TAVH20,TCBASE,NTAMB,AMBDFC(5),AMBCPC(5),TAMDB(5),TAMW
XB(5),AMBRH(5),TAMRV(5),PCTAMB(5,5),NSYSOP,TDISMX,NSPCON,UCVALL,A
XREAC,SPFLLOW,NH2C,WIDTH,PRPAGR,CAPFAC,USEFAC,TKWHRS,IRITE,IREAD
      WRITE(IRITE,10) CPCCD,DFCCD,TCOD           01325
10   FORMAT(/5X,*WITH THE VARIOUS AMBIENT TEMPERATURES*,/,,
      X 5X,*THE COSTS ARE -*,/,,
      X 3X,*OPERATING COST =*,F6.3,* MILLS/KW-HR*,/,,
      X 3X,*DIFFERENTIAL FUEL COST =*,F6.3,* MILLS/KW-HR*,/,,
      X /,3X,*TOTAL SYSTEM COST =*,F6.3,* MILLS/KW-HR*)
      RETURN                                     01331
      END                                       01332

```

```
FUNCTION H(I)          01333
H =21.572142-,93539227*T+.28365243E-01*T**2 -.26605772E-03*T**3+ 01334
X.12608996E-05*T**4 01335
RETURN               01336
END                  01337
```

```
FUNCTION P(T)
P = .16818166E-1 + .14461089E-2*T + .83460247E-5*T**2 + .4997537E-6
X *T**3 = .20658843E-9*T**4 + .22620224E-10*T**5
RETURN
END
```

01338
01339
01340
01341
01342

DATA SUBD1

200	150	.12	10	1000	5
100	80	60	25	0	
5150	1750	800	700	360	
80	70	50	30	15	
3	3	4	3	3	5
150	100	100	100	100	150
350	400	400	450	450	350
150	250	350			
7987	8037	8153			
100	200	300			
7974	8025	8174			
100	200	300	350		
8055	8195	8430	8543		
100	200	300			
8828	9381	9815			
100	200	300			
0	0	0			
150	200	250	300	350	
8000	8009	8042	8089	8151	
85	75	75	1.5	10	4000
70	80	85			-1
60	70	70			3
60	65	70			
10	10	10			
4000	4000	4000			
25	25	50			
30	30	40			
40	30	30			
50	25	25			
00	00	100			
2000	2	1	85	350	2.76E5
1		1	1	1	4.2E7

DATA SUBD2

200	150	.12	10	1000		
100	80	60	25	0		
5150	1750	800	700	360		
80	70	50	30	15		
3	3	4	3	3	5	
150	100	100	100	100	150	
350	400	400	450	450	350	
150	250	350				
7987	8037	8153				
100	200	300				
7974	8025	8174				
100	200	300	350			
8055	8195	8430	8543			
100	200	300				
8828	9381	9815				
100	200	300				
0	0	0				
150	200	250	300	350		
8000	8009	8042	8089	8151		
85	75	75	1.5	10	4000	0
70	80	85				
60	70	70				
60	65	70				
10	10	10				
4000	4000	4000				
25	25	50				
30	30	40				
40	30	30				
50	25	25				
00	00	100				
2000	0	1		350	2.76E5	4.2E7
1	1	1	1	1		

DATA SUBD3

200	150	.12	10	5000		
100	80	60	25	0	5	
5150	1750	800	700	360		
80	70	50	30	15		
3	3	4	3	3	5	
150	100	100	100	100	150	
350	400	400	450	450	350	
150	250	350				
7987	8037	8153				
100	200	300				
7974	8025	8174				
100	200	300	350			
8055	8195	8430	8543			
100	200	300				
8828	9381	9815				
100	200	300				
0	0	0				
150	200	250	300	350		
8000	8009	8042	8089	8151		
85	75	75	1.5	10	4000	0
70	80	85				3
60	70	70				
60	65	70				
10	10	10				
4000	4000	4000				
25	25	50				
30	30	40				
40	30	30				
50	25	25				
00	00	100				
2000	2	0	85	1	1	
1		1				

DATA SUBD4

200	150	.12	10	5000	5
100	80	60	25	0	
5150	1750	800	700	360	
80	70	50	30	15	
3	3	4	3	3	5
150	100	100	100	100	150
350	400	400	450	450	350
150	250	350			
7987	8037	8153			
100	200	300			
7974	8025	8174			
100	200	300	350		
8055	8195	8430	8543		
100	200	300			
8828	9381	9815			
100	200	300			
0	0	0			
150	200	250	300	350	
8000	8009	8042	8089	8151	
85	75	75	1.5	10	4000
70	80	85			0
60	70	70			
60	65	70			
10	10	10			
4000	4000	4000			
25	25	50			
30	30	40			
40	30	30			
50	25	25			
00	00	100			
2000	0	0			
1	1	1	1	1	1

1	Accession Number	2	Subject Field & Group
			05E
SELECTED WATER RESOURCES ABSTRACTS INPUT TRANSACTION FORM			

5	Organization
	Dynatech R/D Company

6	Title
	"A Survey of Alternate Methods for Cooling Condenser Discharge Water -- System Selection, Design, and Optimization"

10	Author(s)	16	Project Designation
	Smith, N. Maulbetsch, John S.		FWQA Contract 12-14-477 Project # 16130 DHS
		21	Note

22	Citation
	Water Pollution Control Research Series 16130 DHS 01/71

23	Descriptors (Starred First)
	*Power - electric; *Cost analysis; Condensers; *Heat exchangers; *Water cooling; Thermal power; economics

25	Identifiers (Starred First)

27	Abstract
	A computer program is described for calculation of both cooling system and power plant cost and the determination of the minimum total cost for a given set of parameters. To this end the effect of various design parameters have been studied to determine which have significant effects on the performance of the various cooling schemes and which are important to power plant costs. Design equations based on these parameters are incorporated into a computer program through which the minimum total cost is calculated.

This report was submitted in fulfillment of Contract No. 12-14-477 under the sponsorship of the Federal Water Quality Administration. (Rainwater - EPA/WQO)

Abstractor	Frank H. Rainwater	Institution	EPA/WQO/National Thermal Pollution Research Program
WR-102 (REV JULY 1969) WRSIC		SEND TO: WATER RESOURCES SCIENTIFIC INFORMATION CENTER U. S. DEPARTMENT OF THE INTERIOR WASHINGTON, D. C. 20240	