

EPA-600/2-76-048b

March 1976

Environmental Protection Technology Series

**MOLECULAR SIEVE TESTS FOR CONTROL OF
NO_x EMISSIONS FROM A NITRIC ACID PLANT**
Volume II - Appendices



Industrial Environmental Research Laboratory
Office of Research and Development
U.S. Environmental Protection Agency
Research Triangle Park, North Carolina 27711

RESEARCH REPORTING SERIES

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into five series. These five broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and a maximum interface in related fields. The five series are:

1. Environmental Health Effects Research
2. Environmental Protection Technology
3. Ecological Research
4. Environmental Monitoring
5. Socioeconomic Environmental Studies

This report has been assigned to the ENVIRONMENTAL PROTECTION TECHNOLOGY series. This series describes research performed to develop and demonstrate instrumentation, equipment, and methodology to repair or prevent environmental degradation from point and non-point sources of pollution. This work provides the new or improved technology required for the control and treatment of pollution sources to meet environmental quality standards.

EPA REVIEW NOTICE

This report has been reviewed by the U.S. Environmental Protection Agency, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policy of the Agency, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

This document is available to the public through the National Technical Information Service, Springfield, Virginia 22161.

EPA-600/2-76-048b
March 1976

MOLECULAR SIEVE TESTS FOR
CONTROL OF NO_X EMISSIONS FROM A
NITRIC ACID PLANT
VOLUME II--APPENDICES

by

John T. Chehaske and Jonathan S. Greenberg

Engineering-Science, Inc.
7903 Westpark Drive
McLean, Virginia 22101

Contract No. 68-02-1406, Task 2
ROAP No. 21AFA-106
Program Element No. 1AB015

EPA Project Officer: E. J. Wooldridge

Industrial Environmental Research Laboratory
Office of Energy, Minerals, and Industry
Research Triangle Park, NC 27711

Prepared for

U.S. ENVIRONMENTAL PROTECTION AGENCY
Office of Research and Development
Washington, DC 20460

CONTENTS

<u>APPENDIX</u>		<u>Page</u>
A.	Data Reduction Technique with Example Calculations Instantaneous Sieve Flow Rates and NO _x Concentrations from Reduced Strip Chart Data with Calculated Mass Flow Rates, Mass Loadings and Control Efficiencies	1
B.	NO _x Emission Data Reports for EPA Method No. 7 Tests	58
C.	EPA Reference Method No. 7	66
D.	Field Data Log for DuPont 411 Photometric Analyzer	71
E.	Field Data for EPA Method No. 7 Tests	138
F.	Laboratory Report for EPA Method No. 7 Tests and Analytical Report for NO ₂ Calibration Gases	186
G.	Process Data	192

APPENDIX A

DATA REDUCTION TECHNIQUE AND EXAMPLE CALCULATIONS

INSTANTANEOUS SIEVE FLOW RATES AND NO_X CONCENTRATIONS
FROM REDUCED STRIP CHART DATA WITH CALCULATED MASS
FLOW RATES, MASS LOADINGS AND CONTROL EFFICIENCIES

APPENDIX A

The outputs of the UV-visible photometric analyzers used to measure the inlet and outlet NO_2/NO_x concentrations were recorded on strip chart recorders. Separate recorders were used for each of the test sites. Figure A-1 is a copy of the recorded instrument output for inlet test site HV-23 during the first 115 minutes of test 11. Figure A-2 is a copy of the recorded instrument output for outlet test site HV-13 during the same period. Both copies provide the basis for example calculations in this section.

A data reduction technique was used to provide instantaneous sieve inlet and outlet NO_x concentrations at appropriate intervals suitable for application of the trapezoidal rule for integration. The major assumption in the integration method is that concentration changed linearly between the endpoints of an interval, thus it was required that the points defining the intervals be carefully selected. The following method was used for reducing the strip charts.

1. The nearly continuous strip chart records of inlet and outlet NO_2 measurements were converted to continuous form using linear interpolation in order to provide an estimate of the NO_2 concentrations which existed while the analyzers were being operated in either the NO_x or zero modes. First, the zero drift which occurred during the intervals between zeroing of the instruments was distributed over each interval using linear interpolations. The technique was applied by drawing a straight line on the strip chart between the points where the zero baseline was established. This provided an estimate of the instrument zero baseline at any point in time. Second, the NO_2 measurements which were missed as a result of switching the instruments to the NO_x or zero modes were approximated by drawing straight line on the strip chart between points where the NO_2 measurements terminated and started again. Examples of the distribution of zero baseline drift are found between 0700 and 0905 on Figure A-1 and between 0700, 0758

FIGURE A-1. EXAMPLE OF RECORDED NO₂/NO_X STRIP CHART DATA
(FIRST 115 MINUTES OF TEST - 11, INLET SITE HV-23)

-3-





FIGURE A-2. EXAMPLE OF RECORDED NO₂/NO_X STRIP CHART DATA
(FIRST 115 MINUTES OF TEST - 11 OUTLET SITE HV-13)

-4-



and 0853 on Figure A-2. Examples of the estimation of NO₂ measurements during periods when the analyzers were either in the zero or NO_x mode are found from 0715 to 0720 and 0730 to 0735 on Figure A-1 and from 0750 to 0802 on Figure A-2.

2. Points were selected for reading NO₂ concentrations from the recorded charts at appropriate intervals for use of the trapezoidal rule. The points selected included, but were not limited to all points which corresponded to the beginning of each NO_x measurement. Each point was carefully selected so that the contour of the strip chart trace could be approximated by a series of straight lines connecting the points. The location of points selected in the example are identified by vertical lines with corresponding times drawn on the strip charts.

3. For each point selected on the strip chart traces, the time and the percent of chart values for the zero baseline and NO₂ measurements were determined and copied on to a data reduction worksheet. Figure A-3 is a copy of the data reduction worksheet used for test 11. The times corresponding to each point appear in column 2. NO₂ percent of chart values for the inlet trace appear in column 3 and the zero baseline values in column 4. Outlet NO₂ and zero baseline percent of chart values appear in column 9 and 10 respectively.

4. The difference between each NO₂ percent of chart value and the corresponding zero baseline value was calculated. These values appear in columns 5 and 11 on the worksheet. NO₂ concentrations were calculated using the appropriate range factors. For the inlet instrument, the factor was 50 ppm of NO₂ per percent of chart, for the outlet instrument the factor was 5 ppm of NO₂ per percent of chart.

5. The percent of chart values for each of the NO_x measurements and the corresponding zero baseline values were determined and copied onto the worksheet. The NO_x determinations on the worksheet are identified by the mode identification in column 1. For

FIGURE A-3. EXAMPLE DATA REDUCTION WORKSHEET

TEST - 11

DATE 3/17/75 HERCULES INC., RUN 11, INLET HV-23, OUTLET HV-13 UNIT A 0711-1114

OUTLET																			
Column	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
Mode	Time	TRACE % OF CHART	BASELINE % OF CHART	DIFFERENCE	PPM NO ₂	PPM NO _x	% NO ₂	TRACE % OF CHART	BASELINE % OF CHART	DIFFERENCE	PPM NO ₂	PPM NO _x	% NO ₂	ELAPSED TIME	SAMPLE FLOW	REGEN FLOW	PPM NO ₂ IN	PPM NO ₂ OUT	
NO ₂	0711	63.75	20.0	43.75	2188	/ / /	65.4	68.25	30.25	38.0	190.0	/ / /	/ / /	0	5500	1020	3340	190	
NO ₂	0714	63.5	20.0	43.5	2175	/ / /	65.4	40.5	30.5	18.0	1900	/ / /	/ / /	3	5500	1020	3320	90	
NO ₂	0715	64.0	20.0	44.0	2200	/ / /	(65.4)	47.0	30.5	16.5	82.5	/ / /	/ / /	4	5500	1015	3360	82	
NO _x	0715	87.25	67.25	3362	/ / /	/ / /	/ / /	/ / /	/ / /	/ / /	/ / /	/ / /	/ / /						
NO ₂	0717	63.0	20.0	43.0	2150	/ / /	65.0	46.0	30.5	15.5	77.5	/ / /	/ / /	6	5500	1015	3310	78	
NO ₂	0725	61.0	20.25	40.75	2038	/ / /	63.2	53.0	30.5	22.5	112.5	/ / /	/ / /	14	5475	1020	3220	112	
NO ₂	0726	61.0	20.25	40.75	2038	/ / /	63.0	55.25	30.5	24.75	123.75	/ / /	/ / /	15	5475	1020	3220	124	
NO ₂	0730	62.25	20.25	42.0	2100	/ / /	(62.0)	51.0	30.75	20.25	101.25	/ / /	/ / /	19	5450	1020	3380	101	
NO _x	0730	88.0	67.75	3388	/ / /	/ / /	/ / /	/ / /	/ / /	/ / /	/ / /	/ / /	/ / /						
NO ₂	0734	63.0	20.25	42.75	2138	/ / /	63.1	47.0	30.75	16.25	81.25	/ / /	/ / /	23	5450	1020	3390	81	
NO ₂	0745	63.75	20.5	43.25	2162	/ / /	(65.8)	43.75	31.0	12.75	63.75	/ / /	/ / /	34	5475	1020	3290	64	
NO _x	0745	86.25	65.75	3288	/ / /	/ / /	/ / /	/ / /	/ / /	/ / /	/ / /	/ / /	/ / /						
NO ₂	0750	64.0	20.5	43.5	2175	/ / /	66.3	43.25	31.0	12.25	61.25	/ / /	(48)	39	5475	1020	3280	61	
NO _x	0800	64.5	20.5	44.0	2200	/ / /	(67.4)	41.5	30.0	11.50	57.50	/ / /	/ / /	44	5475	1020	3260	58	
NO ₂	0810	64.0	20.5	43.5	2175	/ / /	68.0	41.5	30.0	11.50	57.50	/ / /	/ / /	59	5475	1020	3200	58	

the inlet test site, the NO_x measurements were made approximately every ten minutes for five minute intervals. On Figure A-1 the beginnings of the NO_x measurements occur at 0715, 0730, 0745 and 0800. The percent of chart values on the worksheet appear in columns 3 and 4 below the NO_2 values for the same times. For the outlet test site, the NO_x measurements were made approximately once an hour due to the absence of NO in the outlet stream. On Figure A-2 the beginning of an NO_x measurement occurs at 0750. The percent of chart values for the NO_x measurements were read at the end of each 5 minute NO_x determination, after the complete oxidation of NO to NO_2 in the sealed sample cell had occurred.

6. The difference between each NO_x percent of chart value and the corresponding zero baseline value was calculated, and the NO_x concentrations were determined in the same manner as in step 4. The different values appear in columns 5 and 11, and the concentrations appear in column 7 and 13 on the worksheet.

7. The percent NO_2 in each NO_x measurement was calculated from the ratio of the NO_2 measured at the beginning of each NO_x measurement to the NO_x measured. The calculated percents appear as the circled values in columns 8 and 14 on the worksheet. The percent NO_2 for each point where no corresponding NO_x measurement existed was calculated by interpolating between known NO_x percent values. For the inlet test site, the calculated values appear as uncircled values in column 8 of the worksheet.

8. The inlet NO_2 concentrations which appear in column 6 on the worksheet were converted to NO_x concentrations using the calculated percent NO_2 in column 8. The calculated values for the inlet appear in column 18. The outlet NO_x concentrations appearing in column 19 were calculated from the outlet NO_2 concentrations in column 12 using an NO_2 to NO_x ratio of 1.0. (The average ratio of NO_2 to NO_x at the outlet test sites during the eleven cycles was 0.999 with a standard deviation of .040. The variations about the mean were due to a combination of instrumental, recorder and chart reading imprecision.)

9. The inlet flows into the sieve and the flows diverted for regeneration (regeneration flow) were read from copies of process instrument charts for the respective times. All times were converted to elapsed time with reference to the beginning of each cycle. These values appear in columns 15, 16 and 17 on the worksheet.

10. The data appearing in columns 15 through 19 for each of the eleven cycles was keypunched and read into a computer program which produced the outputs presented in this section, Tables A-1 through A-31. An example calculation for the first 4 minutes of test cycle 11 with an explantion of each parameter preceeds the output tables.

EXAMPLE CALCULATIONS
FOR
TABLE A-31

The first five columns of Table A-31 contain the reduced strip chart data that was read into the computer program. The columns are:

TIME INTO CYCLE - (TIC) - The elapsed time from the beginning of an adsorption cycle. Units: minutes.

INLET FLOW - (IF) - The flow rate of the tail gas stream into the adsorbing bed. Units: standard cubic feet per minute.

REGEN FLOW - (RF) - The flow rate of the cleaned tail gas stream which is diverted after leaving the adsorption bed for regenerations of the second bed. Units: standard cubic feet per minute.

INLET CONC - (IC) - The concentration of NO_x in the inlet stream to the adsorption bed. For test cycles 1 through 8 this represents the NO_x concentration at site HV-12, after the feed chiller and mist eliminator. For test cycles 9-11, this represents the NO_x concentrations at HV-23. Units: parts per million.

OUTLET CONC - (OC) - The concentration of the NO_x in the outlet stream after passing through the adsorption bed. For test cycles 1 through 11 this represents the NO_x concentrations at site HV-13.

The last seven columns are calculated instantaneous mass flow rates and control efficiencies. The columns are:

MASS FLOW RATE IN - (MFRI) - The NO_x mass flow rate into the adsorption bed. This value is calculated as follows:

$$\text{MFRI} = \text{IF} \times \text{IC} \times C$$

where C is the conversion factor for converting ppm ft^3 at 15.556°C (60°F) and 760 millimeters of mercury pressure to grams of NO_x as NO_2 (M.W. = 46)

$$C = \frac{46 \text{ gm mole}^{-1}}{22.414 \text{ l mole}^{-1} \times \frac{288.716^\circ\text{K}}{273.15^\circ\text{K}}} \times 10^{-6} \text{ ppm}^{-1} \times 28.316 \text{ l ft}^{-3}$$

$$= 5.49815 \times 10^{-5} \text{ gm ppm}^{-1} \text{ ft}^{-3}$$

Example Calculation, Test 11

TIC (min)	MFRI (gm min ⁻¹)	IF (ft ³ min ⁻¹)	IC (ppm)	C (gm ppm ⁻¹ ft ⁻³)
0	1010.010	5500	3340	5.49815×10^{-5}
3	1003.962	5500	3320	5.49815×10^{-5}
4	1016.058	5500	3360	5.49815×10^{-5}

MASS FLOW RATE ADS - (MFRA) - The instantaneous mass flow rate at which NO_x is absorbed by the molecular sieve bed. This value is calculated as follows:

$$\text{MFRA} = \text{IF} \times (\text{IC}-\text{OC}) \times C$$

Example Calculation, Test 11

TIC (min)	MFRA (gm min ⁻¹)	IF (ft ³ min ⁻¹)	IC (ppm)	OC (ppm)	C (gm ppm ⁻¹ ft ⁻³)
0	952.554	5500	3340	190	5.49815×10^{-5}
3	976.746	5500	3320	90	5.49815×10^{-5}
4	991.261	5500	3360	82	5.49815×10^{-5}

MASS FLOW RATE REGEN - (MFRR) - The instantaneous mass flow rate of the NO_x diverted for the regeneration of the second bed. This value is calculated as follows:

$$\text{MFRR} = \text{RF} \times \text{OC} \times C$$

Example Calculation, Test 11

TIC (min)	MFRR (gm min ⁻¹)	RF (ft ³ min ⁻¹)	OC (ppm)	C (gm ppm ⁻¹ ft ⁻³)
0	10.655	1020	190	5.49815×10^{-5}
3	5.047	1020	90	5.49815×10^{-5}
4	4.576	1015	82	5.49815×10^{-5}

MASS FLOW RATE EMIT - (MFRE) - The instantaneous mass flow rate of NO_x emitted to the atmosphere from the stack outlet. This value is calculated as follows:

$$MFRE = MFRI - MFRA - MFRR$$

Example Calculation, Test 11

TIC (min)	MFRE (gm min ⁻¹)	MFRI (gm min ⁻¹)	MFRA (gm min ⁻¹)	MFRR (gm min ⁻¹)
0	46.801	1010.010	952.554	10.655
3	22.169	1003.962	976.746	5.047
4	20.221	1016.058	991.261	4.576

% REDUC OF NO_X DUE TO ADS - (RDTA) - The percentage of the instantaneous NO_x removal efficiency of the PuraSiv N unit due to adsorption. This value is calculated as follows:

$$\% RDTA = (MFRA \div MFRI) \times 100$$

Example Calculation, Test 11

TIC (min)	% RDTA (%)	MFRA (gm min ⁻¹)	MFRI (gm min ⁻¹)
0	94.3113	952.554	1010.010
3	97.2891	976.746	1003.962
4	97.5594	991.261	1016.058

% REDUC OF NO_X DUE TO REGEN - (% RDTR) - The percentage of the instantaneous NO_X removal efficiency of the PuraSiv N unit due to regeneration. This value is calculated as follows:

$$\% \text{ RDTR} = (\text{FMRR} \div \text{MFRI}) \times 100$$

Example Calculation, Test 11

TIC (min)	% RDTR (%)	MFRR (gm min ⁻¹)	MFRI (gm min ⁻¹)
0	1.0549	10.655	1010.010
3	0.5027	5.047	1003.962
4	0.4504	4.576	1016.058

% REDUC OF NO_X - (%R) - The instantaneous NO_X removal efficiency of the PuraSiv N unit. This value is calculated as follows:

$$\% R = \% \text{ RDTA} + \% \text{ RDTR}$$

Example Calculation, Test 11

TIC (min)	% R (%)	% RDTA (%)	% RDTR (%)
0	95.366	94.311	1.055
3	97.792	97.289	0.503
4	98.009	97.559	0.450

EXAMPLE CALCULATIONS

FOR

TABLE A-32

The first column contains the time interval of the cycle for which the calculations pertain. The next eight columns are calculated NO_x mass loadings and average control efficiencies for each interval. The last column lists the average ppm emitted during each interval. The columns are:

NO_x IN DURING INTERVAL - (NIDI) - The mass of NO_x which enters the inlet to the adsorption bed during the designated interval (a,b). This value is calculated as follows:

$$\text{NIDI} = ((\text{MFRI}(a) + \text{MFRI}(b)) \times (b-a)) \div 2$$

Example Calculation, Test 11

INT (a,b)	NIDI (gm)	MFRI(a) (gm min ⁻¹)	MFRI(b) (gm min ⁻¹)	(b-a) (min)
0,3	3020.958	1010.010	1003.962	3
3,4	1010.010	1003.962	1016.058	1

NO_x ABSORBED DURING INTERVAL - (NADI) - The mass of NO_x which is adsorbed by the adsorption bed during the designated interval (a,b). This value is calculated as follows:

$$\text{NADI} = ((\text{MFRA}(a) + \text{MFRA}(b)) \times (b-a)) \div 2$$

Example Calculation, Test 11

INT (a,b)	NIDI (gm)	MFRI(a) (gm min ⁻¹)	MFRI(b) (gm min ⁻¹)	(b-a) (min)
0,3	2893.950	952.554	976.746	3
3,4	984.004	976.746	991.261	1

NO_x REGEN DURING INTERVAL - (NRDI) - The mass of NO_x which is diverted during the regeneration of the second bed during the designated interval (a,b). This value is calculated as follows:

$$NRDI = ((MFRR(a) + MFRR(b)) \times (b-a)) \div 2$$

Example Calculation, Test 11

INT (a,b)	NRDI (gm)	MFRR(a) (gm min ⁻¹)	MFRR(b) (gm min ⁻¹)	(b-a) (min)
0,3	23.553	10.655	5.047	3
3,4	4.811	5.047	4.576	1

NO_X EMITTED DURING INTERVAL - (NEDI) - The mass of NO_x emitted to the atmosphere from the stack outlet during the interval (a,b).

This value is calculated as follows:

$$NEDI = NIDI - NADI - NRDI$$

Example Calculation, Test 11

INT (a,b)	NEDI (gm)	NIDI (gm)	NADI (gm)	NRDF (gm)
0,3	103.455	3020.958	2893.950	23.553
3,4	21.194	1010.010	984.004	4.812

PERCENT OF NO_X ADSORBED DURING INTERVAL - (% ADI) - The percentage of the NO_x removal efficiency due to adsorption during the interval (a,b). This value is calculated as follows:

$$\% ADI = (NADI \div NIDI) \times 100$$

Example Calculation, Test 11

INT (a,b)	% ADI (%)	NADI (gm)	NIDI (gm)
0,3	95.796	2893.950	3020.958
3,4	97.425	984.004	1010.010

PERCENT NO_x FOR REGEN DURING INTERVAL - (%RDI) - The percentage of the NO_x removal efficiency due to regeneration during the interval (a,b). This value is calculated as follows:

$$\% \text{ RDI} = (\text{NRDI} \div \text{NIDI}) \times 100$$

Example Calculation, Test 11

INT (a,b)	% RDI (%)	NRDI (gm)	NIDI (gm)
0,3	0.780	23.553	3020.958
3,4	0.476	4.812	1010.010

PERCENT REDUCTION OF NO_x DURING INTERVAL - (% RI) - The NO_x removal efficiency of the PuraSiv N unit during the interval (a,b). This value is calculated as follows:

$$\% \text{ RI} = \% \text{ NADI} + \% \text{ NFRDI}$$

Example Calculation, Test 11

INT (a,b)	% RI (%)	% NADI (%)	% NFRDI (%)
0,3	96.576	95.796	0.780
3,4	97.901	97.425	0.476

AVERAGE PPM OF NO_x EMIT DURING INTERVAL - (APPM) - The average concentrations of NO_x emitted to the atmospheric from the stack outlet during the interval (a,b). This value is calculated as follows:

$$\text{APPM} = (\text{OC}(a) + \text{OC}(b)) \div 2$$

Example Calculation, Test 11

INT (a,b)	APPM (ppm)	OC(a) (ppm)	OC(b) (ppm)
0,3	140	190	90
3,4	86	90	82

EXAMPLE CALCULATIONS
FOR
TABLE A-33

The first column contains the elapsed time from the beginning of the cycle. Columns 2 through 5 contains the cumulative mass loadings which occurred from the beginning of the cycle to the time indicated. Columns 6 through 8 contain the average NO_x reductions achieved over the indicated time period. Column 9 contains the average ppm of NO_x emitted from the beginning of the cycle to the indicated time. The columns are:

TOTAL NO_x IN - (TNI) - The total mass of NO_x which entered the adsorption bed from the beginning of the cycle to the indicated time (TIC). This value is calculated as follows:

$$TNI = \sum_0^{TIC} NIDI$$

Example Calculation, Test 11

TIC (min)	INT (min)	TNI (gm)	NIDI (gm)
3	(0,3)	3020.958	3020.958
4	(3,4)	4030.968	1010.010

TOTAL NO_x ADS - (TNA) - The total mass of NO_x adsorbed molecular sieve bed from the beginning of the cycle to the indicated time. This value is calculated as follows:

$$TNA = \sum_0^{TIC} NADI$$

Example Calculation, Test 11

TIC (min)	INT (min)	TNA (gm)	NADI (gm)
3	0,3	2893.950	2893.950
4	3,4	3877.954	984.004

TOTAL NO_X USED FOR REGEN - (TNR) - The total mass of NO_x diverted for the regeneraton of the second bed from the beginning of the cycle to the indicated time. This value is calculated as follows:

$$TNR = \sum_{0}^{TIC} NRDI$$

Example Calculation, Test 11

TIC (min)	INT (min)	TNR (gm)	NRDI (gm)
3	0,3	23.553	23.553
4	3,4	28.364	4.811

TOTAL NO_X EMITTED - (TNE) - The total mass of NO_x emitted to the atmosphere from the stack outlet from the beginning of the cycle to the indicated time. This value is calculated as follows:

$$TNE = \sum_{0}^{TIC} NEDI$$

Example Calculation, Test 11

TIC (min)	INT (min)	TNE (gm)	NEDI (gm)
3	0,3	103.455	103.455
4	3,4	124.649	21.199

% NO_X REDUC DUE TO ADS - (% NRDIA) - The percentage of the average NO_x removal efficiency due to adsorption from the beginning of the cycle to the indicated time. This value is calculated as follows:

$$\% NRDIA = TNA \div TNI \times 100$$

Example Calculation, Test 11

TIC (min)	% NRDIA (%)	TNA (gm)	TNI (gm)
3	95.795	2893.950	3020.958
4	96.204	3877.954	4030.968

% NO_X REDUC DUE TO REGEN - (%NRDTR) - The percentage of the average NO_X removal efficiency due to regeneration from the beginning of the cycle to the indicated time. This value is calculated as follows:

$$\% \text{ NRDTR} = \text{TNUFR} \div \text{TNI} \times 100$$

Example Calculation, Test 11

TIC (min)	% NRDTR (%)	TNUFR (gm)	TNI (gm)
3	0.780	23.553	3020.958
4	0.703	28.364	4030.968

AVG % REDUC OF NO_X - (A % R) - The average NO_X removal efficiency of the PuraSiv N unit from the beginning of the cycle to the indicated time. This value is calculated as follows:

$$A \% R = \% \text{ NRDTR} + \% \text{ NRDTR}$$

Example Calculation, Test 11

TIC (min)	A % R (%)	% NRDTR (%)	% NRDTR (%)
3	96.575	95.795	0.780
4	96.907	96.204	0.703

AVG PPM OF NO_X EMIT DURING INTERVAL - (APPME) - The average concentration of NO_X emitted to the atmosphere from the stack outlet, from the beginning of the cycle to the indicated time. This value is calculated as follows:

$$\text{APPME} = (\sum (b-a) \times \text{APPM}) \div \text{TIC}$$

Example Calculation, Test 11

TIC (min)	APPME (ppm)	(a,b) (min)	(b-a) (min)	APPM (ppm)
3	140.0	0,3	3	140
4	126.5	3,4	1	86

TABLE A-1. SUMMARY OF CALCULATED NO_X MASS FLOW RATES AND
CONTROL EFFICIENCIES FOR INSTANTANEOUS FLOW
AND CONCENTRATION DATA FOR TEST -- 1

HERCULES INC., RUN 1, INLET HV-12, OUTLET HV-13, UNIT B, 1412-1800 3/5/75

TIME INTD CYCLE (MIN)	INLET FLDW (SCFM)	REGEN. FLDW (SCFM)	INLET CUNC. (PPM)	OUTLET CONC. (PPM)	RATE IN (G/MIN)	MASS FLOW (G/MIN)	MASS FLOW (G/MIN)	MASS FLOW (G/MIN)	MASS FLOW (G/MIN)	% REDUC. OF NOX DUE TO ADS.	% REDUC. OF NOX DUE TO REGEN.	% REDUC. OF NOX ADS.
0.0	5625	1025	2090	166	646.4	595.0	9.36	41.98	92.06	1.45	93.50	
3.0	5975	1025	2080	92	683.3	653.1	5.18	25.04	95.58	0.76	96.34	
6.0	5975	1020	2080	80	683.3	657.0	4.49	21.79	95.15	0.66	96.81	
18.0	5975	1020	2020	109	663.6	627.8	6.11	29.70	94.60	0.92	95.53	
23.0	5975	1020	2020	84	663.6	636.0	4.71	22.88	95.84	0.71	96.55	
33.0	5975	1025	1980	65	650.5	629.1	3.66	17.69	95.72	0.56	97.28	
38.0	5950	1025	2070	70	677.2	654.3	3.94	18.95	96.62	0.58	97.20	
42.0	5950	1025	2200	64	719.7	698.8	3.61	17.33	97.09	0.50	97.59	
49.0	5950	1025	2670	75	873.5	848.9	4.23	20.31	97.19	0.48	97.67	
56.0	5975	1025	2800	79	919.8	893.9	4.45	21.50	97.18	0.48	97.66	
64.0	5975	1025	2550	81	837.7	811.1	4.56	22.04	96.82	0.54	97.37	
68.0	5975	1025	2600	81	854.1	827.5	4.56	22.04	96.88	0.53	97.42	
78.0	5700	1025	2660	84	833.6	807.3	4.73	21.59	95.84	0.57	97.41	
83.0	5675	1025	2660	86	830.0	803.1	4.85	21.99	96.77	0.58	97.35	
93.0	5675	1025	2650	89	826.9	799.1	5.02	22.75	96.64	0.61	97.25	
98.0	5675	1025	2650	91	826.9	798.5	5.13	23.27	96.57	0.62	97.19	
103.0	5675	1025	2680	95	836.2	806.5	5.35	24.29	95.46	0.64	97.10	
113.0	5675	1025	2690	99	839.3	808.4	5.58	25.31	96.32	0.66	96.98	
123.0	5675	1025	2660	95	830.0	800.3	5.35	24.29	96.43	0.65	97.07	
133.0	5650	1025	2600	114	807.7	772.3	6.42	28.99	95.62	0.80	96.41	
143.0	5675	1025	2770	118	864.3	827.5	6.65	30.17	95.74	0.77	96.51	
153.0	5650	1025	2930	130	910.2	869.8	7.33	33.06	95.56	0.80	96.37	
158.0	5650	1025	2900	135	900.9	858.9	7.61	34.33	95.34	0.84	95.19	
168.0	5625	1025	2750	141	850.5	806.9	7.95	35.66	94.87	0.93	95.81	
173.0	5625	1025	2700	142	835.0	791.1	8.00	35.91	94.74	0.96	95.70	
183.0	5750	1025	2650	151	837.8	790.3	8.51	39.23	94.30	1.02	95.32	
188.0	5650	1025	2650	155	823.2	775.1	8.74	39.41	94.15	1.06	95.21	
198.0	5675	1025	2610	161	814.4	764.1	9.07	41.16	93.83	1.11	94.95	
205.0	5700	1025	2650	170	830.5	777.2	9.58	43.70	93.58	1.15	94.74	
213.0	5700	1025	2680	174	839.9	785.4	9.81	44.72	93.51	1.17	94.67	
218.0	5675	1025	2660	179	830.0	774.1	10.09	45.76	93.27	1.22	94.49	
228.0	5650	1025	2640	185	820.1	762.6	10.43	47.04	92.99	1.27	94.26	

TABLE A-2. SUMMARY OF NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED FOR INTERVALS DURING TEST -- 1

HERCULES INC., RJN 1, INLET HV-12, OUTLET HV-13, UNIT B, 1412-1800 3/5/75

INTERVAL OF CYCLE (MIN)	NOX IN DURING INTERVAL (GRAMS)	NOX ADSORBED DURING INTERVAL (GRAMS)	NOX REGEN. DURING INTERVAL (GRAMS)	NOX EMITTED DURING INTERVAL (GRAMS)	PERCENT OF NOX ADSORBED DURING INTERVAL	PERCENT NOX FOR REGEN. DURING INTERVAL	PERCENT REDUC. OF NOX DURING INTERVAL	AVERAGE PPM OF NOX EMIT. DURING INTERVAL
0.0- 3.0	1994.5	1872.2	21.81	100.53	93.87	1.09	94.96	128
3.0- 8.0	3416.5	3275.3	24.18	117.08	95.87	0.71	96.57	86
8.0- 18.0	6734.5	6424.1	53.00	257.45	95.39	0.79	96.18	95
18.0- 23.0	3318.0	3159.5	27.06	131.45	95.22	0.82	96.04	97
23.0- 33.0	6570.3	6325.5	41.87	202.87	96.27	0.64	96.91	75
33.0- 38.0	3319.1	3208.5	19.02	91.61	96.67	0.57	97.24	67
38.0- 42.0	2793.8	2706.1	15.10	72.57	96.86	0.54	97.40	67
42.0- 49.0	5576.1	5416.9	27.42	131.74	97.15	0.49	97.64	70
49.0- 56.0	6276.6	6099.9	30.38	146.33	97.18	0.48	97.67	77
56.0- 64.0	7030.2	6820.0	36.07	174.18	97.01	0.51	97.52	80
64.0- 68.0	3383.7	3277.3	18.26	88.18	96.85	0.54	97.39	81
68.0- 78.0	8438.8	8174.2	46.49	218.18	96.86	0.55	97.41	82
78.0- 83.0	4159.0	4026.1	23.95	108.95	96.80	0.58	97.38	85
83.0- 93.0	8284.1	8011.1	49.31	223.71	96.70	0.60	97.30	87
93.0- 98.0	4134.3	3993.9	25.36	115.05	96.60	0.61	97.22	90
93.0-108.0	8315.3	8029.1	52.41	237.77	96.51	0.63	97.14	93
108.0-113.0	4188.9	4037.5	27.33	124.00	96.39	0.65	97.04	97
113.0-123.0	8346.5	8043.9	54.67	247.99	96.37	0.65	97.03	97
123.0-138.0	12282.4	11794.5	88.34	399.58	96.03	0.72	96.75	104
133.0-143.0	4179.9	3999.3	32.69	147.89	95.68	0.78	96.46	116
143.0-153.0	8872.4	8486.4	69.88	316.13	95.65	0.79	96.44	124
153.0-158.0	4527.7	4321.8	37.34	168.47	95.45	0.82	96.28	133
158.0-168.0	8756.8	8329.1	77.77	349.95	95.12	0.89	96.00	138
168.0-173.0	4213.8	3995.0	39.87	178.94	94.81	0.95	95.75	141
173.0-183.0	8364.1	7905.8	82.56	375.71	94.52	0.99	95.51	147
183.0-188.0	4152.5	3912.8	43.11	196.61	94.23	1.04	95.27	153
188.0-198.0	8187.9	7696.0	89.04	402.88	93.99	1.09	95.08	158
198.0-205.0	5757.0	5394.7	65.29	297.00	93.71	1.13	94.84	166
205.0-213.0	6681.6	6250.3	77.55	353.68	93.55	1.16	94.71	172
213.0-218.0	4174.7	3898.7	49.73	226.22	93.39	1.19	94.58	176
218.0-228.0	8250.4	7683.8	102.57	464.04	93.13	1.24	94.38	182

TABLE A-3. CUMULATIVE NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED DURING TEST -- 1

HERCULES INC., RUN 1, INLET HV-12, OUTLET HV-13, UNIT B, 1412-1800 3/5/75

TIME INTO CYCLE (MIN)	TOTAL NOX IN (GRAMS)	TOTAL NOX ADS. (GRAMS)	USED FOR REGEN. (GRAMS)	TOTAL NOX EMIT. (GRAMS)	% NOX REDUC. DUE TO ADS.	% NOX REDUC. DUE TO REGEN.	Avg. % REDUC. OF NOX	Avg. PPM

0								
3.0	1994.5	1872.2	21.8	100.5	93.87	1.09	94.96	128
8.0	5411.1	5147.5	46.0	217.6	95.13	0.85	95.98	101
18.0	12145.6	11571.6	99.0	475.1	95.27	0.81	96.09	97
23.0	15463.6	14731.1	126.0	606.5	95.26	0.82	96.08	97
33.0	22033.9	21056.6	167.9	809.4	95.56	0.76	96.33	90
38.0	25353.0	24265.1	186.9	901.0	95.71	0.74	96.45	87
42.0	28146.8	26971.2	202.0	973.6	95.82	0.72	96.54	85
49.0	33722.9	32388.1	229.5	1105.3	96.04	0.68	96.72	83
56.0	39999.4	38487.9	259.8	1251.6	96.22	0.65	96.87	82
64.0	47029.6	45307.9	295.9	1425.8	96.34	0.63	96.97	82
68.0	50413.3	48585.2	314.2	1514.0	96.37	0.62	97.00	82
78.0	58852.1	56759.3	360.7	1732.2	96.44	0.61	97.06	82
83.0	63011.1	60785.4	384.6	1841.1	96.47	0.61	97.08	82
93.0	71295.3	68796.5	433.9	2064.8	96.50	0.61	97.10	83
98.0	75429.5	72790.4	459.3	2179.9	96.50	0.61	97.11	83
108.0	83744.9	80815.5	511.7	2417.6	96.50	0.61	97.11	84
113.0	87933.7	84853.1	539.0	2541.6	96.50	0.61	97.11	85
123.0	96289.3	92896.9	593.7	2789.6	96.49	0.62	97.10	86
138.0	108562.6	104691.4	682.0	3189.2	96.43	0.63	97.06	88
143.0	112742.5	108690.7	714.7	3337.1	96.41	0.63	97.04	88
153.0	121615.0	117177.2	784.6	3653.2	96.35	0.65	97.00	91
158.0	126142.6	121499.0	821.9	3821.7	96.32	0.65	96.97	92
168.0	154899.5	129828.1	899.7	4171.7	96.24	0.67	96.91	95
173.0	139113.3	133823.1	939.6	4350.6	96.20	0.68	96.87	96
183.0	147477.3	141728.9	1022.1	4726.3	96.10	0.69	96.80	99
188.0	151629.8	145641.7	1065.2	4922.9	96.05	0.70	96.75	100
193.0	159817.7	153337.6	1154.3	5325.8	95.95	0.72	96.67	103
205.0	165574.7	158732.4	1219.6	5622.8	95.87	0.74	96.60	105
213.0	172256.3	164982.7	1297.1	5976.5	95.78	0.75	96.53	108
218.0	176431.0	168881.4	1346.9	6202.7	95.72	0.76	96.48	109
228.0	184681.4	176565.2	1449.4	6666.7	95.61	0.78	96.39	112

TABLE A-4. SUMMARY OF CALCULATED NO_X MASS FLOW RATES AND
CONTROL EFFICIENCIES FOR INSTANTANEOUS FLOW
AND CONCENTRATION DATA FOR TEST -- 2

HERCULES INC., RUN 2, INLET HV-12, OUTLET HV-13, UNIT B, 1010-1408 3/6/75

TIME INTD CYCLE (4IN)	INLET FLDw (SCFM)	REGEN. FLCW (SCFM)	INLET CNC. (PPM)	OUTLET CNC. (PPM)	MASS FLOW RATE (G/MIN)	MASS FLOW RATE (G/MIN)	MASS FLOW RATE (G/MIN)	MASS FLOW RATE (G/MIN)	z REDUC. OF NOX ADS.	z REDUC. OF NOX REGEN.	z REDUC. OF NOX ADS.
3.0	5750	1050	2470	141	730.9	736.3	8.14	36.44	94.29	1.04	95.33
2.0	5575	1055	2430	41	744.8	732.3	2.38	10.19	98.31	0.32	98.63
5.0	5575	1055	2410	62	738.7	719.7	3.60	15.41	97.43	0.49	97.91
10.0	5575	1055	2630	90	806.2	778.6	5.22	22.37	96.58	0.65	97.23
12.0	5575	1055	2670	85	818.4	792.4	4.93	21.12	96.82	0.60	97.42
20.0	5675	1055	2680	74	836.2	813.1	4.29	18.80	97.24	0.51	97.75
30.0	5725	1055	2630	50	827.8	812.1	2.90	12.84	99.10	0.35	98.45
35.0	5725	1055	2680	49	843.6	828.2	2.84	12.58	98.17	0.34	98.51
40.0	5725	1055	2710	49	853.0	837.6	2.84	12.58	98.19	0.33	98.53
45.0	5725	1055	2650	50	834.1	818.4	2.90	12.84	98.11	0.35	98.46
50.0	5725	1055	2770	52	871.9	855.5	3.02	13.35	98.12	0.35	98.47
55.0	5725	1050	2820	54	887.6	870.7	3.12	13.88	98.09	0.35	98.44
58.0	5725	1050	2870	56	903.4	885.8	3.23	14.39	98.05	0.36	98.41
62.0	5725	1050	3043	61	957.8	938.6	3.52	15.68	98.00	0.37	98.36
65.0	5725	1050	3100	61	975.8	956.6	3.52	15.68	98.03	0.36	98.39
70.0	5725	1050	3180	71	1001.0	978.6	4.10	18.25	97.77	0.41	98.18
78.0	5725	1050	3300	82	1038.7	1012.9	4.73	21.08	97.52	0.46	97.97
80.0	5725	1050	3260	85	1026.1	999.4	4.91	21.85	97.39	0.48	97.87
85.0	5725	1045	3310	90	1041.9	1013.6	5.17	23.16	97.28	0.50	97.78
89.0	5725	1050	3440	96	1082.8	1052.6	5.54	24.68	97.21	0.51	97.72
95.0	5725	1050	3390	104	1067.1	1034.3	6.00	26.73	96.93	0.56	97.49
110.0	5725	1040	3220	125	1013.6	974.2	7.15	32.20	95.12	0.71	96.82
115.0	5725	1040	3150	130	991.5	950.6	7.43	33.49	95.87	0.75	96.62
120.0	5725	1040	3100	135	975.8	933.3	7.72	34.77	95.65	0.79	96.44
125.0	5725	1035	3100	139	975.8	932.0	7.91	35.84	95.52	0.81	96.33
130.0	5725	1025	3120	145	982.1	936.4	8.17	37.47	95.35	0.83	96.18
135.0	5725	1025	3280	154	1032.4	984.0	8.68	39.80	95.30	0.84	96.15
140.0	5725	1030	3350	171	1054.5	1000.6	9.68	44.14	94.90	0.92	95.81
150.0	5700	1025	3300	188	1034.2	975.3	10.59	48.32	94.30	1.02	95.33
152.0	5700	1025	3300	185	1034.2	976.2	10.43	47.55	94.39	1.01	95.40
155.0	5725	1025	3310	195	1041.9	980.5	10.99	50.39	94.11	1.05	95.16
160.0	5725	1025	3360	204	1057.6	993.4	11.50	52.72	93.93	1.09	95.02
165.0	5725	1025	3380	215	1063.9	996.2	12.12	55.56	93.64	1.14	94.78
170.0	5700	1025	3300	232	1034.2	961.5	13.07	59.63	92.97	1.26	94.23
176.0	5675	1040	3360	238	1048.4	974.1	13.61	60.65	92.92	1.30	94.21
185.0	5650	1045	3480	253	1081.0	1002.5	14.54	64.06	92.73	1.34	94.07
190.0	5625	1045	3320	268	1026.8	943.9	15.40	67.49	91.93	1.50	93.43
193.0	5625	1050	3000	275	927.8	842.8	15.88	69.17	90.83	1.71	92.54
200.0	5650	1050	2990	274	928.8	843.7	15.82	69.30	90.84	1.70	92.54
205.0	5650	1055	2980	272	925.7	841.2	15.78	68.72	90.87	1.70	92.58
210.0	5625	1055	2970	274	918.5	833.8	15.89	68.85	90.77	1.73	92.50
215.0	5625	1055	2960	276	915.4	830.1	16.01	69.35	90.68	1.75	92.42
220.0	5625	1055	3030	279	937.1	850.8	16.18	70.10	90.79	1.73	92.52
230.0	5625	1055	3120	288	964.9	875.9	16.71	72.36	90.77	1.73	92.50
235.0	5625	1055	2970	290	918.5	828.8	16.82	72.87	90.24	1.83	92.07
238.0	5625	1055	2910	291	900.0	810.0	16.88	73.12	90.00	1.88	91.88

TABLE A-5. SUMMARY OF NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED FOR INTERVALS DURING TEST -- 2

HERCULES INC., RUN 2, INLET HV-12, DUTLET HV-13, UNIT B, 1010-1408 3/6/75

INTERVAL OF CYCLE (MIN)	NOX IN DURING INTERVAL (GRAMS)	NOX ADSORBED DURING INTERVAL (GRAMS)	NOX REGEN. DURING INTERVAL (GRAMS)	NOX EMITTED DURING INTERVAL (GRAMS)	PERCENT OF NOX ADSORBED DURING INTERVAL	PERCENT NOX FOR REGEN. DURING INTERVAL	PERCENT OF NOX EMITTED DURING INTERVAL	AVERAGE PPM OF NOX EMIT.
0.0- 2.0	1525.7	1468.6	10.52	46.63	96.25	3.69	96.94	92
2.0- 5.0	2225.3	2178.0	8.96	38.40	97.87	0.40	98.27	51
5.0- 10.0	3862.2	3745.7	22.04	94.44	96.98	0.57	97.55	76
10.0- 12.0	1624.6	1570.9	10.15	43.49	96.70	0.62	97.32	88
12.0- 20.0	6619.5	6421.9	36.89	159.68	97.03	0.56	97.59	79
20.0- 30.0	8320.3	8126.1	35.96	158.18	97.67	0.43	98.10	62
30.0- 35.0	4178.6	4100.6	14.36	63.55	98.14	0.34	98.48	49
35.0- 40.0	4241.5	4164.4	14.21	62.91	98.18	0.34	98.52	49
40.0- 45.0	4217.9	4140.0	14.36	63.55	98.15	0.34	98.49	49
45.0- 50.0	4265.1	4184.9	14.79	65.47	98.12	0.35	98.46	51
50.0- 55.0	4398.9	4315.5	15.33	68.08	98.10	0.35	98.45	53
55.0- 58.0	2686.6	2634.6	9.53	42.41	98.07	0.35	98.42	55
58.0- 62.0	3722.5	3648.8	13.51	60.15	98.02	0.36	98.38	59
62.0- 65.0	2900.4	2842.8	10.56	47.04	98.01	0.36	98.38	61
65.0- 70.0	4941.9	4838.0	19.05	84.82	97.90	0.39	98.28	66
70.0- 78.0	8158.8	7966.2	35.33	157.31	97.64	0.43	98.07	77
78.0- 80.0	2064.9	2012.3	9.64	42.93	97.45	0.47	97.92	83
80.0- 85.0	5170.1	5032.4	25.20	112.52	97.34	0.49	97.82	88
85.0- 89.0	4249.4	4132.3	21.43	95.67	97.24	0.50	97.75	93
89.0- 95.0	6449.6	6260.8	34.64	154.22	97.07	0.54	97.61	100
95.0-110.0	15604.7	15064.0	98.64	441.98	96.54	0.63	97.17	115
110.0-115.0	5012.7	4812.0	36.45	164.21	96.00	0.73	96.72	128
115.0-120.0	4919.3	4709.7	37.88	170.65	95.76	0.77	96.53	133
120.0-125.0	4878.9	4663.3	39.07	176.54	95.58	0.80	96.38	137
125.0-130.0	4894.7	4671.2	40.20	183.28	95.43	0.82	96.26	142
130.0-135.0	5035.3	4801.0	42.13	193.16	95.33	0.84	96.16	150
135.0-140.0	5217.3	4961.5	45.91	209.84	95.10	0.88	95.98	162
140.0-150.0	11443.4	9879.7	101.39	462.32	94.60	0.97	95.57	179
150.0-152.0	2068.4	1951.5	21.02	95.88	94.35	1.02	95.36	187
152.0-155.0	3114.1	2935.1	32.12	146.91	94.25	1.03	95.28	190
155.0-160.0	5248.8	4934.8	56.22	257.77	94.02	1.07	95.09	199
160.0-165.0	5303.9	4974.1	59.03	270.69	93.78	1.11	94.90	210
165.0-170.0	5245.3	4894.3	62.98	287.98	93.31	1.20	94.51	223
170.0-176.0	6247.3	5806.9	80.05	360.85	92.94	1.28	94.22	235
176.0-185.0	9582.4	8894.6	126.65	561.19	92.82	1.32	94.14	245
185.0-190.0	5259.6	4865.9	74.84	328.86	92.34	1.42	93.76	260
190.0-198.0	7818.4	7146.6	125.10	546.64	91.41	1.60	93.01	271
198.0-200.0	1856.6	1686.5	31.69	138.47	90.83	1.71	92.54	274
200.0-205.0	4636.4	4212.3	78.99	345.04	90.85	1.70	92.56	273
205.0-210.0	4610.6	4187.6	79.18	343.91	90.82	1.72	92.54	273
210.0-215.0	4584.9	4159.7	79.76	345.49	90.73	1.74	92.46	275
215.0-220.0	4631.3	4202.2	80.48	348.63	90.73	1.74	92.47	278
220.0-230.0	9510.1	8633.3	164.45	712.34	90.78	1.73	92.51	283
230.0-235.0	4708.6	4261.7	83.82	363.08	90.51	1.78	92.29	289
235.0-238.0	2727.8	2458.2	50.55	218.98	90.12	1.85	91.97	290

TABLE A-6. CUMULATIVE NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED DURING TEST -- 2

HERCULES INC., RUN 2, INLET HV-12, OUTLET HV-13, UNIT B, 1010-1408 3/6/75

TIME INTD CYCLE (MIN)	TOTAL NOX IN (GRAMS)	TOTAL NOX ADS. (GRAMS)	NOX USED FOR REGEN. (GRAMS)	TOTAL NOX EMIT. (GRAMS)	% NOX REDUC. DUE TO ADS.	% NOX REDUC. DUE TO REGEN.	Avg. % OF NOX	Avg. PPM
0								
2.0	1525.7	1468.6	10.5	46.6	96.25	0.69	96.94	92
5.0	3751.1	3646.6	19.5	85.0	97.21	0.52	97.73	68
10.0	7613.2	7392.3	41.5	179.5	97.10	0.55	97.64	72
12.0	9237.8	8963.2	51.7	222.9	97.03	0.56	97.59	75
20.0	15856.3	15385.1	88.6	382.6	97.03	0.56	97.59	76
30.0	24178.6	23511.3	124.5	540.8	97.25	0.52	97.76	72
35.0	28355.1	27611.9	138.9	604.4	97.38	0.49	97.87	68
40.0	32596.7	31776.3	153.1	667.3	97.48	0.47	97.95	66
45.0	36814.6	35916.3	167.5	730.8	97.56	0.45	98.01	64
50.0	41079.7	40101.1	182.2	796.3	97.62	0.44	98.06	63
55.0	45478.6	44416.6	197.6	864.4	97.66	0.43	98.10	62
58.0	48165.1	47051.2	207.1	906.8	97.69	0.43	98.12	61
62.0	51887.6	50700.0	220.6	966.9	97.71	0.43	98.14	61
65.0	54788.0	53542.9	231.2	1014.0	97.73	0.42	98.15	61
70.0	59729.9	58380.9	250.2	1098.8	97.74	0.42	98.16	62
78.0	67888.7	66347.0	285.6	1256.1	97.73	0.42	98.15	63
80.0	69953.6	68359.4	295.2	1299.0	97.72	0.42	98.14	64
85.0	75123.6	73391.7	320.4	1411.5	97.69	0.43	98.12	65
89.0	79373.0	77524.0	341.8	1507.2	97.67	0.43	98.10	66
95.0	85822.6	83784.8	376.5	1661.4	97.63	0.44	98.06	68
110.0	10127.3	98848.8	475.1	2103.4	97.46	0.47	97.93	75
115.0	116440.0	103660.8	511.5	2267.6	97.39	0.48	97.87	77
120.0	111358.3	108370.6	549.4	2438.3	97.32	0.49	97.81	79
125.0	116237.2	113033.9	588.5	2614.8	97.24	0.51	97.75	82
130.0	121131.8	117705.0	628.7	2798.1	97.17	0.52	97.69	84
135.0	126163.1	122506.0	670.8	2991.3	97.10	0.53	97.63	87
140.0	131385.4	127467.6	716.7	3201.1	97.02	0.55	97.56	89
150.0	141828.8	137347.2	818.1	3663.4	96.84	0.58	97.42	95
152.0	143897.2	139296.7	839.2	3759.3	96.80	0.58	97.39	97
155.0	147011.3	142233.8	871.3	3906.2	96.75	0.59	97.34	98
160.0	152260.1	147168.6	927.5	4164.0	96.66	0.61	97.27	102
165.0	157564.0	152142.8	986.5	4434.7	96.56	0.63	97.19	105
170.0	162809.3	157037.1	1049.5	4722.6	96.45	0.64	97.10	108
176.0	169057.0	162344.0	1129.6	5083.5	96.32	0.67	96.99	113
185.0	178639.5	171738.6	1256.2	5644.7	96.14	0.70	96.84	119
190.0	183939.0	176604.4	1331.0	5973.6	96.03	0.72	96.75	123
193.0	191727.4	183751.1	1456.1	6520.2	95.84	0.76	96.60	129
200.0	193584.0	185437.5	1487.8	6658.7	95.79	0.77	96.56	130
205.0	198220.4	189649.9	1566.8	7003.7	95.68	0.79	96.47	134
210.0	202931.1	193837.4	1646.0	7347.6	95.57	0.81	96.38	137
215.0	207416.0	197997.1	1725.8	7693.1	95.46	0.83	96.29	140
220.0	212047.3	202199.3	1806.2	8041.7	95.36	0.85	96.21	143
230.0	221557.4	210832.6	1970.7	8754.1	95.16	0.89	96.05	149
235.0	226266.0	215094.4	2054.5	9117.2	95.06	0.91	95.97	152
238.0	228993.8	217552.6	2105.1	9336.1	95.00	0.92	95.92	154

TABLE A-7. SUMMARY OF CALCULATED NO_X MASS FLOW RATES AND
CONTROL EFFICIENCIES FOR INSTANTANEOUS FLOW
AND CONCENTRATION DATA FOR TEST -- 3

MERCULES INC., RUN 3, INLET HV-12, OUTLET HV-13, UNIT A 1408-1812 3/6/75

TIME INTO CYCLE (MIN)	INLET FLOW (SCFM)	REGEN. FLOW (SCFM)	INLET CONC. (PPM)	OUTLET CONC. (PPM)	MASS FLOW RATE (G/MIN)	MASS FLOW RATE (G/MIN)	MASS FLOW RATE (G/MIN)	MASS FLOW RATE (G/MIN)	% REDUC. OF NOX ADS.	% REDUC. OF NOX DUE TO REGEN.	% REDUC. OF NOX ADS.
0.0	5625	1055	2910	291	900.0	810.0	16.88	73.12	90.00	1.88	91.88
6.0	5875	1045	2800	168	904.4	850.2	9.65	44.61	94.00	1.07	95.07
7.0	5875	1045	2910	161	940.0	888.0	9.25	42.76	94.47	0.98	95.45
12.0	5875	1040	2830	186	904.4	844.4	10.64	49.45	93.36	1.18	94.53
22.0	5850	1040	2820	126	907.0	866.5	7.20	33.32	95.53	0.79	96.33
27.0	5850	1040	2840	160	913.5	862.0	9.15	42.31	94.37	1.00	95.37
37.0	5850	1040	2820	89	907.0	878.4	5.09	23.54	96.84	0.56	97.41
42.0	5850	1040	2870	86	923.1	895.4	4.92	22.74	97.00	0.53	97.54
47.0	5850	1040	2900	82	932.8	906.4	4.69	21.69	97.17	0.50	97.68
52.0	5850	1040	2920	82	939.2	912.8	4.69	21.69	97.19	0.50	97.69
57.0	5850	1035	3060	84	984.2	957.2	4.78	22.24	97.25	0.49	97.74
67.0	5850	1035	3350	90	1077.5	1048.6	5.12	23.83	97.31	0.48	97.79
72.0	5850	1035	3480	92	1119.3	1089.7	5.24	24.36	97.36	0.47	97.82
82.0	5825	1035	3520	104	1127.3	1094.0	5.92	27.39	97.05	0.52	97.57
87.0	5850	1035	3420	108	1100.0	1065.3	6.15	28.59	96.84	0.56	97.40
97.0	5850	1035	3350	114	1077.5	1047.8	6.49	30.18	96.60	0.60	97.20
102.0	5875	1035	3320	116	1072.4	1034.9	6.60	30.87	96.51	0.62	97.12
112.0	5850	1035	3450	122	1109.7	1070.4	6.94	32.30	96.46	0.63	97.09
117.0	5875	1035	3360	129	1085.3	1043.7	7.34	34.33	95.16	0.68	96.84
123.0	5875	1035	3340	139	1078.9	1034.0	7.91	36.99	95.84	0.73	96.57
132.0	5875	1035	3280	142	1059.5	1013.6	8.08	37.79	95.67	0.76	96.43
144.0	5850	1035	3190	155	1026.0	976.2	8.82	41.03	95.14	0.86	95.00
147.0	5850	1035	3160	156	1016.4	966.2	8.88	41.30	95.06	0.87	95.94
157.0	5825	1020	3100	164	992.8	940.3	9.20	43.33	94.71	0.93	95.64
162.0	5825	1020	3080	170	986.4	932.0	9.53	44.91	94.48	0.97	95.45
172.0	5825	1020	3080	174	986.4	930.7	9.76	45.97	94.35	0.99	95.34
177.0	5825	1015	3040	178	973.6	916.6	9.93	47.07	94.14	1.02	95.17
182.0	5125	1050	3020	172	851.0	802.5	9.93	38.54	94.30	1.17	95.47
187.0	3425	1050	2420	168	455.7	424.1	9.70	21.94	93.06	2.13	95.19
192.0	3425	930	1970	162	371.0	340.5	8.28	22.22	91.78	2.23	94.01
197.0	3425	930	1060	164	199.6	168.7	8.39	22.50	84.53	4.20	88.73
202.0	3500	930	2000	148	384.9	356.4	7.57	20.91	92.60	1.97	94.57
206.0	2700	930	1510	308	224.2	178.4	15.75	29.97	79.60	7.03	86.63
207.0	2700	1125	1380	274	204.9	164.2	16.95	23.73	80.14	8.27	88.42
209.0	2700	1125	1100	156	163.3	140.1	9.65	13.51	85.82	5.91	91.73
212.0	4130	1050	750	148	169.1	135.7	8.54	24.82	80.27	5.05	85.32
217.0	5750	1020	1200	131	379.4	338.0	7.35	34.07	89.08	1.94	91.02
222.0	5125	1040	1560	138	439.6	400.7	7.89	30.99	91.15	1.80	92.95
232.0	5550	1030	2250	130	686.6	646.9	7.36	32.31	94.22	1.07	95.29
244.0	5450	1030	2580	150	773.1	728.1	8.49	36.45	94.19	1.10	95.28

TABLE A-8. SUMMARY OF NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED FOR INTERVALS DURING TEST -- 3

HERCULES INC., RUN 3, INLET HV-12, OUTLET HV-13, UNIT A 1408-1812 3/6/75

INTERVAL OF CYCLE (MIN)	NOX IN DURING INTERVAL (GRAMS)	NJX ADSORBED DURING INTERVAL (GRAMS)	NOX REGEN. DURING INTERVAL (GRAMS)	NOX EMITTED DURING INTERVAL (GRAMS)	PERCENT OF NOX ADSORBED DURING INTERVAL	PERCENT NOX FOR REGEN. DURING INTERVAL	PERCENT REDUC. DURING INTERVAL	AVERAGE PPM OF NOX EMIT. DURING INTERVAL
0.0- 6.0	5413.3	4980.5	79.60	353.20	92.00	1.47	93.48	228
6.0- 7.0	922.2	869.1	9.45	43.68	94.24	1.02	95.26	165
7.0- 12.0	4611.1	4330.8	49.71	230.50	93.92	1.08	95.00	174
12.0- 22.0	9057.4	8554.3	89.20	413.84	94.45	0.98	95.43	156
22.0- 27.0	4551.2	4321.3	40.88	189.09	94.95	0.90	95.85	143
27.0- 37.0	9102.5	8702.0	71.19	329.25	95.60	0.78	96.38	124
37.0- 42.0	4575.3	4434.6	25.02	115.70	96.92	0.55	97.47	87
42.0- 47.0	4639.7	4504.6	24.02	111.07	97.09	0.52	97.61	84
47.0- 52.0	4679.9	4548.0	23.44	108.43	97.18	0.50	97.68	82
52.0- 57.0	4838.5	4675.1	23.67	109.81	97.22	0.49	97.72	83
57.0- 67.0	10309.6	10028.8	49.51	230.32	97.29	0.48	97.77	87
67.0- 72.0	5492.0	5345.7	25.89	120.45	97.34	0.47	97.81	91
72.0- 82.0	11233.3	10918.8	55.77	258.73	97.23	0.50	97.70	98
82.0- 87.0	5568.4	5398.3	30.16	139.95	96.95	0.54	97.49	106
87.0- 97.0	10887.6	10530.5	63.17	293.86	96.72	0.58	97.30	111
97.0-102.0	5374.9	5189.4	32.72	152.62	96.55	0.61	97.16	115
102.0-112.0	10910.4	10526.8	67.72	315.83	96.48	0.62	97.11	119
112.0-117.0	5487.5	5285.2	35.71	166.57	96.31	0.65	96.96	126
117.0-128.0	11903.1	11427.0	83.88	392.25	96.00	0.70	96.70	134
128.0-132.0	4276.7	4095.2	31.98	149.55	95.76	0.75	96.50	141
132.0-144.0	12513.2	11938.8	101.41	472.93	95.41	0.81	96.22	148
144.0-147.0	3063.6	2913.6	26.55	123.50	95.10	0.87	95.97	155
147.0-157.0	10046.1	9532.6	90.37	423.13	94.89	0.90	95.79	160
157.0-162.0	4948.1	4680.7	46.83	220.60	94.60	0.95	95.54	167
162.0-172.0	9864.2	9313.4	96.46	454.40	94.42	0.98	95.39	172
172.0-177.0	4900.1	4618.3	49.23	232.61	94.25	1.00	95.25	176
177.0-182.0	4561.5	4297.8	49.66	214.03	94.22	1.09	95.31	175
182.0-187.0	3266.7	3066.5	49.07	151.19	93.87	1.50	95.37	171
187.0-192.0	2066.7	1911.4	44.96	110.40	92.48	2.18	94.66	165
192.0-197.0	1426.5	1273.0	41.67	111.80	89.24	2.92	92.16	163
197.0-212.0	1461.2	1312.8	39.88	108.53	89.84	2.73	92.57	156
202.0-208.0	1218.1	1069.7	46.63	101.77	87.82	3.83	91.64	213
205.0-207.0	214.5	171.3	16.35	26.85	79.86	7.62	87.48	292
207.0-209.0	368.2	304.3	26.60	37.24	82.66	7.22	89.89	215
209.0-212.0	498.5	413.8	27.29	57.49	82.99	5.47	88.47	151
212.0-217.0	1371.1	1184.2	39.73	147.22	86.37	2.90	89.26	138
217.0-222.0	2047.4	1846.6	38.09	162.66	90.19	1.86	92.06	134
222.0-232.0	5633.8	5238.0	76.26	316.51	93.02	1.35	94.38	134
232.0-244.0	8758.1	8250.4	95.14	412.56	94.20	1.09	95.29	140

TABLE A-9. CUMULATIVE NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED DURING TEST -- 3

HERCULES INC., RUN 3, INLET HV-12, OUTLET HV-13, UNIT A 1408-1812 3/6/75

TIME INTO CYCLE (MIN)	TOTAL NOX IN (GRAMS)	TOTAL NOX ADS. (GRAMS)	NOX USED FOR REGEN. (GRAMS)	TOTAL NOX EMIT. (GRAMS)	% REDUC. DUE TO ADS.	% REDUC. DUE TO REGEN.	Avg. % OF NOX	Avg. % OF NOX EMIT.	PPM
<hr/>									
0									
6.0	5413.3	4980.5	79.6	353.2	92.00	1.47	93.48	228	
7.0	6335.5	5849.5	89.0	396.9	92.33	1.41	93.74	219	
12.0	10946.5	10180.4	138.8	627.4	93.00	1.27	94.27	200	
22.0	20303.9	18734.7	228.0	1041.2	93.66	1.14	94.79	180	
27.0	24555.1	23056.0	268.8	1230.3	93.89	1.09	94.99	173	
37.0	33657.6	31758.0	340.0	1559.6	94.36	1.01	95.37	160	
42.0	38232.9	36192.6	365.1	1675.3	94.66	0.95	95.62	151	
47.0	42872.6	40697.2	389.1	1786.3	94.93	0.91	95.83	144	
52.0	47552.5	45245.2	412.5	1894.8	95.15	0.87	96.02	138	
57.0	52361.0	49920.3	436.2	2004.6	95.34	0.83	96.17	133	
67.0	62669.6	59949.0	485.7	2234.9	95.66	0.78	96.43	126	
72.0	68161.7	65294.7	511.6	2355.4	95.79	0.75	96.54	124	
82.0	79394.9	76213.5	567.4	2614.1	95.99	0.71	96.71	121	
87.0	84963.3	81611.8	597.5	2754.0	96.06	0.70	96.76	120	
97.0	95850.9	92142.3	660.7	3047.9	96.13	0.69	96.82	119	
102.0	101225.7	97331.7	693.4	3200.5	96.15	0.69	96.84	119	
112.0	112136.0	107858.6	761.1	3516.3	96.19	0.68	96.86	119	
117.0	117623.5	113143.8	796.8	3682.9	96.19	0.68	96.87	119	
123.0	129526.7	124570.8	880.7	4075.2	96.17	0.68	96.85	120	
128.0	133803.4	128666.0	912.7	4224.7	96.16	0.68	96.84	121	
144.0	146316.6	140604.9	1014.1	4697.6	96.10	0.69	96.79	123	
147.0	149330.2	143518.4	1040.6	4821.1	96.08	0.70	96.77	124	
157.0	159426.3	153051.0	1131.0	5244.3	96.00	0.71	96.71	126	
162.0	164374.4	157731.7	1177.8	5464.9	95.96	0.72	96.68	127	
172.0	174238.6	167045.1	1274.3	5919.3	95.87	0.73	96.60	130	
177.0	179138.7	171663.3	1323.5	6151.9	95.83	0.74	96.57	131	
182.0	183700.2	175961.1	1373.2	6365.9	95.79	0.75	96.53	132	
187.0	186966.9	179027.6	1422.3	6517.1	95.75	0.76	96.51	133	
192.0	189033.6	180938.9	1467.2	6627.5	95.72	0.78	96.49	134	
197.0	190460.1	182211.9	1508.9	6739.3	95.67	0.79	96.46	134	
202.0	191921.3	183524.7	1548.8	6847.8	95.62	0.81	96.43	134	
206.0	193139.4	184594.4	1595.4	6949.6	95.58	0.83	96.40	135	
207.0	193353.9	184765.7	1611.8	6976.4	95.56	0.83	96.39	135	
209.0	193722.0	185070.0	1638.4	7013.7	95.53	0.85	96.38	136	
212.0	194220.6	185463.8	1665.6	7071.2	95.50	0.86	96.36	136	
217.0	195591.7	186667.9	1705.4	7218.4	95.44	0.87	96.31	136	
222.0	197639.0	188514.5	1743.5	7381.0	95.38	0.88	96.27	136	
232.0	203269.8	193752.6	1819.7	7697.5	95.32	0.90	96.21	136	
244.0	212027.9	202002.9	1914.9	8110.1	95.27	0.90	96.17	136	

TABLE A-10. SUMMARY OF CALCULATED NO_X MASS FLOW RATES AND
CONTROL EFFICIENCIES FOR INSTANTANEOUS FLOW
AND CONCENTRATION DATA FOR TEST -- 4

HERCULES INC., RUN 4, INLET HV-12, OUTLET HV-13, UNIT B 0850-1255 3/7/75

TIME INTJ CYCLE (4IN)	INLET FLOW (SCFM)	REGEN. FLOW (SCFM)	INLET CONC. (PPM)	OUTLET CONC. (PPM)	RATE (G/MIN)	MASS FLOW (G/MIN)	MASS FLOW (G/MIN)	MASS FLOW (G/MIN)	% REDUC. OF NOX DUE TO ADS.	% REDUC. OF NOX DUE TO REGEN.	% REDUC. OF NOX DUE TO NOX
0.0	5700	1015	2780	68	871.2	849.9	3.79	17.52	97.55	0.44	97.99
5.0	5700	1015	2760	18	865.0	859.3	1.00	4.64	99.35	0.12	99.46
12.0	5700	1015	2760	75	865.0	841.5	4.19	19.32	97.28	0.48	97.77
25.0	5700	1015	2800	68	877.5	856.2	3.79	17.52	97.57	0.43	98.00
35.0	5700	1015	2500	58	783.5	765.3	3.24	14.94	97.68	0.41	98.09
40.0	5700	1015	2440	58	764.7	746.5	3.24	14.94	97.62	0.42	98.05
50.0	5700	1015	2510	58	786.6	768.4	3.24	14.94	97.69	0.41	98.10
55.0	5700	1015	2600	59	814.8	796.3	3.29	15.20	97.73	0.40	98.13
60.0	5700	1010	2730	62	855.6	836.1	3.44	15.99	97.73	0.40	98.13
70.0	4500	1010	3030	66	749.7	733.3	3.67	12.66	97.82	0.49	98.31
75.0	4450	1000	2320	68	567.6	551.0	3.74	12.90	97.07	0.66	97.73
80.0	4450	1020	1830	65	447.7	431.8	3.65	12.26	95.45	0.81	97.26
82.0	4450	1020	1640	64	401.3	385.6	3.59	12.07	96.10	0.89	96.99
85.0	4475	1020	1610	60	396.1	381.4	3.36	11.40	96.27	0.85	97.12
90.0	4500	1020	1600	56	395.9	382.0	3.14	10.71	96.50	0.79	97.29
97.0	4500	1020	1560	54	336.0	372.6	3.03	10.33	96.54	0.78	97.32
100.0	5625	965	1360	50	420.6	405.1	2.65	12.81	96.32	0.63	96.95
110.0	5675	1000	2970	61	926.7	907.7	3.35	15.68	97.95	0.36	98.31
115.0	5675	1015	3900	74	1216.9	1193.8	4.13	18.96	98.10	0.34	98.44
120.0	5675	1010	4070	86	1269.9	1243.1	4.78	22.06	97.89	0.38	98.26
130.0	5700	1010	4080	109	1278.6	1244.5	6.05	28.11	97.33	0.47	97.80
137.0	5700	1010	4180	121	1310.0	1272.1	6.72	31.20	97.11	0.51	97.62
145.0	5700	1010	4150	138	1330.6	1257.3	7.66	35.59	95.67	0.59	97.26
150.0	5700	1010	4140	149	1297.5	1250.8	8.27	38.42	96.40	0.64	97.04
160.0	5725	1010	3980	162	1252.8	1201.8	9.00	42.00	95.93	0.72	96.65
165.0	5725	1010	3670	175	1155.2	1100.1	9.72	45.37	95.23	0.84	96.07
175.0	5725	1010	3390	179	1067.1	1010.7	9.94	46.40	94.72	0.93	95.65
180.0	5725	1010	3500	181	1101.7	1044.7	10.05	46.92	94.83	0.91	95.74
190.0	5750	1010	3680	198	1163.4	1100.8	11.00	51.60	94.62	0.95	95.56
205.0	5775	1010	3910	222	1241.5	1171.0	12.33	58.16	94.32	0.99	95.32
210.0	5775	1010	3730	232	1184.3	1110.7	12.88	60.78	93.78	1.09	94.87
220.0	5775	1010	3310	238	1051.0	975.4	13.22	62.35	92.81	1.26	94.07
235.0	5800	1010	3260	242	1039.6	962.4	13.44	63.73	92.58	1.29	93.87
245.0	5800	1010	3310	249	1055.5	976.1	13.83	65.58	92.48	1.31	93.79

TABLE A-11. SUMMARY OF NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED FOR INTERVALS DURING TEST -- 4

HERCULES INC., RUN 4, INLET HV-12, OUTLET HV-13, UNIT B 0850-1255 3/7/75

INTERVAL OF CYCLE (MIN)	NOX IN (GRAMS)	NOX ADSORBED DURING INTERVAL	NOX REGEN. DURING INTERVAL	NOX EMITTED DURING INTERVAL	PERCENT OF NOX ADSORBED	PERCENT NOX FOR REGEN.	PERCENT REDUC. OF NOX	AVERAGE PPM OF NOX EMIT.
	(GRAMS)	(GRAMS)	(GRAMS)	(GRAMS)	INTERVAL	INTERVAL	INTERVAL	INTERVAL
0.0- 5.0	4340.5	4273.1	12.00	55.38	98.45	0.28	98.72	43
5.0- 12.0	6054.8	5952.8	18.16	83.84	98.32	0.30	98.62	46
12.0- 25.0	11326.1	11034.8	51.87	239.43	97.43	0.46	97.89	71
25.0- 35.0	8305.0	8107.5	35.16	162.28	97.62	0.42	98.05	63
35.0- 40.0	3870.4	3779.5	16.18	74.70	97.65	0.42	98.07	58
40.0- 50.0	7756.5	7574.7	32.37	149.40	97.66	0.42	98.07	58
50.0- 55.0	4003.6	3911.9	16.32	75.34	97.71	0.41	98.12	59
55.0- 60.0	4176.0	4081.2	16.84	77.96	97.73	0.40	98.13	61
60.0- 70.0	8026.2	7847.4	35.54	143.26	97.77	0.44	98.22	64
70.0- 75.0	3293.3	3210.8	18.51	63.91	97.50	0.56	98.06	67
75.0- 80.0	2538.4	2457.1	18.46	62.89	96.80	0.73	97.52	67
80.0- 82.0	849.0	817.4	7.23	24.33	96.28	0.85	97.13	64
82.0- 85.0	1196.1	1150.4	10.43	35.20	96.18	0.87	97.06	62
85.0- 90.0	1980.1	1908.4	16.26	55.28	96.39	0.82	97.21	58
90.0- 97.0	2735.4	2641.2	21.59	73.66	96.52	0.79	97.31	55
97.0-100.0	1209.9	1166.6	8.52	34.71	96.43	0.70	97.13	52
100.0-110.0	6736.5	6564.0	30.03	142.45	97.44	0.45	97.89	56
110.0-115.0	5358.9	5253.6	18.71	86.60	98.03	0.35	98.38	67
115.0-120.0	6217.0	6092.2	22.26	102.54	97.99	0.36	98.35	80
120.0-130.0	12742.9	12437.9	54.14	250.83	97.61	0.42	98.03	98
130.0-137.0	9063.2	8807.9	44.70	207.58	97.22	0.49	97.71	115
137.0-145.0	10442.3	10117.6	57.53	267.15	96.89	0.55	97.44	129
145.0-155.0	6495.1	6270.2	39.84	185.02	96.54	0.61	97.15	144
150.0-160.0	12751.2	12262.7	86.35	402.09	96.17	0.68	96.85	156
160.0-166.0	7223.9	6935.7	56.14	262.09	95.59	0.78	96.37	169
166.0-175.0	10003.2	9498.8	88.46	412.97	94.99	0.88	95.87	177
175.0-180.0	5421.9	5138.6	49.98	233.31	94.78	0.92	95.70	180
180.0-190.0	11325.5	10727.6	105.23	492.62	94.72	0.93	95.65	190
190.0-205.0	18035.8	17038.6	174.92	823.22	94.47	0.97	95.44	210
205.0-210.0	6064.6	5704.2	63.03	297.35	94.06	1.04	95.10	227
210.0-220.0	11176.6	10430.5	130.50	615.67	93.32	1.17	94.49	235
220.0-235.0	15679.3	14533.7	199.91	945.65	92.69	1.28	93.97	240
235.0-245.0	10475.6	9692.7	136.33	646.55	92.53	1.30	93.83	246

TABLE A-12. CUMULATIVE NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED DURING TEST -- 4

HERCULES INC., RUN 4, INLET HV-12, OUTLET HV-13, UNIT 8 0850-1255 3/7/75

TIME INT. CYCLE (MIN)	TOTAL NOX (GRAMS)	TOTAL NOX (GRAMS)	NOX USED FOR ADDS. REGEN.	TOTAL NOX (GRAMS)	% REDUC. DUE TO ADS.	% REDUC. DUE TO REGEN.	Avg. OF REDUC.	Avg. PPM OF NOX EMIT.
.....								
0								
5.0	4340.5	4273.1	12.0	55.4	98.45	0.28	98.72	43
12.0	10395.3	10225.9	30.2	139.2	98.37	0.29	98.66	45
25.0	21721.4	21260.7	82.0	378.7	97.88	0.38	98.26	59
35.0	30026.3	29368.2	117.2	540.9	97.81	0.39	98.20	60
40.0	33896.7	33147.7	133.4	615.6	97.79	0.39	98.18	60
50.0	41653.2	40722.5	165.7	765.0	97.77	0.40	98.16	59
55.0	45656.9	44634.4	182.1	840.4	97.76	0.40	98.16	59
60.0	49832.8	48715.6	198.9	918.3	97.76	0.40	98.16	59
70.0	57859.0	56563.0	234.4	1061.6	97.76	0.41	98.17	60
75.0	61152.3	59773.8	253.0	1125.5	97.75	0.41	98.16	60
80.0	63690.7	62230.9	271.4	1188.4	97.71	0.43	98.13	61
82.0	64539.7	63048.3	278.7	1212.7	97.69	0.43	98.12	61
85.0	65735.8	64198.8	289.1	1247.9	97.66	0.44	98.10	61
90.0	67715.3	66107.2	305.3	1303.2	97.62	0.45	98.08	61
97.0	70452.2	68748.4	326.9	1376.9	97.58	0.46	98.05	60
100.0	71662.1	69915.0	335.5	1411.6	97.56	0.47	98.03	60
110.0	78393.6	76479.1	365.5	1554.0	97.55	0.47	98.02	60
115.0	83757.5	81732.7	384.2	1640.6	97.58	0.46	98.04	60
120.0	89974.5	87824.9	406.5	1743.2	97.61	0.45	98.06	61
130.0	102717.4	100262.8	460.6	1994.0	97.61	0.45	98.06	64
137.0	111777.6	109070.7	505.3	2201.6	97.58	0.45	98.03	67
145.0	122219.9	119188.3	562.8	2468.7	97.52	0.46	97.98	70
150.0	128715.0	125458.6	602.7	2653.8	97.47	0.47	97.94	73
160.0	141466.2	137721.3	689.0	3055.8	97.35	0.49	97.84	78
160.0	148690.1	144627.0	745.2	3317.9	97.27	0.50	97.77	82
175.0	153690.3	154125.8	833.6	3730.9	97.12	0.53	97.65	87
180.0	164112.2	159264.4	883.6	3964.2	97.05	0.54	97.58	90
190.0	175437.7	169992.0	988.8	4456.8	96.90	0.56	97.46	95
205.0	193474.5	187030.6	1163.8	5280.0	96.67	0.60	97.27	104
210.0	199539.1	192734.9	1226.8	5577.4	96.59	0.61	97.20	107
220.0	210715.7	203165.3	1357.3	6193.1	96.42	0.64	97.06	113
235.0	226395.0	217699.1	1557.2	7138.7	96.16	0.69	96.85	122
245.0	236870.6	227391.8	1693.5	7785.3	96.00	0.71	96.71	127

TABLE A-13. SUMMARY OF CALCULATED NO_X MASS FLOW RATES AND
CONTROL EFFICIENCIES FOR INSTANTANEOUS FLOW
AND CONCENTRATION DATA FOR TEST -- 5

HERCULES INC., RUN 5, INLET HV-12, OUTLET HV-13, UNIT A 1255-1658 3/7/75

TIME INTO CYCLE (MIN)	INLET FLW (SCFM)	REGEN. FLOW (SCFM)	INLET CONC. (PPM)	OUTLET CONC. (PPM)	MASS FLOW RATE (G/MIN)	MASS FLW RATE (G/MIN)	MASS REGEN. RATE (G/MIN)	MASS EMIT. (G/MIN)	MASS REDUC. DUE TO ADS. (G/MIN)	% REDUC. OF NOX DUE TO REGEN. NOX	
0.0	5800	1010	3310	249	1055.5	978.1	13.83	65.58	92.48	1.31	93.79
3.0	5575	1015	3330	150	1020.7	974.7	8.37	37.61	95.50	0.82	96.32
5.0	5575	1010	3350	140	1026.8	983.9	7.77	35.14	95.82	0.76	96.58
9.0	5575	1010	3200	129	980.9	941.3	7.16	32.38	95.97	0.73	96.70
13.0	5650	1030	3080	146	956.8	911.4	8.27	37.09	95.26	0.86	96.12
15.0	5650	1025	2960	189	919.5	860.8	10.65	48.06	93.61	1.16	94.77
17.0	5650	1020	2760	235	857.4	784.4	13.18	59.82	91.49	1.54	93.02
20.0	5675	1020	2410	180	752.0	695.8	10.09	46.07	92.53	1.34	93.87
23.0	5675	1020	2340	106	730.1	697.1	5.94	27.13	95.47	0.81	96.28
30.0	5675	1025	2180	72	680.2	657.7	4.06	18.41	96.70	0.60	97.29
35.0	5700	1025	2040	61	639.3	620.2	3.44	15.68	97.01	0.54	97.55
41.0	5700	1025	2060	52	645.6	629.3	2.93	13.37	97.48	0.45	97.93
50.0	5700	1025	2090	49	655.0	639.6	2.76	12.59	97.66	0.42	98.08
65.0	5725	1020	2090	54	657.9	640.9	3.03	13.97	97.42	0.46	97.88
80.0	5725	1020	2050	61	645.3	626.1	3.42	15.78	97.02	0.53	97.55
85.0	5650	1020	2150	64	667.9	648.0	3.59	16.29	97.02	0.54	97.56
95.0	5625	1020	2260	75	699.0	675.8	4.21	18.99	96.68	0.60	97.28
102.0	5625	1020	2340	80	723.7	699.0	4.49	20.26	95.58	0.62	97.20
110.0	5450	1015	2340	81	701.2	676.9	4.52	19.75	96.54	0.64	97.18
115.0	5450	1020	2320	85	695.2	669.7	4.77	20.70	96.34	0.69	97.02
121.0	5450	1020	2290	85	686.2	660.7	4.77	20.70	95.29	0.69	96.98
125.0	5450	1020	2260	86	677.2	651.4	4.82	20.95	96.19	0.71	96.91
140.0	5450	1020	2250	92	674.2	646.6	5.16	22.41	95.91	0.77	96.68
148.0	5450	1020	2250	95	674.2	645.7	5.33	23.14	95.78	0.79	96.57
155.0	5450	1020	2220	99	665.2	635.6	5.55	24.11	95.54	0.83	96.38
163.0	5450	1020	2150	105	644.2	612.8	5.89	25.57	95.12	0.91	96.03
170.0	5450	1020	2160	110	647.2	614.3	6.17	26.79	94.91	0.95	95.86
185.0	5500	1020	1890	114	571.5	537.1	6.39	28.08	93.97	1.12	95.09
190.0	5500	1020	2090	115	632.0	597.2	6.45	28.33	94.50	1.02	95.52
200.0	5550	1020	2200	120	671.3	634.7	6.73	29.89	94.55	1.00	95.55
205.0	5550	1020	2200	125	671.3	633.2	7.01	31.13	94.32	1.04	95.36
211.0	5500	1020	2200	129	665.3	626.3	7.23	31.77	94.14	1.09	95.22
215.0	5525	1020	2200	130	668.3	628.8	7.29	32.20	94.09	1.09	95.18
230.0	5550	1020	2260	134	689.6	648.7	7.51	33.37	94.07	1.09	95.16
235.0	5550	1020	2300	138	701.1	659.7	7.74	34.37	94.00	1.10	95.10
243.0	5550	1020	2310	140	704.9	662.2	7.85	34.87	93.94	1.11	95.05

TABLE A-14. SUMMARY OF NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED FOR INTERVALS DURING TEST -- 5

HERCULES INC., RUN 5, INLET HV-12, OUTLET HV-13, UNIT A 1255-1658 3/7/75

INTERVAL OF CYCLE (4IN)	NOX IN (GRAMS)	NOX ADSORBED DURING INTERVAL	NOX REGEN. DURING INTERVAL	NOX EMITTED DURING INTERVAL	PERCENT OF NOX ADSORBED	PERCENT NOX FOR REGEN.	PERCENT REDUC. OF NOX	AVERAGE PPM OF NOX EMIT.
		(GRAMS)	(GRAMS)	(GRAMS)	INTERVAL	INTERVAL	INTERVAL	INTERVAL
0.0- 3.0	3114.4	2926.3	33.30	154.78	93.96	1.07	95.03	201
3.0- 5.0	2047.6	1958.7	16.15	72.75	95.66	0.79	96.45	145
5.0- 9.0	4015.4	3850.5	29.88	135.03	95.89	0.74	96.64	135
9.0- 13.0	3875.3	3705.5	30.86	138.93	95.62	0.80	96.42	138
13.0- 15.0	1876.3	1772.2	18.92	85.15	94.45	1.01	95.46	168
15.0- 17.0	1776.9	1645.2	23.83	107.88	92.59	1.34	93.93	212
17.0- 20.0	2414.0	2220.3	34.91	158.84	91.97	1.45	93.42	207
20.0- 23.0	2223.1	2089.3	24.06	109.80	93.98	1.08	95.06	143
23.0- 30.0	4936.2	4741.8	35.01	159.38	96.06	0.71	96.77	89
30.0- 35.0	3298.8	3194.9	18.74	85.22	96.85	0.57	97.42	66
35.0- 41.0	3854.8	3748.5	19.10	87.14	97.24	0.50	97.74	57
41.0- 50.0	5852.6	5710.2	25.61	116.82	97.57	0.44	98.00	51
50.0- 65.0	9846.5	9603.8	43.42	199.23	97.54	0.44	97.98	52
65.0- 80.0	9773.6	9502.1	48.37	223.12	97.22	0.49	97.72	57
80.0- 85.0	3282.9	3185.2	17.53	80.18	97.02	0.53	97.56	62
85.0- 95.0	6834.2	6618.8	38.98	176.41	96.85	0.57	97.42	69
95.0-102.0	4973.3	4811.5	30.42	137.36	96.63	0.61	97.24	78
102.0-110.0	5699.5	5503.4	36.03	160.03	96.56	0.63	97.19	80
110.0-115.0	3490.9	3366.6	23.22	101.14	96.44	0.67	97.10	83
115.0-121.0	4144.1	3991.3	28.60	124.22	96.31	0.69	97.00	85
121.0-125.0	2726.8	2624.3	19.18	83.30	96.24	0.70	96.95	86
125.0-140.0	13135.6	9735.6	74.87	325.16	96.05	0.74	96.79	89
140.0-148.0	5393.7	5169.5	41.95	182.19	95.84	0.78	96.62	94
148.0-155.0	4683.0	4484.5	38.08	165.38	95.65	0.81	96.47	97
155.0-163.0	5237.9	4993.3	45.76	198.75	95.33	0.87	96.21	102
163.0-173.0	4520.2	4294.7	42.20	183.28	95.01	0.93	95.95	108
173.0-185.0	9143.3	8635.0	94.22	411.54	94.47	1.03	95.50	112
185.0-190.0	3008.9	2835.7	32.11	141.02	94.25	1.07	95.31	115
190.0-200.0	6516.7	6159.7	65.90	291.07	94.52	1.01	95.53	118
200.0-205.0	3356.6	3169.7	34.35	152.55	94.43	1.02	95.46	123
205.0-211.0	4009.8	3778.3	42.73	188.72	94.23	1.07	95.29	127
211.0-215.0	2667.2	2510.2	29.05	127.95	94.11	1.09	95.20	130
215.0-230.0	10184.5	9581.6	111.04	491.81	94.08	1.09	95.17	132
230.0-235.0	3478.7	3271.2	38.14	169.36	94.04	1.10	95.13	136
235.0-243.0	5626.9	5287.6	62.36	276.96	93.97	1.11	95.08	139

TABLE A-15. CUMULATIVE NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X.
EMITTED DURING TEST -- 5

HERCULES INC., RUN 5, INLET HV-12, OUTLET HV-13, UNIT A 1255-1658 3/7/75

TIME INTO CYCLE (MIN)	TOTAL NOX IN (GRAMS)	TOTAL NOX ADS. (GRAMS)	NOX USED FOR REGEN. (GRAMS)	TOTAL NOX EMIT. (GRAMS)	% REDUC. DUE TO ADS.	% REDUC. DUE TO REGEN.	Avg. % OF NOX	Avg. PPM OF NOX EMIT.
<hr/>								
0								
3.0	3114.4	2926.3	33.3	154.8	93.96	1.07	95.03	201
5.0	5161.9	4885.0	49.4	227.5	94.63	0.96	95.59	179
9.0	9177.4	8735.5	79.3	362.6	95.19	0.86	96.05	159
13.0	13052.7	12441.0	110.2	501.5	95.31	0.84	96.16	153
15.0	14929.0	14213.3	129.1	586.6	95.21	0.86	96.07	155
17.0	16705.9	15858.4	152.9	694.5	94.93	0.92	95.84	161
20.0	19119.9	18078.7	187.8	853.4	94.55	0.98	95.54	168
23.0	21343.0	20168.0	211.9	963.1	94.49	0.99	95.49	165
30.0	26279.2	24909.8	246.9	1122.5	94.79	0.94	95.73	147
35.0	29578.0	28104.6	265.6	1207.7	95.02	0.90	95.92	136
41.0	33432.3	31853.1	284.8	1294.9	95.28	0.85	96.13	124
50.0	39285.4	37563.3	310.4	1411.7	95.62	0.79	96.41	111
65.0	49131.9	47167.1	353.8	1610.9	96.00	0.72	96.72	97
80.0	58905.4	55669.2	402.2	1834.1	96.20	0.68	96.89	89
85.0	62183.3	59854.4	419.7	1914.2	96.25	0.67	96.92	88
95.0	69322.5	66473.2	458.7	2090.6	96.31	0.66	96.97	86
102.0	74001.3	71284.7	489.1	2228.0	96.33	0.66	96.99	85
110.0	79701.3	76788.1	525.1	2388.0	96.34	0.66	97.00	85
115.0	83192.2	80154.7	548.3	2489.2	96.35	0.66	97.01	85
121.0	87336.3	84146.0	576.9	2613.4	96.35	0.66	97.01	85
125.0	90063.1	86770.3	596.1	2696.7	96.34	0.66	97.01	85
140.0	100198.3	96505.9	671.0	3021.8	96.31	0.67	96.98	85
148.0	105592.4	101675.5	712.9	3204.0	96.29	0.68	96.97	86
155.0	110280.4	106160.0	751.0	3369.4	96.26	0.68	96.94	86
163.0	115518.3	111153.4	796.8	3568.2	96.22	0.69	96.91	87
170.0	120039.5	115448.1	839.0	3751.5	96.18	0.70	96.87	88
185.0	129179.3	124083.1	933.2	4163.0	96.05	0.72	96.78	90
190.0	132188.2	126918.9	965.3	4304.0	96.01	0.73	96.74	90
200.0	138704.9	133078.6	1031.2	4595.1	95.94	0.74	96.69	92
205.0	142061.5	136248.3	1065.5	4747.6	95.91	0.75	96.66	92
211.0	146071.3	140026.6	1108.3	4936.4	95.86	0.76	96.62	93
215.0	148738.4	142536.8	1137.3	5064.3	95.83	0.76	96.60	94
230.0	158922.9	152118.4	1248.4	5556.1	95.72	0.79	96.50	97
235.0	162401.6	155389.6	1286.5	5725.5	95.68	0.79	96.47	97
243.0	168028.5	160677.2	1348.9	6002.4	95.62	0.80	96.43	99

TABLE A-16. SUMMARY OF CALCULATED NO_X MASS FLOW RATES AND
CONTROL EFFICIENCIES FOR INSTANTANEOUS FLOW
AND CONCENTRATION DATA FOR TEST -- 6

HERCULES INC., RUN 6, INLET HV-12, OUTLET HV-13, UNIT A 1400-1754 3/11/75

TIME INTO CYCLE (MIN)	INLET FLOW (SCFM)	REGEN. FLOW (SCFM)	INLET CONC. (PPM)	OUTLET CONC. (PPM)	MASS RATE (G/MIN)	MASS FLOW (G/MIN)	MASS RATE (G/MIN)	MASS FLOW (G/MIN)	% REDUC. OF NOX ADS.	% REDUC. OF NOX DUETO REGEN.	% REDUC. OF NOX ADS.

0.0	3150	1030	1150	8	199.2	197.8	0.45	0.93	99.30	0.23	99.53
15.0	4250	1035	1060	11	247.7	245.1	0.63	1.94	98.96	0.25	99.21
20.0	4300	1035	890	10	210.4	208.0	0.57	1.80	98.88	0.27	99.15
30.0	4350	1030	750	10	179.4	177.0	0.57	1.83	98.67	0.32	98.98
35.0	4350	1030	720	8	172.2	170.3	0.45	1.46	98.89	0.26	99.15
45.0	4350	1030	710	6	169.8	168.4	0.34	1.10	99.15	0.20	99.36
50.0	4350	1030	710	6	169.8	168.4	0.34	1.10	99.15	0.20	99.36
60.0	4350	1030	710	9	169.8	167.7	0.51	1.64	98.73	0.30	99.03
65.0	4350	1030	710	9	169.8	167.7	0.51	1.64	98.73	0.30	99.03
75.0	4350	1030	710	10	169.8	167.4	0.57	1.83	98.59	0.33	98.93
80.0	4350	1030	680	10	162.6	160.2	0.57	1.83	98.53	0.35	98.88
90.0	5200	1025	800	10	228.7	225.9	0.56	2.30	98.75	0.25	99.00
95.0	5175	1025	880	11	250.4	247.3	0.62	2.51	98.75	0.25	99.00
105.0	5175	1025	970	14	276.0	272.0	0.79	3.19	98.56	0.29	98.84
110.0	5175	1025	1020	14	290.2	286.2	0.79	3.19	98.63	0.27	98.90
120.0	5200	1025	1190	15	340.2	335.9	0.85	3.44	98.74	0.25	98.99
125.0	5200	1025	1230	16	351.7	347.1	0.90	3.67	98.70	0.26	98.96
135.0	5200	1025	1260	18	360.2	355.1	1.01	4.13	98.57	0.28	98.85
140.0	5200	1025	1260	16	360.2	355.7	0.90	3.67	98.73	0.25	98.98
150.0	5200	1025	1200	20	343.1	337.4	1.13	4.59	98.33	0.33	98.66
165.0	5200	1025	1150	21	328.8	322.8	1.18	4.82	98.17	0.36	98.53
170.0	5200	1025	1150	21	328.8	322.8	1.18	4.82	98.17	0.36	98.53
180.0	5200	1025	1140	24	325.9	319.1	1.35	5.51	97.89	0.41	98.31
195.0	5175	1025	1140	25	324.4	317.2	1.41	5.70	97.81	0.43	98.24
200.0	5175	1025	1150	29	327.2	319.0	1.63	6.62	97.48	0.50	97.98
210.0	5175	1025	1150	29	327.2	319.0	1.63	6.62	97.48	0.50	97.98
225.0	5175	1025	1130	29	321.5	313.3	1.63	6.62	97.43	0.51	97.94
230.0	5175	1025	1110	29	315.8	307.6	1.63	6.62	97.39	0.52	97.90
234.0	5175	1025	1090	29	310.1	301.9	1.63	6.62	97.34	0.53	97.87

TABLE A-17. SUMMARY OF NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED FOR INTERVALS DURING TEST -- 6

HERCULES INC., RUN 6, INLET HV-12, OUTLET HV-13, UNIT A 1400-1754 3/11/75

INTERVAL OF CYCLE (MIN)	NOX IN DURING INTERVAL (GRAMS)	NOX ADSORBED DURING INTERVAL (GRAMS)	NOX REGEN. DURING INTERVAL (GRAMS)	NOX EMITTED DURING INTERVAL (GRAMS)	PERCENT OF NOX ADSORBED DURING INTERVAL	PERCENT NOX FOR REGEN. DURING INTERVAL	PERCENT REDUC. OF NOX DURING INTERVAL	AVERAGE PPM OF NOX EMIT. DURING INTERVAL
0.0- 15.0	3351.5	3321.8	8.09	21.58	99.11	0.24	99.36	10
15.0- 20.0	1145.3	1132.9	2.99	9.35	98.92	0.26	99.18	10
20.0- 30.0	1949.0	1925.2	5.68	18.10	98.78	0.29	99.07	10
30.0- 35.0	873.9	868.2	2.55	8.21	98.78	0.29	99.07	9
35.0- 45.0	1710.1	1693.3	3.96	12.78	99.02	0.23	99.25	7
45.0- 50.0	849.1	841.9	1.70	5.48	99.15	0.20	99.36	6
50.0- 60.0	1698.1	1680.2	4.25	13.69	98.94	0.25	99.19	7
60.0- 65.0	849.1	838.3	2.55	8.21	98.73	0.30	99.03	9
65.0- 75.0	1698.1	1675.4	5.38	17.34	98.66	0.32	98.98	9
75.0- 80.0	831.1	819.2	2.83	9.13	98.56	0.34	98.90	10
80.0- 90.0	1956.8	1930.5	5.65	20.60	98.66	0.29	98.95	10
90.0- 95.0	1197.8	1182.8	2.96	12.01	98.75	0.25	99.00	10
95.0-105.0	2631.9	2596.3	7.04	28.52	98.65	0.27	98.92	12
105.0-110.0	1415.5	1395.6	3.94	15.97	98.59	0.28	98.87	14
110.0-120.0	3152.2	3110.9	8.17	33.19	98.69	0.26	98.95	15
120.0-125.0	1729.7	1707.6	4.37	17.79	98.72	0.25	98.97	15
125.0-135.0	3559.5	3510.9	9.58	39.02	98.63	0.27	98.90	17
135.0-140.0	1901.2	1776.9	4.79	19.51	98.65	0.27	98.92	17
140.0-150.0	3515.6	3465.2	10.14	41.32	98.54	0.29	98.83	18
150.0-165.0	5039.1	4951.1	17.33	70.59	98.26	0.34	98.60	21
165.0-170.0	1643.9	1613.9	5.92	24.10	98.17	0.36	98.53	21
170.0-180.0	3273.6	3209.3	12.68	51.65	98.03	0.39	98.42	23
180.0-195.0	4877.2	4772.4	20.71	84.10	97.85	0.42	98.28	24
195.0-200.0	1623.9	1590.5	7.61	30.80	97.64	0.47	98.11	27
200.0-210.0	3272.1	3189.6	16.34	66.17	97.48	0.50	97.98	29
210.0-225.0	4865.4	4741.7	24.51	99.26	97.66	0.50	97.96	29
225.0-230.0	1593.4	1552.1	8.17	33.09	97.41	0.51	97.92	29
230.0-234.0	1251.9	1218.9	6.54	26.47	97.36	0.52	97.89	29

TABLE A-18. CUMULATIVE NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED DURING TEST -- 6

HERCULES INC., RUV 6, INLET HV-12, OUTLET HV-13, UNIT A 1400-1754 3/11/75

TIME INTO CYCLE (MIN)	TOTAL NOX (GRAMS)	TOTAL NOX ADS. (GRAMS)	NOX USED FOR REGEN. (GRAMS)	TOTAL NOX EMIT. (GRAMS)	% NOX REDUC. DUE TO ADS.	% NOX REDUC. DUE TO REGEN.	Avg. % OF NOX	Avg. PPM
					DUE TO REGEN.	NOX EMIT.		
0								
15.0	3351.5	3321.8	8.1	21.6	99.11	0.24	99.36	10
20.0	4496.7	4454.7	11.1	30.9	99.07	0.25	99.31	10
30.0	6445.7	6379.9	16.8	49.0	98.98	0.26	99.24	10
35.0	7324.6	7248.1	19.3	57.2	98.95	0.26	99.22	10
45.0	9034.7	8941.4	23.3	70.0	98.97	0.26	99.22	9
50.0	9883.7	9783.3	25.0	75.5	98.98	0.25	99.24	9
60.0	11581.8	11463.4	29.2	89.2	98.98	0.25	99.23	9
65.0	12430.9	12301.7	31.8	97.4	98.96	0.26	99.22	9
75.0	14129.0	13977.1	37.1	114.7	98.93	0.26	99.19	9
80.0	14960.1	14796.3	40.0	123.9	98.90	0.27	99.17	9
90.0	16916.9	16726.8	45.6	144.5	98.88	0.27	99.15	9
95.0	18114.7	17909.6	48.6	156.5	98.87	0.27	99.14	9
105.0	20746.6	20505.9	55.6	185.0	98.84	0.27	99.11	9
110.0	22162.1	21901.6	59.6	201.0	98.82	0.27	99.09	10
120.0	25514.3	25012.4	67.7	234.2	98.81	0.27	99.07	10
125.0	27044.0	26720.0	72.1	252.0	98.80	0.27	99.07	10
135.0	30603.5	30230.9	81.7	291.0	98.78	0.27	99.05	11
140.0	32404.7	32007.8	86.5	310.5	98.77	0.27	99.04	11
150.0	35921.4	35472.9	96.6	351.8	98.75	0.27	99.02	12
165.0	40960.4	40424.1	114.0	422.4	98.69	0.28	98.97	13
170.0	42604.4	42038.0	119.9	446.5	98.67	0.28	98.95	13
180.0	45878.0	45247.2	132.6	498.1	98.63	0.29	98.91	14
195.0	50755.2	50019.6	153.3	582.2	98.55	0.30	98.85	15
200.0	52384.1	51610.2	160.9	613.1	98.52	0.31	98.83	15
210.0	55656.2	54799.7	177.2	679.2	98.46	0.32	98.78	16
225.0	60521.6	59541.4	201.7	778.5	98.38	0.33	98.71	17
230.0	62115.0	61093.5	209.9	811.6	98.36	0.34	98.69	17
234.0	63366.9	62312.4	216.4	838.0	98.34	0.34	98.68	17

TABLE A-19. SUMMARY OF CALCULATED NO_X MASS FLOW RATES AND
CONTROL EFFICIENCIES FOR INSTANTANEOUS FLOW
AND CONCENTRATION DATA FOR TEST -- 7

HERCULES INC., RUN 7, INLET HV-12, OUTLET HV-13, UNIT B 1002-1404 3/12/75

TIME INTO CYCLE (MIN)	INLET FLOW (SCFM)	REGEN. FLW (SCFM)	INLET CONC. (PPM)	OUTLET CONC. (PPM)	MASS FLOW (G/MIN)	MASS FLOW (G/MIN)	MASS FLOW (G/MIN)	MASS FLOW (G/MIN)	% REDUC. OF NOX DUE TO ADSORB.	% REDUC. OF NOX DUE TO REGEN.	% REDUC. OF NOX NOX
0.0	4300	1025	1950	78	461.0	442.6	4.40	14.05	96.00	0.95	96.95
1.0	4300	1025	1910	48	451.6	440.2	2.71	8.64	97.49	0.60	98.09
7.0	4300	1025	2030	54	479.9	467.2	3.04	9.72	97.34	0.63	97.97
12.0	4300	1025	2080	58	491.8	478.0	3.27	10.44	97.21	0.66	97.88
20.0	4300	1025	2100	68	496.5	480.4	3.83	12.24	96.76	0.77	97.53
25.0	4300	1025	2050	68	484.7	468.6	3.83	12.24	96.68	0.79	97.47
38.0	4300	1025	2100	46	496.5	485.6	2.59	8.28	97.81	0.52	98.33
43.0	4300	1025	2150	46	508.3	497.4	2.59	8.28	97.86	0.51	98.37
48.0	4300	1025	2170	46	513.0	502.2	2.59	8.28	97.88	0.51	98.39
53.0	4300	1025	2250	46	531.9	521.1	2.59	8.28	97.96	0.49	98.44
79.0	4300	1025	2650	50	626.5	614.7	2.82	9.00	98.11	0.45	98.56
80.0	4300	1025	2690	50	636.0	624.1	2.82	9.00	98.14	0.44	98.58
84.0	4300	1025	2770	49	654.5	643.3	2.76	8.82	98.23	0.42	98.65
88.0	4300	1025	2710	52	640.7	628.4	2.93	9.36	98.08	0.46	98.54
93.0	4300	1020	2690	61	636.0	621.5	3.42	11.00	97.73	0.54	98.27
103.0	4300	1020	2750	61	650.2	635.7	3.42	11.00	97.78	0.53	98.31
108.0	4300	1020	2600	62	614.7	600.0	3.48	11.18	97.62	0.57	98.18
119.0	4300	1020	2480	61	586.3	571.9	3.42	11.00	97.54	0.58	98.12
133.0	4300	1020	2290	59	541.4	527.5	3.31	10.64	97.42	0.61	98.03
139.0	4300	1020	2300	59	543.8	529.8	3.31	10.64	97.43	0.61	98.04
148.0	4300	1020	2280	60	539.0	524.9	3.36	10.82	97.37	0.62	97.99
153.0	4300	1020	2240	62	529.6	514.9	3.48	11.18	97.23	0.66	97.89
163.0	4300	1020	2263	64	534.3	519.2	3.59	11.54	97.17	0.67	97.84
173.0	4300	1020	2320	70	548.5	531.9	3.93	12.62	96.98	0.72	97.70
178.0	4325	1020	2350	71	558.8	541.9	3.98	12.90	96.98	0.71	97.69
183.0	4325	1020	2390	72	568.3	551.2	4.04	13.08	96.99	0.71	97.70
194.0	4325	1020	2280	74	542.2	524.6	4.15	13.45	96.75	0.77	97.52
198.0	4325	1020	2330	76	554.1	536.0	4.26	13.81	96.74	0.77	97.51
203.0	4325	1020	2210	78	525.5	507.0	4.37	14.17	96.47	0.83	97.30
208.0	4325	1020	2190	78	520.8	502.2	4.37	14.17	95.44	0.84	97.28
213.0	4850	1015	2190	76	584.0	563.7	4.24	16.02	96.53	0.73	97.26
223.0	5225	1020	2160	75	620.5	599.0	4.21	17.34	96.53	0.68	97.21
229.0	5225	1020	2280	81	655.0	631.7	4.54	18.73	95.45	0.69	97.14
238.0	5225	1020	2740	92	787.1	760.7	5.16	21.27	96.64	0.66	97.30
242.0	5200	1020	2740	95	783.4	756.2	5.33	21.83	96.53	0.68	97.21

TABLE A-20. SUMMARY OF NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED FOR INTERVALS DURING TEST -- 7

HERCULES INC., RUN 7, INLET HV-12, OUTLET HV-13, UNIT B 1002-1404 3/12/75

INTERVAL OF CYCLE (MIN)	NOX IN DURING INTERVAL	NOX ADSORBED DURING INTERVAL	NOX REGEN. DURING INTERVAL	NOX EMITTED DURING INTERVAL	PERCENT OF NOX ADSORBED DURING INTERVAL	PERCENT NOX FOR REGEN. DURING INTERVAL	PERCENT OF NOX REGEN. DURING INTERVAL	AVERAGE PPM OF NOX EMI.
0.0- 1.0	456.3	441.4	3.55	11.34	96.74	0.78	97.51	63
1.0- 7.0	2794.5	2722.1	17.24	55.10	97.41	0.62	98.03	51
7.0- 12.0	2429.2	2363.0	15.78	50.42	97.27	0.65	97.92	56
12.0- 20.0	3952.9	3833.8	28.40	90.75	96.99	0.72	97.70	63
20.0- 25.0	2452.9	2372.5	19.16	61.22	96.72	0.78	97.50	68
25.0- 38.0	6377.4	6202.2	41.76	133.43	97.25	0.65	97.91	57
38.0- 43.0	2512.0	2457.6	12.96	41.41	97.84	0.52	98.35	46
43.0- 48.0	2553.3	2499.0	12.96	41.41	97.87	0.51	98.38	46
48.0- 58.0	5224.9	5116.1	25.92	82.83	97.92	0.50	98.41	46
58.0- 78.0	11584.6	11357.6	54.10	172.86	98.04	0.47	98.51	48
78.0- 80.0	1262.5	1238.8	5.64	18.01	98.13	0.45	98.57	50
80.0- 84.0	2581.7	2534.9	11.16	35.65	98.19	0.43	98.62	49
84.0- 88.0	2591.2	2543.4	11.38	36.37	98.15	0.44	98.60	50
88.0- 98.0	6383.3	6249.8	31.76	101.82	97.91	0.50	98.40	57
93.0-103.0	3215.3	3143.2	17.10	55.00	97.76	0.53	98.29	61
103.0-108.0	3162.1	3089.4	17.24	55.45	97.70	0.55	98.25	62
108.0-118.0	6005.1	5859.7	34.49	110.91	97.58	0.57	98.15	62
118.0-133.0	8457.9	8245.2	50.47	162.31	97.48	0.60	98.08	60
133.0-138.0	2712.9	2643.2	16.54	53.20	97.43	0.61	98.04	59
138.0-148.0	5414.0	5273.4	33.37	107.30	97.40	0.62	98.02	60
148.0-153.0	2671.6	2599.4	17.10	55.00	97.30	0.64	97.94	61
153.0-163.0	5319.5	5170.5	35.33	113.61	97.20	0.66	97.86	63
163.0-173.0	5414.0	5255.6	37.57	120.83	97.07	0.69	97.77	67
173.0-178.0	2763.3	2684.7	19.77	63.81	96.98	0.71	97.69	71
173.0-183.0	2817.9	2732.9	20.05	64.96	96.98	0.71	97.69	71
183.0-194.0	6107.8	5916.8	45.03	145.92	96.87	0.74	97.61	73
194.0-198.0	2192.5	2121.1	16.82	54.51	96.75	0.77	97.51	75
198.0-203.0	2699.0	2607.4	21.59	69.96	96.61	0.80	97.41	77
203.0-208.0	2615.7	2523.0	21.87	70.87	96.45	0.84	97.29	78
208.0-213.0	2761.9	2664.9	21.54	75.50	96.49	0.78	97.27	77
213.0-223.0	6022.5	5813.5	42.24	166.82	96.53	0.70	97.23	75
223.0-229.0	3826.5	3692.1	26.25	108.20	96.49	0.69	97.17	78
229.0-238.0	6489.6	6266.0	43.66	179.99	96.55	0.67	97.23	86
238.0-242.0	3141.0	3033.9	20.97	86.21	96.59	0.67	97.26	93

TABLE A-21. CUMULATIVE NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED DURING TEST -- 7

HERCULES INC., RUN 7, INLET HV-12, OUTLET HV-13, UNIT B 1002-1404 3/12/75

TIME INTO CYCLE (MIN)	TOTAL NOX IN (GRAMS)	TOTAL NOX ADS. (GRAMS)	USED FOR REGEN. (GRAMS)	TOTAL NOX EMIT. (GRAMS)	% NOX REDUC. DUE TO ADS.	% NOX REDUC. DUE TO REGEN.	Avg. % OF NOX	Avg. PPM
0								
1.0	456.3	441.4	3.6	11.3	96.74	0.78	97.51	63
7.0	3250.3	3163.5	20.8	66.4	97.32	0.64	97.96	53
12.0	5680.3	5526.6	36.6	116.9	97.30	0.64	97.94	54
20.0	9632.9	9360.4	65.0	207.6	97.17	0.67	97.84	58
25.0	12085.8	11732.8	84.1	268.8	97.08	0.70	97.78	60
38.0	18463.2	17935.1	125.9	402.3	97.14	0.68	97.82	59
43.0	20975.2	20392.7	138.9	443.7	97.22	0.66	97.88	57
48.0	23528.5	22891.6	151.8	485.1	97.29	0.65	97.94	56
58.0	28753.4	28007.8	177.7	567.9	97.41	0.62	98.02	54
78.0	40338.0	39365.4	231.8	740.8	97.59	0.57	98.16	53
83.0	41500.5	40604.2	237.5	758.8	97.61	0.57	98.18	53
84.0	44182.2	43139.1	248.6	794.4	97.64	0.56	98.20	53
88.0	46773.4	45682.6	260.0	830.8	97.67	0.56	98.22	52
93.0	53156.7	51932.3	291.8	932.6	97.70	0.55	98.25	53
103.0	56372.1	55075.5	308.9	987.6	97.70	0.55	98.25	53
108.0	59534.2	58165.0	326.1	1043.1	97.70	0.55	98.25	54
118.0	65539.3	64024.6	360.6	1154.0	97.69	0.55	98.24	54
133.0	73997.2	72269.8	411.1	1316.3	97.67	0.56	98.22	55
138.0	76710.1	74913.0	427.6	1369.5	97.66	0.56	98.21	55
149.0	82124.1	80186.3	461.0	1476.8	97.64	0.56	98.20	55
153.0	84795.7	82785.8	478.1	1531.8	97.63	0.56	98.19	56
163.0	90115.1	87956.3	513.4	1645.4	97.60	0.57	98.17	56
173.0	95529.2	93211.9	551.0	1766.3	97.57	0.58	98.15	57
178.0	98297.5	95896.6	570.8	1830.1	97.56	0.58	98.14	57
183.0	101115.3	98629.5	590.8	1895.0	97.54	0.58	98.13	57
194.0	107223.1	104546.3	635.9	2040.9	97.50	0.59	98.10	58
198.0	109415.5	106667.4	652.7	2095.5	97.49	0.60	98.08	59
203.0	112114.5	109274.8	674.3	2165.4	97.47	0.60	98.07	59
208.0	114730.3	111797.8	696.2	2236.3	97.44	0.61	98.05	60
213.0	117492.2	114462.7	717.7	2311.8	97.42	0.61	98.03	60
223.0	123514.7	120276.1	759.9	2478.6	97.38	0.62	97.99	61
229.0	127341.2	123968.2	786.2	2586.8	97.35	0.62	97.97	61
238.0	133830.8	130234.2	829.8	2766.8	97.31	0.62	97.93	63
242.0	136971.9	133268.1	850.8	2853.0	97.30	0.62	97.92	63

TABLE A-22. SUMMARY OF CALCULATED NO_X MASS FLOW RATES AND
CONTROL EFFICIENCIES FOR INSTANTANEOUS FLOW
AND CONCENTRATION DATA FOR TEST -- 8

HERCULES INC., RUV 8, INLET HV-12, OUTLET HV-13, UNIT A 1404-1806 3/12/75

TIME INTO CYCLE (MIN)	INLET FLOW (SCFM)	REGEN. FLOW (SCFM)	INLET CONC. (PPM)	OUTLET CONC. (PPM)	MASS RATE (G/MIN)	MASS FLOW (G/MIN)	MASS RATE (G/MIN)	MASS FLOW (G/MIN)	% REDUC. OF NOX ADS.	% REDUC. OF NOX DUE TO REGEN.	% REDUC. OF NOX

0.0	5200	1020	2740	95	7d3.4	756.2	5.33	21.83	96.53	0.68	97.21
2.0	5200	1020	2730	50	780.5	766.2	2.80	11.49	98.17	0.36	98.53
5.0	5050	1020	2720	45	755.2	742.7	2.52	9.97	98.35	0.33	98.68
11.0	5050	1020	2630	56	730.2	714.7	3.14	12.41	97.87	0.43	98.30
13.0	5050	1020	2480	76	688.6	667.5	4.26	16.84	95.94	0.62	97.55
18.0	5050	1020	2440	84	677.5	654.2	4.71	18.61	96.56	0.70	97.25
26.0	5025	1020	2350	58	649.3	633.2	3.25	12.77	97.53	0.50	98.03
31.0	5050	1020	2270	49	630.3	616.7	2.75	10.86	97.84	0.44	98.28
41.0	5050	1020	2340	46	649.7	636.9	2.58	10.19	98.03	0.40	98.43
45.0	5050	1020	2380	45	660.8	648.3	2.52	9.97	98.11	0.38	98.49
56.0	5050	1020	2350	45	652.5	640.3	2.52	9.97	98.09	0.39	98.47
72.0	5050	1020	2280	51	633.1	618.9	2.86	11.30	97.76	0.45	98.21
76.0	5050	1020	2270	51	630.3	616.1	2.86	11.30	97.75	0.45	98.21
85.0	5050	1020	2340	56	649.7	634.2	3.14	12.41	97.61	0.48	98.09
101.0	5075	1020	2410	61	672.5	655.4	3.42	13.60	97.47	0.51	97.98
115.0	5025	1020	2520	70	696.2	676.9	3.93	15.41	97.22	0.56	97.79
131.0	5025	1020	2520	71	696.2	676.6	3.98	15.63	97.18	0.57	97.75
136.0	5025	1020	2460	72	679.7	659.8	4.04	15.85	97.07	0.59	97.67
145.0	5025	1020	2180	75	602.3	581.6	4.21	16.52	96.56	0.70	97.26
154.0	5025	1020	2060	76	559.1	548.1	4.26	16.74	96.31	0.75	97.06
161.0	5025	1020	2050	78	566.4	544.8	4.37	17.18	96.20	0.77	96.97
176.0	5025	1020	2050	84	566.4	543.2	4.71	18.50	95.90	0.83	96.73
192.0	5025	1020	2040	91	563.6	538.5	5.10	20.04	95.54	0.91	96.44
196.0	5025	1020	2060	91	559.1	544.0	5.10	20.04	95.58	0.90	96.48
203.0	5025	1020	2190	96	605.1	578.5	5.38	21.14	95.62	0.89	96.51
216.0	5000	1020	2540	106	698.3	669.1	5.94	23.20	95.83	0.85	96.68
221.0	4975	1020	2590	114	708.5	677.3	6.39	24.79	95.60	0.90	96.50
227.0	4975	1020	2560	120	700.2	667.4	6.73	26.09	95.31	0.96	96.27
236.0	4975	1020	2150	121	588.1	555.0	6.79	26.31	94.37	1.15	95.53
242.0	4975	1020	2310	121	631.9	598.8	6.79	26.31	94.76	1.07	95.84

TABLE A-23. SUMMARY OF NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED FOR INTERVALS DURING TEST -- 8

HERCULES INC., RUN 8, INLET HV-12, OUTLET HV-13, UNIT A 1404-1806 3/12/75

INTERVAL OF CYCLE (MIN)	NOX IN DURING INTERVAL (GRAMS)	NOX ADSORBED DURING INTERVAL (GRAMS)	NOX REGEN. DURING INTERVAL (GRAMS)	NOX EMITTED DURING INTERVAL (GRAMS)	PERCENT OF NOX ADSORBED DURING INTERVAL	PERCENT NOX FOR REGEN. DURING INTERVAL	PERCENT REDUC. OF NOX DURING INTERVAL	AVERAGE PPM OF NOX EMIT. DURING INTERVAL
0.0- 2.0	1563.9	1522.4	8.13	33.32	97.35	0.52	97.87	73
2.0- 5.0	2303.6	2263.4	7.99	32.19	98.26	0.35	98.60	48
5.0- 11.0	4456.4	4372.3	16.99	67.14	98.11	0.38	98.49	51
11.0- 16.0	3547.1	3455.4	18.51	73.12	97.42	0.52	97.94	66
16.0- 18.0	1366.1	1321.6	8.97	35.45	96.75	0.66	97.40	80
18.0- 26.0	5307.0	5149.6	31.85	125.54	97.03	0.60	97.63	71
25.0- 31.0	3198.9	3124.8	15.00	59.07	97.68	0.47	98.15	53
31.0- 41.0	6400.0	6268.1	26.64	105.25	97.94	0.42	98.36	48
41.0- 46.0	3276.3	3213.2	12.76	50.41	98.07	0.39	98.46	46
46.0- 56.0	6566.6	6441.6	25.24	99.71	98.10	0.38	98.48	45
56.0- 72.0	10284.4	10071.2	43.07	170.17	97.93	0.42	98.35	48
72.0- 76.0	2526.7	2470.0	11.44	45.20	97.76	0.45	98.21	51
76.0- 86.0	6400.0	6251.4	30.00	118.54	97.68	0.47	98.15	54
85.0-101.0	9916.4	9672.1	49.21	195.06	97.54	0.50	98.03	59
101.0-116.0	10265.2	9992.5	55.10	217.60	97.34	0.54	97.88	65
115.0-131.0	10443.5	10151.3	59.31	232.86	97.20	0.57	97.77	70
131.0-136.0	3439.7	3340.9	20.05	78.72	97.13	0.58	97.71	72
136.0-146.0	6409.7	6206.7	41.22	161.85	96.83	0.64	97.47	74
146.0-154.0	4685.7	4518.9	33.87	133.00	96.44	0.72	97.16	76
154.0-161.0	3974.3	3825.4	30.23	118.69	96.25	0.76	97.01	77
161.0-176.0	8495.7	8160.0	68.14	267.54	96.05	0.80	96.85	81
176.0-192.0	9039.9	8653.1	78.51	308.28	95.72	0.87	96.59	87
192.0-196.0	2265.5	2164.9	20.41	80.15	95.56	0.90	96.46	91
195.0-206.0	5871.0	5612.7	52.44	205.89	95.60	0.89	96.49	93
206.0-216.0	6516.6	6238.3	56.64	221.67	95.73	0.87	96.60	101
216.0-221.0	3516.8	3366.0	30.84	119.96	95.71	0.88	96.59	110
221.0-227.0	4226.1	4034.1	39.37	152.65	95.46	0.93	96.39	117
227.0-236.0	5797.5	5500.9	60.82	235.83	94.88	1.05	95.93	120
236.0-242.0	3659.9	3461.3	40.71	157.87	94.57	1.11	95.69	121

TABLE A-24. CUMULATIVE NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED DURING TEST -- 8

HERCULES INC., RJN 8, INLET HV-12, OUTLET HV-13, UNIT A 1404-1806 3/12/75

TIME INTO CYCLE (MIN)	TOTAL NOX (GRAMS)	TOTAL NOX (GRAMS)	NOX USED FOR REGEN.	TOTAL EMIT. (GRAMS)	% NOX REDUC. DUE TO ADS.	% NOX REDUC. DUE TO REGEN.	Avg. % OF NOX NOX EMIT.	Avg. PPM
.....								
0								
2.0	1563.9	1522.4	8.1	33.3	97.35	0.52	97.87	72
5.0	3867.5	3785.9	16.1	65.5	97.89	0.42	98.31	58
11.0	8323.9	8158.1	33.1	132.7	98.01	0.40	98.41	54
16.0	11870.9	11613.6	51.6	205.8	97.83	0.43	98.27	58
18.0	13237.0	12935.2	60.6	241.2	97.72	0.46	98.18	60
26.0	18544.0	13084.8	92.4	366.8	97.52	0.50	98.02	63
31.0	21742.8	21209.6	107.5	425.8	97.55	0.49	98.04	62
41.0	28142.8	27477.7	134.1	531.1	97.64	0.48	98.11	58
46.0	31419.2	30693.8	146.8	581.5	97.68	0.47	98.15	57
56.0	37985.7	37132.5	172.1	681.2	97.75	0.45	98.21	55
72.0	48270.1	47203.6	215.2	851.4	97.79	0.45	98.24	53
76.0	50796.8	49673.6	226.6	896.6	97.79	0.45	98.23	53
80.0	57196.3	55925.1	256.6	1015.1	97.78	0.45	98.23	53
101.0	67113.1	65597.2	305.8	1210.2	97.74	0.46	98.20	54
110.0	77378.4	75589.7	360.9	1427.8	97.69	0.47	98.15	55
131.0	87821.8	85741.0	420.2	1660.6	97.63	0.48	98.11	57
136.0	91261.5	89081.9	440.3	1739.4	97.61	0.48	98.09	58
145.0	97671.3	95288.6	481.5	1901.2	97.56	0.49	98.05	59
154.0	102357.0	99807.4	515.4	2034.2	97.51	0.50	98.01	60
161.0	106531.3	103632.8	545.6	2152.9	97.46	0.51	97.98	60
175.0	114827.0	111792.8	613.7	2420.4	97.36	0.53	97.89	62
192.0	123966.9	120446.0	692.2	2728.7	97.24	0.56	97.80	64
196.0	126132.4	122610.9	712.7	2808.9	97.21	0.56	97.77	65
205.0	132033.4	123223.6	765.1	3014.8	97.14	0.58	97.72	66
216.0	138523.0	134461.9	821.7	3236.4	97.07	0.59	97.66	68
221.0	142036.8	137827.8	852.6	3356.4	97.04	0.60	97.64	69
227.0	146262.9	141861.9	891.9	3509.1	96.99	0.61	97.60	70
236.0	152060.4	147362.8	952.8	3744.9	96.91	0.63	97.54	72
242.0	155720.3	150824.1	993.5	3902.8	96.86	0.64	97.49	73

TABLE A-25. SUMMARY OF CALCULATED NO_X MASS FLOW RATES AND
CONTROL EFFICIENCIES FOR INSTANTANEOUS FLOW
AND CONCENTRATION DATA FOR TEST -- 9

HERCULES INC., RUN 9, INLET HV-23, OUTLET HV-13 UNIT B 1017-1503 3/13/75

TIME (INT) CYCLE (MIN)	INLET FLOW (SCFM)	REGEN. FLOW (SCFM)	INLET CUNC. (PPM)	OUTLET CUNC. (PPM)	MASS RATE (G/MIN)	MASS FLOW (G/MIN)	MASS RATE (G/MIN)	MASS FLOW (G/MIN)	MASS RATE (G/MIN)	% REDUC. OF NOX DUE TO REGEN.	% REDUC. OF NOX DUE TO JF	% REDUC. NOX
0.0	4300	1030	1880	40	444.5	435.0	2.27	7.19	97.87	0.51	98.38	
13.0	4300	1030	1900	45	449.2	438.6	2.55	8.09	97.63	0.57	98.20	
18.0	4300	1030	1860	50	439.7	427.9	2.83	8.99	97.31	0.64	97.96	
22.0	4300	1030	1860	58	439.7	426.0	3.28	10.43	96.88	0.75	97.63	
25.0	3050	1030	1810	55	303.5	294.3	3.11	6.11	96.96	1.03	97.99	
28.0	3040	1030	1800	52	300.9	292.2	2.94	5.75	97.11	0.98	98.09	
32.0	3040	1030	1770	45	295.8	288.3	2.55	4.97	97.46	0.86	98.32	
37.0	3040	1030	1760	39	290.8	284.3	2.21	4.31	97.76	0.76	98.52	
43.0	3040	1030	1750	38	292.5	286.2	2.15	4.20	97.83	0.74	98.56	
58.0	3040	1030	2050	32	342.6	337.3	1.81	3.54	98.44	0.53	98.97	
73.0	5000	1035	1850	31	508.6	500.1	1.76	6.76	98.32	0.35	98.67	
78.0	5175	1035	1660	30	472.3	463.8	1.71	6.83	98.19	0.36	98.55	
81.0	3650	1030	1660	30	333.1	327.1	1.70	4.32	98.19	0.51	98.70	
83.0	3650	1030	1500	30	301.0	295.0	1.70	4.32	98.00	0.56	98.56	
85.0	3625	1030	1480	30	295.0	289.0	1.70	4.28	97.97	0.58	98.55	
86.0	3625	1030	1360	30	271.1	265.1	1.70	4.28	97.79	0.63	98.42	
87.0	3525	1030	1450	30	281.0	275.2	1.70	4.12	97.93	0.60	98.54	
88.0	6100	1015	1467	30	485.3	475.2	1.67	8.39	97.93	0.34	98.27	
93.0	6250	1020	1840	30	632.3	622.0	1.68	8.63	98.37	0.27	98.64	
103.0	5800	1040	2940	44	937.5	923.5	2.52	11.52	98.50	0.27	98.77	
108.0	5825	1035	2890	45	925.6	911.2	2.56	11.85	98.44	0.28	98.72	
120.0	5825	1035	3020	54	967.2	949.9	3.07	14.22	98.21	0.32	98.53	
125.0	5810	1035	3120	56	994.9	977.1	3.19	14.67	98.21	0.32	98.53	
130.0	5800	1030	3360	64	1071.5	1051.1	3.62	16.78	98.10	0.34	98.43	
140.0	5775	1030	3440	76	1092.3	1068.1	4.30	19.83	97.79	0.39	98.18	
150.0	5775	1035	3640	81	1155.8	1130.0	4.61	21.11	97.77	0.40	98.17	
160.0	5750	1030	3810	91	1204.5	1175.7	5.15	23.62	97.61	0.43	98.04	
175.0	5825	1030	3860	108	1236.2	1201.0	6.12	28.47	97.20	0.49	97.70	
180.0	5800	1030	3990	115	1272.4	1235.7	6.51	30.16	97.12	0.51	97.63	
182.0	5800	1030	3900	118	1243.7	1206.1	6.68	30.95	95.97	0.54	97.51	
183.0	5800	1030	4290	119	1368.0	1330.1	6.74	31.21	97.23	0.49	97.72	
184.0	5800	1030	4370	119	1393.6	1355.6	6.74	31.21	97.28	0.48	97.76	
190.0	5800	1030	4120	126	1313.8	1273.7	7.14	33.04	95.94	0.54	97.48	
195.0	5825	1030	4170	134	1335.5	1292.6	7.59	35.33	96.79	0.57	97.35	
205.0	5800	1030	3980	146	1269.2	1222.6	8.27	38.29	95.33	0.65	96.98	
210.0	5800	1030	3790	150	1208.6	1160.8	8.49	39.34	95.04	0.70	96.75	
211.0	6350	1015	3790	150	1323.2	1270.8	8.37	44.00	95.04	0.63	96.67	
213.0	6350	1015	3810	150	1330.2	1277.8	8.37	44.00	96.06	0.63	96.69	
214.0	6375	1015	3750	150	1314.4	1261.8	8.37	44.21	96.00	0.64	96.64	
215.0	4325	1065	3360	152	799.0	762.8	8.90	27.24	95.48	1.11	96.59	
216.0	4325	1065	3240	151	770.5	734.5	8.84	27.07	95.34	1.15	96.49	
217.0	4325	1065	3230	151	768.1	732.2	8.84	27.07	95.33	1.15	96.48	
218.0	4325	1065	3260	186	775.2	731.0	10.89	33.34	94.29	1.40	95.70	
219.0	4325	1065	2600	74	618.3	600.7	4.33	13.26	97.15	0.70	97.85	
220.0	4325	1065	2600	149	618.3	582.0	8.72	26.71	94.27	1.41	95.68	
225.0	4325	1065	3080	150	732.4	696.7	8.78	26.89	95.13	1.20	96.33	
230.0	4325	1065	3290	148	782.3	747.2	8.67	26.53	95.50	1.11	96.61	

**TABLE A-25. SUMMARY OF CALCULATED NO_X MASS FLOW RATES AND
CONTROL EFFICIENCIES FOR INSTANTANEOUS FLOW
AND CONCENTRATION DATA FOR TEST -- 9 (CONTINUED)**

HERCULES INC., RUN 9, INLET HV-23, OUTLET HV-13 UNIT B 1017-1503 3/13/75

TIME INTO CYCLE (MIN)	INLET FLOW (SCFM)	REGEN. FLOW (SCFM)	INLET CONC. (PPM)	OUTLET CONC. (PPM)	MASS RATE (G/MIN)	MASS FLOW (G/MIN)	MASS RATE (G/MIN)	MASS FLOW (G/MIN)	% REDUC. OF NOX ADS.	% REDUC. OF NOX DUE TO REGEN.	% REDUC. OF NOX REGEN.
235.0	4325	1065	3640	149	865.6	830.1	8.72	26.71	95.91	1.01	96.91
240.0	4325	1065	3630	151	863.2	827.3	8.84	27.07	95.84	1.02	96.86
244.0	4325	1065	3090	158	734.6	697.2	9.25	28.32	94.89	1.26	96.15
248.0	4325	1065	3080	160	732.4	694.4	9.37	28.68	94.81	1.28	96.08
251.0	4325	1065	3470	166	825.1	785.7	9.72	29.75	95.22	1.18	96.39
255.0	6125	1190	4050	174	1363.9	1305.3	11.38	47.21	95.70	0.83	96.54
261.0	6125	1200	4260	189	1434.6	1371.0	12.47	51.18	95.56	0.87	96.43
264.0	6125	1140	4220	194	1421.1	1355.8	12.16	53.17	95.40	0.86	96.26
266.0	6075	1065	2850	195	951.9	886.8	11.42	53.71	93.16	1.20	94.36
267.0	6075	1035	2850	200	951.9	885.1	11.38	55.42	92.98	1.20	94.18
272.0	6050	1025	2560	201	851.6	784.7	11.33	55.53	92.15	1.33	93.48
280.0	6225	1025	2160	192	739.3	673.6	10.82	54.89	91.11	1.46	92.57
283.0	6225	1025	2060	188	705.1	640.7	10.59	53.75	90.87	1.50	92.38

TABLE A-26. SUMMARY OF NO_X MASS LOADING, AVERAGE
CONTROL EFFICIENCY AND AVERAGE CONCENTRATION
OF NO_X EMITTED FOR INTERVALS DURING TEST -- 9

HERCULES INC., RUN 9, INLET HV-23, OUTLET HV-13 UNIT B 1017-1503 3/13/75

INTERVAL JF CYCLE (MIN)	NOX IN DURING INTERVAL (GRAMS)	NOX ADSORBED DURING INTERVAL (GRAMS)	NOX REGEN. DURING INTERVAL (GRAMS)	NOX EMITTED DURING INTERVAL (GRAMS)	PERCENT OF NOX ADSORBED DURING INTERVAL	PERCENT NOX FOR REGEN. DURING INTERVAL	PERCENT REDUC. OF NOX DURING INTERVAL	AVERAGE PPM OF NOX EMIT. DURING INTERVAL
0.0- 13.0	5808.3	5678.2	31.29	99.33	97.75	0.54	98.29	43
13.0- 18.0	2222.4	2166.2	13.45	42.70	97.47	0.61	98.08	47
18.0- 22.0	1759.0	1707.9	12.23	38.83	97.10	0.70	97.79	54
22.0- 26.0	1486.5	1440.7	12.80	33.07	96.91	0.86	97.78	57
26.0- 28.0	604.4	586.5	6.06	11.86	97.04	1.00	98.04	54
28.0- 32.0	1193.4	1161.0	10.99	21.44	97.28	0.92	98.20	48
32.0- 37.0	1466.7	1431.6	11.89	23.21	97.61	0.81	98.42	42
37.0- 43.0	1750.0	1711.4	13.08	25.53	97.79	0.75	98.54	39
43.0- 58.0	4763.6	4675.8	29.73	58.02	98.16	0.62	98.78	35
58.0- 73.0	6384.2	6280.1	26.82	77.21	98.37	0.42	98.79	31
73.0- 78.0	2452.2	2409.6	8.68	33.97	98.26	0.35	98.61	30
78.0- 81.0	1209.2	1186.3	5.11	16.73	98.19	0.42	98.62	30
81.0- 83.0	634.2	622.1	3.40	8.64	98.10	0.54	98.64	30
83.0- 85.0	596.0	584.0	3.40	8.60	97.99	0.57	98.56	30
85.0- 86.0	283.0	277.0	1.70	4.28	97.89	0.60	98.49	30
86.0- 87.0	276.0	270.1	1.70	4.20	97.86	0.62	98.48	30
87.0- 88.0	383.2	375.2	1.69	6.25	97.93	0.44	98.37	30
88.0- 93.0	2794.0	2743.1	8.39	42.54	98.18	0.30	98.48	30
93.0-103.0	7849.2	7727.5	20.99	100.71	98.45	0.27	98.72	37
103.0-108.0	4657.8	4586.7	12.69	58.42	98.47	0.27	98.75	45
108.0-120.0	11356.7	11166.4	33.80	156.44	98.32	0.30	98.62	50
120.0-125.0	4905.4	4817.5	15.65	72.23	98.21	0.32	98.53	55
125.0-130.0	5166.1	5070.4	17.03	78.64	98.15	0.33	98.48	60
130.0-145.0	16228.1	15894.0	59.46	274.59	97.94	0.37	98.31	70
145.0-150.0	5627.1	5495.4	22.28	102.34	97.78	0.40	98.18	78
153.0-160.0	11801.4	11528.9	48.81	223.63	97.69	0.41	98.11	86
160.0-175.0	18305.5	17830.3	84.52	390.66	97.40	0.46	97.87	100
175.0-183.0	6271.5	6093.4	31.57	146.58	97.16	0.50	97.66	111
183.0-182.0	2516.1	2441.8	13.20	61.11	97.05	0.52	97.57	116
182.0-183.0	1305.9	1268.1	6.71	31.08	97.11	0.51	97.62	118
183.0-184.0	1380.8	1342.9	6.74	31.21	97.25	0.49	97.74	119
184.0-190.0	8122.2	7887.8	41.62	192.76	97.11	0.51	97.63	123
190.0-195.0	6623.4	6415.6	36.81	170.93	96.86	0.56	97.42	130
195.0-205.0	13023.5	12576.2	79.28	368.09	96.56	0.61	97.17	140
205.0-210.0	6194.5	5958.5	41.91	14.07	96.19	0.68	96.87	148
210.0-211.0	1265.9	1215.8	8.43	41.67	96.04	0.67	96.71	150
211.0-213.0	2653.4	2548.7	16.74	88.00	96.05	0.63	96.68	150
213.0-214.0	1322.3	1269.8	8.37	44.10	96.03	0.63	96.66	150
214.0-215.0	1056.7	1012.3	8.64	35.72	95.80	0.82	96.62	151
215.0-216.0	784.7	748.7	8.87	27.15	95.41	1.13	96.54	151
215.0-217.0	769.3	733.4	8.84	27.07	95.33	1.15	96.48	151
217.0-218.0	771.6	731.6	9.87	30.20	94.81	1.28	96.09	168
218.0-219.0	696.7	665.8	7.61	23.30	95.56	1.09	96.66	130
219.0-220.0	618.3	591.8	6.53	19.99	95.71	1.06	96.77	111
220.0-225.0	3376.7	3198.9	43.77	133.98	94.74	1.30	96.03	149
225.0-230.0	3786.9	3609.7	43.62	133.53	95.32	1.15	96.47	149
230.0-235.0	4119.8	3943.2	43.48	133.09	95.71	1.06	96.77	148

TABLE A-26. SUMMARY OF NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED FOR INTERVALS DURING TEST -- 9 (CONTINUED)

HERCULES INC., RUN 9, INLET HV-23, OUTLET HV-13 UNIT 3 1017-1503 3/13/75

1
461

INTERVAL OF CYCLE (MIN)	NOX IN INTERVAL (GRAMS)	NOX ADSORBED DURING INTERVAL (GRAMS)	NOX REGEN. DURING INTERVAL (GRAMS)	NOX EMITTED DURING INTERVAL (GRAMS)	PERCENT OF NOX EMITTED ADSORBED DURING INTERVAL	PERCENT NOX FOR REGEN. DURING INTERVAL	PERCENT REDUC. OF NOX DURING INTERVAL	AVERAGE PPM OF NOX EMIT. DURING INTERVAL
235.0-240.0	4321.9	4143.6	43.92	134.43	95.87	1.02	96.89	150
240.0-244.0	3196.0	3049.0	36.19	110.77	95.40	1.13	96.53	154
244.0-248.0	1467.2	1391.6	18.62	57.00	94.85	1.27	96.12	159
248.0-250.0	3115.1	2963.1	38.18	116.86	95.02	1.23	96.25	163
250.0-253.0	5472.6	5227.4	52.76	192.41	95.52	0.96	96.48	171
253.0-260.0	6996.2	6690.6	59.64	245.98	95.63	0.85	96.48	181
260.0-264.0	5711.5	5453.5	49.26	208.70	95.48	0.86	96.35	192
264.0-266.0	2373.1	2242.6	23.58	106.89	94.50	0.99	95.50	195
266.0-267.0	951.9	886.0	11.40	54.57	93.07	1.20	94.27	198
267.0-272.0	4508.7	4174.6	56.77	277.38	92.59	1.26	93.85	200
272.0-280.0	6363.3	5833.0	88.59	441.70	91.67	1.39	93.06	196
280.0-283.0	2166.5	1971.4	32.12	162.97	91.00	1.48	92.48	190

TABLE A-27. CUMULATIVE NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED DURING TEST -- 9

HERCULES INC., RUN 9, INLET HV-23, OUTLET HV-13 UNIT B 1017-1503 3/13/75

TIME INTO CYCLE (MIN)	TOTAL NOX (GRAMS)	TOTAL NOX (GRAMS)	NOX USED FOR REGEN. (GRAMS)	TOTAL NOX EMIT. (GRAMS)	% NOX REDUC. DUE TO ADS.	% NOX REDUC. DUE TO REGEN.	Avg. % OF NOX EMIT.	Avg. PPM
0								
13.0	5808.8	5678.2	31.3	99.3	97.75	0.54	98.29	42
18.0	8031.2	7844.4	44.7	142.0	97.67	0.56	98.23	44
22.0	9790.2	9552.3	57.0	180.9	97.57	0.58	98.15	46
26.0	11276.7	10993.0	69.8	213.9	97.48	0.62	98.10	47
28.0	11881.1	11579.5	75.8	225.8	97.46	0.64	98.10	47
32.0	13074.5	12740.4	86.8	247.2	97.45	0.66	98.11	48
37.0	14541.2	14172.0	98.7	270.4	97.46	0.68	98.14	47
43.0	16291.2	15883.4	111.8	296.0	97.50	0.69	98.18	46
56.0	21954.8	20559.3	141.5	354.0	97.65	0.67	98.32	44
73.0	27438.9	26839.4	168.3	431.2	97.81	0.61	98.43	41
78.0	29691.2	29249.0	177.0	465.2	97.85	0.59	98.44	40
81.0	31099.4	30435.3	182.1	481.9	97.86	0.59	98.45	39
83.0	31733.5	31057.4	185.5	490.5	97.87	0.58	98.45	39
85.0	32329.5	31641.4	188.9	499.1	97.87	0.58	98.46	39
86.0	32612.5	31918.5	190.6	503.4	97.87	0.58	98.46	39
87.0	32888.6	32188.6	192.3	507.6	97.87	0.58	98.46	39
88.0	33271.7	32563.9	194.0	513.9	97.87	0.58	98.46	39
93.0	36065.7	35306.9	202.4	556.4	97.90	0.56	98.46	38
103.0	43914.9	43034.4	223.4	657.1	97.99	0.51	98.50	38
108.0	48572.7	47621.0	236.1	715.5	98.04	0.49	98.53	38
120.0	59929.3	58787.5	269.9	872.0	98.09	0.45	98.55	40
125.0	64834.7	63665.0	285.5	944.2	98.10	0.44	98.54	41
130.0	70000.8	68675.4	302.6	1022.8	98.11	0.43	98.54	42
145.0	86228.8	84569.4	362.0	1297.4	98.08	0.42	98.50	46
150.0	91848.9	90004.8	384.3	1399.8	98.06	0.42	98.48	47
167.0	103650.2	101593.7	433.1	1623.4	98.02	0.42	98.43	50
175.0	121955.8	119424.1	517.6	2014.1	97.92	0.42	98.35	56
180.0	128227.3	125517.4	549.2	2160.6	97.89	0.43	98.31	57
182.0	130743.3	127959.2	562.4	2221.7	97.87	0.43	98.30	58
183.0	132049.2	129227.3	569.1	2252.8	97.86	0.43	98.29	59
184.0	133430.0	130570.1	575.9	2284.0	97.86	0.43	98.29	59
199.0	141552.2	138457.9	617.5	2476.8	97.81	0.44	98.25	62
199.0	148175.6	144873.6	654.3	2647.7	97.77	0.44	98.21	64
205.0	161199.1	157449.7	733.6	3015.8	97.67	0.46	98.13	68
210.0	167393.5	163408.2	775.5	3209.9	97.62	0.46	98.08	71
211.0	168659.5	164624.0	783.9	3251.6	97.61	0.46	98.07	71
213.0	171312.9	167172.7	800.7	3339.6	97.58	0.47	98.05	72
214.0	172635.2	168442.5	809.0	3383.7	97.57	0.47	98.04	73
215.0	173691.9	169454.9	817.7	3419.4	97.56	0.47	98.03	73
216.0	174476.6	170203.6	826.5	3446.5	97.55	0.47	98.02	73
217.0	175245.9	170936.9	835.4	3473.6	97.54	0.48	98.02	74
218.0	176017.5	171668.5	845.2	3503.8	97.53	0.48	98.01	74
219.0	176714.3	172334.3	852.9	3527.1	97.52	0.48	98.00	74
222.0	177332.5	172926.1	859.4	3547.1	97.52	0.48	98.00	74
225.0	180709.2	176125.0	903.2	3681.1	97.46	0.50	97.96	76
230.0	184496.1	179734.7	946.8	3814.6	97.42	0.51	97.93	77

TABLE A-27. CUMULATIVE NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED DURING TEST -- 9 (CONTINUED)

HERCULES INC., RUN 9, INLET HV-23, OUTLET HV-13 UNIT 3 1017-1503 3/13/75

TIME INTO CYCLE (MIN)	TOTAL NOX IN (GRAMS)	TOTAL NOX ADS. (GRAMS)	NOX USED FOR REGEN. (GRAMS)	TOTAL NOX EMIT. (GRAMS)	% REDUC. DUE TO ADS.	% REDUC. DUE TO REGEN.	Avg. % OF NOX NOX EMIT.	Avg. PPM
235.0	188615.9	183678.0	990.3	3947.7	97.38	0.53	97.91	78
240.0	192937.3	187821.5	1034.2	4082.1	97.35	0.54	97.88	79
244.0	196133.3	190870.5	1070.4	4192.9	97.32	0.55	97.86	81
248.0	197631.0	192262.1	1089.0	4249.9	97.30	0.55	97.85	81
253.0	200716.1	195222.2	1127.2	4366.8	97.26	0.56	97.82	82
255.0	206188.7	200449.6	1179.9	4559.2	97.22	0.57	97.79	84
261.0	213184.9	207140.2	1239.6	4805.1	97.16	0.58	97.75	86
264.0	218896.4	212593.7	1288.8	5013.8	97.12	0.59	97.71	88
265.0	221269.4	214836.3	1312.4	5120.7	97.09	0.59	97.69	89
267.0	222221.4	215722.3	1323.8	5175.3	97.08	0.60	97.67	90
272.0	226730.1	219896.8	1380.6	5452.7	96.99	0.61	97.60	93
280.0	233093.4	225729.9	1469.2	5894.4	96.84	0.63	97.47	96
283.0	235259.9	227701.3	1501.3	6057.4	96.79	0.64	97.43	98

**TABLE A-28. SUMMARY OF CALCULATED NO_X MASS FLOW RATES AND
CONTROL EFFICIENCIES FOR INSTANTANEOUS FLOW
AND CONCENTRATION DATA FOR TEST -- 10**

HERCULES INC., RUN 10, INLET HV-23, DUTLET HV-13 UNIT A 1503-1905 3/13/75

TIME INTJ CYCLE (MIN)	INLET FLOW (SCFM)	REGEN. FLOW (SCFM)	INLET CONC. (PPM)	OUTLET CONC. (PPM)	MASS RATE (G/MIN)	MASS FLOW (G/MIN)	MASS RATE (G/MIN)	MASS FLOW (G/MIN)	MASS RATE (G/MIN)	% REDUC. OF NOX DUE TO ADSORB.	% REDUC. OF NOX DUE TO REGEN.	% REDUC. OF NOX
0.0	6225	1025	2060	188	705.1	640.7	10.59	53.75	90.87	1.50	92.38	
1.0	5925	1025	2060	116	671.1	633.3	6.54	31.25	94.37	0.97	95.34	
6.0	5950	1025	2510	89	821.1	792.0	5.02	24.10	96.45	0.61	97.07	
7.0	5950	1025	2630	89	860.4	831.3	5.02	24.10	96.62	0.58	97.20	
12.0	5925	1025	3100	119	1009.9	971.1	6.71	32.06	95.16	0.66	96.83	
14.0	5925	1025	2970	145	967.5	920.3	8.17	39.06	95.12	0.84	95.96	
18.0	5950	1025	3080	124	1007.6	967.0	6.99	33.58	95.97	0.69	95.67	
20.0	5950	1025	2910	95	952.0	920.9	5.35	25.72	96.74	0.56	97.30	
21.0	5950	1025	2880	85	942.2	914.4	4.79	23.02	97.05	0.51	97.56	
22.0	5950	1025	2880	79	942.2	916.3	4.45	21.39	97.26	0.47	97.73	
25.0	5975	1025	3050	65	1002.0	980.6	3.66	17.69	97.87	0.37	98.23	
27.0	5975	1025	2980	66	979.0	957.3	3.72	17.96	97.79	0.38	98.17	
32.0	6000	1025	2850	56	940.2	921.7	3.16	15.32	98.04	0.34	98.37	
33.0	6013	1025	2990	56	986.4	967.9	3.16	15.32	98.13	0.32	98.45	
34.0	6000	1025	2720	55	897.3	879.2	3.10	15.04	97.98	0.35	98.32	
42.0	6075	1025	2860	54	955.3	937.2	3.04	14.99	98.11	0.32	98.43	
48.0	6075	1025	3000	51	1032.0	985.0	2.87	14.16	98.30	0.29	98.59	
50.0	6075	1025	2850	51	951.9	934.9	2.87	14.16	98.21	0.30	98.51	
51.0	6075	1025	2980	51	995.4	978.3	2.87	14.16	98.29	0.29	98.58	
53.0	6075	1025	3030	50	1012.1	995.4	2.82	13.88	98.35	0.28	98.63	
57.0	6075	1025	2910	49	972.0	955.6	2.76	13.61	98.32	0.28	98.60	
63.0	6075	1025	2960	51	988.7	971.6	2.87	14.16	98.28	0.29	98.57	
66.0	6075	1025	3100	55	1035.4	1017.1	3.10	15.27	98.23	0.30	98.53	
68.0	6075	1025	3020	59	1008.7	989.0	3.33	16.38	98.05	0.33	98.38	
72.0	6103	1025	3110	62	1043.1	1022.3	3.49	17.30	98.01	0.33	98.34	
78.0	6103	1025	2860	70	959.2	935.7	3.94	19.53	97.55	0.41	97.96	
82.0	6100	1025	2950	76	989.4	963.9	4.28	21.21	97.42	0.43	97.86	
84.0	6100	1025	2900	78	972.6	946.5	4.40	21.76	97.31	0.45	97.76	
85.0	6100	1025	3040	79	1019.6	993.1	4.45	22.04	97.40	0.44	97.84	
87.0	6075	1025	2990	81	998.7	971.6	4.56	22.49	97.29	0.46	97.75	
92.0	6075	1025	2920	85	975.3	946.9	4.79	23.60	97.09	0.49	97.58	
93.0	6075	1025	2940	89	982.0	952.3	5.02	24.71	96.97	0.51	97.48	
95.0	6075	1025	2710	94	915.2	873.8	5.30	26.10	95.53	0.59	97.12	
98.0	6075	1025	2710	96	905.2	873.1	5.41	26.66	96.46	0.60	97.06	
102.0	6075	1025	2950	101	985.3	951.6	5.69	28.04	95.58	0.58	97.15	
117.0	6103	1025	3160	119	1059.8	1019.9	6.71	33.20	95.23	0.63	96.87	
132.0	6103	1075	3200	132	1073.2	1029.0	7.80	36.47	95.88	0.73	96.60	
137.0	6125	1025	3120	136	1050.7	1004.9	7.66	38.14	95.64	0.73	96.37	
147.0	6150	1025	3050	142	1031.3	983.3	8.00	40.01	95.34	0.78	96.12	
152.0	6150	1025	3060	146	1034.7	985.3	8.23	41.14	95.23	0.80	96.02	
162.0	6100	1025	3210	159	1076.6	1023.3	8.96	44.37	95.05	0.83	95.88	
167.0	6075	1025	3160	165	1055.5	1000.4	9.30	45.81	94.78	0.88	95.66	
173.0	6075	1025	3120	175	1042.1	983.7	9.86	48.59	94.39	0.95	95.34	
177.0	6075	1025	3200	179	1068.8	1009.1	10.09	49.70	94.41	0.94	95.35	
187.0	6075	1025	3380	196	1129.0	1063.5	11.05	54.42	94.20	0.98	95.18	
188.0	6075	1025	3480	198	1162.4	1096.2	11.16	54.98	94.31	0.96	95.27	
192.0	6050	1025	3380	208	1124.3	1055.1	11.72	57.47	93.85	1.04	94.89	

TABLE A-28. SUMMARY OF CALCULATED NO_X MASS FLOW RATES AND
CONTROL EFFICIENCIES FOR INSTANTANEOUS FLOW
AND CONCENTRATION DATA FOR TEST -- 10 (CONTINUED)

HERCULES INC., RUN 10, INLET HV-23 OUTLET HV-13 UNIT A 1503-1905 3/13/75

TIME INTJ CYCLE (MIN)	INLET FLOW (SCFM)	REGEN. FLOW (SCFM)	INLET CONC. (PPM)	OUTLET CONC. (PPM)	MASS RATE (G/MIN)	MASS FLOW	MASS FLOW	MASS FLOW	MASS REDUC. OF NOX	% REDUC.	% REDUC.
						IN ADS.	REGEN. RATE (G/MIN)	EMIT. (G/MIN)	DUE TO ADS.	DUE TO REGEN.	OF NOX
207.0	6075	1025	3500	230	1169.0	1092.2	12.96	63.86	93.43	1.11	94.54
217.0	6050	1025	3610	245	1200.8	1119.3	13.81	67.69	93.21	1.15	94.36
223.0	6050	1025	3580	254	1190.8	1106.4	14.31	70.18	92.91	1.20	94.11
225.0	6050	1025	3560	258	1184.2	1098.4	14.54	71.28	92.75	1.23	93.98
231.0	6050	1025	3520	264	1170.9	1083.1	14.88	72.94	92.50	1.27	93.77
237.0	6050	1035	3600	264	1197.5	1109.7	15.02	72.79	92.67	1.25	93.92
242.0	6050	1025	3520	268	1170.9	1081.7	15.10	74.04	92.39	1.29	93.68

TABLE A-29. SUMMARY OF NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED FOR INTERVALS DURING TEST -- 10

HERCULES INC., RUN 10, INLET HV-23, OUTLET HV-13 UNIT A 1503-1905 3/13/75

INTERVAL OF CYCLE (MIN)	NOX IN DURING INTERVAL (GRAMS)	NOX ADSORBED DURING INTERVAL (GRAMS)	NOX REGEN. DURING INTERVAL (GRAMS)	NOX EMITTED DURING INTERVAL (GRAMS)	PERCENT OF NOX ADSORBED DURING INTERVAL	PERCENT NOX FOR REGEN. DURING INTERVAL	PERCENT REDUC. OF NOX DURING INTERVAL	AVERAGE PPM OF NOX EMIT. DURING INTERVAL
0.0- 1.0	688.1	637.0	8.57	42.50	92.58	1.24	93.82	153
1.0- 6.0	3730.5	3563.2	28.88	130.38	95.52	0.77	96.29	102
5.0- 7.0	840.7	811.6	5.02	24.10	96.54	0.60	97.13	89
7.0- 12.0	4675.6	4505.9	29.31	140.40	96.37	0.63	97.00	104
12.0- 14.0	1977.4	1891.4	14.88	71.12	95.65	0.75	96.40	132
14.0- 18.0	3953.2	3774.6	30.32	145.28	95.55	0.77	96.32	134
18.0- 20.0	1959.6	1887.9	12.34	59.30	96.34	0.63	96.97	109
20.0- 21.0	947.1	917.6	5.07	24.37	96.89	0.54	97.43	90
21.0- 22.0	942.2	915.3	4.62	22.20	97.15	0.49	97.64	82
22.0- 25.0	2915.2	2845.4	12.17	58.62	97.57	0.42	97.99	72
25.0- 27.0	1980.7	1937.9	7.38	35.65	97.83	0.37	98.20	65
27.0- 32.0	4797.9	4697.5	17.19	83.20	97.91	0.36	98.27	61
32.0- 33.0	963.3	944.8	3.16	15.32	98.08	0.33	98.41	56
33.0- 34.0	941.3	923.5	3.13	15.18	98.06	0.33	98.39	55
34.0- 42.0	7410.3	7265.6	24.57	120.15	98.05	0.33	98.38	54
42.0- 48.0	5871.9	5766.7	17.75	87.46	98.21	0.30	98.51	53
48.0- 50.0	1954.0	1919.9	5.75	28.32	98.26	0.29	98.55	51
50.0- 51.0	973.6	956.6	2.87	14.16	98.25	0.30	98.55	51
51.0- 53.0	2007.4	1973.7	5.69	28.04	98.32	0.28	98.60	50
53.0- 57.0	3963.1	3901.9	11.16	54.98	98.33	0.28	98.61	50
57.0- 63.0	5882.0	5781.8	16.91	83.30	98.30	0.29	98.58	50
63.0- 66.0	3036.2	2983.1	8.96	44.15	98.25	0.30	98.55	53
66.0- 68.0	2044.2	2006.1	6.42	31.65	98.14	0.31	98.45	57
68.0- 72.0	4103.5	4022.5	13.64	67.36	98.03	0.33	98.36	61
72.0- 73.0	6076.8	5874.0	22.32	110.50	97.79	0.37	98.16	66
73.0- 82.0	3897.2	3799.3	16.46	81.48	97.49	0.42	97.91	73
82.0- 84.0	1962.0	1910.4	8.68	42.97	97.37	0.44	97.81	77
84.0- 85.0	996.1	969.8	4.42	21.90	97.36	0.44	97.80	78
85.0- 87.0	2019.3	1964.7	9.02	44.53	97.35	0.45	97.79	80
87.0- 92.0	4935.0	4798.4	23.39	115.23	97.19	0.47	97.67	83
92.0- 93.0	978.7	949.6	4.90	24.16	97.03	0.50	97.53	87
93.0- 96.0	2830.8	2739.1	15.47	76.22	96.76	0.55	97.31	91
95.0- 98.0	1810.3	1746.9	10.71	52.75	96.49	0.59	97.09	95
98.0- 102.0	3781.0	3649.4	22.20	109.40	96.52	0.59	97.11	99
102.0-117.0	15338.7	14786.3	92.99	459.36	96.40	0.61	97.01	110
117.0-132.0	15998.0	15366.6	108.81	522.55	96.05	0.68	96.73	125
132.0-137.0	5339.8	5084.7	38.67	186.51	95.76	0.73	96.49	134
137.0-147.0	10410.1	9941.0	78.33	390.74	95.49	0.75	96.25	139
147.0-152.0	5165.0	4921.6	40.58	202.88	95.29	0.79	96.07	144
152.0-162.0	10556.4	10043.0	85.94	427.53	95.14	0.81	95.95	152
162.0-167.0	5330.2	5059.1	45.65	225.45	94.91	0.86	95.77	162
167.0-173.0	6292.8	5952.1	57.48	283.21	94.59	0.91	95.50	170
173.0-177.0	4221.9	3985.4	39.90	196.58	94.40	0.95	95.34	177
177.0-187.0	10989.0	10362.7	105.67	520.61	94.30	0.96	95.26	188
187.0-188.0	1145.7	1079.9	11.10	54.70	94.26	0.97	95.23	197
188.0-192.0	4573.4	4302.7	45.76	224.89	94.08	1.00	95.08	203
192.0-207.0	17200.2	16105.1	185.13	909.96	93.63	1.08	94.71	219

TABLE A-29. SUMMARY OF NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED FOR INTERVALS DURING TEST -- 10 (CONTINUED)

HERCULES INC., RUN 10, INLET HV-23, OUTLET HV-13 UNIT A 1503-1905 3/13/75

152
1

NOX INTERVAL OF CYCLE (MIN)	NOX IN DURING INTERVAL (GRAMS)	NOX ADSORBED DURING INTERVAL (GRAMS)	NOX REGEN. DURING INTERVAL (GRAMS)	NOX EMITTED DURING INTERVAL (GRAMS)	PERCENT OF NOX EMITTED DURING INTERVAL	PERCENT NOX FOR ADSORBED REGEN. DURING INTERVAL	PERCENT REDUC. OF NOX DURING INTERVAL	AVERAGE PPM OF NOX EMIT. DURING INTERVAL
207.0-217.0	11849.3	11057.7	133.85	657.75	93.32	1.13	94.45	237
217.0-223.0	7175.0	6677.0	84.36	413.59	93.06	1.18	94.24	250
223.0-225.0	2375.0	2204.7	28.85	141.46	92.83	1.21	94.04	256
225.0-231.0	7065.2	6544.3	88.25	432.66	92.63	1.25	93.88	261
231.0-237.0	7105.1	6578.2	89.70	437.20	92.58	1.26	93.85	264
237.0-242.0	5921.0	5478.5	75.32	367.09	92.53	1.27	93.80	266

TABLE A-30. CUMULATIVE NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED DURING TEST -- 10

HERCULES INC., RUN 10, INLET HV-23, OUTLET HV-13 UNIT A 1503-1905 3/13/75

TIME INTD CYCLE (MIN)	TOTAL NOX IN ADS. (GRAMS)	TOTAL NOX USED FOR REGEN. (GRAMS)	TOTAL NOX EMIT. (GRAMS)	% REDUC. DUE TO ADS.	% REDUC. DUE TO REGEN.	Avg. OF NOX EMIT.	Avg. PPM
0							
1.0	688.1	637.0	8.6	42.5	92.58	1.24	93.82 153
6.0	4418.6	4200.2	37.4	180.9	95.06	0.85	95.91 111
7.0	5259.3	5011.9	42.5	205.0	95.30	0.81	96.10 108
12.0	9934.9	9517.8	71.8	345.4	95.80	0.72	96.52 106
14.0	11312.3	11409.2	86.6	416.5	95.78	0.73	96.50 110
19.0	15382.6	15163.8	117.0	561.8	95.72	0.74	96.46 115
29.0	17822.1	17071.7	129.3	621.1	95.79	0.73	96.52 115
21.0	18769.2	17989.4	134.4	645.5	95.85	0.72	96.56 114
22.0	19711.4	18904.7	139.0	667.7	95.91	0.71	96.61 112
25.0	22627.5	21750.1	151.2	726.3	96.12	0.67	96.79 107
27.0	24609.5	23688.0	158.6	761.9	96.26	0.64	96.90 104
32.0	29406.4	28385.5	175.7	845.1	96.53	0.60	97.13 97
33.0	30369.7	29330.3	178.9	860.5	96.58	0.59	97.17 96
34.0	31311.5	30253.8	182.0	875.6	96.62	0.58	97.20 95
42.0	38721.8	37519.4	206.6	995.8	96.89	0.53	97.43 87
43.0	44593.7	43286.1	224.4	1083.2	97.07	0.50	97.57 83
50.0	46547.7	45206.0	230.1	1111.6	97.12	0.49	97.61 81
51.0	47521.3	46162.6	233.0	1125.7	97.14	0.49	97.63 81
53.0	49528.7	48136.3	238.7	1153.8	97.19	0.48	97.67 80
57.0	53496.8	52038.2	249.8	1208.7	97.27	0.47	97.74 78
63.0	59378.8	57820.0	266.7	1292.0	97.37	0.45	97.82 75
66.0	62414.9	60803.1	275.7	1336.2	97.42	0.44	97.86 74
63.0	64459.1	62809.1	282.1	1367.8	97.44	0.44	97.88 73
72.0	68562.5	66831.7	295.8	1435.2	97.48	0.43	97.91 73
78.0	74569.4	72705.6	318.1	15+5.7	97.50	0.43	97.93 72
82.0	78466.6	76504.9	334.5	1627.2	97.50	0.43	97.93 72
84.0	80429.6	78415.3	343.2	1670.2	97.50	0.43	97.92 72
85.0	81424.7	79385.0	347.6	1692.1	97.49	0.43	97.92 72
87.0	83443.0	81349.8	356.6	1736.6	97.49	0.43	97.92 73
92.0	88378.0	86146.2	380.0	1851.8	97.47	0.43	97.90 73
93.0	89356.7	87095.8	384.9	1876.0	97.47	0.43	97.90 73
96.0	92187.4	89834.8	400.4	1952.2	97.45	0.43	97.88 74
98.0	93997.9	91581.7	411.1	2004.9	97.43	0.44	97.87 74
102.0	97778.8	95231.1	433.3	2114.3	97.39	0.44	97.84 75
117.0	113117.5	110017.5	526.3	2573.7	97.26	0.47	97.72 80
132.0	129115.5	125384.1	635.1	3096.3	97.11	0.49	97.60 85
137.0	134425.3	130468.7	673.8	3282.8	97.06	0.50	97.56 87
147.0	144835.3	140409.7	752.1	3673.5	96.94	0.52	97.46 90
152.0	150000.4	145331.3	792.7	3876.4	96.89	0.53	97.42 92
162.0	160556.8	155374.2	878.6	4303.9	96.77	0.55	97.32 96
167.0	165697.0	160433.3	924.3	4529.4	96.71	0.56	97.27 98
173.0	172179.8	166385.4	981.8	4812.6	96.63	0.57	97.20 100
177.0	176401.7	173370.9	1021.7	5009.2	96.58	0.58	97.16 102
187.0	187390.7	180733.6	1127.3	5529.8	96.45	0.60	97.05 107
189.0	188536.4	181813.5	1138.4	5584.5	96.43	0.60	97.04 107
192.0	193109.7	186116.2	1184.2	5809.3	96.38	0.61	96.99 109

TABLE A-30. CUMULATIVE NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED DURING TEST -- 10 (CONTINUED)

HERCULES INC., RUN 10, INLET HV-23, OUTLET HV-13 UNIT A 1503-1905 3/13/75

TIME INTD CYCLE (MIN)	TOTAL NOX IN (GRAMS)	TOTAL NOX USED FOR ADS.	% NOX REGEN.	TOTAL NOX EMIT. (GRAMS)	% REDUC. DUE TO ADS.	% REDUC. DUE TO REGEN.	Avg. OF NOX NOX EMIT.	Avg. PPM
207.0	210309.9	202221.3	1369.3	6719.3	96.15	0.65	96.81	117
217.0	222159.2	213279.0	1503.2	7377.1	96.00	0.68	96.68	123
223.0	229334.2	219556.0	1587.5	7790.6	95.91	0.69	96.60	126
225.0	231739.3	222160.8	1616.4	7932.1	95.88	0.70	96.58	127
231.0	238774.5	228705.1	1704.7	8364.8	95.78	0.71	96.50	131
237.0	245879.6	235283.3	1794.4	8802.0	95.69	0.73	96.42	134
242.0	251800.6	240761.9	1869.7	9169.0	95.62	0.74	96.36	137

TABLE A-31. SUMMARY OF CALCULATED NO_X MASS FLOW RATES AND
CONTROL EFFICIENCIES FOR INSTANTANEOUS FLOW
AND CONCENTRATION DATA FOR TEST -- 11

HERCULES INC., RUN 11, INLET HV-23, OUTLET HV-13 UNIT A 0711-1114 3/14/75

TIME INTO CYCLE (MIN)	INLET FLOW (SCFM)	REGEN. FLOW (SCFM)	INLET CONC. (PPM)	OUTLET CONC. (PPM)	MASS RATE (G/MIN)	MASS FLOW (G/MIN)	MASS RATE (G/MIN)	MASS FLOW (G/MIN)	% REDUC. OF NOX ADS.	% REDUC. OF NOX REGEN.	% REDUC. OF NOX NOX
0.0	5500	1020	3340	190	1010.0	952.6	10.66	46.80	94.31	1.05	95.37
3.0	5500	1020	3320	90	1004.0	976.7	5.05	22.17	97.29	0.50	97.79
4.0	5500	1015	3360	82	1016.1	991.3	4.58	20.22	97.56	0.45	98.01
6.0	5500	1015	3310	78	1000.9	977.4	4.35	19.23	97.64	0.43	98.08
14.0	5475	1020	3220	112	969.3	935.6	6.28	27.43	95.52	0.65	97.17
15.0	5475	1020	3220	124	969.3	932.0	6.95	30.37	96.15	0.72	96.87
19.0	5450	1020	3380	101	1012.8	982.5	5.66	24.60	97.01	0.56	97.57
23.0	5450	1020	3390	81	1015.8	991.5	4.54	19.73	97.61	0.45	98.06
34.0	5475	1020	3290	64	990.4	971.1	3.59	15.68	98.05	0.36	98.42
39.0	5475	1020	3280	61	987.4	969.0	3.42	14.94	98.14	0.35	98.49
49.0	5475	1020	3260	58	981.3	963.9	3.25	14.21	98.22	0.33	98.55
59.0	5475	1020	3200	58	963.3	945.8	3.25	14.21	98.19	0.34	98.53
64.0	5475	1020	3150	61	948.2	929.9	3.42	14.94	98.06	0.36	98.42
79.0	5450	1020	3120	79	934.9	911.2	4.43	19.24	97.47	0.47	97.94
94.0	5475	1020	3110	95	936.2	907.6	5.33	23.27	96.95	0.57	97.51
97.0	5475	1020	3100	99	933.2	903.4	5.55	24.25	96.81	0.59	97.40
109.0	5475	1020	3100	114	933.2	898.9	6.39	27.92	95.32	0.69	97.01
124.0	5475	1020	3130	128	942.2	903.7	7.18	31.35	95.91	0.76	96.67
139.0	5475	1020	3090	141	930.2	887.7	7.91	34.54	95.44	0.85	96.29
154.0	5475	1020	3080	156	927.2	880.2	8.75	38.21	94.94	0.94	95.88
160.0	5450	1020	3060	164	916.9	867.8	9.20	39.95	94.64	1.00	95.64
169.0	5425	1020	3060	178	912.7	859.6	9.98	43.11	94.18	1.09	95.28
184.0	5450	1020	3050	200	913.9	854.0	11.22	48.71	93.44	1.23	94.67
199.0	5475	1020	2990	219	900.1	834.1	12.28	53.64	92.68	1.36	94.04
214.0	5475	1020	2960	230	891.0	821.8	12.90	56.34	92.23	1.45	93.68
220.0	5475	1020	2960	235	891.0	820.3	13.18	57.56	92.06	1.48	93.54
229.0	5475	1020	2940	240	885.0	812.8	13.46	58.79	91.84	1.52	93.36
243.0	5475	1020	2880	246	866.9	792.9	13.80	60.26	91.46	1.59	93.05

TABLE A-32. SUMMARY OF NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED FOR INTERVALS DURING TEST -- 11

HERCULES INC., RUN 11, INLET HV-23, OUTLET HV-13 UNIT A 0711-1114 3/14/75

INTERVAL JF CYCLE (MIN)	NOX IN DURING INTERVAL (GRAMS)	NOX ADSORBED DURING INTERVAL (GRAMS)	NOX REGEN. DURING INTERVAL (GRAMS)	NOX EMITTED DURING INTERVAL (GRAMS)	PERCENT OF NOX ADSORBED DURING INTERVAL	PERCENT NOX FOR REGEN. DURING INTERVAL	PERCENT REDUC. JF NOX DURING INTERVAL	AVERAGE PPM OF NOX EMIT. DURING INTERVAL
0.0- 3.0	3021.0	2894.0	23.55	103.45	95.80	0.78	96.58	140
3.0- 4.0	1010.0	984.0	4.81	21.19	97.43	0.48	97.90	86
4.0- 6.0	2017.0	1968.6	8.93	39.45	97.63	0.44	98.04	80
6.0- 14.0	7880.9	7651.7	42.54	186.67	97.09	0.54	97.63	95
14.0- 15.0	969.3	933.8	6.62	28.90	96.34	0.68	97.02	118
15.0- 19.0	3964.2	3829.0	25.24	109.95	96.59	0.64	97.23	113
19.0- 23.0	4057.2	3948.2	20.41	88.66	97.31	0.50	97.81	91
23.0- 34.0	11034.0	10794.5	44.72	194.73	97.83	0.41	98.24	72
34.0- 39.0	4944.3	4850.2	17.53	76.54	98.10	0.35	98.45	62
39.0- 49.0	9843.5	9664.4	33.37	145.74	98.18	0.34	98.52	60
49.0- 59.0	9723.1	9548.5	32.53	142.07	98.20	0.33	98.54	58
59.0- 64.0	4778.7	4689.2	16.68	72.87	98.13	0.35	98.48	59
64.0- 79.0	14123.5	13808.2	58.89	256.38	97.77	0.42	98.18	70
79.0- 94.0	14033.2	13641.1	73.19	318.84	97.21	0.52	97.73	87
94.0- 97.0	2804.0	2715.4	16.32	71.28	96.88	0.58	97.46	97
97.0-109.0	11198.1	10813.4	71.67	313.04	96.56	0.64	97.20	106
109.0-114.0	14065.3	13519.0	101.79	444.57	96.12	0.72	96.84	121
124.0-139.0	14042.7	13435.4	113.14	494.17	95.68	0.81	96.48	134
139.0-154.0	13929.9	13259.3	124.92	545.61	95.19	0.90	96.08	148
154.0-160.0	5532.2	5243.9	53.84	234.47	94.79	0.97	95.76	160
160.0-169.0	8233.4	7773.3	86.31	373.75	94.41	1.05	95.46	171
169.0-184.0	13699.9	12852.2	158.99	688.68	93.81	1.16	94.97	189
184.0-199.0	13604.9	12661.0	176.23	767.67	93.06	1.30	94.36	210
199.0-214.0	13433.2	12419.5	188.85	824.84	92.45	1.41	93.86	224
214.0-220.0	5346.2	4926.3	78.23	341.69	92.15	1.46	93.61	232
220.0-229.0	7992.2	7348.7	119.87	523.56	91.95	1.50	93.45	238
229.0-243.0	12263.7	11239.6	190.79	833.29	91.65	1.56	93.21	243

TABLE A-33. CUMULATIVE NO_X MASS LOADING, AVERAGE CONTROL
EFFICIENCY AND AVERAGE CONCENTRATION OF NO_X
EMITTED DURING TEST -- 11

HERCULES INC., RUN 11, INLET HV-23, OUTLET HV-13 UNIT A 0711-1114 3/14/75

TIME INTO CYCLE (MIN)	TOTAL NOX IN (GRAMS)	TOTAL NOX ADS. (GRAMS)	USED FOR REGEN. (GRAMS)	TOTAL NOX EMIT. (GRAMS)	% REDUC. DUE TO ADS.	% REDUC. DUE TO REGEN.	Avg. % OF NOX	Avg. PPM OF NOX EMIT.
.....								
0								
3.0	3021.0	2894.0	23.6	103.5	95.80	0.78	96.58	140
4.0	4031.0	3878.0	28.4	124.6	96.20	0.70	96.91	126
6.0	6048.0	5846.6	37.3	164.1	96.67	0.62	97.29	111
14.0	13928.9	13498.3	79.8	350.8	96.91	0.57	97.48	102
15.0	14898.2	14432.1	86.4	379.7	96.87	0.58	97.45	103
19.0	18862.4	18261.1	111.7	489.6	96.81	0.59	97.40	105
23.0	22919.7	22209.3	132.1	578.3	96.90	0.58	97.48	103
34.0	33953.6	33003.8	176.8	773.0	97.20	0.52	97.72	93
39.0	38897.9	37854.0	194.3	849.6	97.32	0.50	97.82	89
49.0	48741.4	47518.4	227.7	995.3	97.49	0.47	97.96	83
59.0	58464.5	57066.8	260.2	1137.4	97.61	0.45	98.05	79
64.0	63243.2	61756.0	276.9	1210.2	97.65	0.44	98.09	77
79.0	77366.7	75564.2	335.8	1466.6	97.67	0.43	98.10	76
94.0	91399.3	89205.4	409.0	1785.4	97.60	0.45	98.05	78
97.0	94203.9	91921.8	425.3	1856.7	97.58	0.45	98.03	78
109.0	15431.9	102735.2	497.0	2169.8	97.47	0.47	97.94	81
124.0	119467.3	116254.2	598.8	2614.3	97.31	0.50	97.81	86
139.0	133510.0	129689.6	711.9	3108.5	97.14	0.53	97.67	91
154.0	147439.9	142948.9	836.8	3654.1	96.95	0.57	97.52	97
160.0	152972.1	143192.8	890.7	3888.6	96.88	0.58	97.46	99
169.0	161205.5	155966.2	977.0	4262.3	96.75	0.61	97.36	103
184.0	174905.4	168818.4	1136.0	4951.0	96.52	0.65	97.17	110
199.0	188510.3	181479.4	1312.2	5718.7	96.27	0.70	96.97	118
214.0	201943.5	193898.9	1501.1	6543.5	96.02	0.74	96.76	125
220.0	207289.6	196825.1	1579.3	6885.2	95.92	0.76	96.68	128
229.0	215281.3	206173.9	1699.2	7408.8	95.77	0.79	96.56	132
243.0	227545.5	217413.5	1890.0	8242.1	95.55	0.83	96.38	139

APPENDIX B

NO_X EMISSION DATA REPORTS FOR EPA METHOD NO. 7 TESTS

OXIDES OF NITROGEN (AS NO₂) DATA AND RESULTS

RUN ID	DATE	TIME	FLASK NO.	FLASK VOL ML	PRESSURES -- IN.HG				TEMP F		N MASS UG	FLOW RATE SCFM	NOX PPM	NOX RATE LB/HR
					INL BARO	FLASK VAC	FNL BARO	FNL FLAS	INL	FNL				
I-HV-12-1	3/5	1316	3	1965	29.75	26.50	29.76	0.50	75	71	7550	5700	2334	95.04
I-HV-12-2	3/5	1345	5	1955	29.74	26.65	29.77	4.90	74	70	6550	5700	2426	98.77
I-HV-12-3	3/5	1415	19	2116	29.72	26.60	29.78	0.05	75	70	8900	5975	2490	106.28
I-HV-12-4	3/5	1446	9	2053	29.71	26.60	29.77	0.60	75	73	7650	5975	2267	96.79
I-HV-12-5	3/5	1516	20	2069	29.71	26.70	29.73	0.20	70	81	10500	5975	3088	131.83
I-HV-12-6	3/5	1545	13	2071	29.70	26.60	29.73	0.0	73	76	10500	5675	3039	123.21
I-HV-12-7	3/5	1645	15	2064	29.68	26.65	29.72	0.05	68	75	10650	5650	3089	124.68
I-HV-12-8	3/5	1745	1	2039	29.66	26.60	29.76	0.85	71	71	7200	5700	2159	87.92
2-HV-12-9	3/6	1015	1	2039	29.78	26.40	29.65	0.45	75	74	6850	5575	2068	82.35
2-HV-12-10	3/6	1115	3	1965	29.77	26.60	29.64	5.85	73	73	7250	5725	2840	116.16
2-HV-12-11	3/6	1215	5	1955	29.76	26.65	29.64	1.95	73	73	9900	5725	3270	133.76
2-HV-12-12	3/6	1316	19	2116	29.75	26.50	29.63	0.05	74	73	11850	5650	3372	136.12
3-HV-12-13	3/6	1415	9	2053	29.73	26.35	29.61	1.75	74	73	8350	5875	2635	110.60
3-HV-12-14	3/6	1515	20	2069	29.73	26.40	29.60	1.05	74	72	10150	5850	3078	128.65
3-HV-12-15	3/6	1616	13	2071	29.71	26.50	29.61	0.45	75	73	9100	5875	2685	112.68
3-HV-12-16	3/6	1715	15	2064	29.70	26.45	29.58	6.10	73	74	6900	5325	2627	99.94
4-HV-12-17	3/7	0915	1	2039	29.65	26.45	29.83	2.10	74	67	6850	5700	2145	87.34
4-HV-12-18	3/7	1015	3	1965	29.63	26.65	29.84	0.90	73	65	5900	4475	1805	57.71
4-HV-12-19	3/7	1115	5	1955	29.61	26.25	29.84	4.85	72	65	11200	5700	4133	168.30
4-HV-12-20	3/6	1215	19	2116	29.61	26.35	29.85	1.75	72	64	14000	5775	4145	170.99

OXIDES OF NITROGEN (AS NO₂) DATA AND RESULTS

RUN ID	DATE	TIME	NO.	FLASK VOL ML	PRESSURES -- IN.HG			TEMP F		N MASS UG	FLOW RATE SCFM	NOX PPM	NOX RATE LB/HR
					INL BARO	FLASK VAC	FNL BARO	FNL FLAS	INL FNL				
5-HV-12-21	3/7	1316	9	2053	29.60	26.50	29.84	3.55	73 65	8600	5675	2817	114.21
5-HV-12-22	3/6	1415	20	2069	29.58	26.25	29.82	4.10	76 65	8200	5725	2757	112.78
5-HV-12-23	3/7	1517	13	2071	29.56	26.50	29.82	1.75	77 65	9000	5450	2708	105.42
5-HV-12-24	3/7	1615	15	2064	29.53	26.35	29.82	4.10	75 65	6850	5550	2295	90.98
5-HV-12-25	3/7	1658	6	2073	29.54	26.50	29.82	1.00	78 65	9800	5550	2857	113.28
6-HV-12-26	3/11	1415	1	2039	29.65	27.35	29.51	0.55	74 78	3650	4250	1076	32.67
6-HV-12-27	3/11	1445	3	1965	29.65	27.10	29.51	0.80	73 78	2300	4350	717	22.30
6-HV-12-28	3/11	1515	5	1955	29.62	26.75	29.50	0.20	75 78	3650	4350	1132	35.20
6-HV-12-29	3/11	1545	21	2080	29.62	26.60	29.53	7.50	77 78	4600	5175	1863	68.88
6-HV-12-30	3/11	1620	26	2055	29.61	26.65	29.53	0.70	74 78	2800	5200	844	31.36
6-HV-12-31	3/11	1645	20	2069	29.60	26.75	29.55	2.25	75 77	3450	5200	1090	40.51
6-HV-12-32	3/11	1715	8	2058	29.60	26.75	29.55	1.50	73 75	5150	5175	1582	58.48
6-HV-12-33	3/11	1745	15	2064	29.60	26.65	29.50	0.90	77 76	4750	5175	1431	52.90
7-HV-12-34	3/12	1023	1	2039	29.53	26.55	29.46	0.65	77 75	4750	4300	1435	44.10
7-HV-12-35	3/12	1117	3	1965	29.53	26.45	29.47	1.05	78 73	9000	4300	2866	88.04
7-HV-12-36	3/12	1215	5	1955	29.55	26.45	29.46	2.05	78 72	8550	4300	2846	87.44
7-HV-12-37	3/12	1316	19	2116	29.55	26.35	29.42	0.05	78 68	9500	4325	2689	83.09
8-HV-12-38	3/12	1430	22	2063	29.54	26.40	29.42	0.45	78 68	8150	5025	2398	86.09
8-HV-12-39	3/12	1516	20	2069	29.54	26.20	29.33	0.20	77 74	9550	5050	2842	102.54
8-HV-12-40	3/12	1615	8	2058	29.50	26.40	29.33	0.0	77 70	9600	5025	2801	100.55

OXIDES OF NITROGEN (AS NO₂) DATA AND RESULTS

RUN ID	DATE	TIME	NO.	FLASK VOL ML	PRESSURES -- IN.HG			TEMP F		N MASS UG	FLOW RATE SCFM	NOX PPM	NOX RATE LB/HR	
					INL BARO	FLASK BARO	FNL VAC	BARO	FLAS					INL
8-HV-12-41	3/12	1745	15	2064	29.48	26.35	29.32	0.40	76	71	8150	5025	2417	86.77
9-HV-12-42	3/13	1047	1	2039	29.44	26.35	29.56	2.90	70	59	3750	3040	1202	26.11
9-HV-12-43	3/13	1132	3	1965	29.43	26.25	29.59	3.30	68	58	5500	5000	1863	66.57
9-HV-12-44	3/13	1219	5	1955	29.41	26.35	29.63	3.60	70	59	9750	5825	3347	139.28
9-HV-12-45	3/13	1317	19	2116	29.39	26.30	29.65	2.25	73	59	11000	5825	3291	136.96
10HV-12-46	3/13	1530	22	2063	29.32	26.30	29.70	2.65	73	59	7200	5975	2236	95.45
10HV-12-47	3/13	1632	20	2069	29.32	26.35	29.70	1.35	77	59	5550	6075	1626	70.58
10HV-12-48	3/13	1732	8	2058	29.35	26.30	29.70	2.25	70	59	9350	6150	2869	126.05
10HV-12-49	3/13	1847	15	2064	29.26	26.25	29.70	1.85	72	60	10450	6050	3146	135.97
11HV-12-50	3/14	0747	1	2039	29.59	26.45	29.79	0.65	60	51	11000	5475	3150	123.19
11HV-12-51	3/14	0847	3	1965	29.62	26.50	29.79	0.75	60	51	9500	5475	2833	110.79
11HV-12-52	3/14	0947	5	1955	29.63	26.70	29.79	0.35	60	54	13150	5475	3879	151.73
11HV-12-53	3/14	1047	19	2116	29.66	29.65	29.79	1.35	59	54	9550	5475	2428	94.96
1-HV-13-01	3/5	1258	2	2035	29.75	26.40	29.76	0.05	73	71	355	4675	104	3.49
1-HV-13-02	3/5	1318	4	2041	29.75	26.65	29.76	1.50	75	70	380	4675	116	3.89
1-HV-13-03	3/5	1350	23	1984	29.74	26.50	29.77	0.05	73	70	450	4950	135	4.78
1-HV-13-04	3/5	1420	21	2080	29.72	26.55	29.78	0.0	75	73	237	4955	67	2.40
1-HV-13-05	3/5	1454	24	2053	29.71	26.20	29.77	1.25	75	73	265	4925	81	2.88
1-HV-13-06	3/5	1520	25	2076	29.71	26.55	29.73	0.45	73	73	244	4950	71	2.52
1-HV-13-07	3/5	1550	14	2124	29.70	26.55	29.72	1.20	73	74	295	4650	87	2.89

161

OXIDES OF NITROGEN (AS NO₂) DATA AND RESULTS

RUN ID	DATE	TIME	NO.	FLASK VOL ML	PRESSURES -- IN.HG			TEMP F		N MASS UG	FLOW RATE SCFM	NOX PPM	NOX RATE LB/HR	
					INL BARO	FLASK VAC	FNL BARO	FLASK FNL	INL					FNL
1-HV-13-08	3/5	1650	16	2071	29.68	26.55	29.72	1.40	70	74	470	4625	143	4.74
1-HV-13-09	3/5	1750	18	2078	29.66	26.60	29.70	2.00	71	74	506	4650	157	5.22
2-HV-13-10	3/6	1021	2	2035	29.78	26.65	29.65	0.65	73	73	336	4520	101	3.27
2-HV-13-11	3/6	1120	4	2041	29.77	26.65	29.64	0.10	73	73	167	4675	49	1.64
2-HV-13-12	3/6	1220	23	1984	29.76	26.55	29.63	1.45	72	73	280	4700	89	3.01
2-HV-13-13	3/6	1320	21	2080	29.75	26.45	29.61	5.75	74	72	354	4580	131	4.29
3-HV-13-14	3/6	1420	24	2053	29.73	26.40	29.61	0.50	74	72	540	4835	161	5.58
3-HV-13-15	3/6	1520	25	2076	29.73	26.50	29.61	4.55	74	73	235	4815	82	2.83
3-HV-13-16	3/6	1621	14	2124	29.71	26.40	29.60	1.45	75	73	330	4840	99	3.43
4-HV-13-17	3/7	0921	2	2035	29.65	26.50	29.84	1.45	73	64	118	4685	35	1.20
4-HV-13-18	3/7	1021	4	2041	29.63	26.45	29.84	0.35	73	64	103	3480	29	0.74
4-HV-13-19	3/7	1121	23	1984	29.61	26.55	29.84	0.65	72	65	466	4690	140	4.70
4-HV-13-20	3/7	1220	21	2080	29.61	26.50	29.84	1.75	72	65	522	4765	156	5.33
5-HV-13-21	3/7	1320	24	2053	29.60	26.45	29.84	0.90	73	65	200	4655	58	1.96
5-HV-13-22	3/7	1420	25	2076	29.58	26.40	29.83	2.25	76	65	265	4630	81	2.70
5-HV-13-23	3/7	1524	14	2124	29.56	26.45	29.82	2.15	77	65	208	4430	62	1.97
5-HV-13-24	3/7	1620	16	2071	29.53	26.50	29.82	2.60	75	65	420	4530	130	4.23
5-HV-13-25	3/7	1654	18	2078	29.54	26.45	29.82	3.70	77	65	290	4530	94	3.05
6-HV-13-26	3/11	1420	2	2035	29.65	27.00	29.51	0.50	74	77	135	3265	40	0.94
6-HV-13-27	3/11	1450	4	2041	29.65	26.85	29.51	0.25	73	77	30	3320	8	0.21

OXIDES OF NITROGEN (AS NO₂) DATA AND RESULTS

RUN ID	DATE	TIME	FLASK NO.	FLASK VOL ML	PRESSURES INL BARO	-- FLASK VAC	IN.HG BARO	TEMP F	N MASS UG	FLOW RATE SCFM	NOX PPM	NOX RATE LB/HR		
					FNL	FNL	FLAS	INL	FNL					
6-HV-13-28	3/11	1520	23	1984	29.62	26.65	29.53	0.0	75	78	38	3320	11	0.27
6-HV-13-29	3/11	1521	19	2116	29.62	26.70	29.53	0.0	77	78	340	3320	96	2.29
6-HV-13-30	3/11	1620	9	2053	29.61	26.65	29.55	3.80	73	79	122	4175	41	1.25
6-HV-13-31	3/11	1645	25	2076	29.61	26.70	29.55	4.50	75	77	68	4175	23	0.71
6-HV-13-32	3/11	1721	14	2124	29.60	26.60	29.54	1.60	75	76	78	4150	23	0.70
6-HV-13-33	3/11	1750	16	2071	29.60	26.60	29.50	0.50	75	77	90	4150	26	0.79
7-HV-13-34	3/12	1028	2	2035	29.53	26.45	29.47	0.45	77	76	180	3275	54	1.27
7-HV-13-35	3/12	1120	4	2041	29.53	26.50	29.47	0.65	78	73	165	3275	49	1.16
7-HV-13-36	3/12	1220	23	1984	29.55	26.50	29.46	0.75	78	71	210	3280	65	1.53
8-HV-13-38	3/12	1430	26	2055	29.55	26.45	29.41	0.40	78	71	158	4030	46	1.35
8-HV-13-39	3/12	1520	25	2076	29.54	26.55	29.33	1.60	77	75	159	4030	49	1.42
8-HV-13-40	3/12	1620	14	2124	29.50	26.45	29.35	1.05	77	70	295	4005	86	2.48
6-HV-13-41	3/12	1720	16	2071	29.48	26.40	29.33	0.05	76	70	351	4005	101	2.92
9-HV-13-42	3/13	1049	2	2035	29.44	26.40	29.59	1.60	70	59	140	2010	42	0.61
9-HV-13-43	3/13	1135	4	2041	29.43	26.30	29.59	3.00	68	59	114	4140	36	1.09
9-HV-13-44	3/13	1200	23	1984	29.41	26.55	29.62	1.85	68	59	206	4760	64	2.19
9-HV-13-45	3/13	1325	6	2073	29.39	26.35	29.65	3.25	73	59	354	4770	112	3.83
10HV-13-46	3/13	1535	26	2055	29.33	26.30	29.70	1.45	73	61	197	4975	58	2.09
10HV-13-47	3/13	1635	25	2076	29.32	26.30	29.60	3.40	69	61	316	5050	101	3.67
10HV-13-48	3/13	1735	14	2124	29.35	26.25	29.70	1.85	70	60	158	5125	46	1.70

OXIDES OF NITROGEN (AS NO₂) DATA AND RESULTS

RUN ID	DATE	TIME	NO.	FLASK VOL ML	PRESSURES -- IN.HG				TEMP F	N MASS UG	FLOW RATE SCFM	NOX PPM	NOX RATE LB/HR	
					INL BARO	FLASK VAC	FNL BARO	FNL FLAS						
10HV-13-49	3/13	1850	16	2071	29.26	26.20	29.70	1.75	72	60	308	5025	92	3.31
11HV-13-50	3/14	0750	2	2035	29.59	26.50	29.79	1.85	60	51	225	4455	67	2.15
11HV-13-51	3/14	0850	4	2041	29.62	26.55	29.79	4.10	60	51	281	4455	92	2.94
11HV-13-52	3/14	0951	23	1984	29.63	26.70	29.79	2.95	60	54	634	4430	204	6.46
11HV-13-53	3/14	1050	6	2073	29.66	26.50	29.79	0.20	59	54	820	4455	228	7.28
9-HV-23-01	3/13	1045	27	2092	29.44	26.20	29.56	0.75	70	59	7150	3040	2059	44.72
9-HV-23-02	3/13	1130	2	2035	29.43	26.40	29.59	1.90	68	59	5150	5000	1582	56.52
9-HV-23-03	3/13	1217	28	2064	29.41	26.45	29.63	2.20	70	59	10250	5825	3127	130.13
9-HV-23-04	3/13	1315	29	2089	29.39	26.35	29.63	1.10	73	59	13150	5825	3802	158.23
10HV-23-05	3/13	1530	10	2050	29.32	26.25	29.70	1.90	73	59	8250	5975	2506	106.96
10HV-23-06	3/13	1630	11	2052	29.32	26.35	29.70	0.90	73	59	10150	6075	2949	128.00
10HV-23-07	3/13	1730	12	2067	29.36	26.40	29.70	1.05	70	58	12000	6150	3475	152.67
10HV-23-08	3/13	1845	17	2073	29.26	26.20	29.70	1.05	72	58	11650	6050	3375	145.87
11HV-23-09	3/14	0745	27	2092	29.59	26.45	29.79	0.45	60	51	11000	5475	3045	119.12
11HV-23-10	3/14	0845	4	2041	29.62	26.35	29.79	3.20	60	51	11500	5475	3666	143.40
11HV-23-11	3/14	0945	28	2064	29.63	26.50	29.79	4.00	60	54	7750	5475	2531	98.99
11HV-23-12	3/14	1045	7	2099	29.66	26.60	29.79	0.40	59	55	10250	5475	2840	111.07
CAL GAS 1	3/6		6	2073	29.76	26.75	29.53	8.78	75	74	6250	1	2700	0.02
CAL GAS 2	3/6		7	2099	29.76	26.65	29.80	2.85	75	66	13350	1	4167	0.03
CAL GAS 3	3/6		8	2058	29.76	26.50	29.80	2.35	63	68	12750	1	4030	0.03

OXIDES OF NITROGEN (AS NO₂) DATA AND RESULTS

RUN ID	DATE	TIME	NO.	FLASK VOL ML	PRESSURES -- IN.HG			TEMP F	N MASS UG	FLOW RATE SCFM	NOX NOX PPM	RATE LB/HR		
					INL BARO	FLASK VAC	FNL BARO						FLAS INL	FNL
CAL GAS 4	3/7		10	2050	29.76	26.60	29.80	0.0	74	68	142	1	40	0.00
CAL GAS 5	3/7		11	2052	29.75	26.65	29.80	0.0	74	68	138	1	39	0.00
CAL GAS 6	3/7		12	2067	29.75	26.60	29.80	1.60	74	68	142	1	43	0.00

APPENDIX C

EPA REFERENCE METHOD NO. 7

tilled water and add these washings to the same storage container.

4.3 Sample analysis. Transfer the contents of the storage container to a 50 ml. volumetric flask. Dilute to the mark with deionized, distilled water. Pipette a 10 ml. aliquot of this solution into a 125 ml. Erlenmeyer flask. Add 40 ml. of isopropanol and two to four drops of thiorin indicator. Titrate to a pink endpoint using 0.01 N barium perchlorate. Run a blank with each series of samples.

5. Calibration.

5.1 Use standard methods and equipment which have been approved by the Administrator to calibrate the rotameter, pitot tube, dry gas meter, and probe heater.

5.2 Standardize the barium perchlorate against 25 ml. of standard sulfuric acid containing 100 ml. of isopropanol.

6. Calculations.

6.1 Dry gas volume. Correct the sample volume measured by the dry gas meter to

$$C_{SO_2} = \left(7.05 \times 10^{-5} \frac{\text{lb.-l.}}{\text{g.-ml.}} \right) \frac{(V_t - V_b) N \left(\frac{V_{std}}{V_a} \right)}{V_{std}}$$

where

C_{SO_2} = Concentration of sulfur dioxide at standard conditions, dry basis, lb./cu. ft.

7.05×10^{-5} = Conversion factor, including the number of grams per gram equivalent of sulfur dioxide (32 g./g.-eq.), 463.6 g./lb., and 1,000 ml./l. lb.-l./g.-ml.

V_t = Volume of barium perchlorate titrant used for the sample, ml.

V_b = Volume of barium perchlorate titrant used for the blank, ml.

N = Normality of barium perchlorate titrant, g.-eq./l.

V_{std} = Total solution volume of sulfur dioxide, 50 ml.

V_a = Volume of sample aliquot titrated, ml.

V_{std} = Volume of gas sample through the dry gas meter (standard conditions), cu. ft., see Equation 6-1.

7. References.

Atmospheric Emissions from Sulfuric Acid Manufacturing Processes, U.S. DHEW, PMS, Division of Air Pollution, Public Health Service Publication No. 999-AP-18, Cincinnati, Ohio, 1963.

Corbett, P. F., The Determination of SO₂ and SO₃ in Flue Gases, Journal of the Institute of Fuel, 24:237-243, 1951.

Marty, R. E. and E. K. Diehl, Measuring Flue-Gas SO₂ and SO₃, Power 101:94-97, November, 1957.

Patton, W. F. and J. A. Brink, Jr., New Equipment and Techniques for Sampling Chemical Process Gases, J. Air Pollution Control Association, 23, 162 (1963).

standard conditions (70° F. and 29.92 inches Hg) by using equation 6-1.

$$V_{std} = V_m \left(\frac{T_{std}}{T_m} \right) \left(\frac{P_{bar}}{P_{std}} \right) = 17.71 \frac{^{\circ}\text{K}}{\text{in. Hg}} \left(\frac{V_m P_{bar}}{T_m} \right) \quad \text{equation 6-1}$$

where:

V_{std} = Volume of gas sample through the dry gas meter (standard conditions), cu. ft.

V_m = Volume of gas sample through the dry gas meter (meter conditions), cu. ft.

T_{std} = Absolute temperature at standard conditions, 530° R.

T_m = Average dry gas meter temperature, °R.

P_{bar} = Barometric pressure at the orifice meter, inches Hg.

P_{std} = Absolute pressure at standard conditions, 29.92 inches Hg.

6.2 Sulfur dioxide concentration.

$$(V_t - V_b) N \left(\frac{V_{std}}{V_a} \right)$$

equation 6-2

METHOD 7—DETERMINATION OF NITROGEN OXIDE EMISSIONS FROM STATIONARY SOURCES

1. Principle and applicability.

1.1 Principle. A grab sample is collected in an evacuated flask containing a dilute sulfuric acid-hydrogen peroxide absorbing solution, and the nitrogen oxides, except nitrous oxide, are measured colorimetrically using the phenoldisulfonic acid (PDS) procedure.

1.2 Applicability. This method is applicable for the measurement of nitrogen oxides from stationary sources only when specified by the test procedures for determining compliance with New Source Performance Standards.

2. Apparatus.

2.1 Sampling. See Figure 7-1.

2.1.1 Probe—Pyrex¹ glass, heated, with filter to remove particulate matter. Heating is unnecessary if the probe remains dry during the purging period.

2.1.2 Collection flask—Two-liter, Pyrex¹ round bottom with short neck and 24/40 standard taper opening, protected against implosion or breakage.

2.1.3 Flask valve—T-bore stopcock connected to a 24/40 standard taper joint.

2.1.4 Temperature gauge—Dial-type thermometer, or equivalent, capable of measuring 2° F. intervals from 25° to 125° F.

2.1.5 Vacuum line—Tubing capable of withstanding a vacuum of 3 inches Hg absolute pressure, with "T" connection and T-bore stopcock, or equivalent.

2.1.6 Pressure gauge—U-tube manometer, 36 inches, with 0.1-inch divisions, or equivalent.

¹ Trade name.

App. A

Title 40—Protection of Environment

valve to its "vent" position and turn off the pump. Check the manometer for any fluctuation in the mercury level. If there is a visible change over the span of one minute, check for leaks. Record the initial volume, temperature, and barometric pressure. Turn the flask valve to its "purge" position, and then do the same with the pump valve. Purge the probe and the vacuum tube using the squeeze bulb. If condensation occurs in the probe and flask valve area, heat the probe and purge until the condensation disappears. Then turn the pump valve to its "vent" position. Turn the flask valve to its "sample" position and allow sample to enter the flask for about 15 seconds. After collecting the sample, turn the flask valve to its "purge" position and disconnect the flask from the sampling train. Shake the flask for 5 minutes.

4.2 Sample recovery.

4.2.1 Let the flask set for a minimum of 16 hours and then shake the contents for 2 minutes. Connect the flask to a mercury filled U-tube manometer, open the valve from the flask to the manometer, and record the flask pressure and temperature along with the barometric pressure. Transfer the flask contents to a container for shipment or to a 250 ml. beaker for analysis. Rinse the flask with two portions of distilled water (approximately 10 ml.) and add rinse water to the sample. For a blank use 25 ml. of absorbing solution and the same volume of distilled water as used in rinsing the flask. Prior to shipping or analysis, add sodium hydroxide (1*N*) dropwise into both the sample and the blank until alkaline to litmus paper (about 25 to 35 drops in each).

4.3 Analysis.

4.3.1 If the sample has been shipped in a container, transfer the contents to a 250 ml. beaker using a small amount of distilled

$$V_{ss} = \frac{T_{std}(V_f - V_a)}{P_{std}} \left(\frac{P_f}{T_f} - \frac{P_i}{T_i} \right) = \left(17.71 \frac{\text{in. Hg}}{\text{in. Hg}} \right) (V_f - 25 \text{ ml.}) \left(\frac{P_f}{T_f} - \frac{P_i}{T_i} \right) \quad \text{Equation 7-1}$$

where:

V_{ss} = Sample volume at standard conditions (dry basis), ml.

T_{std} = Absolute temperature at standard conditions, 530° R.

P_{std} = Pressure at standard conditions, 29.92 inches Hg.

V_f = Volume of flask and valve, ml.

V_a = Volume of absorbing solution, 25 ml.

water. Evaporate the solution to dryness on a steam bath and then cool. Add 2 ml. phenol-disulfonic acid solution to the dried residue and triturate thoroughly with a glass rod. Make sure the solution contacts all the residue. Add 1 ml. distilled water and four drops of concentrated sulfuric acid. Heat the solution on a steam bath for 3 minutes with occasional stirring. Cool, add 20 ml. distilled water, mix well by stirring, and add concentrated ammonium hydroxide dropwise with constant stirring until alkaline to litmus paper. Transfer the solution to a 100 ml. volumetric flask and wash the beaker three times with 4 to 5 ml. portions of distilled water. Dilute to the mark and mix thoroughly. If the sample contains solids, transfer a portion of the solution to a clean, dry centrifuge tube, and centrifuge, or filter a portion of the solution. Measure the absorbance of each sample at 420 nm using the blank solution as a zero. Dilute the sample and the blank with a suitable amount of distilled water if absorbance falls outside the range of calibration.

5. Calibration.

5.1 Flask volume. Assemble the flask and flask valve and fill with water to the stopcock. Measure the volume of water to ± 10 ml. Number and record the volume on the flask.

5.2 Spectrophotometer. Add 0.0 to 16.0 ml. of standard solution to a series of beakers. To each beaker add 25 ml. of absorbing solution and add sodium hydroxide (1*N*) dropwise until alkaline to litmus paper (about 25 to 35 drops). Follow the analysis procedure of section 4.3 to collect enough data to draw a calibration curve of concentration in $\mu\text{g. NO}_x$ per sample versus absorbance.

6. Calculations.

6.1 Sample volume.

P_f = Final absolute pressure of flask, inches Hg.

P_i = Initial absolute pressure of flask, inches Hg.

T_f = Final absolute temperature of flask, °R.

T_i = Initial absolute temperature of flask, °R.

6.2 Sample concentration. Read $\mu\text{g. NO}_x$ for each sample from the plot of $\mu\text{g. NO}_x$ versus absorbance.

$$C = \left(\frac{m}{V_{ss}} \right) \left(\frac{\frac{1 \text{ lb.}}{\text{cu. ft.}}}{1.6 \times 10^4 \frac{\mu\text{g.}}{\text{ml.}}} \right) = \left(6.2 \times 10^{-4} \frac{\text{lb./s.c.f.}}{\mu\text{g./ml.}} \right) \left(\frac{m}{V_{ss}} \right)$$

equation 7-2

where:

C = Concentration of NO_x as NO_x (dry basis), lb./s.c.f.

m = Mass of NO_x in gas sample, $\mu\text{g.}$

V_{ss} = Sample volume at standard conditions (dry basis), ml.

7. References.

Standard Methods of Chemical Analysis. 6th ed. New York, D. Van Nostrand Co., Inc.

1962, vol. 1, p. 329-330.

Standard Method of Test for Oxides of Nitrogen in Gaseous Combustion Products

- 2.1.7 Pump—Capable of producing a vacuum of 3 inches Hg absolute pressure.
 2.1.8 Squeeze bulb—One way.
 2.2 Sample recovery.

- 2.2.1 Pipette or dropper.
 2.2.2 Glass storage containers—Cushioned for shipping.




Figure 7-1. Sampling train, flask valve, and flask.

- 2.2.3 Glass wash bottle.
 2.3 Analysis.
 2.3.1 Steam bath.
 2.3.2 Beakers or casseroles—250 ml., one for each sample and standard (blank).
 2.3.3 Volumetric pipettes—1, 2, and 10 ml.
 2.3.4 Transfer pipette—10 ml. with 0.1 ml. divisions.
 2.3.5 Volumetric flask—100 ml., one for each sample, and 1,000 ml. for the standard (blank).
 2.3.6 Spectrophotometer—To measure absorbance at 420 nm.
 2.3.7 Graduated cylinder—100 ml. with 1.0 ml. divisions.
 2.3.8 Analytical balance—To measure to 0.1 mg.
 3. Reagents.
 3.1 Sampling.
 3.1.1 Absorbing solution—Add 2.8 ml. of concentrated H_2SO_4 to 1 liter of distilled water. Mix well and add 6 ml. of 3 percent hydrogen peroxide. Prepare a fresh solution weekly and do not expose to extreme heat or direct sunlight.
 3.2 Sample recovery.
 3.2.1 Sodium hydroxide (1N)—Dissolve 40 g. NaOH in distilled water and dilute to 1 liter.
 3.2.2 Red litmus paper.
 3.2.3 Water—Deionized, distilled.

- 3.3 Analysis.
 3.3.1 Fuming sulfuric acid—15 to 18% by weight free sulfur trioxide.
 3.3.2 Phenol—White solid reagent grade.
 3.3.3 Sulfuric acid—Concentrated reagent grade.
 3.3.4 Standard solution—Dissolve 0.5495 g. potassium nitrate (KNO_3) in distilled water and dilute to 1 liter. For the working standard solution, dilute 10 ml. of the resulting solution to 100 ml. with distilled water. One ml. of the working standard solution is equivalent to 25 μ g. nitrogen dioxide.
 3.3.5 Water—Deionized, distilled.
 3.3.6 Phenoldisulfonic acid solution—Dissolve 25 g. of pure white phenol in 150 ml. concentrated sulfuric acid on a steam bath. Cool, add 75 ml. fuming sulfuric acid, and heat at 100° C. for 2 hours. Store in a dark, stoppered bottle.
 4. Procedure.
 4.1 Sampling.
 4.1.1 Pipette 25 ml. of absorbing solution into a sample flask. Insert the flask valve stopper into the flask with the valve in the "purge" position. Assemble the sampling train as shown in Figure 7-1 and place the probe at the sampling point. Turn the flask valve and the pump valve to their "evacuate" positions. Evacuate the flask to at least 3 inches Hg absolute pressure. Turn the pump

(Phenoldisulfonic Acid Procedure), In: 1968 Book of ASTM Standards, Part 23, Philadelphia, Pa. 1968, ASTM Designation D-1608-60, p. 725-729.

Jacob, M. B., The Chemical Analysis of Air Pollutants, New York, N.Y., Interscience Publishers, Inc., 1960, vol. 10, p. 351-356.

METHOD 8—DETERMINATION OF SULFURIC ACID MIST AND SULFUR DIOXIDE EMISSIONS FROM STATIONARY SOURCES

1. Principle and applicability.

1.1 Principle. A gas sample is extracted from a sampling point in the stack and the acid mist including sulfur trioxide is separated from sulfur dioxide. Both fractions are measured separately by the barium-thorin titration method.

1.2 Applicability. This method is applicable to determination of sulfuric acid mist (including sulfur trioxide) and sulfur dioxide from stationary sources only when specified by the test procedures for determining compliance with the New Source Performance Standards.

2. Apparatus.

2.1 Sampling. See Figure 8-1. Many of the design specifications of this sampling train are described in APTD-0501.

2.1.1 Nozzle—Stainless steel (316) with sharp tapered leading edge.

2.1.2 Probe—Pyrex¹ glass with a heating system to prevent visible condensation during sampling.

2.1.3 Pitot tube—Type S, or equivalent, attached to probe to monitor stack gas velocity.

2.1.4 Filter holder—Pyrex¹ glass.

2.1.5 Impingers—Four as shown in Figure 8-1. The first and third are of the Greenburg-Smith design with standard tip. The second and fourth are of the Greenburg-Smith design, modified by replacing the standard tip with a $\frac{1}{4}$ inch ID glass tube extending to one-half inch from the bottom of the impinger flask. Similar collection systems, which have been approved by the Administrator, may be used.

2.1.6 Metering system—Vacuum gauge, leak-free pump, thermometers capable of measuring temperature to within 5° F, dry gas meter with 2% accuracy, and related equipment, or equivalent, as required to maintain an isokinetic sampling rate and to determine sample volume.

2.1.7 Barometer—to measure atmospheric pressure to ± 0.1 inch Hg.

Trade name.




Figure 8-1. Sulfuric acid mist sampling train.

APPENDIX D

FIELD DATA LOG FOR DUPONT 411 PHOTOMETRIC ANALYZER

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/4/75 Zero Gas <0.1 ppm Cylinder Pressure 1500
 Instrument Ser. No. 0142 Zero Gas 3980 ppm NO_x Cylinder Pressure 700
 Location Hercules, Bessemer Alas Oxygen Cylinder Pressure 2500
Inlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1230	E ₁	220	C 1000 F 500					Test 50
	E ₂	11	11					Test 45
Might		11	11					Test 12
R.ight		11	11					
M.dark		11	11					
R.dark		11	11					
	M-R	250	C 834 F 500		025			
1500	Zero	222	C 850 F 500	400	000			
1505	3980 ppm Span	11	11	400	3960 ^{to} 4000			cell temp 115 ° F
1715	Zero	11	C 850 F 502	400				adjust fine zero
	3980 Span	11	11	400	3980	79.5		adjust recorder span
1730	Sample	11	11	400	500			Leave on overnight

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/5/75

Instrument Ser. No. 0142

Location Hercules Bessemer Ala
Inlet

Zero Gas SPAN	< 0.1 ppm NO _x	Cylinder Pressure	1500
Zero Gas	3980 ppm NO _x	Cylinder Pressure	690
Oxygen	2	Cylinder Pressure	2300

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0830	Sample	222	C850 F502	200	2700			Analyzer Operated During Night
0845	Zero	"	"	500	140			
0855	Zero	"	C850 F487	500	000			adjust fine zero
0905	Span	"	"	500	4000	80		cell temp 113 °C
0915	Sample	"	"	400	Aprox 1700			5000 ppm full scale
0945	NO _x	"	"	0	1900			
0950	Sample	"	"	400				PDS NO _x sample. Water in line
1000	No Sample	"	"	0				Change sample. shut off flow line, dry trap
1115	Zero	"	"	400	-018			
1125	Zero	"	C850 F512					
1135		"	"	0				Plant Shut Down
1215	Zero	"	"	400	+060			
1225	Zero	"	C850 F515	400	000	20		adjust zero
1226	Sample	"	"	400	approx 1600			change range from 20 mv to 50 mv
1245	NO _x	"	"	0	1850			cell temp 116 °F

Page 2 of C142 InletNO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/5/75Instrument Ser. No. C142Location Hercules, Besserman Alc
Sample InletZero Gas 100 ppm NO Cylinder Pressure 1500Span 3980 ppm NO_x Cylinder Pressure 700Zero Gas 3980 ppm NO_x Cylinder Pressure 2300

Oxygen _____

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1255	Sample	222	C 350 F 515	400	1400 to 1300			
1315	NO _x	"	"	0	1940			PDS Sample 1315
1320	Sample	"	"	400	1300			
1330	NO _x	"	"	0	1980			
1335	Sample	"	"	400	1340			
1345	NO _x	"	"	0	2030			PDS Sample 1345 cell temp 118°F
1350	Sample	"	"	400	1350			
1400	NO _x	"	"	0	2010			
1405	Sample	"	"	400	1340			SEVO ON B 1412
1415	NO _x	"	"	0	2100			PDS Sample 1415
1420	Sample	"	"	400	1340			
1430	NO _x	"	"	0	2050			
1435	Sample	"	"	400	1290			
1445	NO _x	"	"	0	1970			PDS Sample 1445 cell temp 121°F
1450	Sample	"	"	400	1350 1700			

Page 3 of C142 Inlet

NO_x FIELD DATA ..

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/5/75

Zero Gas _____ Cylinder Pressure _____

Instrument Ser. No. 0142

Zero Gas _____ Cylinder Pressure _____

Location Herrules, Bessemer Ala
Sample Inlet

Oxygen _____ Cylinder Pressure _____

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1500	Zero	222	C850 F515	400	-010	20		
1504	Zero Sample	"	C850 F517	400	000	20		adjust fine zero
1505	Sample 1504	"	"	400	1740			
1508	NO _x	"	"	0	2800			
1512	Sample	"	"	400	1650			
1516	NO _x	"	"	0	2550			PDS Sample 1516
1520	Sample	"	"	400	1730			
1530	NO _x	"	"	0	1660			
1535	Sample	"	"	400	1780			
1545	NO _x	"	"	0	2590			cell top 121°F PDS Sample 1545
1550	Sample	"	"	400	1780			
1600	NO _x	"	"	0	2680			
1605	Sample	"	"	400	1770			
1615	NO _x	"	"	0	2610			
1620	Sample	"	"	400	1750			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/5/75Page 8 of 0142 Inlet

-16-

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1630	NO _x	222	C 850 F 517	0	2600			
1635	Sample	11	11	400	2000			
1645	NO _x	11	11	0	2910			PDS Sample 1645 cell temp 122°F
1650	Sample	11	11	400	2000 to 1850			
1700	NO _x	11	11	0	2750			
1707	Sample	11	11	400	1750			
1715	NO _x	11	11	0	2610			
1720	Sample	11	11	400	1750			
1730	NO _x	11	11	0	2620			
1735	Sample	11	11	400	1770			PDS Sample 1745 cell temp 120°F
1745	NO _x	11	11	0	2680			
1752	Sample	11	11	400	1820			
1800	NO _x	11	11	0	2650			
1805	Zero	11	11	600	000	20		
1820	Span	11	11	400	3960 4020	995		cell temp 118°F

NO _x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER.

(Continued)

DATE 3/5/75Page 5 of C142 Inlet

TIME	MODE	(Indicate Adjustments)		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1830	Sample 222	C 850 F 517						

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/6/75
 Instrument Ser. No. 0142
 Location Hercules, Bessemer Ala
Inlet

Zero Gas <0.1 ppm NO_x Cylinder Pressure 1475
Span 3980 ppm NO_x Cylinder Pressure 675
Zero Gas 3980 ppm NO_x Cylinder Pressure 2350
 Oxygen 2350

TIME	MODE	(Indicate Adjustments)		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0825	Sample	222	C850 F517	300	1380			Instrument + Operated During Night. Recorder OK
0830	Sample	"	"	11	1380			Cell Temp 115°F Set chart at 0830 120 mm/hr
0833	zero	"	"	400	020	20.5%		
0837	zero	"	C850 F513	400	000	20.		adjust fine zero
0850	zero	"	"	400	080			
0851	zero	"	C850 F510	400	000	20		adjust Fine zero
0855	Span	"	"	400	3950	98.5		
0900	"	"	"	400	3950	99.		adjust Recorder to 99
0903	Sample	"	"	400	1500 to 1680			
0915	NO _x	"	"	0	2280			
0920	Sample	"	"	400	1590			
0930	NO _x	"	"	0	2310			
0935	Sample	"	"	400	1680			
0945	NO _x	"	"	0	2450			
0950	Sample	"	"	400	1750 1700 to			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/6/75Page 2 of 0142 Inlet

-79-

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1000	NO _x	222	C 850 F 510	0	2410			
1005	Sample	"	"	400	1750 1660 ^{to}			
1015	NO _x	"	"	0	2430			PDS Sample 1015
1020	Sample	"	"	400	1810			
1030	NO _x	"	"	0	2700			cell temp 117°F
1035	Sample	"	"	400	1910 1980 ^{to}			
1045	NO _x	"	"	0	2760			
1050	Sample	"	"	400	2000 ^{to} 2180			
1100	NO _x	"	"	0	3000			
1105	Sample	"	"	400	2120 2220 ^{to}			
1115	NO _x	"	"	0	3190			PDS Sample 1115
1120	Sample	"	"	400	2300 2310 ^{to}			
1130	NO _x	"	"	0	3360			
1135	Sample	"	"	400	2400 2460 ^{to}			
1145	NO _x	"	"	0	3400			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER.

(Continued)

DATE 3/6/75Page 3 of 0142 Inlet

180-

TIME	MODE	(Indicate Adjustments) SPAN SETTING		ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1150	Sample	222	C850 F510		400	2410 2320 ^{to}			
1200	NO _x	11	11	0		3230			
1205	Sample	11	11	400		2230 2190			
1215	NO _x	11	11	0		3120			PDS Sample 1215
1220	zero Sample	11	11	400		000			
1225	Sample	11	11	400		2340 2370 ^{to}			
1230	NO _x	11	11	0		3370			cell temp 119°F
1235	Sample	11	11	400		2320 2300 ^{to}			
1245	NO _x	11	11	0		3300			
1250	Sample	11	11	400		2360 2280 ^{to}			
1300	NO _x	11	11	0		3330			
1305	Sample	11	11	400		2290 2390 ^{to}			
1315	NO _x	11	11	0		3440			PDS Sample 1316
1320	Sample	11	11	400		2280 2150 ^{to}			
1330	NO _x	11	11	0		2975			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/6/75Page 4 of 0142 Inlet

-18-

TIME	MODE	(Indicate Adjustments) SPAN SETTING		ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1335	Sample	222	C 850 F 510		400	2120 to 2100			
1345	NO _x	11	11	11	0	2920			
1350	Sample	11	11	11	400	2180 to 2230			
1400	NO _x	11	11	11	0	3110			
1405	Sample	11	11	11	400	2150 to 2070			
1415	NO _x	11	11	11	0	2870			PDS Sample 1415
1420	Sample	11	11	11	400	2040 to 2000			
1430	NO _x	11	11	11	0	2770			cell temp 122°F
1435	Sample	11	11	11	400	2000			
1445	NO _x	11	11	11	0	2750			
1450	Sample	11	11	11	400	1970 to 2040			
1500	NO _x Sample	11	11	11	0	2890			
1505	Sample	11	11	11	400	2200 to 2390			
1515	NO _x	11	11	11	0	3270			PDS Sample 1515
1520	Sample	11	11	11	400	2470 to 2550			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/6/75Page 5 of 0142 Inlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1530	NO _x	222	C 850 F 510	0	3460			
1535	Sample	11	11	400	2560 2470 ^{to}			
1545	NO _x	11	11	0	3290			
1550	Sample	11	11	400	2500 2530 ^{to}			
1600	NO _x	11	11	0	3370			
1605	Sample	11	11	400	2450 2440 ^{to}			
1616	NO _x	11	11	0	3300			PDS · Sample 1616
1620	Sample	11	11	400	2380 2290 ^{to}			
1632	NO _x	11	11	0	3070			:
1636	Sample	11	11	400	2250 2220 ^{to}			
1645	NO _x	11	11	0	3000			
1650	Sample	11	11	400	2220 ^{to} 2180			cell temp 126°F
1700	NO _x	11	11	0	2940			
1706	Sample	11	11	400	2150 ^{to} 1770			
1715	NO _x	11	11	0	2320			PDS Sample 1715

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/6/75Page 6 of 0142 Inlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1720	Sample	222	C850 F510	400	1400 to 1460 to			Upset condition
1730	NOx	11	11	0	1770			"
1735	Sample	11	11	400	1275 0610 to			"
1745	NOx	11	11	0	1070			"
1750	Sample	11	11	400	1100 1420 to			"
1800	NOx	11	11	0	2120			cell temp 122
1828	Zero Sample	11	11	400	-110	17.75		
1836	Zero	11	C850 F524	400	000	20		adjust fine zero
1843	Span	11	11	400	3950	99		cell temp 120°F
1850	Sample	11	11	400				

NO FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/7/75 Zero Gas < 0.1 ppm NO Cylinder Pressure 1450
 Instrument Ser. No. 0142 Span 3980 ppm NO Cylinder Pressure 700
 Location Hercules, Bessemer, Ala Oxygen Oxygen Cylinder Pressure 2350
Inlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0840	Sample	222	C 850 F 524	550	1700			Instrument Operated During Night. Recorder OK.
0850	Zero	11	11	400	060	21 +		Increase Recorder Chart Speed to 120 mm/hr
0900	Zero	11	C 850 F 518	400	000	20		Adjust fine zero
0903	Span	3980 ppm 11	11	400	4000	99.5		cell temp 116 °F
0910	Sample	11	11	400	1670			
0915	NOx	11	11	0	2800			PDS Sample 0915
0920	Sample	11	11	400	1550 1470			
0930	NOx	11	11	0	2440			
0935	Sample	11	11	400	1510 1550			
0945	NOx	11	11	0	2710			
0950	Sample	11	11	400	1630 1790			
1000	NOx	11	11	0	3020			
1005	Sample	11	11	400	1600 to 1110			
1015	NOx	11	11	0	1620			PDS Sample 1015
1020	Sample	11	11	400	1220 940 to			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER.

(Continued)

DATE 3/7/75Page 2 of 0142 Inlet

-85-

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1030	NO _x	222	C 850 F 518	0	1360			
1035	Sample	21	11	400	1500 2080			
1045	NO _x	11	11	0	3900			
1051	Sample	11	11	400	2210 2240			
1100	NO _x	11	11	0	4060			attenuate to 100mv range on recorder for NO _x reading
1106	Sample	11	11	400	2290 2310			place recorder back on 50mv range
1115	NO _x	11	11	0	4150			PDS Sample / attenuate to 100mv range on recorder
1120	Sample	11	11	400	2340 2350			place recorder back on 50mv range
1130	NO _x	11	11	0	4000			attenuate to 100mv range on recorder not necessary
1135	Sample	11	11	400	2200 2060			
1145	NO _x	11	11	0	3400			
1150	Sample	11	11	400	2110 to 2170			
1200	NO _x	11	11	0	3690			
1205	Sample	11	11	400	2240 2340			
1215	NO _x	11	11	0	3940			PDS Sample 1215

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/7/75Page 3 of 0142 Inlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1220	Sample	222	C850 F518	400	2310 _{to} 2140			
1230	NO _x	"	"	0	3330			cell temp 116°F
1236	Sample	"	"	400	2140 _{to} 2100 _{to}			
1245	NO _x	"	"	0	3300			
1250	Sample	"	"	400	2120 _{to} 2160 _{to}			
1300	NO _x	"	"	0	3350			
1305	Sample	"	"	400				change chart paper
1310	"	"	"	400	2150 _{to} 1810			New chart paper
1315	NO _x	"	"	0	2490			PDS Sample 1315
1320	Zero <u>Sample</u>	"	"	400	050	21		
1325	ZERO	"	C850 F514	400	000	20		adjust fine zero
1330	sample	"	"	400	1490 _{to} 1530			cell temp 118°F
1345	NO _x	"	"	0	2090			
1350	Sample	"	"	400	1560 _{to} 1550			
1400	NO _x	"	"	0	280			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/7/75Page 4 of 0142 Inlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1405	Sample	222	C 850	F 514	400	1490 1470 ^{to}			
1415	NO _x	11	11	0	2040				PDS Sample 1415
1420	Sample	11	11	400	1550 1600 ^{to}				
1430	NO _x	11	11	0	2240				
1435	Sample	11	11	400	1680 1700 ^{to}				cell temp 120°F
1445	NO _x	11	11	0	2300				
1450	Sample	11	11	400	1700 1660 ^{to}				
1500	NO _x	11	11	0	2240				
1505	Sample	11	11	400	1650 1650 ^{to}				
1515	NO _x	11	11	0	2210				PDS Sample 1515
1520	Sample	11	11	400	1650 ^{to} 1650				
1530	NO _x	11	11	0	2190				
1535	Sample	11	11	400	1590 1570				cell temp 126°F
1545	NO _x	11	11	0	2120				
1552	Sample	11	11	400	1470 1400 ^{to}				

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/7/75Page 5 of 0192 Inlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1600	NO _x	222	C850 F514	0	1890			
1605	Sample	11	11	400	1500 ^{to} 1560			
1615	NO _x	11	11	0	2240			PDS Sample 1615
1623	Sample	11	11	400	1570 ^{to} 1580			
1630	NO _x	11	11	0	2140			
1635	Sample	11	11	400	1600 ^{to} 1590			
1645	NO _x	11	11	0	2190			
1650	Sample	11	11	400	1630 ^{to} 1630			
1700	NO _x	11	11	0	2200			PDS NO _x Sample 1658
1705	Zero	11	11	400	-080	18.2		
1710	Zero	11	C850 F528	11	000	20		adjust fine zero
1715	Span	11	C850 F528	400	3980 ^{to} 4000	99.2 ^{to} 99.8		cell temp 120

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/10/75
 Instrument Ser. No. 0142
 Location Hercules, Bessamer Ala
Inlet

Zero Gas	<u><0.1 ppm NO_x</u>	Cylinder Pressure	<u>1350</u>
Span	<u>3980 ppm NO_x</u>	Cylinder Pressure	<u>630</u>
Oxygen	<u>2</u>	Cylinder Pressure	<u>2250</u>

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0830	Zero	222	C850 F52B	400	030	26		
0835	Zero	"	C850 F486	400	000	20		adjust fine zero
0845	Span	"	"	11	4000	100		cell temp 110 °F
0855	Zero	"	"	100	10	decreasing		
1355	Zero	"	"	400	-170	17.25		cell temp 120 °F
1400	zero	"	C850 F505	400	000	20		adjust fine zero
1415	"	"	"	"	"			Change light source
1430	Zero	"	C850 F550	400	000	30		adjust fine zero
1440	Span	"	"	400	3960	99.5		adjust to 99.5 cell temp 115

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/11/75Instrument Ser. No. 0142Location Hercules, Bessemer Ala
Inlet

Zero Gas	<u>Span</u> 40.1 ppm NO _x	Cylinder Pressure	<u>1310</u>
Zero Gas	<u>Span</u> 3980 ppm NO ₂	Cylinder Pressure	<u>650</u>
Oxygen		Cylinder Pressure	<u>2310</u>

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0805	Zero	222	C 850 F 550	400	-40	19		
0820	Zero	"	C 850 F 556	400	000	20		adjust fine zero
0825	"	"	"	025	000	20		
1300	"	"	"	400	-100	17.8		
1320	"	"	C 850 F 571	400	000	20		adjust fine zero
1325	Span	"	"	400	3980	99.75		cell temp 115 °F
1350	Zero	"	"	400	000	20		
1355	Sample	"	"	400	675 to 600			
1415	NO _x	"	"	0	1060			PDS Sample 1415
1420	Sample	"	"	400	510 to 480			
1430	NO _x	"	"	0	760			
1435	Sample	"	"	400	470 480 to			
1445	NO _x	"	"	0	730			PDS Sample 1445
1450	Sample	"	"	400	990 to 500			
1500	NO _x	"	"	0	760			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER.

(Continued)

DATE 3/16/75Page 2 of 0142 Inlet

-161-

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1505	Sample	222	C850 F571	400	510 590 ^{to}			
1515	NO _x	11	11	0	760			PDS Sample 1515
1520	Sample	11	11	400	470 ^{to} 560			
1530	NO _x	11	11	0	870			
1535	Sample	11	11	400	630 880 ^{to}			
1545	NO _x	11	11	0	1060			PDS Sample 1545
1550	Sample	11	11	400	720 ^{to} 850			
1600	NO _x	11	11	0	1280			
1605	Sample	11	11	400	880 ^{to} 910			
1615	NO _x	11	11	0	1340			PDS Sample 1615
1620	Sample	11	11	400	900 ^{to} 880			
1630	NO _x	11	11	0	1290			
1635	Sample	11	11	400	870 ^{to} 870			
1645	NO _x	11	11	0	1280			PDS Sample 1645
1650	Sample	11	11	400	0850 ^{to} 0850			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/11/75Page 3 of 0142 Inlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1700	NO _x	222	C850 F571	0	1240			PDS Sample
1705	Sample	11	11	400	0870 0850			
1715	NO _x	11	11	0	1260			PDS Sample 1715
1720	Sample	11	11	400	0860 0870			
1730	NO _x	11	11	0	1270			
1735	Sample	11	11	400	0860 0860			
1745	NO _x	11	11	0	1250			PDS Sample 1745
1750	Sample	11	11	400	760			
1755	Zero	11	11	400	0130	22.8		
1755	Zero	11	C850 F553	400	000	20		
1804	Span	11	11	400	3930	99		cell temp 120°F
1810	Sample	11	11	400				

NO_x FIELD DATA ..

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/12/75Instrument Ser. No. 0142Location Hercules, Bessemer Ala
Inlet

Zero Gas	<u><0.1 ppm</u>	Cylinder Pressure	<u>1300</u>
Span Gas	<u>3.980 ppm</u>	Cylinder Pressure	<u>600</u>
Oxygen		Cylinder Pressure	<u>2300</u>

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0810	Sample	222	<u>C850</u> <u>F553</u>	400	760			
0815	Zero	"	"	"	-190	15.9		
0825	"	"	"	"	000	20		adjust fine zero
0840	Span	"	"	400	3890	98		cell temp 125°C
0850	"	"	"	400	3890	98		adjust recorder span
0855	"	"	"	400	3900	98		equivalent to 3470 ppm at 115°
0856	Zero	"	██████████ "	400	-030	19.2		██████████ adjust fine zero
0900	Zero	"	<u>C850</u> <u>F582</u>	400	000	20		adjust fine zero
0903	Span	"	"	400	3950	99.0		cell temp 120°C
0910	Zero	"	"	400	020	20.5		
0920	Zero	"	<u>C850</u> <u>F578</u>	400	000	20		adjust fine zero
0925	Span	"	"	400	3930	98.7		cell temp 120°
0930	Sample	"	"		<u>1480</u> <u>1550±10</u>			
1022	NO _x	"	"	0	2110			PDS Sample 1023
1027	Sample	"	"	400	<u>1470</u> <u>1550</u>			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER.

(Continued)

DATE 3/12/75Page 2 of 014? Inlet

164

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1045	NO _x	222	C850 F578	0	2170			
1050	Sample	11	11	400	1550 1620 ^{to}			
1100	NO _x	11	11	0	2260			
1105	Sample	11	11	400	1700 1890 ^{to}			
1120	NO _x	11	11	0	2660			PDS Sample 1120
1125	Sample	11	11	400	1970 1950 ^{to}			cell temp 122 °F
1130	NO _x	11	11	0	2720			
1135	Sample	11	11	400	1990 ^{to} 2000			
1145	NO _x	11	11	0	2760			
1150	Sample	11	11	400	1870 1810 ^{to}			
1200	NO _x	11	11	0	2490			
1205	Sample	11	11	400	1740 ^{to} 1660 ^{to}			
1215	NO _x	11	11	0	2290			PDS Sample 1215
1220	Sample	11	11	400	1700 ^{to} 1670 ^{to}			cell temp 124 °F
1230	NO _x	11	11	0	2290			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/12/75Page 3 of 0142 Inlet

-65-

TIME	MODE	(Indicate Adjustments) SPAN SETTING		ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1235	Sample	222	C850 F578		400	1650 1690 ^{to}			cell temp 126°F
1245	NOx	"	"	0		2270			
1251	Sample	"	"	400		1650 1690 ^{to}			
1300	NOx	"	"	0		2360			
1305	Sample	"	"	400		1730 1660 ^{to}			
1316	NOx	"	"	0		2290			
1321	Sample	"	"	400		1600 1580 ^{to}			P.D.S Sample 1326
1330	NOx	"	"	0		2200			
1335	Sample	"	"	400		1590 1570 ^{to}			cell temp 122°F
1345	NOx	"	"	0		2180			increased production rate
1350	Sample	"	"	400		1650 1970 ^{to}			
1400	NOx	"	"	0		2740			
1405	Sample	"	"	400		1970 1930 ^{to}			
1415	ZERO	"	"	400		000	20		
1420	Sample	"	"	400		1800 1760 ^{to}			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER.

(Continued)

DATE 3/12/75Page 4 of C142 Inlet

-96-

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1430	NO _x	227	C 85C F 578	0	2380			PDS Sample 1430
1435	Sample	11	11	400	1650 1670 ^{to}			cell temp 120°F
1445	NO _x	11	11	0	2350			
1450	Sample	11	11	400	1720 1720 ^{to}			
1500	NO _x	11	11	0	2380			
1505	Sample	11	11	400	1690 1670 ^{to}			
1516	NO _x	11	11	0	2300			PDS Sample 1516
1521	Sample	11	11	400	1700 1730 ^{to}			
1530	NO _x	11	11	0	2380			
1535	Sample	11	11	400	1760 1790 ^{to}			cell temp 120°F
1545	NO _x	11	11	0	2450			
1550	Sample	11	11	400	1800 ^{to} 1850			
1600	NO _x	11	11	0	2540			
1605	Sample	11	11	400	1860			
1615	NO _x	11	11	0	2530			PDS Sample 1615

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/12/75Page 5 of 0142 Inlet

-16-

TIME	MODE	(Indicate Adjustments) SPAN SETTING		ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1620	Sample	222	C850 F578		400	1850 1650 ^{to}			
1630	NO _x	11	11	11	0	2200			cell temp 121°F
1635	Sample	11	11	11	400	1570 1560 ^{to}			
1645	NO _x	11	11	11	0	2090			
1650	Sample	11	11	11	400	1550 1540			
1700	NO _x	11	11	11	0	2080			
1705	Sample	11	11	11	400	1550 1520 ^{to}			
1715	NO _x	11	11	11	0	2080			
1721	Sample	11	11	11	400	1500 1560 ^{to}			
1730	NO _x	11	11	11	0	2240			
1735	Sample	11	11	11	400	1750 1820 ^{to}			cell temp 123°F
1745	NO _x	11	11	11	0	2640			PDS Sample 1745
1750	Sample	11	11	11	400	1800 1530 ^{to}			
1800	NO _x	11	11	11	0	2200			
1805	Sample	11	11	11	400	1640 1720 ^{to}			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER.

(Continued)

DATE 3/12/75Page 6 of Inlet 0142

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1810	Zero	222	C850 F578	400	050	21		
1830	ZERO	2.22	C850 F572	400	000	20		adjust fine zero
1833	Span	11	11	400	3950			cell temp 120°F
1845	Sample							Change Port to HV 23 Inlet to Demister

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/13/75

Instrument Ser. No. 0142

Location Hercules Bessemer Ala
HV-23 Inlet to Demister

Zero Gas <0.1 ppm NO_x Cylinder Pressure 1200
 Span Zero Gas 3980 ppm NO_x Cylinder Pressure _____
 Oxygen _____ Cylinder Pressure _____

TIME	MODE	(Indicate Adjustments) SPAN SETTING		ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0815	Sample	222	C850 F572		300	2440			cell temp 110°F
0816	ZERO	11		11	400	320	26		
0830	Zero	11	C850 F530		000	000	20		adjust fine zero
0845	Span	11		11	400	3970	99		cell temp 113°F
0900	ZERO	11		11	400	000	20		
0915	Zero	11		11	400	-010	19.8		
0930	Zero	11	C850 F531		400	000	20		adjust fine zero
0940	Sample	11		11	400	1400 1260 ^{to}			
1017	Sample	11		11	400	1260 ^{to} 1270			sieve switched 1017
1030	NO _x	11		11	0	1910			
1035	Sample	11		11	400	1250 1200 ^{to}			
1045	NO _x	11		11	0	1810			by pass opened 1040 PDS Sample 1075
1050	Sample	11		11	400	1250 1160 ^{to}			
1100	NO _x	11		11	0	1770			
1105	Sample	11		11	400	1320 ^{to} 1450			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/13/75Page 2 of 0142 HV-23 Inlet to Demister

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1115	NO _x	22-2	C850 F531	0	2060			
1120	Sample	11	11	400	1420 1360 ^{to}			
1130	NO _x	11	11	0	1850			PDS Sample 1130
1135	Sample	11	11	400	1230 1000 ⁺			
1145	NO _x	11	11	0	1440			
1150	Sample	11	11	400	1380 ^{to} 1840			
1200	NO _x	11	11	0	2940			
1205	Sample	11	11	400	1850 1810 ^{to}			
1217	NO _x	11	11	0	3040			PDS Sample 1217
1222	Sample	11	11	400	1970 2100 ^{to}			cell temp 114°F
1230	NO _x	11	11	0	3370			
1235	Zero	11	11	400	040	20.9		
1238	Zero	11	C850 F527	400	000	20		adjust Fine zero
1240	Sample	11	11	400	2250 ^{to} 2260			
1245	NO _x	11	11	0	3120			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER.

(Continued)

DATE 3/13/75Page 3 of 0142 HV-23 Inlet to Demister

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1250	Sample	222	C850 FS27	400	2380 ₂₄₇₀ ^{to}			
1300	NO _x	11	11	0	3800			
1305	Sample	11	11	400	2510 ₂₅₉₀ ^{to}			
1315	NO _x	11	11	0	3850			
1320	Sample	11	11	400	2640 ₂₆₉₀ ^{to}			
1330	NC _x	11	11	0	4030			switch recorder to 100 mv scale for NO _x reading
1335	Sample	11	11	400	2690 ₂₅₉₀ ^{to}			cell temp 117°F
1345	NO _x	11	11	0	3930			
1350	Sample	11	11	400	2500 ₂₆₀₀ ^{to}			
1400	NO _x	11	11	0				1357 Sundyne switch off and turned on. Bypass valve opened.
1415	NO _x	11	11	0	3570			
1420	Sample	11	11	400	2570 ₁₁₂₀ ^{to}			cell temp 119°F
1500	NC _x	11	11	0	2090			
1505	Sample	11	11	400	1150 ₁₉₇₀ ^{to}			
1515	NC _x	11	11	0	3020			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/13/75Page 4 of 0142

HV-23 Inlet to Demister

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1520	Sample	222	C850 F527	400	1870 ⁺⁰ 1860			
1530	NO _x	11	11	0	2890			PDS sample 1530
1535	Sample	11	11	400	1730 ⁺⁰			cell temp 121°F
1545	NO _x	11	11	0	2770			
1550	Sample	11	11	400	1870 1790 ⁺⁰			
1600	NO _x	11	11	0	2810			
1605	Sample	11	11	400	1820 1930 ⁺⁰			
1615	NO _x	11	11	0	3020			
1620	Sample	11	11	400	1800 1920 ⁺⁰			
1630	NO _x	11	11	0	2860			
1635	Sample	11	11	400	1800 1690 ⁺⁰			cell temp 121°F
1645	NO _x	11	11	0	2830			
1650	Sample	11	11	400	1760 ⁺⁰ 1830 ⁺⁰			
1700	NO _x	11	11	0	3040			
1705	Sample	11	11	400	1870 1890 ⁺⁰			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER.

(Continued)

DATE 3/13/75Page 5 of C142

HV-23 Dennis from I-710

TIME	MODE	(Indicate Adjustments) SPAN SETTING		ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1715	NO _x	222		C650 FS27	0	3050			
1720	Sample	11		11	400	1950 1850 ^{to}			
1730	NO _x	11		11	0	2930			
1735	Sample	11		11	400	1850 ^{to} 1920			cell temp 121°F
1745	NO _x	11		11	0	3060			
1750	Sample	11		11	400	1860 1900 ^{to}			
1800	NO _x	11		11	0	3040			
1805	Sample	11		11	400	1980 ^{to} 2010			
1815	NO _x	11		11	0	3210			
1820	Sample	11		11	400	2050 2090 ^{to}			
1830	NO _x	11		11	0	3320			
1835	Sample	11		11	400	2150 ^{to} 2270			
1848	NO _x	11		11	0	3440			cell temp 130°F
1853	Sample	11		11	400	2210 2290 ^{to}			
1860	NO _x	11		11	0	3420			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/13/75Page 6 of 0142

HV-23

Demister Inlet
Outlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1905	Zero	222	C850 F527	400	-180	16		
1910	11	11	E850 F550	400	000	20		adjust fine zero
1913	Span	11	11	400	3920	98.25		cell temp 120°F
1920	Sample	11	11	400				

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/14/75 Zero Gas <0.1 ppm NO_x Cylinder Pressure 1150
 Instrument Ser. No. 0142 Zero Gas 3980 ppm NO_x Cylinder Pressure 550
 Location Hercules Bessemer Ala. Oxygen 22.00 Cylinder Pressure 2200
HV-2.3 Inlet to Demister

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0630	Sample	222	C850 F550	400				
0635	ZERO	"	"	"	018	23.7		
0642	ZERO	"	C850 F527	"	000	20		adjust fine zero
0645	Span	"	"	400	4040	slighty 7100		cell temp 107°C
0651	Sample	"	"	400	1960 2180			sieve switched to A on absorb 0711
0711	Sample	"	"	400	2180			
0715	NO _x	"	"	0	3400			
0720	Sample	"	"	400	2100 2120			
0730	NO _x	"	"	0	3410			
0735	Sample	"	"	400	2180 2180			
0745	NO _x	"	"	0	3320			PDS Sample 0745
0750	Sample	"	"	400	2210 2220			
0800	NO _x	"	"	0	3290			
0805	Sample	"	"	400	2210 2175			
0815	NO _x	"	"	0	3190			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER.

(Continued)

DATE 3/14/75Page 2 of 0142 HV-23 Inlet to Demister

106-

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0820	Sample	222	C850 F527	400	2150 ^{to} 2150			
0830	NO _x	11	11	0	3180			
0835	Sample	11	11	400	2160 ^{to} 2140			
0845	NO _x	11	11	0	3170			0845 PDS Sample 110 °F cell temp
0850	Sample	11	11	400	2140 ^{to} 2140			
0900	NO _x	11	11	0	3160			
0905	zero	11	11	400	050	21		
0910	zero	11	C850 F520	11	000	20		adjust fine zero
0915	Sample	11	11	400	2075 ^{to} 20100			
0930	NO _x	11	11	0	3090			
0935	Sample	11	11	400	2030 ^{to} 2010			
0945	NO _x	11	11	0	3090			PDS Sample 0945. cell temp 108 °F
0950	Sample	11	11	400	1930 ^{to} 1930			
1000	NO _x	11	11	0	3070			
1005	Sample	11	11	400	1970 ^{to} 2030			

NO FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/14/75

Page 3 of 0142

HV-23 Inlet to Demister

NO FIELD DATA
X

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/4/75Instrument Ser. No. 0166Location Hercules, Bessemer Ala.
OUTLETZero Gas <0.1 ppm NO_x Cylinder Pressure 1500
SpanZero Gas 35 ppm NO_x Cylinder Pressure 2100Oxygen Cylinder Pressure 2500

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
11:45	E ₁	795	C 1000 F 500					Test 49.5
	E ₂	11	11					Test 47.
	M light	11	11					Test 21.
	R light	11	11					Test 17.5
	M dark	11	11					Test 35.
	R dark	11	11					Test 33.
12:15	Zero							
	M-R	250	C 806 F 500		025			Screen In C23
12:15	Zero	795	C 800 F 496	400	000			adjust to 000. Cal Filter in, Meter at 0
12:30	Span	795	11	400	032			
14:30	Span	795	11	400	032			
14:45	Zero	795	11	400	000			
14:50	Zero	795	C 800 F 490	400	000			Adjust fine zero
15:10	Span	795	C 800 F 490	400	4000 3960 to	79-80		cell temp 108°F
17:00	Zero	11	11	400	000			zero stabil

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/4/75Instrument Ser. No. C166Location Hercules, Bessemer Ala
OutletZero Gas < 0.1 ppm NO_x Cylinder Pressure 1500Span Gas 3.5 ppm NO_x Cylinder Pressure 2100Oxygen 2500 Cylinder Pressure 2500

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1730	Sample	795		800	800			Sample, recorder 1000 ppm full scale
0830	Sample	795		700	100			see new sheet for

3/4/75-

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/5/75Instrument Ser. No. 0166Location Hercules, Bessemer Ala
OutletZero Gas <0.1 ppm NO_x Cylinder Pressure 1500Span Gas 35 ppm NO₂ Cylinder Pressure 1800Oxygen Cylinder Pressure 2300

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0830	Sample	795	C 800 F 490	400	100			Instrument Operated During Night.
0845	Zero	"	"	300	050			
0855	Zero	795	C 800 F 474	300	000			adjust fine zero cal filter in Meter 471
0905	Span	"	"	500	032			cell temp 108°F
0915	Zero	"	"	500	000			
0920	Span	795	"	500	30			
0925	Sample	795	"	500	Aprox 20-25			100 ppm full scale
0950	NO _x	795	"	0	029			
0955	Sample	795	"	500				
1045	Zero	795	"	500	-048			
1050	Zero	795	C 803 F 474	500	000	50		Set zero at 50% of chart
1100	Zero	795	C 803 F 477	500	000	50		adjust fine zero
1110	Sample	795	"	500	65-70			
1135		"	"	0				Plant Shut Down
1215	Zero	795	"	500	005			

Page 2 of C166 outletNO_x FIELD DATA
DUPONT 411 PHOTOMETRIC ANALYZERDate 3/5/75Instrument Ser. No. 0166Location Hercules, Bessemer-Ala
OUTLETZero Gas < C1 ppm NO Cylinder Pressure 1500Zero Gas 5 ppm NO Cylinder Pressure 1400Oxygen 21% Cylinder Pressure 1400

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1220	Zero	795	C ⁶⁰ 3 F 473		000	50		adjust zero
1235	Sample	11	11	400	100			
1245	NOx	11	11	0	100			PDS Sample
1255	Sample	11	11	400	98 to 113			1258 cell temp 109°F
1320	NOx	11	11	0	113			PDS Sample
1325	Sample	11	11	400	135			1320
1335	NOx	11	11	0	135			
1340	Zero	11	11	400	000			
1343	Sample	11	11	400	154			
1350	NOx	11	11	0	154			PDS Sample
1355	Sample	11	11	400	166			1350 cell temp 110°F
1405	NOx	11	11	0	166			
1410	Sample	11	11	400	166 to 85			Sieve on B 1412
1420	NOx	11	11	0	85			PDS Sample
1425	Sample	11	11	400	114 to 90			1420

Page 3 of F 0166 Outlet NO_x FIELD DATA
 DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/5/75

Instrument Ser. No. 0166

Location Hercules, Bessemer Ala
Outlet

Zero Gas 40.1 ppm NO Cylinder Pressure 1500

Span Gas 35 ppm NO₂ Cylinder Pressure 1900

Oxygen Cylinder Pressure

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1435	NO _x	795	C 803 F 473	0	085			
1440	Sample	"	"	400	073			
1445	Zero	"	"	400	007			cell temp 110
1448	Zero	"	C 803 F 469	400	000	50		adjust fine zero
1450	Sample	"	"	400	065			
1454	NO _x	"	"	0	066			PDS Sample 1454
1457	Sample	"	"	400	075			
1501	NO _x	"	"	0	076			
1507	Sample	"	"	400	086			
1520	NO _x	"	"	0	086			PDS Sample 1520
1525	Sample	"	"	400	082 ^{to} 093			
1535	NO _x	"	"	0	094			
1540	Sample	"	"	400	098 ^{to} 101			
1550	NO _x	"	"	0	103			cell temp 111°F PDS Sample 1550
1555	Sample	"	"	400	106 ^{to} 114			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER.

(Continued)

DATE 3/5/75Page 7 of C166 Outlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1605	NO _x	895		C 803 F 469	C	115			
1610	Zero	11		11	400	015			
1615	Zero	11		C 803 F 463	400	000	50		adjust fine zero
1618	Sample	11		11	400	111			
1623	NO _x	11		11	0	113			
1628	Sample	11		11	400	120			
1635	NO _x	11		11	0	122			
1640	Sample	11		11	400	126 to 139			
1650	NO _x	11		11	0	138			PDS sample 1550
									1660, cell temp 109 °F
1655	Sample	11		11	400	146 to 149			
1705	NO _x	11		11	0	151 to 151			
1710	Sample	11		11	400	152 to 164			
1720	NO _x	11		11	0	165			
1725	Zero	11		11	400	006			
1730	Zero	11		C 803 F 461	400	000	50		adjust fine zero

NO. FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/5/75

Page ~~5~~ 5 of 0166 Outlet

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/6/75Instrument Ser. No. 0166Location Hercules, Bessemer Ala
OutletZero Gas < 0.1 ppm NO Cylinder Pressure 1475Zero Gas 35 ppm NO₂ Cylinder Pressure 1800Oxygen Cylinder Pressure 2350

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0820	Sample	795	C 803 F 454	300	010			Instrument Operated During Night. Recorder Inking at 0520 AM
0830	Sample	"	"	"		set chart 0830 120 mm/hr		Cell Temp 110 °F
0833	Zero	"	"	400	-075	16		
0845	Zero	"	C 803 F 478	400	000	30		adjust fine zero
0853	Span	"	"	400	033	36.5		
0900	Sample	"	"	400	105 121 to			
0920	NO _x	"	"	0	124			
0925	Sample	"	"	400	124 to 134			
0935	NO _x	"	"	0	135			
0940	Sample	"	"	400	141 146 to			
0950	NO _x	"	"	0	148			
0955	Sample	"	"	400	150 155 to			
1005	NO _x	"	"	0	159			sieve switched to A
1010	Sample	"	"	400	111 to			
1020	NO _x	"	"	0	112			P1's Sample 1021

Stopped

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/6/75Page 2 of 0166 Outlet

-911-

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1025	Zero	795	C 803 F 454	400	023	34.8		cell temp 109 °F
1035	Zero	795	C 803 F 470	400	000	30		adjust fine zero
1040	Sample	11	11	400	052			
1050	NO _x	11	11	0	054			
1055	Sample	11	11	400	057 to 063			
1105	NO _x	11	11	0	066			
1110	Sample	11	11	400	073 to 085			
1120	NO _x	11	11	0	086			PDS sample 1120
1125	Sample	11	11	400	099 113 to			
1135	NO _x	11	11	0	113			
1140	Zero	11	11	400	025			
1145	Zero	11	C 803 F 460	400	000	30		adjust fine zero
1150	Sample	11	11	400	111 130 to			
1205	NO _x	11	11	0	132			
1210	Sample	11	11	400	135 147 to			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/6/75Page 3 of C166 Outlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1220	NO _x	795	C803 F460	0	147			PDS Sample 1220
1225	Sample	11	11	400	160 178 to			cell temp 109°F
1235	NO _x	11	11	0	turned wrong value			
1236	Sample	11	11	400	185 193 to			
1242	NO _x	11	11	0	190			
1245	Sample	11	11	400	205 209 to			
1250	NO _x	11	11	0	212			
1255	zero sample	11	11	400	005	31		
1255	zero	11	C803 F458	400	000	30		adjust fine zero
1258	Sample	11	11	400	225 to 237			
1306	NO _x	11	11	0	239			
1311	Sample	11	11	400	250 264 to			
1320	NO _x	11	11	0	265			PDS Sample 1320
1325	Sample	11	11	400	270 268 to			
1335	NO _x	11	11	0	268			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/6/75Page 4 of 0166 Outlet

118-

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1340	Sample	795	C803 F458	400	272 to 275			
1350	NO _x	11	11	0	274			
1355	Sample	11	11	400	278 to 283			
1405	NO _x	11	11	0	284			sieve switched 1408
1410	Sample	11	11	400	159 177 to			
1420	NO _x	11	11	0	176			PDS Sample 1420
1425	Zero	11	11	400	-012	27.8		cell temp 108° E
1430	Zero	11	C803 F462	400	000	30		adjust fine zero
1435	Sample	11	11	400	112 084 to			
1450	NO _x	11	11	0	083			
1455	Sample	11	11	400	080 077 to			
1505	NO _x	11	11	0	079			
1510	Sample	11	11	400	081 085 to			
1520	NO _x	11	11	0	087			PDS Sample 1520
1525	Zero	11	11	400	-008	28.5		

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER.

(Continued)

DATE 3/6/75Page 5 of 0166 Outlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1530	Zero	795	C803 F466	400	000	30		adjust fine zero
1535	Sample	"	"	400	109 to 115			
1550	NO _x	"	"	0	116			
1555	Sample	"	"	400	120 128 to			
1605	NO _x	"	"	0	127			
1610	Sample	"	"	400	134 to 141			
1620	NO _x	"	"	0	141			PDS Sample 1621
1625	Sample	"	"	400	149 to 154			
1635	NO _x	"	"	0	156			
1640	Zero	"	"	400	-002	29.5		
1646	Zero	"	C803 F468	400	000	30		adjust fine zero
1650	Sample	"	"	400	172 to 182			cell temp 108°F
1655	NO _x	"	"	0	187			
1710	Sample	"	"	400	179 to 172			
1720	NO _x	"	"	0	170			Upset Conditions

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/6/75Page 6 of 0166 Outlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECODER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1723	Sample	795	C803 F468	400	170 +0 302			Upset conditions
1735	NO _x	11	11	0	284			11
1740	Sample	11	11	200	150			11
1750	Sample	11	11	200	150			11
1755	Sample	11	11	300	146			
1810	Sample	11	11	300	165			1812
1828	Zero	11	11	400	+25	3.5		
1835	Zero	11	C803 F458	400	000	30		adjust fine zero
1843	Span	11	11	400	032			cell temp 106°F
1850	Sample	11	11	400				

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/7/75
 Instrument Ser. No. 0166
 Location Hercules, Bessemer Ala
Outlet

Zero Gas Span	<u>20.1 ppm NO_x</u>	Cylinder Pressure	<u>14.50</u>
Zero Gas	<u>35 ppm NO₂</u>	Cylinder Pressure	<u>1800</u>
Oxygen		Cylinder Pressure	<u>2350</u>

TIME	MODE	(Indicate Adjustments)		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0840	Sample	795	C 803 F 458	200	048			Instrument Operated During Night. Recorder Stopped Inkling at 0500 3/7/75
0850	Zero	"	"	400	-016	27		Increase Record Chart Speed 120 mm/hr
0900	Zero	"	C 803 F 463	400	000	30		adjust fine zero
0904	Span	"	"	400	034	37 -		cell temp 105°F
0910	Sample	"	"	400	083 ^{to} 070			
0925	"	"	"	"	070 077 ^{to}			PDS Sample 0921
0940	"	"	"	"	077 093			
0955	Zero	"	"	400	028	35.75		
1000	Zero	"	C 803 F 452	400	000	30		adjust fine zero
1005	Sample	"	"	400	068 059 ^{to}			
1020	"	"	"	400	059 056 ^{to}			PDS Sample 1021
1030	"	"	"	400	056 097 ^{to}			
1050	"	"	"	400	097 ^{to} 130			
1105	"	"	"	400	130 ^{to} 163			
1120	NO _x	"	"	0	170			PDS Sample 1131

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/7/75Page 2 of 0166 Outlet

122-

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1125	Zero	795	C803 F452	400	016	33.3		
1130	Zero	11	C803 F447	400	000	30		adjust fine zero
1135	Sample	11	11	400	177 181 to			
1205	11	11	11	350	203 to 229			
1220	NO _x	11	11	0	236			PDS Sample 1220
1225	Sample	11	11	400	234 238 to			cell temp 105°F
1240	11	11	11	11	238 to 245			
1255	11	11	11	11	245 to 122			sieve switched to 1255
1304	11	11	11	11	122 to 228			
1312	11	11	11	11	228 041 to			
1335	11	11	11	11	041 to			PDS Sample 1320
1336	ZERO	11	11	400	-012	27.5		
1341	ZERO	11	C803 F451	400	000	30		adjust fine zero
1345	Sample	11	11	400	048 049 to			
1400	11	11	11	11	049 to 053			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/8/75Page 3 of 0166 Outlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1415	Sample	795	C 803 F 451	400	053 052			
1420	NO _x	11	11	0	053			PDS Sample 1420
1425	Sample	11	11	400	060 066 ^{to}			cell temp 110°F
1440	zero	11	11	400	-020	26		
1450	zero	11	C 803 F 458	400	000	30		adjust fine zero
1456	Sample	11	11	400	087 ^{to} 086			
1510	11	11	11	400	086 ^{to} 085			
1523	NO _x	11	11	0	083			PDS Sample 1523
1528	Sample	11	11	400	086 ^{to} 090			
1538	zero	11	11	400	-020	26		cell temp 111°F
1541	Zero	11	C 803 F 465	400	000	30		adjust fine zero
1544	Sample	11	11	400	110 ^{to} 114			
1600	11	11	11	11	114 ^{to} 126			
1620	NO _x	11	11	0	125			PDS Sample 1620
1626	Sample	11	11	400	127 ^{to} 132			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/7/75Page 4 of 0166 Outlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1640	Sample	795	C803 F465	400	132 to 136			
1655	"	"	"	"	136 138 to			PDS Sample 1654
1658	"	"	"	"	138			sieve switch 1658
1702	"	"	"	"	069			
1714	"	"	"	"	115			
1722	Zero	"	"	400	-006	28.8		
1727	Zero	"	C803 F467	400	000	30		adjust fine zero
1730	Span	"	"	400	031	36.		
1735	3980 Span	"	"	400	3950			Placed Analyzer on Range Two cell temp 110°F

NO X FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/10/75

Instrument Ser. No. 0166

Location Herrules, Bessemer Ala
Outlet

Zero Gas <0.1 ppm NO Cylinder Pressure 13

Span Zero Gas 35 ppm NO₂ Cylinder Pressure 1700

Oxygen _____ Cylinder Pressure ~~+~~ 2250

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/11/75
 Instrument Ser. No. 0166 6
 Location Herriges, Bessemer Ala
Outlet

Zero Gas	<u>10.1 ppm NO_x</u>	Cylinder Pressure	<u>1310</u>
Span Gas	<u>35 ppm NO_x</u>	Cylinder Pressure	<u>1650</u>
Oxygen		Cylinder Pressure	<u>2310</u>

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0805	Zero	795	C 790 F 487	400	+16	33.25		
0820	Zero	"	C 790 F 481	400	000	30		adjust fine zero
0825	"	"	"	025	000	30		
1300	"	"	"	400	-046	21		
1320	"	"	C 790 F 497	400	000	30		adjust fine zero
1325	Span	"	"	"	080	36		cell temperature 110°F
1350	Zero	"	"	400	+000	29.9		
1355	"	"	C 790 F 494	400	000	30		adjust fine zero
1356	Sample	"	"	"	017 ⁺⁰ 023 ⁻⁰			
1420	NO _x	"	"	0	029			PDS Sample 1420
1425	Zero	"	"	400	019	39		
1430	"	"	C 790 F 480	"	000	30		adjust fine zero
1435	Sample	"	"	400	008 ⁺⁰ 014 ⁻⁰			
1450	NO _x	"	"	0	014			PDS Sample 1450
1455	Zero Sample	"	"	400	009 ⁺⁰ 011 ⁻⁰			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER.

(Continued)

DATE 3/11/75Page 2 of 0166 Outlet

-127-

TIME	MODE	(Indicate Adjustments)		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
		SPAN SETTING	ZERO SETTING					
1500	Zero	795	C 790 F 486	400	000	30		adjust fine zero
1505	Sample	11	11	400	008 ^{to} 015			
1520	NO _x	11	11	0	015			PDS Sample 1520
1525	Zero	11	11	400	008			
1530	Zero	11	C 790 F 482	11	000	30		adjust fine zero
1535	Sample	11	C 790 F 482	400	001 ^{to} 015			
1550	NO _x	11	11	0	016			PDS Sample 1550
1555	Zero	11	11	400	007	30.8		
1600	Zero	11	C 790 F 480	11	000	30		adjust fine zero
1605	Sample	11	11	400	016 ^{to} 021			
1620	NO _x	11	11	0	023			PDS Sample 1620
1625	Zero	11	11	400	007			
1630	Zero	11	C 790 F 477	400	000	30		
1635	Sample	11	11	400	019 ^{to} 023			
1650	NO _x	11	11	0	023			PDS Sample 1650

NO FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/12/75

Page 3 of 0166 Outlet

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/12/75Instrument Ser. No. 0166Location Hercules, Bessemer Ala
OutletZero Gas 20.1 ppm NO_x Cylinder Pressure 1300Zero Gas 35 ppm NO_x Cylinder Pressure 1650Oxygen 2300 Cylinder Pressure 2300

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0810	Sample	795	C 790 F 460	400	-26			
0815	Zero	"	"	400	-76	15		
0825	"	"	C790 F503	400	000	30		adjust fine zero
0840	Span	"	"	400	030 ⁺⁰ 037 ⁺⁰			cell temp 112°F
0845	zero	"	"	400	007 ⁺⁰ 033 ⁺⁰			
0930	zero	"	C790 F991	400	000	30		adjust fine zero
0935	Sample	"	"	400	072 ⁺⁰ 083 ⁺⁰			sieved switched 1002 B on absorb
1002	Sample	"	"	400	083 ⁺⁰ 053 ⁺⁰ 077			
1027	NO _x	"	"	0	077			PDS Sample 1028
1032	zero	"	"	400	010	32		
1037	zero	"	C790 F988	400	000	30		adjust fine zero
1040	Sample	"	"	400	046 ⁺⁰ 049			
1122	NO _x	"	"	0	079			PDS Sample 1120
1127	zero	"	"	400	000	30		cell temp 113°F
1130	Sample	"	"	400	052 ⁺⁰ 050 ⁺⁰			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued).

DATE 3/12/75Page 2 of 0166 outlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1220	NO _x	795	C790 F488	0	050			PDS sample 1220
1225	Zero	"	"	400	-008	28.25		cell temp 114°F
1230	Zero	"	C790 F490	400	000	30		adjust fine zero
1235	Sample	"	"	400	063 to 067 to			
1320	NO _x	"	"	0	peak 066			
1325	Zero	"	"	400	-010			
1330	Zero	"	C790 F495	400	000	30		adjust fine zero
1335	Sample	"	"	400	077 to 101 to			1345 increased production sieve switched 1404 to A adsorb
1404	Sample	"	"	400	055 to 093 to 059			
1435	NO _x	"	"	0	060			PDS Sample 1430
1440	Zero	"	"	400	011	32.25		
1445	Zero	"	C790 F491	400	000	30		adjust fine zero
1450	Sample	"	"	400	045 to 057			
1520	NO _x	"	"	0	053			PDS Sample 1520
1525	Zero	"	"	7CC	003 005 to			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/12/75Page 3 of 0166 Outlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1530 zero	zero	795	C790 F488	11	400	000	30		adjust fine zero
1535	Sample	11	11	11		061 to 088			
1620	NO _x	11	11	0		090			PDS Sample 1620
1625	zero sample	11	11	400		016	33.3		
1630	zero	11	C790 F483	400		000	30		adjust fine zero cell temp 108 °C
1638	Sample	11	11	400		077 095 to			
1720	NO _x	11	11	0		095			PDS Sample 1720
1725	zero sample	11	11	400		004	30.8		
1730	zero	11	C790 F482	11		000	30		adjust fine zero
1735	Sample	11	11	400		103 121 to			cell temp 109 °F
1806	Sample	11	11	400		121			sieve switched
1810	zero	11	11	400		000	30		
1833	Span	11	11	400		031	36.2		cell temp 108 °F
1845	Sample	11	11	400					

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/13/75Instrument Ser. No. 0166Location Hercules, Bessemer Ala
OutletZero Gas CO.1 ppm NO_x Cylinder Pressure 1200Span Gas 3.5 ppm Cylinder Pressure _____

Oxygen _____ Cylinder Pressure _____

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0815	Sample	795	C790 F482	400	84			cell temp 105°F
0816	zero	"	"	400	+32	36.4		
0830	"	"	C790 F469	"	000	30		adjust fine zero
0845	Span	"	"	400	032	36.4		
0900	zero	"	"	400	000	30		
0907	Span	"	"	400	031	36.2		
0925	Sample	"	"	400	057 070			
1010	zero	"	"	400	010	32		
1013	zero	"	C790 F466	400	000	30		adjust fine zero
1016	Sample	"	"	400	041 050 to			sieve switched 1017 to B on Adsorb Bypass opened 1010
1049	NO _x	"	"	0	056			PDS Sample 1049
1054	Sample	"	"	400	079 050 to			
1135	NO _x	"	"	0	051			PDS Sample 1135
1140	zero	"	"	400	022	34.3		
1145	zero	"	C790 F458	400				adjust fine zero increased production 1141

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/13/75Page 2 of 0166 Outlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1150	Sample	795	C 790 F 458	400	030 052 to				
1222	NO _x	11	11	0	054				
1227	Zero	11	11	400	-004				cell temp 107°F
1232	Zero	11	C 790 F 460	400	000	30			adjust fine zero
1235	Sample	11	11	400	069 102 to				
1320	NO _x	11	11	0	102				
1325	Zero	11	11	400	-07	26.7			cell temp 108°F PDS Sample 1325
1330	Zero	11	C 790 F 466	11	000	30			adjust fine zero
1335	Sample	11	11	400	136 147 to				cell temp 109°F
1357	Sample	11	11	400	147 187 to				Sundyne off air on Bypass valve opened
1447	Zero	11	11	400	-012				cell temp 109°F
1450	Zero	11	C 790 F 470	400	000				adjust fine zero
1452	Sample	11	11	400	202 187 to				
1503	Sample	11	11	400	045				sieve switched to A on adsorb
1535	NO _x	11	11	0	044				PDS Sample 1535

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/13/75Page 3 of 0166 Outlet

-134-

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1540	Zero	795	C 790 F 458	400	-014	26.2		cell temp 110°F
1545	Zero	11	C 790 F 476	400	000	30		adjust fine zero
1550	Sample	11	11	400	051 073 to			
1635	NO _x	11	11	0	102 104 to			PDS Sample 1635 cell temp 109°F
1640	Zero	11	11	400	016	33		
1643	Zero	11	C 790 F 470	11	000	30		adjust fine zero
1645	Sample	11	11	400	102 148 to			
1730	Zero	11	11	400	005	31		
1733	Zero	11	C 790 F 467	11	000	30		adjust fine zero
1735	Sample	11	11	400	148 165 to			cell temp 108°F
1750	NO _x	11	11	0	165			PDS Sample 1735
1755	Sample	11	11	400	174 to 192			
1810	Zero	11	11	400	-005			
1813	Zero	11	C 790 F 470	11	000	30		adjust fine zero
1815	Sample	11	11	400	208 255 to			

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/13/75Page 4 of 0166 Outlet

TIME	MODE	(Indicate Adjustments) SPAN SETTING		ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1845	NO _x	795	C 790	F 470	0	256			cell temp 108°F
1850	Sample	11	11	400	264 ^{to} 271 ^{to}				PDS sample 1850
1905	Zero	11	11	400	+03	30.5			Sieve switched to B on absorb
1910	11	11	C 790 F 469	400	000	30			adjust fine zero
1913	Span	11	11	400	032	36.5			cell temp 106°F
1920	Sample	11	11	400					

NO_x FIELD DATA --

DUPONT 411 PHOTOMETRIC ANALYZER

Date 3/14/75Instrument Ser. No. 0166Location Herrules, Bessemer Alc.
OutletZero Gas <0.1 ppm NO_x Cylinder Pressure 1150Zero Gas 3.5 ppm NO_x Cylinder Pressure 1600Oxygen 2200 Cylinder Pressure 2200

TIME	MODE	(Indicate Adjustments) SPAN SETTING	ZERO SETTING	FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
0630	Sample	795	C790 F469	400				
0635	Zero	11	11	11	102	50.5		
0643	Zero	11	C790 F433	11	000	30		adjust fine zero
0645	Span	11	11	400	031	36		cell temp 98°C
0651	Sample	11	11	400	155 192 to			
0711	Sample	11	11	400	80 to 116 to 163			Sieve switch to A on Adsorb 0711
0750	NO _x	11	11	0	068			
0755	Zero	11	11	400	008			PDS sample 0755
0758	Zero	11	C790 F429	400	000	30		adjust + fine zero
0802	Sample	11	11	400	056 099 to			
0818	NO _x	11	11	0	099			cell temp 102°F
0853	Zero	11	11	400	000	30		
0858	Sample	11	11	400	114 to 163			
0951	NO _x	11	11	0	163			PDS sample 0951
0956	Zero	11	11	400	000	30		

NO_x FIELD DATA

DUPONT 411 PHOTOMETRIC ANALYZER

(Continued)

DATE 3/14/75Page 2 of 0166 Out lot

TIME	MODE	(Indicate Adjustments) SPAN SETTING		FLOW (cc/min)	METER CONC. (ppm)	AVERAGE RECORDER % OF CHART	CONC. FROM CHART (ppm)	COMMENTS
1000	Sample	795	C790 F429	400	183 235 to			
1051	NO _x	11	11	0	235			PDS sample 1051 cell temp 101°F
1056	Zero	11	11	400	-001			
1058	Zero	11	C790 F430	11	000	30		adjust fine zero
1100	Sample	11	11	400	244 249 to			
1114	Sample	11	11	400	249			sieve switched 1114
1115	Zero	11	11	400	+003	30.75		
1122	Zero	11	C790 F429	400	000	30		adjust fine zero
1127	Span	11	11	400	082			cell temp 100

APPENDIX E

FIELD DATA FOR EPA METHOD NO. 7 TESTS

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

 DATE 06 Mar 75

 RUN NO. CAL. Gas.

1/Perkins, Inc. Bessemer, Ala. 3980 ppm		1	2	3
Time				
Flask Number		6	7	8
V _f Volume of Flask and Valve, ml		2073	2099	2058
V _a Volume of Absorbing Reagent, ml		25	25	25
V _n Volume of Flask minus Reagent, ml		2048	2074	2033
P _{bi} Initial Barometric Pressure, in. Hg		29.78	29.76	29.76
P _{fi} Initial Flask Vacuum, in. Hg vac		26.75	26.65	26.50
P _i Initial Absolute Pressure in Flask, in. Hg		3.01	3.11	3.26
P _{bf} Final Barometric Pressure, in. Hg		29.53	29.80	29.80
P _{ff} Final Flask Vacuum in. Hg vac		-8.78	-2.85	-2.35
P _f Final Absolute Pressure in Flask, in. Hg		20.75	26.95	27.45
T _i Initial Flask Temperature, °F		75	75	63
T _{ir} Initial Flask Temperature, °R		535	535	523
T _f Final Flask Temperature, °F		74	66	68
T _{fr} Final Flask Temperature, °R		534	526	528
V _{sc} Volume of Sample at Dry Std. Cond., ml		1205	1668	1647
M Mass of NO ₂ in Gas Sample, µg		6,250	13,350	12,750
C Concentration of NO _x as NO ₂ , dry basis, lb/scf	3.215 x 10 ⁻⁴	4.961 x 10 ⁻⁴	4.774 x 10 ⁻⁴	4.037 x 10 ⁻⁴
PPM V	2705	4174	4037	

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

$$PPM V = \frac{(C)(387 \times 10^6)}{46}$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 07 MAR 75
RUN NO. Cal Gas

Hercules, Inc. Bessemer, Ala.

4 5 6
3 2 3

Time			
Flask Number	10	11	12
V _f Volume of Flask and Valve, ml	2050	2052	2067
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2025	2027	2042
P _{bi} Initial Barometric Pressure, in. Hg	29.76	29.75	29.75
P _{fi} Initial Flask Vacuum, in. Hg vac	26.60	26.65	26.60
P _i Initial Absolute Pressure in Flask, in. Hg	3.16	3.10	3.15
P _{bf} Final Barometric Pressure, in. Hg	29.80	29.80	29.80
P _{ff} Final Flask Vacuum in. Hg vac	0.00	0.00	-1.60
P _f Final Absolute Pressure in Flask, in. Hg	29.80	29.80	28.20
T _i Initial Flask Temperature, °F	74	74	74
T _{ir} Initial Flask Temperature, °R	534	534	534
T _f Final Flask Temperature, °F	68	68	68
T _{fr} Final Flask Temperature, °R	523	523	523
V _{sc} Volume of Sample at Dry Std. Cond., ml	1812	1818	1718
M Mass of NO ₂ in Gas Sample, µg	142	138	142
C Concentration of NO _x as NO ₂ , dry basis, lb/scf	4.859 x 10 ⁻⁶	4.707 x 10 ⁻⁶	5.124 x 10 ⁻⁶

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

$$P_{ff} = \frac{(C)(5.87 \times 10^{-6})}{T_{fr}}$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

 DATE 05 Mar. 75

 RUN NO. inlet HV-12

F'recules, Inc. Bessemer, AL.

 Run No.: HV-K-1 HV-12-1 HV-12-2

Time	CONTAMINATE	1316	1345
Flask Number	*1	3	5
V _f Volume of Flask and Valve, ml	2039	1965	1955
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2014	1940	1930
P _{bi} Initial Barometric Pressure, in. Hg	29.75	29.75	29.74
P _{fi} Initial Flask Vacuum, in. Hg vac	26.00	26.50	26.65
P _i Initial Absolute Pressure in Flask, in. Hg		3.25	3.09
P _{bf} Final Barometric Pressure, in. Hg		29.76	29.77
P _{ff} Final Flask Vacuum in. Hg vac	-0.50	-1.90	
P _f Final Absolute Pressure in Flask, in. Hg		29.26	24.87
T _i Initial Flask Temperature, °F	73	75	74
T _{ir} Initial Flask Temperature, °R	535	535	
T _f Final Flask Temperature, °F		71	70
T _{fr} Final Flask Temperature, °R		531	530
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

 * H₂O sucked back from bypass line

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 05 Mar 75

RUN NO. inlet . HV-12

Hercules, Inc. Bessemer, Ala.

Run No. - HV-12-3 | HV-12-4 | HV-12-5

Time	1415	1446	1516
Flask Number	7	9	11
V _f Volume of Flask and Valve, ml	2116	2053	2069
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2091	2028	2044
P _{bi} Initial Barometric Pressure, in. Hg	29.72	29.71	29.71
P _{fi} Initial Flask Vacuum, in. Hg vac	26.60	26.60	26.70
P _i Initial Absolute Pressure in Flask, in. Hg	3.12	3.11	3.01
P _{bf} Final Barometric Pressure, in. Hg	29.78	29.77	29.73
P _{ff} Final Flask Vacuum in. Hg vac	-0.05	-0.60	+0.20
P _f Final Absolute Pressure in Flask, in. Hg	29.73	29.17	29.93
T _i Initial Flask Temperature, °F	75	75	70
T _{ir} Initial Flask Temperature, °R	535	535	530
T _f Final Flask Temperature, °F	70	73	81
T _{fr} Final Flask Temperature, °R	530	533	541
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

 DATE 05 Mar. 75

 RUN NO. inlet - HV-12

Hercules, Inc. Bessemer, AL		Run No. - HV-12-6	HV-12-7	HV-12-8
Time		1545	1645	1745
Flask Number		13	15	1
V _f	Volume of Flask and Valve, ml	2071	2064	2039
V _a	Volume of Absorbing Reagent, ml	25	25	25
V _n	Volume of Flask minus Reagent, ml	2046	2039	2014
P _{bi}	Initial Barometric Pressure, in. Hg	29.70	29.68	29.66
P _{fi}	Initial Flask Vacuum, in. Hg vac	26.60	26.65	26.60
P _i	Initial Absolute Pressure in Flask, in. Hg	3.10	3.03	3.06
P _{bf}	Final Barometric Pressure, in. Hg	29.73	29.72	29.76
P _{ff}	Final Flask Vacuum in. Hg vac	0.00	+0.05	+0.85
P _f	Final Absolute Pressure in Flask, in. Hg	29.73	29.77	30.61
T _i	Initial Flask Temperature, °F	73	68	71
T _{ir}	Initial Flask Temperature, °R	533	528	531
T _f	Final Flask Temperature, °F	76	75	71
T _{fr}	Final Flask Temperature, °R	536	535	531
V _{sc}	Volume of Sample at Dry Std. Cond., ml			
M	Mass of NO ₂ in Gas Sample, µg			
C	Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 06 Mar 75
RUN NO. Inlet HU-12

Hercules, Inc. Bessemer, AL

Run No. HU 12.9/HU 12-10: HU-12.1

Time	1015	1115	1215
Flask Number	1	3	5
V _f Volume of Flask and Valve, ml	2039	1965	1955
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2014	1940	1930
P _{bi} Initial Barometric Pressure, in. Hg	29.78	29.77	29.76
P _{fi} Initial Flask Vacuum, in. Hg vac	26.40	26.60	26.65
P _i Initial Absolute Pressure in Flask, in. Hg	3.38	3.17	3.11
P _{bf} Final Barometric Pressure, in. Hg	29.65	29.64	29.64
P _{ff} Final Flask Vacuum in. Hg vac	+0.45	-5.85	-1.75
P _f Final Absolute Pressure in Flask, in. Hg	30.10	23.79	27.69
T _i Initial Flask Temperature, °F	75	73	73
T _{ir} Initial Flask Temperature, °R	535	533	533
T _f Final Flask Temperature, °F	74	73	73
T _{fr} Final Flask Temperature, °R	534	533	533
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 06-MAR-75

RUN NO. Inlet HV-12

Kemicks, Inc. Bessemer, Ala.

Run No. HV-12-12 HV-12-13 HV-12-14

Time	1316	1415	1515
Flask Number	7	9	11
V_f Volume of Flask and Valve, ml	2116	2053	2069
V_a Volume of Absorbing Reagent, ml	25	25	25
V_n Volume of Flask minus Reagent, ml	2091	2028	2044
P_{bi} Initial Barometric Pressure, in. Hg	29.75	29.73	29.73
P_{fi} Initial Flask Vacuum, in. Hg vac	26.50	26.35	26.40
P_i Initial Absolute Pressure in Flask, in. Hg	3.25	3.38	3.33
P_{bf} Final Barometric Pressure, in. Hg	29.63	29.61	29.60
P_{ff} Final Flask Vacuum in. Hg vac	+0.05	-1.75	-1.05
P_f Final Absolute Pressure in Flask, in. Hg	29.68	27.86	28.55
T_i Initial Flask Temperature, °F	74	74	74
T_{ir} Initial Flask Temperature, °R	534	534	534
T_f Final Flask Temperature, °F	73	73	72
T_{fr} Final Flask Temperature, °R	533	533	532
V_{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO_2 in Gas Sample, µg			
C Concentration of NO_x as NO_2 , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

 DATE 06 Mar 75

 RUN NO. Inlet HU12

 Hercules, Inc. Bessemer Ala. ^{Run No.} HU12-15 HU12-16

Time	1616	1715
Flask Number	13	15
V _f Volume of Flask and Valve, ml	2071	2064
V _a Volume of Absorbing Reagent, ml	25	25
V _n Volume of Flask minus Reagent, ml	2046	2039
P _{bi} Initial Barometric Pressure, in. Hg	29.71	29.70
P _{fi} Initial Flask Vacuum, in. Hg vac	26.50	26.45
P _i Initial Absolute Pressure in Flask, in. Hg	3.21	3.25
P _{bf} Final Barometric Pressure, in. Hg	29.61	29.58
P _{ff} Final Flask Vacuum in. Hg vac	+0.45	-6.10
P _f Final Absolute Pressure in Flask, in. Hg	30.06	23.48
T _i Initial Flask Temperature, °F	75	73
T _{ir} Initial Flask Temperature, °R	535	533
T _f Final Flask Temperature, °F	73	74
T _{fr} Final Flask Temperature, °R	533	534
V _{sc} Volume of Sample at Dry Std. Cond., ml		
M Mass of NO ₂ in Gas Sample, µg		
C Concentration of NO _x as NO ₂ , dry basis, lb/scf		

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 7 Mar 75
 RUN NO. HV-12 - Inlet

Herrules, Inc. Bessemer, Ala. Run No. HV-12-17 HV-12-18 HV-12-19

Time	915	1015	1115
Flask Number	1	3	5
V _f Volume of Flask and Valve, ml	2039	1965	1955
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2014	1940	1930
P _{bi} Initial Barometric Pressure, in. Hg	29.65	29.63	29.61
P _{fi} Initial Flask Vacuum, in. Hg vac	26.45	26.55	26.25
P _i Initial Absolute Pressure in Flask, in. Hg	3.20	3.08	3.36
P _{bf} Final Barometric Pressure, in. Hg	29.83	29.84	29.84
P _{ff} Final Flask Vacuum in. Hg vac	-2.10	-0.90	-4.85
P _f Final Absolute Pressure in Flask, in. Hg	27.73	28.94	24.99
T _i Initial Flask Temperature, °F	74	73	72
T _{ir} Initial Flask Temperature, °R	534	533	532
T _f Final Flask Temperature, °F	67	65	65
T _{fr} Final Flask Temperature, °R	527	525	525
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 07 Mar

RUN NO. HVI2 Inlet

Hercules, Inc. Bessemer AL Run No. HVI2-20 HVI2-21 HVI2-22

Time	1215	1316	115
Flask Number	7	9	11
V _f Volume of Flask and Valve, ml	2116	2053	2069
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2091	2028	2014
P _{bi} Initial Barometric Pressure, in. Hg	29.61	29.60	29.58
P _{fi} Initial Flask Vacuum, in. Hg vac	26.35	26.50	26.25
P _i Initial Absolute Pressure in Flask, in. Hg	3.26	3.10	3.33
P _{bf} Final Barometric Pressure, in. Hg	29.85	29.84	29.82
P _{ff} Final Flask Vacuum in. Hg vac	-1.75	-3.55	-4.10
P _f Final Absolute Pressure in Flask, in. Hg	28.10	26.29	25.72
T _i Initial Flask Temperature, °F	72	73	76
T _{ir} Initial Flask Temperature, °R	532	533	536
T _f Final Flask Temperature, °F	64	65	65
T _{fr} Final Flask Temperature, °R	524	525	525
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

 DATE 07 MAR 75

 RUN NO. HV 12 Inlet

Hercules Inc. Bessemer, Ala.		Run No	HV12-23	HV12-24	HV12-25
Time			1517	1615	1658 1700
Flask Number			13	15	6 (ES)
V _f	Volume of Flask and Valve, ml		2071	2064	2073
V _a	Volume of Absorbing Reagent, ml		25	25	25
V _n	Volume of Flask minus Reagent, ml		2046	2039	2048
P _{bi}	Initial Barometric Pressure, in. Hg		29.56	29.53	29.54
P _{fi}	Initial Flask Vacuum, in. Hg vac		26.50	26.35	26.50
P _i	Initial Absolute Pressure in Flask, in. Hg		3.06	3.18	3.04
P _{bf}	Final Barometric Pressure, in. Hg		29.82	29.82	29.82
P _{ff}	Final Flask Vacuum in. Hg vac		-1.75	-4.10	-1.00
P _f	Final Absolute Pressure in Flask, in. Hg		28.07	25.72	28.82
T _i	Initial Flask Temperature, °F		77	75	78
T _{ir}	Initial Flask Temperature, °R		537	535	538
T _f	Final Flask Temperature, °F		65	65	65
T _{fr}	Final Flask Temperature, °R		525	525	525
V _{sc}	Volume of Sample at Dry Std. Cond., ml				
M	Mass of NO ₂ in Gas Sample, µg				
C	Concentration of NO _x as NO ₂ , dry basis, lb/scf				

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 11 MAR 75 Plant Hercules Inc.
 RUN NO. Inlet 17/12 Location Bessemer, Ala.

Run No H112-26 H112-27 H112-28

Time	1415	1445	1515
Flask Number	1	3	5
V_f Volume of Flask and Valve, ml	2039	1965	1955
V_a Volume of Absorbing Reagent, ml	25	25	25
V_n Volume of Flask minus Reagent, ml	2014	1940	1930
P_{bi} Initial Barometric Pressure, in. Hg	29.65	29.65	29.62
P_{fi} Initial Flask Vacuum, in. Hg vac	27.35	27.10	26.75
P_i Initial Absolute Pressure in Flask, in. Hg	2.30	2.55	2.87
P_{bf} Final Barometric Pressure, in. Hg	29.51	29.51	29.50
P_{ff} Final Flask Vacuum in. Hg vac	+0.55	-0.30	+0.20
P_f Final Absolute Pressure in Flask, in. Hg	30.06	28.71	29.70
T_i Initial Flask Temperature, °F	74	73	75
T_{ir} Initial Flask Temperature, °R	534	533	535
T_f Final Flask Temperature, °F	78	78	78
T_{fr} Final Flask Temperature, °R	538	538	538
V_{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO_2 in Gas Sample, µg			
C Concentration of NO_x as NO_2 , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

 DATE 11 MAR 75 PLANT Hercules Inc.

 RUN NO. INlet HV12 LOCATION Boasement Aha.

 Run No HV12-29 ^{1/3 outlet} HV12-30 HV12-31

	Time	1545	1615	1645
	Flask Number	8	9	11
V _f	Volume of Flask and Valve, ml	2080	2116	2053
V _a	Volume of Absorbing Reagent, ml	25	25	25
V _n	Volume of Flask minus Reagent, ml	2055	2091	2028
P _{bi}	Initial Barometric Pressure, in. Hg	29.62	29.62	29.61
P _{fi}	Initial Flask Vacuum, in. Hg vac	26.60	26.70	26.65
P _i	Initial Absolute Pressure in Flask, in. Hg	3.02	2.96	2.85
P _{bf}	Final Barometric Pressure, in. Hg	29.53	29.55	29.55
P _{ff}	Final Flask Vacuum in. Hg vac	-7.50	-3.80	-2.25
P _f	Final Absolute Pressure in Flask, in. Hg	22.03	25.75	27.30
T _i	Initial Flask Temperature, °F	77	77	73
T _{ir}	Initial Flask Temperature, °R	537	533	535
T _f	Final Flask Temperature, °F	78	79	77
T _{fr}	Final Flask Temperature, °R	538	539	537
V _{sc}	Volume of Sample at Dry Std. Cond., ml			
M	Mass of NO ₂ in Gas Sample, µg			
C	Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 11 Mar 75 Plant Hercules Inc.
 RUN NO. Ink #FH/12 Location Bessemer, Ala.

Run No. FH/12 32 11/12 33 FH/12 34

Time	1715	1745
Flask Number	8(E)	15
V_f Volume of Flask and Valve, ml	2058	2064
V_a Volume of Absorbing Reagent, ml	25	25
V_n Volume of Flask minus Reagent, ml	2033	2039
P_{bi} Initial Barometric Pressure, in. Hg	29.60	29.60
P_{fi} Initial Flask Vacuum, in. Hg vac	26.7	26.65
P_i Initial Absolute Pressure in Flask, in. Hg	2.85	2.95
P_{bf} Final Barometric Pressure, in. Hg	29.55	29.50
P_{ff} Final Flask Vacuum in. Hg vac	1.50	-0.90
P_f Final Absolute Pressure in Flask, in. Hg	31.05	29.60
T_i Initial Flask Temperature, °F	73	75
T_{ir} Initial Flask Temperature, °R	533	535
T_f Final Flask Temperature, °F	77	76
T_{fr} Final Flask Temperature, °R	537	536
V_{sc} Volume of Sample at Dry Std. Cond., ml		
M Mass of NO_2 in Gas Sample, µg		
C Concentration of NO_x as NO_2 , dry basis, lb/scf		

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

 DATE 12 Mar 75

 Plant Hercules Inc.

 RUN NO. Inlet HV12

 Location Bessemer, Ala.

 Run No HV12-34 11/12-35 11/12-36

Time	1023	1117	1215
Flask Number	1	3	5
V _f Volume of Flask and Valve, ml	20.39	19.65	19.55
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	20.14	19.10	19.30
P _{bi} Initial Barometric Pressure, in. Hg	29.53	29.53	29.55
P _{fi} Initial Flask Vacuum, in. Hg vac	26.55	26.45	26.45
P _i Initial Absolute Pressure in Flask, in. Hg	2.98	3.08	3.10
P _{bf} Final Barometric Pressure, in. Hg	29.46	29.47	29.46
P _{ff} Final Flask Vacuum in. Hg vac	-0.65	-1.05	-2.05
P _f Final Absolute Pressure in Flask, in. Hg	28.81	28.42	27.41
T _i Initial Flask Temperature, °F	77	78	78
T _{ir} Initial Flask Temperature, °R	537	538	538
T _f Final Flask Temperature, °F	75	73	72
T _{fr} Final Flask Temperature, °R	535	533	532
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 12 Mar 75 Plant Hercules Inc.
 RUN NO. Inlet HV12 Location Bessemer Alc.

	RUN No 14V12-37	14V12-33	14V12-39
Time	1316	1430	1516
Flask Number	7	9	11
V_f Volume of Flask and Valve, ml	2116	2063	2069
V_a Volume of Absorbing Reagent, ml	25	25	25
V_n Volume of Flask minus Reagent, ml	2091	2038	2044
P_{bi} Initial Barometric Pressure, in. Hg	29.55	29.54	29.54
P_{fi} Initial Flask Vacuum, in. Hg vac	26.35	26.40	26.20
P_i Initial Absolute Pressure in Flask, in. Hg	3.20	3.14	3.34
P_{bf} Final Barometric Pressure, in. Hg	29.42	29.42	29.33
P_{ff} Final Flask Vacuum in. Hg vac	+0.05	-0.45	-0.20
P_f Final Absolute Pressure in Flask, in. Hg	29.47	28.97	29.13
T_i Initial Flask Temperature, °F	78	78	77
T_{ir} Initial Flask Temperature, °R	538	538	537
T_f Final Flask Temperature, °F	68	68	74
T_{fr} Final Flask Temperature, °R	528	528	534
V_{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO_2 in Gas Sample, µg			
C Concentration of NO_x as NO_2 , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 12 Mar 75
RUN NO. HV12 Inlet

Hercules Inc. Bessemer Alz. Run No. HV-12-40/HV-12-41

Time	1615	1715
Flask Number	80	15
V _f Volume of Flask and Valve, ml	2058	2064
V _a Volume of Absorbing Reagent, ml	25	25
V _n Volume of Flask minus Reagent, ml	2033	2039
P _{bi} Initial Barometric Pressure, in. Hg	29.50	29.48
P _{fi} Initial Flask Vacuum, in. Hg vac	26.40	26.35
P _i Initial Absolute Pressure in Flask, in. Hg	3.10	3.13
P _{bf} Final Barometric Pressure, in. Hg	29.33	29.32
P _{ff} Final Flask Vacuum in. Hg vac	0.00	-0.40
P _f Final Absolute Pressure in Flask, in. Hg	29.33	28.92
T _i Initial Flask Temperature, °F	77.	76
T _{ir} Initial Flask Temperature, °R	537	536
T _f Final Flask Temperature, °F	70	71
T _{fr} Final Flask Temperature, °R	530	531
V _{sc} Volume of Sample at Dry Std. Cond., ml		
M Mass of NO ₂ in Gas Sample, µg		
C Concentration of NO _x as NO ₂ , dry basis, lb/scf		

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 13 Mar 74

RUN NO. Inlet 11V12

Hercules Inc. Bassomer Aha. Run No. 11V12-42/11V12-43/11V12-44

Time	1047	1132	1219
Flask Number	1	3	5
V_f Volume of Flask and Valve, ml	2039	1965	1955
V_a Volume of Absorbing Reagent, ml	25	25	25
V_n Volume of Flask minus Reagent, ml	2014	1940	1930
P_{bi} Initial Barometric Pressure, in. Hg	29.44	29.43	29.41
P_{fi} Initial Flask Vacuum, in. Hg vac	26.35	26.25	26.35
P_i Initial Absolute Pressure in Flask, in. Hg	3.09	3.13	3.06
P_{bf} Final Barometric Pressure, in. Hg	29.56	29.59	29.63
P_{ff} Final Flask Vacuum in. Hg vac	-2.90	-3.30	-3.60
P_f Final Absolute Pressure in Flask, in. Hg	26.66	26.29	26.03
T_i Initial Flask Temperature, °F	70	68	70
T_{ir} Initial Flask Temperature, °R	530	528	530
T_f Final Flask Temperature, °F	59	58	59
T_{fr} Final Flask Temperature, °R	519	513	519
V_{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO_2 in Gas Sample, µg			
C Concentration of NO_x as NO_2 , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

 DATE 13 Mar 75

 RUN NO. Inlet HV12

Hercules Inc - Bessemer, Ala. Run No - HV1245		46	47
Time	1317	1530	1632
Flask Number	7	9	11
V _f Volume of Flask and Valve, ml	2116	2063	2069
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2091	2038	2044
P _{bi} Initial Barometric Pressure, in. Hg	29.39	29.32	29.32
P _{fi} Initial Flask Vacuum, in. Hg vac	26.30	26.30	26.35
P _i Initial Absolute Pressure in Flask, in. Hg	3.09	3.02	2.97
P _{bf} Final Barometric Pressure, in. Hg	29.65	29.70	29.70
P _{ff} Final Flask Vacuum in. Hg vac	-2.25	-2.65	-1.35
P _f Final Absolute Pressure in Flask, in. Hg	2740	2705	2835
T _i Initial Flask Temperature, °F	73	73	77
T _{ir} Initial Flask Temperature, °R	533	533	537
T _f Final Flask Temperature, °F	59	59	59
T _{fr} Final Flask Temperature, °R	519	519	519
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

 DATE Mar 75

 RUN NO. Inket - HV12

 Hercules Inc., Bessemer, Ala. Run No. HV1248 49

Time	<u>1732</u>	<u>1847</u>
Flask Number	<u>8 (ES)</u>	<u>15</u>
V_f Volume of Flask and Valve, ml	<u>2058</u>	<u>2064</u>
V_a Volume of Absorbing Reagent, ml	<u>25</u>	<u>25</u>
V_n Volume of Flask minus Reagent, ml	<u>2033</u>	<u>2039</u>
P_{bi} Initial Barometric Pressure, in. Hg	<u>29.35</u>	<u>29.26</u>
P_{fi} Initial Flask Vacuum, in. Hg vac	<u>26.30</u>	<u>26.25</u>
P_i Initial Absolute Pressure in Flask, in. Hg	<u>3.05</u>	<u>3.01</u>
P_{bf} Final Barometric Pressure, in. Hg	<u>29.70</u>	<u>29.70</u>
P_{ff} Final Flask Vacuum in. Hg vac	<u>-2.25</u>	<u>-1.85</u>
P_f Final Absolute Pressure in Flask, in. Hg	<u>27.45</u>	<u>27.85</u>
T_i Initial Flask Temperature, °F	<u>70</u>	<u>72</u>
T_{ir} Initial Flask Temperature, °R	<u>530</u>	<u>532</u>
T_f Final Flask Temperature, °F	<u>59</u>	<u>60</u>
T_{fr} Final Flask Temperature, °R	<u>519</u>	<u>520</u>
V_{sc} Volume of Sample at Dry Std. Cond., ml		
M Mass of NO_2 in Gas Sample, µg		
C Concentration of NO_x as NO_2 , dry basis, lb/scf		

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

 DATE 14 MAR 75

 RUN NO. INKet 14V12

Hercules, Inc. Bessemer Alz. Run No. 50 51 52

Time	0747	0847	947
Flask Number	1	3	5
V _f Volume of Flask and Valve, ml	2039	1965	1955
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2014	1940	1930
P _{bi} Initial Barometric Pressure, in. Hg	29.59	29.62	29.63
P _{fi} Initial Flask Vacuum, in. Hg vac	26.45	26.50	26.70
P _i Initial Absolute Pressure in Flask, in. Hg	3.14	3.12	2.93
P _{bf} Final Barometric Pressure, in. Hg	29.79	29.79	29.79
P _{ff} Final Flask Vacuum in. Hg vac	-0.65	-0.75	-0.35
P _f Final Absolute Pressure in Flask, in. Hg	29.14	29.04	29.44
T _i Initial Flask Temperature, °F	60	60	60
T _{ir} Initial Flask Temperature, °R	520	520	520
T _f Final Flask Temperature, °F	51	51	54
T _{fr} Final Flask Temperature, °R	511	511	514
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

 DATE 14 MAR 75

 RUN NO. TNhf 14V-12
Hercules, Inc. Bessemer ALA. Run No. 53

Time	<u>1047</u>	
Flask Number	<u>7</u>	
V_f	Volume of Flask and Valve, ml	<u>2116</u>
V_a	Volume of Absorbing Reagent, ml	<u>25</u>
V_n	Volume of Flask minus Reagent, ml	<u>2091</u>
P_{bi}	Initial Barometric Pressure, in. Hg	<u>29.66</u>
P_{fi}	Initial Flask Vacuum, in. Hg vac	<u>26.65</u>
P_i	Initial Absolute Pressure in Flask, in. Hg	<u>3.01</u>
P_{bf}	Final Barometric Pressure, in. Hg	<u>29.79</u>
P_{ff}	Final Flask Vacuum in. Hg vac	<u>-1.35</u>
P_f	Final Absolute Pressure in Flask, in. Hg	<u>28.44</u>
T_i	Initial Flask Temperature, °F	<u>59</u>
T_{ir}	Initial Flask Temperature, °R	<u>519</u>
T_f	Final Flask Temperature, °F	<u>54</u>
T_{fr}	Final Flask Temperature, °R	<u>514</u>
V_{sc}	Volume of Sample at Dry Std. Cond., ml	
M	Mass of NO_2 in Gas Sample, µg	
C	Concentration of NO_x as NO_2 , dry basis, lb/scf	

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 05 Mar 75
 RUN NO. outlet-HV-13

Hercules, Inc. Bessunger, ALZ.

Run No.- HV-13-1 HV-13-2 HV-13-3

Time	1258	1318	1350
Flask Number	2	4	6
V _f Volume of Flask and Valve, ml	2035	2041	1984
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2010	2016	1959
P _{bi} Initial Barometric Pressure, in. Hg	29.75	29.75	29.74
P _{fi} Initial Flask Vacuum, in. Hg vac	26.40	26.65	26.50
P _i Initial Absolute Pressure in Flask, in. Hg	3.35	3.10	3.24
P _{bf} Final Barometric Pressure, in. Hg	29.76	29.76	29.77
P _{ff} Final Flask Vacuum in. Hg vac	+0.05	-1.50	-0.05
P _f Final Absolute Pressure in Flask, in. Hg	29.81	28.26	29.72
T _i Initial Flask Temperature, °F	73	75	73
T _{ir} Initial Flask Temperature, °R	533	535	533
T _f Final Flask Temperature, °F	71	70	70
T _{fr} Final Flask Temperature, °R	531	530	530
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

 DATE 05 Mar 75

 RUN NO. Outlet - HV-13

Hercules, Inc. Bessemer, AL

Run No. - HV-13-4 | HV-13-5 | HV-13-6

	Time	1420	1454	1520
Flask Number		8	10*	12
V _f	Volume of Flask and Valve, ml	2080	2053	2076
V _a	Volume of Absorbing Reagent, ml	25	25	25
V _n	Volume of Flask minus Reagent, ml	2055	2028	2051
P _{bi}	Initial Barometric Pressure, in. Hg	29.72	29.71	29.71
P _{fi}	Initial Flask Vacuum, in. Hg vac	26.55	26.60	26.55
P _i	Initial Absolute Pressure in Flask, in. Hg	3.17	3.11	3.16
P _{bf}	Final Barometric Pressure, in. Hg	29.78	29.77	29.73
P _{ff}	Final Flask Vacuum in. Hg vac	0.00	1.25	+0.45
P _f	Final Absolute Pressure in Flask, in. Hg	29.78	31.02	30.13
T _i	Initial Flask Temperature, °F	75	75	73
T _{ir}	Initial Flask Temperature, °R	535	535	533
T _f	Final Flask Temperature, °F	73	73	73
T _{fr}	Final Flask Temperature, °R	533	533	533
V _{sc}	Volume of Sample at Dry Std. Cond., ml			
M	Mass of NO ₂ in Gas Sample, µg			
C	Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

* E.S. STOPCOCK NO. 9 must be calibrated

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 05 Mar 75
RUN NO. HU-130 outlet

Hornickers Inc. Bessemer, Ala.		HU13-7	HU13-E	HU13-9
Time		1550	1650	1750
Flask Number		14	16*	18
V _f	Volume of Flask and Valve, ml	2124	2071	2078
V _a	Volume of Absorbing Reagent, ml	25	25	25
V _n	Volume of Flask minus Reagent, ml	2099	2046	2053
P _{bi}	Initial Barometric Pressure, in. Hg	29.70	29.68	29.66
P _{fi}	Initial Flask Vacuum, in. Hg vac	26.55	26.55	26.60
P _i	Initial Absolute Pressure in Flask, in. Hg	+3.15	3.13	3.06
P _{bf}	Final Barometric Pressure, in. Hg	29.72	29.72	29.70
P _{ff}	Final Flask Vacuum in. Hg vac	+1.20	+1.40	+2.00
P _f	Final Absolute Pressure in Flask, in. Hg	30.92	31.12	31.70
T _i	Initial Flask Temperature, °F	73	70	71
T _{ir}	Initial Flask Temperature, °R	533	530	531
T _f	Final Flask Temperature, °F	74	74	74
T _{fr}	Final Flask Temperature, °R	534	534	534
V _{sc}	Volume of Sample at Dry Std. Cond., ml			
M	Mass of NO ₂ in Gas Sample, µg			
C	Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 06 Mar 75

RUN NO. Outlet-HV-13-

Hercules, Inc. Bessemer, Ala.

Run No HV-13-10 HV-13-11 HV-13-12

Time	1021	120	1220
Flask Number	2	4	6
V _f Volume of Flask and Valve, ml	2035	2041	1984
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2010	2016	1959
P _{bi} Initial Barometric Pressure, in. Hg	29.73	29.77	29.76
P _{fi} Initial Flask Vacuum, in. Hg vac	26.65	26.65	26.55
P _i Initial Absolute Pressure in Flask, in. Hg	3.13	3.12	3.21
P _{bf} Final Barometric Pressure, in. Hg	29.65	29.64	29.63
P _{ff} Final Flask Vacuum in. Hg vac	-0.65	-0.10	-1.45
P _f Final Absolute Pressure in Flask, in. Hg	29.00	29.54	28.18
T _i Initial Flask Temperature, °F	73	73	72
T _{ir} Initial Flask Temperature, °R	533	533	532
T _f Final Flask Temperature, °F	73	73	73
T _{fr} Final Flask Temperature, °R	533	533	533
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 06 MAR 75
RUN NO. HU-13-Outlet

Hercules, Inc. Bessemer, AL		Run No. HU-13- ⁻¹³ 1 HU-13-14 HU-13-15
Time	1320	1420 1520
Flask Number	8	10 12
V _f Volume of Flask and Valve, ml	2080	2053 2076
V _a Volume of Absorbing Reagent, ml	25	25 25
V _n Volume of Flask minus Reagent, ml	20.55	20.28 20.51
P _{bi} Initial Barometric Pressure, in. Hg	29.75	29.73 29.73
P _{fi} Initial Flask Vacuum, in. Hg vac	26.45	26.40 26.50
P _i Initial Absolute Pressure in Flask, in. Hg	3.30	3.33 3.23
P _{bf} Final Barometric Pressure, in. Hg	29.61	29.61 29.61
P _{ff} Final Flask Vacuum in. Hg vac	-5.75	+0.50 -4.55
P _f Final Absolute Pressure in Flask, in. Hg	23.86	30.11 25.06
T _i Initial Flask Temperature, °F	74	74 74
T _{ir} Initial Flask Temperature, °R	534	534 534
T _f Final Flask Temperature, °F	72	72 73
T _{fr} Final Flask Temperature, °R	532	532 533
V _{sc} Volume of Sample at Dry Std. Cond., ml		
M Mass of NO ₂ in Gas Sample, µg		
C Concentration of NO _x as NO ₂ , dry basis, lb/scf		

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 06 MAR 75
RUN NO. Outlet 1/HU13

Hercules, Inc. Bessemer Alz. Run No. HU13 16 HU13 17

Time	1621	16
Flask Number	14	16
V _f Volume of Flask and Valve, ml	2124	2071
V _a Volume of Absorbing Reagent, ml	25	25
V _n Volume of Flask minus Reagent, ml	1099	2046
P _{bi} Initial Barometric Pressure, in. Hg	29.71	29.70
P _{fi} Initial Flask Vacuum, in. Hg vac	26.40	26.55
P _i Initial Absolute Pressure in Flask, in. Hg	3.31	
P _{bf} Final Barometric Pressure, in. Hg	29.60	
P _{ff} Final Flask Vacuum in. Hg vac	-1.45	
P _f Final Absolute Pressure in Flask, in. Hg	28.15	
T _i Initial Flask Temperature, °F	75	73
T _{ir} Initial Flask Temperature, °R	535	
T _f Final Flask Temperature, °F	73	
T _{fr} Final Flask Temperature, °R	533	
V _{sc} Volume of Sample at Dry Std. Cond., ml		
M Mass of NO ₂ in Gas Sample, µg		
C Concentration of NO _x as NO ₂ , dry basis, lb/scf		

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 7 Mar 75
 RUN NO. HV-13 Outlet

X Hercules, Inc. Bessemer Alz. Run No. HV-13-17 HV-13-18 HV-13-19

	Time	0921	1021	1121
	Flask Number	2	4	6
V _f	Volume of Flask and Valve, ml	2035	2041	1984
V _a	Volume of Absorbing Reagent, ml	25	25	25
V _n	Volume of Flask minus Reagent, ml	2010	2016	1959
P _{bi}	Initial Barometric Pressure, in. Hg	29.65	29.63	29.61
P _{fi}	Initial Flask Vacuum, in. Hg vac	26.50	26.45	26.55
P _i	Initial Absolute Pressure in Flask, in. Hg	3.15	3.18	3.06
P _{bf}	Final Barometric Pressure, in. Hg	29.84	29.84	29.84
P _{ff}	Final Flask Vacuum in. Hg vac	-1.45	-0.35	-0.65
P _f	Final Absolute Pressure in Flask, in. Hg	28.39	29.49	29.19
T _i	Initial Flask Temperature, °F	73	73	72
T _{ir}	Initial Flask Temperature, °R	533	533	532
T _f	Final Flask Temperature, °F	64	64	65
T _{fr}	Final Flask Temperature, °R	524	524	525
V _{sc}	Volume of Sample at Dry Std. Cond., ml			
M	Mass of NO ₂ in Gas Sample, µg			
C	Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 07 MAR
RUN NO. HV13-Outlet

Hercules Inc. Bessemer Alz. Run No. HV13-20 HV13-21 HV13-22

Time	1220	1320	1420
Flask Number	108	10	12
V _f Volume of Flask and Valve, ml	2080	2053	2026
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2055	2028	2051
P _{bi} Initial Barometric Pressure, in. Hg	29.61	29.60	29.58
P _{fi} Initial Flask Vacuum, in. Hg vac	26.50	26.45	26.40
P _i Initial Absolute Pressure in Flask, in. Hg	3.11	3.15	3.18
P _{bf} Final Barometric Pressure, in. Hg	29.84	29.84	29.83
P _{ff} Final Flask Vacuum in. Hg vac	-1.75	-0.90	-2.25
P _f Final Absolute Pressure in Flask, in. Hg	28.09	28.94	27.53
T _i Initial Flask Temperature, °F	72	7.3	76
T _{ir} Initial Flask Temperature, °R	532	533	536
T _f Final Flask Temperature, °F	65	65	65
T _{fr} Final Flask Temperature, °R	525	525	525
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 07 Mar 75
 RUN NO. HV-13 Outlet

Hercules Inc. Bessemer Alz. Run No. HV1323 HV13-24 HV13-25 *

	1524	1620	1654
Time	1524	1620	1654
Flask Number	14	16	18
V _f Volume of Flask and Valve, ml	2124	2071	2078
V _a Volume of Absorbing Reagent, ml	25	50 25	25
V _n Volume of Flask minus Reagent, ml	20992	2021	2053
P _{bi} Initial Barometric Pressure, in. Hg	29.56	29.53	29.54
P _{fi} Initial Flask Vacuum, in. Hg vac	26.45	26.50	26.45
P _i Initial Absolute Pressure in Flask, in. Hg	3.11	3.03	3.09
P _{bf} Final Barometric Pressure, in. Hg	29.82	29.82	29.82
P _{ff} Final Flask Vacuum in. Hg vac	-2.15	-2.60	-3.70
P _f Final Absolute Pressure in Flask, in. Hg	27.67	27.22	26.12
T _i Initial Flask Temperature, °F	77	75	77
T _{ir} Initial Flask Temperature, °R	533	535	537
T _f Final Flask Temperature, °F	65	65	65
T _{fr} Final Flask Temperature, °R	525	525	525
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff} \quad C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

HV13-24 was charged with 50ml P.O.S.

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 11 MAR 75 PLANT Hercules Inc.
 RUN NO. Cuthart HV13 LOCATION Bessemer, Ala.

	Run No.	HV13-26	HV13-27	HV13-28
Time	1420	1450	1520	
Flask Number	2	4	6	
V _f Volume of Flask and Valve, ml	2035	2041	1784	
V _a Volume of Absorbing Reagent, ml	25	25	25	
V _n Volume of Flask minus Reagent, ml	2010	2016	1959	
P _{bi} Initial Barometric Pressure, in. Hg	29.65	29.65	29.62	
P _{fi} Initial Flask Vacuum, in. Hg vac	27.00	26.85	26.65	
P _i Initial Absolute Pressure in Flask, in. Hg	2.65	2.30	2.27	
P _{bf} Final Barometric Pressure, in. Hg	29.51	29.51	29.53	
P _{ff} Final Flask Vacuum in. Hg vac	+0.50	+0.25	0.00	
P _f Final Absolute Pressure in Flask, in. Hg	30.01	29.76	29.53	
T _i Initial Flask Temperature, °F	74	73	75	
T _{ir} Initial Flask Temperature, °R	534	533	535	
T _f Final Flask Temperature, °F	77	77	78	
T _{fr} Final Flask Temperature, °R	537	537	538	
V _{sc} Volume of Sample at Dry Std. Cond., ml				
M Mass of NO ₂ in Gas Sample, µg				
C Concentration of NO _x as NO ₂ , dry basis, lb/scf				

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 11 MAR 75
RUN NO. HV13 OutletPlant Heaches Inc.
Location Bessemer, ALA.Run No. HV13-29 ^{11/13-30} 11/13-31

Time	5:1 <u>1521</u>	16:20 <u>1620</u>	
Flask Number	7	8 <u>10</u>	12
V _f Volume of Flask and Valve, ml	2116	2080	2055
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2091	—	2030
P _{bi} Initial Barometric Pressure, in. Hg	29.62	29.62	29.61
P _{fi} Initial Flask Vacuum, in. Hg vac	26.70	26.60	26.65
P _i Initial Absolute Pressure in Flask, in. Hg	2.92	2.96	2.90
P _{bf} Final Barometric Pressure, in. Hg	29.53	29.53	29.55
P _{ff} Final Flask Vacuum in. Hg vac	0.00 + 0.70	-4.50	
P _f Final Absolute Pressure in Flask, in. Hg	29.53	30.23	25.05
T _i Initial Flask Temperature, °F	77	77	74
T _{ir} Initial Flask Temperature, °R	537	534	535
T _f Final Flask Temperature, °F	78	78	77
T _{fr} Final Flask Temperature, °R	538	538	537
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 11 Mar 74 75

RUN NO. Cuillet 11/13

Hercules Int. Rossmere, Fla. Run No 11/13-32 11/13 33 11/13-34

Time	(72)	1750
Flask Number	14	16
V _f Volume of Flask and Valve, ml	2124	2071
V _a Volume of Absorbing Reagent, ml	25	25
V _n Volume of Flask minus Reagent, ml	2099	2046
P _{bi} Initial Barometric Pressure, in. Hg	29.60	29.60
P _{fi} Initial Flask Vacuum, in. Hg vac	26.60	26.60
P _i Initial Absolute Pressure in Flask, in. Hg	3.00	3.00
P _{bf} Final Barometric Pressure, in. Hg	29.54	29.50
P _{ff} Final Flask Vacuum in. Hg vac	-1.60	+0.50
P _f Final Absolute Pressure in Flask, in. Hg	27.94	30.00
T _i Initial Flask Temperature, °F	75	75
T _{ir} Initial Flask Temperature, °R	535	535
T _f Final Flask Temperature, °F	76	77
T _{fr} Final Flask Temperature, °R	536	537
V _{sc} Volume of Sample at Dry Std. Cond., ml		
M Mass of NO ₂ in Gas Sample, µg		
C Concentration of NO _x as NO ₂ , dry basis, lb/scf		

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 12 Mar 75RUN NO. Muthel HV13Hercules Inc. Bessemer Alat.Run No. HV13-31 HV13-35 HV13-36

	Time	1028	1120	1220
	Flask Number	2	4	6
V_f	Volume of Flask and Valve, ml	2035	2041	1984
V_a	Volume of Absorbing Reagent, ml	25	25	25
V_n	Volume of Flask minus Reagent, ml	2010	2016	1959
P_{bi}	Initial Barometric Pressure, in. Hg	29.53	29.53	29.55
P_{fi}	Initial Flask Vacuum, in. Hg vac	26.45	26.50	26.50
P_i	Initial Absolute Pressure in Flask, in. Hg	3.08	3.03	3.05
P_{bf}	Final Barometric Pressure, in. Hg	29.47	29.47	29.46
P_{ff}	Final Flask Vacuum in. Hg vac	-0.45	-0.65	-0.75
P_f	Final Absolute Pressure in Flask, in. Hg	29.02	28.82	28.71
T_i	Initial Flask Temperature, °F	77	78	78
T_{ir}	Initial Flask Temperature, °R	537	538	538
T_f	Final Flask Temperature, °F	76	73	71
T_{fr}	Final Flask Temperature, °R	536	533	531
V_{sc}	Volume of Sample at Dry Std. Cond., ml			
M	Mass of NO_2 in Gas Sample, µg			
C	Concentration of NO_x as NO_2 , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 12 MAR 75

RUN NO. Outlet-HU-13

Hercules Inc., Bessemer, Ala.		RUN No.	HU13-37	HU13-38	HU13-39
Time			1320	1425	1520
Flask Number			8	10	12
V _f	Volume of Flask and Valve, ml		2080	205.5	2076
V _a	Volume of Absorbing Reagent, ml		25	25	25
V _n	Volume of Flask minus Reagent, ml			2030	2051
P _{bi}	Initial Barometric Pressure, in. Hg		29.55	29.55	29.54
P _{fi}	Initial Flask Vacuum, in. Hg vac		26.55	26.45	26.55
P _i	Initial Absolute Pressure in Flask, in. Hg			310	292
P _{bf}	Final Barometric Pressure, in. Hg			29.41	29.33
P _{ff}	Final Flask Vacuum in. Hg vac			-0.40	-1.60
P _f	Final Absolute Pressure in Flask, in. Hg			29.01	27.73
T _i	Initial Flask Temperature, °F		78	78	77
T _{ir}	Initial Flask Temperature, °R			538	537
T _f	Final Flask Temperature, °F			71	75
T _{fr}	Final Flask Temperature, °R			531	535
V _{sc}	Volume of Sample at Dry Std. Cond., ml				
M	Mass of NO ₂ in Gas Sample, µg				
C	Concentration of NO _x as NO ₂ , dry basis, lb/scf				

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

HU13-37 Not Charged w/PDS

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 12 MAR 75
 RUN NO. HV13 - Outlet

<u>Hercules, Inc., Bessemer, Ala.</u>		<u>HV13-40</u>	<u>HV13-41</u>	<u>HV13</u>
Time		1620	1720	
Flask Number		14	16	
V_f	Volume of Flask and Valve, ml	2124	2071	
V_a	Volume of Absorbing Reagent, ml	25	25	25
V_n	Volume of Flask minus Reagent, ml	1099	2046	
P_{bi}	Initial Barometric Pressure, in. Hg	29.50	29.48	
P_{fi}	Initial Flask Vacuum, in. Hg vac	26.45	26.40	
P_i	Initial Absolute Pressure in Flask, in. Hg	3.05	3.08	
P_{bf}	Final Barometric Pressure, in. Hg	29.35	29.33	
P_{ff}	Final Flask Vacuum in. Hg vac	-1.05	-0.05	
P_f	Final Absolute Pressure in Flask, in. Hg	28.30	29.28	
T_i	Initial Flask Temperature, °F	77	76	
T_{ir}	Initial Flask Temperature, °R	537	536	
T_f	Final Flask Temperature, °F	70	70	
T_{fr}	Final Flask Temperature, °R	530	530	
V_{sc}	Volume of Sample at Dry Std. Cond., ml			
M	Mass of NO_2 in Gas Sample, µg			
C	Concentration of NO_x as NO_2 , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 13 Mar 75

RUN NO. HV13 Outlet

Hercules, Inc. Bessemer, Alat. Run No HV13-42 HV13-43 44

	Time	1049	1135	1200
	Flask Number	2	4	6
V_f	Volume of Flask and Valve, ml	2035	2041	1984
V_a	Volume of Absorbing Reagent, ml	25	25	25
V_n	Volume of Flask minus Reagent, ml	2010	2016	1959
P_{bi}	Initial Barometric Pressure, in. Hg	29.44	29.53	29.41
P_{fi}	Initial Flask Vacuum, in. Hg vac	26.40	26.30	26.25
P_i	Initial Absolute Pressure in Flask, in. Hg	3.04	3.13	3.16
P_{bf}	Final Barometric Pressure, in. Hg	29.59	29.59	29.62
P_{ff}	Final Flask Vacuum in. Hg vac	-1.60	-3.00	-1.85
P_f	Final Absolute Pressure in Flask, in. Hg	27.99	26.59	27.77
T_i	Initial Flask Temperature, °F	70	68	68
T_{ir}	Initial Flask Temperature, °R	530	528	528
T_f	Final Flask Temperature, °F	59	59	59
T_{fr}	Final Flask Temperature, °R	519	519	519
V_{sc}	Volume of Sample at Dry Std. Cond., ml			
M	Mass of NO_2 in Gas Sample, µg			
C	Concentration of NO_x as NO_2 , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 13 March
RUN NO. HV13 - Outfit

Hercules, Inc. - Bessemer, AL₂ Run No. X

HVB 45 | HV1346

Time		1325	1535
Flask Number	36	6 ES	10
V _f Volume of Flask and Valve, ml	2073	2073	2055
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2055	2048	2030
P _{bi} Initial Barometric Pressure, in. Hg	29.39	29.39	29.33
P _{fi} Initial Flask Vacuum, in. Hg vac	26.35	26.35	26.30
P _i Initial Absolute Pressure in Flask, in. Hg		3.04	3.03
P _{bf} Final Barometric Pressure, in. Hg		29.65	29.70
P _{ff} Final Flask Vacuum in. Hg vac		-3.25	-1.45
P _f Final Absolute Pressure in Flask, in. Hg		26.40	28.25
T _i Initial Flask Temperature, °F	73	73	73
T _{ir} Initial Flask Temperature, °R		533	533
T _f Final Flask Temperature, °F		59	61
T _{fr} Final Flask Temperature, °R		519	521
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 13 MAR 75
RUN NO. H/13 Outlet

Hercules Inc. - Bessemer, Ala. Run No. 47 | 48 | 49

Time	1635	1735	1850
Flask Number	12	14	16
V _f Volume of Flask and Valve, ml	2076	2124	2071
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2051	2099	2046
P _{bi} Initial Barometric Pressure, in. Hg	29.32	29.35	29.26
P _{fi} Initial Flask Vacuum, in. Hg vac	26.30	26.25	26.20
P _i Initial Absolute Pressure in Flask, in. Hg	3.02	3.10	3.06
P _{bf} Final Barometric Pressure, in. Hg	29.60	29.59	29.70
P _{ff} Final Flask Vacuum in. Hg vac	-3.10	-1.60	-1.85
P _f Final Absolute Pressure in Flask, in. Hg	26.20	27.85	27.95
T _i Initial Flask Temperature, °F	69	69	70
T _{ir} Initial Flask Temperature, °R	529	530	532
T _f Final Flask Temperature, °F	61	59	60
T _{fr} Final Flask Temperature, °R	521	520	520
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 14 MAR 75
 RUN NO. Outlet 1/14/13

Hercules, Inc. Bessemer, AL. Run No. 50 51 52

Time	0750	0850	951
Flask Number	2	4	6
V_f Volume of Flask and Valve, ml	2035	2041	1984
V_a Volume of Absorbing Reagent, ml	25	25	25
V_n Volume of Flask minus Reagent, ml	2010	2016	1959
P_{bi} Initial Barometric Pressure, in. Hg	29.59	29.62	29.63
P_{fi} Initial Flask Vacuum, in. Hg vac	26.50	26.55	26.70
P_i Initial Absolute Pressure in Flask, in. Hg	3.09	3.07	2.93
P_{bf} Final Barometric Pressure, in. Hg	29.70	29.79	29.79
P_{ff} Final Flask Vacuum in. Hg vac	-1.85	-4.10	-2.95
P_f Final Absolute Pressure in Flask, in. Hg	27.94	25.69	26.84
T_i Initial Flask Temperature, °F	60	60	60
T_{ir} Initial Flask Temperature, °R	520	520	520
T_f Final Flask Temperature, °F	51	51	54
T_{fr} Final Flask Temperature, °R	511	511	514
V_{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO_2 in Gas Sample, µg			
C Concentration of NO_x as NO_2 , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 14 MAR 75
RUN NO. Outlet 14V13

SB

Time	1050		
Flask Number	6 (E5)		
V _f Volume of Flask and Valve, ml	2073		
V _a Volume of Absorbing Reagent, ml	25		
V _n Volume of Flask minus Reagent, ml	2048		
P _{bi} Initial Barometric Pressure, in. Hg	29.66		
P _{fi} Initial Flask Vacuum, in. Hg vac	26.50		
P _i Initial Absolute Pressure in Flask, in. Hg	3.16		
P _{bf} Final Barometric Pressure, in. Hg	29.79		
P _{ff} Final Flask Vacuum in. Hg vac	-0.20		
P _f Final Absolute Pressure in Flask, in. Hg	29.59		
T _i Initial Flask Temperature, °F	59		
T _{ir} Initial Flask Temperature, °R	519		
T _f Final Flask Temperature, °F	54		
T _{fr} Final Flask Temperature, °R	514		
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

 DATE 13 MAR 75

 RUN NO. Inlet HV 23

Hercules Inc., Bossemore, CA

Run No.

HV23-1

HV23-2

HV23-3

		HV23-1	HV23-2	HV23-3
Time		1045	1130	1217
Flask Number		ES 1	ES 2	ES 5
V _f	Volume of Flask and Valve, ml	2092	2041	2075 2064
V _a	Volume of Absorbing Reagent, ml	25	25	25
V _n	Volume of Flask minus Reagent, ml	2067	2016	2050
P _{bi}	Initial Barometric Pressure, in. Hg	29.44	29.43	29.41
P _{fi}	Initial Flask Vacuum, in. Hg vac	26.20	26.40	26.35
P _i	Initial Absolute Pressure in Flask, in. Hg	3.24	3.03	3.06
P _{bf}	Final Barometric Pressure, in. Hg	29.56	29.59	29.63
P _{ff}	Final Flask Vacuum in. Hg vac	-0.75	-1.90	-2.20
P _f	Final Absolute Pressure in Flask, in. Hg	28.81	27.69	27.43
T _i	Initial Flask Temperature, °F	70	68	70
T _{ir}	Initial Flask Temperature, °R	530	528	530
T _f	Final Flask Temperature, °F	59	59	59
T _{fr}	Final Flask Temperature, °R	519	519	519
V _{sc}	Volume of Sample at Dry Std. Cond., ml			
M	Mass of NO ₂ in Gas Sample, µg			
C	Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 13 Mar 75

RUN NO. Inlet 1/123

HV-23

Hercules, Inc. Bessemer, ALA. Run No.		4	5	6
Time		13/3	1530	1630
Flask Number		7	10	11
V _f	Volume of Flask and Valve, ml	2089	2050	2052
V _a	Volume of Absorbing Reagent, ml	25	25	25
V _n	Volume of Flask minus Reagent, ml	2064	2025	2027
P _{bi}	Initial Barometric Pressure, in. Hg	29.39	29.32	29.32
P _{fi}	Initial Flask Vacuum, in. Hg vac	26.35	26.25	26.35
P _i	Initial Absolute Pressure in Flask, in. Hg	3.04	3.07	2.97
P _{bf}	Final Barometric Pressure, in. Hg	29.63	29.70	29.70
P _{ff}	Final Flask Vacuum in. Hg vac	-1.10	-1.90	-0.90
P _f	Final Absolute Pressure in Flask, in. Hg	28.53	27.80	23.30
T _i	Initial Flask Temperature, °F	73	73	73
T _{ir}	Initial Flask Temperature, °R	533	533	533
T _f	Final Flask Temperature, °F	59	59	59
T _{fr}	Final Flask Temperature, °R	519	519	519
V _{sc}	Volume of Sample at Dry Std. Cond., ml			
M	Mass of NO ₂ in Gas Sample, µg			
C	Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 13 MAR 75RUN NO. HV23 INletHercules Inc. Bessemer Alfa. Run No HV23-7 HV23 - 8 HV23

V_f	Volume of Flask and Valve, ml	2067	2073
V_a	Volume of Absorbing Reagent, ml	25	25
V_n	Volume of Flask minus Reagent, ml	2042	2048
P_{bi}	Initial Barometric Pressure, in. Hg	29.36	29.26
P_{fi}	Initial Flask Vacuum, in. Hg vac	26.40	26.30 , 26.20
P_i	Initial Absolute Pressure in Flask, in. Hg	2.96	3.06
P_{bf}	Final Barometric Pressure, in. Hg	29.70	29.70
P_{ff}	Final Flask Vacuum in. Hg vac	-1.05	-1.05
P_f	Final Absolute Pressure in Flask, in. Hg	28.65	28.65
T_i	Initial Flask Temperature, °F	70	72
T_{ir}	Initial Flask Temperature, °R	530	532
T_f	Final Flask Temperature, °F	58	58
T_{fr}	Final Flask Temperature, °R	518	518
V_{sc}	Volume of Sample at Dry Std. Cond., ml		
M	Mass of NO_2 in Gas Sample, µg		
C	Concentration of NO_x as NO_2 , dry basis, lb/scf		

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 14 Mar 75

RUN NO. Inlet HV23

Hercules, Inc. Bessemer, AL_a Run No. 9 10 11

Time	0745	845	945
Flask Number	1 (ES)	2 (ES)	5
V _f Volume of Flask and Valve, ml	2092	2041	2064
V _a Volume of Absorbing Reagent, ml	25	25	25
V _n Volume of Flask minus Reagent, ml	2067	2016	2039
P _{bi} Initial Barometric Pressure, in. Hg	29.59	29.62	29.63
P _{fi} Initial Flask Vacuum, in. Hg vac	26.45	26.35	26.50
P _i Initial Absolute Pressure in Flask, in. Hg	3.14	3.27	3.13
P _{bf} Final Barometric Pressure, in. Hg	29.79	29.79	29.79
P _{ff} Final Flask Vacuum in. Hg vac	-0.45	-3.20	-4.00
P _f Final Absolute Pressure in Flask, in. Hg	29.34	26.59	25.79
T _i Initial Flask Temperature, °F	60	60	60
T _{ir} Initial Flask Temperature, °R	520	520	520
T _f Final Flask Temperature, °F	51	51	54
T _{fr} Final Flask Temperature, °R	511	511	514
V _{sc} Volume of Sample at Dry Std. Cond., ml			
M Mass of NO ₂ in Gas Sample, µg			
C Concentration of NO _x as NO ₂ , dry basis, lb/scf			

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

NITROGEN DIOXIDE SAMPLING DATA AND CALCULATIONS

DATE 14 MAR 74
 RUN NO. 14V-23 ~~Dinkel~~

Hercules, Inc. Bessemer, AL

Run No. 12

Time	1045	
Flask Number	7 ^(E)	
V_f Volume of Flask and Valve, ml	2099	
V_a Volume of Absorbing Reagent, ml	25	
V_n Volume of Flask minus Reagent, ml	2074	
P_{bi} Initial Barometric Pressure, in. Hg	29.66	
P_{fi} Initial Flask Vacuum, in. Hg vac	26.60	
P_i Initial Absolute Pressure in Flask, in. Hg	3.06	
P_{bf} Final Barometric Pressure, in. Hg	29.79	
P_{ff} Final Flask Vacuum in. Hg vac	-0.40	
P_f Final Absolute Pressure in Flask, in. Hg	29.39	
T_i Initial Flask Temperature, °F	59	
T_{ir} Initial Flask Temperature, °R	519	
T_f Final Flask Temperature, °F	55	
T_{fr} Final Flask Temperature, °R	515	
V_{sc} Volume of Sample at Dry Std. Cond., ml		
M Mass of NO_2 in Gas Sample, µg		
C Concentration of NO_x as NO_2 , dry basis, lb/scf		

$$V_n = V_f - V_a$$

$$V_{sc} = (17.71) (V_n) \left[\frac{P_f}{T_{fr}} - \frac{P_i}{T_{ir}} \right]$$

$$P_i = P_{bi} - P_{fi}$$

$$P_f = P_{bf} - P_{ff}$$

$$C = (6.2 \times 10^{-5}) \left[\frac{M}{V_{sc}} \right]$$

APPENDIX F

**LABORATORY REPORT FOR EPA METHOD NO. 7 TESTS AND
ANALYTICAL REPORT FOR NO₂ CALIBRATION GASES**



COMMONWEALTH LABORATORY

INCORPORATED

CHEMISTS BUILDING, 2209 EAST BROAD STREET

RICHMOND, VIRGINIA 23223

P. O. BOX 8025
AREA CODE 804
TELEPHONE: 648-8358

AIR AND WATER
SAMPLING, ANALYSIS

April 3, 1975

No. 75-102-04

CERTIFICATE OF ANALYSIS

One hundred and twenty-nine (129) samples taken at Hercules, Inc.; Bessemer, Alabama; received March 18, 1975.

Attn: Mr. J. T. Chehaske

Job No. 1850, Task Order No. 2

Method: Federal Register, Vol. 36, No. 159, August 17, 1971, Method 7.

SAMPLE IDENTIFICATION

TOTAL µg NO₂

Cal Gas Blank	0
Cal Gas No. 1	6,250
Cal Gas No. 2	13,350
Cal Gas No. 3	12,750
Cal Gas No. 4	142
Cal Gas No. 5	138
Cal Gas No. 6	142

HV-12 Inlet

Blank, March 05	0
1	7,550
2	6,550
3	8,900
4	7,650
5	10,500
6	10,500
7	10,650
8	7,200
9	6,850
10	7,250
11	9,900
12	11,850
13	8,350
14	10,150
15	9,100
16	6,900
17	6,850
18	5,900
19	11,200
20	14,000
21	8,600

HV-12 Inlet (continued)

<u>SAMPLE I.D.</u>	<u>TOTAL $\mu\text{g NO}_2$</u>
22	8,200
23	9,000
24	6,850
25	9,800
26	3,650
27	2,300
28	3,650
29	4,600
30	2,800
31	3,450
32	5,150
33	4,750
34	4,750
35	9,000
36	8,550
37	9,500
38	8,150
39	9,550
40	9,600
41	8,150
42	3,750
43	5,500
44	9,750
45	11,000
46	7,200
47	5,550
48	9,350
49	10,450
50	11,000
51	9,500
52	13,150
53	9,550
Blank March 11	0
Blank March 15	0
Blank March 13	0

Outlet HV-13

TOTAL $\mu\text{g NO}_2$

1	355
2	380
3	450
4	237
5	265
6	244
7	295
8	470
9	506
10	336
11	167
12	280
13	354
14	540
15	235
16	330

Blank March 06

	0
17	118
18	103
19	466
20	522
21	200
22	265
23	208
24	420
25	290
26	135
27	30
28	38
29	340
30	122
31	68
32	78
33	90
34	180
35	165
36	210
38	158
39	159
40	295
41	351
42	140
43	114

Outlet HV-13 (continued)

	<u>TOTAL µg NO₂</u>
Blank March 12	0
44	206
45	354
46	197
47	316
48	158
49	308
50	225
51	281
52	634
53	820

HV-23 Demister Inlet

1	7,150
2	5,150
3	10,250
4	13,150
5	8,250
6	10,150
7	12,000
8	11,650
9	11,000
10	11,500
11	7,750
12	10,250

Respectfully submitted,

John A. Bingham

John A. Bingham
Chemist



P.O. DRAWER NO. 272, UNION LANDING & RIVER ROADS, RIVERTON, NEW JERSEY 08077
TELEPHONE: 609-829-7878

Rare & Specialty Gases Department

April 16, 1975
RSG-75-86

Engineering Sciences, Inc.
7903 West Park Drive
McClear, Virginia 22101

Attention: Mr. John Greenberg

Dear Mr. Greenberg:

The following results on the initial analysis made on the two cylinders we sent you are from our laboratory analytical sheet and are the correct results. There were numerical errors on the tags you received. We are sorry if this caused you any problems in your work.

	<u>Cyl. No.</u>	<u>Test No.</u>	<u>NO₂</u>	<u>NO</u>	<u>N₂</u>	<u>Date</u>
Initial Analysis	MM-2457	U-0219	31.0 PPM	1.5 PPM	Bal.	1/28/
Reanalysis	"	"	32.0 PPM	0.5 PPM	"	4/14/
Initial Analysis	MM-2510	U-0218	3980 PPM	20.0 PPM	"	1/28/
Reanalysis	"	"	3910 PPM	30.0 PPM	"	4/14/

Very truly yours,
AIRCO INDUSTRIAL GASES

Frank Kramer

FK/jh

Frank Kramer
Chief Laboratory Analyst
Rare & Specialty Gases Dept.

RECORDED

APPENDIX G

PROCESS DATA

PURASIV-N PROCESS DATA

DATE 3/5/75

PLANT Hercules Inc., Bessemer, Ala.

FUEL OIL TANK LEVEL 71 in. AT 1300 HRS.

ENGINEERING-SCIENCE, INC.

PROJECT EPA-LOE JOB NO. 1850

DETAIL HERCULES HND, TESTING

DATE 3/5/75

BY 976

SHT. 1
QE 16

NITRIC ACID PROCESS DATA

DATE 3/5/75

PLANT Hercules, Inc., Bessemer, Ala.

ENGINEERING-SCIENCE, INC.

PROJECT EPA-10E JOB NO. 1850

DETAIL - HERCULES HNG TESTING

DATE 3/5/75

BY 9-76

SHT. 2
pg. 16

PURASIV-N PROCESS DATA

DATE 3/6/75

PLANT Hercules Inc., Bessemer, Ala.

FUEL OIL TANK LEVEL

ENGINEERING-SCIENCE, INC.

PROJECT - E170-1CE Job No. 1850

DETAIL HERCULES HND. TESTING

DATE 3/6/75

BY J. T. G.

SIT. 3

OF 16

NITRIC ACID PROCESS DATA

DATE 3/6/75

PLANT Hercules, Inc., Bessemer, Alz.

ENGINEERING-SCIENCE, INC.

PROJECT EPA-105 JOB NO. 1850

HERBICIDES AND TESTING

DATE 3/6/75

SHT. 4

By 9:26

DE 15

PURASIV-N PROCESS DATA

DATE 3/7/75

PLANT Hercules Inc., Bessemer, Ala.
FUEL OIL TANK LEVEL 68" @ 1700

TIME	FED GAS		INLET GAS		OUTLET GAS		REGENERATION GAS				BED m. inc. /Bypass valve press	ΔP WATER METER READING	TEMP TEST	
	PRESS. (PI-13)	TEMP. (T-3)	FLOW (FR-10)	TEMP. (TR-17)	PRESS. (PI-10)	TEMP. (TI-10)	FLOW (FR-10)	TEMPERATURE, IN (TR-122) (F10)	TAP OF BED (444)	OUT (TR-123) (#11)	PRESS IN (PE-151) psig			
MN			825				1050							
0100			830				1040							
0200			830				1030							
0300			780				1030							
0400			790				1010							
0500			0				0							
0600			0				0							
0700			0				0							
0800			600				1015						15	
0900	83	75	5700	42	78	56	1015	250	55	62	124	50/18	-	30
1000	-	-	4500	42	-	-	1010	440	110	70	-	29/18	-	-
1100	80	80	5700	42	76	75	1010	55	220	145	121	51/18	-	34
1200	82	82	5750	45	77	75	1010	55	368	255	122	52/18	-	35
1300	82	82	5550	45	77	73	1010	200	57	77	122	55/18	-	35
1400	83	83	5700	45	78	71	1020	445	105	85	123	57/18	-	35
1521	88	86	5500	48	80	73	1300	60	370	155	126	68/18	-	38
1630	88	81	5600	45	81	61	1150	50	60	135	125	57/18	-	34
1710	86	85	5850	50	80	65	1020	360	65	75	127	54/18	-	35

ENGINEERING-SCIENCE, INC.

PROJECT EPA-LOE Job No 1850

DATE 3/7/75 SHT 5

DETAIL HERCULES HNO₃ TESTING

By 9:36 | DE 16

NITRIC ACID PROCESS DATA

DATE 3/7/75

PLANT Hercules, Inc., Bessemer, Ala.

ENGINEERING-SCIENCE, INC.

PROJECT E.P.C.-625 JOB NO. LS50

PROJECT _____

DATE 3/7/7

Skt. 6

DETAIL HERCULES UNCL. FESTING

By

OF 10

PURASIV-N PROCESS DATA

DATE 3/10/75

PLANT Hercules Inc., Bessemer, Ala.

FUEL OIL TANK LEVEL 66 1/2" @ 13:30

TIME	FEED GAS		INLET GAS		OUTLET GAS		REGENERATION GAS			BED IN. W.C.	ΔP in. w.c.	METER READING	TEMP. °F	
	PRESS. (PI-13)	TEMP. (T-3)	FLOW (FR-101)	TEMP. (TR-117)	PRESS. (PI-10)	TEMP. (TR-105)	FLOW (FR-102)	TEMPERATURE, °F IN (TR-122) (#10)	TOP OF BED (#484)	OUT (TR-123) (#11)	PRESS (PI-101)			

PURASIV-N
STOPPED

ENGINEERING-SCIENCE, INC.

PROJECT EPA-LOE Job No. 18510

DETAIL HERCULES NO₂ TESTING

DATE

BY

SHT. 7

OF 16

NITRIC ACID PROCESS DATA

DATE 3/10/75

PLANT Hercules, Inc., Bessemer, Ala.

TIME	AIR FLOW ($\times 4500 =$ CFH)	AIR RECEIVER PRESS. PSIG.	SYSTEM PRESS PSIG.	BACK PRESS PSIG	X. D. R. RPM	Injection Water GPM	Acid Strength Tinny %	X.R.D Feed Gas N ₂ O ₂	Product Strength %
1600	20	127	94	80	30	3.5	-	-	-
16:40	36	116	110	80	67	1.2	-	3.2	-
PLANT CONTINUED TO RUN UNTIL 07:00 ON 3/11/75 PURASIV WAS NOT USED									

ENGINEERING-SCIENCE, INC.

PROJECT EPA-105 JOB NO. 1850

DETAIL HERCULES INC. TESTING

DATE 3/10/75

SHT. 8

BY R.R.

OF 16

PURASIV-N PROCESS DATA

DATE 3/11/75

PLANT Hercules Inc., Bessemer, Ala.

FUEL OIL TANK LEVEL 67" @ 17:30

TIME	FEED GAS		INLET GAS		OUTLET GAS		REGENERATION GAS				BED	WATER	FINAL TEMP. OF		
	PRESS. (PI-13)	TEMP. (T-3)	FLOW (FR-10)	TEMP. (TR-11)	PRESS. (PI-10)	TEMP. (T-10)	FLOW (FR-10)	TEMPERATURES, °F	IN (TR-12) (#10)	TOP OF BED (#484)	OUT (TR-123) (#11)	PRESS IN (PI-10)	ΔP in. W.C.	METER READING	
B	1400	86	74	3200	40	75	66	1030	395	42	50	130	68/12	664 14.93	30
	1445	97	74	4400	40	83	56	1040	412	40	58	130	52/18	5141 19.52	30
	1530	90	77	5200	40	80	56	1030	418	41	98	126	70/18	8130 15.31	29
	1615	90	79	5200	40	80	58	1030	417	45	185	125	70/10	11565 16.15	30
	1700	90	79	5200	40	80	62	1030	415	48	242	125	70/15	15480 11.92	30
	1800	90	81	5400	40	80	57	1030	110	56	90	127	70/18	19.850 17.45	30
	1900														
	2000	89	74	5400	50			1030	60				70		30
	2100														
	2200	89	77	5300	50			1020	280				70		30
	2300														
	2400	88	81	5100	45			1020	50				72		32

ENGINEERING-SCIENCE, INC.

PROJECT EPA-100 JOB NO. 1850

DATE 3/11/75

SHT. 9

DETAIL HERCULES HNO3 TESTING

BY

OF 16

NITRIC ACID PROCESS DATA

DATE 3/11/75

PLANT Hercules, Inc., Bessemer, Ala.

TIME	AIR FLOW (X 4500 = CFH)	AIR RECEIVER PRESS. PSIG.	SYSTEM PRESS PSIG.	BACK PRESS PSIG	X.D.R. RPM	Injection water GPM	Acid Strength, TAN ^N /%	X.R.D. Perf Gas % O ₂	Product strength %
A									
1300	Light	OFF	[Start - UP]						
1400	34	118	96	76	78	0.8		2.55	1103/ 664
1445	36	118	112	94	82	1.3		3.42	
1530	62	120	114	85	134	1.85		4.0	
1615	60	116	112	84	134	1.8	29/4.2 26/7.1 16/ 21.6 4/ 56.85	3.5	58.5
1700	60	116	112	84	134	2.1		3.7	
B									
1800	60	116	112	84	134	2.1		3.6	
1900	60	118	114	84	134	2.2			
2000	60	116	112	84	134	2.0	29/7.1 26/9.7 16/ 33.7 4/ 57.78		58.18
2100	60	116	112	84	134	2.0			
2200	60	116	112	84	134	2.0			
2300		116	112	84	134	2.0			
2400		116	112	84	136	2.0	29/9.7 26/14.7 16/ 40.4 4/ 57.51		58.98

ENGINEERING-SCIENCE, INC.

PROJECT EPA-10E JOB NO. 1.850

DATE 3/11/75

SHT. 10

DETAIL HERCULES HNO₃ TESTING

BY

OF 16

PURASIV-N PROCESS DATA

H₂O
meter

DATE 3/12/75

PLANT Hercules Inc., Bessemer, Ala.

FUEL OIL TANK LEVEL _____

Time	Reading
09:00	98,030
14:11	124,610
17:00	138,830

TIME	FEED GAS		INLET GAS		OUTLET GAS		REGENERATION GAS				BED PRESS. (PI-13) psig	ΔP m.m.w.c.	WATER METER READING	ISSIN TEMP. °F	
	PRESS. (T-3) OF	TEMP. (TR-101) OF	FLOW (FR-101) scfm	TEMP. (TR-107) OF	PRESS. (PI-106) psig	TEMP. (TI-105) OF	FLOW (FR-108) scfm	TEMPERATURE, IN (TR-122) (#10)	TOP OF BED (4414) OF	OUT (TR-123) (#11)					
B	1:00			5200	10.4			1020					70/		
	2:00	88	82	5200	40			1020	300				70/		32
	3:00			5200				1020					70/		
	4:00	88	82	5200	45			1020	60				70/		34
	5:00			5200				1020					70/		
A	6:00	88	82	5200	45			1020	50				70/		34
	7:00			4200				1020					52/		
	8:00	98	79	4200	42	84	67	1020	48	50	197	130	52/18		32
	9:00	98	79	4200	41	84	68	1020	48	50	240	130	52/18		32
	10:00	99	80	4350	42	84	62	1030	160	50	90	132	50/18		32
B	11:00	98	81	4350	41	84	68	1030	428	35	62	132	50/18		32
	12:00	98	82	4300	42	84	68	1030	65	35	108	132	50/18		34
	13:00	98	85	4300	43	84	67	1030	50	35	250	132	50/18		34
	14:00	90	86	5250	47	80	64	1020	50	39	98	124	69/18		36
	15:00	90	81	5100	42	80	72	1020	438	48	62	126	70/18		32
A	16:00	90	83	5000	44	80	72	1020	68	48	108	126	70/18		32
	17:00	90	85	5000	45	81	72	1030	50	52	250	126	70/18		34
	18:00	88	84	5050	45	80	73	1020	49	50	122	124	70/18		34
	19:00														
	20:00	98	82	4300	45			1020	55				44		31
B	21:00														
	22:00	98	82	4200	45			1020	50				44		32
	23:00														
	24:00	98	85	4300	50			1020	70				44		34

ENGINEERING-SCIENCE, INC.

PROJECT EPA-60E JOB NO. 1850

DATE 3/12/75 SHT. 11

DETAIL HERCULES HNO₃ TESTING

BY R&R OF 16

NITRIC ACID PROCESS DATA

DATE 3/12/75

PLANT Hercules, Inc., Bessemer, Ala.

TIME	AIR FLOW (x 4500 = CFH)	AIR RECEIVER PRESS. PSIG.	SYSTEM PRESS PSIG.	BACK PRESS PSIG	X. D. R. RPM	INJECTION WATER GPM	Acid Strength Tray %/%	X-P.D Feed Wt% N2O	Product Strength %
1:00	60	114	110	83	136	2.0			
2:00	60	116	112	84	136	2.0			
3:00	60	116	112	84	136	2.0	29/13.1 14 24/17.8 4/	55.2 55.03	59.02
4:00	60	114	110	84	136	2.0	29/16.2 24/20.9 16/54.7 4/59.24		
5:00	60	114	110	83	136	2.0	29/17.0 24/27.1 16/55.6 4/54.24		59.28
6:00	60	114	110	83	136	2.0	29/17.0 24/27.1 16/55.6 4/54.24		
7:00	40	114	110	83	88	2.0			59.48
8:00	36	116	114	94	88	1.9			3.15
9:00	36	116	114	94	88	1.8			3.1
10:00	36	117	114	98	88	1.8	24/97 24/159 16/53.2 4/60.01	2.8	60.25
11:00	36	116	116	96	88	1.8			2.2
12:00	36	116	114*	94	89	1.8	29/10.6 24/15.4 16/51.9 4/51.31		2.1
13:00	36	116	114	94	88	1.8	29/10.6 24/15.4 16/51.9 4/51.31		59.97
14:00	62	116	112	84	140	2.2			2.8
15:00	58	116	112	84	140	2.2	29/13.1 24/13.6 16/51.9 4/51.31		2.9
16:00	58	116	112	84	140	2.3	29/13.1 24/13.6 16/51.9 4/51.31		2.8
17:00	58	116	112	84	138	2.3	29/13.1 24/13.6 16/51.9 4/51.31		3.5
18:00	57	114	110	83	128	2.3			3.2
19:00	58	116	112	83	132	2.0	29/11.1 24/15.4 16/49.9 4/51.30		
20:00	58	116	112	83	132	2.0	29/11.1 24/15.4 16/49.9 4/51.30		59.70
21:00	58	116	111	82	132	2.0			
22:00	58	115	111	82	132	2.0			
23:00	56	115	111	82	132	2.0			
24:00	57	114	110	83	128	2.0	29/12.2 24/17.0 16/44.8 4/50.01		58.78

ENGINEERING-SCIENCE, INC.

PROJECT EPA-100

JOB NO. LES50

DATE 3/12/75

SHT. 12

DETAIL HERCULES NHC TESTING

BY R&R

OF 15

PURASIV-N PROCESS DATA

DATE 3/13/75

PLANT Hercules Inc., Bessemer, Ala.

FUEL OIL TANK LEVEL

TIME	FEED GAS		INLET GAS		OUTLET GAS		REGENERATION GAS				BED	WATER	BRINE		
	PRESS. (PI-13)	TEMP. (T-3)	FLOW (FR-101)	T, MP (TR-117)	PRESS. (PI-102)	TEMP. (T-105)	FLOW (FR-102)	TEMPERATURE, °F (TR-122) (=10)	IN (TR-123) (=11)	TOP OF BED (4484)	OUT (TR-123) (=11)	PRESS. IN (PI-101)	Δ P in. w.c.	METER READING	TEMP. °F
1:00															
2:00	88	86	4900	50			1020	50				70	-	35	
3:00															
4:00	88	84	5100	45			1020	440				68	-	35	
5:00			5100				1020								
6:00	88	82	5100	48			1020	70				68	-	34	
7:00															
8:00	96	75	4200	50	83	68	1030	50	45	112	130	52/18	-	30	
9:00	100	76	4200	39	86	64	1030	44	48	218	132	52/18	-	30	
B 10:00	100	76	4200	40	84	63	1030	42	42	102	132	52/18	-	30	
11:00	100	78	3000	40	85	66	1030	99	38	129	132	38/1	-	29	
12:00	86	80	5800	42	80	58	1040	415	38	58	125	77/18	-	30	
13:00	84	81	5800	48	78	72	1030	60	44	102	124	76/14	-	38	
* 14:00	No	Data	Taken	: System	Fluctuating			*	*	*	*	*			
A 15:00	86	80	6200	47	78	68	1030	130	60	80	126	60/15	-	33	
16:00	86	78	6050	42	73	68	1030	408	47	66	126	60/18	-	32	
17:00	95	80	6150	44	75	65	1030	60	49	102	125	62/14	-	33	
18:00	82	78	6050	46	78	62	1030	48	52	194	124	60/18	-	34	
B 19:00	82	81	6050	48	74	63	1030	50	50	102	122	60/18	-	35	
20:00	84	86	6300	50			1020	440				58	-	31	
21:00															
22:00	83	86	6300	50			1020	50				56	-	38	
23:00															
24:00	84	76	6200	50			1020	430				60	-	32	

ENGINEERING-SCIENCE, INC.

PROJ: EPA-10E Job No. 18510

DATE 3/13/75

SHT. 13

DATA: HERCULES INC. TESTING

BY RJR

OF 16

H₂O METERNITRIC ACID PROCESS DATADATE 3/13/75PLANT Hercules, Inc., Bessamer, Ala.

Time	Reading
09:00	222,850
13:00	241,800
18:00	267,590

TIME	AIR FLOW (x 4500 = CFH)	AIR RECEIVER PRESS. PSIG	SYSTEM PRESS PSIG	BACK PRESS PSIG	X.D.R. RPM	Injection Water gpm	Acid Strength Troy %	XRD Feed CNS % C ₂	Product Strength %
1:00	57	114	110	83	132	2.0			
2:00	58	114	110	83	132	2.0			
3:00	57	115	111	83	130	2.0	29/14.5 24/16.6 14/56.4 4/57.61		59.97
4:00	55	115	111	83	130	2.0			
5:00	56	115	111	83	130	2.0	29/154 24/17.3 14/56.4 4/60.03		60.53
6:00	56	114	110	83	130	2.0			
7:00	36	114	110	83	82	2.0	29/13.0 24/21.6 14/23.9 4/59.68		60.20
8:00	35	115	112	93	82	1.8			1.9
9:00	33	120	118	100	82	1.7	29/11.4 24/17.0 14/51.4 4/60.73	3.2	-
10:00	35	116	112	96	82	1.8		3.5	60.22
11:00	36	118	115	98	82	1.7		3.1	-
12:00	76	116	112	80	158	2.6		3.1	
13:00	73	116	112	80	158	2.5	29/11.4 24/17.0 14/7 4/7	2.8	59.42
* 14:00	Production Rate	Charging	*	*	*	*			
15:00	78	118	114	80	161	2.7		4.2	
16:00	80	121	118	80	164	2.6	29/14.5 24/20.1 14/53.26 4/58.71	2.8	58.11
17:00	80	120	116	78	164	2.7		3.1	
18:00	80	118	114	77	164	2.7		3.0	
19:00	82	118	113	77	164	2.6	29/19.3 24/25.6 14/56.86 4/60.10	3.0	
20:00	82	118	114	76	164	3.0			59.14
21:00	82	118	114	76	164	3.0			
22:00	82	118	114	76	164	3.0			
23:00	82	118	114	76	168	3.0	29/20.9 24/26.2 14/56.4 4/58.71	220	
24:00	82	120	116	80	168	2.8		220	59.95

ENGINEERING-SCIENCE, INC.

PROJECT EPA-122 JOB NO. 1850DETAIL HERCULES HNO₃ TESTINGDATE 3/13SHT. 14BY REROF 16

NITRIC ACID PROCESS DATA

DATE 3/14/75

PLANT Hercules, Inc., Bessemer, Ala.

TIME	AIR FLOW (x 4500 = CFH)	AIR RECEIVER PRESS. PSIG.	SYSTEM PRESS PSIG.	BACK PRESS PSIG	X. D. R. RPM	Injection water 9 PM	Acid Strength Tray %	1RD Feed Gross O ₂	Product Strength
11:00	83	120	114	80	168	2.8	-	O 11	
2:00	83	120	116	80	168	2.8	-	O 2	
3:00	84	121	116	80	168	2.8	29/14.5 2/4.3 14/539 4/58.71	O 4	
4:00	84	121	116	80	168	2.8	-	O 4	
5:00	85	121	117	80	168	2.8	29/154 2/4/20.1 14/539 4/59.88	O 3	59.83
6:00	85	121	117	80	168	2.8	-	O 3	
7:00	85	121	117	80	168	2.8	-	O 3	
8:00	80	118	114	77	168	2.6	-	R	
9:00	80	118	114	78	168	2.6	-		
10:00	80	116	112	76	168	2.6	-		
11:00	80	116	112	76	168	2.6	-		

ENGINEERING-SCIENCE, INC.

PROJECT EPA-LOG

JOB NO. L250

DATE 3/14/75

SHT. 15

DETAIL HERCULES NHO₃ TESTING

BY RRR

OF 16

PURASIV-N PROCESS DATA

Water Meter

DATE 3/14/75

PLANT Hercules Inc., Bessemer, Ala.

FUEL OIL TANK LEVEL 63 1/2" @ 10:00 AM
3/14/75

Time	Reading (in)
07:13	331, 6'55
11:00	347, 375

TIME	FEED GAS		INLET GAS		OUTLET GAS		REGENERATION GAS				BED ΔP in. W.C.	WATER METER READIN. in.	FRACTION %	
	PRESS. (PI-13)	TEMP. (T-3)	FLOW (FR-101)	TEMP. (TR-117)	PRESS. (PE-102)	TEMP. (TT-102)	FLOW (FR-102)	TEMPERATURES, °F IN (TR-122) TOP OF BED (=10) (=44°)	OUT (TR-123) (=11)	PRESS. (PL-101)	IN psig			
1:00	-													
2:00	84	74	6100	45			1020	50				60		32
3:00	-													
4:00	84	72	6300	40			1020	400				60		30
5:00	.													
6:00	84	70	6200	45			1030	50				60		30
7:00	80	68	5900	44	75	5.5	1030	45	42	74	120	58/18		31
8:00	83	67	5500	44	78	69	1030	408	48	55	12.3	60/18		32
9:00	84	66	5500	45	80	71	1030	411	49	102	124	60/18		32
10:00	82	67	5450	44	80	69	1030	48	51	160	122	60/18		31
11:00	82	68	5500	44	78	67	1030	47	49	114	122	60/18		32

ENGINEERING-SCIENCE, INC.

PROJECT EPA-LOE JOB NO. 18510

DATE 3/14/75 SHT. 16

DETAIL HERCULES INC. TESTING

BY RKR OF 16

0. Compressor #3 off line - ^{outage} being used by other parts of plant
 1. Unit was shut down during the night - pilot flame failure
 2. Unit restarted about 7:20 - run at partial load until 0930
 3. Switched to adsorber A @ 0930. Brought flow rate thru system up to ~ 6000 scfm.
 4. 1135 Acid plant shut down - Purasiv shut off. Lost a boiler at the power plant - low steam press. to ammonia vaporizer forced shut down.
 1210 - restarted Purasiv - initial flow 5350, changed to 4800@
 1230.
 1305 - raised Purasiv flow rate to 5700.
 1412 - Unit B switched on adsorption mode, feed flow increased to 5950.
 1517 - Started Voltage & Amperage Recorder
 1520 - Feed rate ~~set point~~ lowered to 5700 scfm (design rate)
 1800 - Unit auto. - switched to adsorber A, flow started at 5700
 Bed ΔP ^{set point} changed to 61.

3/6/75 DAILY LOG . Compressor #3 being used by powder line
 0800 arrived at plant - plant & Purasiv had operated continuously during the night. Outlet chart recorder had stoppedinking at
 0830 Purasiv ΔP set point changed from 61 in. W.C. to 56 in. W.C.
 Purasiv flow dropped from 5900 scfm to 5750 scfm
~~Recycle~~ Regen. flow rate changed from 1010 to 1040 scfm
 1010 Purasiv auto-switched from A to B on adsorption mode. Bed ΔP jumped from 58 to 60.5.
 1035 Sulet flow up to 5750, bed ΔP set point changed from 58.0 to 60.5 in. W.C.
 1409 Purasiv auto switched to B on adsorption, A on regen.
 Sulet flow jumped to 5900 scfm and bed ΔP dropped to 56 with no change in the ΔP set point
 1709 Failure of push rod linkage on X.R.D. caused plant to shut down for about 5 minutes. Flow to Purasiv was dropped but did not shut down unit. Plant back in about 20 minutes. Ran up & down for next 20 min
 1812 Purasiv auto switched to A adsorption, B regen. New bed ΔP about 46 in. W.C. outlet flow rate 5250
 Plant still lining out
 1820 Compressor #6 failed. Plant kept running at reduced rate
 outlet flow 575, Regen flow 1050, ΔP 12.5,

3/6/75 CONT.

1800 to M.N. Continued operating at a reduced rate. Plant running about 60 on air flow chart.

3/7/75

- M.N. to 0430 sieve operated at about 800 scfm inlet and 1020 regen until 0430 when high liquid level in the sieve demister shut the Purasiv down. Attempts by operator to restart were unsuccessful. Plant also down.
- 0730 Purasiv restarted by Bob Albright. Plant running about 50 on air flow chart
- 0830 Plant up to 85 air flow - but then lost something and could only get 75. Plant not sure what is causing lower flow.
- 0850 auto sieve change to B on adsorb., A on regen.
- 1000 Compressor #6 kicked off - air flow to plant off for a min or so - plant brought back up immediately. Purasiv flow maintained although at reduced rate of 4500 for about 25 min - then back up to 5700.
- 1255 Purasiv auto switch to A on adsorb., B on regen. Flow before switch was 5800 scfm, regen 1010 scfm. After switch inlet
- 1308 increased air flow to blower to get more O₂ into tower. Total air flow went from 73 to 77 on chart. Purasiv inlet went from 5550 to 5650, regen from 1010 to 1020. O₂ in tail gas went from 1.7% to 3.3%
- 1655 Purasiv auto switch to B on adsorb., A on regen

ENGINEERING-SCIENCE, INC.

PROJECT EPA - LOE JOB NO. 1850
DETAIL HERCULES HNO₃ TESTS

DATE 3/7/75 SHT. 2
BY JTG OF 8

3/10/75 - Daily Log - R.L. Roberson

Arrived at plant approx 8:00 AM. Review data to be taken and locations of various meters.
Port for water meter is expected around 13:00.

09:45 Waiting for plant to come on-line.
Delay - for NH₃ pressure to build
in feed tanks

11:00 Pressure Rising very slowly in NH₃ - Tank #3

14:00 Pressure at 145 psig in Tank #3
Plant has decided to try to raise sufficient
feed pressure in Tank #4. Will light off
on #4 & switch to #5

Note: The NH₃ pressure in feed (Supply)
tanks must be 165 psig because
1) NH₃ must be a gas when it goes into BURNER
2) NH₃ pressure must be greater than
the combustion AIR pressure, else
there would be "blow-back" into
receivers

15:10 NH₃ Combustor is lighted

16:00 Acid being made, as system smooths
out the Pura Siv will be purged.

16:20 Purging began, Will require at least
ONE (1) hour.

16:45 Pura Siv not started because of thermocouple
failure in the heater unit of the Siv. Thus,
flame could not be stabilized.

ENGINEERING-SCIENCE, INC.

PROJECT EPA - LOE JOB NO. 1850
DETAIL Hercules HNO₃ Tests

DATE 3/10/75 SHT. 3
BY RdR OF 8

3-11-75

Daily Log

07:10 Unit shut down to repair leak in discharge line from oxidizing unit

08:15 Begin to remove line with leak (bad weld)

08:30 Estimated start-up time \Rightarrow 10:30

13:00 Leak repaired, other minor repairs completed
Combustor Ignited.

14:00 PURASIR Cycle Begun
Adsorber - A

One Air compressor with a 1300 cfm capacity is down. This reduces production rate - the ~~ent~~ compressor may be down for the rest of the week. At this lower production rate, the Adsorption tower is much more efficient and thus lower inlet concentrations are to be expected!

15:20 AN Auxiliary compressor with 600 cfm capacity was brought online. This will increase production rate

16:30 Process appears to have leveled out.
Data to be taken hourly

17:10 No acid samples have been taken. It takes \approx ~~1/2~~, 4 hrs. after start-up for acid to get up to strength.

17:54 CYCLE OVER \Rightarrow ADSORPTION B

ENGINEERING-SCIENCE, INC.

PROJECT EPA-LOR JOB NO. 1850
DETAIL Hercules HNO₃ Tests

DATE 3/11/75 SHT. 4
BY ASR OF 8

3-12-75

Daily Log

07:00 The auxiliary compressor was taken off line. Actually, this compressor is still running but its air (output) belongs to another part of the plant. Thus, the AOP ~~is~~ will be at less than rated capacity for all of the 2nd shift (7am-3pm).

10:02 Vessel B ADSORBING

11:00 Bob Albright reports that the #6 compressor may be online by Noon 3/13 (Thur.) This would put the plant close to capacity.

13:45 Auxiliary Compressor put on line. This is the #3 compressor which adds about 600 cfm.

14:03 Cycle Change - VESSEL A ADSORBING

18:06 Cycle Change - VESSEL B ADSORBING

ENGINEERING-SCIENCE, INC.

PROJECT EPA-LOE JOB NO. 1850
DETAIL Hercules HNO₃ Tests

DATE 3/12/75 SHT. 5
BY R.R OF 8

3-13-75

Daily Log

- 6:45 No. 3 Compressor shunted back to power house.
Thus, Production Rate dropped.
- 10:16 CYCLE CHANGE VESSEL B ADSORPTION
- 10:28 Flame FAILURE in Heater (Regen cycle for
Vessel A)
- 10:40 By-Pass open, flow thru Sieve dropped
to 3000 cfm. Differential pressure down to 38/1
By-Pass should be wide open
- 11:15 Flame still out, continuing to Bypass Sieve
- 11:30 Compressor No. 6 has been repaired AND
is running. The production rate will increase
Air flow is reading 74 ($\times 4500$) cfm
X.R.D Speed = 174 rpm
Flow thru Sieve is up to 5300 cfm
By pass closing \Rightarrow Flame lighted
- 11:32 Sieve flow increased to 5800 cfm
but falling off!
- 11:33 Discover loose line on X.R.D (Power Recovery)
Its speed has dropped to 136 rpm
Problem \circ Broken valve connection on
X.R.D. ~~line~~
- 11:36 ALARM X.R.D Down, Air Flow and
Production dropping
XRD intake valve must be repaired
Flow thru Sieve = 3000 cfm
- 11:41 XRD repaired AND back on-line. Should get
up to rate if nothing else happens

ENGINEERING-SCIENCE, INC.

PROJECT EPA - LOE JOB NO. 1856
DETAIL Hercules, HNO₃ Testing

DATE 3/13/75 SHT. 6
BY RdR OF 8

3-13-75 Continued

11:45 AOP is beginning to approach rate
Flow thru Sieve 6200 cfm.
The flame was ignited ~ 11:30.
PurASieve reset to automatic and cycle
will continue.

12:55 Plant operating smoothly. This is the
first time the plant has approached
rate this week (10 March 75)

13:55 No. 3 Compressor put on line. This should
give max. rate

13:59 High diff pressure alarm in ABSORPTION TOWER.

14:00 By-Pass open (Auto Valve is not opening thus
creating high AP in tower)

14:10 B. Albright is not sure why, but the regen
flow began to fluctuate between 600 - 1350 scfm.
PurASieve AP ~ 22 in W.C. ; ByPass is fully open

14:55 - PurASieve began to settle down, Production rate
was slightly reduced

15:03 CYCLE CHANGE : VESSEL A ADSORBING

16:24 ALARM : High AP in Adsorption tower. This is the
same problem that occurred at 14:00. Corrected w/
no problem for PurASieve

19:05 CYCLE CHANGE : VESSEL B ADSORBING

TECHNICAL REPORT DATA
(Please read instructions on the reverse before completing)

1. REPORT NO. EPA-600/2-76-048b	2.	3. RECIPIENT'S ACCESSION NO.
4. TITLE AND SUBTITLE Molecular Sieve Tests for Control of NOx Emissions from a Nitric Acid Plant; Volume II--Appendices		5. REPORT DATE March 1976
7. AUTHOR(S) John T. Chehaske and Jonathan S. Greenberg		6. PERFORMING ORGANIZATION CODE
9. PERFORMING ORGANIZATION NAME AND ADDRESS Engineering-Science, Inc. 7903 Westpark Drive McLean, Virginia 22101		8. PERFORMING ORGANIZATION REPORT NO.
		10. PROGRAM ELEMENT NO. LAB015; ROAP 21AFA-106
		11. CONTRACT/GRANT NO. 68-02-1406, Task 2
12. SPONSORING AGENCY NAME AND ADDRESS EPA, Office of Research and Development Industrial Environmental Research Laboratory Research Triangle Park, NC 27711		13. TYPE OF REPORT AND PERIOD COVERED Task Final; 11/74-12/75
		14. SPONSORING AGENCY CODE EPA-ORD
15. SUPPLEMENTARY NOTES Project officer for this report is E.J. Wooldridge, Ext 2547.		
16. ABSTRACT <p>The report gives results of performance testing for NOx emission control on Union Carbide's PuraSiv N unit, now controlling emissions from the tail gas stream of the ammonia oxidation nitric acid production facility of Hercules, Inc. in Bessemer, Alabama. Simultaneous measurements of NO₂/NOx concentrations were performed in the PuraSiv N inlet and outlet streams during 11 individual 4-hour adsorption cycles, using continuous photometric analyzers. NOx concentrations were also measured at the test sites, using the EPA Method 7 reference procedure, to provide comparative data. Total NCx mass loading to the sieve was variable from cycle to cycle, ranging from 63,370 to 251,800 grams, reported as NO₂. Average efficiency of the control unit for the cycles tested ranged from 98.68 to 95.92%. The integrated average concentrations of NOx emitted over the complete cycles ranged from 17 to 154 ppm.</p>		
17. KEY WORDS AND DOCUMENT ANALYSIS		
a. DESCRIPTORS Air Pollution Nitric Acid Chemical Plants Absorbers (Materials) Nitrogen Oxides Adsorption	b. IDENTIFIERS/OPEN ENDED TERMS Air Pollution Control Stationary Sources Molecular Sieves Ammonia Oxidation Tail Gas PuraSiv N	c. COSATI Field/Group 13B 07B 07A 11G
18. DISTRIBUTION STATEMENT Unlimited	19. SECURITY CLASS (This Report) Unclassified	21. NO. OF PAGES 219
	20. SECURITY CLASS (This page) Unclassified	22. PRICE