

United States
Environmental Protection
Agency


Industrial Environmental Research
Laboratory
Research Triangle Park NC 27711

EPA-600/2-79-185
August 1979

Research and Development



Cost Effectiveness Model for Pollution Control at Coking Facilities



RESEARCH REPORTING SERIES

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into nine series. These nine broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and a maximum interface in related fields. The nine series are:

1. Environmental Health Effects Research
2. Environmental Protection Technology
3. Ecological Research
4. Environmental Monitoring
5. Socioeconomic Environmental Studies
6. Scientific and Technical Assessment Reports (STAR)
7. Interagency Energy-Environment Research and Development
8. "Special" Reports
9. Miscellaneous Reports

This report has been assigned to the ENVIRONMENTAL PROTECTION TECHNOLOGY series. This series describes research performed to develop and demonstrate instrumentation, equipment, and methodology to repair or prevent environmental degradation from point and non-point sources of pollution. This work provides the new or improved technology required for the control and treatment of pollution sources to meet environmental quality standards.

EPA REVIEW NOTICE

This report has been reviewed by the U.S. Environmental Protection Agency, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policy of the Agency, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

This document is available to the public through the National Technical Information Service, Springfield, Virginia 22161.

EPA-600/2-79-185

August 1979

Cost Effectiveness Model for Pollution Control at Coking Facilities

by

William F. Kemner

PEDCo Environmental, Inc.
11499 Chester Road
Cincinnati, Ohio 45242

Contract No. 68-02-2603, Task No. 44
and Contract No. 68-02-3074, Task No. 6
Program Element No. 1AB604

EPA Project Officer: Larry G. Twidwell

Industrial Environmental Research Laboratory
Office of Environmental Engineering and Technology
Research Triangle Park, NC 27711

Prepared for

U.S. ENVIRONMENTAL PROTECTION AGENCY
Office of Research and Development
Washington, DC 20460

DISCLAIMER

This report is furnished to the Environmental Protection Agency by PEDCo Environmental, Inc., Cincinnati, Ohio, in fulfillment of EPA Contract No. 68-02-2603, Task No. 44 and EPA contract No. 68-02-3074, Task 6. It describes the initial development and use of a cost optimization model for control of emissions from coke ovens. The cost model has been developed so that it will accommodate new information that becomes available on control cost, control systems, and emission levels. The data presented in this report and now used in the model are considered to be the best currently available. Because some areas of knowledge are continually developing, however, some engineering estimates are used to facilitate the development and refinement of the model.

The contents of the report reproduced herein are as received from the contractor. The opinions expressed are those of the authors and do not necessarily reflect the views of the EPA. Mention of company or product names is not to be considered as an endorsement by the authors or the EPA.

TABLE OF CONTENTS

	<u>Page</u>
Disclaimer .	ii
List of Figures	v
List of Tables	vii
Acknowledgement	viii
1.0 Introduction	1
References	3
2.0 Model Structure	4
2.1 Data Requirements	6
2.2 Control Cards	13
3.0 Emission Factors	20
3.1 Source 1--Larry Car Charging	22
3.2 Source 2--Coke Pushing Operations	25
3.3 Source 3--Quench Towers with Clean H ₂ O; Source 16--Without Clean H ₂ O	27
3.4 Source 4--Door Emissions	29
3.5 Source 5--Topside Leaks	31
3.6 Source 6--Old Combustion Stack; Source 15--New Combustion Stack	31
3.7 Source 7--Coke Handling	32
3.8 Source 8--Coal Preheat	33
3.9 Source 9--Coal Preparation	34
3.10 Source 10--Coal Storage	35
3.11 Source 11--Pipeline Charging	35
3.12 Source 12--Redler Conveyor Charging	37
3.13 Source 13--Hot-Larry-Car Charging	39
3.14 Source 14--Byproduct Recovery Plants	39
References	41

TABLE OF CONTENTS (continued)

	<u>Page</u>
4.0 Cost Methodology	44
4.1 Standards and Assumptions	44
4.2 Procedure for Cost Estimating	49
References	57
5.0 Control Systems	58
5.1 General Specifications	58
References	81
6.0 Battery Data Base (Dataset 3)	82
References	96
7.0 Model Formulation	97
8.0 Results	101
Appendix A - Example Computer Printouts for Cost Functions Presently Included in Model	A-1
Appendix B - Example Computer Printout for Cost Update Program	B-1

FIGURES

<u>No.</u>		<u>Page</u>
1	Schematic Diagram of Overall Computing Scheme	5
2	Card Format for Emission Factors--Dataset 1	8
3	Card Format for Cost Function Coefficients and Efficiency	12
4	Card Formats for Datasets 4, 5, and 6	14
5	Sample Output Report of Coke Oven Optimization Model	15
6	Format for the Control Cards	16
7	Relationship of Emission Sources in a Typical Byproduct Coke Plant	45
8	Flow Plan and Material Balance of a Representative Coke Byproduct Recovery Plant	46
9	Worksheet for Estimating Capital Costs	52
10	Cross Section of Coke-side Shed	62
11	Conventional Quench Tower Baffles	65
12	Simplified Pictorial Diagram of a Dry Quenching System	66
13	Door Hood Arrangement	68
14	Dust-suppression Spray System at Car Dump	73
15	Permanently Installed Spray Stanchions Around Perimeter of Coal Piles	75
16	Total Particulate Emissions from Coke Quenching	77
17	Coke Plant Wastewater Treatment System	80

FIGURES (continued)

<u>No.</u>		<u>Page</u>
18	Battery Data Card Format	90
19	Capital Cost of Control Options for Wet Coal Charging	106
20	Cost Per Pound of Particulate Removal for Control Options for Wet Coal Charging	107
21	Total Annualized Cost as a Function of Overall Efficiency	114

TABLES

<u>No.</u>		<u>Page</u>
1	Summary of Uncontrolled Emission Factors	7
2	Control Options by Source	10
3	Relationships of Size and Other Parameters, Coke Oven Battery	48
4	Typical Items Included in Investment Costs for Control Devices	51
5	Annualized Operating Cost Factors for Control Systems	54
6	Rates Used in the Cost Model	55
7	Coke Plants Using Process Water for Quenching	79
8	Coke Oven Model - Battery Data Base	84
9	Plant ID Codes	91
10	Total Capital and Annualized Costs for Control Options	103
11	Total Uncontrolled Emissions	105
12	Model Output for Baseline of No Control	108
13	Model Output for 95 Percent Overall Particulate Reduction	109
14	Model Output for 80 Percent Overall Particulate Reduction	111
15	Model Output for 85 Percent Overall Particulate Reduction	112
16	Model Output for 90 Percent Overall Particulate Reduction	113
A-1	Cost Function Coefficients for Control Options	A-2

ACKNOWLEDGEMENT

Many individuals have been helpful in developing this report. Mr. Andrew Trenholm of Office of Air Quality, Planning and Standards (OAQPS) provided invaluable assistance in developing emission factor and control efficiency estimates and in reviewing control system specifications. Mr. John Pratapas of Economics Analysis Branch (EAB) reviewed the approach used for calculating capital and annualized cost estimates. The assistance of the Project Officer, Dr. Larry Twidwell, is also gratefully acknowledged.

Mr. William Kemner served as Project Director, and Dr. Terrance Briggs as Project Manager. Ms. Beth Fairbairn and Mr. Steve Tomes of PEDCo did the computer programming and Mr. Gary Saunders conducted much of the data development effort.

SECTION 1

INTRODUCTION

The characterization and control of coke oven emissions have been of intense interest and study for some 10 years. Originally, focus was directed primarily toward visible emissions because most coke oven emissions are fugitive in nature. As additional data became available on the complex chemical structure and health effects of both the particulate and gaseous emissions, however, attention shifted to the organic components contained therein. Because the environmental control of the coke oven process and its associated operations requires the evaluation of numerous options and because technology and new information are continually developing, the Environmental Protection Agency (EPA) contracted PEDCo Environmental, Inc., to develop a computer model that could calculate the cost and emission levels for any combination of controls. Even more important, the model should be able to calculate the lowest-cost mix of controls for the various sources to meet a given overall level of emissions. The model should also answer the reverse problem by calculating the lowest overall emission level that can be attained at a given total cost. The model may be used to optimize, i.e., minimize, either annualized cost or total capital costs.

Intended to be an engineering tool for evaluating various control strategies on a continuing basis, the model is designed to operate on the EPA computer at the National Computer Center in Research Triangle Park, North Carolina. It accommodates data on four key pollutants: particulate matter (defined herein as front-half--Method 5), benzene soluble organics (BSO), benzo-a-pyrene (BaP), and benzene. The model includes the coke oven

battery, the coal storage and preparation steps, the quenching and coke screening operations, and the byproduct plant. It addresses both conventional batteries and preheated coal batteries. Various studies are under way to characterize the emissions from the byproduct operations, but the model now contains very limited information regarding this source.

The model utilizes three distinct types of data, referred to as "datasets." Each dataset can be updated and manipulated separately. Dataset 1 covers the uncontrolled emission rates for each pollutant, Dataset 2, capital and annualized costs and the control efficiency of various controls, and Dataset 3, the population of the coke oven batteries (e.g., battery height, capacity, and number of ovens).

Although a precise definition of the coke oven population was not a prime objective of this project, the definition provided by Dataset 3 is sufficiently comprehensive to be representative of both the metallurgical and foundry coke segments of the industry.

The model includes an auxiliary computer program that can update costs to account for such factors as inflation, changing utility rates, and changing labor costs.

The reader of this report is assumed to have a relatively comprehensive knowledge of coking operations and the concomitant emission problems and control schemes. The references at the end of this section are recommended reading for those who desire such background material.

REFERENCES FOR SECTION 1

1. Draft of Standards Support and Environmental Impact Statement, Volume I: Proposed National Emission Standards By-product Coke Oven Wet-coal Charging and Topside Leaks. U.S. Environmental Protection Agency, Research Triangle Park, North Carolina. June 1978.
2. Arthur D. Little, Inc. Steel and the Environment. A Cost Impact Analysis. May 1975.
3. Kemner, W., et al. Control of Emissions from Dry Coal Charging at Coke Batteries. Prepared for U.S. EPA under Contract 68-02-2603, Task 28, January 1979.
4. Technical Guidance for Control of Industrial Process Fugitive Particulate Emissions. EPA-450/3-77-010. March 1977.
5. Barnes, T.M., H.W. Lownie, Jr., and J. Varga. Summary Report on Control of Coke Oven Emissions to the American Iron and Steel Institute. Batelle Columbus Laboratories. December 31, 1973.

SECTION 2

MODEL STRUCTURE

As shown in Figure 1, the coke model has four essential elements:

1. The data management element reads the required information, determines the mode of operation, and translates the input data into the proper format for the optimization element.
2. The optimization element calculates the lowest cost for achieving a given level of emissions or the lowest level of emissions that can be achieved at a given cost. Note that optimization is on one pollutant at a time; however, the results for other pollutants are calculated in each case.
3. The deterministic mode element calculates specific cases without regard to optimization, e.g., the total cost to industry for putting ESP's on all coke oven stacks.
4. The print element prints the output reports in the desired format.

It will be noted that the optimization model is built around the standard 80-column punched card. Although this approach is somewhat outdated by today's computer technology standards, it offers certain advantages at this stage of model development. The main advantage is that the user can actually keep the data cards in his possession and keep track of the data as they are changed. The entire system can later be converted to real time operation from a remote terminal.




Figure 1. Schematic diagram of overall computing scheme.

2.1 DATA REQUIREMENTS

Emission Factors (Dataset 1)

Fourteen air emission sources and four pollutants are presently considered. A total of 64 uncontrolled emission factors are required because two sources have alternate factors. The emission factors used are shown in Table 1. It should be noted that data for coke oven emissions are very sparse for most sources and the factors shown in Table 1 represent only a starting point used for the purpose of proceeding with model development. The reliability of many of the factors is very low and is discussed more fully in Section 3. The term "uncontrolled" is not easily defined in the case of coke ovens, but for purposes of this project, it represents the conditions existing at the majority of batteries in the late 1960's. Although this definition still leaves much room for judgment, it eliminates totally uncontrolled conditions that could prevail if a coking process were operated with no concern whatever for emissions.

Because estimates of many of the emission factors have been based on limited data, provision has been made for easy updating to accommodate future refinements by use of the card format shown in Figure 2. The 16 cards (i.e., 14 sources, 2 with alternate factors) representing the emission factors comprise Dataset 1 input to the model (Figure 1). These emission factor cards also contain the space to write the name for the source for convenient identification. (The alphabetic names for new sources and control options that appear on the computer output must be entered into the computer using cards identified in the users' manual.) The derivation of emission factors is discussed in detail in Section 3.

Cost Functions (Dataset 2)

All cost functions are expressed as $Y = AX^B$, where Y is annualized cost in dollars and X is tons of coke capacity. Total capital cost is also provided as a function $Y = AX^B$. Capital and

TABLE 1. SUMMARY OF UNCONTROLLED EMISSION FACTORS
(lb/ton of coal)

(See Section 3 for discussion of each factor)

Source code No.	Emission source	Pollutant			
		TSP ^a	BSO	BaP	Benzene
1	Larry car charge (wet coal)	1.0 ^b	1.1 ^b	0.002 ^c	0.5 ^d
2	Coke pushing ^e	2.0 ^f	0.08 ^f	4x10 ^{-5f}	0.006 ^f
3	Quench, clean water	1.7 ^{f,9}	1.7x10 ^{-3b}	1.4x10 ^{-4b}	3x10 ^{-5c}
4	Doors	0.4 ^b	0.5 ^b	0.003 ^b	0.02 ^b
5	Topside leaks	0.2 ^d	0.25 ^d	0.001 ^d	0.005 ^d
6	Combustion stack (old) ^h	1.3 ^d	0.006 ^d	6x10 ^{-5d}	0 ^d
7	Coke handling	1.0 ^d	0 ^d	0 ^d	0 ^d
8	Coal preheat	7.05 ^b	1.05 ^b	3.9x10 ^{-4c}	0.014 ^c
9	Coal preparation	0.5 ^d	0 ^d	0 ^d	0 ^d
10	Coal storage	0.15 ^d	0 ^d	0 ^d	0 ^d
11	Pipeline charge (dry coal)	0.016 ^d	0.019 ^d	3.5x10 ^{-5d}	0.008 ^d
12	Redler conveyor (dry coal)	0.010 ^d	0.006 ^d	1.1x10 ^{-5d}	0.0049 ^d
13	Hot larry car (dry coal)	0.017 ^d	0.019 ^d	3.5x10 ^{-5d}	0.008 ^d
14	Byproduct	0 ^c	0.3 ^c	0 ^c	0.2 ^c
15	Combustion stack (new) ^h	0.13 ^d	6x10 ^{-4d}	6x10 ^{-6d}	0 ^d
16	Quench, dirty water	3.2 ^{f,9}	6.4x10 ^{-3b}	3.1x10 ^{-4b}	2.6x10 ^{-4c}

^a All TSP values derived from the front half of Method 5 or an equivalent method.

^b One or more tests conducted, moderate confidence in accuracy.

^c Test data available but inconclusive, low confidence in accuracy.

^d No test data available. Emission factor calculated from other sources, very low confidence in accuracy.

^e For dry coal charging, lower values may be appropriate (see text).

^f Several tests conducted, good correlation between data, good confidence in numerical accuracy.

⁹ Two cases are considered: "clean" water and "dirty" water. Existing data are used to select the appropriate emission factor.

^h Emissions depend on the maintenance history and age of the battery. The term "new" designates a well maintained battery with effective patching and maintenance programs. The term "old" designates the opposite. The population is subdivided on the assumption that batteries under 15 years old are new and over 15 years old are old. This approach is questionable, but in the absence of site-specific data, it is a starting point. Sensitivity analysis can be used to investigate the significance of various assumptions.

8




Figure 2. Card format for emission factors--Dataset 1.

annualized cost functions are provided for both new and retrofit installations.

The cost function matrix has the following dimensions:

Sources - Maximum of 20 (16 presently assigned)

Alternative control options--A maximum of nine per source, including uncontrolled

Table 2 lists the control options by source. The efficiencies shown are initial estimates only and are subject to change. The model provides for up to eight total control options for each source, but only a total of 41 are considered at this time. Although control efficiency is discrete in some cases and continuous in others, discrete levels have been used in the model for simplification. The total control option matrix capability is therefore 20 x 9, which produces a potential maximum of 180 "A" values and 180 "B" values for annualized and capital cost for both new and retrofit installations. Figure 3 shows the card format for A and B values. These cards are introduced as Dataset 2 (see Figure 1). As new control options are added or existing ones modified, the appropriate cost functions are added to Dataset 2. Most of the cost functions now in the model were calculated by PEDCo, using a separate computer program that is not part of the optimization model for coking facilities. The calculation of costs is discussed in detail in Sections 4 and 5.

Coke Oven Battery Data (Dataset 3)

This dataset contains the coke capacity, physical size, and existing control equipment information for each individual battery. It is described more fully in Section 6.

Cost Update Program

The cost update program is separate from the optimization model. Its purpose is to enable the user to recalculate annualized and capital costs by using different utility rates, labor rates, and overhead factors and accounting for inflation.

TABLE 2. CONTROL OPTIONS BY SOURCE

Source No.	Source	Control option No. ^a	Control option	TSP, % efficiency			BSO, % efficiency			BaP, % efficiency			Benzene, % efficiency			Remarks
				capture	removal	total	capture	removal	total	capture	removal	total	capture	removal	total	
01	Larry car charging	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Modified car, steam, boot	80.0	NA	80.0	80.0	NA	80.0	80.0	NA	80.0	80.0	NA	80.0	
		03	New car, steam, boot	99.0	NA	99.0	99.0	NA	99.0	99.0	NA	99.0	99.0	NA	99.0	
		04	Retrofit second main + option 03	99.5	NA	99.5	99.5	NA	99.5	99.5	NA	99.5	99.5	NA	99.5	
02	Coke pushing	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Controlled coking	60.0	NA	60.0	60.0	NA	60.0	60.0	NA	60.0	60.0	NA	60.0	19.0 h avg. coking time vs. 17.5 h base. Not appl. for foundry batteries
		03	Shed + ESP 95%	90.0	95.0	85.5	90.0	50.0	45.0	90.0	50.0	45.0	90.0	50.0	45.0	Shed options include 90% capture of one-half of door emissions
		04	Shed + scrubber 95% - 30 in. AP	90.0	95.0	85.5	90.0	55.0	49.5	90.0	55.0	49.5	90.0	55.0	49.5	
		05	Enclosed car	90.0	98.0	88.2	90.0	60.0	54.0	90.0	40.0	36.0	90.0	60.0	54.0	
		06	Shed + ESP 90%	90.0	99.0	89.1	90.0	50.0	45.0	90.0	50.0	45.0	90.0	50.0	45.0	
		07	Shed + scrubber 99% - 50 in. AP	90.0	99.0	89.1	90.0	60.0	54.0	90.0	60.0	54.0	90.0	60.0	54.0	
03	Quenching clean water	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Baffles	100.0	70.0	70.0	100.0	70.0	70.0	100.0	70.0	70.0	100.0	0.0	0.0	
		03	Diverted flow baffles	100.0	90.0	90.0	100.0	90.0	90.0	100.0	90.0	90.0	100.0	0.0	0.0	
		04	Dry quenching	100.0	98.0	98.0	100.0	99.0	99.0	100.0	99.0	99.0	100.0	99.0	99.0	Includes option 5 on source 2
04	Doors	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Cleaning and maintenance	60.0	NA	60.0	60.0	NA	60.0	60.0	NA	60.0	60.0	NA	60.0	
		03	High pressure water cleaning	80.0	NA	80.0	80.0	NA	80.0	80.0	NA	80.0	80.0	NA	80.0	Includes door cleaning machine
		04	Door hood and scrubber - 30 in. AP + 02	75.0	95.0	88.5	75.0	60.0	78.0	75.0	60.0	78.0	75.0	50.0	65.0	Option 6 is same as 4 but 1 side only ^b
		05	Door hood + scrubber - 60 in. AP + 02	85.0	98.0	93.3	85.0	70.0	83.8	85.0	70.0	83.8	85.0	60.0	72.0	Option 7 is same as 5 but 1 side only
05	Topside	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Luting and cleaning	90.0	NA	90.0	90.0	NA	90.0	90.0	NA	90.0	90.0	NA	90.0	Not applicable to pipeline batteries that are handled separately
		03	Luting and maintenance	95.0	NA	95.0	95.0	NA	95.0	95.0	NA	95.0	95.0	NA	95.0	
		04	New lids and castings + 02	97.0	NA	97.0	97.0	NA	97.0	97.0	NA	97.0	97.0	NA	97.0	

NA - Not applicable.

TABLE 2 (continued)

Source No.	Source	Control option No. ^a	Control option	TSP, % efficiency			BSO, % efficiency			BaP, % efficiency			Benzene, % efficiency			Remarks
				capture	removal	total	capture	removal	total	capture	removal	total	capture	removal	total	
06	Combustion stack -old	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Oven patching	100.0	80.0	80.0	100.0	80.0	80.0	100.0	80.0	80.0	100.0	80.0	80.0	
		03	Dry ESP 90%	100.0	90.0	90.0	100.0	50.0	50.0	100.0	50.0	50.0	100.0	50.0	50.0	
		04	Dry ESP 98%	100.0	98.0	98.0	100.0	60.0	60.0	100.0	60.0	60.0	100.0	60.0	60.0	
		05	Baghouse 98%	100.0	98.0	98.0	100.0	50.0	50.0	100.0	50.0	50.0	100.0	50.0	50.0	
07	Coke handling	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Enclosures + baghouse 99%	90.0	99.0	89.1	NA	NA	NA	NA	NA	NA	NA	NA	NA	
08	Coal preheater	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Scrubber-15 in.	100.0	95.0	95.0	100.0	60.0	60.0	100.0	60.0	60.0	100.0	50.0	50.0	
		03	Dry ESP 95%	100.0	95.0	95.0	100.0	45.0	45.0	100.0	45.0	45.0	100.0	45.0	45.0	
		04	Scrubber-30 in.	100.0	98.0	98.0	100.0	60.0	60.0	100.0	60.0	60.0	100.0	50.0	50.0	
		05	Dry ESP 99%	100.0	99.0	99.0	100.0	50.0	50.0	100.0	50.0	50.0	100.0	50.0	50.0	
09	Coal preparation	01	Uncontrolled			0.0	NA	NA	NA	NA	NA	NA	NA	NA	NA	
		02	Enclosure and baghouse-99%	98.0	99.0	97.0	NA	NA	NA	NA	NA	NA	NA	NA	NA	
10	Coal storage yard	01	Uncontrolled	0.0	NA	0.0	NA	NA	NA	NA	NA	NA	NA	NA	NA	
		02	Water truck	60.0	NA	60.0	NA	NA	NA	NA	NA	NA	NA	NA	NA	
		03	Unload sprays & water truck	75.0	NA	75.0	NA	NA	NA	NA	NA	NA	NA	NA	NA	
		04	Coal pile sprays	90.0	NA	90.0	NA	NA	NA	NA	NA	NA	NA	NA	NA	
11	Pipeline charging	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Operation and maintenance	90.0	NA	99.0	99.0	NA	99.0	99.0	NA	99.0	99.0	NA	99.0	
12	Redler charging	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Operation and maintenance	99.0	NA	99.0	99.0	NA	99.0	99.0	NA	99.0	99.0	NA	99.0	
13	Hot larry car charging	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Operation and maintenance	99.0	NA	99.0	99.0	NA	99.0	99.0	NA	99.0	99.0	NA	99.0	
14	Byproduct plant	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Maintenance	NA	NA	NA	80.0	NA	80.0	80.0	NA	80.0	80.0	NA	80.0	
15	Combustion stack -new	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Oven patching	80.0	NA	80.0	80.0	NA	80.0	80.0	NA	80.0	80.0	NA	80.0	
16	Quenching - dirty water	01	Uncontrolled			0.0			0.0			0.0			0.0	
		02	Baffles	100.0	70.0	70.0	100.0	35.0	35.0	100.0	35.0	35.0	100.0	0.0	0.0	
		03	Clean water + 02	100.0	85.0	85.0	100.0	75.0	75.0	100.0	80.0	80.0	100.0	75.0	75.0	
		04	Diverted flow baffles + clean water	100.0	95.0	95.0	100.0	85.0	85.0	100.0	85.0	85.0	100.0	75.0	75.0	
		05	Dry quenching ^c	NA	99.0	99.0	NA	99.0	99.0	NA	99.0	99.0	NA	99.0	99.0	

^a These code numbers are also used to indicate existing control in columns 21-60 of the load card for data set 3 shown in Figure 4.

^b Options 6 and 7 are used by the model when a shed is selected to avoid double accounting for capture of coke-side door emissions.

^c The cost for this option in this case also includes the cost of water treatment for the water that otherwise would be used for quenching.

①	②	③	④	⑤	⑥	⑦	⑧	⑨	⑩	⑪	⑫	⑬	⑭

- ① EMISSION SOURCE
- ② CONTROL OPTION
- ③ A COEFFICIENT FOR ANNUALIZED COST OF RETROFIT SOURCES
- ④ B COEFFICIENT FOR ANNUALIZED COST OF RETROFIT SOURCES
- ⑤ A COEFFICIENT FOR TOTAL CAPITAL COST OF RETROFIT SOURCES
- ⑥ B COEFFICIENT FOR TOTAL CAPITAL COST OF RETROFIT SOURCES
- ⑦ A COEFFICIENT FOR ANNUALIZED COST OF NEW SOURCES
- ⑧ B COEFFICIENT FOR ANNUALIZED COST OF NEW SOURCES
- ⑨ A COEFFICIENT FOR TOTAL CAPITAL COST OF NEW SOURCES
- ⑩ B COEFFICIENT FOR TOTAL CAPITAL COST OF NEW SOURCES
- ⑪ TSP CONTROL EFFICIENCY
- ⑫ BSO CONTROL EFFICIENCY
- ⑬ BaP CONTROL EFFICIENCY
- ⑭ BENZENE CONTROL EFFICIENCY

Figure 3. Card format for cost function coefficients and efficiency.

The input to the cost update program consists of the capital cost and utility and labor requirements for three sizes of batteries (or plants as applicable). A rate card contains the various rates and factors that can vary. The program will extend rates, calculate overhead expenses and capital recovery, and finally, calculate regression equations for capital and annualized cost as a function of capacity, according to equations of the form:

$$Y = AX^B$$

This program is run only if new rates are needed. Figure 4 shows the card formats for the Datasets 4, 5, and 6 which are the input data to the cost update program. Appendix B contains an example run of the cost update program. The output cards of the cost update program represent the input cost function cards for the optimization model.

2.2 CONTROL CARDS

The model has three basic modes of operation:

1. Deterministic
2. Optimized cost, fixed emissions
3. Optimized emissions, fixed cost

The control cards serve as the interface between the user's "questions" and the model structure.

Mode 1 is the most straightforward. Its objective is to calculate the cost of a given strategy without regard to optimization. A control efficiency and a control option are specified for each source (or for one source). Figure 5 shows the output. The only reason the quenching and combustion stack sources appear twice is because two different uncontrolled emission factors are used for each in the model as described earlier. The costs and emissions for these sources are additive. Figure 6 shows the formats of the control cards. (Not all columns of the Number 1 card are necessary for Mode 1.)

DATASET 4

(1)	(2)		(3)		(4)		(5)		(6)		(7)		(8)		(9)		(10)		(11)		(12)		(13)		(14)		(15)	(16)
																						.						4

- | | |
|---------------------------|--|
| ① EMISSION SOURCE | ⑩ TOTAL DIRECT LABOR, h |
| ② CONTROL OPTION | ⑪ SOLID WASTE, tons/yr |
| ③ CAPITAL COST FACTOR, \$ | ⑫ ESTIMATED LIFE OF UNIT, YEARS |
| ④ RETROFIT FACTOR | ⑬ MAINTENANCE MATERIAL COST, \$10 ³ |
| ⑤ SIZE, tons/yr | ⑭ SUPPLIES, \$10 ³ |
| ⑥ WATER, 1000 gal/yr | ⑮ CARD CODE "4" |
| ⑦ ELECTRICITY, kWh/yr | ⑯ SIZE CODE 1 - SMALL PLANT |
| ⑧ STEAM, 1000 lb/yr | 2 - MEDIUM PLANT |
| ⑨ FUEL, 1000 gal/yr | 3 - LARGE PLANT |

DATASET 5

①	②		③	④	⑤	⑥	⑦
							5

- | | |
|---|-------------------------------|
| ① EMISSION SOURCE | ⑤ CONTROL EFFICIENCY, BaP |
| ② CONTROL OPTION | ⑥ CONTROL EFFICIENCY, BENZENE |
| ③ CONTROL EFFICIENCY, TSP (STARTS IN COLUMN 56) | ⑦ CARD CODE "5" IN COLUMN 79 |
| ④ CONTROL EFFICIENCY, BSO | |

DATASET 6

[illegible]

- | | |
|-------------------------------------|--|
| ① WATER RATE, \$/gal | ⑧ PAYROLL OVERHEAD, % |
| ② ELECTRIC RATE, \$/kwh | ⑨ PLANT OVERHEAT, % |
| ③ STEAM RATE, \$/1000 lb | ⑩ CAPITAL RECOVERY, % |
| ④ FUEL RATE, \$/gal | ⑪ ADMINISTRATION OVERHEAD, % |
| ⑤ DIRECT LABOR, \$/h | ⑫ PROPERTY TAXES AND INSURANCE OVERHEAD, % |
| ⑥ SUPERVISION LABOR, \$/h | ⑬ COST BASIS, e.g., 2nd QUARTER, 1979 = 2Q79 |
| ⑦ SOLID WASTE DISPOSAL RATE, \$/ton | ⑭ INFLATION FACTOR, e.g., 7% = 1.07 |

Figure 4. Card formats for Datasets 4, 5, and 6.

COKE OVEN OPTIMIZATION

OBJECTIVE COST CALCULATION, NO OPTIMIZATION 75.1 % OVERALL EFFICIENCY POLLUTANT: BAP BASE YEAR 1979
 BASELINE: COST ADJUSTED FOR EXISTING CONTROLS

SOURCE	CONTROLLED EMISSIONS (LBS/TON COAL)				CONTROLLED EMISSIONS (TONS/YEAR)				CONTROL SCHEME	CONTROLLED COST (MILLION DOLLARS)	
	TSP	BSO	BAP	BEN	TSP	BSO	BAP	BEN		CAPITAL	ANNUALIZED
LARRY CAR CHARGING	# .01	.0110	.0000	.0050	496	545	0	248	NEW CAR, STEAM, BOOT	303.6	164.7
COKE PUSHING	#2.00	.0800	.0000	.0060	109463	4378	2	328	UNCONTROLLED	.0	.0
QUENCHING - CLEAN WATER	#1.70	.0017	.0001	.0000	41049	41	3	0	UNCONTROLLED	.0	.0
DOORS	# .16	.2000	.0012	.0080	8757	10946	65	437	CLEANING & MAINT.	.0	173.8
TOPSIDE	# .02	.0250	.0001	.0005	1094	1368	5	27	LUTING & CLEANING	.0	57.2
COMBUSTION STACK - OLD	#1.30	.0060	.0001	.0000	48840	225	2	0	UNCONTROLLED	.0	.0
COKE HANDLING	#1.00	.0000	.0000	.0000	54731	0	0	0	UNCONTROLLED	.0	.0
COAL PREHEATER	#7.05	1.0500	.0004	.0140	35925	5350	1	71	UNCONTROLLED	.0	.0
COAL PREPARATION	# .50	.0000	.0000	.0000	27365	0	0	0	UNCONTROLLED	.0	.0
COAL STORAGE YARD	# .15	.0000	.0000	.0000	8209	0	0	0	UNCONTROLLED	.0	.0
PIPELINE CHARGING	# .02	.0190	.0000	.0080	49	59	0	24	UNCONTROLLED	.0	.0
REDLER CHARGING	# .01	.0060	.0000	.0049	13	7	0	6	UNCONTROLLED	.0	.0
NOT LARRY CAR CHARGING	# .02	.0190	.0000	.0080	10	12	0	5	UNCONTROLLED	.0	.0
BY-PRODUCTS PLANT	# .00	.0600	.0000	.0400	0	3283	0	2189	MAINTENANCE	.0	17.4
COMBUSTION STACK - NEW	# .13	.0006	.0000	.0000	2231	10	0	0	UNCONTROLLED	.0	.0
QUENCHING - DIRTY WATER	# .48	.0016	.0001	.0001	14680	48	1	1	CLEAN WATER & BAFFLES	278.1	168.1
TOTAL UNC.	9.3	2.235	.006	.686	508238	122349	337	37577			
EXISTING CONTROL					388402	76172	254	17656		297.5	197.1
EXISTING EFFICIENCY					23.6	37.7	24.6	53.0			
BASELINE CONTROL					508237	122348	337	37577		.0	.0
BASELINE EFFICIENCY					.0	.0	.0	.0			
TOTAL CONTROLLED					352920	26278	84	3341		581.7	581.2
PERCENT CONTROLLED					30.6	78.5	75.1	91.1			

EXISTING		NEW	
TOTAL BATTERIES	216	TOTAL OVENS	12221
TOTAL CAPACITY	109494267 TONS COAL	TOTAL CAPACITY	0 TONS COAL
	76623000 TONS COKE		0 TONS COKE
# NOT IN OPTIMIZATION			

Figure 5. Sample output report of coke oven optimization model.

CONTROL CARD 1

①	②	③	④	⑤	⑥	⑦	⑧

- | | |
|--------------------------|---|
| ① MONTH OF RUN | ⑤ POLLUTANT OPTIMIZED |
| ② DAY OF RUN | ⑥ TOTAL DOLLAR RESTRICTION (FOR MODE 3) |
| ③ YEAR OF RUN | ⑦ TOTAL EMISSION RESTRICTION, PERCENT EFFICIENCY (FOR MODE 2) |
| ④ MODE: 1=DETERMINISTIC; | ⑧ BASE YEAR OF DATA |
- 2=MINIMUM ANNUALIZED COST, RESTRICT EMISSIONS
3=MINIMUM EMISSIONS, RESTRICT ANNUALIZED COST
4=MINIMUM CAPITAL COST, RESTRICT EMISSIONS
5=MINIMUM EMISSIONS, RESTRICT CAPITAL COST

CONTROL CARD 2

①	②	③	④	⑤	⑥	⑦	⑧	⑨	⑩	⑪	⑫	⑬	⑭	⑮	⑯	⑰	⑱	⑲	⑳

- ① THROUGH ⑳ FIXED CONTROL OPTION FOR EMISSION SOURCES 1 THROUGH 20

CONTROL CARD 3

①	②	③	④	⑤	⑥	⑦	⑧	⑨	⑩	⑪	⑫	⑬	⑭	⑮	⑯	⑰	⑱	⑲	⑳	㉑

- ① BASELINE CODE
② THROUGH ㉑ BASELINE CONTROL OPTION FOR SOURCES 1 THROUGH 20 RESPECTIVELY

Figure 6. Format for the control cards.

In Mode 2, the optimization routine is called into use. The user first specifies the sources that are to be fixed at a control level (i.e., as in Mode 1); the remaining sources will be optimized. A total control level expressed as percent efficiency for a given pollutant is specified and the lowest cost (either capital or annualized) combination that will meet that level is calculated. If some sources are specified to be uncontrolled and not included in the optimization, the user must take these emissions into account by lowering the total control efficiency. Otherwise, an infeasible solution can result because the remaining controlled sources may not meet the total allowable level. The output is similar to that in Figure 5. A symbol (#) appears by each source that was fixed, and these do not enter into the optimization.

In both modes the number two control card can be used to set a control level for any given source equal to uncontrolled, in which case the cost is zero. In effect, this enables certain sources to be removed from the optimization analysis.

The base year specified on Control Card 1 is merely a reference date to be printed on the output report. If, for example, the run is a projection for 1985 and projected new batteries have been added to the battery data base, the base year will be 1985. Presently, no new batteries are included in the battery data base and the base year is 1979.

Mode 3 is the opposite of Mode 2. A cost limitation (either capital or annualized) is entered, and the optimization program determines the lowest emission rate for the specified pollutant. It is probably necessary to run Mode 1 and Mode 2 before running Mode 3 to have some idea of what constitutes a reasonable total cost.

The comments portion of the printout will contain messages indicating unreasonable conditions, input errors, or solutions beyond the bounds of the program. For example, if the emission restriction (Mode 2) cannot be achieved by the control systems

available to the program, the printout will give a message to that effect.

Control Card 3 controls the baseline used for most calculations. The baseline codes are as follows:

<u>Code</u>	<u>Baseline</u>
1	Uncontrolled; i.e., all costs are calculated with no regard to existing controls or existing State Implementation Plan (SIP) requirements.
2	Existing control; costs are adjusted by not counting the cost of controls already installed.
3	SIP; i.e., costs are adjusted by not counting the cost of controls required by SIP whether they are actually installed or not. No account is taken for existing controls which exceed SIP requirements.
4	Average SIP; this option is the same as Option 3, but for convenience of data preparation only one SIP definition is used and applied to every plant; whereas as in Option 3 the specific SIP must be entered on each battery card depending on the state in which the battery is located.
5	This is a combination of 2 and 3. The costs are adjusted by not counting the cost of controls already installed or the cost of controls required by SIP whichever is greater.
6	Average SIP and existing; this option is the same as Option 5 but only one SIP definition is used and applied to every plant.

Note that no entries are required beyond field one for the baseline Options 1 and 2 because no distinction is made between sources in these options. For baseline Options 3 and 5, the control option codes corresponding to SIP must be entered on the coke oven battery data cards rather than using Control Card 3.

Currently the model does not attempt to account for costs of tear-out. If, for example, the optimum alternative differs from that already installed in a given plant, no tear-out costs are included. Nor does the model address incremental costs for moving

from one control scheme to a higher-cost scheme. If, for example, existing control is a shed and scrubber and the optimum alternative is a shed and ESP, the full cost of the optimum alternative is included rather than just the cost of the ESP.

In Figure 5, line 1 displays the total weighted uncontrolled emissions expressed in lbs/ton of coal and total tons. Lines 2 and 3 display the total tons of emissions and percent efficiency respectively for existing controls. Lines 4 and 5 display the total tons of emissions and percent efficiency respectively for the baseline controls which are in the optimum solution. Lines 6 and 7 display the total tons of emissions and percent efficiency for the optimum solution. The costs shown on line 2 represent the value of existing controls. The costs shown on line 4 represent the cost of the controls contained in the optimum solution which are already installed or assumed to be installed as designated by the baseline.

The costs shown on line 6 represent the cost of the controls in the optimum solution which exceed the baseline control level. The sum of these two lines therefore represents the total value of the controls in the solution.

SECTION 3

EMISSION FACTORS

For the 16 emission sources identified, emission factors were developed for each of the four pollutants: particulates, BSO, BaP, and benzene. To the extent possible, results from emission tests were used to establish these emission factors. When explicit data were unavailable, an attempt was made to derive an emission rate from other available information and assumptions. If an emission factor could not be developed by either of these approaches, an engineering estimate was made as accurately as possible. All the matrix numbers had to be provided (even if estimated) so that initial runs of the model could be completed. As new data become available, the values in the matrix (Table 1) can be updated to reflect more accurately the nature of emissions from byproduct coke ovens. If estimates have a broad confidence range, model runs can be made for various values to examine sensitivity.

Data were obtained from PEDCo's files, EPA reports, articles in various journals, and emission test reports. A literature search provided considerable information on coke oven emission sources and methods of reducing emissions; however, little actual test data or emission factors were available in comparison with the total number of potential emission sources. When actual numerical values were reported, they were used. The level of precision used in reported results was retained herein, but this does not imply that the value is precise when used as a general emission factor for all batteries. This is not surprising because it is difficult to sample these emission sources, most of which are fugitive in nature. Nevertheless, the literature did

provide considerable information on control techniques and what could be expected from them.

Because most emissions from the 16 sources are fugitive in nature, they do not lend themselves readily to Method 5 sampling techniques. Two commonly used techniques are single-point sampling with a Method 5 sampling train and sampling a fugitive plume with a High-Vol sampler. Sampling is sometimes attempted at isokinetic conditions, even though it often is difficult to achieve. Generally sample results are merely corrected to reflect isokinetic sampling. These methodologies appear to yield as reliable data as can be expected.

Using test data to develop emission factors requires several assumptions. The first is that the results of the test are representative of the emissions found at the entire battery (e.g., charging emissions do not differ significantly from one oven to another if the same sampling procedures are followed). In the case of door emission tests, one notable exception would be if test results were obtained on only one door; the fact that the one door tested was leaking does not indicate that all the doors leak. Another exception would be the sampling results from a single green push; one push does not necessarily represent all the coke pushes of that battery.

The second assumption is that the emissions from the battery tested are representative of the industry as a whole. Although it would be ideal to have test results from various plants for confirmation, it must be assumed that the values from the test used are the best currently available and are representative of battery emissions within the entire industry.

Several problems are unresolved. One is the matter of equivalency of two different sampling methodologies. Although some difference can be expected between the results of the Method 5 train and the Hi-Vol method (depending on the parameters of the emission stream sampled), they are similar enough to be considered equivalent methods. Another problem is the definition of TSP. Generally, a reference to a particulate catch means the

front half of a Method 5 train (or its equivalent). Total suspended particulate (or TSP), however, implies both the front half and back half of a Method 5 train particulate catch (or the equivalent). Because the definition of particulate matter is generally a function of temperature, emission factors derived on the basis of a front-half catch and those derived from both a front- and back-half catch would differ significantly. Thus the definition would tend to affect the predicted control efficiencies, particularly when discussing TSP. It is likely that many of the control devices on the optional control systems would not "see" the particulate captured in the back half of the sampling train because it would be gaseous in form as it passed through the control device and would condense some time later. Still another problem concerns the different methods used to test the various organic species to determine emission rates. Nevertheless, the variability between samples appears to have a greater effect than the differences in sensitivities and biases of the analytical methods because the different analytical methods are believed to yield essentially the same results.

The nature and magnitude of the biases on test results for each of the identified emission sources are discussed. Also discussed are the specific assumptions and references used to arrive at each emission factor. The general assumptions and comments just covered apply to nearly all the emission sources. For ease in predicting control efficiencies, particulate emission factors are given either as the front-half or equivalent value.

3.1 SOURCE 1--LARRY CAR CHARGING (WET COAL)

Particulates

A baseline of emissions must be established when referring to larry car charging. For the purposes of discussion, "uncontrolled" is assumed to mean that a minimal amount of control is applied during charging and minimal effort is expended to reduce emissions from wet coal charging. (This generally reflects the

situation in the industry about 10 years ago.) On this premise, an uncontrolled emission factor of 1 lb particulate/ton of coal charged has been estimated by EPA in the draft Standard Support and Environmental Impact Statement (SSEIS) for charging.¹ It is not known whether this number represents what could be expected to be captured by the total Method 5 train or just the front-half particulate catch. If this factor represents only the front half, actual total uncontrolled particulate is likely to be 1.96 lb/ton coal because it is assumed that the ratio of particles collected in the front half and back half of a train are about equal. This was the case in the testing of an experimental larry car during a joint project between the American Iron and Steel Institute (AISI) and the EPA. The back half proved to be approximately 0.96 of the mass of the front half.^{2,3}

The results of four tests revealed a controlled emission rate of 0.017 lb/ton coal (front half) for stage charging. It should be noted that these four tests were conducted anisokinetically, then corrected to reflect isokinetic conditions. A total particulate factor, calculated on the basis of the front-half catch, is 0.033 lb/ton coal.^{2,3}

A standard Wilputte larry car tested as part of the AISI/EPA program was found to have an emission level of 0.14 lb/ton coal (front-half, 10-test average) when tested by the same method as the experimental larry car. The test values could be in error as much as an order of magnitude, but less error is expected because of the sample size of ten. These latter tests were used as a guide in assigning a control efficiency for conventional stage charging.

Benzene Soluble Organics

The AISI/EPA particulate test revealed that BSO comprised 57 percent of the front-half catch and 60 percent of the back-half, and it can generally be assumed that BSO comprises 55 to 60 percent of the total particulate catch without significant

chance of error.^{1,2,4} With the use of the BSO/particulate ratios above, the calculated emission factors from the AISI/EPA test are as follows:

Uncontrolled	1.1 lb/ton coal
AISI/EPA larry car	0.019 lb/ton coal

Benzo-a-Pyrene

A significant variation in the levels of BaP was detected in the samples tested. Although the number of samples tested was not statistically large enough to derive a highly reliable emission factor, the AISI samples in which BaP was observed indicated an "average" of 2×10^{-5} lb/ton coal.^{1,2} An emission factor for BaP of 0.002 lb/ton coal has been calculated on the basis of ambient data and the ratio of BaP and BSO.^{1,4,5} This latter value is considered more reliable because of the large sample size and is used in the model.

Benzene

No explicit data on the magnitude of benzene emissions were found in the references noted above; however, an emission factor was calculated on the basis of the results of two tests of coke-side shed emissions and a test on coke-oven door emissions.⁶⁻⁹ These tests indicate that benzene emissions are equivalent to 25 to 50 percent of the front-half particulate emission rate. (This is not to say benzene is captured in the front-half.) Assuming an emission rate for benzene equivalent to 50 percent of the front-half catch, the following emission factors are calculated:

Uncontrolled	0.5 lb/ton coal
AISI/EPA larry car	0.008 lb/ton coal

These rates are highly variable for door emissions, however, and using these estimates to derive an emission factor for charging emissions provides a low-confidence estimate.

3.2 SOURCE 2--COKE PUSHING OPERATIONS

Particulates

Several data sources were available to use in the calculation of an emission factor for coke pushing operations.^{6,7,8,10,11} The magnitude of pushing emissions varies, depending on test methodology and "greenness" of the push. The sources used were a report on tests using Hi-Vol samplers suspended in the plume and one on sampling isokinetically.¹²⁻¹⁴ Results from tests using a Method 5 sampling train or sampling the stack of a coke-side shed appeared somewhat low and biased (a certain amount of dilution could bias the results on the low side). The two coke pushing operations tested were in close agreement. One of the batteries used an enclosed push car with hooding to capture the particulate.¹³⁻¹⁵ The enclosed car was controlled by a scrubber, and a standard Method 5 sampling train was used to sample the scrubber inlet and outlet. A Hi-Vol sampler was placed above the hood to capture the fugitive emissions. The total emission rate of particulate was estimated by combining the results of the Hi-Vol sampler and the scrubber inlet.

The emission rate from pushes that were moderately green averaged approximately 2.0 lb particulate/ton coal. Because little condensible matter was found in proportion to the particulate captured (i.e., back-half vs. front-half), a separate emission factor for a front-half and back-half TSP need not be calculated. For clean pushes an emission factor of 0.7 lb particulate/ton coal appears appropriate.

The significance of the clean push emission factor involves two separate items. First, the use of dry coal charging appears to provide uniform coking while reducing coking time.¹⁶ When running this optimization model it may be appropriate for the coke pushing emission factor to be selected on the basis of whether wet coal or dry coal methods are employed. Second, an often discussed alternative or control option is to increase the average coking time and establish some minimum coking time before

pushing takes place. Such an option might reduce emissions in cases where battery operators otherwise would cut short the coking time, but indications are that the greenness of the push is more closely related to the oven characteristics and heating integrity than to coking time.¹² Although further study is needed, it is conceivable that some ovens in need of maintenance could not thoroughly "coke-out" the coal charge regardless of coking time. The greenness of the push after some specified minimum coking time might therefore be used as an indicator that an oven needs maintenance.

Benzene Soluble Organics

An emission factor for BSO as condensibles in the coke pushing operations was based on a test of the hooded coke car used in the Ford/Koppers demonstration project.^{13,14} The emission rate was determined to be 0.08 lb BSO/ton coal for pushes that were moderately green, and a BSO emission factor of 0.03 lb BSO/ton coal was determined for clean pushes. These rates are based on the assumption that most of the condensible material captured is BSO. Although tests of coke-side sheds indicate that the amount of BSO generated is somewhat higher than these rates, it is believed that other factors (such as door leaks) biased the results.^{4,6,7,8} Results of another test for coke pushing emissions, which will be available in several months, may confirm the stated emission factors.

Benzo-a-Pyrene

Emissions of BaP were detected by sampling with cyclohexane and analyzing by GC/MS. An emission rate of 4×10^{-5} lb BaP/ton coal was established.^{13,14} It should be noted that the emissions of BaP were not reduced by passage through the venturi scrubber used at the plant, even though the emission level is very low. Although door leaks tend to interfere with the results, tests of the coke-side shed confirm the relatively low level of emissions.^{4,6,7,8}

Benzene

The tests of the Ford/Koppers scrubber-controlled quench car showed a small amount of benzene released during coke pushing operations. The average of six tests was 0.008 lb C₆H₆/ton coal (actually benzene and homologues). The actual rate of benzene only is expected to be in the range of 0.006 to 0.008 lb/ton coal. For clean pushes, benzene emissions could be as low as 0.0005 lb/ton, but they are expected to average 0.001 lb/ton coal. These factors are based on tests of the Ford/Koppers system.^{13,14}

3.3 SOURCE 3--QUENCH TOWERS WITH CLEAN H₂O; SOURCE 16-- WITHOUT CLEAN H₂O

Particulates

Considerable data have become available on the magnitude and nature of coke quench tower emissions.¹⁷⁻²¹ Besides the interest in the various types of control options, considerable interest has developed in quenching with clean versus dirty water. Emission factors for quenching with both clean and dirty water are discussed.

The development of an emission factor for particulate from quench towers is based primarily on the work of Edlund et al.,^{18,19} and on a data comparison from a recent report by Midwest Research Institute (MRI).²⁰ The results of the various tests vary widely; however, a data comparison was made primarily between Method 5 tests and Hi-Vol sampling techniques. It is difficult to maintain isokinetic sampling rates in the gas stream because the moisture content varies widely, but isokinetic sampling may be maintained "over the average." The difference in quench tower designs and other variables make it difficult to quantify the bias. Uncontrolled emissions from quench towers refer to the use of natural draft towers without baffles or other control devices to capture the emissions from wet quenching. The following particulate emission factors (to be used in the model) are based

on Edlund et al.:^{18,19} 1.7 lb particulate/ton coal (clean H₂O)
3.2 lb particulate/ton coal (dirty H₂O). These numbers are slightly higher than the averages from MRI, but they are well documented and fall well within the range of variation observed for the various tests. There appears to be no direct correlation between particulate emissions from quenching and the greenness of a push.

Benzene Soluble Organics

Many of the tests performed were also for the purpose of quantifying emissions of organic materials. Again, variations were similar to those observed for particulate emissions. For example, some test results from "clean" water quenches showed higher emission rates than results from "dirty" water quenches.²⁰ The emission factors shown below, however, are based on recent test^{17,21} results from a quench tower where the concentration of BSO in the gas stream was found to be about 1000 times less than the concentration of particulate matter during clean water quenches. Furthermore, dirty water quenches showed a concentration of BSO four times higher than that found in clean water quenches.^{17,21} Based on these ratios, the emission factors for BSO to be used in the model are:

1.7 x 10⁻³ lb BSO/ton coal (clean H₂O)
6.4 x 10⁻³ lb BSO/ton coal (dirty H₂O)

Benzo-a-Pyrene

Several tests made of the emissions of BaP showed some variations, but the absolute variation was small. The appearance of these variations may be due to the low levels of BaP present, which approach the detection limits of the sampling methodology. On the other hand, the data appeared to be consistent with the particulate data because dirty water quenches had about twice the level of pollutant emission as clean water quenches.^{17,21} The following emission factors were indicated:

1.4 x 10⁻⁴ lb BaP/ton coal (clean H₂O)
3.1 x 10⁻⁴ lb BaP/ton coal (dirty H₂O)

Emissions of BaP, which are not found in every sample, appear to be related somewhat to the greenness of the push.

Benzene

Data are limited regarding benzene emissions. Only two grab samples are available, and the data do not explicitly indicate whether these samples were taken during clean or dirty water quenches.¹⁷ Although the reliability of these values is extremely poor, they are used with the assumption that a higher level of benzene will be found in dirty water quenches:

3×10^{-5} lb/ton coal (clean H₂O)

2.6×10^{-4} lb/ton coal (dirty H₂O)

3.4 SOURCE 4--DOOR EMISSIONS

Particulates

Considerable data are available on emissions from doors during the coking cycle.^{6-10,22,23} It can normally be assumed that any door emissions that occur will be greatest during and immediately after oven charging.^{5,9} One test indicated that most emissions occur within the first 8 hours of the coking cycle. In a discussion of door emissions, it is difficult to define "uncontrolled" emissions. Two methods might be used to determine uncontrolled emissions. First, uncontrolled door emissions may be defined as emissions occurring because of failure to clean the oven doors thoroughly after each cycle. Such failure results in improperly sealed doors. Uncontrolled emissions might also result from failure to immediately remove damaged and warped doors from service for repairs at the end of a cycle. A second definition of uncontrolled emissions might be based on the number of doors leaking (e.g., no more than 40%). Thus, "uncontrolled" is not necessarily a measure of effort, but rather of results. A series of two tests were performed using an enclosure hood around the door and a Hi-Vol sampler. An emission rate of 0.025 to 0.04 lb/ton coal can be calculated from these data,⁹ but this value

seems low in view of available data from tests of coke-side sheds and door emission sheds with prototype gas cleaning equipment.²³ These latter data produced an uncontrolled emission factor of 0.4 lb/ton coal, which will be used in the model. This factor is based on the assumption that emissions from both sides of the battery are essentially the same and that approximately 40 percent of the doors leak when "uncontrolled."

Benzene Soluble Organics

A considerable portion of the door emissions is BSO; the BSO may actually exceed the front-half particulate emissions. The data from most of the tests indicate a factor of 0.25 lb BSO/ton coal may be appropriate for emissions from the doors on one side of a battery.^{4,9} This value is supported both by tests on a single door and by tests of continuous background emissions in a coke-side shed.⁶⁻⁸ The values obtained from the shed are more significant in that they consider the average of all leaks from one side of the battery. Again, it is assumed that the emission rates from both sides of the battery are equal, resulting in a total emission rate of 0.5 lb BSO/ton coal.

Benzo-a-Pyrene

Based on most of the data available from stack tests and comments from EPA, an BaP emission factor of 0.003 lb BaP/ton coal appears appropriate, although some data indicate a lower level of emissions is possible.^{1,4,6-9} If 40 percent of the coke battery doors are leaking, it is believed that the emissions from doors would be equal to or greater than that for "uncontrolled" larry car charging.

Benzene

Emissions of benzene can represent a significant portion of the condensible particulate matter during the initial portion of the coking cycle, but these emissions appear to decrease rapidly over the first 2 to 3 hours.⁹ Averaged over the entire coking cycle and from several ovens, benzene emissions appear large at

first, then decrease considerably in magnitude.⁹ The results from both an individual door test and tests of a coke-side shed indicate an emission factor of 0.01 lb C₆H₆/ton coal for one side of the battery.⁶⁻⁹ For both sides (assuming both emit equally) the emission factor is 0.02 lb C₆H₆/ton coal.

3.5 SOURCE 5--TOPSIDE LEAKS

Although no test data are available for reliable quantification of topside emissions, it is likely that they are similar in composition to door emissions. It is also likely that such emissions are less than half those from door leaks.^{1,4} The rationale for this assumption is that the area through which topside emissions may escape is roughly half that of the doors, oven pressure is generally lower, and the emissions are more easily controlled (e.g., by luting or replacement of warped lids). Emissions occur primarily from charging lids and stand-pipe caps.^{1,4} The following emission factors will be used for the model:

Particulate	0.2 lb/ton coal
BSO	0.25 lb/ton coal
BaP	0.001 lb/ton coal
Benzene	0.005 lb/ton coal

These uncontrolled emission factors are based on the assumption that a minimal amount of manpower is devoted to topside maintenance.

3.6 SOURCE 6--OLD COMBUSTION STACK; SOURCE 15--NEW COMBUSTION STACK

Particulates

Although data are available for calculating emission factors for combustion stacks, they are currently considered confidential and cannot be used in this study. Enough information was provided to estimate the level of emissions, however. When use of the data is permitted, they should be incorporated into the matrix of emission factors.

An average particulate emission factor for all combustion stacks is estimated to be 0.7 lb/ton coal.⁵ The range of values is wide, however, with old battery stacks showing higher emissions because of oven cracks and subsequent leakage into the flues. Nevertheless, the values are expected to be well within the range of 1.3 lb/ton coal for the old stack and 0.13 lb/ton coal for the new stack. The values are known to be about an order of magnitude apart.

Benzene Soluble Organics

Emissions of BSO are expected to be small from combustion stacks: 0.006 lb/ton coal from old stacks, and 0.0006 lb/ton coal from new stacks.

Benzo-a-Pyrene, Benzene

Emissions of BaP range from 6×10^{-5} lb/ton coal from old stacks to 6×10^{-6} lb/ton coal from new stacks. Very little benzene is believed to be emitted because it is probably combusted.⁵ Therefore, benzene emissions are considered to be zero.

3.7 SOURCE 7--COKE HANDLING

Particulates

No explicit data were found on which to quantify emissions from coke handling, but it is assumed that the coke is cooled sufficiently to prevent hydrocarbon emissions. Further, it is expected that larger particulate matter from sizing and screening operations would contribute greatly to the total particulate mass.²⁴ Therefore, an emission factor of 1.0 lb/ton coal has been estimated. This value is twice that found for coal preparation.

3.8 SOURCE 8--COAL PREHEAT

Particulates

Data from several tests of coal preheating systems are used to indicate the level of emissions to be expected from the preheater.^{25,26} More data are needed to improve the data base and should be added as they become available.

The particulate emission factor is based on the results of two series of emissions tests in which production rates and drying temperatures varied.²⁵ Particulate emissions appear to relate primarily to the rate of coal drying, and there is a slight correlation between emissions and gas temperatures. An average uncontrolled emission rate was developed over six test runs with the various production/temperature combinations and was determined to be 7.05 lb particulate/ton coal.²⁵ The relationship between production rate and emissions/ton coal appears to be inversely proportional. "Uncontrolled emissions" refers to the use of no control device after initial separation of the preheated coal from the gas stream.

Benzene Soluble Organics

The level of organic emissions (taken as BSO) was also tested during the particulate tests and average emissions were determined to be 1.05 lb/ton coal for six tests.²⁵ More recent data indicate a slightly higher emission rate, but this factor will be used until more information becomes available.²⁶ Although not enough data are available to define accurately the relationship between gas temperature and the rate of organic emissions, the emission rate appears to increase exponentially with higher production rates. Organic emissions also appear to increase with gas temperature.

Benzo-a-Pyrene

Recent data on BaP emissions indicate that emissions from the preheater scrubber outlet are approximately 2.0×10^{-4} lb

BaP/ton coal.²⁶ Based on an assumed scrubber efficiency of 50 percent for BaP, the uncontrolled emission rate would be 3.9×10^{-4} lb BaP/ton coal. Although the absolute variation of the emission rates tends to be small, the percentage variation is quite high.

Benzene

Data concerning benzene emissions are confusing at best.²⁶ Recent data indicate benzene emissions to be higher at the scrubber outlet than at the inlet, which would indicate a "negative" efficiency for benzene scrubbing, but no other source for benzene has been found that would clarify this. The outlet values will be used to determine an emission factor for the model. These values should be considered of low reliability, however, until the results are explained. One possible explanation is that the data sets might be reversed. Because insufficient data were provided to calculate a benzene emission factor directly, the known ratio between benzene and BSO had to be used. Based on the ratio between benzene and BSO hydrocarbons from this test (factor = $0.0130 \times \text{BSO}$), benzene emissions are estimated to be $0.014 \text{ lb C}_6\text{H}_6/\text{ton coal}$.

3.9 SOURCE 9--COAL PREPARATION

Particulates

Coal preparation is generally defined as the crushing, screening, and sizing of coal prior to charging of the ovens. Included are the emissions from handling and material transfer points. Coal dust is the predominant particulate emission. Normally no hydrocarbons are emitted because insufficient heat is supplied to cause any carbonization of the coal. It is assumed that the coal has been washed and separated from the burden material at the coal mine prior to its transport to the coke battery. Two sources indicate that with minimal controls (i.e.

hooding, water sprays), the expected particulate level is approximately 0.5 lb particulate/ton coal. This includes all transfer and crushing points.^{27,28} Uncontrolled emissions have the potential to be as high as 10 lb particulate/ton coal.

3.10 SOURCE 10--COAL STORAGE

Particulates

The only pollutant of concern from this source is particulate because it is assumed that the other pollutants either do not occur or are below detectable levels. The amount of particulate emissions from coal storage piles is usually a function of the size and shape of the storage pile, the wind speed, and the amount of material movement on the pile.²⁹ Thus a site-specific value would need to be assigned for the storage pile at each plant. PEDCo has performed several surveys on emissions from storage piles.^{29,30} Based on the assumption that the storage pile will be relatively inactive and that wind erosion is the primary cause of fugitive emissions, the emission factor would be 0.10 to 0.15 lb/ton coal. If loading onto the storage pile, traffic around the pile, and loadout of material are considered, the emission factor would be in the range of 0.4 to 0.5 lb/ton coal. The former value will be used in the model. If the total activity on or around the piles is applicable, the higher value can be used.

3.11 SOURCE 11--PIPELINE CHARGING (PREHEATED DRY COAL)

Particulates

Theoretically, emissions from pipeline charging could be near zero. In most cases, however, theoretical and actual values differ significantly at the batteries observed to date. In most pipeline charging operations, both operation and maintenance practices and engineering design factors have contributed to the level of emissions that have been observed.¹⁶

No formal tests have been made of emissions caused by pipeline charging. The charging hole lids and standpipe elbow covers are the major emission points. (Door leaks can also be a significant source of pollutants; these are discussed under Source 4.) The emission factors presented below are arrived at by relating a mass/time emission factor to visible emissions, using a mass/time constant of 0.0015 lb particulate/second of observed emissions. This factor is based on observation of the AISI/EPA larry car emissions.^{2,3,16} Based on this factor, an average of approximately 0.55 lb/charge was observed at the "worst case" battery. It is assumed here that the characteristics of charging emissions are the same as those observed for the AISI/EPA larry car charging. If the quantity of coal charged to the oven is assumed to be equivalent to 35 tons of wet coal, the emission factor is calculated to be 0.016 lb/ton coal.¹⁶ This value would be equivalent to that captured by the front half of a Method 5 sampling train. A total particulate emission factor of 0.031 lb/ton coal can be developed for a front and back half if it is assumed that characteristics are the same as those for the emissions of the AISI/EPA larry car charging. The assumptions used for calculating emission factors for dry coal charging are broad, and the results derived must be considered tenuous. The computations show that emission factors for pipeline charging and the AISI/EPA larry car charging are comparable. Informal observations also show that pushes from batteries using dry coal tend to be cleaner (i.e., the coal is more completely "coked") than those from batteries using wet coal. This factor has not been quantified in the model.

Benzene Soluble Organics

If it is assumed that emission characteristics are similar for BSO from both wet and dry coal charging and that BSO comprises 60 percent of the total particulate emissions, the calculated emission factor would be 0.019 lb BSO/ton coal. The assumed value of 60 percent is slightly higher than that observed

at the AISI/EPA test; however, the preheated coal may produce more volatile organic compounds during charging because of its higher temperature.

Benzo-a-Pyrene

Because both the emission factors and the assumed emission characteristics are similar to those of the AISI/EPA larry car, the BaP/BSO ratio for wet coal charging is used to derive an emission factor of 3.5×10^{-5} lb BaP/ton coal.

Benzene

For similar reasons, the benzene emission factor to be used in the model is 0.008 lb C_6H_6 /ton coal.

3.12 SOURCE 12--REDLER CONVEYOR (PREHEATED COAL) CHARGING

No formal emission tests have been performed on the Redler conveyor system. An emission factor has been developed, however, on the basis of several visible emission observations.¹⁶ Based on seconds of observed emissions, the emission factor is estimated to be 0.35 lb/ton charge. Assuming an equivalent 35 tons of wet coal/charge, the emission factor is 0.01 lb/ton coal.¹⁶

Particulate emissions were observed primarily from the charging ports and from the conveyor/chute junction. Emissions from the charging ports are not expected to differ significantly from those produced by the AISI/EPA larry car.¹⁶ Emissions from the conveyor/chute junction, however, appear to be mostly relatively large coal particles which could increase the weight of total particulate emissions.¹⁶ These emissions should not increase the emission factor above 0.03 lb/ton coal.

An emission factor based on total particulate emissions (front- and back-half) is expected to range from 0.0148 to 0.0168 lb/ton coal, primarily because of condensible emissions from the charging ports. (This is assuming that $\sim 1/2$ of the total emissions are from the charging ports, that the back-half emissions

would be 96 percent of the mass of the front-half, and that the total of any other emission sources is added.)

Benzene Soluble Organics

Emissions of BSO are expected to be less than those from pipeline and larry-car charging because the ratio of BSO to total front-half and back-half particulate is lower. The change in this ratio is due to the relative short periods of visible emissions that have been observed from the charging ports where the BSO is assumed to originate. Charging port emissions represent 0.0098 lb/ton (estimated) of particulate; if 60 percent of the particulate fraction is assumed to be due to BSO, emissions are calculated to be 0.006 lb BSO/ton coal.

Benzo-a-Pyrene

Because of the small quantity of BSO emitted, emissions of BaP are expected to be less than half that expected for the worst case for wet-coal larry car charging, or 0.0005 lb BaP/ton coal; and they could average as low as 1.1×10^{-5} lb BaP/ton coal. The latter value will be used in the model because it is believed to be more representative of actual emissions.⁵

Benzene

Emissions of benzene are difficult to quantify. Based on the assumption that benzene emissions originate from the charging port and that the emission factor is 25 percent of that for total particulate emissions from the charging port (0.0098), the emission factor becomes 0.0025 lb C₆H₆/ton coal. At 50 percent of the total particulate from the charging port, the emission factor becomes 0.0049 lb C₆H₆/ton coal. This higher value will be used in the model.

The preceding emission factors are only estimates; there are no test data to substantiate them. Dry coal charging should improve the level of pushing emissions because of the greater number of "clean" pushes resulting from more complete coking; it

should also provide the potential for lower levels of charging emissions.

3.13 SOURCE 13--HOT-LARRY-CAR CHARGING (PREHEATED DRY COAL)

Although no data are available on which to base emission factors for any of the four pollutants, these emissions are not expected to be significantly higher than those from wet-coal charging. Because the equipment will be new, the hot larry car should perform as well or better than the AISI/EPA larry car.¹⁶ Therefore, the following emission factors are to be used:

- 0.017 lb particulate/ton coal
- 0.033 lb total particulate/ton coal
- 0.019 lb BSO/ton coal
- 3.5×10^{-5} lb BaP/ton coal
- 0.008 lb C₆H₆/ton coal

The value for total particulate emissions is not used in the model, but it is shown for general information.

3.14 SOURCE 14--BYPRODUCT RECOVERY PLANTS

It is difficult to quantify the emissions from coke-oven byproduct-recovery plants. The main difficulties are the numerous fugitive sources and the significant differences in the type of byproduct recovery practiced from plant to plant. The approach taken to quantification of emissions was to select a plant that appeared to be representative of a majority of the byproduct recovery plants. Because not all sources of emissions have been tested and reliable emission data are not readily available, the estimates presented here are rough, and represent only the summation of estimates for various areas in a typical byproduct plant.³¹ Front-half Method 5 particulate emissions are believed to be zero.

The primary pollutants appear to be organics, but no useful data are available except on benzene. During processing, the coke-oven gas is cooled to a sufficiently low temperature to

condense the various hydrocarbons that make up the benzene soluble organics. Therefore only those with relatively high volatility should be emitted as fugitive emissions. Based on test data and estimates, benzene emission are calculated to be at least 0.2 lb/ton coal. It is possible some constituents of BSO (such as naphthalene) are emitted at very high levels and contribute at least 0.3 lb BSO/ton coal. This value will be used in the model until more specific data become available.^{5,31} Although BaP levels are unknown, they should be relatively low because of the condensation effect mentioned above.^{5,31} For the purposes of the model, BaP emissions will be considered zero.

REFERENCES FOR SECTION 3

1. Draft of Standards Support Environmental Impact Statement. Volume 1: Proposed National Emission Standards, Byproduct Coke Oven Wet-Coal Charging and Topside Leaks. Emission Standards and Engineering Division, U.S. EPA, Research Triangle Park, N.C. June 1978.
2. Coke Oven Charging Emission Control Test Program. Vol. 1. EPA-650/2-74-062. July 1974.
3. Coke Oven Charging Emission Control Test Program--Supplemental Observations. EPA-650/2-74-062A. September 1974.
4. Trenholm, A.R., and L.L. Beck. Assessment of Hazardous Organic Emissions from Slot Type Coke Oven Batteries. ESED, U.S. EPA, March 16, 1978.
5. Personal communication from A.R. Trenholm, ESED, U.S. EPA, March 21, 1979.
6. Source Testing of a Stationary Coke Side Enclosure. EPA-340/1-76-012. 1976.
7. Great Lakes Carbon Corporation. Study of Coke Side Coke-Oven Emissions. EPA-340/1-77-014A. Vol. 1: Source Testing of a Stationary Coke Side Enclosure. St. Louis, Missouri. 1977.
8. Great Lakes Carbon Corporation. Study of Coke Side Coke-Oven Emissions. EPA-340/1-77-014A. Vol. 2: Source Testing of a Stationary Coke Side Enclosure. St. Louis, Missouri.
9. Sampling and Analysis of Coke Oven Door Emissions. EPA-600/2-77-213. 1977.
10. Paley, L.R., and R.J. Powals. Assessment of the Fugitive Particulate Emissions Escaping from a Coke-Side Shed. (Date and Publication Date Unknown).

11. Paley, L.R., M. Antell, V.W. Hanson, and R.J. Powals. Were the Measured Emission Rates Representative of a Coke Battery's Typical Emissions? Presented at the Joint APCA/Source Evaluation Society Meeting, Dayton, Ohio, September 19, 1975.
12. Jacko, R.B., D.W. Neuerdorf, and J.R. Blandford. Purdue University, West Lafayette, Indiana 47907. Plume Parameter and Particulate Emissions from the Byproduct Coke Oven Pushing Operation. Presented at the 71st APCA Conference, Houston, Texas, June 25-30, 1978. APCA No. 78-9.4.
13. Emissions Testing and Evaluation of Ford/Koppers Coke Pushing Control System. Vol. 1: Final Report. EPA-600/2-77-187A. 1977.
14. Emissions Testing and Evaluation of Ford/Koppers Coke Pushing Control System. Vol. 2: Appendices. EPA-600/2-77-187B. 1977.
15. Roe, E.H., and J.D. Patton. Coke Oven Pushing Emission Control System. Journal of the Air Pollution Control Association, 25(4):379-382. April 1975.
16. PEDCO Environmental, Inc. Control of Emissions from Dry Coal Charging at Coke Oven Batteries. (Preliminary Draft). Prepared for U.S. EPA, IERL, OAQPS, Durham, N.C., under Contract No. 68-02-2603, Task 28. October 1978.
17. Dowling, M.P., J.D. Jeffry, and A.H. Laube. York Research Corporation, Stamford, Connecticut. Reduction of Quench Tower Emissions. Presented at the 71st APCA Conference, Houston, Texas, June 25-30, 1978. APCA No. 78-9.2.
18. Edlund, C., A.H. Laube, and J.D. Jeffry. U.S. EPA, Washington, D.C. Effects of Water Quality on Coke Quench Tower Particulate Emissions. Presented at the 70th APCA Conference, Toronto, Ontario, Canada, June 20-24, 1977. APCA No. 77-6.3.
19. Laube, A.H., J. Jeffry, and C. Edlund. Characterization of Pollutants Exiting Quench Towers. Presented at the 4th National Conference on Energy and the Environment, Cincinnati, Ohio, October 3-7, 1976. pp. 260-267.
20. Midwest Research Institute. Engineering Analysis of Emission Controls for Wet Quench Towers. Prepared for ESED, U.S. Environmental Protection Agency, Research Triangle Park, N.C., under Contract No. 68-02-2609, Task 7.

21. Rudolph, J.L., and C.E. Rechsteiner. Analysis of Samples from Coke Quench Tower Emissions. (Draft). Prepared by Arthur D. Little, Inc., for York Research Corporation. November 1978.
22. Study of Concepts for Minimizing Emissions from Coke-Oven Door Seals. EPA 650/2-75-064. 1975.
23. Barrett, R.E., and P.R. Webb. Effectiveness of a Wet Electrostatic Precipitator for Controlling POM Emissions from Coke Oven Door Leakage. Presented at the 71st Annual Meeting of the Air Pollution Control Association, Houston, Texas, June 25-30, 1978.
24. Air Pollution in the By-Product Coke Industry. Chapter II: Dust and Fume Generation in the Iron and Steel Industry. Russian Translation, MIR. 1977.
25. Betz Environmental Engineers. An Emission/Efficiency Evaluation of the A-5 Coke Oven Battery North Pre-Heat Bleed Venturi Scrubber System at the Aliquippa Works of the Jones and Laughlin Corporation. Pittsburgh, Pennsylvania, January 1977 and May 1977 (two tests).
26. York Research Corporation. Draft data from coal preheater tests at J&L Steel (Aliquippa Plant). EPA/IERL. July-August 1978.
27. Background Information for Standards of Performance: Coal Preparation Plants. Volume 1: Proposed Standards. EPA-450/2-74-021a. October 1974.
28. Inspection Manual for Enforcement of New Source Performance Standards: Coal Preparation Plants. EPA-340/1-77-022. November 1977.
29. Survey of Fugitive Dust from Coal Mines. EPA-908/1-78-003. February 1978.
30. PEDCo Environmental, Inc. Technical Guidance for Control of Industrial Process Fugitive Particulate Emissions. EPA-450/3-77-010. March 1977.
31. Research Triangle Institute. Environmental Assessment of Coke By-Product Recovery Plants. EPA 600/2-79-006, NTIS PB 293278/AS. 1979.

SECTION 4

COST METHODOLOGY

4.1 STANDARDS AND ASSUMPTIONS

Cost Standards

Three basic costs have been determined: (1) total installed capital cost, (2) annual operating cost, and (3) annualized cost. These costs reflect 4th quarter 1978 dollars. The procedures for calculating installed capital costs for control equipment are presented in Section 4.2, as are the details of the capital recovery factor, the items included in the cost estimates, unit prices for labor, and other such information.


Process Standards

The flow diagram of a typical coke plant (Figure 7) and the corresponding flow diagram of a byproduct plant (Figure 8) indicate the scope of the processes included in the model.

The following constants are used the control cost calculations:

Useful life of battery	40 years
Days in year	365
Hours in day	24
Coke oven gas/ton wet coal	11,500 ft ³
Bulk density of wet coal	50 lb/ft ³
Bulk density of dry coal	44 lb/ft ³
Coking time	17.5 h for furnace coke 24.0 h for foundry coke 12.5 for preheated coal

Figure 7. Relationship of emission sources in a typical byproduct coke plant.



^a Basis: the scale factor to Dunlop and McMichael (36) is 550

^b Rounded

Figure 8. Flow plan and material balance of a representative coke byproduct recovery plant.¹

Doors	Self-sealing (no luted doors)
Wet coal moisture	6 percent
Excess flushing liquor	45 gal/ton wet coal
Quench water requirement	150 gal/ton coke
Coke/coal yield	70 percent
Percent of gas used for underfire	40 percent

Flow rates:

Enclosed hot car, acfm	75,000
Enclosed shed, acfm	(0.67) x volume
Volume of shed	35.6 ft ³ /ft of length per ton of coke pushed (T)
Length of shed (L)	4 ft x (No. of ovens) + 20 ft
Wet quenching, acfm	30,800 x T
Dry quenching, acfm	88 x (tons of coke/day)
Combustion stack, acfm	59 x (tons of coal/day) at 450°F @ 100% excess air
Coal preheater stack, acfm	16,900 x (10 ⁶ tons of coal/year)

Temperatures:

The exhaust temperatures used are as follows:

Source	Temperature, °F
Charging	180
Pushing	300
Quenching	200
Doors	120
Topside	120
Combustion stack	450
Coal preheater	180

Table 3 shows the relationship between key oven parameters used to translate capacity data into the physical size data needed to determine certain costs. For example, oven volume is the key parameter for sizing larry-car hoppers, tons of coke per push is the key parameter for sizing an enclosed hot car, and oven height is a key parameter for determining shed cost. These

TABLE 3. RELATIONSHIPS OF SIZE AND OTHER PARAMETERS,
COKE OVEN BATTERY
Basis: 50 ovens

Oven height, m	3	4	6
Oven volume, ft ³	540	720	1390
Tons coke/push	8.5	12.0	25.0
Without preheat			
Coking time, h	17.5	17.5	17.5
Pushes/day	68.6	68.6	68.6
Tons coke/yr ^a	213,000	300,000	626,000
With preheat			
Coking time, h	12.5	12.5	12.5
Pushes/day	96	96	96
Tons coke/yr ^a	296,000	420,000	876,000

^aDirectly proportional to number of ovens and inversely proportional to coking time.

relationships were used in calculating the cost functions for model input. For convenience the cost equations are expressed as a function of capacity. Because most batteries fall into one of the three categories shown in Table 3, the use of capacity as the cost variable is reasonable.

Two "interactions" are recognized in the model. An interaction is defined as a control of one source that effects control of another source. The interactions are as follows:

- The use of shed control on the pushing source effects control of coke-side door emissions. The removal efficiency is the same as that for pushing emissions except that only the coke-side door emissions are captured.
- The use of dry quenching on the quenching source effects control of pushing emissions because dry quenching utilizes an enclosed hot car. The cost of dry quenching also includes the cost of water treatment at those plants that would otherwise use dirty water for quenching.

4.2 PROCEDURE FOR COST ESTIMATING

Estimates for coke making systems are divided into two major categories, capital costs and annualized costs. Capital costs include such things as basic equipment and installation costs, contractors' fees, and taxes. Estimates are sometimes obtained directly from vendors and published information, or they may be based on engineering experience and judgment. Some elements of annualized costs also can be obtained from published information or other documented sources, whereas other elements (e.g., annualized overhead) must be calculated because they are dependent on capital costs.

The direct operating cost estimates in this report are based on engineering judgment unless otherwise noted. They reflect 4th quarter 1978 dollars based on the Chemical Engineering Plant Cost Index.

Capital Costs

Capital costs represent the total investment required to install a new control system. General factors that must be considered for any type of control device are total equipment cost, piping and ductwork, insulation, painting, and the like. Table 4 lists typical items included in investment costs of air pollution control systems.

System-specific factors affecting costs must also be considered. For coke oven systems these are capture method, temperature, effect on byproduct quality (if applicable), fuel storage (if applicable), and construction interest charges. Not included are production losses due to control equipment installation and startup and research and development costs.

The worksheet presented as Figure 9 organizes all capital investment cost factors for control systems into direct and indirect costs. Factors for the components in each group are calculated either as a function of the basic cost of the equipment or material (obtained from vendor quotations) or calculated specifically from engineering estimates (e.g., cubic yards of concrete required for foundations).

Annualized Costs

Total annualized costs include direct operating costs, capital charges, and overhead charges.

Direct operating costs include such items as utilities (fuel oil, natural gas, electricity, process water, etc.), operating labor (both direct and supervisory), maintenance and supplies (labor and material), and solid waste disposal.

Capital charges include depreciation, interest, administrative overhead, property taxes, and insurance. Depreciation and interest are computed from the total capital cost by using a Capital Recovery Factor (CRF), the value of which depends on the

TABLE 4. TYPICAL ITEMS INCLUDED IN INVESTMENT COSTS
FOR CONTROL DEVICES

Total equipment cost, f.o.b. site
Device control instrumentation
Piping and duct work
Electrical equipment (motors, starters, conduits, etc.)
Insulation
Painting
Concrete and steel for foundations and support structures
Labor for equipment installation and materials application
Site preparation and building modifications
Construction management and supervision (contractor's fees)
Contingencies
Engineering and inspection
Startup
Freight charges for equipment and materials
Taxes and insurance

SUMMARY

PEDCO ENVIRONMENTAL DESCRIPTION _____		DATE _____		
PROJECT NO. _____		BY _____		
DESCRIPTION	DETAIL SHEET	MATERIAL	LABOR	TOTAL
DIRECT COSTS				
1. Equipment				
2. Instrumentation				
3. Piping				
4. Electrical				
5. Foundations				
6. Structural				
7. Sitework				
8. Insulation				
9. Painting				
10. Buildings				
11. _____				
12. _____				
15. DIRECT SUBTOTAL				
INDIRECT COSTS				
21. Field Overhead				
22. Contractor's Fee				
23. Engineering				
24. Freight				
25. Offsite				
26. Taxes (5% x material)				
27. Allowance For Shakedown				
28. Spares				
29. _____				
30. _____				
31. INDIRECT SUBTOTAL				
35. SUBTOTAL				
41. Contingency (20% of line 35)				
42. Interest During Construction (10% of line 35)				
45. TOTAL				

Figure 9. Worksheet for estimating capital costs.

operating life of the system and on the interest rate.* For example, a CRF of 13.2 percent per year of the total capital costs is allowed for a system with a 15-year life expectancy and an interest rate of 10 percent. Property taxes and insurance are fixed together at 2.0 percent of the total capital cost per year. Administrative overhead charges are also fixed at 2.0 percent of the total capital cost.

Table 5 presents annualized operating cost factors used for control systems. Table 6 lists the specific rates used for computing the annualized costs for this particular study.

Modified/Reconstructed Facilities

The cost of installing a control system in an existing plant that has been modified, reconstructed, or expanded (given the same exhaust gas parameters) is greater than in a new plant because of special design considerations, more complex piping requirements, etc. It is difficult to estimate additional installation costs or retrofit penalty because many things are peculiar to an individual plant. Such factors as lack of space, additional ducting, and additional engineering have been considered here.

The location of the control system is governed by the configuration of the existing equipment. Long ducting runs from ground level to the control device and to the stack are sometimes required, depending on the location of the process or stack. Placing the control equipment above ground, which often requires steel structural support, may increase costs. Other cost components that may be increased because of space restrictions and plant configuration are contractor's fees and engineering fees. Under normal conditions these fees are estimated at 15 percent and 10 percent, but they can be expected to increase to 20 percent and 15 percent for a retrofit. Fees vary according to

* $CFR = \frac{i(1+i)^n}{(1+i)^n - 1}$ where i = interest rate (decimal factor) and
 n = economic life of asset (No. years)

TABLE 5. ANNUALIZED OPERATING COST FACTORS
FOR CONTROL SYSTEMS

Direct operating costs

Utilities:

Fuel oil
Coal
Natural gas
Electricity

Operating labor:

Direct and supervisory (assume X shifts/day and X days/year to calculate hours/day)

Maintenance:

Labor
Materials

Supplies:

Labor
Materials

Solid waste disposal

Water treatment costs

Capital charges

Depreciation and interest

Administrative overhead

Property taxes

Insurance

Recovery credit adjustments

TABLE 6. RATES USED IN THE COST MODEL

Item	4th Quarter, 1978 dollars	Source
Water	0.161/1000 gal	a
Electricity	0.0266/kWh	a
Steam	4.13/M lb	b
No. 2 oil	0.42/gal	b
Natural gas	2.80/1000 ft ³	b
Coke oven gas	1.39/1000 ft ³	b
Direct labor	15.22/h	a
Supervisory labor	18.26/h	b
Compound MR dust control	3.69/gal	c
Bag cost (Lt 275°F)	0.28/ft ²	d
Bag cost (Gt 275°F)	0.44/ft ²	d
Sodium hydroxide	360/ton (100% basis)	e
Polyelectrolyte	2.48/gal	f
Solid waste disposal	8.25/ton	d
Payroll overhead	20% of payroll	d
Plant overhead	50% of labor and supplies	d
Interest rate	10%	d
Administration overhead	2% of installed cost	d
Property taxes and insurance overhead	2% of installed cost	d

^aTBS (Reference 2).

^bCalculated by PEDCo from rates in Reference 2.

^cPEDCo Fugitive Dust Report. EPA-450/3-77-010. Reference 3.

^dEstimated by PEDCo.

^eReference 4.

^fReference 5.

locale, difficulty of the job, the risks involved, and current economic conditions. PEDCo estimated the fees cited.

The required additional ducting varies considerably with plant configuration, but for purposes of this study, it is estimated that approximately 50 percent more ducting is required for a retrofitted control system.

Additional labor will be required to tie the system into the process, probably at premium-time wage rates (assumed to be double the straight-time pay).

When these additional cost factors are applied, the cost of retrofit installations generally runs about 20 percent higher than the cost of new installations; specific retrofit penalties are estimated individually for each module in the PEDCo cost model. Retrofit is not feasible in some plants, and these cases must be treated on a site-specific basis. The systems which are the most difficult to deal with as retrofits are dry coal charging and dry quenching. In the case of dry coal charging, there is the additional problem of apportioning cost between pollution control and increased production capability. Dry coal charging systems are included in the model only if they already are installed; retrofits to existing batteries are not included. Dry quenching is included with the provision that it may be not feasible for all plants.

Annualized Cost of Control Systems

The annualized costs of control systems for modified/reconstructed facilities are calculated in a manner similar to that for new facilities. The cost components that are based on capital costs are about 10 to 20 percent higher than those for new facilities.

REFERENCES FOR SECTION 4

1. Research Triangle Institute. Environmental Assessment of Coke By-Product Recovery Plants. EPA 600/2-79-006, NTIS PB 293278/AS. 1979.
2. Temple, Barker & Sloane. Analysis of Economic Effects of Environmental Regulations on the Integrated Iron & Steel Industry EPA-230/3-77-015B, July 1977.
3. Technical Guidance for Control of Industrial Process Fugitive Particulate Emissions. Prepared for EPA by PEDCo Environmental, Inc. March 1977. EPA-450/3-77-010.
4. Chemical Marketing Reporter, October 9, 1978.
5. Personal communication between W. Kemner of PEDCo and D. Pietruszka of Betz Co., Trevose, Pennsylvania, 19047. June 1978.

SECTION 5

CONTROL SYSTEMS

This section provides a general description of each control option listed in Section 2 (Table 2). Further details such as exhaust temperature, duct diameter, and flow rate for each size of battery and plant are presented in the computer printouts for each control option in Appendix A. This section also provides a summary of capital and annualized costs for each option.

The cost estimates presented are based on engineering estimates by PEDCo, unless otherwise noted. Where applicable, the procedures described in Section 4.2 are used to derive the costs. For those control options that involve additional manpower or changes in operation and maintenance (rather than equipment), costs represent estimates of additional manhours required (sometimes based on related work previously performed by PEDCo).

5.1 GENERAL SPECIFICATIONS

Source 1--Larry Car Charging

Control Option 2: Modified Car, Steam, and Smoke Boot--

Modification costs are based on a standard four-hopper larry car. The basic modifications are the addition of a gooseneck cleaner, hydraulics for independent drop sleeve operation, a suction pipe (U-tube), stainless steel cones for hoppers, heat shields, new hopper discharge assemblies allowing independent operation, and a fume pipe for ventilation from the U-tube on Port 4 to Port 1. Costs also include all necessary engineering,

assembly, and installation. Estimates are based on the assumption that the existing car is relatively new and that modifications are feasible. It is also assumed that headroom at the coal bunker is adequate. Estimates do not consider OSHA requirements for filtered air supply.

The steam supply considered in this option consists of a pressure regulating station, a 4-inch header along the battery, 1-inch takeoffs at each standpipe, and steam injection jets and the attendant miscellaneous piping, insulation, and installation.

Although the baseline for "uncontrolled" probably represents a battery already supplied with steam, it is assumed that the supply is not adequate to provide the quantity, pressure control, or the reliability necessary for good stage charging.

The final portion of this option involves a smoke seal for the leveling bar. The operating costs cover one additional lidman per shift (to insure timely lid replacement and luting) and one pipefitter on day shift to provide preventive maintenance for steam nozzle and liquor spray. Steam requirement is estimated at 24 lb/ton coke.

Control Option 3: New Car, Steam, Smoke Boot--

The new car included in Option 3 controls affords greater control because it is more reliable, and includes such design improvements as a gravity feed butterfly valve (Carbotek), and "two ovens-away drafting."

The car basically consists of four hoppers with flow control valves and drop sleeves, fume pipes between Ports 1 and 4 and Port 4 two ovens away, hydraulic slide gates, and gooseneck cleaner.

The battery steam supply and smoke boot are also included.

Many site-specific details of design will increase or decrease the cost from plant to plant. Furthermore, site-specific problems such as three-hole batteries, coal bunker clearance, warped battery tops, and off-battery-limit steam supply problems are not considered in the cost estimates.

The operating costs include the same additional manpower as described for Option 2. The additional costs for treating the condensed steam are not included, nor are potential losses due to deleterious effects of steam on tar quality (these should be addressed later in the refining of the fully developed model).

Control Option 4: Retrofit of Second Collecting Main Plus Option 3--

This option applies only to batteries with one collecting main, and includes the same features as Option 3 plus the retrofit of a second main. The estimate for the latter is based on the cost data in Reference 1. The reference does not indicate specifically what is included, but it is assumed that the second collecting main includes standpipes and goosenecks, collecting main, crossover mains across the battery top, steam and liquor spray systems, and a pressure regulating system. Such an installation is probably not feasible for batteries nearing the end of their useful life.

An additional refinement of the model could restrict usage of this option for older batteries because battery age is included in the battery data base. The model should also account for the probable decrease in door emissions afforded by a double collecting main, but presently this factor is ignored.

Source 2--Pushing

Control Option 2: Controlled Coking--

This option involves no capital cost--only annual operating costs. These include one additional man per shift for monitoring flue temperature and coking time. The major portion of the costs is based on an increase in average coking time of 17.5 to 19 hours. This represents an 8 percent loss in capacity (given that demand is at capacity). Lost production is valued at \$110/ton of coke. For a battery with a capacity of 400,000 tons/year, the cost is $(0.08) \times (400,000) \times (\$110)$, or \$3,520,000. At capacity utilization ratios below 92 percent, the cost thus calculated is

theoretically zero, but periodic need for maximum output would still entail some lost production.

Control Options 3 and 6: Shed and Electrostatic Precipitator (ESP); Control Options 4 and 7: Shed and Scrubber--

The control efficiencies of the ESP are translated into cost by the relationship between efficiency and collection area shown below:²

<u>Efficiency, %</u>	<u>Plate area, ft²/1000 acfm of gas flow</u>
99.9	385
99.0	240
95.0	188

The larger the plate area, the higher the control efficiency and the greater the control cost.

Aside from this factor, the general specifications for both of the shed ESP systems are identical as described here. The length of the shed is 4 feet per oven plus 20 feet of overhang. The exhaust volume is calculated according to the equation:

$$\text{Exhaust volume in acfm} = 1.67 (\text{shed volume})$$

$$\text{shed volume} = 35.6 (L)(T)$$

where

L = length of shed and

T = tons of coke per push

The shed includes foundations, columns, sheeting, internal lighting, and exhaust main along the length of the shed and under the exhaust main, an access walkway through shed. Figure 10 is a simplified cross section of the shed.

The shed system includes the shed, the ESP, the fan and drive, connecting duct work, the exhaust stack, and control dampers at the fans. As is the case for all air-moving systems, fan redundancy is 100 percent for fans smaller than 500 bhp and 50 percent over 500 bhp. For example, if the total horsepower required is 400 bhp, two 400 bhp fans are provided. For a total requirement of 1000 bhp, three 500 bhp fans are provided. Fan drive horsepower is based on standard air density of 0.075 lb/ft³ to allow for cold starts.




Figure 10. Cross section of coke-side shed.

The redundancy of the ESP is 20 percent of the plate area required. The ESP's are insulated and covered and include dust-handling hoppers and conveyors. Duct diameters are based on a duct velocity of 4000 ft/min. Stack diameters are based on a stack velocity of 3000 ft/min. The 300 ft of duct work for the shed is unlined and uninsulated carbon steel, as is the 100-ft stack. Fans are induced-draft and centrifugal with radial-tipped blades, and are rated for material handling (MH). The totally enclosed motors are drip-proof and have oil-cooled bearings as required. The fan electrical system includes motor starters, louver operators, annunciators and related switches, and wiring. No allowance is made for additional substations or increasing plant electrical capacity.

The only difference in the scrubber systems is that the ESP is substituted with an unlined stainless steel venturi scrubber and mist eliminator. Total system pressure drop is 50 in. H₂O for a 99 percent TSP collection efficiency and 30 in. H₂O for a 95 percent collection efficiency. (These are initial estimates only and can be refined later.) The L/G ratio of the scrubbing liquor is 7.9. Wastewater is recycled through a treatment system, which includes a clarifier-vacuum filter section, a wastewater recirculating pump, and a makeup water pump. It is assumed that this system will have a 5 percent blowdown rate to an existing water treatment system for removal of dissolved compounds such as phenol and cyanide.

The shed systems are assumed to capture coke-side door emissions in addition to 90 percent of the pushing emissions. Coke-side door emissions are assumed to be 50 percent of total door emissions.

Control Option 5: Enclosed Hot Car--

The enclosed hot car used in this option is described in the literature and in Reference 2. Equipment costs are based on a rough quote by Chemico; indirect costs were added by PEDCo. No separate allowance is made for reenforcement or modification of

the bench or for modification of the quench tower or wharf except as they might be included in a gross estimate represented by the retrofit factor. The Chemico car was chosen from a variety of designs to represent this general class of control. Additional variations can be added to the model if desired.

Source 3--Quenching Clean Water

Control Option 2: Wooden Baffles--


The cost of quench tower controls is a function of the number of quench towers in the plant rather than of coking capacity. Because specific data are not available on the number of quench towers required, it is assumed that one quench tower can handle up to 900,000 tons/yr of coke production. Figure 11 shows the scope of this option.

Control Option 3: Diverted Flow Baffles--

The total installed capital cost of a diverted-flow, baffled quench tower was estimated by PEDCo based on a brochure from Firma Carl Still. The estimate includes baffles, water system, and quench tower extension. It does not include dismantling of an existing tower and total replacement by a new quench tower. Operating costs are calculated to be about 10 percent of the total capital cost. The number of quench towers required is calculated as indicated under Option 2.

Control Option 4: Dry Quenching--

Costs are based on a system such as that shown in simplified form in Figure 12, which was derived from a brochure by American Wagner Biro Company. This system includes enclosed pushing hardware, which is accounted for in the model; i.e., when dry quenching is used, pushing control is put at level 5. Because no U.S. plants use dry quenching and the steam generated might not be useful to the plant, the potential steam credit is not considered here. If it were, the annualized cost would become negative, which would complicate the optimization model. If desired, however, the cost update program can be used to generate



TYPICAL BAFFLE ARRANGEMENT

Figure 11. Conventional quench tower baffles.




Figure 12. Simplified pictorial diagram of a dry quenching system.

revised cost functions for dry quenching, which do account for steam credit. There are some relatively small plants (less than 100,000 tons of coke per year) in the data base for which dry quenching is probably not feasible. It is also questionable whether the present cost function is applicable in this small range. These issues can be further investigated as a later refinement.

Source 4--Doors

Control Option 2: Cleaning and Maintenance--

This option involves no capital cost. The annual operating cost is based on the addition of two men/shift for cleaning, door inspection, and repair. Maintenance costs also include the cost of door replacement at a rate of 10 percent per year.




Control Option 3: High Pressure Water Cleaning--

This option entails the installation of two (one per side) high-pressure water-cleaning machines, either on the existing pusher and door machines or on a separate car. Costs are based on a rough quote by Industrial High Pressure Systems, Inc. It is assumed that the existing pusher and door machine operators will operate the cleaning units. The option requires the addition of one man/shift for troubleshooting and inspection. Cost of replacement doors is the same as for control Option 2.

Control Options 4 and 5: Door Hood and Scrubber--

The scrubber, duct work, fans, and auxiliaries used in this control option are generally of the same specification as previously described. An unlined stainless steel venturi is used with a mist eliminator. The scrubber efficiency at 30 in. H_2O pressure drop is estimated to be 95 percent; at 60 in. H_2O , 98 percent. The water treatment system is the same as described under Source 2. The duct length included is 150 ft plus the length of ducts along both sides of the battery calculated as four feet per oven per side. Stack height is 100 feet. Both are constructed of unlined, uninsulated, carbon steel. Figure 13 presents a sketch of the system and indicates the required flow

FRONT VIEW



DOOR FACE AREA = $(1.5 \text{ ft}) \times (4 \text{ ft}) = 6 \text{ ft}^2$
NUMBER OF OVENS EXHAUSTED AT ANY GIVEN TIME = 6
FACE VELOCITY = 200 ft/min FOR 75% CAPTURE
FACE VELOCITY = 250 ft/min FOR 85% CAPTURE
FLOW RATE (ONE SIDE) = $(6 \text{ ft}^2) \times (6) \times (200 \text{ ft/min})$
= 7200 acfm
TEMPERATURE = 100°F
FLOW RATE = 6800 scfm
FLOW RATE (BOTH SIDES) = 13,600 scfm FOR 75% CAPTURE
= 17,000 scfm FOR 85% CAPTURE

^a IN ACTUAL PRACTICE, DUCT WOULD BE OF VARYING DIAMETER AND REQUIRE SOME DAMPER ARRANGEMENT TO DISTRIBUTE FLOW ALONG LENGTH OF BATTERY. THE COST ESTIMATE IS NOT OF SUFFICIENT DETAIL TO RECOGNIZE SUCH DETAILS. DUCT COST THEREFORE IS BASED ON A CONSTANT DIAMETER.

Figure 13. Door hood arrangement.

rate. Also included in the cost of this option are the costs described under Option 2.

Source 5--Topside

Control Options 2 and 3: Luting, Cleaning and Maintenance--

These two control options entail no capital costs and differ only in degree. Option 2 includes one additional man/shift for inspection and luting of lids and standpipes (in addition to the lidman and larry car operator). For Option 3, additional maintenance hours are added for grouting lid seats and standpipe bases and replacing faulty lids and caps. The cost estimate is based on an additional 1000 hours/year of labor plus the cost of supplies.

Control Option 4: New Lids and Seats--

The cost of this option includes one additional man/shift for inspection and luting of lids and standpipes plus an additional capital cost for new lids and seats at a rate of four lids per oven. This option is not applicable to preheated coal batteries.

Source 6--Combustion Stack (Old)

Control Option 2: Oven Patching--

The arbitrary definition of "old" combustion stack is based on a battery age of 15 years or older. This option involves the cost of 5900 maintenance hours per year for oven spraying and patching on a regular basis and one additional man around the clock for inspection and adjustments to the heating system. No capital costs are included.

Control Options 3 and 4: Dry ESP--

The control efficiencies of ESP's are related to cost in that higher efficiencies require larger collection areas, as shown below:²

<u>Efficiency, %</u>	<u>Plate area, ft²/1000 acfm of gas flow</u>
90.0	232
98.0	450

General ESP specifications are the same as those described under Source 2. The length of duct allowed is 150 ft; duct work is brick lined carbon steel. In the case of retrofits, it is assumed that the duct is tied into the existing flue and the existing stack is used. A booster fan with a total static pressure capacity of 6 in. H₂O is added. The flow rate for this source is calculated as:

$$\text{acfm} = 59 \times \text{tons coal/day}$$

with an exhaust temperature of 450°F. This flow is based on a stoichiometric calculation for coke oven gas with 100 percent excess air.³ Costs for flue gas conditioning are not included. A separate ESP system is provided for each battery although, in specific cases, it might be feasible to use a common ESP for adjacent batteries. Because of space limitations and problems with duct tie-in, the retrofit of an ESP to underfire stacks may not always be possible. The ability to shut the gas off to an existing battery long enough to accomplish tie-in without damaging oven refractories is a site-specific problem and is not addressed in this study.

Control Option 5: Baghouse--

This option is the same as Options 3 and 4 except that a fabric filter is substituted for the ESP. Temperature to the baghouse is limited by increasing the rate of air flow sufficiently to reduce the temperature from 450° to 275°F. The resulting flow rate is about 1.85 times that flow used for Options 3 and 4. The air-to-cloth ratio used is 3.0.

Source 7--Coke Handling

Control Option 2: Enclosures and Baghouse--

Specific details of this control system for emissions from coke handling will vary from plant to plant. The generalized

system used in the model consists of a plain carbon steel hood over the primary screen and five conveyor transfer point enclosures vented to a fabric filter having an air-to-cloth ratio of 6.0. Duct work is unlined, uninsulated, plain carbon steel of variable length depending on plant size. The average length is 75 ft. An exhaust fan with a static pressure rating of 8 in. H₂O is included. Flow rate is based on standard ventilation formulas for hoods and appropriate conveyor belt widths.² The control system is rated to accommodate the total coking capacity of a plant and is based on the assumption that a common coke-handling station serves all batteries. This is a safe assumption because only a few plants have widely separated groups of batteries and more than one handling and loadout station. The system does not include controls at the coke wharf.

Source 8--Coal Preheater

Control Options 2 and 4: Wet Scrubber--

The control options for this source are applicable only to those few batteries that have coal preheating systems. The two scrubber options are identical except in pressure drop requirement and concomitant fan capacity. Both scrubbers are stainless steel and contain corrugated-baffle mist eliminators. Both options include 100 ft of carbon steel duct work and a 100-ft stack. Flow rate (in acfm) is calculated according to the following formula:

$$\text{acfm} = 16,900 \times \left(\frac{\text{tons of coal/year}}{1,000,000} \right)$$

Control Options 3 and 5: Dry ESP--

These options are similar to the scrubber options except they call for ESP's rather than wet scrubbers. No data are available on the collection area required for coal preheater exhaust. Based on the assumption that preheater particulate emissions are similar to underfire stack emissions, the following values are used:²

<u>Efficiency, %</u>	<u>Plate area ft²/1000 acfm of gas flow</u>
95.0	324
99.0	538

Source 9--Coal Preparation

Control Option 2: Enclosures and Baghouse--

The sources of coal preparation emissions are the crushing, mixing, and transfer steps that occur between the initial coal-receiving station and the coal storage bunkers at the battery. The size of the control system is determined by the coal capacity of the plant. The system includes six conveyor transfer-point hoods vented to a fabric filter having an air-to-cloth ratio of 6.0. Duct length varies with plant size, but the average is 250 ft. The system also includes an exhaust fan with a static pressure capacity of 8 in. H₂O.

Source 10--Coal Storage Yard

Control Option 2: Spray Truck--

This option consists of a standard tractor trailer outfitted with a spray system and water storage tank. The estimated efficiency rating is 60 percent, but little data are available on dust control of coal storage piles. It is assumed that the truck would be used during periods of dry weather or windy conditions to suppress emissions at these most critical times. Operating costs include driver time, dust suppressant chemicals, and truck maintenance.

Control Option 3: Unloading Sprays and Spray Truck--

In addition to a spray truck, control Option 3 includes a spray system at the car dumper (or barge unloading station). The system is shown in Figure 14. Control efficiency should be increased from 60 to 75 percent with the application of option. This increase is based not only on the suppression of emissions during dumping, but also on the assumption that application of a dust suppressant provides more thorough and longer lasting control than water spraying alone.




Figure 14. Dust-supression spray system at car dumper.

Source 10--Coal Storage

Control Option 4: Coal Pile Sprays--

This control option (shown in Figure 15) is much more expensive than Options 2 and 3. It consists of permanently installed spray stanchions around the perimeter of the coal piles. These stanchions can be regulated at a central pump house. The lines are insulated and heated for winter operation. The size of the system is based on the amount of storage area required (based on a coal pile storage density of 0.28 ton/ft^2).² The control options for Source 10 are based on total plant capacity. Cost estimates are independent of battery characteristics.

Source 11--Pipeline Charging; Source 12--Redler Conveyor Charging; and Source 13--Hot Larry Car Charging

Control Option 2: Operation and Maintenance--

Information concerning controls for dry-coal charging systems (Sources 11, 12, and 13) is limited. These sources represent topside emissions from batteries charged with dry coal. Emission controls for such sources as doors and stacks are the same as those in conventional batteries. The control of emissions from hot larry car loading at the coal bunker is not considered because there is only one such battery and controls were included in its design.

A recent study of pipeline-charged batteries and Redler-charged batteries suggests such controls as additional steam aspiration, better seals at discharge ports, and slower charging rates.⁴ Because specific controls have not been selected, however, a capital cost cannot be determined. Cost estimates present only an annual operating cost based on the addition of one topside worker for inspection, luting, and minor maintenance of lids, standpipes, and the pipeline or conveyor.





Figure 15. Permanently installed spray stanchions around perimeter of coal piles.

Source 14 - Byproducts Plant

Control Option 2: Maintenance--

No control systems or procedures have yet been developed for the control of air emissions from byproduct plants. So that a working model recognizing this potential emission source could be provided, a control option consisting of 8760 hours/year of inspection and maintenance has been used. This includes valve packing, tank patching, and repair of pipe leaks, and should produce a control efficiency of 80 percent. These data are artificial data, however, and are used only to provide a complete dataset for the model.

Source 15--Combustion Stack (New)

Control Option 2: Oven Patching--

The designation of a battery stack as "old" or "new" is arbitrary and is used only to help explain broad variations in uncontrolled emissions. If site-specific data classifying each stack according to emission level were available, the designation of age as a parameter could be eliminated. Oven patching is the same as the control option described for old battery stacks, and it is the only control option used for new stacks because more extensive measures are not necessary.

Source 16--Quenching With Dirty Water

Control Option 2: Wooden Baffles--

This option is identical to that shown in Figure 11 (for Source 3, Option 2).

Control Option 3: Clean Water and the Use of Baffles--

The most definitive study available on the subject of emissions from quenching is by Edlund.⁵ The study addresses only particulate emissions. Figure 16 illustrates the relationship between emissions and dissolved solids in the quench water. Determining the total dissolved solids for each plant is beyond




Figure 16. Total particulate emissions from coke quenching.⁵

the scope of this project, but it is known that the composition of process water varies from plant to plant, as does the ratio of process water to quench water. The total amount of process water also varies. Table 7 (extracted from a preliminary summary of Effluent Guidelines 308 Questionnaire Data) shows these variations.⁶

The variations in quench water composition and the many different water treatment methods used require some assumptions for simplification:

1. Plants are designated as using either clean water or dirty water for quenching. The particulate emission rates are assumed to be 1.7 lb/ton of coal for clean water and 3.2 lb/ton of coal for dirty water.
2. The control scheme for treating dirty water (instead of using it for quenching) is an ammonia distillation column using caustic soda, a bio-oxidation plant with 3-day retention time, and activated carbon filters for polishing. An incinerator is included for incinerating the ammonia vapors, although these could be recovered and converted to useful byproduct. A flow sheet of this system is presented in Figure 17. It is assumed that water thus treated becomes acceptable effluent and that river water (i.e., clean water) is used for quenching.
3. The quantity of water to be treated is assumed to be 150 gal/ton of coke. (It should be noted that the control option of dry quenching must include the treatment of the dirty water that would otherwise have been used for quenching). The plant is sized for 50 percent excess capacity to enable recovery from outages.
4. When dry quenching and wastewater treatment are used in combination, it is assumed the steam generated by the dry quenching system is used to displace the steam requirement of the water treatment system.

Although these are significant assumptions that could affect the usefulness of the model, they are necessary to establish a starting point. More detailed data and additional control schemes can be factored into the model at some later date.

The other control options for quenching have already been described.

TABLE 7. COKE PLANTS USING PROCESS WATER FOR QUENCHING

Reference No.	Company	Location	Excess NH_3 liquor	Benzol plant	Final cooler	Barometric condenser	Desulfurizer	Other ^a	Total, gal/min	Process wastewater as % of total quench volume	Process wastewater in gal/ton
0012A	Alabama B.P.	Tarrant, Ala.			145				145	11.1	93
0112B	Bethlehem	Lackawanna, N.Y.			120	100		5	225	5.6	50
0112C(Rose)	Bethlehem	Johnstown, Pa.	18	14	5			5	42	12.9	60
0112C(Frank)	Bethlehem	Johnstown, Pa.	58	64	10			28	160	11.1	74
0112D	Bethlehem	Chesterton, Ind.			505	230	765	270	1770	53.9	493
0256E	Cyclops-FMP DET.	Portsmouth, Ohio	110						110	98.1	139
0280B	Philadelphia Coke	Philadelphia, Pa.			70				70	18.3	121
0384(#2)	Inland	E. Chicago, Ind.		295	125			10	430	16.7	100
0384(#3)	Inland	E. Chicago, Ind.						100	100	13.8	90
0432A	J&L	Aliquippa, Pa.	166	104	125	28		70	493	64.5	323
0448A	Kaiser	Fontana, Calif.	97	42	1				140	43.8	49
0464E	Koppers	Bessemer, Ala.			150				150	57.6	144
0584C	National	Granite City, Ill.	52		10				62	7.1	51
0584F(Main)	National	Weirton, W. Va.		32.5	29				61.5	22.1	39
0684A	Republic	Youngstown, Ohio	100	20	5			30	155	11.1	81
0684B	Republic	Warren, Ohio	50	50	10			20	130	16.3	146
0684F(1)	Republic	Cleveland, Ohio		209					209	62.1	93
0684F(2)	Republic	Cleveland, Ohio		56					56	28.3	42
0732A	Shenango	Neville Island, Pa.			80				80	16.2	73
0856F	USS	Fairless Mills, Pa.			2.5	5		100	107.5	10.3	52
0856N	USS	Lorain, Ohio	167	73		71			311	72.8	103
0860B	USS	Gary, Ind.	278		174				452	7.6	65
0464	USS	Geneva, Utah	90	75	100				265	70.7	106
0948A	YS&T	Campbell, Ohio	90	61	175				326	92.2	123

^a Includes tarry car scrubber wastewaters, shunt scrubbers, gas holder seals, preheater condensates, drains and seals on gas mains, and miscellaneous floor drains.




Figure 17. Coke plant wastewater treatment system.

REFERENCES FOR SECTION 5

1. Draft of Standards Support and Environmental Impact Statement. Volume I: Proposed National Emission Standards By-product Coke Oven Wet Coal Charging and Topside Leaks. U.S. EPA, Office of Air Quality Planning and Standards, Research Triangle Park, North Carolina. June 1978.
2. Development of Air Pollution Control Cost Functions for the Integrated Iron and Steel Industry. (Draft) Prepared by PEDCo Environmental, Inc., Cincinnati, Ohio, for the U.S. EPA, Office of Air Quality Planning and Standards, Washington, D.C., under Contract No. 68-01-4600. September 1978.
3. Midwest Research Institute. Study of Coke Oven Battery Stack Emission Control Technology Volume II, Control Methods. Prepared for Emission Standards and Engineering Division. U.S. EPA Office of Air Quality Planning and Standards, Research Triangle Park, North Carolina. EPA Contract 68-02-2609, Task 5. March 1979.
4. PEDCo Environmental, Inc. Control of Emissions from Dry Coal Charging at Coke Oven Batteries. Prepared for U.S. EPA, Office of Air Quality Planning and Standards, Research Triangle Park, North Carolina. EPA Contract 68-02-2603, Task 28. October 1978.
5. Edlund, Carl, A.H. Laube, and J. Jeffrey. Effects of Water Quality on Coke Quench Towers Particulate Emissions.
6. Personal communication with Mr. Bernie Bloom, DSSE, Washington, D.C. to W. Kemner, PEDCo. September 14, 1978.

SECTION 6

BATTERY DATA BASE (DATASET 3)

This dataset provides a record of the following for each battery in the United States:

- Company location code
- Date installed or date of last major rebuilding
- Number of ovens
- Capacity, tons of coke/year
- Type of charging used
- Oven height
- Number of collecting mains
- Control equipment in place

These data are used as input to the model to determine total coke industry emissions and the costs to control them.

The data base for coke oven batteries was assembled from a variety of documents, some of which provide conflicting information.¹⁻⁶ Most of the capacity data is from Reference 1. Where given data conflicted, PEDCo used its own expertise and knowledge of the industry to select data values for use in the model. For most of the foundry coke batteries, the main data source was Reference 6.

The scope of this project does not cover the development of a detailed data base for the U.S. coking industry, but it was necessary to prepare a reasonably accurate census to estimate control costs.

Input of the battery data is arranged so that it can be updated easily as additional data become available. Although some of the data are estimated and some may be outdated, most of

the industry is correctly represented in the census, and the aggregate costs calculated from the current data base should be representative.

Table 8 represents the data base provided to the model. Figure 18 shows the data coding form used to change or update the data base. Table 9 presents the plant ID codes used for the data coding form.

Total industry cost for a given control option and efficiency are calculated generally as:

$$\text{Industry cost} = \sum_{i=1}^n A \cdot X_i^B$$

where A and B = cost coefficients from the cost model

X_i = capacity (tons coke/year) for battery i

n = total number of batteries

Company names are used only for convenience in coding and keeping track of the data. This study is not source-specific, and company names will not appear in the model printout.

In this model, plant capacity has generally been used as the variable in determining control costs. Certain costs, however, are not strictly a function of capacity. Shed cost, for example, is a function of oven height and number of ovens. In the case of quench towers, on the other hand, cost is proportional to the size and number of towers. The slight inaccuracies introduced by the use of capacity as the cost variable, however, are not of major concern in this stage of model development. In the case of quench tower baffles, it is assumed that one quench tower can handle up to 2500 tons of coke per day. For coal yards, coal preparation, coke processing, and byproduct plants, the model calculates costs for entire plants rather than individual batteries (i.e., X_i becomes the total capacity of all batteries in a plant).

Certain other site-specific factors could affect cost. For example, the economy of scale gained by combining two or more adjacent batteries under a common control device to control

TABLE 8. COKE OVEN MODEL BATTERY DATA BASE

PAGE 1

PLANT NO	INST. DATE	NO. OVENS	COKE CAPACITY TONS/YR	CHARGING	HEIGHT (METERS)	PUSH CONTROL	QUENCH WATER	NO. COLL. MAINS
1	1966	55	220000.	LARRY CAR	3	NONE	CLEAN	1
1	1967	55	220000.	LARRY CAR	3	NONE	CLEAN	1
2	1938	15	80000.	LARRY CAR	4	NONE	CLEAN	1
2	1941	25	130000.	LARRY CAR	4	NONE	CLEAN	1
2	1947	25	130000.	LARRY CAR	4	NONE	CLEAN	1
2	1952	76	540000.	LARRY CAR	4	NONE	CLEAN	2
2	1961	45	240000.	LARRY CAR	4	NONE	CLEAN	1
2	1976	57	670000.	LARRY CAR	6	ENCLOSED CAR	CLEAN	2
2	1977	57	670000.	LARRY CAR	6	ENCLOSED CAR	CLEAN	2
4	1942	47	190000.	LARRY CAR	4	SHED	CLEAN	1
4	1953	15	190000.	LARRY CAR	4	SHED	CLEAN	1
5	1941	51	400000.	LARRY CAR	3	NONE	DIRTY	1
5	1942	51	400000.	LARRY CAR	3	NONE	DIRTY	1
5	1953	80	440000.	LARRY CAR	4	NONE	DIRTY	1
5	1976	80	890000.	LARRY CAR	6	OTHER	DIRTY	2
6	1915	63	260000.	LARRY CAR	3	NONE	CLEAN	1
6	1918	63	260000.	LARRY CAR	3	NONE	CLEAN	1
6	1920	63	260000.	LARRY CAR	3	NONE	CLEAN	1
6	1922	63	260000.	LARRY CAR	3	NONE	CLEAN	1
6	1929	63	250000.	LARRY CAR	3	NONE	CLEAN	1
6	1936	60	260000.	LARRY CAR	3	NONE	CLEAN	1
6	1941	61	310000.	LARRY CAR	4	NONE	CLEAN	1
6	1948	61	310000.	LARRY CAR	4	NONE	CLEAN	1
6	1950	65	350000.	LARRY CAR	4	NONE	CLEAN	2
6	1952	65	350000.	LARRY CAR	4	NONE	CLEAN	2
6	1955	65	350000.	LARRY CAR	4	NONE	CLEAN	2
6	1957	65	350000.	LARRY CAR	4	NONE	CLEAN	2
7	1941	76	450000.	LARRY CAR	4	NONE	DIRTY	1
7	1943	76	450000.	LARRY CAR	4	NONE	DIRTY	1
7	1943	57	300000.	LARRY CAR	4	NONE	DIRTY	1
7	1944	57	300000.	LARRY CAR	4	NONE	DIRTY	1
7	1952	76	495000.	LARRY CAR	4	NONE	DIRTY	1
7	1962	76	495000.	LARRY CAR	4	NONE	DIRTY	1
7	1970	76	900000.	LARRY CAR	6	NONE	DIRTY	1
8	1948	74	420000.	LARRY CAR	4	NONE	DIRTY	1
9	1969	82	1170000.	LARRY CAR	6	OTHER	DIRTY	1
9	1972	82	1270000.	LARRY CAR	6	OTHER	DIRTY	2
10	1960	31	150000.	LARRY CAR	4	NONE	DIRTY	2
10	1972	65	380000.	LARRY CAR	4	NONE	DIRTY	2
10	1974	47	290000.	LARRY CAR	4	NONE	DIRTY	2
11	1947	21	80000.	LARRY CAR	3	NONE	CLEAN	1

(continued)

TABLE 8 (continued)

PLANT NO	INST. DATE	NO. OVENS	CURR. CAPACITY TONS/YR	CHANGING	HEIGHT (METERS)	PUSH CONTROL	QUENCH WATER	NO. COLL. MAINS
11	1948	63	250000.	LARRY CAN	3	NONE	CLEAN	1
11	1952	29	120000.	LARRY CAN	3	NONE	CLEAN	1
12	1964	70	420000.	LARRY CAN	4	NONE	DIRTY	1
13	1962	61	460000.	LARRY CAN	4	OTHER	CLEAN	1
13	1963	61	460000.	LARRY CAN	4	OTHER	CLEAN	1
13	1963	25	200000.	LARRY CAN	4	OTHER	CLEAN	1
13	1964	45	340000.	LARRY CAN	4	OTHER	CLEAN	1
13	1972	13	100000.	LARRY CAN	4	OTHER	CLEAN	1
14	1949	49	440000.	LARRY CAN	4	OTHER	DIRTY	1
14	1953	27	240000.	LARRY CAN	4	OTHER	DIRTY	1
14	1961	61	280000.	LARRY CAN	4	OTHER	DIRTY	1
15	1957	70	430000.	LARRY CAN	4	OTHER	DIRTY	1
15	1957	78	480000.	LARRY CAN	4	OTHER	DIRTY	1
15	1970	85	1060000.	LARRY CAN	6	OTHER	DIRTY	1
16	1950	65	320000.	LARRY CAN	4	NONE	DIRTY	1
16	1956	87	460000.	LARRY CAN	4	NONE	DIRTY	1
16	1958	87	460000.	LARRY CAN	4	NONE	DIRTY	1
16	1958	87	460000.	LARRY CAN	4	NONE	DIRTY	1
16	1970	51	550000.	LARRY CAN	6	NONE	DIRTY	1
16	1974	56	910000.	PIPELINE	6	SHED	DIRTY	1
16	1978	69	1100000.	PIPELINE	6	ENCLOSED CAR	DIRTY	2
17	1953	57	300000.	LARRY CAN	4	OTHER	CLEAN	1
17	1956	50	320000.	LARRY CAN	4	NONE	CLEAN	1
17	1957	50	320000.	LARRY CAN	4	NONE	CLEAN	1
18	1953	79	470000.	LARRY CAN	4	NONE	CLEAN	1
18	1960	59	370000.	LARRY CAN	4	NONE	CLEAN	1
18	1961	59	370000.	LARRY CAN	4	NONE	CLEAN	1
18	1961	59	370000.	LARRY CAN	4	NONE	CLEAN	1
18	1961	59	370000.	LARRY CAN	4	NONE	CLEAN	1
19	1945	106	590000.	LARRY CAN	4	NONE	DIRTY	1
19	1948	106	590000.	LARRY CAN	4	NONE	DIRTY	1
19	1951	54	320000.	LARRY CAN	4	NONE	DIRTY	1
19	1976	56	1040000.	PIPELINE	6	SHED	DIRTY	1
21	1942	45	210000.	LARRY CAN	4	NONE	DIRTY	2
21	1942	45	210000.	LARRY CAN	4	NONE	DIRTY	2
21	1944	45	210000.	LARRY CAN	4	NONE	DIRTY	2
21	1953	45	210000.	LARRY CAN	4	NONE	DIRTY	2
21	1953	45	210000.	LARRY CAN	4	NONE	DIRTY	2
21	1960	45	210000.	LARRY CAN	4	NONE	DIRTY	2
21	1960	45	210000.	LARRY CAN	4	NONE	DIRTY	2
22	1944	54	220000.	LARRY CAN	4	NONE	CLEAN	1

(continued)

TABLE 8 (continued)

PLANT NO	INST. DATE	NO. OVENS	COKE CAPACITY TONS/YR	CHARGING	HEIGHT (METERS)	PUSH CONTROL	QUENCH WATER	NO. COLL. MAINS
22	1947	39	220000.	LARRY CAN	4	NONE	CLEAN	1
24	1944	40	340000.	LARRY CAN	4	NONE	DIRTY	1
24	1949	38	260000.	LARRY CAN	4	NONE	DIRTY	1
24	1950	40	340000.	LARRY CAN	4	NONE	DIRTY	1
24	1950	65	440000.	LARRY CAN	4	NONE	DIRTY	1
24	1960	59	400000.	LARRY CAN	4	NONE	DIRTY	2
25	1952	63	440000.	LARRY CAN	4	NONE	DIRTY	2
25	1952	63	440000.	LARRY CAN	4	NONE	DIRTY	2
25	1957	51	350000.	LARRY CAN	4	NONE	DIRTY	2
25	1958	51	350000.	LARRY CAN	4	NONE	DIRTY	2
25	1958	51	350000.	LARRY CAN	4	NONE	DIRTY	2
26	1976	51	350000.	LARRY CAN	4	NONE	DIRTY	2
27	1955	31	210000.	LARRY CAN	4	NONE	DIRTY	1
28	1943	75	500000.	LARRY CAN	4	SHED	CLEAN	1
29	1943	65	430000.	LARRY CAN	4	NONE	CLEAN	1
29	1952	65	390000.	LARRY CAN	4	NONE	CLEAN	1
29	1965	65	430000.	LARRY CAN	4	NONE	CLEAN	1
31	1951	87	550000.	LARRY CAN	4	NONE	DIRTY	2
31	1951	87	550000.	LARRY CAN	4	NONE	DIRTY	2
32	1924	61	270000.	LARRY CAN	4	NONE	CLEAN	2
32	1924	61	270000.	LARRY CAN	4	NONE	CLEAN	2
32	1924	61	270000.	LARRY CAN	4	NONE	CLEAN	2
32	1948	85	360000.	LARRY CAN	3	NONE	CLEAN	2
32	1950	61	270000.	LARRY CAN	4	NONE	CLEAN	2
32	1950	61	270000.	LARRY CAN	4	NONE	CLEAN	2
32	1954	64	340000.	LARRY CAN	4	NONE	CLEAN	2
32	1954	64	340000.	LARRY CAN	4	NONE	CLEAN	2
32	1954	64	340000.	LARRY CAN	4	NONE	CLEAN	2
32	1955	64	340000.	LARRY CAN	4	NONE	CLEAN	2
32	1955	64	340000.	LARRY CAN	4	NONE	CLEAN	2
32	1955	64	340000.	LARRY CAN	4	NONE	CLEAN	2
32	1957	64	340000.	LARRY CAN	4	NONE	CLEAN	2
32	1957	64	340000.	LARRY CAN	4	NONE	CLEAN	2
32	1958	64	340000.	LARRY CAN	4	NONE	CLEAN	2
32	1972	87	630000.	LARRY CAN	4	NONE	CLEAN	2
32	1973	87	640000.	LARRY CAN	4	SHED	CLEAN	2
32	1976	87	630000.	LARRY CAN	4	NONE	CLEAN	2
32	1977	87	630000.	LARRY CAN	4	NONE	CLEAN	2
33	1947	54	230000.	LARRY CAN	3	NONE	DIRTY	1
33	1947	54	230000.	LARRY CAN	3	NONE	DIRTY	1
33	1947	54	230000.	LARRY CAN	3	NONE	DIRTY	1

(continued)

TABLE 8 (continued)

PLANT NO	INST. DATE	NO. OVENS	CONE CAPACITY TONS/YR	CHARGING	HEIGHT (METERS)	PUSH CONTROL	QUENCH WATER	NO. COLL. MAINS
33	1955	59	230000.	LAHMY CAN	3	NONE	DIRTY	1
33	1955	59	230000.	LAHMY CAN	3	NONE	DIRTY	1
33	1956	59	230000.	LAHMY CAN	3	NONE	DIRTY	1
33	1957	59	230000.	LAHMY CAN	3	NONE	DIRTY	2
36	1949	77	320000.	LAHMY CAN	3	NONE	DIRTY	2
36	1951	77	320000.	LAHMY CAN	3	NONE	DIRTY	2
36	1951	77	320000.	LAHMY CAN	3	NONE	DIRTY	1
36	1954	77	320000.	LAHMY CAN	3	NONE	DIRTY	1
36	1954	77	320000.	LAHMY CAN	3	NONE	DIRTY	1
36	1970	85	900000.	LAHMY CAN	6	NONE	DIRTY	1
36	1975	57	930000.	HEDLER	6	ENCLOSED CAR	DIRTY	2
36	1976	57	930000.	HEDLER	6	ENCLOSED CAR	DIRTY	2
39	1952	77	400000.	LAHMY CAN	4	NONE	CLEAN	1
39	1952	77	400000.	LAHMY CAN	4	NONE	CLEAN	1
39	1958	63	400000.	LAHMY CAN	4	NONE	CLEAN	1
39	1978	57	900000.	HOT L.C.	6	OTHER	CLEAN	2
40	1950	63	320000.	LAHMY CAN	4	NONE	DIRTY	2
40	1950	63	320000.	LAHMY CAN	4	NONE	DIRTY	2
40	1950	63	320000.	LAHMY CAN	4	NONE	DIRTY	2
40	1950	63	320000.	LAHMY CAN	4	NONE	DIRTY	2
41	1947	53	350000.	LAHMY CAN	4	NONE	DIRTY	1
41	1947	53	350000.	LAHMY CAN	4	NONE	DIRTY	1
41	1951	61	400000.	LAHMY CAN	4	NONE	DIRTY	1
41	1954	41	270000.	LAHMY CAN	4	NONE	DIRTY	1
41	1956	41	270000.	LAHMY CAN	4	NONE	DIRTY	1
41	1973	67	1350000.	LAHMY CAN	6	OTHER	CLEAN	2
42	1948	53	250000.	LAHMY CAN	4	NONE	CLEAN	1
42	1952	63	300000.	LAHMY CAN	4	NONE	CLEAN	1
42	1953	47	180000.	LAHMY CAN	3	NONE	CLEAN	1
42	1955	47	180000.	LAHMY CAN	3	NONE	CLEAN	1
42	1964	51	190000.	LAHMY CAN	3	NONE	CLEAN	1
42	1976	79	800000.	LAHMY CAN	6	NONE	CLEAN	2
43	1942	74	550000.	LAHMY CAN	4	NONE	CLEAN	1
43	1956	19	140000.	LAHMY CAN	4	NONE	CLEAN	1
44	1968	45	370000.	LAHMY CAN	5	SHED	DIRTY	1
45	1954	76	460000.	LAHMY CAN	4	NONE	DIRTY	2
45	1955	76	460000.	LAHMY CAN	4	NONE	DIRTY	2
45	1958	76	460000.	LAHMY CAN	4	NONE	DIRTY	2
46	1952	75	460000.	LAHMY CAN	4	NONE	CLEAN	1
46	1956	75	460000.	LAHMY CAN	4	NONE	CLEAN	1
46	1961	67	535000.	LAHMY CAN	4	NONE	CLEAN	1

(continued)

TABLE 8 (continued)

PLANT NO	INST. DATE	NO. OVENS	CURE CAPACITY TONS/YR	CHANGING	HEIGHT (FEET/IN)	PUSH CONTROL	QUENCH WATER	NO. COLL. MAINS
88	1973	30	73000.	LANNY CAN	4	NONE	CLEAN	1
88	1973	30	73000.	LANNY CAN	4	NONE	CLEAN	1
89	1917	68	254000.	LANNY CAN	4	NONE	CLEAN	1
49	1941	76	548000.	LANNY CAN	6	NONE	CLEAN	1
49	1955	24	145000.	PIPELINE	4	NONE	CLEAN	1
50	1943	35	185000.	LANNY CAN	4	OTHER	CLEAN	1
50	1952	23	120000.	LANNY CAN	4	OTHER	CLEAN	1
65	1950	35	250000.	LANNY CAN	4	NONE	DIRTY	2
65	1952	35	250000.	LANNY CAN	4	NONE	DIRTY	2
65	1958	35	250000.	LANNY CAN	4	NONE	DIRTY	2
77	1918	24	58000.	LANNY CAN	3	NONE	DIRTY	1
77	1941	20	56000.	LANNY CAR	3	NONE	DIRTY	1
81	1962	60	328000.	LANNY CAN	4	NONE	CLEAN	1
85	1953	76	489000.	LANNY CAN	4	NONE	CLEAN	1
85	1967	70	797000.	LANNY CAN	5	NONE	CLEAN	1
86	1972	23	82000.	LANNY CAN	4	NONE	DIRTY	1
86	1972	23	82000.	LANNY CAN	4	NONE	DIRTY	1
87	1930	74	340000.	LANNY CAN	4	NONE	DIRTY	1
88	1968	70	674000.	PIPELINE	4	NONE	CLEAN	1
89	1926	40	119000.	LANNY CAN	4	NONE	CLEAN	1
89	1929	40	119000.	LANNY CAN	4	NONE	CLEAN	1
89	1941	41	121000.	LANNY CAN	4	NONE	CLEAN	1
89	1946	47	140000.	LANNY CAN	4	NONE	CLEAN	1
90	1974	40	117000.	LANNY CAN	3	OTHER	DIRTY	1
90	1974	60	175000.	LANNY CAN	3	OTHER	DIRTY	1
91	1951	51	316000.	LANNY CAN	4	NONE	CLEAN	1
91	1964	50	316000.	LANNY CAN	4	NONE	CLEAN	1
91	1967	50	316000.	LANNY CAN	4	NONE	CLEAN	1
92	1952	0	360000.	LANNY CAR	0	NONE	DIRTY	1
92	1961	93	266000.	LANNY CAN	3	SHED	CLEAN	1
93	1914	65	192000.	LANNY CAN	3	NONE	CLEAN	1
94	1958	20	48000.	LANNY CAR	3	NONE	CLEAN	1
94	1958	40	88000.	LANNY CAN	3	NONE	CLEAN	1
95	1920	17	48000.	LANNY CAN	4	NONE	DIRTY	1

(continued)

TABLE 8 (continued)

PLANT NO	INST. DATE	NO. UVENS	CURE CAPACITY TONS/YR	CHARGING	HEIGHT (METERS)	PUSH CONTROL	QUENCH WATER	NO. COLL. MAINS
95	1920	32	150000.	LANNY CAN	4	NONE	DIRTY	1
95	1925	25	79000.	LANNY CAN	4	NONE	DIRTY	1
95	1944	20	95000.	LANNY CAN	4	NONE	DIRTY	1
95	1944	30	102000.	LANNY CAN	4	NONE	DIRTY	1
95	1952	30	120000.	LANNY CAN	4	NONE	DIRTY	1
95	1964	30	153000.	LANNY CAN	4	NONE	DIRTY	1
96	1956	60	234000.	LANNY CAN	3	NONE	DIRTY	1
97	1920	60	232000.	LANNY CAN	4	NONE	CLEAN	1
97	1920	60	232000.	LANNY CAN	4	NONE	CLEAN	1
97	1950	30	116000.	LANNY CAN	4	NONE	CLEAN	1
97	1955	30	116000.	LANNY CAN	4	NONE	CLEAN	1
97	1957	60	232000.	LANNY CAN	4	NONE	CLEAN	1
98	1951	50	287000.	LANNY CAN	3	NONE	DIRTY	1
98	1952	57	282000.	LANNY CAN	3	NONE	DIRTY	1
99	1941	25	110000.	LANNY CAN	4	NONE	DIRTY	1
99	1951	29	128000.	LANNY CAN	4	NONE	DIRTY	1
99	1952	25	64000.	LANNY CAN	3	NONE	DIRTY	1
99	1968	78	500000.	PIPELINE	6	NONE	DIRTY	1

TOTAL PLANTS 59
 TOTAL BATTERIES 216
 TOTAL UVENS 12221.
 TOTAL CAPACITY 76623.5+03

1 2 3 4 5 6 7 9 11 13

8 10 12

1 NUMBER OF BATTERIES IN A PLANT

2 TYPE OF BATTERY: 1 = EXISTING; 2 = NEW HYPOTHETICAL

3 PLANT IDENTIFICATION NUMBER

4 DATE OF INSTALLATION OR LAST MAJOR REHABILITATION

5 NUMBER OF OVENS IN BATTERY

6 COKE CAPACITY, tons/yr

7 CHARGING METHOD: 1 = LARRY CAR; 2 = PIPELINE; 3 = REDLER; 4 = HOT LARRY CAR

8 OVEN HEIGHT, m

9 NUMBER OF COLLECTING MAINS: 1 OR 2

10 BASELINE CONTROL LEVEL FOR SOURCE 1

11 EXISTING CONTROL LEVEL FOR SOURCE 1

12 BASELINE CONTROL LEVEL FOR SOURCE 2

13 EXISTING CONTROL LEVEL FOR SOURCE 2

REMAINDER OF COLUMNS SET IN SIMILAR FASHION FOR SOURCES 3 THROUGH 20

Figure 18. Battery data card format.

TABLE 9. PLANT ID CODES

Plant ID ^a	Company
01	Keystone Coke, Conshohocken, Pa.
02	Armco, Middletown, Ohio
04	Armco, Houston, Tex.
05	Bethlehem, Bethlehem, Pa.
06	Bethlehem, Sparrows Point, Md.
07	Bethlehem, Lackawanna, N.Y.
08	Bethlehem, Johnstown, Pa.
09	Bethlehem, Burns Harbor, Ind.
10	CFI, Pueblo, Colo.
11	Crucible, Midland, Pa.
12	Empire Detroit, Portsmouth, Ohio
13	Ford, Rouge Works, Detroit, Mich.
14	Granite City, Granite City, Ill.
15	Great Lakes Steel, Detroit, Mich.
16	Inland, East Chicago, Ind.
17	Interlake, South Chicago, Ill.
18	J & L, Pittsburgh, Pa.
19	J & L, Aliquippa, Pa.
21	Kaiser, Fontana, Calif.
22	Lonestar Steel, Texas
24	Republic, Mahoning Valley Dist., Ohio
25	Republic, Cleveland, Ohio
27	Republic, Central Alloy Dist., Ohio
28	Republic, South Chicago, Ill.
29	Republic, Gulfsteel, Ala.
31	USS, Fairless Hills, Pa.
32	USS, Homestead Clairton, Pa.
33	USS, Lorain, Cuyahoga, Ohio
36	USS, Gary, Ind.
39	USS, Fairfield, Ala.
40	USS, Geneva, Utah

(continued)

TABLE 9 (continued)

Plant ID ^a	Company
41	Weirton Steel, Weirton, W. Va.
42	Wheeling Pitt, Steubenville, Ohio
43	Wheeling Pitt, Monesson, Pa.
44	Wisconsin, South Chicago, Ill.
45	YST, Campbell, Youngstown, Ohio
46	YST, East Chicago, Ind.
48	Indiana Gas, Terre Haute, Ind.
49	Allied, Ironton, Ohio
50	Koppers, Erie, Pa.
65	Shenango, Neville Island, Pa.
77	Chatanooga Coke & Chem., Tenn.
81	Allied, Buffalo, N.Y.
85	Allied, Ashland, Ky.
86	Diamond Shamrock, Painesville, Ohio
87	Eastern Fuel Assoc. Philadelphia, Pa.
88	Allied Chemical, Detroit, Mich.
89	Citizens Gas, Indianapolis, Ind.
90	Milwaukee Solvay, Milwaukee, Wis.
91	Donnar Hanna, Buffalo, N.Y.
92	Missouri Coke, St. Louis, Mo.
93	Koppers, St. Paul, Minn.
94	Empire Coke, Holt, Ala.
95	Koppers, Bessemer, Ala.
96	Sharon, Fairmont, W. Va.
97	Jim Walter, Birmingham, Ala.
98	USS Duluth, Minn.
99	ABC, Tarrant, Ala.

^aPlant ID numbers are not sequential.

battery stacks has not been considered. Also, the number of spare hot cars required in a multibattery plant is less in proportion to capacity than the number at an isolated plant having one battery. Such site-specifics are not considered in this project.

New Versus Existing Batteries

To evaluate projected growth (or decline) in the industry, the user may add battery data cards corresponding to the projected growth, or delete the battery cards for projected retirements.

New battery cards must be filled out even though the data may be speculative. It is not sufficient just to enter simply 10 percent growth; the user must decide, for example, that there will be 10 new batteries by 1985, that they will be 60-oven batteries 6 meters high and that they will be equipped with some specific controls. Only if specific plans for a given plant are known is the plant ID entered. In the case of retirements the user simply removes the battery card from the card deck.

The primary distinction between "new" and "existing" in the model is the use of new or retrofit cost functions.

Existing Installed Equipment

Columns 21 to 60 of the battery data card (Figure 18) are 20 two-digit fields corresponding to the twenty sources considered. Only 16 are now used. The code numbers to be entered in these fields correspond to the control option codes. The first column of each two digit field contains the desired baseline code and the second column contains the existing control code.

Because the control level (control efficiency and exact control equipment) of a given plant may not be the same as those designated in the options used, the user must be careful to select the code for the control option that most closely corresponds to the existing equipment or control program.

In the computer program, the code is used for one of two purposes:

1. To correct total industry cost (or total cost for any given industry subset) by eliminating the cost of a control option for those plants where the option is already in use.
2. To allow the use of a control baseline (e.g., SIP) whereby only costs above this baseline are considered. The same baseline can be used for every battery. A single card for all batteries can be used to avoid having to enter the same codes on each of the more than 200 battery cards. This card is designated as Control Card 3, described in Section 2.

As an example of the first purpose, assume Battery 1 has already installed a new larry car for stage charging and has good stage charging practice. The card for this battery would then contain a Code 3 in the charging columns (Column 22). Consequently, in the program to determine the cost of charging controls for this plant, the only costs calculated will be those for controls achieving control levels greater than level 3. "Tear-out" costs (i.e., for removal of existing controls) are not considered in the present model.

A more complicated example arises when the existing controls achieve an efficiency close to that described in the options but are represented by different hardware. If a battery already has a shed and scrubber, for example, it is probably better to consider this comparable in achieving a given level of control rather than equivalent to the specific hardware configuration. For this reason, the control options are ordered according to degree of efficiency. This permits the user to select the option that achieves the highest level he considers appropriate. The computer will disregard the cost of all options equal to or less than the option selected for the given battery.

The approach in the second purpose is similar, but the concept is different. In this case the user establishes a baseline of control below which control costs are not considered whether installed or not. For example, if the baseline for

charging control is modified larry cars for stage charging, no costs will be calculated for control options achieving control levels below those of larry car modification. The battery card in this case would contain a Code 2 in the charging columns (Column 21). In the extreme, if the highest control option were selected as the baseline for every source, no costs would be calculated. If the user wanted costs for inspection only, they could be obtained by making a computer run with "uncontrolled" as the baseline.

REFERENCES FOR SECTION 6

1. Industry Response to Section 308 Effluent Guidelines Questionnaires 1976-1977.
2. Pictrucha, W.E., and R.L. Deily. Steel Industry in Brief: Databook USA, 1977. Institute for Iron and Steel Industries, Green Brook, New Jersey.
3. Iron & Steel Works Directory of the United States and Canada. American Iron and Steel Institute. 1977.
4. Air and Water Compliance Summary for the Iron and Steel Industry. U.S. Environmental Protection Agency, Office of Enforcement. October 20, 1977.
5. World Steel Industry Data Handbook, Vol. 1. The United States, 33 Magazine 1978, McGraw Hill, 1221 Avenue of the Americas, New York, New York 10020.
6. Kulujian, N.J. By-Product Coke Battery Compliance Evaluation. Prepared for U.S. Environmental Protection Agency, DSSE by PEDCo Environmental, Inc. June 1975. EPA Contract No. 68-02-1321, Task 13.

SECTION 7

MODEL FORMULATION

The first step in the model is the calculation of total industry control costs. In the discussion of this calculation, mathematical nomenclature has been defined as follows:

i = the emission source ($i = 1 \dots I$)

j = the pollutant ($j = 1 \dots J$)

k = the control technology ($k = 1 \dots K$)

n = the specific battery ($n = 1 \dots N$)

E = the annual emissions, in tons/year

C = the annualized cost (or capital cost)

e_{ijk} = the control efficiency

X_n = the capacity of battery n in tons coke/year

U_{ij} = the uncontrolled emission factor in lbs/ton coal

Note that for some sources such as coke handling, X_n actually represents capacity for all batteries in a given plant.

Then C_{ijkn} represents a specific dollar value calculated from the general cost function:

$$C_{ijkn} = A_{ijk} X_n^{B_{ijk}}$$

where A = y intercept, B = slope

Note that $C_{i1kn} = C_{i2kn} = C_{i4kn}$,

i.e., the cost of a specific control system does not vary by pollutant.

$$\text{Similarly, } E_{ijkn} = \left[\frac{(100 - e_{ijk})}{100} (U_{ij}) (X_n / .7) \right] / 2000$$

but, $E_{i1kn} \neq E_{i2kn} \neq E_{i3kn} \neq E_{i4kn}$

The C and E matrices are calculated from the input data-sets. Note that $k = 1$ will represent no additional control. Therefore, $C_{ij1n} = \text{zero}$ by definition and

$$E_{ij1n} = [(U_{ij})(X_n/.7)] \div 2000$$

The total emission restriction (Mode 2) is entered as an overall percent efficiency, represented by R_j . This will be converted to ρ_j , an annual quantity, by the equation:

$$\rho_j = (1 - \frac{R_j}{100}) (\sum_{n=1}^N \sum_{i=1}^I E_{ijn}, k = 1)$$

The total cost restriction (Mode 3) will be entered as a total dollar amount, T.

Finally, note that not all i exist for every n. Therefore, the C and E matrices are not full.

The next step is to compress the total C and E matrices to a total industry basis, i.e., eliminate the n dimension. Let C' and E' represent the total industry:

$$C'_{ijk} = \sum_{n=1}^N C_{ijn}$$

Again noting that $C'_{i1k} = C'_{i2k} = C'_{i3k} = C'_{i4k}$

Similarly,

$$E'_{ijk} = \sum_{n=1}^N E_{ijn}$$

and $E'_{ijk} \neq E'_{i2k} \neq E'_{i3k} = E'_{i4k}$

Furthermore, E' can be treated as four separate matrices, E'_{ik} for $j = 1$, E'_{ik} for $j = 2$, etc.

The data is now reduced to two simple matrices:

C_{ik} and E_{ik} for each j

To find the optimum combination of controls, consider Mode 2, the restriction being total emissions, ρ_j , and the objective being to find lowest cost. Another matrix, Y , must now be introduced. The values of Y will be either one or zero. A one will indicate that a control option, k , is selected and a zero will indicate that the control option is not selected. The Y matrix is a mathematical device to solve the optimization and has no significance from an engineering standpoint. For example,

$$\text{let } Y_{ik} = Y_{14} = 1$$

this means Control Option 4 on Emission Source 1 is part of the optimum solution.

If this is so, then by definition, all other Y 's for source 1 are zero:

$$Y_{11} = Y_{12} = Y_{13} = Y_{15} = Y_{16} = Y_{1k} = 0$$

That is, a source can only be controlled by one option at a time.

The statement of the problem in matrix form is therefore:

$$\begin{array}{ll} \text{Minimize } \sum CY & \text{for a given } j \\ \text{subject to } \sum Y = 1 & \text{for all } i \\ \text{and } \sum EY \leq \rho & \text{for a given } j \\ \text{and } Y \geq 0 & \text{for all } i \end{array}$$

In expanded form:

$$\begin{array}{l} \text{minimize } C_{11}Y_{11} + C_{12}Y_{12} + \dots + C_{1k}Y_{1k} \\ \quad + C_{21}Y_{21} + C_{22}Y_{22} + \dots + C_{2k}Y_{2k} \\ \quad + \dots + C_{ik}Y_{ik} \\ \text{subject to } Y_{11} + Y_{12} + Y_{13} + \dots + Y_{1k} = 1 \\ \quad Y_{21} + Y_{22} + Y_{23} + \dots + Y_{2k} = 1, \text{ etc. for each } i \\ \text{and: } E_{11}Y_{11} + E_{12}Y_{12} + \dots + E_{1k}Y_{1k} \\ \quad + E_{21}Y_{21} + E_{22}Y_{22} + \dots + E_{2k}Y_{2k} \\ \quad + \dots + E_{ik}Y_{ik} \leq \rho_j \\ \text{and } Y_{ik} \geq 0 \text{ for every } i \text{ and } k \end{array}$$

The optimal solution to this problem will be determination of the Y matrix. The Y matrix in turn will define a k value for each i (i.e., a control option for each emission source that will result in the overall minimum cost for meeting a total emission restriction). Note that any given k may equal 1, i.e., no control. In general, the program will select those alternatives which reduce emissions the most and cost the least.

After the optimum solution is found, the Y matrix will be superimposed onto the E matrices for the other pollutants to determine the emissions of the pollutants that were not restricted. To the optimum totals the program will add the costs and emissions for those sources previously excluded from the optimization (by using the No. 2 cards described in Section 1) to get total industry costs and emissions.

The statement for Mode 3 is very similar:

$$\begin{array}{ll} \text{Minimize} & \Sigma EY \\ \text{subject to:} & \Sigma CY \leq T \\ \text{and} & \Sigma Y = 1 \\ \text{and} & Y \geq 0 \end{array}$$

The same approach as described above is used in this case also. Operation of the model in Modes 2 and 3 is identical regardless of whether annualized cost or capital cost is the subject of optimization.

The greatest value of the model is its ability to supply rapid answers to "what if" questions. The model has great flexibility, and its user can easily examine its sensitivity to variations in the emission factors and control costs by simply changing the input data.

Controls for any given emission source can be fixed at a predetermined level and the source can thus be removed from the optimization procedure. The battery data base can be set up to represent all batteries or any subset of batteries. For example, furnace coke producers can be separated from foundry coke producers.

SECTION 8

RESULTS

The function of the model is to calculate emissions and emission control costs and to select a set of controls that will meet a given emission restriction at the lowest cost. Conceptually, this is as if the "bubble concept" were applied to all the coke plants in the United States. Section 2 describes the many variations of the basic scheme.

An example best illustrates the logic of the model. The data base for this example consists of the 216 coke oven batteries presented in Section 6, the uncontrolled emission factors presented in Table 1, and the control options and their efficiencies presented in Table 2. Annualized and capital cost functions associated with the control options are shown in Appendix A.

Figure 19 is a graphic presentation of the capital cost functions for the three control options applicable to Source 1, wet coal charging. These values are based on tons of coke capacity for a 60-oven battery. An increase in the number of ovens would increase the cost because certain elements of the capital cost (e.g., steam lines and number of standpipes) are directly proportional to the number of ovens. Every cost function represented in Appendix A could be plotted as shown on Figure 19.

Figure 20 shows the annualized cost per pound of particulate removed for the same three options. The spacing of the curves is related to both the relative costs of the options and the relative efficiencies. Although Option 3 is more costly than Option 2, the curves are very close because the efficiency of

Option 3 is 99 percent compared with only 80 percent for Option 2. The 99.5 percent efficiency of Option 4, on the other hand, represents an improvement of only 0.5 percent over Option 3, but the cost is much higher. Each option for each source could be analyzed in a similar manner.

Table 10 presents the capital and annualized cost matrix calculated for the present data base. Table 11 presents the uncontrolled emissions matrix. These matrices and the appropriate control efficiencies could be used to generate curves like those in Figures 19 and 20 for each source.

The function of the optimization model is to analyze all such curves and find the lowest cost combinations. In this section, the examples deal with minimizing annualized cost, but the approach is identical for capital cost. Table 12 is the model output for a case of no control on any source. This provides a convenient frame of reference for uncontrolled emission quantities. The table shows that pushing is the largest single source of uncontrolled particulate emissions, although the total of quenching (with clean water and with dirty water) is slightly larger. Charging is by far the largest single source of both BSO and benzene emissions.

Table 13 is the model output to meet a restriction calling for an overall particulate control at least 95 percent efficiency, which requires the highest possible control level on every source except dry coal charging and the byproducts plant. The latter two are excluded from the solution by the model because their contributions to particulate emissions are very low; in fact, particulate emissions from the byproducts plant are zero. Total annualized costs for the industry are \$1,396,000,000 and total capital costs (retrofit) are \$2,887,000,000. It should be noted that the model seeks to minimize annualized costs in the examples presented in this section. In this example the costs do not take into account any control that may already exist, as indicated by the baseline notation in the tables. That is, the costs are theoretical costs based on no controls on any battery.

TABLE 10. TOTAL CAPITAL AND ANNUALIZED COSTS FOR CONTROL OPTIONS
(in millions of dollars)

Source/control option	Total capital cost	Total annualized cost
Wet coal charging		
Modified larry car	91	124
New larry car	304	165
New larry car and second main	649	254
Coke pushing		
Controlled coking	0	993
Shed + ESP with 95% eff.	905	295
Shed + scrubber with 95% eff.	1277	489
Enclosed hot car	1164	314
Shed + ESP with 99% eff.	973	307
Shed + scrubber with 99% eff.	1330	538
Quenching, clean water		
Conventional baffles	7	2.4
Diverted flow baffles	53	14
Dry quenching	424	111
Doors		
Cleaning and maintenance	0	174
High pressure water cleaning	90	189
Hoods + scrubber with 95% eff.	386	464
Hoods + scrubber with 98% eff.	439	481
Topside		
Luting and cleaning	0	57
Luting, cleaning, and maintenance	0	109
New lids	22	63
Combustion stack, old		
Oven patching	0	89
Dry ESP with 90% eff.	411	153
Dry ESP with 98% eff.	544	176
Fabric filter with 98% eff.	323	112

(continued)

TABLE 10 (continued)

Source/control option	Total capital cost	Total annualized cost
Coke handling		
Enclosures + fabric filter	40	17
Coal preheater		
Scrubber with 95% eff.	11.7	9
Dry ESP with 95% eff.	10.5	5
Scrubber with 98% eff.	12.1	10
Dry ESP with 99% eff.	12.7	6
Coal preparation		
Enclosures + fabric filter	29	13
Coal storage		
Water spray truck	17	8
Unloading sprays + spray truck	30	11
Coal pile sprays	148	69
Pipeline charging		
Operating and maintenance program	0	3
Redler charging		
Operating and maintenance program	0	0.7
Hot larry car charging		
Operating and maintenance program	0	0.3
Byproduct plant		
Maintenance program	0	17
Combustion stack, new		
Oven patching	0	20
Quenching, dirty water		
Conventional baffles	9	3.5
Clean water + conventional baffles	273	168
Clean water + diverted flow baffles	341	184
Dry quenching	300	251

TABLE 11. TOTAL UNCONTROLLED EMISSIONS
(tons/year)

Emission source	Pollutant			
	Particulates	BSO	BaP	Benzene
Wet coal charging	49,600	54,600	100	24,800
Coke pushing	109,500	4,400	2	330
Quenching with clean water	41,000	41	3	1
Doors	21,900	27,400	164	1,100
Topside	10,900	13,700	55	274
Combustion stack, old	43,800	225	2	0
Coke handling	54,700	0	0	0
Coal preheater	35,900	5,400	2	71
Coal preparation	27,400	0	0	0
Coal storage	3,200	0	0	0
Pipeline charging	50	60	a	25
Redler charging	13	8	a	7
Hot larry car charging	11	12	a	5
Byproducts plant	0	16,400	0	10,900
Combustion stack, new	2,200	10	a	0
Quenching with dirty water	97,900	196	10	8

^aLess than one ton per year.




Figure 19. Capital cost of control options for wet coal charging.




Figure 20. Cost per pound of particulate removal for control options for wet coal charging.

TABLE 12. MODEL OUTPUT FOR BASELINE OF NO CONTROL

COKE OVEN OPTIMIZATION

OBJECTIVE: MINIMUM ANNUALIZED COST RESTRICTION: .0% OVERALL EFFICIENCY POLLUTANT: BSO
 BASELINE: ASSUMING NO SIP OR EXISTING CONTROLS

BASE YEAR 1979

SOURCE	CONTROLLED EMISSIONS (LBS/TON COAL)				CONTROLLED EMISSIONS (TONS/YEAR)				CONTROL SCHEME	CONTROLLED COST (MILLION DOLLARS)	
	TSP	BSO	BAP	BEN	TSP	BSO	BAP	BEN		CAPITAL	ANNUALIZED
LARRY CAR CHARGING	01.00	1.1000	.0020	.5000	49635	54599	99	24817	UNCONTROLLED	.0	.0
COKE PUSHING	02.00	.0800	.0000	.0060	109463	4378	2	328	UNCONTROLLED	.0	.0
QUENCHING - CLEAN WATER	01.70	.0017	.0001	.0000	41049	41	3	0	UNCONTROLLED	.0	.0
DOORS	0 .40	.5000	.0030	.0200	21892	27365	164	1094	UNCONTROLLED	.0	.0
TOPSIDE	0 .20	.2500	.0010	.0050	10946	13682	54	273	UNCONTROLLED	.0	.0
COMBUSTION STACK - OLD	01.30	.0060	.0001	.0000	48840	225	2	0	UNCONTROLLED	.0	.0
COKE HANDLING	01.00	.0000	.0000	.0000	54731	0	0	0	UNCONTROLLED	.0	.0
COAL PREHEATER	07.05	1.0500	.0004	.0140	35925	5350	1	71	UNCONTROLLED	.0	.0
COAL PREPARATION	0 .50	.0000	.0000	.0000	27365	0	0	0	UNCONTROLLED	.0	.0
COAL STORAGE YARD	0 .15	.0000	.0000	.0000	8209	0	0	0	UNCONTROLLED	.0	.0
PIPELINE CHARGING	0 .02	.0190	.0000	.0080	49	59	0	24	UNCONTROLLED	.0	.0
REDLER CHARGING	0 .01	.0060	.0000	.0049	13	7	0	6	UNCONTROLLED	.0	.0
HOT LARRY CAR CHARGING	0 .02	.0190	.0000	.0080	10	12	0	5	UNCONTROLLED	.0	.0
BY-PRODUCTS PLANT	0 .00	.3000	.0000	.2000	0	16419	0	10946	UNCONTROLLED	.0	.0
COMBUSTION STACK - NEW	0 .13	.0006	.0000	.0000	2231	10	0	0	UNCONTROLLED	.0	.0
QUENCHING - DIRTY WATER	03.20	.0064	.0003	.0003	97871	195	9	7	UNCONTROLLED	.0	.0
TOTAL UNC.	9.3	2.235	.006	.686	508238	122349	337	37577			
EXISTING CONTROL					388402	76172	254	17656		297.5	197.1
EXISTING EFFICIENCY					23.6	37.7	24.6	53.0			
BASELINE CONTROL					508237	122348	337	37577		.0	.0
BASELINE EFFICIENCY					.0	.0	.0	.0			
TOTAL CONTROLLED					508238	122349	337	37577		.0	.0
PERCENT CONTROLLED					.0	.0	.0	.0			

EXISTING		NEW	
TOTAL BATTERIES	216	TOTAL BATTERIES	0
TOTAL OVENS	12221	TOTAL OVENS	0
TOTAL CAPACITY	109494267 TONS COAL	TOTAL CAPACITY	0 TONS COAL
	76623000 TONS COKE		0 TONS COKE
* NOT IN OPTIMIZATION			

TABLE 13. MODEL OUTPUT FOR 95 PERCENT OVERALL PARTICULATE REDUCTION

COKE OVEN OPTIMIZATION

OBJECTIVE: MINIMUM ANNUALIZED COST RESTRICTION: 95.0% OVERALL EFFICIENCY POLLUTANT:TSP
 BASELINE: ASSUMING NO SIP OR EXISTING CONTROLS

BASE YEAR 1979

SOURCE	CONTROLLED EMISSIONS (LBS/TON COAL)				CONTROLLED EMISSIONS (TONS/YEAR)				CONTROL SCHEME	CONTROLLED COST (MILLION DOLLARS)	
	TSP	BSO	BAP	BEN	TSP	BSO	BAP	BEN		CAPITAL	ANNUALIZED
LARRY CAR CHARGING	.01	.0055	.0000	.0025	248	272	0	124	NEW CAR, SECOND MAIN	649.3	253.6
COKE PUSHING	# .22	.0440	.0000	.0033	11931	2408	1	180	ENCLOSED HOT CAR	.0	.0
QUENCHING - CLEAN WATER	.03	.0000	.0000	.0000	820	0	0	0	DRY QUENCHING	423.9	111.4
DOORS	.03	.0810	.0005	.0056	1466	4433	26	306	DOOR HOOD, SCRUBBER 98%	439.1	481.1
TOPSIDE	.01	.0075	.0000	.0002	328	410	1	8	NEW LIDS & CASTINGS	21.8	63.0
COMBUSTION STACK - OLD	.03	.0030	.0000	.0000	976	112	1	0	BAGHOUSE, 98%	323.2	111.6
COKE HANDLING	.11	.0000	.0000	.0000	5965	0	0	0	ENCLOSURES + BAGHOUSE	40.0	16.5
COAL PREHEATER	.07	.5250	.0002	.0070	359	2675	0	35	ESP 99%	12.7	5.8
COAL PREPARATION	.02	.0000	.0000	.0000	820	0	0	0	ENCLOSURE + BAGHOUSE - 99%	29.1	12.7
COAL STORAGE YARD	.02	.0000	.0000	.0000	820	0	0	0	COAL PILE SPRAYS	147.9	68.6
PIPELINE CHARGING	.02	.0190	.0000	.0080	49	59	0	24	UNCONTROLLED	.0	.0
REDLER CHARGING	.01	.0060	.0000	.0049	13	7	0	6	UNCONTROLLED	.0	.0
NOT LARRY CAR CHARGING	.02	.0190	.0000	.0080	10	12	0	5	UNCONTROLLED	.0	.0
BY-PRODUCTS PLANT	.00	.3000	.0000	.2000	0	16419	0	10946	UNCONTROLLED	.0	.0
COMBUSTION STACK - NEW	.03	.0001	.0000	.0000	446	2	0	0	OVEN PATCHING	.0	20.1
QUENCHING - DIRTY WATER	.03	.0001	.0000	.0000	978	1	0	0	DRY QUENCHING	799.5	251.4
TOTAL UNC.	9.3	2.235	.006	.686	508238	122349	337	37577			
EXISTING CONTROL					388402	76172	254	17656		297.5	197.1
EXISTING EFFICIENCY					23.6	37.7	24.6	53.0			
BASLINE CONTROL					508237	122348	337	37577		.0	.0
BASLINE EFFICIENCY					.0	.0	.0	.0			
TOTAL CONTROLLED					25238	26816	32	11638		2886.6	1395.8
PERCENT CONTROLLED					95.0	78.1	90.5	69.0			

EXISTING		NEW	
TOTAL BATTERIES	216	TOTAL OVENS	12221
TOTAL CAPACITY	109494267 TONS COAL	TOTAL CAPACITY	0 TONS COAL
	76623000 TONS COKE		0 TONS COKE

NOT IN OPTIMIZATION

When dry quenching is selected as the control for quenching emissions, no cost is assigned to the enclosed car option for pushing emissions because the equivalent of an enclosed car is included in the cost of the dry quenching system. For small batteries (less than 100,000 tons of coke per year) further examination of the cost functions for dry quenching is required because they are not necessarily applicable in this small size range. If a shed is selected as the control option for pushing emissions, the cost of door hoods is reduced to the extent that they are not used on the coke-side doors. Otherwise there would be a double accounting of the control cost for coke-side doors.

Cost is overstated when the options selected include a scrubber and wastewater recirculation. This occurs because each battery is treated independently. An example would be a plant with four batteries, on which both door hoods and a wastewater recirculation system are provided for each battery. In such a scheme it is likely that one common water system could be installed to serve all four batteries for less than the cost of four separate water systems. Similarly, if a shed and scrubber were installed for control of pushing emissions and coke-side door emissions and a hood system was installed for pusher-side doors, the water system (and perhaps the scrubber itself) could be designed to handle both sources.

Although the existing model could be modified to address these issues, specific assumptions would be required.

Tables 14, 15, and 16 represent the model output for the same kind of problem except that the control efficiency restrictions are set at 80, 85, and 90 percent, respectively. In these cases, certain sources can use lower-level control schemes, and the total cost is decreased. Figure 21 shows total cost as a function of efficiency, based on the results shown on Tables 13 through 16.

TABLE 14. MODEL OUTPUT FOR 80 PERCENT OVERALL PARTICULATE REDUCTION

COKE OVEN OPTIMIZATION

OBJECTIVE: MINIMUM ANNUALIZED COST RESTRICTION: 80.0% OVERALL EFFICIENCY POLLUTANT: TSP BASE YEAR 1979
 BASELINE: ASSUMING NO SIP OR EXISTING CONTROLS

SOURCE	CONTROLLED EMISSIONS (LBS/TON COAL)				CONTROLLED EMISSIONS (TONS/YEAR)				CONTROL SCHEME	CONTROLLED COST (MILLION DOLLARS)	
	TSP	BSO	BAP	BEN	TSP	BSO	BAP	BEN		CAPITAL	ANNUALIZED
LARRY CAR CHARGING	.20	.2200	.0004	.1000	9927	10919	19	4963	MODIFIED CAR, STEAM, BOOT	90.6	124.0
COKE PUSHING	.22	.0440	.0000	.0033	11931	2408	1	180	SHED + ESP 99%	972.9	307.0
QUENCHING - CLEAN WATER	.17	.0002	.0000	.0000	4104	4	0	0	DIVERTED FLOW BAFFLES	58.0	14.0
DOORS	.40	.5000	.0030	.0200	21892	27365	164	1094	UNCONTROLLED	.0	.0
TOPSIDE	.20	.2500	.0010	.0050	10946	13682	54	273	UNCONTROLLED	.0	.0
COMBUSTION STACK - OLD	.03	.0030	.0000	.0000	976	112	1	0	BAGHOUSE, 98%	323.2	111.6
COKE HANDLING	.11	.0000	.0000	.0000	5965	0	0	0	ENCLOSURES + BAGHOUSE	40.0	16.5
COAL PREHEATER	.07	.5250	.0002	.0070	359	2675	0	35	ESP 99%	12.7	5.8
COAL PREPARATION	.02	.0000	.0000	.0000	820	0	0	0	ENCLOSURE + BAGHOUSE - 99%	29.1	12.7
COAL STORAGE YARD	.04	.0000	.0000	.0000	2052	0	0	0	UNLOAD SPRAYS + WATER TRUCK	29.6	11.4
PIPELINE CHARGING	.02	.0190	.0000	.0080	49	59	0	24	UNCONTROLLED	.0	.0
REDLER CHARGING	.01	.0060	.0000	.0049	13	7	0	6	UNCONTROLLED	.0	.0
HOT LARRY CAR CHARGING	.02	.0190	.0000	.0080	10	12	0	5	UNCONTROLLED	.0	.0
BY-PRODUCTS PLANT	.00	.3000	.0000	.2000	0	16419	0	10946	UNCONTROLLED	.0	.0
COMBUSTION STACK - NEW	.13	.0006	.0000	.0000	2231	10	0	0	UNCONTROLLED	.0	.0
QUENCHING - DIRTY WATER	.96	.0019	.0001	.0003	29361	58	2	7	BAFFLES	9.3	3.5
TOTAL UMC.	9.3	2.235	.006	.686	508238	122349	337	37577			
EXISTING CONTROL					388402	76172	254	17656		297.5	197.1
EXISTING EFFICIENCY					23.6	37.7	24.6	53.0			
BASELINE CONTROL					508237	122348	337	37577		.0	.0
BASELINE EFFICIENCY					.0	.0	.0	.0			
TOTAL CONTROLLED					100644	73737	245	17539		1565.3	606.5
PERCENT CONTROLLED					80.2	39.7	27.3	53.3			

EXISTING		NEW	
TOTAL BATTERIES	216	TOTAL OVENS	12221
TOTAL CAPACITY	109494267 TONS COAL	TOTAL CAPACITY	0 TONS COAL
	76623000 TONS COKE		0 TONS COKE

NOT IN OPTIMIZATION

TABLE 15. MODEL OUTPUT FOR 85 PERCENT OVERALL PARTICULATE REDUCTION

COKE OVEN OPTIMIZATION

OBJECTIVE: MINIMUM ANNUALIZED COST RESTRICTION: 85.0% OVERALL EFFICIENCY POLLUTANT:TSP
 BASELINE: ASSUMING NO SIP OR EXISTING CONTROLS

BASE YEAR 1979

SOURCE	CONTROLLED EMISSIONS (LBS/TON COAL)				CONTROLLED EMISSIONS (TONS/YEAR)				CONTROL SCHEME	CONTROLLED COST (MILLION DOLLARS)	
	TSP	B50	BAP	BEN	TSP	B50	BAP	BEN		CAPITAL	ANNUALIZED
LARRY CAR CHARGING	.20	.2200	.0004	.1000	9927	10919	19	4963	MODIFIED CAR, STEAM, BOOT	90.6	124.0
COKE PUSHING	.22	.0440	.0000	.0033	11931	2408	1	180	SHED + ESP 99%	972.9	307.0
QUENCHING - CLEAN WATER	.17	.0002	.0000	.0000	4104	4	0	0	DIVERTED FLOW BAFFLES	58.0	14.0
DOORS	.40	.5000	.0030	.0200	21892	27365	164	1094	UNCONTROLLED	.0	.0
TOPSIDE	.20	.2500	.0010	.0050	10946	13682	54	273	UNCONTROLLED	.0	.0
COMBUSTION STACK - OLD	.03	.0030	.0000	.0000	976	112	1	0	BAGHOUSE, 98%	323.2	111.6
COKE HANDLING	.11	.0000	.0000	.0000	5965	0	0	0	ENCLOSURES + BAGHOUSE	40.0	16.5
COAL PREHEATER	.07	.5250	.0002	.0070	359	2675	0	35	ESP 99%	12.7	5.8
COAL PREPARATION	.02	.0000	.0000	.0000	820	0	0	0	ENCLOSURE + BAGHOUSE - 99%	29.1	12.7
COAL STORAGE YARD	.04	.0000	.0000	.0000	2052	0	0	0	UNLOAD SPRAYS + WATER TRUCK	29.6	11.4
PIPELINE CHARGING	.02	.0190	.0000	.0080	49	59	0	24	UNCONTROLLED	.0	.0
REDLER CHARGING	.01	.0060	.0000	.0049	13	7	0	6	UNCONTROLLED	.0	.0
HOT LARRY CAR CHARGING	.02	.0190	.0000	.0080	10	12	0	5	UNCONTROLLED	.0	.0
BY-PRODUCTS PLANT	.00	.3000	.0000	.2000	0	16419	0	10946	UNCONTROLLED	.0	.0
COMBUSTION STACK - NEW	.13	.0006	.0000	.0000	2231	10	0	0	UNCONTROLLED	.0	.0
QUENCHING - DIRTY WATER	.16	.0010	.0000	.0001	4893	29	1	1	CLEAN WATER, DIV. FLOW BAFFLES	341.1	183.6
TOTAL UNC.	9.3	2.235	.006	.686	508238	122349	337	37577			
EXISTING CONTROL					388402	76172	254	17656		297.5	197.1
EXISTING EFFICIENCY					23.6	37.7	24.6	53.0			
BASELINE CONTROL					508237	122348	337	37577		.0	.0
BASELINE EFFICIENCY					.0	.0	.0	.0			
TOTAL CONTROLLED					76176	73707	244	17533		1897.1	786.6
PERCENT CONTROLLED					85.0	39.8	27.6	53.3			

EXISTING		NEW	
TOTAL BATTERIES	216	TOTAL BATTERIES	0
TOTAL OVENS	12221	TOTAL OVENS	0
TOTAL CAPACITY	109494267 TONS COAL	TOTAL CAPACITY	0 TONS COAL
	76623000 TONS COKE		0 TONS COKE

■ NOT IN OPTIMIZATION

TABLE 16. MODEL OUTPUT FOR 90 PERCENT OVERALL PARTICULATE REDUCTION

COKE OVEN OPTIMIZATION

OBJECTIVE: MINIMUM ANNUALIZED COST RESTRICTION: 90.0% OVERALL EFFICIENCY POLLUTANT:TSP
 BASELINE: ASSUMING NO SIP OR EXISTING CONTROLS

BASE YEAR 1979

SOURCE	CONTROLLED EMISSIONS (LBS/TON COAL)				CONTROLLED EMISSIONS (TONS/YEAR)				CONTROL SCHEME	CONTROLLED COST (MILLION DOLLARS)	
	TSP	B50	BAP	BEN	TSP	B50	BAP	BEN		CAPITAL	ANNUALIZED
LARRY CAR CHARGING	.01	.0110	.0000	.0050	496	545	0	248	NEW CAR, STEAM, BOOT	303.6	164.7
COKE PUSHING	.23	.0408	.0000	.0031	12366	2234	1	167	ENCLOSED HOT CAR	429.2	135.4
QUENCHING - CLEAN WATER	.17	.0002	.0000	.0000	4104	4	0	0	DIVERTED FLOW BAFFLES	58.0	14.0
DOORS	.40	.5000	.0030	.0200	21892	27365	164	1094	UNCONTROLLED	.0	.0
TOPSIDE	.01	.0075	.0000	.0002	328	410	1	8	NEW LIDS & CASTINGS	21.8	63.0
COMBUSTION STACK - OLD	.03	.0030	.0000	.0000	976	112	1	0	BAGHOUSE, 98%	323.2	111.6
COKE HANDLING	.11	.0000	.0000	.0000	5965	0	0	0	ENCLOSURES + BAGHOUSE	40.0	16.5
COAL PREHEATER	.07	.5250	.0002	.0070	359	2675	0	35	ESP 99%	12.7	5.8
COAL PREPARATION	.02	.0000	.0000	.0000	820	0	0	0	ENCLOSURE + BAGHOUSE - 99%	29.1	12.7
COAL STORAGE YARD	.04	.0000	.0000	.0000	2052	0	0	0	UNLOAD SPRAYS + WATER TRUCK	29.6	11.4
PIPELINE CHARGING	.02	.0190	.0000	.0080	49	59	0	24	UNCONTROLLED	.0	.0
REDLER CHARGING	.01	.0060	.0000	.0049	13	7	0	6	UNCONTROLLED	.0	.0
HOT LARRY CAR CHARGING	.02	.0190	.0000	.0080	10	12	0	5	UNCONTROLLED	.0	.0
BY-PRODUCTS PLANT	.00	.3000	.0000	.2000	0	16419	0	10946	UNCONTROLLED	.0	.0
COMBUSTION STACK - NEW	.03	.0001	.0000	.0000	446	2	0	0	OVEN PATCHING	.0	20.1
QUENCHING - DIRTY WATER	.03	.0001	.0000	.0000	978	1	0	0	DRY QUENCHING	799.5	251.4
TOTAL UNC.	9.3	2.235	.006	.686	508238	122349	337	37577			
EXISTING CONTROL					388402	76172	254	17656		297.5	197.1
EXISTING EFFICIENCY					23.6	37.7	24.6	53.0			
BASLINE CONTROL					508237	122348	337	37577		.0	.0
BASLINE EFFICIENCY					.0	.0	.0	.0			
TOTAL CONTROLLED					50862	49851	170	12538		2046.8	806.6
PERCENT CONTROLLED					90.0	59.3	49.6	66.6			

EXISTING		NEW	
TOTAL BATTERIES	216	TOTAL OVENS	12221
TOTAL CAPACITY	109494267 TONS COAL	TOTAL BATTERIES	0
	76623000 TONS COKE	TOTAL OVENS	0

NOT IN OPTIMIZATION




Figure 21. Total annualized cost as a function of overall efficiency.

Clearly these examples represent only a few of the cases that can be evaluated. Furthermore, the results for other pollutants and emission factors, control cost functions, and battery subsets have not been examined. These are among the many possibilities that remain for the users of the model.

APPENDIX A

EXAMPLE COMPUTER PRINTOUTS FOR COST FUNCTIONS PRESENTLY INCLUDED IN MODEL

Complete and detailed printouts for each control option have been provided to the Project Officer as data supplements for the three plant sizes. Table A-1 is a summary of all the cost functions. This appendix also includes summary pages for each control option for the large plant. Each set of pages is arranged in ascending order according to source number and control option number (as indicated at the top of every page). The first page contains general information and the second page describes the control system. The third page summarizes the capital cost (if applicable) and the fourth page summarizes the annualized cost.

TABLE A-1. COST FUNCTION COEFFICIENTS FOR CONTROL OPTIONS^a
(cost in fourth quarter 1978 dollars)

Source control option	Basis for X value	New Installation				Retrofit Installation			
		Capital cost		Annualized cost coefficient		Capital cost coefficient		Annualized cost coefficient	
		A	B	A	B	A	B	A	B
Wet coal charging	Battery								
Modified larry car		290,539.2	0.0250	227,751.9	0.0762	319,187.0	0.0251	230,194.8	0.0761
New larry car		2,784.7	0.4882	68,022.8	0.1934	3,064.5	0.4882	63,015.2	0.2014
New larry car & second main		326,894.4	0.1935	341,620.2	0.1117	293,877.1	0.2046	320,512.5	0.1178
Coke pushing	Battery								
Controlled coking		0	0	25.7	0.9593	0	0	25.7	0.9593
Shed and ESP, 95%		17,498.8	0.4228	3,177.5	0.4737	22,052.2	0.4141	3,659.2	0.4670
Shed and scrubber, 95%		25,028.5	0.4223	7,752.5	0.4439	30,128.9	0.4166	8,519.4	0.4403
Enclosed hot car		423,778.8	0.1938	70,214.2	0.2354	466,163.3	0.1938	76,212.7	0.2332
Shed and ESP, 99%		14,710.7	0.4422	2,907.6	0.4836	18,452.7	0.4337	3,345.8	0.4771
Shed and scrubber, 99%		23,357.7	0.4310	5,243.8	0.4823	28,061.2	0.4254	5,825.5	0.4776
Quenching, clean water	Plant								
Conventional baffles		1.7	0.8412	0.4	0.8750	2.1	0.8412	0.4	0.8707
Diverted flow baffles		82.6	0.7119	9.5	0.7714	107.5	0.7119	12.7	0.7621
Dry quenching ^b		771.8	0.7065	87.6	0.7683	848.9	0.7065	96.8	0.7651
Doors	Battery								
Cleaning and maintenance		0	0	804,801.2	0	0	0	804,801.2	0
High pressure water cleaning		414,499.8	0	876,701.5	0	414,499.8	0	876,701.5	0
Door hoods, scrubber, 95%		18,558.0	0.3453	954,615.0	0.0624	21,613.0	0.3487	880,426.2	0.0708
Door hoods, scrubber, 98%		21,562.1	0.3441	879,789.9	0.0715	25,298.2	0.3465	812,304.1	0.0800
Door hoods, scrubber, 95% one side		13,431.0	0.3409	106,371.0	0.0431	15,000.0	0.3443	998,158.0	0.0496
Door hoods, scrubber, 98% one side		11,682.0	0.3620	863,212.0	0.0614	13,625.0	0.3638	808,202.0	0.0682
Topside	Battery								
Luting and cleaning		0	0	264,900.1	0	0	0	264,900.1	0
Luting, cleaning, and maintenance		0	0	503,300.4	0	0	0	503,300.4	0
New lids, luting, and cleaning		81,100.0	0	300,799.9	0	105,399.9	0	304,299.8	0
Combustion stack, old	Battery								
Oven patching		0	0	503,300.4	0	0	0	503,300.4	0
Dry ESP, 90%		2,534.3	0.5283	5,373.4	0.3994	2,976.1	0.5306	5,061.8	0.4101
Dry ESP, 98%		2,609.3	0.5484	3,989.6	0.4333	3,085.1	0.5500	3,800.7	0.4440
Fabric filter, 98%		418.3	0.6518	551.5	0.5543	515.9	0.6504	546.8	0.5616

(continued)

TABLE A-1 (continued)

Source control option	Basis for X value	New Installation				Retrofit Installation			
		Capital cost		Annualized cost coefficient		Capital cost		Annualized cost coefficient	
		A	B	A	B	A	B	A	B
Coke handling Enclosures and fabric filters ...	Plant	196.0	0.5789	111.2	0.5612	207.7	0.5823	112.9	0.5629
Coal preheater	Battery								
Scrubber, 95%		2,083.4	0.4691	131,626.3	0.1515	2,244.9	0.4704	123,839.7	0.1574
Dry ESP, 95%		1,869.5	0.4688	52,969.1	0.1785	2,007.5	0.4702	49,467.6	0.1855
Scrubber, 98%		2,051.3	0.4724	102,188.8	0.1719	2,211.2	0.4737	96,494.4	0.1755
Dry ESP, 99%		1,944.9	0.4799	41,863.8	0.2006	2,095.3	0.4811	38,805.0	0.2084
Coal preparation Enclosures and fabric filter	Plant	682.6	0.4686	2,893.9	0.3108	693.2	0.4746	2,710.6	0.3180
Coal storage	Plant								
Water spray truck		159,450.1	0.0341	76,052.9	0.0428	179,919.7	0.0336	79,334.9	0.0422
Water spray truck and unloading sprays		314,191.3	0.0245	101,422.0	0.0443	372,093.4	0.0231	110,347.1	0.0424
Coal pile sprays		42.5	0.7780	13.4	0.8097	53.3	0.7695	14.8	0.8055
Pipeline charging Operating and maintenance program	Battery	0	0	539,800.0	0	0	0	593,800.0	0
Redler charging Operating and maintenance program	Battery	0	0	358,100.3	0	0	0	358,100.3	0
Hot larry car charging Operating and maintenance program	Battery	0	0	264,900.1	0	0	0	264,900.1	0
Byproducts plant Maintenance program	Plant	0	0	300,000.0	0	0	0	300,000.0	0
Combustion stack, new oven patching	Battery	0	0	503,300.4	0	0	0	503,300.4	0
Quenching, dirty water	Plant								
Conventional baffles		1.7	0.8412	0.3	0.8944	2.1	0.8412	0.4	0.8888
Conventional baffles and clean water			0.4319	348.3	0.6848	21,656.8	0.4328	436.3	0.6724
Diverted flow baffles and clean water		11,753.1	0.4765	352.8	0.6894	13,599.2	0.4802	440.6	0.6779
Dry quenching ^c				838.3	0.6503			967.5	0.6448

^a Cost = Ax^B ; X = tons of coke/year.

^b Annualized cost does not account for potential steam credit.

^c Annualized cost does not account for potential steam credit except for steam used in water treatment.

INDEX TO COST SHEETS

<u>Source</u>	<u>Option</u>	<u>Page</u>
Larry car charging	2	A-5
	3	A-9
	4	A-13
Coke pushing	2	A-17
	3	A-20
	4	A-24
	5	A-28
	6	A-32
	7	A-36
Quenching, clean water	2	A-40
	3	A-44
	4	A-48
Doors	2	A-52
	3	A-55
	4	A-59
	5	A-63
	6	A-67
	7	A-71
Topside	2	A-75
	3	A-78
	4	A-81
Combustion stack, old	2	A-85
	3	A-88
	4	A-92
	5	A-96
Coke handling	2	A-100
Coal preheater	2	A-104
	3	A-108
	4	A-112
	5	A-116
Coal preparation	2	A-120
Coal storage	2	A-124
	3	A-128
	4	A-132
Pipeline charging	2	A-136
Redler charging	2	A-139
Hot larry car charging	2	A-142
Byproducts plant	2	A-145
Combustion stack, new	2	A-148
Quenching, dirty water	2	A-151
	3	A-154
	4	A-158
	5	A-162

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 501. LARRY CAR CHARGING	COKE	2

CAPACITY: .708 MILLION TONS/YEAR

PARTICULATE

LOAD IN:	1.000000 LBS/TON COAL	
ALLOWABLE:	.200000 LBS/TON COAL	EFFICIENCY: 80.0%
	23.10 LBS/HR	

BSO

LOAD IN:	1.100000 LBS/TON COAL	
ALLOWABLE:	.220000 LBS/TON COAL	EFFICIENCY: 80.0%
	25.41 LBS/HR	

BAP

LOAD IN:	.002000 LBS/TON COAL	
ALLOWABLE:	.000400 LBS/TON COAL	EFFICIENCY: 80.0%
	.05 LBS/HR	

BENZENE

LOAD IN:	.500000 LBS/TON COAL	
ALLOWABLE:	.100000 LBS/TON COAL	EFFICIENCY: 80.0%
	11.55 LBS/HR	

DUST COLLECTED PER DAY: 1.1 TONS(DRY)

TEMP OUT OF PROCESS: 180. F

EXHAUST TEMPERATURE: 180. F

SCFM FLOW: 0. AT 70. F

ACFM FLOW: 0. AT 180. F

L/G RATIO: .0

PROCESS WATER FLOW: 0. GPM

COOLING WATER FLOW: 0. GPM

SUSPENDED SOLIDS OUT: 0. MG/L %SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 501. LARRY CAR CHARGING	COKE	2

CONTROL SYSTEM CONFIGURATION:

LARRY CAR
LEVELING BAR SMOKE SEAL
STEAM SUPPLY

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH		SPARE FAN CAPACITY:	0.2
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1011967.		

CAPITAL COST:

	UNITS	OPTION
PPSES: 501. LARRY CAR CHARGING	COKE	2

CAPACITY: .708 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST.)

CATEGORY	COST IN DOLLARS	
*** DIRECT COST ***		
EQUIPMENT OR MATERIAL	110500.	
INSTRUMENTATION	0.	
PIPING	15000.	
ELECTRICAL	7500.	
FOUNDATIONS	0.	
STRUCTURAL	45700.	
SITE WORK	0.	
INSULATION	18100.	
PROTECTIVE COATING	400.	
BUILDINGS	0.	
EQUIPMENT/MATERIAL LABOR	37000.	
DIRECT COST SUBTOTAL		234200.
*** INDIRECT COST ***		
FIELD OVERHEAD	30400.	
CONTRACTORS FEE	17900.	
ENGINEERING	21600.	
FREIGHT	2400.	
OFFSITE WORK	0.	
TAXES	8200.	
SHAKEDOWN	4600.	
SPARES	5600.	
CONTINGENCY	65200.	
INDIRECT COST SUBTOTAL		155900.
INTEREST DURING INSTALLATION		16700.
TOTAL COST		406800.
TOTAL COST WITH RETROFIT		447500.

OPERATING COST:

PPSES: 501. LARRY CAR CHARGING		UNITS	OPTION
		COKE	2
CAPACITY:		.708 MILLION TONS/YEAR	
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	17001. MLBS/YR	\$ 4.0920/MLBS	69600.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	5200. HRS/YR	\$14.34/HR	74600. (C)
SUPERVISION	1040. HRS/YR	\$17.20/HR	17900. (D)
MATERIALS			36700. (E)
SUPPLIES			19400. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			374000.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			49700.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			152200.
TOTAL OPERATING COST			575900.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.81
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			1422.72
OPERATING COST AS PERCENT OF CAPITAL COST			128.7
INSTALLATION TIME IN WEEKS			52.
ESTIMATED LIFE OF SYSTEM IN YEARS			25.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (11.02% OF TOTAL CAPITAL)			49300.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			9000.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			9000.
TOTAL ANNUALIZED COST - RETROFIT			643200.
- NEW			636900.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 501. LARRY CAR CHARGING	COKE	3
CAPACITY: .708 MILLION TONS/YEAR		
PARTICULATE		
LOAD IN: 1.000000 LBS/TON COAL		
ALLOWABLE: .010000 LBS/TON COAL	EFFICIENCY: 99.0%	
1.16 LBS/HR		
BSO		
LOAD IN: 1.100000 LBS/TON COAL		
ALLOWABLE: .011000 LBS/TON COAL	EFFICIENCY: 99.0%	
1.27 LBS/HR		
BAP		
LOAD IN: .002000 LBS/TON COAL		
ALLOWABLE: .000020 LBS/TON COAL	EFFICIENCY: 99.0%	
.00 LBS/HR		
BENZENE		
LOAD IN: .500000 LBS/TON COAL		
ALLOWABLE: .005000 LBS/TON COAL	EFFICIENCY: 99.0%	
.58 LBS/HR		
DUST COLLECTED PER DAY: 1.4 TONS(DRY)		
TEMP OUT OF PROCESS: 180. F		
EXHAUST TEMPERATURE: 180. F		
SCFM FLOW: 0. AT 70. F		
ACFM FLOW: 0. AT 180. F		
L/G RATIO: .0		
PROCESS WATER FLOW: 0. GPM		
COOLING WATER FLOW: 0. GPM		
SUSPENDED SOLIDS OUT: 0. MG/L	%SOLIDS:	.0

CAPITAL COST:

PPSES: 501.	LARRY CAR CHARGING	UNITS COKE	OPTION 3
-------------	--------------------	---------------	-------------

CAPACITY: .708 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4Q78 COST)

CATEGORY	COST IN DOLLARS
----------	-----------------

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	1222600.	
INSTRUMENTATION	0.	
PIPING	0.	
ELECTRICAL	0.	
FOUNDATIONS	0.	
STRUCTURAL	0.	
SITE WORK	0.	
INSULATION	17000.	
PROTECTIVE COATING	0.	
BUILDINGS	0.	
EQUIPMENT/MATERIAL LABOR	117700.	
DIRECT COST SUBTOTAL		1357300.

*** INDIRECT COST ***

FIELD OVERHEAD	39100.	
CONTRACTORS FEE	19100.	
ENGINEERING	14500.	
FREIGHT	18000.	
OFFSITE WORK	0.	
TAXES	57000.	
SHAKEDOWN	6100.	
SPARES	57100.	
CONTINGENCY	297200.	
INDIRECT COST SUBTOTAL		508100.

INTEREST DURING INSTALLATION	136600.
------------------------------	---------

TOTAL COST	2002000.
------------	----------

TOTAL COST WITH RETROFIT	2202200.
--------------------------	----------

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 501. LARRY CAR CHARGING	COKE	3

CONTROL SYSTEM CONFIGURATION:

LARRY CAR
LEVELING BAR SMOKE SEAL
STEAM SUPPLY

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.2	
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1011967.		

OPERATING COST:

		UNITS	OPTION
PPSES: 501.	LARRY CAR CHARGING	COKE	3
CAPACITY:	.708 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	17001. MLBS/YR	\$ 4.0920/MLBS	69600.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	6200. HRS/YR	\$14.34/HR	88900. (C)
SUPERVISION	1240. HRS/YR	\$17.20/HR	21300. (D)
MATERIALS			43900. (E)
SUPPLIES			23100. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			402600.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			53200.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			166500.
TOTAL OPERATING COST			622300.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.88
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			1242.31
OPERATING COST AS PERCENT OF CAPITAL COST			28.3
INSTALLATION TIME IN WEEKS			80.
ESTIMATED LIFE OF SYSTEM IN YEARS			25.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (11.02% OF TOTAL CAPITAL)			242600.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			44000.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			44000.
TOTAL ANNUALIZED COST - RETROFIT			952900.
- NEW			922900.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 501. LARRY CAR CHARGING	COKE	4
CAPACITY:	.708 MILLION TONS/YEAR	
PARTICULATE		
LOAD IN: 1.000000 LBS/TON COAL		
ALLOWABLE: .005000 LBS/TON COAL	EFFICIENCY: 99.5%	
.58 LBS/HR		
BSO		
LOAD IN: 1.100000 LBS/TON COAL		
ALLOWABLE: .005500 LBS/TON COAL	EFFICIENCY: 99.5%	
.64 LBS/HR		
BAP		
LOAD IN: .002000 LBS/TON COAL		
ALLOWABLE: .000010 LBS/TON COAL	EFFICIENCY: 99.5%	
.00 LBS/HR		
BENZENE		
LOAD IN: .500000 LBS/TON COAL		
ALLOWABLE: .002500 LBS/TON COAL	EFFICIENCY: 99.5%	
.29 LBS/HR		
DUST COLLECTED PER DAY:	1.4 TONS(DRY)	
TEMP OUT OF PROCESS:	180. F	
EXHAUST TEMPERATURE:	180. F	
SCFM FLOW: 0. AT 70. F		
ACFM FLOW: 0. AT 180. F		
L/G RATIO:	.0	
PROCESS WATER FLOW:	0. GPM	
COOLING WATER FLOW:	0. GPM	
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 501. LARRY CAR CHARGING	CUKE	4

CONTROL SYSTEM CONFIGURATION:

LARRY CAR
LEVELING BAR SMOKE SEAL
STEAM SUPPLY
SECOND COLLECTING MAIN

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH		SPARE FAN CAPACITY:	0.2
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1011967.		

CAPITAL COST:

		UNITS	OPTION
PPSES: 501.	LARRY CAR CHARGING	COKE	4

CAPACITY: .708 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST

CATEGORY	COST IN DOLLARS	
*** DIRECT COST ***		
EQUIPMENT OR MATERIAL	2410600.	
INSTRUMENTATION	0.	
PIPING	0.	
ELECTRICAL	0.	
FOUNDATIONS	0.	
STRUCTURAL	0.	
SITE WORK	0.	
INSULATION	17000.	
PROTECTIVE COATING	0.	
BUILDINGS	0.	
EQUIPMENT/MATERIAL LABOR	117700.	
DIRECT COST SUBTOTAL		2545300.
*** INDIRECT COST ***		
FIELD OVERHEAD	158300.	
CONTRACTORS FEE	138300.	
ENGINEERING	252900.	
FREIGHT	77600.	
OFFSITE WORK	19900.	
TAXES	116600.	
SHAKEDOWN	125300.	
SPARES	116700.	
CONTINGENCY	690500.	
INDIRECT COST SUBTOTAL		1696100.
INTEREST DURING INSTALLATION		196000.
TOTAL COST		4437400.
TOTAL COST WITH RETROFIT		4637600.

OPERATING COST:

		UNITS	OPTION
PPSES:	501. LARRY CAR CHARGING	COKE	4
CAPACITY:	.708 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	17001. MLBS/YR	\$ 4.0920/MLBS	69600.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	11600. HRS/YR	\$14.34/HR	166400. (C)
SUPERVISION	2320. HRS/YR	\$17.20/HR	39900. (D)
MATERIALS			82600. (E)
SUPPLIES			43300. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			557600.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			72400.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			244000.
TOTAL OPERATING COST			874000.
OPERATING COST IN DOLLARS PER TON PRODUCTION			1.23
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			1736.01
OPERATING COST AS PERCENT OF CAPITAL COST			18.6
INSTALLATION TIME IN WEEKS			80.
ESTIMATED LIFE OF SYSTEM IN YEARS			25.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (11.02% OF TOTAL CAPITAL)			510900.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			92800.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			92800.
TOTAL ANNUALIZED COST - RETROFIT			1570500.
- NEW			1540300.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 502. COKE PUSHING	COKE	2
CAPACITY:	.708 MILLION TONS/YEAR	
PARTICULATE		
LOAD IN:	2.000000 LBS/TON COAL	
ALLOWABLE:	.800000 LBS/TON COAL	EFFICIENCY: 60.0%
	92.42 LBS/HR	
BSO		
LOAD IN:	.080000 LBS/TON COAL	
ALLOWABLE:	.032000 LBS/TON COAL	EFFICIENCY: 60.0%
	3.70 LBS/HR	
BAP		
LOAD IN:	.000040 LBS/TON COAL	
ALLOWABLE:	.000016 LBS/TON COAL	EFFICIENCY: 60.0%
	.00 LBS/HR	
BENZENE		
LOAD IN:	.006000 LBS/TON COAL	
ALLOWABLE:	.002400 LBS/TON COAL	EFFICIENCY: 60.0%
	.28 LBS/HR	
DUST COLLECTED PER DAY:	1.7 TONS(DRY)	
TEMP OUT OF PROCESS:	300. F	
EXHAUST TEMPERATURE:	300. F	
SCFM FLOW:	0. AT 70. F	
ACFM FLOW:	0. AT 300. F	
L/G RATIO:	.0	
PROCESS WATER FLOW:	0. GPM	
COOLING WATER FLOW:	0. GPM	
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 502. COKE PUSHING	COKE	2

CONTROL SYSTEM CONFIGURATION:

CONTROLLED COKING

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.2	
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1011967.		

OPERATING COST:

		UNITS	OPTION
PPSES: 502.	COKE PUSHING	COKE	2
CAPACITY:	.708 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	0. HRS/YR	\$14.34/HR	0. (C)
SUPERVISION	0. HRS/YR	\$17.20/HR	0. (D)
MATERIALS			0. (E)
SUPPLIES			6857100. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			7012900.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			31200.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			3506500.
TOTAL OPERATING COST			10550600.
OPERATING COST IN DOLLARS PER TON PRODUCTION			14.89
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			17376.39
OPERATING COST AS PERCENT OF CAPITAL COST			.0
INSTALLATION TIME IN WEEKS			8.
ESTIMATED LIFE OF SYSTEM IN YEARS			99.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (10.00% OF TOTAL CAPITAL)			0.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			0.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			0.
TOTAL ANNUALIZED COST - RETROFIT			10550600.
- NEW			10550600.

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	502. COKE PUSHING	COKE	3
CAPACITY:	.708 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	2.000000 LBS/TON COAL		
ALLOWABLE:	.290000 LBS/TON COAL	EFFICIENCY:	85.5%
	35.26 LBS/HR		
BSO			
LOAD IN:	.080000 LBS/TON COAL		
ALLOWABLE:	.044000 LBS/TON COAL	EFFICIENCY:	45.0%
	5.35 LBS/HR		
BAP			
LOAD IN:	.000040 LBS/TON COAL		
ALLOWABLE:	.000022 LBS/TON COAL	EFFICIENCY:	45.0%
	.00 LBS/HR		
BENZENE			
LOAD IN:	.006000 LBS/TON COAL		
ALLOWABLE:	.003300 LBS/TON COAL	EFFICIENCY:	45.0%
	.40 LBS/HR		
DUST COLLECTED PER DAY:	2.4 TONS(DRY)		
TEMP OUT OF PROCESS:	300. F		
EXHAUST TEMPERATURE:	150. F		
SCFM FLOW:	317000. AT 70. F		
ACFM FLOW:	365000. AT 150. F		
L/G RATIO:	.0		
PROCESS WATER FLOW:	0. GPM		
COOLING WATER FLOW:	0. GPM		
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS:	.0

GENERAL INFORMATION:

PPSES: 502. COKE PUSHING

UNITS	OPTION
COKE	3

CONTROL SYSTEM CONFIGURATION:

ESP
COKE OVEN SHED
FAN AND DRIVE
DUCTWORK
STACK
DUST HANDLING HOPPER & CONVEYORS
DAMPERS
FAN AND DRIVE ELECTRICAL

SCA: 188.	TOTAL PLATE AREA: 82000. SQ.FT. @ 20% SPARE CAPACITY
FEET OF ADDITIONAL DUCT: 300.	DIAMETER: 11.
TOTAL PRESSURE DROP: 12. INCHES	
3 FANS @ 575. HP EACH	SPARE FAN CAPACITY: 50.%
OPERATING HOURS AT FULL HP: 8322.	
OPERATING HOURS AT REDUCED HP: 0.	
STACK HEIGHT: 100.	DIAMETER: 12.
NO. OF OVENS 60.	
OVEN HEIGHT 6.0 METERS	
OVEN VOLUME 1348. CUBIC FEET	
TONS COKE/PUSH 24.	
AVG. COKING TIME, HRS. 17.5	
NO. CYCLES/DAY 82.	
BULK DENSITY 50. LBS/CUBIC FT.	
YIELD .70	
TONS COAL/YEAR 1011967.	

CAPITAL COST:

PPSES: 502.	COKE PUSHING	UNITS COKE	OPTION 3
-------------	--------------	---------------	-------------

CAPACITY: .708 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST.

CATEGORY	COST IN DOLLARS
----------	-----------------

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	1740300.
INSTRUMENTATION	0.
PIPING	0.
ELECTRICAL	71900.
FOUNDATIONS	15500.
STRUCTURAL	72100.
SITE WORK	7900.
INSULATION	59900.
PROTECTIVE COATING	9600.
BUILDINGS	8800.
EQUIPMENT/MATERIAL LABOR	694500.
DIRECT COST SUBTOTAL	2680500.

*** INDIRECT COST ***

FIELD OVERHEAD	358100.
CONTRACTORS FEE	261400.
ENGINEERING	237100.
FREIGHT	84400.
OFFSITE WORK	48100.
TAXES	98000.
SHAKEDOWN	95000.
SPARES	89200.
CONTINGENCY	829900.
INDIRECT COST SUBTOTAL	2101200.

INTEREST DURING INSTALLATION	429600.
------------------------------	---------

TOTAL COST	5211300.
------------	----------

TOTAL COST WITH RETROFIT	5840000.
--------------------------	----------

OPERATING COST:

		UNITS	OPTION
PPSES:	502. COKE PUSHING	COKE	3
CAPACITY:	.708 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	8677492. KWH/YR	\$.0266/KWH	231000.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	11867. HRS/YR	\$14.34/HR	170200. (C)
SUPERVISION	2373. HRS/YR	\$17.20/HR	40800. (D)
MATERIALS			86800. (E)
SUPPLIES			44700. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	865. TON/YR	\$ 8.25/TON	7100.
DIRECT OPERATING COST			736400.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			73400.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			249200.
TOTAL OPERATING COST			1059000.
OPERATING COST IN DOLLARS PER TON PRODUCTION			1.49
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			1223.95
OPERATING COST AS PERCENT OF CAPITAL COST			18.1
INSTALLATION TIME IN WEEKS			130.
ESTIMATED LIFE OF SYSTEM IN YEARS			20.
KWH PER TON CAPACITY			12.2
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)			686000.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			116800.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			116800.
TOTAL ANNUALIZED COST - RETROFIT			1978600.
- NEW			1879500.

GENERAL INFORMATION:

UNITS OPTION

PPSES: 502. COKE PUSHING

COKE 4

CAPACITY: .708 MILLION TONS/YEAR

PARTICULATE

LOAD IN: 2.000000 LBS/TON COAL

ALLOWABLE: .290000 LBS/TON COAL EFFICIENCY: 85.5%
35.26 LBS/HR

BSO

LOAD IN: .080000 LBS/TON COAL

ALLOWABLE: .040400 LBS/TON COAL EFFICIENCY: 49.5%
4.91 LBS/HR

BAP

LOAD IN: .000040 LBS/TON COAL

ALLOWABLE: .000020 LBS/TON COAL EFFICIENCY: 49.5%
.00 LBS/HR

BENZENE

LOAD IN: .006000 LBS/TON COAL

ALLOWABLE: .003030 LBS/TON COAL EFFICIENCY: 49.5%
.37 LBS/HR

DUST COLLECTED PER DAY: 2.4 TONS(DRY)

TEMP OUT OF PROCESS: 300. F

EXHAUST TEMPERATURE: 100. F

SCFM FLOW: 345000, AT 70. F

ACFM FLOW: 365000. AT 100. F

L/G RATIO: 7.9

PROCESS WATER FLOW: 2738. GPM

COOLING WATER FLOW: 0. GPM

SUSPENDED SOLIDS OUT: 124. MG/L %SOLIDS: .0

GENERAL INFORMATION:

PPSES: 502. COKE PUSHING

UNITS OPTION
COKE 4

CONTROL SYSTEM CONFIGURATION:

VENTURI SCRUBBER
COKE OVEN SHED
MIST ELIMINATOR
FAN AND DRIVE
DUCTWORK
STACK
WASTEWATER RECYCLE SYSTEM
DAMPERS
WASTE WATER RETURN SYSTEM
WATER PUMPING SYSTEM
FAN AND DRIVE ELECTRICAL

FEET OF ADDITIONAL DUCT:	300.	DIAMETER: 11.
TOTAL PRESSURE DROP:	30.	INCHES
3 FANS @ 1436. HP EACH	SPARE FAN CAPACITY:	50.%
OPERATING HOURS AT FULL HP:	8322.	
OPERATING HOURS AT REDUCED HP:	0.	
STACK HEIGHT:	100.	DIAMETER: 12.
NO. OF OVENS	60.	
OVEN HEIGHT	6.0	METERS
OVEN VOLUME	1348.	CUBIC FEET
TONS COKE/PUSH	24.	
AVG. COKING TIME, HRS.	17.5	
NO. CYCLES/DAY	82.	
BULK DENSITY	50.	LBS/CUBIC FT.
YIELD	.70	
TONS COAL/YEAR	1011967.	

CAPITAL COST:

		UNITS	OPTION
PPSES:	502. COKE PUSHING	COKE	4
CAPACITY:	.708 MILLION TONS/YEAR		
TOTAL COST	(COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST.)		
CATEGORY	COST IN DOLLARS		
*** DIRECT COST ***			
EQUIPMENT OR MATERIAL	2507500.		
INSTRUMENTATION	51900.		
PIPING	235000.		
ELECTRICAL	316500.		
FOUNDATIONS	89500.		
STRUCTURAL	123800.		
SITE WORK	11000.		
INSULATION	23400.		
PROTECTIVE COATING	28300.		
BUILDINGS	38600.		
EQUIPMENT/MATERIAL LABOR	623700.		
DIRECT COST SUBTOTAL	4049200.		
*** INDIRECT COST ***			
FIELD OVERHEAD	457700.		
CONTRACTORS FEE	247400.		
ENGINEERING	396500.		
FREIGHT	91800.		
OFFSITE WORK	72800.		
TAXES	145800.		
SHAKEDOWN	136400.		
SPARES	118400.		
CONTINGENCY	1131000.		
INDIRECT COST SUBTOTAL	2797800.		
INTEREST DURING INSTALLATION	563500.		
TOTAL COST	7410500.		
TOTAL COST WITH RETROFIT	8259100.		

OPERATING COST:

		UNITS	OPTION
PPSES:	502. COKE PUSHING	COKE	4
CAPACITY:	.708 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	273402. MGAL/YR	\$.1595/1000 GAL	43600.
ELECTRICITY	18980168. KWH/YR	\$.0266/KWH	505300.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	17163. HRS/YR	\$14.34/HR	246200. (C)
SUPERVISION	3433. HRS/YR	\$17.20/HR	59100. (D)
MATERIALS			191100. (E)
SUPPLIES			110200. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	1730. TON/YR	\$ 8.25/TON	14300.
DIRECT OPERATING COST			1325600.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			92200.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			381200.
TOTAL OPERATING COST			1799000.
OPERATING COST IN DOLLARS PER TON PRODUCTION			2.54
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			2079.21
OPERATING COST AS PERCENT OF CAPITAL COST			21.8
INSTALLATION TIME IN WEEKS			130.
ESTIMATED LIFE OF SYSTEM IN YEARS			15.
KWH PER TON CAPACITY			26.8
CAPITAL RECOVERY (13.15% OF TOTAL CAPITAL)			1085900.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			165200.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			165200.
TOTAL ANNUALIZED COST - RETROFIT			3215300.
- NEW			3069700.

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	502. COKE PUSHING	COKE	5
CAPACITY:	.708 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	2.000000 LBS/TON COAL		
ALLOWABLE:	.236000 LBS/TON COAL	EFFICIENCY:	88.2%
	88.45 LBS/HR		
BSO			
LOAD IN:	.080000 LBS/TON COAL		
ALLOWABLE:	.036800 LBS/TON COAL	EFFICIENCY:	54.0%
	13.79 LBS/HR		
BAP			
LOAD IN:	.000040 LBS/TON COAL		
ALLOWABLE:	.000026 LBS/TON COAL	EFFICIENCY:	36.0%
	.01 LBS/HR		
BENZENE			
LOAD IN:	.006000 LBS/TON COAL		
ALLOWABLE:	.002760 LBS/TON COAL	EFFICIENCY:	54.0%
	1.03 LBS/HR		
DUST COLLECTED PER DAY:	2.4 TONS(DRY)		
TEMP OUT OF PROCESS:	300. F		
EXHAUST TEMPERATURE:	100. F		
SCFM FLOW:	71000. AT	70. F	
ACFM FLOW:	75000. AT	100. F	
L/G RATIO:	.0		
PROCESS WATER FLOW:	0. GPM		
COOLING WATER FLOW:	0. GPM		
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS:	.0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 502. COKE PUSHING	COKE	5

CONTROL SYSTEM CONFIGURATION:

ENCLOSED HOT CAR

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	5.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.7	
OPERATING HOURS AT FULL HP:	2700.		
OPERATING HOURS AT REDUCED HP:	5900.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1011967.		

CAPITAL COST:

		UNITS	OPTION
PPSES: 502.	COKE PUSHING	COKE	5

CAPACITY: .708 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST.)

CATEGORY	COST IN DOLLARS	
*** DIRECT COST ***		
EQUIPMENT OR MATERIAL	3841700.	
INSTRUMENTATION	0.	
PIPING	0.	
ELECTRICAL	0.	
FOUNDATIONS	0.	
STRUCTURAL	0.	
SITE WORK	0.	
INSULATION	0.	
PROTECTIVE COATING	0.	
BUILDINGS	0.	
EQUIPMENT/MATERIAL LABOR	23100.	
DIRECT COST SUBTOTAL		3864800.
*** INDIRECT COST ***		
FIELD OVERHEAD	11500.	
CONTRACTORS FEE	3800.	
ENGINEERING	55000.	
FREIGHT	7700.	
OFFSITE WORK	0.	
TAXES	192400.	
SHAKEDOWN	192400.	
SPARES	38500.	
CONTINGENCY	877500.	
INDIRECT COST SUBTOTAL		1378800.
INTEREST DURING INSTALLATION		524400.
TOTAL COST		5768000.
TOTAL COST WITH RETROFIT		6344800.

OPERATING COST:

		UNITS	OPTION
PPSES:	502. COKE PUSHING	COKE	5
CAPACITY:	.708 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	6375. MGAL/YR	\$.1595/1000 GAL	1000.
ELECTRICITY	4173. KWH/YR	\$.0266/KWH	100.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	672958. GAL/YR	\$.4180/GAL	281300.
*** OPERATING LABOR ***			
DIRECT	0. HRS/YR	\$14.34/HR	0. (A)
SUPERVISION	0. HRS/YR	\$17.20/HR	0. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	8000. HRS/YR	\$14.34/HR	114800. (C)
SUPERVISION	1600. HRS/YR	\$17.20/HR	27500. (D)
MATERIALS			114800. (E)
SUPPLIES			38600. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	1785. TON/YR	\$ 8.25/TON	14700.
DIRECT OPERATING COST			592800.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			28500.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			147900.
TOTAL OPERATING COST			769200.
OPERATING COST IN DOLLARS PER TON PRODUCTION			1.09
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			861.80
OPERATING COST AS PERCENT OF CAPITAL COST			12.1
INSTALLATION TIME IN WEEKS			104.
ESTIMATED LIFE OF SYSTEM IN YEARS			20.
KWH PER TON CAPACITY			41.8
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)			745300.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			126900.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			126900.
TOTAL ANNUALIZED COST - RETROFIT			1768300.
- NEW			1677500.

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	502. COKE PUSHING	COKE	6
CAPACITY:	.708 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	2.000000 LBS/TON COAL		
ALLOWABLE:	.218000 LBS/TON COAL	EFFICIENCY:	89.1%
	26.51 LBS/HR		
BSO			
LOAD IN:	.080000 LBS/TON COAL		
ALLOWABLE:	.044000 LBS/TON COAL	EFFICIENCY:	45.0%
	5.35 LBS/HR		
BAP			
LOAD IN:	.000040 LBS/TON COAL		
ALLOWABLE:	.000022 LBS/TON COAL	EFFICIENCY:	45.0%
	.00 LBS/HR		
BENZENE			
LOAD IN:	.006000 LBS/TON COAL		
ALLOWABLE:	.003300 LBS/TON COAL	EFFICIENCY:	45.0%
	.40 LBS/HR		
DUST COLLECTED PER DAY:	2.5 TONS(DRY)		
TEMP OUT OF PROCESS:	300. F		
EXHAUST TEMPERATURE:	150. F		
SCFM FLOW:	317000. AT 70. F		
ACFM FLOW:	365000. AT 150. F		
L/G RATIO:	.0		
PROCESS WATER FLOW:	0. GPM		
COOLING WATER FLOW:	0. GPM		
SUSPENDED SOLIDS OUT:	0, MG/L	%SOLIDS:	.0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 502. COKE PUSHING	COKE	6

CONTROL SYSTEM CONFIGURATION:

ESP
 COKE OVEN SHED
 FAN AND DRIVE
 DUCTWORK
 STACK
 DUST HANDLING HOPPER & CONVEYORS
 DAMPERS
 FAN AND DRIVE ELECTRICAL

SCA: 240.	TOTAL PLATE AREA: 105000. SQ.FT. @ 20% SPARE CAPACITY
FEET OF ADDITIONAL DUCT: 300.	DIAMETER: 11.
TOTAL PRESSURE DROP: 12. INCHES	
3 FANS @ 575. HP EACH	SPARE FAN CAPACITY: 50.%
OPERATING HOURS AT FULL HP: 8322.	
OPERATING HOURS AT REDUCED HP: 0.	
STACK HEIGHT: 100.	DIAMETER: 12.
NO. OF OVENS 60.	
OVEN HEIGHT 6.0 METERS	
OVEN VOLUME 1348. CUBIC FEET	
TONS COKE/PUSH 24.	
AVG. COKING TIME, HRS. 17.5	
NO. CYCLES/DAY 82.	
BULK DENSITY 50. LBS/CUBIC FT.	
YIELD .70	
TONS COAL/YEAR 1011967.	

CAPITAL COST:

PPSES: 502.	COKE PUSHING	UNITS	OPTION
		COKE	6

CAPACITY: .708 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST)

CATEGORY	COST IN DOLLARS
----------	-----------------

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	1876100.
INSTRUMENTATION	0.
PIPING	0.
ELECTRICAL	81100.
FOUNDATIONS	16200.
STRUCTURAL	81200.
SITE WORK	9100.
INSULATION	68900.
PROTECTIVE COATING	10500.
BUILDINGS	10100.
EQUIPMENT/MATERIAL LABOR	754000.
DIRECT COST SUBTOTAL	2907200.

*** INDIRECT COST ***

FIELD OVERHEAD	395300.
CONTRACTORS FEE	287400.
ENGINEERING	259300.
FREIGHT	91500.
OFFSITE WORK	54800.
TAXES	105400.
SHAKEDOWN	106200.
SPARES	100400.
CONTINGENCY	900700.
INDIRECT COST SUBTOTAL	2301000.

INTEREST DURING INSTALLATION	472100.
------------------------------	---------

TOTAL COST	5680300.
------------	----------

TOTAL COST WITH RETROFIT	6355900.
--------------------------	----------

OPERATING COST:

		UNITS	OPTION
PPSES:	502. COKE PUSHING	COKE	6
CAPACITY:	.708 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	9151822. KWH/YR	\$.0266/KWH	243600.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	11867. HRS/YR	\$14.34/HR	170200. (C)
SUPERVISION	2373. HRS/YR	\$17.20/HR	40800. (D)
MATERIALS			86800. (E)
SUPPLIES			44700. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	902. TON/YR	\$ 8.25/TON	7400.
DIRECT OPERATING COST			749300.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			73400.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			249200.
TOTAL OPERATING COST			1071900.
OPERATING COST IN DOLLARS PER TON PRODUCTION			1.51
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			1188.80
OPERATING COST AS PERCENT OF CAPITAL COST			16.9
INSTALLATION TIME IN WEEKS			130.
ESTIMATED LIFE OF SYSTEM IN YEARS			20.
KWH PER TON CAPACITY			12.9
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)			746600.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			127100.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			127100.
TOTAL ANNUALIZED COST - RETROFIT			2072700.
- NEW			1966300.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 502. COKE PUSHING	COKE	7

CAPACITY: .708 MILLION TONS/YEAR

PARTICULATE

LOAD IN:	2.000000 LBS/TON COAL	
ALLOWABLE:	.218000 LBS/TON COAL	EFFICIENCY: 89.1%
	26.51 LBS/HR	

BSO

LOAD IN:	.080000 LBS/TON COAL	
ALLOWABLE:	.036800 LBS/TON COAL	EFFICIENCY: 54.0%
	4.47 LBS/HR	

BAP

LOAD IN:	.000040 LBS/TON COAL	
ALLOWABLE:	.000018 LBS/TON COAL	EFFICIENCY: 54.0%
	.00 LBS/HR	

BENZENE

LOAD IN:	.006000 LBS/TON COAL	
ALLOWABLE:	.002760 LBS/TON COAL	EFFICIENCY: 54.0%
	.34 LBS/HR	

DUST COLLECTED PER DAY: 2.5 TONS(DRY)

TEMP OUT OF PROCESS: 300. F

EXHAUST TEMPERATURE: 100. F

SCFM FLOW: 345000. AT 70. F

ACFM FLOW: 365000. AT 100. F

L/G RATIO: 7.9

PROCESS WATER FLOW: 2738. GPM

COOLING WATER FLOW: 0. GPM

SUSPENDED SOLIDS OUT: 124. MG/L %SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 502. COKE PUSHING	COKE	7

CONTROL SYSTEM CONFIGURATION:

VENTURI SCRUBBER
 COKE OVEN SHED
 MIST ELIMINATOR
 FAN AND DRIVE
 DUCTWORK
 STACK
 WASTEWATER RECYCLE SYSTEM
 DAMPERS
 WASTE WATER RETURN SYSTEM
 WATER PUMPING SYSTEM
 FAN AND DRIVE ELECTRICAL

FEET OF ADDITIONAL DUCT:	300.	DIAMETER: 11.
TOTAL PRESSURE DROP:	50.	INCHES
3 FANS @ 2394. HP EACH	SPARE FAN CAPACITY: 50.%	
OPERATING HOURS AT FULL HP:	8322.	
OPERATING HOURS AT REDUCED HP:	0.	
STACK HEIGHT:	100.	DIAMETER: 12.
NO. OF OVENS	60.	
OVEN HEIGHT	6.0	METERS
OVEN VOLUME	1348.	CUBIC FEET
TONS COKE/PUSH	24.	
AVG. COKING TIME, HRS.	17.5	
NO. CYCLES/DAY	82.	
BULK DENSITY	50.	LBS/CUBIC FT.
YIELD	.70	
TONS COAL/YEAR	1011967.	

CAPITAL COST:

	UNITS	OPTION
PPSES: 502. COKE PUSHING	COKE	7

CAPACITY: .708 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST.)

CATEGORY	COST IN DOLLARS
----------	-----------------

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	2727900.
INSTRUMENTATION	51900.
PIPING	235000.
ELECTRICAL	316500.
FOUNDATIONS	95800.
STRUCTURAL	126200.
SITE WORK	11000.
INSULATION	23400.
PROTECTIVE COATING	28200.
BUILDINGS	38600.
EQUIPMENT/MATERIAL LABOR	628400.
DIRECT COST SUBTOTAL	4282900.

*** INDIRECT COST ***

FIELD OVERHEAD	462200.
CONTRACTORS FEE	250700.
ENGINEERING	396500.
FREIGHT	92400.
OFFSITE WORK	73300.
TAXES	157500.
SHAKEDOWN	148900.
SPARES	119300.
CONTINGENCY	1185700.
INDIRECT COST SUBTOTAL	2886500.

INTEREST DURING INSTALLATION	604600.
------------------------------	---------

TOTAL COST	7774000.
------------	----------

TOTAL COST WITH RETROFIT	8658900.
--------------------------	----------

OPERATING COST:

		UNITS	OPTION
PPSES: 502.	COKE PUSHING	COKE	7
CAPACITY:	.708 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	273402. MGAL/YR	\$.1595/1000 GAL	43600.
ELECTRICITY	31514320. KWH/YR	\$.0266/KWH	838900.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	17763. HRS/YR	\$14.34/HR	254800. (C)
SUPERVISION	3553. HRS/YR	\$17.20/HR	61100. (D)
MATERIALS			197600. (E)
SUPPLIES			112800. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	1803. TON/YR	\$ 8.25/TON	14900.
DIRECT OPERATING COST			1679500.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			94300.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			391100.
TOTAL OPERATING COST			2164900.
OPERATING COST IN DOLLARS PER TON PRODUCTION			3.06
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			2401.01
OPERATING COST AS PERCENT OF CAPITAL COST			25.0
INSTALLATION TIME IN WEEKS			130.
ESTIMATED LIFE OF SYSTEM IN YEARS			15.
KWH PER TON CAPACITY			44.5
CAPITAL RECOVERY (13.15% OF TOTAL CAPITAL)			1138400.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			173200.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			173200.
TOTAL ANNUALIZED COST - RETROFIT			3649700.
- NEW			3498000.

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	503.	QUENCHING - CLEAN WATER	COKE 2
CAPACITY:	2.834 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	1.700000	LBS/TON COAL	
ALLOWABLE:	.510000	LBS/TON COAL	EFFICIENCY: 70.0%
	235.66	LBS/HR	
BSO			
LOAD IN:	.001700	LBS/TON COAL	
ALLOWABLE:	.000510	LBS/TON COAL	EFFICIENCY: 70.0%
	.24	LBS/HR	
BAP			
LOAD IN:	.000140	LBS/TON COAL	
ALLOWABLE:	.000042	LBS/TON COAL	EFFICIENCY: 70.0%
	.02	LBS/HR	
BENZENE			
LOAD IN:	.000030	LBS/TON COAL	
ALLOWABLE:	.000030	LBS/TON COAL	EFFICIENCY: .0%
	.01	LBS/HR	
DUST COLLECTED PER DAY:	6.6 TONS(DRY)		
TEMP OUT OF PROCESS:	200. F		
EXHAUST TEMPERATURE:	200. F		
SCFM FLOW:	566000.	AT 70. F	
ACFM FLOW:	705000.	AT 200. F	
L/G RATIO:	.0		
PROCESS WATER FLOW:	0. GPM		
COOLING WATER FLOW:	0. GPM		
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS:	.0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 503. QUENCHING - CLEAN WATER	COKE	2

CONTROL SYSTEM CONFIGURATION:

QUENCH TOWER BAFFLES

FEET OF ADDITIONAL DUCT:	0.	DIAMETER: 15.
TOTAL PRESSURE DROP:	0.	INCHES
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.2
OPERATING HOURS AT FULL HP:	8760.	
OPERATING HOURS AT REDUCED HP:	0.	
STACK HEIGHT:	0.	DIAMETER: 0.
NO. OF OVENS	60.	
OVEN HEIGHT	6.0	METERS
OVEN VOLUME	1348.	CUBIC FEET
TONS COKE/PUSH	24.	
AVG. COKING TIME, HRS.	17.5	
NO. CYCLES/DAY	82.	
BULK DENSITY	50.	LBS/CUBIC FT.
YIELD	.70	
TONS COAL/YEAR	4047868.	

CAPITAL COST:

	UNITS	OPTION
PPSES: 503. QUENCHING - CLEAN WATER	COKE	2

CAPACITY: 2.834 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4Q78 COST.)

CATEGORY	COST IN DOLLARS
----------	-----------------

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	114100.
INSTRUMENTATION	0.
PIPING	30800.
ELECTRICAL	6200.
FOUNDATIONS	900.
STRUCTURAL	0.
SITE WORK	600.
INSULATION	0.
PROTECTIVE COATING	900.
BUILDINGS	0.
EQUIPMENT/MATERIAL LABOR	80300.
DIRECT COST SUBTOTAL	233800.

*** INDIRECT COST ***

FIELD OVERHEAD	45400.
CONTRACTORS FEE	27900.
ENGINEERING	35100.
FREIGHT	4400.
OFFSITE WORK	0.
TAXES	5700.
SHAKEDOWN	1300.
SPARES	3500.
CONTINGENCY	71400.
INDIRECT COST SUBTOTAL	194700.

INTEREST DURING INSTALLATION	10700.
------------------------------	--------

TOTAL COST	439200.
------------	---------

TOTAL COST WITH RETROFIT	571000.
--------------------------	---------

OPERATING COST:

PPSES: 503.		QUENCHING - CLEAN WATER	UNITS COKE	OPTION 2
CAPACITY:		2.834 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)	
*** UTILITIES ***				
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.	
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.	
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.	
FUEL	0. GAL/YR	\$.4180/GAL	0.	
*** OPERATING LABOR ***				
DIRECT	0. HRS/YR	\$14.34/HR	0. (A)	
SUPERVISION	0. HRS/YR	\$17.20/HR	0. (B)	
*** MAINTENANCE & SUPPLIES ***				
DIRECT LABOR	1200. HRS/YR	\$14.34/HR	17200. (C)	
SUPERVISION	240. HRS/YR	\$17.20/HR	4100. (D)	
MATERIALS			8600. (E)	
SUPPLIES			4500. (F)	
WATER TREATMENT			0.	
SOLID WASTE DISPOSAL	4817. TON/YR	\$ 8.25/TON	39700.	
DIRECT OPERATING COST			74100.	
PAYROLL OVERHEAD =20.0% OF A+B+C+D			4300.	
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			17200.	
TOTAL OPERATING COST			95600.	
OPERATING COST IN DOLLARS PER TON PRODUCTION			.03	
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			39.69	
OPERATING COST AS PERCENT OF CAPITAL COST			16.7	
INSTALLATION TIME IN WEEKS			26.	
ESTIMATED LIFE OF SYSTEM IN YEARS			20.	
KWH PER TON CAPACITY			.0	
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)			67100.	
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			11400.	
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			11400.	
TOTAL ANNUALIZED COST - RETROFIT			185500.	
- NEW			164800.	

GENERAL INFORMATION:

PPSES: 503. QUENCHING - CLEAN WATER UNITS COKE OPTION 3

CAPACITY: 2.834 MILLION TONS/YEAR

PARTICULATE

LOAD IN: 1.700000 LBS/TON COAL
ALLOWABLE: .170000 LBS/TON COAL EFFICIENCY: 90.0%
78.55 LBS/HR

BSO

LOAD IN: .001700 LBS/TON COAL
ALLOWABLE: .000170 LBS/TON COAL EFFICIENCY: 90.0%
.08 LBS/HR

BAP

LOAD IN: .000140 LBS/TON COAL
ALLOWABLE: .000014 LBS/TON COAL EFFICIENCY: 90.0%
.01 LBS/HR

BENZENE

LOAD IN: .000030 LBS/TON COAL
ALLOWABLE: .000030 LBS/TON COAL EFFICIENCY: .0%
.01 LBS/HR

DUST COLLECTED PER DAY: 8.5 TONS(DRY)

TEMP OUT OF PROCESS: 200. F
EXHAUST TEMPERATURE: 150. F

SCFM FLOW: 566000. AT 70. F
ACFM FLOW: 651000. AT 150. F

L/G RATIO: .0

PROCESS WATER FLOW: 1213. GPM

COOLING WATER FLOW: 0. GPM

SUSPENDED SOLIDS OUT: 907. MG/L %SOLIDS: .1

GENERAL INFORMATION:

PPSES: 503. QUENCHING - CLEAN WATER UNITS COKE OPTION 3

CONTROL SYSTEM CONFIGURATION:

QUENCH TOWER BAFFLES

FEET OF ADDITIONAL DUCT: 0. DIAMETER: 14.
TOTAL PRESSURE DROP: 0. INCHES
0 FANS @ 0. HP EACH SPARE FAN CAPACITY: 0.2
OPERATING HOURS AT FULL HP: 8760.
OPERATING HOURS AT REDUCED HP: 0.
STACK HEIGHT: 0. DIAMETER: 0.
NO. OF OVENS 60.
OVEN HEIGHT 6.0 METERS
OVEN VOLUME 1348. CUBIC FEET
TONS COKE/PUSH 24.
AVG. COKING TIME, HRS. 17.5
NO. CYCLES/DAY 62.
BULK DENSITY 50. LBS/CUBIC FT.
YIELD .70
TONS COAL/YEAR 4047868.

CAPITAL COST:

PPSES: 503. QUENCHING - CLEAN WATER UNITS OPTION
CUKE 3

CAPACITY: 2.834 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4Q78 COST)

CATEGORY

COST IN DOLLARS

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	928400.
INSTRUMENTATION	30800.
PIPING	13200.
ELECTRICAL	0.
FOUNDATIONS	0.
STRUCTURAL	0.
SITE WORK	8800.
INSULATION	7900.
PROTECTIVE COATING	3500.
BUILDINGS	0.
EQUIPMENT/MATERIAL LABOR	654700.
DIRECT COST SUBTOTAL	1647300.

*** INDIRECT COST ***

FIELD OVERHEAD	70400.
CONTRACTORS FEE	338800.
ENGINEERING	244200.
FREIGHT	0.
OFFSITE WORK	44000.
TAXES	48400.
SHAKEDOWN	26400.
SPARES	44000.
CONTINGENCY	638000.
INDIRECT COST SUBTOTAL	1454200.

INTEREST DURING INSTALLATION 155100.

TOTAL COST 3256600.

TOTAL COST WITH RETROFIT 4233600.

OPERATING COST:

PPSES: 503. QUENCHING - CLEAN WATER UNITS OPTION
COKE 3

CAPACITY: 2.834 MILLION TONS/YEAR

CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
----------	----------	------	------------------

*** UTILITIES ***

WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.

*** OPERATING LABOR ***

DIRECT	0. HRS/YR	\$14.34/HR	0. (A)
SUPERVISION	0. HRS/YR	\$17.20/HR	0. (B)

*** MAINTENANCE & SUPPLIES ***

DIRECT LABOR	4000. HRS/YR	\$14.34/HR	57400. (C)
SUPERVISION	800. HRS/YR	\$17.20/HR	13800. (D)
MATERIALS			114800. (E)
SUPPLIES			27900. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	6193. TON/YR	\$ 8.25/TON	51100.

DIRECT OPERATING COST	265000.
-----------------------	---------

PAYROLL OVERHEAD =20.0% OF A+B+C+D	14200.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F	107000.
TOTAL OPERATING COST	386200.
OPERATING COST IN DOLLARS PER TON PRODUCTION	.14
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED	124.72
OPERATING COST AS PERCENT OF CAPITAL COST	9.1
INSTALLATION TIME IN WEEKS	52.
ESTIMATED LIFE OF SYSTEM IN YEARS	20.
KWH PER TON CAPACITY	.0
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)	497300.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)	84700.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)	84700.
TOTAL ANNUALIZED COST - RETROFIT	1052900.
- NEW	898900.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 503. QUENCHING - CLEAN WATER	COKE	4
CAPACITY:	2.834 MILLION TONS/YEAR	
PARTICULATE		
LOAD IN: 1.700000 LBS/TON COAL		
ALLOWABLE: .034000 LBS/TON COAL	EFFICIENCY: 98.0%	
15.71 LBS/HR		
BSO		
LOAD IN: .001700 LBS/TON COAL		
ALLOWABLE: .000017 LBS/TON COAL	EFFICIENCY: 99.0%	
.01 LBS/HR		
BAP		
LOAD IN: .000140 LBS/TON COAL		
ALLOWABLE: .000001 LBS/TON COAL	EFFICIENCY: 99.0%	
.00 LBS/HR		
BENZENE		
LOAD IN: .000030 LBS/TON COAL		
ALLOWABLE: .000000 LBS/TON COAL	EFFICIENCY: 99.0%	
.00 LBS/HR		
DUST COLLECTED PER DAY:	9.2 TONS(DRY)	
TEMP OUT OF PROCESS:	200. F	
EXHAUST TEMPERATURE:	200. F	
SCFM FLOW: 549000. AT 70. F		
ACFM FLOW: 683000. AT 200. F		
L/G RATIO:	.0	
PROCESS WATER FLOW:	0. GPM	
COOLING WATER FLOW:	0. GPM	
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 503. QUENCHING - CLEAN WATER	COKE	4

CONTROL SYSTEM CONFIGURATION:

DRY QUENCHING

FEET OF ADDITIONAL DUCT:	0.	DIAMETER: 15.
TOTAL PRESSURE DROP:	0.	INCHES
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.%
OPERATING HOURS AT FULL HP:	8760.	
OPERATING HOURS AT REDUCED HP:	0.	
STACK HEIGHT:	0.	DIAMETER: 0.
NO. OF OVENS	60.	
OVEN HEIGHT	6.0	METERS
OVEN VOLUME	1348.	CUBIC FEET
TONS COKE/PUSH	24.	
AVG. COKING TIME, HRS.	17.5	
NO. CYCLES/DAY	82.	
BULK DENSITY	50.	LBS/CUBIC FT.
YIELD	.70	
TONS COAL/YEAR	4047868.	

CAPITAL COST:

	UNITS	OPTION
PPSES: 503. QUENCHING - CLEAN WATER	COKE	4
CAPACITY:	2.834 MILLION TONS/YEAR	

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST.)

CATEGORY	COST IN DOLLARS
*** DIRECT COST ***	
EQUIPMENT OR MATERIAL	9365400.
INSTRUMENTATION	0.
PIPING	0.
ELECTRICAL	0.
FOUNDATIONS	0.
STRUCTURAL	0.
SITE WORK	0.
INSULATION	0.
PROTECTIVE COATING	0.
BUILDINGS	0.
EQUIPMENT/MATERIAL LABOR	4495300.
DIRECT COST SUBTOTAL	13860700.
*** INDIRECT COST ***	
FIELD OVERHEAD	2409500.
CONTRACTORS FEE	1591300.
ENGINEERING	476500.
FREIGHT	0.
OFFSITE WORK	404600.
TAXES	449500.
SHAKEDOWN	674300.
SPARES	71900.
CONTINGENCY	4890900.
INDIRECT COST SUBTOTAL	10968500.
INTEREST DURING INSTALLATION	3103700.
TOTAL COST	27932900.
TOTAL COST WITH RETROFIT	30726200.

OPERATING COST:

		UNITS	OPTION
PPSES: 503.	QUENCHING - CLEAN WATER	COKE	4
CAPACITY:	2.834 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	22668064. KWH/YR	\$.0266/KWH	603400.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	62337. HRS/YR	\$14.34/HR	894200. (C)
SUPERVISION	12467. HRS/YR	\$17.20/HR	214500. (D)
MATERIALS			447100. (E)
SUPPLIES			233400. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	3372. TON/YR	\$ 8.25/TON	27800.
DIRECT OPERATING COST			2576200.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			252900.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			972500.
TOTAL OPERATING COST			3801600.
OPERATING COST IN DOLLARS PER TON PRODUCTION			1.34
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			1127.44
OPERATING COST AS PERCENT OF CAPITAL COST			12.4
INSTALLATION TIME IN WEEKS			130.
ESTIMATED LIFE OF SYSTEM IN YEARS			25.
KWH PER TON CAPACITY			8.0
CAPITAL RECOVERY (11.02% OF TOTAL CAPITAL)			3385000.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			614500.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			614500.
TOTAL ANNUALIZED COST - RETROFIT			8415600.
- NEW			7996300.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 504. DOORS	COKE	2
CAPACITY: .708 MILLION TONS/YEAR		
PARTICULATE		
LOAD IN:	.500000 LBS/TON COAL	
ALLOWABLE:	.200000 LBS/TON COAL	EFFICIENCY: 60.0%
	23.10 LBS/HR	
BSO		
LOAD IN:	.500000 LBS/TON COAL	
ALLOWABLE:	.200000 LBS/TON COAL	EFFICIENCY: 60.0%
	23.10 LBS/HR	
BAP		
LOAD IN:	.003000 LBS/TON COAL	
ALLOWABLE:	.001200 LBS/TON COAL	EFFICIENCY: 60.0%
	.14 LBS/HR	
BENZENE		
LOAD IN:	.010000 LBS/TON COAL	
ALLOWABLE:	.004000 LBS/TON COAL	EFFICIENCY: 60.0%
	.46 LBS/HR	
DUST COLLECTED PER DAY: .4 TONS(DRY)		
TEMP OUT OF PROCESS: 120. F		
EXHAUST TEMPERATURE: 120. F		
SCFM FLOW: 0. AT 70. F		
ACFM FLOW: 0. AT 120. F		
L/G RATIO: .0		
PROCESS WATER FLOW: 0. GPM		
COOLING WATER FLOW: 0. GPM		
SUSPENDED SOLIDS OUT: 0. MG/L %SOLIDS: .0		

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 504. DOORS	COKE	2

CONTROL SYSTEM CONFIGURATION:

COKE OVEN DOOR CLEAN & MAINT

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.8	
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1011967.		

OPERATING COST:

PPSES: 504. DOORS		UNITS COKE	OPTION 2
CAPACITY: .708 MILLION TONS/YEAR			
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	0. HRS/YR	\$14.34/HR	0. (A)
SUPERVISION	0. HRS/YR	\$17.20/HR	0. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	17520. HRS/YR	\$14.34/HR	251300. (C)
SUPERVISION	3504. HRS/YR	\$17.20/HR	60300. (D)
MATERIALS			125400. (E)
SUPPLIES			58000. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			495000.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			62300.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			247500.
TOTAL OPERATING COST			804800.
OPERATING COST IN DOLLARS PER TON PRODUCTION			1.14
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			5301.89
OPERATING COST AS PERCENT OF CAPITAL COST			.0
INSTALLATION TIME IN WEEKS			8.
ESTIMATED LIFE OF SYSTEM IN YEARS			99.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (10.00% OF TOTAL CAPITAL)			0.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			0.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			0.
TOTAL ANNUALIZED COST - RETROFIT			804800.
- NEW			804800.

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	504. DOORS	COKE	3
CAPACITY:	.708 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	.500000 LBS/TON COAL		
ALLOWABLE:	.100000 LBS/TON COAL	EFFICIENCY:	80.0%
	11.55 LBS/HR		
BSO			
LOAD IN:	.500000 LBS/TON COAL		
ALLOWABLE:	.100000 LBS/TON COAL	EFFICIENCY:	80.0%
	11.55 LBS/HR		
BAP			
LOAD IN:	.003000 LBS/TON COAL		
ALLOWABLE:	.000600 LBS/TON COAL	EFFICIENCY:	80.0%
	.07 LBS/HR		
BENZENE			
LOAD IN:	.010000 LBS/TON COAL		
ALLOWABLE:	.002000 LBS/TON COAL	EFFICIENCY:	80.0%
	.23 LBS/HR		
DUST COLLECTED PER DAY:		.6 TONS(DRY)	
TEMP OUT OF PROCESS:		120. F	
EXHAUST TEMPERATURE:		120. F	
SCFM FLOW:	0. AT	70. F	
ACFM FLOW:	0. AT	120. F	
L/G RATIO:		.0	
PROCESS WATER FLOW:		0. GPM	
COOLING WATER FLOW:		0. GPM	
SUSPENDED SOLIDS OUT:		0. MG/L	%SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 504. DOORS	COKE	3

CONTROL SYSTEM CONFIGURATION:

COKE OVEN DOOR CLEAN & MAINT

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.2	
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1011967.		

CAPITAL COST:

		UNITS	OPTION
PPSES: 504.	DOORS	COKE	3

CAPACITY: .708 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST.

CATEGORY	COST IN DOLLARS
----------	-----------------

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	251900.	
INSTRUMENTATION	0.	
PIPING	0.	
ELECTRICAL	0.	
FOUNDATIONS	0.	
STRUCTURAL	0.	
SITE WORK	0.	
INSULATION	0.	
PROTECTIVE COATING	0.	
BUILDINGS	0.	
EQUIPMENT/MATERIAL LABOR	13300.	
DIRECT COST SUBTOTAL		265200.

*** INDIRECT COST ***

FIELD OVERHEAD	7000.	
CONTRACTORS FEE	3000.	
ENGINEERING	17500.	
FREIGHT	1500.	
OFFSITE WORK	0.	
TAXES	12500.	
SHAKEDOWN	2300.	
SPARES	12000.	
CONTINGENCY	63900.	
INDIRECT COST SUBTOTAL		119700.

INTEREST DURING INSTALLATION	29600.
------------------------------	--------

TOTAL COST	414500.
------------	---------

TOTAL COST WITH RETROFIT	414500.
--------------------------	---------

OPERATING COST:

PPSES: 504. DOORS		UNITS COKE	OPTION 3
CAPACITY: .708 MILLION TONS/YEAR			
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	17520. HRS/YR	\$14.34/HR	251300. (A)
SUPERVISION	3504. HRS/YR	\$17.20/HR	60300. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	4500. HRS/YR	\$14.34/HR	64500. (C)
SUPERVISION	900. HRS/YR	\$17.20/HR	15500. (D)
MATERIALS			82300. (E)
SUPPLIES			16800. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			490700.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			78300.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			245400.
TOTAL OPERATING COST			814400.
OPERATING COST IN DOLLARS PER TON PRODUCTION			1.15
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			4023.85
OPERATING COST AS PERCENT OF CAPITAL COST			196.5
INSTALLATION TIME IN WEEKS			80.
ESTIMATED LIFE OF SYSTEM IN YEARS			25.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (11.02% OF TOTAL CAPITAL)			45700.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			8300.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			8300.
TOTAL ANNUALIZED COST - RETROFIT			876700.
- NEW			876700.

GENERAL INFORMATION:

PPSES: 504. DOORS

UNITS OPTION
COKE 4

CAPACITY: .708 MILLION TONS/YEAR

PARTICULATE

LOAD IN: .500000 LBS/TON COAL
ALLOWABLE: .057500 LBS/TON COAL EFFICIENCY: 88.5%
6.99 LBS/HR

BSO

LOAD IN: .500000 LBS/TON COAL
ALLOWABLE: .110000 LBS/TON COAL EFFICIENCY: 78.0%
13.38 LBS/HR

BAP

LOAD IN: .003000 LBS/TON COAL
ALLOWABLE: .000660 LBS/TON COAL EFFICIENCY: 78.0%
.08 LBS/HR

BENZENE

LOAD IN: .010000 LBS/TON COAL
ALLOWABLE: .003500 LBS/TON COAL EFFICIENCY: 65.0%
.43 LBS/HR

DUST COLLECTED PER DAY: .6 TONS(DRY)

TEMP OUT OF PROCESS: -120. F
EXHAUST TEMPERATURE: 100. F

SCFM FLOW: 20000. AT 70. F
ACFM FLOW: 22000. AT 100. F

L/G RATIO: 8.0
PROCESS WATER FLOW: 160. GPM
COOLING WATER FLOW: 0. GPM
SUSPENDED SOLIDS OUT: 532. MG/L %SOLIDS: .1

GENERAL INFORMATION:

PPSES: 504. DOORS

UNITS OPTION
COKE 4

CONTROL SYSTEM CONFIGURATION:

VENTURI SCRUBBER
MIST ELIMINATOR
FAN AND DRIVE
DUCTWORK
STACK
CANOPY HOOD
WASTEWATER RECYCLE SYSTEM
DAMPERS
WASTE WATER RETURN SYSTEM
WATER PUMPING SYSTEM
FAN AND DRIVE ELECTRICAL
COKE OVEN DOOR CLEAN & MAINT

FEET OF ADDITIONAL DUCT: 630. DIAMETER: 3.
TOTAL PRESSURE DROP: 35. INCHES
2 FANS @ 202. HP EACH SPARE FAN CAPACITY: 100.%
OPERATING HOURS AT FULL HP: 8322.
OPERATING HOURS AT REDUCED HP: 0.
STACK HEIGHT: 100. DIAMETER: 3.
NO. OF OVENS 60.
HOOD SIZE: 16. SQ.FT.
OVEN HEIGHT 6.0 METERS
OVEN VOLUME 1348. CUBIC FEET
TONS COKE/PUSH 24.
AVG. COKING TIME, HRS. 17.5
NO. CYCLES/DAY 82.
BULK DENSITY 50. LBS/CUBIC FT.
YIELD .70
TONS COAL/YEAR 1011967.

CAPITAL COST:

PPSES: 504. DOORS UNITS OPTION
COKE 4

CAPACITY: .708 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4Q78 COST

CATEGORY	COST IN DOLLARS
----------	-----------------

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	441400.
INSTRUMENTATION	51900.
PIPING	67100.
ELECTRICAL	99000.
FOUNDATIONS	22600.
STRUCTURAL	83600.
SITE WORK	3800.
INSULATION	7700.
PROTECTIVE COATING	12900.
BUILDINGS	10800.
EQUIPMENT/MATERIAL LABOR	156700.
DIRECT COST SUBTOTAL	957500.

*** INDIRECT COST ***

FIELD OVERHEAD	138100.
CONTRACTORS FEE	66900.
ENGINEERING	138300.
FREIGHT	41900.
OFFSITE WORK	20400.
TAXES	38000.
SHAKEDOWN	37700.
SPARES	34500.
CONTINGENCY	333200.
INDIRECT COST SUBTOTAL	849000.

INTEREST DURING INSTALLATION	131900.
------------------------------	---------

TOTAL COST	1938400.
------------	----------

TOTAL COST WITH RETROFIT	2363000.
--------------------------	----------

OPERATING COST:

PPSES: 504. DOORS UNITS OPTION
COKE 4

CAPACITY: .708 MILLION TONS/YEAR

CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
----------	----------	------	------------------

*** UTILITIES ***

WATER	15978. MGAL/YR	\$.1595/1000 GAL	2500.
ELECTRICITY	1332553. KWH/YR	\$.0266/KWH	35500.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.

*** OPERATING LABOR ***

DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)

*** MAINTENANCE & SUPPLIES ***

DIRECT LABOR	33977. HRS/YR	\$14.34/HR	487400. (C)
SUPERVISION	6795. HRS/YR	\$17.20/HR	116900. (D)
MATERIALS			236400. (E)
SUPPLIES			128300. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	448. TON/YR	\$ 8.25/TON	3700.

DIRECT OPERATING COST	1166500.
-----------------------	----------

PAYROLL OVERHEAD =20.0% OF A+B+C+D	152000.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F	562400.
TOTAL OPERATING COST	1880900.
OPERATING COST IN DOLLARS PER TON PRODUCTION	2.66
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED	8400.71
OPERATING COST AS PERCENT OF CAPITAL COST	79.6
INSTALLATION TIME IN WEEKS	104.
ESTIMATED LIFE OF SYSTEM IN YEARS	15.
KWH PER TON CAPACITY	1.9
CAPITAL RECOVERY (13.15% OF TOTAL CAPITAL)	310700.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)	47300.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)	47300.
TOTAL ANNUALIZED COST - RETROFIT	2286200.
- NEW	2213300.

GENERAL INFORMATION:

PPSES: 504. DOORS UNITS OPTION
COKE 5

CAPACITY: .708 MILLION TONS/YEAR

PARTICULATE

LOAD IN: .500000 LBS/TON COAL
ALLOWABLE: .033500 LBS/TON COAL EFFICIENCY: 93.3%
4.07 LBS/HR

BSO

LOAD IN: .500000 LBS/TON COAL
ALLOWABLE: .081000 LBS/TON COAL EFFICIENCY: 83.8%
9.85 LBS/HR

BAP

LOAD IN: .003000 LBS/TON COAL
ALLOWABLE: .000486 LBS/TON COAL EFFICIENCY: 83.8%
.06 LBS/HR

BENZENE

LOAD IN: .010000 LBS/TON COAL
ALLOWABLE: .002800 LBS/TON COAL EFFICIENCY: 72.0%
.34 LBS/HR

DUST COLLECTED PER DAY: .6 TONS(DRY)

TEMP OUT-OF PROCESS: 120. F
EXHAUST TEMPERATURE: 100. F

SCFM FLOW: 26000. AT 70. F
ACFM FLOW: 27000. AT 100. F

L/G RATIO: 8.0
PROCESS WATER FLOW: 208. GPM
COOLING WATER FLOW: 0. GPM
SUSPENDED SOLIDS OUT: 409. MG/L %SOLIDS: .0

GENERAL INFORMATION:

PPSES: 504. DOORS

UNITS OPTION
COKE 5

CONTROL SYSTEM CONFIGURATION:

VENTURI SCRUBBER
MIST ELIMINATOR
FAN AND DRIVE
DUCTWORK
STACK
CANOPY HOOD
WASTEWATER RECYCLE SYSTEM
DAMPERS
WASTE WATER RETURN SYSTEM
WATER PUMPING SYSTEM
FAN AND DRIVE ELECTRICAL
COKE OVEN DOOR CLEAN & MAINT

FEET OF ADDITIONAL DUCT: 630. DIAMETER: 3.
TOTAL PRESSURE DROP: 65. INCHES
2 FANS @ 460. HP EACH SPARE FAN CAPACITY: 100.2
OPERATING HOURS AT FULL HP: 8322.
OPERATING HOURS AT REDUCED HP: 0.
STACK HEIGHT: 100. DIAMETER: 3.
NO. OF OVENS 60.
HOOD SIZE: 16. SQ.FT.
OVEN HEIGHT 6.0 METERS
OVEN VOLUME 1348. CUBIC FEET
TONS COKE/PUSH 24.
AVG. COKING TIME, HRS. 17.5
NO. CYCLES/DAY 82.
BULK DENSITY 50. LBS/CUBIC FT.
YIELD .70
TONS COAL/YEAR 1011967.

CAPITAL COST:

PPSES: 504. DOORS

UNITS OPTION
COKE 5

CAPACITY: .708 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST

CATEGORY

COST IN DOLLARS

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	551400.
INSTRUMENTATION	51900.
PIPING	75700.
ELECTRICAL	110300.
FOUNDATIONS	27000.
STRUCTURAL	87900.
SITE WORK	4200.
INSULATION	8600.
PROTECTIVE COATING	14000.
BUILDINGS	12200.
EQUIPMENT/MATERIAL LABOR	177900.

DIRECT COST SUBTOTAL 1121100.

*** INDIRECT COST ***

FIELD OVERHEAD	154800.
CONTRACTORS FEE	75700.
ENGINEERING	148900.
FREIGHT	46100.
OFFSITE WORK	23200.
TAXES	43800.
SHAKEDOWN	43900.
SPARES	39000.
CONTINGENCY	378400.

INDIRECT COST SUBTOTAL 953800.

INTEREST DURING INSTALLATION 150100.

TOTAL COST 2225000.

TOTAL COST WITH RETROFIT 2696700.

OPERATING COST:

PPSES: 504. DOORS UNITS OPTION
COKE 5

CAPACITY: .708 MILLION TONS/YEAR

CATEGORY	QUANTITY	RATE	ANNUAL COST
----------	----------	------	-------------

*** UTILITIES ***

WATER	20772. MGAL/YR	\$.1595/1000 GAL	3300.
ELECTRICITY	3026942. KWH/YR	\$.0266/KWH	80600.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.

*** OPERATING LABOR ***

DIRECT	8760. HRS/YR	\$14.34/HR	125700. (C)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (C)

*** MAINTENANCE & SUPPLIES ***

DIRECT LABOR	33977. HRS/YR	\$14.34/HR	487400. (C)
SUPERVISION	6795. HRS/YR	\$17.20/HR	116900. (C)
MATERIALS			236400. (C)
SUPPLIES			128800. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	472. TON/YR	\$ 8.25/TON	3900.

DIRECT OPERATING COST	1213100.
-----------------------	----------

PAYROLL OVERHEAD =20.0% OF A+B+C+D	152000.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F	562700.
TOTAL OPERATING COST	1927800.
OPERATING COST IN DOLLARS PER TON PRODUCTION	2.72
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED	8167.21
OPERATING COST AS PERCENT OF CAPITAL COST	71.5
INSTALLATION TIME IN WEEKS	104.
ESTIMATED LIFE OF SYSTEM IN YEARS	15.
KWH PER TON CAPACITY	4.3
CAPITAL RECOVERY (13.15% OF TOTAL CAPITAL)	354500.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)	53900.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)	53900.
TOTAL ANNUALIZED COST - RETROFIT	2390100.
- NEW	2309300.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 504. DOORS	COKE	6

CAPACITY: .708 MILLION TONS/YEAR

PARTICULATE

LOAD IN:	.500000 LBS/TON COAL	
ALLOWABLE:	.057500 LBS/TON COAL	EFFICIENCY: 88.5%
	6.99 LBS/HR	

BSU

LOAD IN:	.500000 LBS/TON COAL	
ALLOWABLE:	.110000 LBS/TON COAL	EFFICIENCY: 78.0%
	13.38 LBS/HR	

BAP

LOAD IN:	.003000 LBS/TON COAL	
ALLOWABLE:	.000660 LBS/TON COAL	EFFICIENCY: 78.0%
	.06 LBS/HR	

BENZENE

LOAD IN:	.010000 LBS/TON COAL	
ALLOWABLE:	.003500 LBS/TON COAL	EFFICIENCY: 65.0%
	.43 LBS/HR	

DUST COLLECTED PER DAY: .6 TONS(DRY)

TEMP OUT OF PROCESS:	120. F
EXHAUST TEMPERATURE:	100. F

SCFM FLOW:	10000. AT 70. F
ACFM FLOW:	11000. AT 100. F

L/G RATIO: 8.0

PROCESS WATER FLOW: 80. GPM

COOLING WATER FLOW: 0. GPM

SUSPENDED SOLIDS OUT: 1064. MG/L %SOLIDS: .1

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 504. DOORS	COKE	6

CONTROL SYSTEM CONFIGURATION:

VENTURI SCRUBBER
MIST ELIMINATOR
FAN AND DRIVE
DUCTWORK
STACK
CANOPY HOOD
WASTEWATER RECYCLE SYSTEM
DAMPERS
WASTE WATER RETURN SYSTEM
WATER PUMPING SYSTEM
FAN AND DRIVE ELECTRICAL
COKE OVEN DOOR CLEAN & MAINT

FEET OF ADDITIONAL DUCT:	350.	DIAMETER: 2.
TOTAL PRESSURE DROP:	35.	INCHES
2 FANS @ 101. HP EACH	SPARE FAN CAPACITY: 100.x	
OPERATING HOURS AT FULL HP:	8322.	
OPERATING HOURS AT REDUCED HP:	0.	
STACK HEIGHT:	100.	DIAMETER: 2.
NO. OF OVENS	60.	
HOOD SIZE:	16.	SQ.FT.
OVEN HEIGHT	6.0	METERS
OVEN VOLUME	1348.	CUBIC FEET
TONS COKE/PUSH	24.	
AVG. COKING TIME, HRS.	17.5	
NO. CYCLES/DAY	82.	
BULK DENSITY	50.	LBS/CUBIC FT.
YIELD	.70	
TONS COAL/YEAR	1011967.	

CAPITAL COST:

PPSES: 504. DOORS

UNITS OPTION

COKE 6

CAPACITY: .708 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST

CATEGORY

COST IN DOLLARS

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	270300.
INSTRUMENTATION	51900.
PIPING	48100.
ELECTRICAL	74300.
FOUNDATIONS	16400.
STRUCTURAL	48100.
SITE WORK	3000.
INSULATION	5800.
PROTECTIVE COATING	8000.
BUILDINGS	7800.
EQUIPMENT/MATERIAL LABOR	102900.
DIRECT COST SUBTOTAL	636600.

*** INDIRECT COST ***

FIELD OVERHEAD	95000.
CONTRACTORS FEE	44900.
ENGINEERING	113400.
FREIGHT	24900.
OFFSITE WORK	14600.
TAXES	24500.
SHAKEDOWN	27500.
SPARES	25100.
CONTINGENCY	220700.
INDIRECT COST SUBTOTAL	590600.

INTEREST DURING INSTALLATION

92500.

TOTAL COST

1319700.

TOTAL COST WITH RETROFIT

1583100.

OPERATING COST:

PPSES: 504.	DOORS	UNITS	OPTION
		COKE	6

CAPACITY: .708 MILLION TONS/YEAR

CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
----------	----------	------	------------------

*** UTILITIES ***

WATER	7989. MGAL/YR	\$.1595/1000 GAL	1300.
ELECTRICITY	666276. KWH/YR	\$.0266/KWH	17700.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.

*** OPERATING LABOR ***

DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)

*** MAINTENANCE & SUPPLIES ***

DIRECT LABOR	29937. HRS/YR	\$14.34/HR	429400. (C)
SUPERVISION	5987. HRS/YR	\$17.20/HR	103000. (D)
MATERIALS			209100. (E)
SUPPLIES			112300. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	448. TON/YR	\$ 8.25/TON	3700.

DIRECT OPERATING COST	1032300.
-----------------------	----------

PAYROLL OVERHEAD =20.0% OF A+B+C+D	137600.
------------------------------------	---------

PLANT OVERHEAD =50.0% OF A+B+C+D+E+F	504800.
--------------------------------------	---------

TOTAL OPERATING COST	1674700.
----------------------	----------

OPERATING COST IN DOLLARS PER TON PRODUCTION	2.36
--	------

OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED	7479.75
---	---------

OPERATING COST AS PERCENT OF CAPITAL COST	105.8
---	-------

INSTALLATION TIME IN WEEKS	104.
----------------------------	------

ESTIMATED LIFE OF SYSTEM IN YEARS	15.
-----------------------------------	-----

KWH PER TON CAPACITY	.9
----------------------	----

CAPITAL RECOVERY (13.15% OF TOTAL CAPITAL)	208100.
--	---------

ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)	31700.
--	--------

PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)	31700.
--	--------

TOTAL ANNUALIZED COST - RETROFIT	1946200.
----------------------------------	----------

- NEW	1901000.
-------	----------

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	504. DOORS	COKE	7
CAPACITY:	.708 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	.500000 LBS/TON COAL		
ALLOWABLE:	.033500 LBS/TON COAL	EFFICIENCY:	93.3%
	4.07 LBS/HR		
BSO			
LOAD IN:	.500000 LBS/TON COAL		
ALLOWABLE:	.081000 LBS/TON COAL	EFFICIENCY:	83.8%
	9.85 LBS/HR		
BAP			
LOAD IN:	.003000 LBS/TON COAL		
ALLOWABLE:	.000486 LBS/TON COAL	EFFICIENCY:	83.8%
	.06 LBS/HR		
BENZENE			
LOAD IN:	.010000 LBS/TON COAL		
ALLOWABLE:	.002800 LBS/TON COAL	EFFICIENCY:	72.0%
	.34 LBS/HR		
DUST COLLECTED PER DAY:	.6 TONS(DRY)		
TEMP OUT OF PROCESS:	120. F		
EXHAUST TEMPERATURE:	100. F		
SCFM FLOW:	13000. AT 70. F		
ACFM FLOW:	14000. AT 100. F		
L/G RATIO:	8.0		
PROCESS WATER FLOW:	104. GPM		
COOLING WATER FLOW:	0. GPM		
SUSPENDED SOLIDS OUT:	818. MG/L	%SOLIDS:	.1

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 504. DOORS	COKE	7

CONTROL SYSTEM CONFIGURATION:

VENTURI SCRUBBER
 MIST ELIMINATOR
 FAN AND DRIVE
 DUCTWORK
 STACK
 CANOPY HOOD
 WASTEWATER RECYCLE SYSTEM
 DAMPERS
 WASTE WATER RETURN SYSTEM
 WATER PUMPING SYSTEM
 FAN AND DRIVE ELECTRICAL
 COKE OVEN DOOR CLEAN & MAINT

FEET OF ADDITIONAL DUCT:	350.	DIAMETER:	2.
TOTAL PRESSURE DROP:	65.	INCHES	
2 FANS @ 239. HP EACH	SPARE FAN CAPACITY: 100.%		
OPERATING HOURS AT FULL HP:	8322.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	100.	DIAMETER:	2.
NO. OF OVENS	60.		
HOOD SIZE:	16.	SQ.FT.	
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. CUKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1011967.		

CAPITAL COST:

		UNITS	OPTION
PPSES:	504. DOORS	COKE	7
CAPACITY:	.708 MILLION TONS/YEAR		
TOTAL COST	(COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4Q78 COST)		
CATEGORY	COST IN DOLLARS		
*** DIRECT COST ***			
EQUIPMENT OR MATERIAL	340000.		
INSTRUMENTATION	51900.		
PIPING	54600.		
ELECTRICAL	82800.		
FOUNDATIONS	19700.		
STRUCTURAL	51400.		
SITE WORK	3200.		
INSULATION	6500.		
PROTECTIVE COATING	9000.		
BUILDINGS	8900.		
EQUIPMENT/MATERIAL LABOR	115700.		
DIRECT COST SUBTOTAL	743700.		
*** INDIRECT COST ***			
FIELD OVERHEAD	106500.		
CONTRACTORS FEE	52300.		
ENGINEERING	123000.		
FREIGHT	27600.		
OFFSITE WORK	17000.		
TAXES	29300.		
SHAKEDOWN	32800.		
SPARES	29200.		
CONTINGENCY	254300.		
INDIRECT COST SUBTOTAL	672000.		
INTEREST DURING INSTALLATION	107300.		
TOTAL COST	1523000.		
TOTAL COST WITH RETROFIT	1818400.		

OPERATING COST:

PPSES: 504. DOORS UNITS OPTION
COKE 7

CAPACITY: 708 MILLION TONS/YEAR

CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
----------	----------	------	------------------

*** UTILITIES ***

WATER	10386. MGAL/YR	\$.1595/1000 GAL	1700.
ELECTRICITY	1569274. KWH/YR	\$.0266/KWH	41800.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.

*** OPERATING LABOR ***

DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)

*** MAINTENANCE & SUPPLIES ***

DIRECT LABOR	30137. HRS/YR	\$14.34/HR	432300. (C)
SUPERVISION	6027. HRS/YR	\$17.20/HR	103700. (D)
MATERIALS			211300. (E)
SUPPLIES			113500. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	472. TON/YR	\$ 8.25/TON	3900.

DIRECT OPERATING COST	1064000.
-----------------------	----------

PAYROLL OVERHEAD =20.0% OF A+B+C+D	138400.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F	508300.
TOTAL OPERATING COST	1710700.
OPERATING COST IN DOLLARS PER TON PRODUCTION	2.41
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED	7247.46
OPERATING COST AS PERCENT OF CAPITAL COST	94.1
INSTALLATION TIME IN WEEKS	104.
ESTIMATED LIFE OF SYSTEM IN YEARS	15.
KWH PER TON CAPACITY	2.2
CAPITAL RECOVERY (13.15% OF TOTAL CAPITAL)	239100.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)	36400.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)	36400.
TOTAL ANNUALIZED COST - RETROFIT	2022600.
- NEW	1971900.

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	505. TOPSIDE	COKE	2
CAPACITY:	.708 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	.200000 LBS/TON COAL		
ALLOWABLE:	.020000 LBS/TON COAL	EFFICIENCY:	90.0%
	2.31 LBS/HR		
BSO			
LOAD IN:	.250000 LBS/TON COAL		
ALLOWABLE:	.025000 LBS/TON COAL	EFFICIENCY:	90.0%
	2.89 LBS/HR		
BAP			
LOAD IN:	.001000 LBS/TON COAL		
ALLOWABLE:	.000100 LBS/TON COAL	EFFICIENCY:	90.0%
	.01 LBS/HR		
BENZENE			
LOAD IN:	.005000 LBS/TON COAL		
ALLOWABLE:	.000500 LBS/TON COAL	EFFICIENCY:	90.0%
	.06 LBS/HR		
DUST COLLECTED PER DAY:	.2 TONS(DRY)		
TEMP OUT OF PROCESS:	120. F		
EXHAUST TEMPERATURE:	120. F		
SCFM FLOW:	0. AT 70. F		
ACFM FLOW:	0. AT 120. F		
L/G RATIO:	.0		
PROCESS WATER FLOW:	0. GPM		
COOLING WATER FLOW:	0. GPM		
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS:	.0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 505. TOPSIDE	COKE	2

CONTROL SYSTEM CONFIGURATION:

TOPSIDE MAINTENANCE - LEVEL 1

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.2	
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1011967.		

OPERATING COST:

PPSES: 505. TOPSIDE		UNITS	OPTION
		COKE	2
CAPACITY: .708 MILLION TONS/YEAR			
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	0. HRS/YR	\$14.34/HR	0. (C)
SUPERVISION	0. HRS/YR	\$17.20/HR	0. (D)
MATERIALS			0. (E)
SUPPLIES			0. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			155800.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			31200.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			77900.
TOTAL OPERATING COST			264900.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.37
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			2908.53
OPERATING COST AS PERCENT OF CAPITAL COST			.0
INSTALLATION TIME IN WEEKS			8.
ESTIMATED LIFE OF SYSTEM IN YEARS			99.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (10.00% OF TOTAL CAPITAL)			0.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			0.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			0.
TOTAL ANNUALIZED COST - RETROFIT			264900.
- NEW			264900.

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	505. TOPSIDE	COKE	3
CAPACITY:	.708 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	.200000 LBS/TON COAL		
ALLOWABLE:	.010000 LBS/TON COAL	EFFICIENCY:	95.0%
	1.16 LBS/HR		
BSO			
LOAD IN:	.250000 LBS/TON COAL		
ALLOWABLE:	.012500 LBS/TON COAL	EFFICIENCY:	95.0%
	1.44 LBS/HR		
BAP			
LOAD IN:	.001000 LBS/TON COAL		
ALLOWABLE:	.000050 LBS/TON COAL	EFFICIENCY:	95.0%
	.01 LBS/HR		
BENZENE			
LOAD IN:	.005000 LBS/TON COAL		
ALLOWABLE:	.000250 LBS/TON COAL	EFFICIENCY:	95.0%
	.03 LBS/HR		
DUST COLLECTED PER DAY:	.3 TONS(DRY)		
TEMP OUT OF PROCESS:	120. F		
EXHAUST TEMPERATURE:	120. F		
SCFM FLOW:	0. AT 70. F		
ACFM FLOW:	0. AT 120. F		
L/G RATIO:	.0		
PROCESS WATER FLOW:	0. GPM		
COOLING WATER FLOW:	0. GPM		
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS:	.0

GENERAL INFORMATION:

PPSES: 505. TOPSIDE

UNITS OPTION
COKE 3.**CONTROL SYSTEM CONFIGURATION:**

TOPSIDE MAINTENANCE - LEVEL 2

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH		SPARE FAN CAPACITY:	0.2
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1011967.		

OPERATING COST:

		UNITS	OPTION
PPSES:	505. TOPSIDE	COKE	3
CAPACITY:	.708 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	5900. HRS/YR	\$14.34/HR	84600. (C)
SUPERVISION	1180. HRS/YR	\$17.20/HR	20300. (D)
MATERIALS			21200. (E)
SUPPLIES			18900. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			300800.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			52100.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			150400.
TOTAL OPERATING COST			503300.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.71
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			5235.24
OPERATING COST AS PERCENT OF CAPITAL COST			.0
INSTALLATION TIME IN WEEKS			8.
ESTIMATED LIFE OF SYSTEM IN YEARS			99.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (10.00% OF TOTAL CAPITAL)			0.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			0.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			0.
TOTAL ANNUALIZED COST - RETROFIT			503300.
- NEW			503300.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 505. TOPSIDE	COKE	4
CAPACITY:	.708 MILLION TONS/YEAR	
PARTICULATE		
LOAD IN:	.200000 LBS/TON COAL	
ALLOWABLE:	.006000 LBS/TON COAL	EFFICIENCY: 97.0%
	.69 LBS/HR	
BSO		
LOAD IN:	.250000 LBS/TON COAL	
ALLOWABLE:	.007500 LBS/TON COAL	EFFICIENCY: 97.0%
	.87 LBS/HR	
BAP		
LOAD IN:	.001000 LBS/TON COAL	
ALLOWABLE:	.000030 LBS/TON COAL	EFFICIENCY: 97.0%
	.00 LBS/HR	
BENZENE		
LOAD IN:	.005000 LBS/TON COAL	
ALLOWABLE:	.000150 LBS/TON COAL	EFFICIENCY: 97.0%
	.02 LBS/HR	
DUST COLLECTED PER DAY:	.3 TONS(DRY)	
TEMP OUT OF PROCESS:	120. F	
EXHAUST TEMPERATURE:	120. F	
SCFM FLOW:	0. AT 70. F	
ACFM FLOW:	0. AT 120. F	
L/G RATIO:	.0	
PROCESS WATER FLOW:	0. GPM	
COOLING WATER FLOW:	0. GPM	
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 505. TOPSIDE	COKE	4

CONTROL SYSTEM CONFIGURATION:

TOPSIDE MAINTENANCE - LEVEL 1
NEW LIDS AND CASTINGS

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.2	
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1011967.		

CAPITAL COST:

		UNITS	OPTION
PPSES:	505.	TOPSIDE	COKE
CAPACITY:	.708 MILLION TONS/YEAR		
TOTAL COST	(COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST.)		
CATEGORY	COST IN DOLLARS		
*** DIRECT COST ***			
EQUIPMENT OR MATERIAL	55200.		
INSTRUMENTATION	0.		
PIPING	0.		
ELECTRICAL	0.		
FOUNDATIONS	0.		
STRUCIURAL	0.		
SITE WORK	0.		
INSULATION	0.		
PROTECTIVE COATING	0.		
BUILDINGS	0.		
EQUIPMENT/MATERIAL LABOR	0.		
DIRECT COST SUBTOTAL	55200.		
*** INDIRECT COST ***			
FIELD OVERHEAD	0.		
CONTRACTORS FEE	4300.		
ENGINEERING	2000.		
FREIGHT	3800.		
OFFSITE WORK	0.		
TAXES	900.		
SHAKEDOWN	0.		
SPARES	1800.		
CONTINGENCY	12200.		
INDIRECT COST SUBTOTAL	25000.		
INTEREST DURING INSTALLATION	900.		
TOTAL COST	81100.		
TOTAL COST WITH RETROFIT	105400.		

OPERATING COST:

PPSES: 505. TOPSIDE		UNITS	OPTION
		COKE	4
CAPACITY: .708 MILLION TONS/YEAR			
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	600. HRS/YR	\$14.34/HR	8600. (C)
SUPERVISION	120. HRS/YR	\$17.20/HR	2100. (D)
MATERIALS			2200. (E)
SUPPLIES			1900. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			170600.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			33300.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			85300.
TOTAL OPERATING COST			289200.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.41
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			2946.19
OPERATING COST AS PERCENT OF CAPITAL COST			274.4
INSTALLATION TIME IN WEEKS			12.
ESTIMATED LIFE OF SYSTEM IN YEARS			35.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (10.37% OF TOTAL CAPITAL)			10900.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			2100.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			2100.
TOTAL ANNUALIZED COST - RETROFIT			304300.
- NEW			300800.

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	506. COMBUSTION STACK - OLD	COKE	2
CAPACITY:	.708 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	1.300000 LBS/TON COAL		
ALLOWABLE:	.260000 LBS/TON COAL	EFFICIENCY:	80.0%
	30.04 LBS/HR		
BSO			
LOAD IN:	.006000 LBS/TON COAL		
ALLOWABLE:	.001200 LBS/TON COAL	EFFICIENCY:	80.0%
	.14 LBS/HR		
BAP			
LOAD IN:	.000060 LBS/TON COAL		
ALLOWABLE:	.000012 LBS/TON COAL	EFFICIENCY:	80.0%
	.00 LBS/HR		
DUST COLLECTED PER DAY:	1.4 TONS(DRY)		
TEMP OUT OF PROCESS:	450. F		
EXHAUST TEMPERATURE:	450. F		
SCFM FLOW:	67000. AT 70. F		
ACFM FLOW:	115000. AT 450. F		
L/G RATIO:	.0		
PROCESS WATER FLOW:	0. GPM		
COOLING WATER FLOW:	0. GPM		
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS:	.0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 506. COMBUSTION STACK - OLD	COKE	2

CONTROL SYSTEM CONFIGURATION:

HEATING CONTROL AND PATCHING

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	6.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH		SPARE FAN CAPACITY:	0.2
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1011967.		

OPERATING COST:

		UNITS	OPTION
PPSES: 506.	COMBUSTION STACK - OLD	COKE	2
CAPACITY:	.708 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	5900. HRS/YR	\$14.34/HR	84600. (C)
SUPERVISION	1180. HRS/YR	\$17.20/HR	20300. (D)
MATERIALS			21200. (E)
SUPPLIES			18900. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			300800.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			52100.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			150400.
TOTAL OPERATING COST			503300.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.71
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			956.44
OPERATING COST AS PERCENT OF CAPITAL COST			.0
INSTALLATION TIME IN WEEKS			8.
ESTIMATED LIFE OF SYSTEM IN YEARS			99.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (10.00% OF TOTAL CAPITAL)			0.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			0.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			0.
TOTAL ANNUALIZED COST - RETROFIT			503300.
- NEW			503300.

GENERAL INFORMATION:

PPSES: 506. COMBUSTION STACK - OLD UNITS OPTION
COKE 3

CAPACITY: .708 MILLION TONS/YEAR

PARTICULATE

LOAD IN: 1.300000 LBS/TON COAL
ALLOWABLE: .150000 LBS/TON COAL EFFICIENCY: 90.0%
15.02 LBS/HR

BSO

LOAD IN: .006000 LBS/TON COAL
ALLOWABLE: .003000 LBS/TON COAL EFFICIENCY: 50.0%
.35 LBS/HR

BAP

LOAD IN: .000060 LBS/TON COAL
ALLOWABLE: .000030 LBS/TON COAL EFFICIENCY: 50.0%
.00 LBS/HR

DUST COLLECTED PER DAY: 1.6 TONS(DRY)

TEMP OUT OF PROCESS: 450. F
EXHAUST TEMPERATURE: 450. F

SCFM FLOW: 107000. AT 70. F
ACFM FLOW: 184000. AT 450. F

L/G RATIO: .0
PROCESS WATER FLOW: 0. GPM
COOLING WATER FLOW: 0. GPM
SUSPENDED SOLIDS OUT: 0. MG/L %SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 500. COMBUSTION STACK - OLD	CUKE	3

CONTROL SYSTEM CONFIGURATION:

ESP
 FAN AND DRIVE
 DUCTWORK
 DUST HANDLING HOPPER & CONVEYORS
 DAMPERS
 FAN AND DRIVE ELECTRICAL

SCA: 232.	TOTAL PLATE AREA: 51000. SQ.FT. @ 20% SPARE CAPACITY
FEET OF ADDITIONAL DUCT: 250.	DIAMETER: 8.
TOTAL PRESSURE DROP: 6. INCHES	
2 FANS @ 290. HP EACH	SPARE FAN CAPACITY: 100.%
OPERATING HOURS AT FULL HP: 8760.	
OPERATING HOURS AT REDUCED HP: 0.	
STACK HEIGHT: 0.	DIAMETER: 0.
NO. OF OVENS: 60.	
OVEN HEIGHT: 6.0 METERS	
OVEN VOLUME: 1348. CUBIC FEET	
TONS COKE/PUSH: 24.	
AVG. CURING TIME, HRS.: 17.5	
NO. CYCLES/DAY: 82.	
BULK DENSITY: 50. LBS/CUBIC FT.	
YIELD: .70	
TONS COAL/YEAR: 1011967.	

CAPITAL COST:

PPSES: 506.	COMBUSTION STACK - OLD	UNITS CORE	OPTION 3
-------------	------------------------	---------------	-------------

CAPACITY: .706 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST

CATEGORY	COST IN DOLLARS
----------	-----------------

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	922400.	
INSTRUMENTATION	0.	
PIPING	0.	
ELECTRICAL	57200.	
FOUNDATIONS	9000.	
STRUCTURAL	56700.	
SITE WORK	6100.	
INSULATION	45800.	
PROTECTIVE COATING	7000.	
BUILDINGS	6700.	
EQUIPMENT/MATERIAL LABOR	432600.	
DIRECT COST SUBTOTAL		1543500.

*** INDIRECT COST ***

FIELD OVERHEAD	242800.	
CONTRACTORS FEE	158900.	
ENGINEERING	141700.	
FREIGHT	73200.	
OFFSITE WORK	36000.	
TAXES	55600.	
SHAKEDOWN	69300.	
SPARES	66800.	
CONTINGENCY	505600.	
INDIRECT COST SUBTOTAL		1349900.

INTEREST DURING INSTALLATION	242600.
------------------------------	---------

TOTAL COST	3136000.
------------	----------

TOTAL COST WITH RETROFIT	3794500.
--------------------------	----------

OPERATING COST:

PPSES: 506. COMBUSTION STACK - OLD UNITS OPTION
COKE 3

CAPACITY: .708 MILLION TONS/YEAR

CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
----------	----------	------	------------------

*** UTILITIES ***

WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	2408996. KWH/YR	\$.0266/KWH	64100.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.

*** OPERATING LABOR ***

DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)

*** MAINTENANCE & SUPPLIES ***

DIRECT LABOR	7043. HRS/YR	\$14.34/HR	101000. (C)
SUPERVISION	1409. HRS/YR	\$17.20/HR	24200. (D)
MATERIALS			59100. (E)
SUPPLIES			27700. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	592. TON/YR	\$ 8.25/TON	4900.

DIRECT OPERATING COST	436800.
-----------------------	---------

PAYROLL OVERHEAD =20.0% OF A+B+C+D	56200.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F	183900.
TOTAL OPERATING COST	676900.
OPERATING COST IN DOLLARS PER TON PRODUCTION	.96
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED	1143.41
OPERATING COST AS PERCENT OF CAPITAL COST	17.8
INSTALLATION TIME IN WEEKS	104.
ESTIMATED LIFE OF SYSTEM IN YEARS	20.
KWH PER TON CAPACITY	3.4
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)	445700.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)	75900.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)	75900.
TOTAL ANNUALIZED COST - RETROFIT	1274400.
- NEW	1170700.

GENERAL INFORMATION:

PPSES: 506. COMBUSTION STACK - OLD UNITS OPTION
COKE 4

CAPACITY: .708 MILLION TONS/YEAR

PARTICULATE

LOAD IN: 1.500000 LBS/TON COAL
ALLOWABLE: .026000 LBS/TON COAL EFFICIENCY: 98.0%
3.00 LBS/HR

BSO

LOAD IN: .006000 LBS/TON COAL
ALLOWABLE: .002400 LBS/TON COAL EFFICIENCY: 60.0%
.20 LBS/HR

HAP

LOAD IN: .000060 LBS/TON COAL
ALLOWABLE: .000024 LBS/TON COAL EFFICIENCY: 60.0%
.00 LBS/HR

DUST COLLECTED PER DAY: 1.8 TONS(DRY)

TEMP OUT OF PROCESS: 450. F
EXHAUST TEMPERATURE: 450. F

SCFM FLOW: 107000. A1 70. F
ACFM FLOW: 184000. A1 450. F

L/G RATIO: .0
PROCESS WATER FLOW: 0. GPM
COOLING WATER FLOW: 0. GPM
SUSPENDED SOLIDS OUT: 0. MG/L %SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 506. COMBUSTION STACK - OLD	COKE	4

CONTROL SYSTEM CONFIGURATION:

ESP
 FAN AND DRIVE
 DUCTWORK
 DUST HANDLING HOPPER & CONVEYORS
 DAMPERS
 FAN AND DRIVE ELECTRICAL

SCA: 450.	TOTAL PLATE AREA: 99000. SQ.FT. @ 20% SPARE CAPACITY
FEET OF ADDITIONAL DUCT: 250.	DIAMETER: 8.
TOTAL PRESSURE DROP: 6. INCHES	
2 FANS @ 290. HP EACH	SPARE FAN CAPACITY: 100.%
OPERATING HOURS AT FULL HP: 6760.	
OPERATING HOURS AT REDUCED HP: 0.	
STACK HEIGHT: 0.	DIAMETER: 0.
NO. OF OVENS: 60.	
OVEN HEIGHT: 6.0 METERS	
OVEN VOLUME: 1348. CUBIC FEET	
TONS COKE/PUSH: 24.	
AVG. COKING TIME, HRS.: 17.5	
NO. CYCLES/DAY: 82.	
BULK DENSITY: 50. LBS/CUBIC FT.	
YIELD: .70	
TONS COAL/YEAR: 1011967.	

CAPITAL COST:

PPSES: 506.	COMBUSTION STACK - OLD	UNITS LUKE	OPTION 4
-------------	------------------------	---------------	-------------

CAPACITY: .708 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST)

CATEGORY	COST IN DOLLARS
----------	-----------------

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	1232700.	
INSTRUMENTATION	0.	
PIPING	0.	
ELECTRICAL	78700.	
FOUNDATIONS	10500.	
STRUCTURAL	77500.	
PILE WORK	8800.	
INSULATION	66600.	
PROTECTIVE COATING	9300.	
BUILDINGS	9800.	
EQUIPMENT/MATERIAL LABOR	570700.	
DIRECT COST SUBTOTAL		2064600.

*** INDIRECT COST ***

FIELD OVERHEAD	328700.	
CONTRACTORS FEE	219300.	
ENGINEERING	193100.	
FREIGHT	89700.	
OFFSITE WORK	51700.	
TAXES	72600.	
SHAKEDOWN	95500.	
SPARES	93000.	
CONTINGENCY	669700.	
INDIRECT COST SUBTOTAL		1813300.

INTEREST DURING INSTALLATION	340900.
------------------------------	---------

TOTAL COST	4218800.
------------	----------

TOTAL COST WITH RETROFIT	5093900.
--------------------------	----------

OPERATING COST:

PPSES: 506. COMBUSTION STACK - OLD UNITS OPTION
CUKE 4

CAPACITY: .708 MILLION TONS/YEAR

CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
----------	----------	------	------------------

*** UTILITIES ***

WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	3464055. KWH/YR	\$.0266/KWH	92200.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.

*** OPERATING LABOR ***

DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)

*** MAINTENANCE & SUPPLIES ***

DIRECT LABOR	7043. HRS/YR	\$14.34/HR	101000. (C)
SUPERVISION	1409. HRS/YR	\$17.20/HR	24200. (D)
MATERIALS			59100. (E)
SUPPLIES			27700. (F)
WATER TREATMENT			0.
SOLID WASTE			
DISPOSAL	645. TON/YR	\$ 8.25/TON	5300.

DIRECT OPERATING COST 465300.

PAYROLL OVERHEAD =20.0% OF A+B+C+D 56200.

PLANT OVERHEAD =50.0% OF A+B+C+D+E+F 183900.

TOTAL OPERATING COST 705400.

OPERATING COST IN DOLLARS PER TON PRODUCTION 1.00

OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED 1094.28

OPERATING COST AS PERCENT OF CAPITAL COST 13.8

INSTALLATION TIME IN WEEKS 104.

ESTIMATED LIFE OF SYSTEM IN YEARS 20.

KWH PER TON CAPACITY 4.9

CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL) 598300.

ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL) 101900.

PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL) 101900.

TOTAL ANNUALIZED COST - RETROFIT 1507500.

- NEW 1369700.

GENERAL INFORMATION:

PPSES: 506. COMBUSTION STACK - OLD UNITS OPTION
COKE 5

CAPACITY: .708 MILLION TONS/YEAR

PARTICULATE

LOAD IN: 1.500000 LBS/TON COAL
ALLOWABLE: .026000 LBS/TON COAL EFFICIENCY: 98.0%
3.00 LBS/HR

BSO

LOAD IN: .006000 LBS/TON COAL
ALLOWABLE: .003000 LBS/TON COAL EFFICIENCY: 50.0%
.35 LBS/HR

BAP

LOAD IN: .000060 LBS/TON COAL
ALLOWABLE: .000030 LBS/TON COAL EFFICIENCY: 50.0%
.00 LBS/HR

DUST COLLECTED PER DAY: 1.8 TONS(DRY)

TEMP OUT OF PROCESS: 450. F
EXHAUST TEMPERATURE: 275. F

SCFM FLOW: 198000. AT 70. F
ACFM FLOW: 275000. AT 275. F

L/G RATIO: .0
PROCESS WATER FLOW: 0. GPM
COOLING WATER FLOW: 0. GPM
SUSPENDED SOLIDS OUT: 0. MG/L %SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 506. COMBUSTION STACK - OLD	CUKE	5

CONTROL SYSTEM CONFIGURATION:

BAGHOUSE
FAN AND DRIVE
DUCTWORK
DAMPERS
FAN AND DRIVE ELECTRICAL

A/C: 3.0	TOTAL CLOTH AREA: 110000. SQ.FT. @ 20% SPARE CAPACITY
FEET OF ADDITIONAL DUCT:	250. DIAMETER: 9.
TOTAL PRESSURE DROP:	10. INCHES
3 FANS @ 346. HP EACH	SPARE FAN CAPACITY: 50.2
OPERATING HOURS AT FULL HP:	6760.
OPERATING HOURS AT REDUCED HP:	0.
STACK HEIGHT:	0. DIAMETER: 0.
NO. OF OVENS	60.
OVEN HEIGHT	6.0 METERS
OVEN VOLUME	1348. CUBIC FEET
TONS COKE/PUSH	24.
AVG. COKING TIME, HRS.	17.5
NO. CYCLES/DAY	62.
BULK DENSITY	50. LBS/CUBIC FT.
YIELD	.70
TONS COAL/YEAR	1011967.

CAPITAL COST:

		UNITS	OPTION
PPSES: 506.	COMBUSTION STACK - OLD	COKE	5

CAPACITY: .708 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST

CATEGORY	COST IN DOLLARS
----------	-----------------

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	954500.	
INSTRUMENTATION	15900.	
PIPING	1500.	
ELECTRICAL	19900.	
FOUNDATIONS	36900.	
STRUCTURAL	11900.	
SITE WORK	7200.	
INSULATION	0.	
PROTECTIVE COATING	16800.	
BUILDINGS	36000.	
EQUIPMENT/MATERIAL LABOR	330200.	
DIRECT COST SUBTOTAL		1458300.

*** INDIRECT COST ***

FIELD OVERHEAD	174700.	
CONTRACTORS FEE	127900.	
ENGINEERING	118900.	
FREIGHT	46900.	
OFFSITE WORK	27500.	
TAXES	54500.	
SHAKEDOWN	58100.	
SPARES	53900.	
CURTINGENCY	445800.	
INDIRECT COST SUBTOTAL		1108200.

INTEREST DURING INSTALLATION	164100.
------------------------------	---------

TOTAL COST	2730600.
------------	----------

TOTAL COST WITH RETROFIT	3302700.
--------------------------	----------

OPERATING COST:

PPSES: 506. COMBUSTION STACK - OLD UNITS OPTION
CUKE 5

CAPACITY: .706 MILLION TONS/YEAR

CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
----------	----------	------	------------------

*** UTILITIES ***

WATER	U. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	3985249. KWH/YR	\$.0266/KWH	106100.
STEAM	U. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	U. GAL/YR	\$.4160/GAL	0.

*** OPERATING LABOR ***

DIRECT	2920. HRS/YR	\$14.34/HR	41900. (A)
SUPERVISION	564. HRS/YR	\$17.20/HR	10000. (B)

*** MAINTENANCE & SUPPLIES ***

DIRECT LABOR	6017. HRS/YR	\$14.34/HR	97800. (C)
SUPERVISION	1363. HRS/YR	\$17.20/HR	23500. (D)
MATERIALS			58600. (E)
SUPPLIES			33300. (F)
WATER TREATMENT			0.
SOLID WASTE			
DISPOSAL	645. TON/YR	\$ 8.25/TON	5300.

DIRECT OPERATING COST 376500.

PAYROLL OVERHEAD =20.0% OF A+B+C+D	34600.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F	132600.
TOTAL OPERATING COST	543700.
OPERATING COST IN DOLLARS PER TON PRODUCTION	.77
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED	843.44
OPERATING COST AS PERCENT OF CAPITAL COST	16.5
INSTALLATION TIME IN WEEKS	83.
ESTIMATED LIFE OF SYSTEM IN YEARS	20.
KWH PER TON CAPACITY	5.6
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)	387900.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)	66100.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)	66100.
TOTAL ANNUALIZED COST - RETROFIT	1063800.
- NEW	973600.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 507. COKE HANDLING	COKE	2

CAPACITY: 2.834 MILLION TONS/YEAR

PARTICULATE

LOAD IN: 1.000000 LBS/TON COAL

ALLOWABLE: .109000 LBS/TON COAL EFFICIENCY: 89.1%
53.02 LBS/HR

DUST COLLECTED PER DAY: 4.9 TONS(DRY)

TEMP OUT OF PROCESS: 70. F

EXHAUST TEMPERATURE: 70. F

SCFM FLOW: 90000. AT 70. F

ACFM FLOW: 90000. AT 70. F

L/G RATIO: .0

PROCESS WATER FLOW: 0. GPM

COOLING WATER FLOW: 0. GPM

SUSPENDED SOLIDS OUT: 0. MG/L %SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 507. COKE HANDLING	COKE	2

CONTROL SYSTEM CONFIGURATION:

BAGHOUSE
FAN AND DRIVE
DUCTWORK
CANOPY HOOD
CONVEYOR TRANS PT. HOOD
DAMPERS
FAN AND DRIVE ELECTRICAL

A/C: 6.0	TOTAL CLOTH AREA: 18000. SQ.FT. @ 20% SPARE CAPACITY
FEET OF ADDITIONAL DUCT: 200.	DIAMETER: 5.
TOTAL PRESSURE DROP: 8. INCHES	
2 FANS @ 189. HP EACH	SPARE FAN CAPACITY: 100.%
OPERATING HOURS AT FULL HP: 8322.	
OPERATING HOURS AT REDUCED HP: 0.	
STACK HEIGHT: 0.	DIAMETER: 0.
NO. OF OVENS 60.	
HOOD SIZE: 196. SQ.FT.	
OVEN HEIGHT 6.0 METERS	
OVEN VOLUME 1348. CUBIC FEET	
TONS COKE/PUSH 24.	
AVG. COKING TIME, HRS. 17.5	
NO. CYCLES/DAY 82.	
BULK DENSITY 50. LBS/CUBIC FT.	
YIELD .70	
TONS COAL/YEAR 4047868.	

CAPITAL COST:

		UNITS	OPTION
PPSES: 507.	COKE HANDLING	COKE	2

CAPACITY: 2.834 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4Q78 COST.)

CATEGORY	COST IN DOLLARS	
*** DIRECT COST ***		
EQUIPMENT OR MATERIAL	396800.	
INSTRUMENTATION	4000.	
PIPING	400.	
ELECTRICAL	12600.	
FOUNDATIONS	12300.	
STRUCTURAL	46900.	
SITE WORK	1800.	
INSULATION	0.	
PROTECTIVE COATING	18800.	
BUILDINGS	9000.	
EQUIPMENT/MATERIAL LABOR	99900.	
DIRECT COST SUBTOTAL		607000.
*** INDIRECT COST ***		
FIELD OVERHEAD	71500.	
CONTRACTORS FEE	51800.	
ENGINEERING	63800.	
FREIGHT	20100.	
OFFSITE WORK	7600.	
TAXES	24200.	
SHAKEDOWN	22700.	
SPARES	20300.	
CONTINGENCY	219100.	
INDIRECT COST SUBTOTAL		501100.
INTEREST DURING INSTALLATION		60000.
TOTAL COST		1168100.
TOTAL COST WITH RETROFIT		1299200.

OPERATING COST:

		UNITS	OPTION
PPSES: 507.	COKE HANDLING	COKE	2
CAPACITY:	2.834 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	1375802. KWH/YR	\$.0266/KWH	36600.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	2920. HRS/YR	\$14.34/HR	41900. (A)
SUPERVISION	584. HRS/YR	\$17.20/HR	10000. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	4100. HRS/YR	\$14.34/HR	58800. (C)
SUPERVISION	820. HRS/YR	\$17.20/HR	14100. (D)
MATERIALS			28700. (E)
SUPPLIES			16300. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	1803. TON/YR	\$ 8.25/TON	14900.
DIRECT OPERATING COST			221300.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			25000.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			84900.
TOTAL OPERATING COST			331200.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.12
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			183.66
OPERATING COST AS PERCENT OF CAPITAL COST			25.5
INSTALLATION TIME IN WEEKS			83.
ESTIMATED LIFE OF SYSTEM IN YEARS			20.
KWH PER TON CAPACITY			.5
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)			152600.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			26000.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL).			26000.
TOTAL ANNUALIZED COST - RETROFIT			535800.
- NEW			515200.

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	508. COAL PREHEATER	COKE	2
CAPACITY:	.992 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	7.050000 LBS/TON COAL		
ALLOWABLE:	.352500 LBS/TON COAL	EFFICIENCY:	95.0%
	60.01 LBS/HR		
BSO			
LOAD IN:	1.050000 LBS/TON COAL		
ALLOWABLE:	.420000 LBS/TON COAL	EFFICIENCY:	60.0%
	71.50 LBS/HR		
BAP			
LOAD IN:	.000390 LBS/TON COAL		
ALLOWABLE:	.000156 LBS/TON COAL	EFFICIENCY:	60.0%
	.03 LBS/HR		
BENZENE			
LOAD IN:	.014000 LBS/TON COAL		
ALLOWABLE:	.007000 LBS/TON COAL	EFFICIENCY:	50.0%
	1.19 LBS/HR		
DUST COLLECTED PER DAY:	13.0 TONS(DRY)		
TEMP OUT OF PROCESS:	180. F		
EXHAUST TEMPERATURE:	180. F		
SCFM FLOW:	17000. AT	70. F	
ACFM FLOW:	20000. AT	180. F	
L/G RATIO:	6.5		
PROCESS WATER FLOW:	111. GPM		
COOLING WATER FLOW:	0. GPM		
SUSPENDED SOLIDS OUT:	15206. MG/L	%SOLIDS:	1.5

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 508. COAL PREHEATER	COKE	2

CONTROL SYSTEM CONFIGURATION:

VENTURI SCRUBBER
 MIST ELIMINATOR
 FAN AND DRIVE
 DUCTWORK
 WASTEWATER RECYCLE SYSTEM
 DAMPERS
 WASTE WATER RETURN SYSTEM
 WATER PUMPING SYSTEM
 FAN AND DRIVE ELECTRICAL

FEET OF ADDITIONAL DUCT:	100.	DIAMETER:	3.
TOTAL PRESSURE DROP:	18.	INCHES	
2 FANS @ 94. HP EACH	SPARE FAN CAPACITY: 100.%		
OPERATING HOURS AT FULL HP:	8322.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	12.5		
NO. CYCLES/DAY	115.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1416755.		

CAPITAL COST:

		UNITS	OPTION
PPSES: 508.	COAL PREHEATER	COKE	2

CAPACITY: .992 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4Q78 COST.)

CATEGORY	COST IN DOLLARS	
*** DIRECT COST ***		
EQUIPMENT OR MATERIAL	280800.	
INSTRUMENTATION	51600.	
PIPING	56700.	
ELECTRICAL	84800.	
FOUNDATIONS	18500.	
STRUCTURAL	29100.	
SITE WORK	3400.	
INSULATION	6600.	
PROTECTIVE COATING	7100.	
BUILDINGS	9300.	
EQUIPMENT/MATERIAL LABOR	100300.	
DIRECT COST SUBTOTAL		648200.
*** INDIRECT COST ***		
FIELD OVERHEAD	97500.	
CONTRACTORS FEE	45400.	
ENGINEERING	111800.	
FREIGHT	18800.	
OFFSITE WORK	17300.	
TAXES	24600.	
SHAKEDOWN	31400.	
SPARES	29200.	
CONTINGENCY	217900.	
INDIRECT COST SUBTOTAL		593900.
INTEREST DURING INSTALLATION		101000.
TOTAL COST		1343100.
TOTAL COST WITH RETROFIT		1474200.

OPERATING COST:

		UNITS	OPTION
PPSES:	508. COAL PREHEATER	COKE	2
CAPACITY:	.992 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	11035. MGAL/YR	\$.1595/1000 GAL	1800.
ELECTRICITY	548080. KWH/YR	\$.0266/KWH	14600.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	8567. HRS/YR	\$14.34/HR	122900. (C)
SUPERVISION	1713. HRS/YR	\$17.20/HR	29500. (D)
MATERIALS			104800. (E)
SUPPLIES			40200. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	9489. TON/YR	\$ 8.25/TON	78300.
DIRECT OPERATING COST			547900.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			61600.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			226600.
TOTAL OPERATING COST			836100.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.84
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			176.23
OPERATING COST AS PERCENT OF CAPITAL COST			56.7
INSTALLATION TIME IN WEEKS			104.
ESTIMATED LIFE OF SYSTEM IN YEARS			15.
KWH PER TON CAPACITY			.6
CAPITAL RECOVERY (13.15% OF TOTAL CAPITAL)			193800.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			29500.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			29500.
TOTAL ANNUALIZED COST - RETROFIT			1088900.
- NEW			1066500.

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	508. COAL PREHEATER	COKE	3
CAPACITY:	.992 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	7.050000 LBS/TON COAL		
ALLOWABLE:	.352500 LBS/TON COAL	EFFICIENCY:	95.0%
	60.01 LBS/HR		
BSO			
LOAD IN:	1.050000 LBS/TON COAL		
ALLOWABLE:	.577500 LBS/TON COAL	EFFICIENCY:	45.0%
	98.31 LBS/HR		
BAP			
LOAD IN:	.000390 LBS/TON COAL		
ALLOWABLE:	.000214 LBS/TON COAL	EFFICIENCY:	45.0%
	.04 LBS/HR		
BENZENE			
LOAD IN:	.014000 LBS/TON COAL		
ALLOWABLE:	.007700 LBS/TON COAL	EFFICIENCY:	45.0%
	1.31 LBS/HR		
DUST COLLECTED PER DAY:	13.0 TONS(DRY)		
TEMP OUT OF PROCESS:	180. F		
EXHAUST TEMPERATURE:	180. F		
SCFM FLOW:	17000. AT 70. F		
ACFM FLOW:	20000. AT 180. F		
L/G RATIO:	.0		
PROCESS WATER FLOW:	0. GPM		
COOLING WATER FLOW:	0. GPM		
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS:	.0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 508. COAL PREHEATER	COKE	3

CONTROL SYSTEM CONFIGURATION:

ESP
FAN AND DRIVE
DUCTWORK
DUST HANDLING HOPPER & CONVEYORS
DAMPERS
FAN AND DRIVE ELECTRICAL

SCA: 324.	TOTAL PLATE AREA:	8000. SQ.FT. @ 20% SPARE CAPACITY
FEET OF ADDITIONAL DUCT:	100.	DIAMETER: 3.
TOTAL PRESSURE DROP:	4.	INCHES
2 FANS @ 21. HP EACH	SPARE FAN CAPACITY:	100.%
OPERATING HOURS AT FULL HP:	8322.	
OPERATING HOURS AT REDUCED HP:	0.	
STACK HEIGHT:	0.	DIAMETER: 0.
NO. OF OVENS	60.	
OVEN HEIGHT	6.0	METERS
OVEN VOLUME	1348.	CUBIC FEET
TONS COKE/PUSH	24.	
AVG. COKING TIME, HRS.	12.5	
NO. CYCLES/DAY	115.	
BULK DENSITY	50.	LBS/CUBIC FT.
YIELD	.70	
TONS COAL/YEAR	1416755.	

CAPITAL COST:

	UNITS	OPTION
PPSES: 508. COAL PREHEATER	COKE	3

CAPACITY: .992 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4Q78 COST.)

CATEGORY	COST IN DOLLARS	
*** DIRECT COST ***		
EQUIPMENT OR MATERIAL	328700.	
INSTRUMENTATION	0.	
PIPING	0.	
ELECTRICAL	26600.	
FOUNDATIONS	4400.	
STRUCTURAL	37200.	
SITE WORK	2100.	
INSULATION	16000.	
PROTECTIVE COATING	5000.	
BUILDINGS	2400.	
EQUIPMENT/MATERIAL LABOR	143700.	
DIRECT COST SUBTOTAL		566100.
*** INDIRECT COST ***		
FIELD OVERHEAD	94300.	
CONTRACTORS FEE	59200.	
ENGINEERING	75000.	
FREIGHT	18900.	
OFFSITE WORK	12500.	
TAXES	22100.	
SHAKEDOWN	30300.	
SPARES	29700.	
CONTINGENCY	200900.	
INDIRECT COST SUBTOTAL		542900.
INTEREST DURING INSTALLATION		89200.
TOTAL COST		1198200.
TOTAL COST WITH RETROFIT		1311600.

OPERATING COST:

		UNITS	OPTION
PPSES:	508.	COAL PREHEATER	COKE 3
CAPACITY:	.992 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	363839. KWH/YR	\$.0266/KWH	9700.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	2517. HRS/YR	\$14.34/HR	36100. (C)
SUPERVISION	503. HRS/YR	\$17.20/HR	8700. (D)
MATERIALS			19700. (E)
SUPPLIES			9700. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	4744. TON/YR	\$ 8.25/TON	39100.
DIRECT OPERATING COST			278800.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			40100.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			115000.
TOTAL OPERATING COST			433900.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.44
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			91.46
OPERATING COST AS PERCENT OF CAPITAL COST			33.1
INSTALLATION TIME IN WEEKS			104.
ESTIMATED LIFE OF SYSTEM IN YEARS			20.
KWH PER TON CAPACITY			.4
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)			154100.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			26200.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			26200.
TOTAL ANNUALIZED COST - RETROFIT			640400.
- NEW			622600.

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	508. COAL PREHEATER	COKE	4
CAPACITY:	.992 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	7.050000 LBS/TON COAL		
ALLOWABLE:	.141000 LBS/TON COAL	EFFICIENCY:	98.0%
	24.00 LBS/HR		
BSO			
LOAD IN:	1.050000 LBS/TON COAL		
ALLOWABLE:	.420000 LBS/TON COAL	EFFICIENCY:	60.0%
	71.50 LBS/HR		
BAP			
LOAD IN:	.000390 LBS/TON COAL		
ALLOWABLE:	.000156 LBS/TON COAL	EFFICIENCY:	60.0%
	.03 LBS/HR		
BENZENE			
LOAD IN:	.014000 LBS/TON COAL		
ALLOWABLE:	.007000 LBS/TON COAL	EFFICIENCY:	50.0%
	1.19 LBS/HR		
DUST COLLECTED PER DAY:	13.4 TONS(DRY)		
TEMP OUT OF PROCESS:	180. F		
EXHAUST TEMPERATURE:	180. F		
SCFM FLOW:	17000. AT 70. F		
ACFM FLOW:	20000. AT 180. F		
L/G RATIO:	6.5		
PROCESS WATER FLOW:	111. GPM		
COOLING WATER FLOW:	0. GPM		
SUSPENDED SOLIDS OUT:	15206. MG/L	%SOLIDS:	1.5

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 508. COAL PREHEATER	COKE	4

CONTROL SYSTEM CONFIGURATION:

VENTURI SCRUBBER
 MIST ELIMINATOR
 FAN AND DRIVE
 DUCTWORK
 WASTEWATER RECYCLE SYSTEM
 DAMPERS
 WASTE WATER RETURN SYSTEM
 WATER PUMPING SYSTEM
 FAN AND DRIVE ELECTRICAL

FEET OF ADDITIONAL DUCT:	100.	DIAMETER:	3.
TOTAL PRESSURE DROP:	33.	INCHES	
2 FANS @ 173. HP EACH	SPARE FAN CAPACITY: 100.%		
OPERATING HOURS AT FULL HP:	8322.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	12.5		
NO. CYCLES/DAY	115.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1416755.		

CAPITAL COST:

		UNITS	OPTION
PPSES: 508.	COAL PREHEATER	COKE	4

CAPACITY: .992 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4Q78 COST.)

CATEGORY	COST IN DOLLARS	
*** DIRECT COST ***		
EQUIPMENT OR MATERIAL	301700.	
INSTRUMENTATION	51600.	
PIPING	56700.	
ELECTRICAL	84800.	
FOUNDATIONS	19500.	
STRUCTURAL	29100.	
SITE WORK	3400.	
INSULATION	6600.	
PROTECTIVE COATING	7300.	
BUILDINGS	9300.	
EQUIPMENT/MATERIAL LABOR	100400.	
DIRECT COST SUBTOTAL		670400.
*** INDIRECT COST ***		
FIELD OVERHEAD	97900.	
CONTRACTORS FEE	47600.	
ENGINEERING	113500.	
FREIGHT	18900.	
OFFSITE WORK	17800.	
TAXES	26300.	
SHAKEDOWN	33200.	
SPARES	30200.	
CONTINGENCY	224800.	
INDIRECT COST SUBTOTAL		610200.
INTEREST DURING INSTALLATION		104600.
TOTAL COST		1385200.
TOTAL COST WITH RETROFIT		1520500.

OPERATING COST:

		UNITS	OPTION
PPSES:	508. COAL PREHEATER	COKE	4
CAPACITY:	.992 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	11035. MGAL/YR	\$.1595/1000 GAL	1800.
ELECTRICITY	998794. KWH/YR	\$.0266/KWH	26600.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	8767. HRS/YR	\$14.34/HR	125700. (C)
SUPERVISION	1753. HRS/YR	\$17.20/HR	30200. (D)
MATERIALS			107000. (E)
SUPPLIES			41000. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	9788. TON/YR	\$ 8.25/TON	80800.
DIRECT OPERATING COST			568900.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			62300.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			229900.
TOTAL OPERATING COST			861100.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.87
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			175.94
OPERATING COST AS PERCENT OF CAPITAL COST			56.6
INSTALLATION TIME IN WEEKS			104.
ESTIMATED LIFE OF SYSTEM IN YEARS			15.
KWH PER TON CAPACITY			1.0
CAPITAL RECOVERY (13.15% OF TOTAL CAPITAL)			199900.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			30400.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			30400.
TOTAL ANNUALIZED COST - RETROFIT			1121800.
- NEW			1098600.

GENERAL INFORMATION:

PPSES: 508.	COAL PREHEATER	UNITS	OPTION
		COKE	5

CAPACITY: .992 MILLION TONS/YEAR

PARTICULATE

LOAD IN:	7.050000 LBS/TON COAL	
ALLOWABLE:	.070500 LBS/TON COAL	EFFICIENCY: 99.0%
	12.00 LBS/HR	

BSO

LOAD IN:	1.050000 LBS/TON COAL	
ALLOWABLE:	.525000 LBS/TON COAL	EFFICIENCY: 50.0%
	89.38 LBS/HR	

BAP

LOAD IN:	.000390 LBS/TON COAL	
ALLOWABLE:	.000195 LBS/TON COAL	EFFICIENCY: 50.0%
	.03 LBS/HR	

BENZENE

LOAD IN:	.014000 LBS/TON COAL	
ALLOWABLE:	.007000 LBS/TON COAL	EFFICIENCY: 50.0%
	1.19 LBS/HR	

DUST COLLECTED PER DAY: 13.5 TONS(DRY)

TEMP OUT OF PROCESS:	180. F
EXHAUST TEMPERATURE:	180. F

SCFM FLOW:	17000.	AT	70. F
ACFM FLOW:	20000.	AT	180. F

L/G RATIO:	.0	
PROCESS WATER FLOW:	0. GPM	
COOLING WATER FLOW:	0. GPM	
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 508. COAL PREHEATER	COKE	5

CONTROL SYSTEM CONFIGURATION:

ESP
FAN AND DRIVE
DUCTWORK
DUST HANDLING HOPPER & CONVEYORS
DAMPERS
FAN AND DRIVE ELECTRICAL

SCA: 538.	TOTAL PLATE AREA: 13000. SQ. FT. @ 20% SPARE CAPACITY
FEET OF ADDITIONAL DUCT:	100. DIAMETER: 3.
TOTAL PRESSURE DROP:	4. INCHES
2 FANS @ 21. HP EACH	SPARE FAN CAPACITY: 100.%
OPERATING HOURS AT FULL HP:	8322.
OPERATING HOURS AT REDUCED HP:	0.
STACK HEIGHT:	0. DIAMETER: 0.
NO. OF OVENS	60.
OVEN HEIGHT	6.0 METERS
OVEN VOLUME	1348. CUBIC FEET
TONS COKE/PUSH	24.
AVG. COKING TIME, HRS.	12.5
NO. CYCLES/DAY	115.
BULK DENSITY	50. LBS/CUBIC FT.
YIELD	.70
TONS COAL/YEAR	1416755.

CAPITAL COST:

		UNITS	OPTION
PPSES: 508.	COAL PREHEATER	COKE	5
CAPACITY:	.992 MILLION TONS/YEAR		
TOTAL COST	(COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST.)		
CATEGORY	COST IN DOLLARS		
*** DIRECT COST ***			
EQUIPMENT OR MATERIAL	397400.		
INSTRUMENTATION	0.		
PIPING	0.		
ELECTRICAL	31900.		
FOUNDATIONS	4800.		
STRUCTURAL	42400.		
SITE WORK	2800.		
INSULATION	21100.		
PROTECTIVE COATING	5500.		
BUILDINGS	3100.		
EQUIPMENT/MATERIAL LABOR	177500.		
DIRECT COST SUBTOTAL		686500.	
*** INDIRECT COST ***			
FIELD OVERHEAD	115400.		
CONTRACTORS FEE	74000.		
ENGINEERING	87700.		
FREIGHT	23000.		
OFFSITE WORK	16300.		
TAXES	26200.		
SHAKEDOWN	36700.		
SPARES	36100.		
CONTINGENCY	241300.		
INDIRECT COST SUBTOTAL		656700.	
INTEREST DURING INSTALLATION		112500.	
TOTAL COST		1455700.	
TOTAL COST WITH RETROFIT		1594900.	

OPERATING COST:

		UNITS	OPTION
PPSES: 508.	COAL PREHEATER	COKE	5
CAPACITY:	.992 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	471304. KWH/YR	\$.0266/KWH	12500.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	2517. HRS/YR	\$14.34/HR	36100. (C)
SUPERVISION	503. HRS/YR	\$17.20/HR	8700. (D)
MATERIALS			19700. (E)
SUPPLIES			9700. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	4944. TON/YR	\$ 8.25/TON	40800.
DIRECT OPERATING COST			283300.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			40100.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			115000.
TOTAL OPERATING COST			438400.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.44
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			88.67
OPERATING COST AS PERCENT OF CAPITAL COST			27.5
INSTALLATION TIME IN WEEKS			104.
ESTIMATED LIFE OF SYSTEM IN YEARS			20.
KWH PER TON CAPACITY			.5
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)			187300.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			31900.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			31900.
TOTAL ANNUALIZED COST - RETROFIT			689500.
- NEW			667600.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 509. COAL PREPARATION	COKE	2
CAPACITY:	2.834 MILLION TONS/YEAR	
PARTICULATE		
LOAD IN:	.500000 LBS/TON COAL	
ALLOWABLE:	.015000 LBS/TON COAL	EFFICIENCY: 97.0%
	7.30 LBS/HR	
DUST COLLECTED PER DAY:	2.7 TONS(DRY)	
TEMP OUT OF PROCESS:	70. F	
EXHAUST TEMPERATURE:	70. F	
SCFM FLOW:	70000. AT	70. F
ACFM FLOW:	70000. AT	70. F
L/G RATIO:	.0	
PROCESS WATER FLOW:	0. GPM	
COOLING WATER FLOW:	0. GPM	
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 509. COAL PREPARATION	COKE	2

CONTROL SYSTEM CONFIGURATION:

BAGHOUSE
FAN AND DRIVE
DUCTWORK
CONVEYOR TRANS PT. HOOD
DAMPERS
FAN AND DRIVE ELECTRICAL

A/C: 6.0	TOTAL CLOTH AREA: 14000. SQ.FT. @ 20% SPARE CAPACITY
FEET OF ADDITIONAL DUCT: 300.	DIAMETER: 5.
TOTAL PRESSURE DROP: 8. INCHES	
2 FANS @ 147. HP EACH	SPARE FAN CAPACITY: 100.%
OPERATING HOURS AT FULL HP: 8322.	
OPERATING HOURS AT REDUCED HP: 0.	
STACK HEIGHT: 0.	DIAMETER: 0.
NO. OF OVENS 60.	
OVEN HEIGHT 6.0 METERS	
OVEN VOLUME 1348. CUBIC FEET	
TONS COKE/PUSH 24.	
AVG. COKING TIME, HRS. 17.5	
NO. CYCLES/DAY 82.	
BULK DENSITY 50. LBS/CUBIC FT.	
YIELD .70	
TONS COAL/YEAR 4047868.	

CAPITAL COST:

		UNITS	OPTION
PPSES: 509.	COAL PREPARATION	COKE	2
CAPACITY:	2.834 MILLION TONS/YEAR		

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4Q78 COST.)

CATEGORY	COST IN DOLLARS	
*** DIRECT COST ***		
EQUIPMENT OR MATERIAL	252300.	
INSTRUMENTATION	4000.	
PIPING	500.	
ELECTRICAL	9100.	
FOUNDATIONS	4500.	
STRUCTURAL	24100.	
SITE WORK	500.	
INSULATION	0.	
PROTECTIVE COATING	16100.	
BUILDINGS	0.	
EQUIPMENT/MATERIAL LABOR	73600.	
DIRECT COST SUBTOTAL		384700.
*** INDIRECT COST ***		
FIELD OVERHEAD	45900.	
CONTRACTORS FEE	27300.	
ENGINEERING	35100.	
FREIGHT	23200.	
OFFSITE WORK	1000.	
TAXES	15300.	
SHAKEDOWN	7400.	
SPARES	7500.	
CONTINGENCY	160000.	
INDIRECT COST SUBTOTAL		322700.
INTEREST DURING INSTALLATION		26300.
TOTAL COST		733700.
TOTAL COST WITH RETROFIT		814700.

OPERATING COST:

		UNITS	OPTION
PPSES: 509.	COAL PREPARATION	COKE	2
CAPACITY:	2.834 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	1016568. KWH/YR	\$.0266/KWH	27100.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	500. HRS/YR	\$14.34/HR	7200. (A)
SUPERVISION	100. HRS/YR	\$17.20/HR	1700. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	3000. HRS/YR	\$14.34/HR	43000. (C)
SUPERVISION	600. HRS/YR	\$17.20/HR	10300. (D)
MATERIALS			17600. (E)
SUPPLIES			11400. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	982. TON/YR	\$ 8.25/TON	8100.
DIRECT OPERATING COST			126400.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			12400.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			45600.
TOTAL OPERATING COST			184400.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.07
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			187.86
OPERATING COST AS PERCENT OF CAPITAL COST			22.6
INSTALLATION TIME IN WEEKS			52.
ESTIMATED LIFE OF SYSTEM IN YEARS			20.
KWH PER TON CAPACITY			.4
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)			95700.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			16300.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			16300.
TOTAL ANNUALIZED COST - RETROFIT			312700.
- NEW			300000.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 510. COAL STORAGE YARD	COKE	2

CAPACITY: 2.834 MILLION TONS/YEAR

PARTICULATE

LOAD IN: .150000 LBS/TON COAL

ALLOWABLE: .060000 LBS/TON COAL EFFICIENCY: 60.0%
27.73 LBS/HR

DUST COLLECTED PER DAY: .5 TONS(DRY)

TEMP OUT OF PROCESS: 70. F

EXHAUST TEMPERATURE: 70. F

SCFM FLOW: 0. AT 70. F

ACFM FLOW: 0. AT 70. F

L/G RATIO: .0

PROCESS WATER FLOW: 170. GPM

COOLING WATER FLOW: 0. GPM

SUSPENDED SOLIDS OUT: 0. MG/L XSOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 510. COAL STORAGE YARD	COKE	2

CONTROL SYSTEM CONFIGURATION:

TRANSFER POINT SPRAY
SPRAY TRUCK
WATER PUMPING SYSTEM

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.2	
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	4047868.		

CAPITAL COST:

	UNITS	OPTION
PPSES: 510. COAL STORAGE YARD	COKE	2
CAPACITY: 2.834 MILLION TONS/YEAR		

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4Q78 COST.)

CATEGORY	COST IN DOLLARS	
*** DIRECT COST ***		
EQUIPMENT OR MATERIAL	90100.	
INSTRUMENTATION	3800.	
PIPING	22900.	
ELECTRICAL	15600.	
FOUNDATIONS	100.	
STRUCTURAL	4400.	
SITE WORK	500.	
INSULATION	19800.	
PROTECTIVE COATING	200.	
BUILDINGS	0.	
EQUIPMENT/MATERIAL LABOR	4000.	
DIRECT COST SUBTOTAL		161400.
*** INDIRECT COST ***		
FIELD OVERHEAD	11600.	
CONTRACTORS FEE	7800.	
ENGINEERING	31600.	
FREIGHT	1000.	
OFFSITE WORK	200.	
TAXES	6300.	
SHAKEDOWN	600.	
SPARES	1100.	
CONTINGENCY	36700.	
INDIRECT COST SUBTOTAL		96900.
INTEREST DURING INSTALLATION		7100.
TOTAL COST		265400.
TOTAL COST WITH RETROFIT		297200.

OPERATING COST:

		UNITS	OPTION
PPSES: 510.	COAL STORAGE YARD	COKE	2
CAPACITY:	2.834 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	49870. MGAL/YR	\$.1595/1000 GAL	8000.
ELECTRICITY	32639. KWH/YR	\$.0266/KWH	900.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	1800. HRS/YR	\$14.34/HR	25800. (A)
SUPERVISION	360. HRS/YR	\$17.20/HR	6200. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	800. HRS/YR	\$14.34/HR	11500. (C)
SUPERVISION	160. HRS/YR	\$17.20/HR	2800. (D)
MATERIALS			6500. (E)
SUPPLIES			3300. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			65000.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			9300.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			28100.
TOTAL OPERATING COST			102400.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.04
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			562.16
OPERATING COST AS PERCENT OF CAPITAL COST			34.5
INSTALLATION TIME IN WEEKS			52.
ESTIMATED LIFE OF SYSTEM IN YEARS			20.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)			34900.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			5900.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			5900.
TOTAL ANNUALIZED COST - RETROFIT			149100.
- NEW			144200.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 510. COAL STORAGE YARD	COKE	3
CAPACITY: 2.834 MILLION TONS/YEAR		
PARTICULATE		
LOAD IN: .150000 LBS/TON COAL		
ALLOWABLE: .037500 LBS/TON COAL	EFFICIENCY: 75.0%	
17.33 LBS/HR		
DUST COLLECTED PER DAY: .6 TONS(DRY)		
TEMP OUT OF PROCESS:	70. F	
EXHAUST TEMPERATURE:	70. F	
SCFM FLOW: 0. AT 70. F		
ACFM FLOW: 0. AT 70. F		
L/G RATIO: .0		
PROCESS WATER FLOW:	254. GPM	
COOLING WATER FLOW:	0. GPM	
SUSPENDED SOLIDS OUT: 0. MG/L	%SOLIDS: .0	

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 510. COAL STORAGE YARD	COKE	3

CONTROL SYSTEM CONFIGURATION:

COAL RECEIVING STATION SPRAYS
TRANSFER POINT SPRAY
SPRAY TRUCK
WATER PUMPING SYSTEM

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH		SPARE FAN CAPACITY:	0.2
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	4047868.		

CAPITAL COST:

		UNITS	OPTION
PPSES:	510.	COAL STORAGE YARD	COKE 3
CAPACITY:	2.834 MILLION TONS/YEAR		
TOTAL COST	(COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4Q78 COST.)		

CATEGORY	COST IN DOLLARS	
*** DIRECT COST ***		
EQUIPMENT OR MATERIAL	153300.	
INSTRUMENTATION	3800.	
PIPING	50100.	
ELECTRICAL	22900.	
FOUNDATIONS	2600.	
STRUCTURAL	8400.	
SITE WORK	900.	
INSULATION	26700.	
PROTECTIVE COATING	400.	
BUILDINGS	5500.	
EQUIPMENT/MATERIAL LABOR	10400.	
DIRECT COST SUBTOTAL		281000.
*** INDIRECT COST ***		
FIELD OVERHEAD	24100.	
CONTRACTORS FEE	14800.	
ENGINEERING	42700.	
FREIGHT	1900.	
OFFSITE WORK	300.	
TAXES	9000.	
SHAKEDOWN	1600.	
SPARES	1600.	
CONTINGENCY	62200.	
INDIRECT COST SUBTOTAL		158200.
INTEREST DURING INSTALLATION		13500.
TOTAL COST		452700.
TOTAL COST WITH RETROFIT		525100.

OPERATING COST:

		UNITS	OPTION
PPSES: 510.	COAL STORAGE YARD	COKE	3
CAPACITY:	2.834 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	74805. MGAL/YR	\$.1595/1000 GAL	11900.
ELECTRICITY	48959. KWH/YR	\$.0266/KWH	1300.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	1800. HRS/YR	\$14.34/HR	25800. (A)
SUPERVISION	360. HRS/YR	\$17.20/HR	6200. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	1200. HRS/YR	\$14.34/HR	17200. (C)
SUPERVISION	240. HRS/YR	\$17.20/HR	4100. (D)
MATERIALS			9300. (E)
SUPPLIES			4900. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			80700.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			10700.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			33800.
TOTAL OPERATING COST			125200.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.04
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			549.86
OPERATING COST AS PERCENT OF CAPITAL COST			23.8
INSTALLATION TIME IN WEEKS			52.
ESTIMATED LIFE OF SYSTEM IN YEARS			20.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)			61700.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			10500.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL).			10500.
TOTAL ANNUALIZED COST - RETROFIT			207900.
- NEW			196600.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 510. COAL STORAGE YARD	COKE	4
CAPACITY:	2.834 MILLION TONS/YEAR	
PARTICULATE		
LOAD IN:	.150000 LBS/TON COAL	
ALLOWABLE:	.015000 LBS/TON COAL	EFFICIENCY: 90.0%
	6.93 LBS/HR	
DUST COLLECTED PER DAY:	.7 TONS(DRY)	
TEMP OUT OF PROCESS:	70. F	
EXHAUST TEMPERATURE:	70. F	
SCFM FLOW:	0. AT 70. F	
ACFM FLOW:	0. AT 70. F	
L/G RATIO:	.0	
PROCESS WATER FLOW:	680. GPM	
COOLING WATER FLOW:	0. GPM	
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS: .0

GENERAL INFORMATION:

PPSES: 510. COAL STORAGE YARD

UNITS	OPTION
COKE	4

CONTROL SYSTEM CONFIGURATION:

COAL RECEIVING STATION SPRAYS
 SPRAY TRUCK
 COAL PILE PERIMETER SPRAY
 WATER PUMPING SYSTEM

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH		SPARE FAN CAPACITY:	0.2
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	4047868.		

CAPITAL COST:

		UNITS	OPTION
PPSES: 510.	COAL STORAGE YARD	COKE	4

CAPACITY: 2.834 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST.)

CATEGORY	COST IN DOLLARS
----------	-----------------

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	1240100.	
INSTRUMENTATION	3800.	
PIPING	582100.	
ELECTRICAL	78100.	
FOUNDATIONS	20400.	
STRUCTURAL	4400.	
SITE WORK	15300.	
INSULATION	347000.	
PROTECTIVE COATING	700.	
BUILDINGS	96400.	
EQUIPMENT/MATERIAL LABOR	72300.	
DIRECT COST SUBTOTAL		2460600.

*** INDIRECT COST ***

FIELD OVERHEAD	389900.	
CONTRACTORS FEE	239800.	
ENGINEERING	235600.	
FREIGHT	13800.	
OFFSITE WORK	68100.	
TAXES	63200.	
SHAKEDOWN	17500.	
SPARES	12700.	
CONTINGENCY	687500.	
INDIRECT COST SUBTOTAL		1728100.

INTEREST DURING INSTALLATION	308700.
------------------------------	---------

TOTAL COST	4497400.
------------	----------

TOTAL COST WITH RETROFIT	4974300.
--------------------------	----------

OPERATING COST:

		UNITS	OPTION
PPSES:	510. COAL STORAGE YARD	COKE	4
CAPACITY:	2.834 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	200046. MGAL/YR	\$.1595/1000 GAL	31900.
ELECTRICITY	130928. KWH/YR	\$.0266/KWH	3500.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	40590. HRS/YR	\$14.34/HR	582200. (A)
SUPERVISION	8118. HRS/YR	\$17.20/HR	139700. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	6378. HRS/YR	\$14.34/HR	91500. (C)
SUPERVISION	1276. HRS/YR	\$17.20/HR	21900. (D)
MATERIALS			46500. (E)
SUPPLIES			24700. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			941900.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			167100.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			453300.
TOTAL OPERATING COST			1562300.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.55
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			5717.87
OPERATING COST AS PERCENT OF CAPITAL COST			31.4
INSTALLATION TIME IN WEEKS			80.
ESTIMATED LIFE OF SYSTEM IN YEARS			20.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)			584300.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			99500.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			99500.
TOTAL ANNUALIZED COST - RETROFIT			2345600.
- NEW			2270400.

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	511. PIPELINE CHARGING	COKE	2
CAPACITY:	.992 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	.016000 LBS/TON COAL		
ALLOWABLE:	.000160 LBS/TON COAL	EFFICIENCY:	99.0%
	.03 LBS/HR		
BSO			
LOAD IN:	.019000 LBS/TON COAL		
ALLOWABLE:	.000190 LBS/TON COAL	EFFICIENCY:	99.0%
	.03 LBS/HR		
BAP			
LOAD IN:	.000035 LBS/TON COAL		
ALLOWABLE:	.000000 LBS/TON COAL	EFFICIENCY:	99.0%
	.00 LBS/HR		
BENZENE			
LOAD IN:	.008000 LBS/TON COAL		
ALLOWABLE:	.000080 LBS/TON COAL	EFFICIENCY:	99.0%
	.01 LBS/HR		
DUST COLLECTED PER DAY:	.0 TONS(DRY)		
TEMP OUT OF PROCESS:	180. F		
EXHAUST TEMPERATURE:	180. F		
SCFM FLOW:	0. AT 70. F		
ACFM FLOW:	0. AT 180. F		
L/G RATIO:	.0		
PROCESS WATER FLOW:	0. GPM		
COOLING WATER FLOW:	0. GPM		
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS:	.0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 511. PIPELINE CHARGING	COKE	2

CONTROL SYSTEM CONFIGURATION:

TOPSIDE AND PIPELINE MAINT.

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.2	
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	12.5		
NO. CYCLES/DAY	115.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1416755.		

OPERATING COST:

PPSES: 511. PIPELINE CHARGING		UNITS	OPTION
		COKE	2
CAPACITY:	.992 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	5900. HRS/YR	\$14.34/HR	84600. (C)
SUPERVISION	1180. HRS/YR	\$17.20/HR	20300. (D)
MATERIALS			42300. (E)
SUPPLIES			22100. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			325100.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			52100.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			162600.
TOTAL OPERATING COST			539800.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.54
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			48107.55
OPERATING COST AS PERCENT OF CAPITAL COST			.0
INSTALLATION TIME IN WEEKS			8.
ESTIMATED LIFE OF SYSTEM IN YEARS			99.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (10.00% OF TOTAL CAPITAL)			0.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			0.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			0.
TOTAL ANNUALIZED COST - RETROFIT			539800.
- NEW			539800.

GENERAL INFORMATION:

UNITS OPTION
COKE 2

PPSES: 512. REDLER CHARGING

CAPACITY: .992 MILLION TONS/YEAR

PARTICULATE

LOAD IN: .010000 LBS/TON COAL

ALLOWABLE: .000100 LBS/TON COAL EFFICIENCY: 99.0%
 .02 LBS/HR

BSO

LOAD IN: .006000 LBS/TON COAL

ALLOWABLE: .000060 LBS/TON COAL EFFICIENCY: 99.0%
 .01 LBS/HR

BAP

LOAD IN: .000011 LBS/TON COAL

ALLOWABLE: .000000 LBS/TON COAL EFFICIENCY: 99.0%
 .00 LBS/HR

BENZENE

LOAD IN: .004900 LBS/TON COAL

ALLOWABLE: .000049 LBS/TON COAL EFFICIENCY: 99.0%
 .01 LBS/HR

DUST COLLECTED PER DAY: .0 TONS(DRY)

TEMP OUT OF PROCESS: 180. F

EXHAUST TEMPERATURE: 180. F

SCFM FLOW: 0. AT 70. F

ACFM FLOW: 0. AT 180. F

L/G RATIO: .0

PROCESS WATER FLOW: 0. GPM

COOLING WATER FLOW: 0. GPM

SUSPENDED SOLIDS OUT: 0. MG/L %SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 512. REDLER CHARGING	COKE	2

CONTROL SYSTEM CONFIGURATION:

REDLER SYSTEM MAINT.

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.2	
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	12.5		
NO. CYCLES/DAY	115.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1416755.		

OPERATING COST:

		UNITS	OPTION
PPSES: 512.	REDLER CHARGING	COKE	2
CAPACITY:	.992 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	2000. HRS/YR	\$14.34/HR	28700. (C)
SUPERVISION	400. HRS/YR	\$17.20/HR	6900. (D)
MATERIALS			14300. (E)
SUPPLIES			7500. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			213200.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			38300.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			106600.
TOTAL OPERATING COST			358100.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.36
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			51062.80
OPERATING COST AS PERCENT OF CAPITAL COST			.0
INSTALLATION TIME IN WEEKS			8.
ESTIMATED LIFE OF SYSTEM IN YEARS			99.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (10.00% OF TOTAL CAPITAL)			0.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			0.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			0.
TOTAL ANNUALIZED COST - RETROFIT			358100.
- NEW			358100.

GENERAL INFORMATION:

PPSES: 513.	HOT LARRY CAR CHARGING	UNITS	OPTION
		COKE	2

CAPACITY: .992 MILLION TONS/YEAR

PARTICULATE

LOAD IN:	.017000 LBS/TON COAL	
ALLOWABLE:	.000170 LBS/TON COAL	EFFICIENCY: 99.0%
	.03 LBS/HR	

B50

LOAD IN:	.019000 LBS/TON COAL	
ALLOWABLE:	.000190 LBS/TON COAL	EFFICIENCY: 99.0%
	.03 LBS/HR	

BAP

LOAD IN:	.000035 LBS/TON COAL	
ALLOWABLE:	.000000 LBS/TON COAL	EFFICIENCY: 99.0%
	.00 LBS/HR	

BENZENE

LOAD IN:	.008000 LBS/TON COAL	
ALLOWABLE:	.000080 LBS/TON COAL	EFFICIENCY: 99.0%
	.01 LBS/HR	

DUST COLLECTED PER DAY: .0 TONS(DRY)

TEMP OUT OF PROCESS: 180. F

EXHAUST TEMPERATURE: 180. F

SCFM FLOW: 0. AT 70. F

ACFM FLOW: 0. AT 180. F

L/G RATIO: .0

PROCESS WATER FLOW: 0. GPM

COOLING WATER FLOW: 0. GPM

SUSPENDED SOLIDS OUT: 0. MG/L %SOLIDS: .0

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	513.	HOT LARRY CAR CHARGING	COKE
			2

CONTROL SYSTEM CONFIGURATION:

HOT LARRY CAR -TOPSIDE

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH		SPARE FAN CAPACITY:	0.2
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	12.5		
NO. CYCLES/DAY	115.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1416755.		

OPERATING COST:

		UNITS	OPTION
PPSES:	513. HOT LARRY CAR CHARGING	COKE	2
CAPACITY:	.992 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	0. HRS/YR	\$14.34/HR	0. (C)
SUPERVISION	0. HRS/YR	\$17.20/HR	0. (D)
MATERIALS			0. (E)
SUPPLIES			0. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			155800.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			31200.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			77900.
TOTAL OPERATING COST			264900.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.27
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			22219.45
OPERATING COST AS PERCENT OF CAPITAL COST			.0
INSTALLATION TIME IN WEEKS			8.
ESTIMATED LIFE OF SYSTEM IN YEARS			99.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (10.00% OF TOTAL CAPITAL)			0.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			0.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			0.
TOTAL ANNUALIZED COST - RETROFIT			264900.
- NEW			264900.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 514. BY-PRODUCTS PLANT	COKE	2

CAPACITY: 2.834 MILLION TONS/YEAR

BSO

LOAD IN:	.300000 LBS/TON COAL	
ALLOWABLE:	.060000 LBS/TON COAL	EFFICIENCY: 80.0%
	27.73 LBS/HR	

BENZENE

LOAD IN:	.200000 LBS/TON COAL	
ALLOWABLE:	.040000 LBS/TON COAL	EFFICIENCY: 80.0%
	18.48 LBS/HR	

DUST COLLECTED PER DAY: .0 TONS(DRY)

TEMP OUT OF PROCESS:	100. F
EXHAUST TEMPERATURE:	100. F

SCFM FLOW:	0. AT 70. F
ACFM FLOW:	0. AT 100. F

L/G RATIO:	.0	
PROCESS WATER FLOW:	0. GPM	
COOLING WATER FLOW:	0. GPM	
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS: .0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 514. BY-PRODUCTS PLANT	COKE	2

CONTROL SYSTEM CONFIGURATION:

BY-PRODUCT CONTROLS

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.8	
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	4047868.		

OPERATING COST:

		UNITS	OPTION
PPSES: 514.	BY-PRODUCTS PLANT	COKE	2
CAPACITY:	2.834 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	0. HRS/YR	\$14.34/HR	0. (A)
SUPERVISION	0. HRS/YR	\$17.20/HR	0. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	8760. HRS/YR	\$14.34/HR	125700. (C)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (D)
MATERIALS			0. (E)
SUPPLIES			23400. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			179200.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			31200.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			89600.
TOTAL OPERATING COST			300000.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.11
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			25163.59
OPERATING COST AS PERCENT OF CAPITAL COST			.0
INSTALLATION TIME IN WEEKS			8.
ESTIMATED LIFE OF SYSTEM IN YEARS			99.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (10.00% OF TOTAL CAPITAL)			0.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			0.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			0.
TOTAL ANNUALIZED COST - RETROFIT			300000.
- NEW			300000.

GENERAL INFORMATION:

		UNITS	OPTION
PPSES:	S15. COMBUSTION STACK - NEW	COKE	2
CAPACITY:	.708 MILLION TONS/YEAR		
PARTICULATE			
LOAD IN:	.130000 LBS/TON COAL		
ALLOWABLE:	.026000 LBS/TON COAL	EFFICIENCY:	80.0%
	3.00 LBS/HR		
BSO			
LOAD IN:	.000600 LBS/TON COAL		
ALLOWABLE:	.000120 LBS/TON COAL	EFFICIENCY:	80.0%
	.01 LBS/HR		
BAP			
LOAD IN:	.000006 LBS/TON COAL		
ALLOWABLE:	.000001 LBS/TON COAL	EFFICIENCY:	80.0%
	.00 LBS/HR		
DUST COLLECTED PER DAY:	.1 TONS(DRY)		
TEMP OUT OF PROCESS:	450. F		
EXHAUST TEMPERATURE:	450. F		
SCFM FLOW:	67000. AT	70. F	
ACFM FLOW:	115000. AT	450. F	
L/G RATIO:	.0		
PROCESS WATER FLOW:	0. GPM		
COOLING WATER FLOW:	0. GPM		
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS:	.0

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 515. COMBUSTION STACK - NEW	COKE	2

CONTROL SYSTEM CONFIGURATION:

HEATING CONTROL AND PATCHING

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	6.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.2	
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	1011967.		

OPERATING COST:

PPSES: 515. COMBUSTION STACK - NEW		UNITS COKE	OPTION 2
CAPACITY: .708 MILLION TONS/YEAR			
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.
*** OPERATING LABOR ***			
DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)
*** MAINTENANCE & SUPPLIES ***			
DIRECT LABOR	5900. HRS/YR	\$14.34/HR	84600. (C)
SUPERVISION	1180. HRS/YR	\$17.20/HR	20300. (D)
MATERIALS			21200. (E)
SUPPLIES			18900. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	0. TON/YR	\$ 8.25/TON	0.
DIRECT OPERATING COST			300800.
PAYROLL OVERHEAD =20.0% OF A+B+C+D			52100.
PLANT OVERHEAD =50.0% OF A+B+C+D+E+F			150400.
TOTAL OPERATING COST			503300.
OPERATING COST IN DOLLARS PER TON PRODUCTION			.71
OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED			9564.39
OPERATING COST AS PERCENT OF CAPITAL COST			.0
INSTALLATION TIME IN WEEKS			8.
ESTIMATED LIFE OF SYSTEM IN YEARS			99.
KWH PER TON CAPACITY			.0
CAPITAL RECOVERY (10.00% OF TOTAL CAPITAL)			0.
ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)			0.
PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)			0.
TOTAL ANNUALIZED COST - RETROFIT			503300.
- NEW			503300.

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 516. QUENCHING - DIRTY WATER	COKE	2
CAPACITY:	2.834 MILLION TONS/YEAR	
PARTICULATE		
LOAD IN:	3.200000 LBS/TON COAL	
ALLOWABLE:	.960000 LBS/TON COAL	EFFICIENCY: 70.0%
	443.60 LBS/HR	
BSO		
LOAD IN:	.006400 LBS/TON COAL	
ALLOWABLE:	.001920 LBS/TON COAL	EFFICIENCY: 70.0%
	.89 LBS/HR	
BAP		
LOAD IN:	.000310 LBS/TON COAL	
ALLOWABLE:	.000093 LBS/TON COAL	EFFICIENCY: 70.0%
	.04 LBS/HR	
BENZENE		
LOAD IN:	.000260 LBS/TON COAL	
ALLOWABLE:	.000260 LBS/TON COAL	EFFICIENCY: .0%
	.12 LBS/HR	
DUST COLLECTED PER DAY:	12.4 TONS(DRY)	
TEMP OUT OF PROCESS:	200. F	
EXHAUST TEMPERATURE:	200. F	
SCFM FLOW:	0. AT 70. F	
ACFM FLOW:	0. AT 200. F	
L/G RATIO:	.0	
PROCESS WATER FLOW:	0. GPM	
COOLING WATER FLOW:	0. GPM	
SUSPENDED SOLIDS OUT:	0. MG/L	%SOLIDS: .0

CAPITAL COST:

		UNITS	OPTION
PPSES: 516.	QUENCHING - DIRTY WATER	COKE	2

CAPACITY: 2.834 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST.

CATEGORY	COST IN DOLLARS	
*** DIRECT COST ***		
EQUIPMENT OR MATERIAL	114100.	
INSTRUMENTATION	0.	
PIPING	30800.	
ELECTRICAL	6200.	
FOUNDATIONS	900.	
STRUCTURAL	0.	
SITE WORK	600.	
INSULATION	0.	
PROTECTIVE COATING	900.	
BUILDINGS	0.	
EQUIPMENT/MATERIAL LABOR	80300.	
DIRECT COST SUBTOTAL		233800.
*** INDIRECT COST ***		
FIELD OVERHEAD	45400.	
CONTRACTORS FEE	27900.	
ENGINEERING	35100.	
FREIGHT	4400.	
OFFSITE WORK	0.	
TAXES	5700.	
SHAKEDOWN	1300.	
SPARES	3500.	
CONTINGENCY	71400.	
INDIRECT COST SUBTOTAL		194700.
INTEREST DURING INSTALLATION		10700.
TOTAL COST		439200.
TOTAL COST WITH RETROFIT		571000.

OPERATING COST:

PPSES: 516. QUENCHING - DIRTY WATER UNITS COKE OPTION 2

CAPACITY: 2.834 MILLION TONS/YEAR

CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
----------	----------	------	------------------

*** UTILITIES ***

WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	0. KWH/YR	\$.0266/KWH	0.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	0. GAL/YR	\$.4180/GAL	0.

*** OPERATING LABOR ***

DIRECT	0. HRS/YR	\$14.34/HR	0. (A)
SUPERVISION	0. HRS/YR	\$17.20/HR	0. (B)

*** MAINTENANCE & SUPPLIES ***

DIRECT LABOR	1200. HRS/YR	\$14.34/HR	17200. (C)
SUPERVISION	240. HRS/YR	\$17.20/HR	4100. (D)
MATERIALS			8600. (E)
SUPPLIES			4500. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	9067. TON/YR	\$ 8.25/TON	74800.

DIRECT OPERATING COST	109200.
-----------------------	---------

PAYROLL OVERHEAD =20.0% OF A+B+C+D	4300.
------------------------------------	-------

PLANT OVERHEAD =50.0% OF A+B+C+D+E+F	17200.
--------------------------------------	--------

TOTAL OPERATING COST	130700.
----------------------	---------

OPERATING COST IN DOLLARS PER TON PRODUCTION	.05
--	-----

OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED	28.83
---	-------

OPERATING COST AS PERCENT OF CAPITAL COST	22.9
---	------

INSTALLATION TIME IN WEEKS	26.
----------------------------	-----

ESTIMATED LIFE OF SYSTEM IN YEARS	20.
-----------------------------------	-----

KWH PER TON CAPACITY	.0
----------------------	----

CAPITAL RECOVERY (11.75% OF TOTAL CAPITAL)	67100.
--	--------

ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)	11400.
--	--------

PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)	11400.
--	--------

TOTAL ANNUALIZED COST - RETROFIT	220600.
----------------------------------	---------

- NEW	199900.
-------	---------

GENERAL INFORMATION:

PPSES: 516. QUENCHING - DIRTY WATER UNITS COKE OPTION 3

CAPACITY: 2.834 MILLION TONS/YEAR

PARTICULATE

LOAD IN: 3.200000 LBS/TON COAL
ALLOWABLE: .480000 LBS/TON COAL EFFICIENCY: 85.0%
221.80 LBS/HR

BSO

LOAD IN: .006400 LBS/TON COAL
ALLOWABLE: .001600 LBS/TON COAL EFFICIENCY: 75.0%
.74 LBS/HR

BAP

LOAD IN: .000310 LBS/TON COAL
ALLOWABLE: .000062 LBS/TON COAL EFFICIENCY: 80.0%
.03 LBS/HR

BENZENE

LOAD IN: .000260 LBS/TON COAL
ALLOWABLE: .000065 LBS/TON COAL EFFICIENCY: 75.0%
.03 LBS/HR

DUST COLLECTED PER DAY: 15.1 TONS(DRY)

TEMP OUT OF PROCESS: 200. F

EXHAUST TEMPERATURE: 200. F

SCFM FLOW: 0. AT 70. F

ACFM FLOW: 0. AT 200. F

L/G RATIO: .0

PROCESS WATER FLOW: 1213. GPM

COOLING WATER FLOW: 0. GPM

SUSPENDED SOLIDS OUT: 1707. MG/L %SOLIDS: .2

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 516. QUENCHING - DIRTY WATER	COKE	3

CONTROL SYSTEM CONFIGURATION:

QUENCH TOWER BAFFLES
COKE PLANT WASTEWATER TREATMENT

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH		SPARE FAN CAPACITY:	0.2
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	.70		
TONS COAL/YEAR	4047868.		

CAPITAL COST:

PPSES: 516. QUENCHING - DIRTY WATER

UNITS OPTION
COKE 3

CAPACITY: 2.834 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COST.)

CATEGORY

COST IN DOLLARS

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	3141700.
INSTRUMENTATION	424400.
PIPING	745400.
ELECTRICAL	233900.
FOUNDATIONS	131400.
STRUCTURAL	130500.
SITE WORK	166600.
INSULATION	121100.
PROTECTIVE COATING	49200.
BUILDINGS	546000.
EQUIPMENT/MATERIAL LABOR	321600.
DIRECT COST SUBTOTAL	6011800.

*** INDIRECT COST ***

FIELD OVERHEAD	1034500.
CONTRACTORS FEE	228100.
ENGINEERING	633400.
FREIGHT	28500.
OFFSITE WORK	149600.
TAXES	126300.
SHAKEDOWN	249800.
SPARES	124100.
CONTINGENCY	1559900.
INDIRECT COST SUBTOTAL	4134200.

INTEREST DURING INSTALLATION	982500.
------------------------------	---------

TOTAL COST	11128500.
------------	-----------

TOTAL COST WITH RETROFIT	13398200.
--------------------------	-----------

OPERATING COST:

PPSES: 516. QUENCHING - DIRTY WATER UNITS - OPTION
COKE 3

CAPACITY: 2.834 MILLION TONS/YEAR

CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
----------	----------	------	------------------

*** UTILITIES ***

WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	4250262. KWH/YR	\$.0266/KWH	113100.
STEAM	1062566. MLBS/YR	\$ 4.0920/MLBS	4348000.
FUEL	2312143. GAL/YR	\$.4180/GAL	966500.

*** OPERATING LABOR ***

DIRECT	8760. HRS/YR	\$14.34/HR	125700. (A)
SUPERVISION	1752. HRS/YR	\$17.20/HR	30100. (B)

*** MAINTENANCE & SUPPLIES ***

DIRECT LABOR	17200. HRS/YR	\$14.34/HR	246700. (C)
SUPERVISION	3440. HRS/YR	\$17.20/HR	59200. (D)
MATERIALS			238100. (E)
SUPPLIES			367700. (F)
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	11010. TON/YR	\$ 8.25/TON	90800.

DIRECT OPERATING COST 6585900.

PAYROLL OVERHEAD =20.0% OF A+B+C+D 92300.

PLANT OVERHEAD =50.0% OF A+B+C+D+E+F 533800.

TOTAL OPERATING COST 7212000.

OPERATING COST IN DOLLARS PER TON - PRODUCTION 2.55

OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED 1310.06

OPERATING COST AS PERCENT OF CAPITAL COST 53.8

INSTALLATION TIME IN WEEKS 104.

ESTIMATED LIFE OF SYSTEM IN YEARS 15.

KWH PER TON CAPACITY 37.4

CAPITAL RECOVERY (13.15% OF TOTAL CAPITAL) 1761500.

ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL) 268000.

PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL) 268000.

TOTAL ANNUALIZED COST - RETROFIT 9509500.

- NEW 9120300.

GENERAL INFORMATION:

PPSES: 516. QUENCHING - DIRTY WATER UNITS COKE OPTION 4

CAPACITY: 2.834 MILLION TONS/YEAR

PARTICULATE

LOAD IN: 3.200000 LBS/TON COAL
ALLOWABLE: .160000 LBS/TON COAL EFFICIENCY: 95.0%
73.93 LBS/HR

BSO

LOAD IN: .006400 LBS/TON COAL
ALLOWABLE: .000960 LBS/TON COAL EFFICIENCY: 85.0%
.44 LBS/HR

BAP

LOAD IN: .000310 LBS/TON COAL
ALLOWABLE: .000046 LBS/TON COAL EFFICIENCY: 85.0%
.02 LBS/HR

BENZENE

LOAD IN: .000260 LBS/TON COAL
ALLOWABLE: .000065 LBS/TON COAL EFFICIENCY: 75.0%
.03 LBS/HR

DUST COLLECTED PER DAY: 16.9 TONS(DRY)

TEMP. OUT OF PROCESS: 200. F
EXHAUST TEMPERATURE: 200. F

SCFM FLOW: 0. AT 70. F
ACFM FLOW: 0. AT 200. F

L/G RATIO: .0

PROCESS WATER FLOW: 1213. GPM

COOLING WATER FLOW: 0. GPM

SUSPENDED SOLIDS OUT: 1707. MG/L XSOLIDS: .2

GENERAL INFORMATION:

PPSES: 516.	QUENCHING - DIRTY WATER	UNITS COKE	OPTION 4
-------------	-------------------------	---------------	-------------

CONTROL SYSTEM CONFIGURATION:

QUENCH TOWER BAFFLES
COKE PLANT WASTEWATER TREATMENT

FEET OF ADDITIONAL DUCT:	0.	DIAMETER:	0.
TOTAL PRESSURE DROP:	0.	INCHES	
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.2	
OPERATING HOURS AT FULL HP:	8760.		
OPERATING HOURS AT REDUCED HP:	0.		
STACK HEIGHT:	0.	DIAMETER:	0.
NO. OF OVENS	60.		
OVEN HEIGHT	6.0	METERS	
OVEN VOLUME	1348.	CUBIC FEET	
TONS COKE/PUSH	24.		
AVG. COKING TIME, HRS.	17.5		
NO. CYCLES/DAY	82.		
BULK DENSITY	50.	LBS/CUBIC FT.	
YIELD	70		
TONS COAL/YEAR	4047868.		

CAPITAL COST:

PPSES: 516. QUENCHING - DIRTY WATER UNITS OPTION
COKE 4

CAPACITY: 2.834 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4Q78 COS

CATEGORY

COST IN DOLLARS

*** DIRECT COST ***

EQUIPMENT OR MATERIAL 3956000.
INSTRUMENTATION 455200.
PIPING 727800.
ELECTRICAL 227700.
FOUNDATIONS 130500.
STRUCTURAL 130500.
SITE WORK 174800.
INSULATION 129000.
PROTECTIVE COATING 51800.
BUILDINGS 546000.
EQUIPMENT/MATERIAL LABOR 896000.

DIRECT COST SUBTOTAL 7425300.

*** INDIRECT COST ***

FIELD OVERHEAD 1059500.
CONTRACTORS FEE 539000.
ENGINEERING 842500.
FREIGHT 24100.
OFFSITE WORK 193600.
TAXES 169000.
SHAKEDOWN 274900.
SPARES 164600.
CONTINGENCY 2126500.

INDIRECT COST SUBTOTAL 5393700.

INTEREST DURING INSTALLATION 1126900.

TOTAL COST 13945900.

TOTAL COST WITH RETROFIT 17060800.

OPERATING COST:

PPSES: 516. QUENCHING - DIRTY WATER UNITS OPTION
COKE 4

CAPACITY: 2.834 MILLION TONS/YEAR

CATEGORY	QUANTITY	RATE	ANNUAL COST (
----------	----------	------	---------------

*** UTILITIES ***

WATER	0, MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	4250262, KWH/YR	\$.0266/KWH	113100.
STEAM	1062566, MLBS/YR	\$ 4.0920/MLBS	4348000.
FUEL	2312143, GAL/YR	\$.4180/GAL	966500.

*** OPERATING LABOR ***

DIRECT	8760, HRS/YR	\$14.34/HR	125700. (A
SUPERVISION	1752, HRS/YR	\$17.20/HR	30100. (B

*** MAINTENANCE & SUPPLIES ***

DIRECT LABOR	20000, HRS/YR	\$14.34/HR	286900. (C
SUPERVISION	4000, HRS/YR	\$17.20/HR	68800. (D
MATERIALS			344300. (E
SUPPLIES			391100. (F
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	12306, TON/YR	\$ 8.25/TON	101500.

DIRECT OPERATING COST	6776000.
-----------------------	----------

PAYROLL OVERHEAD =20.0% OF A+B+C+D	102300.
------------------------------------	---------

PLANT OVERHEAD =50.0% OF A+B+C+D+E+F	623500.
--------------------------------------	---------

TOTAL OPERATING COST	7501800.
----------------------	----------

OPERATING COST IN DOLLARS PER TON - PRODUCTION	2.65
--	------

OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED	1219.26
---	---------

OPERATING COST AS PERCENT OF CAPITAL COST	44.0
---	------

INSTALLATION TIME IN WEEKS	104.
----------------------------	------

ESTIMATED LIFE OF SYSTEM IN YEARS	15.
-----------------------------------	-----

KWH PER TON CAPACITY	37.4
----------------------	------

CAPITAL RECOVERY (13.15% OF TOTAL CAPITAL)	2243100.
--	----------

ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL)	341200.
--	---------

PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL)	341200.
--	---------

TOTAL ANNUALIZED COST - RETROFIT	10427300.
----------------------------------	-----------

- NEW	9893100.
-------	----------

GENERAL INFORMATION:

PPSES: 516.	QUENCHING - DIRTY WATER	UNITS COKE	OPTION 5
-------------	-------------------------	---------------	-------------

CAPACITY: 2.834 MILLION TONS/YEAR

PARTICULATE

LOAD IN:	3.200000 LBS/TON COAL	
ALLOWABLE:	.032000 LBS/TON COAL	EFFICIENCY: 99.0%
	14.79 LBS/HR	

BSO

LOAD IN:	.006400 LBS/TON COAL	
ALLOWABLE:	.000064 LBS/TON COAL	EFFICIENCY: 99.0%
	.03 LBS/HR	

BAP

LOAD IN:	.000310 LBS/TON COAL	
ALLOWABLE:	.000003 LBS/TON COAL	EFFICIENCY: 99.0%
	.00 LBS/HR	

BENZENE

LOAD IN:	.000260 LBS/TON COAL	
ALLOWABLE:	.000003 LBS/TON COAL	EFFICIENCY: 99.0%
	.00 LBS/HR	

DUST COLLECTED PER DAY: 17.6 TONS(DRY)

TEMP OUT OF PROCESS:	200. F
EXHAUST TEMPERATURE:	200. F

SCFM FLOW:	549000.	AT	70. F
ACFM FLOW:	683000.	AT	200. F

L/G RATIO: .0

PROCESS WATER FLOW: 1213. GPM

COOLING WATER FLOW: 0. GPM

SUSPENDED SOLIDS OUT: 1707. MG/L %SOLIDS: .2

GENERAL INFORMATION:

	UNITS	OPTION
PPSES: 516. QUENCHING - DIRTY WATER	COKE	5

CONTROL SYSTEM CONFIGURATION:

DRY QUENCHING
COKE PLANT WASTEWATER TREATMENT

FEET OF ADDITIONAL DUCT:	0.	DIAMETER: 15.
TOTAL PRESSURE DROP:	0.	INCHES
0 FANS @ 0. HP EACH	SPARE FAN CAPACITY:	0.2
OPERATING HOURS AT FULL HP:	8760.	
OPERATING HOURS AT REDUCED HP:	0.	
STACK HEIGHT:	0.	DIAMETER: 0.
NO. OF OVENS	60.	
OVEN HEIGHT	6.0	METERS
OVEN VOLUME	1348.	CUBIC FEET
TONS COKE/PUSH	24.	
AVG. COKING TIME, HRS.	17.5	
NO. CYCLES/DAY	82.	
BULK DENSITY	50.	LBS/CUBIC FT.
YIELD	70	
TONS COAL/YEAR	4047868.	

CAPITAL COST:

PPSES: 516. QUENCHING - DIRTY WATER UNITS OPTION
COKE 5

CAPACITY: 2.834 MILLION TONS/YEAR

TOTAL COST (COST BASIS IS 110.00% OF JUNE 1977 DOLLARS FOR 4078 COS

CATEGORY

COST IN DOLLARS

*** DIRECT COST ***

EQUIPMENT OR MATERIAL	12393000.
INSTRUMENTATION	424400.
PIPING	714600.
ELECTRICAL	227700.
FOUNDATIONS	130500.
STRUCTURAL	130500.
SITE WORK	166000.
INSULATION	121100.
PROTECTIVE COATING	48300.
BUILDINGS	546000.
EQUIPMENT/MATERIAL LABOR	4736600.

DIRECT COST SUBTOTAL 19638700.

*** INDIRECT COST ***

FIELD OVERHEAD	3398600.
CONTRACTORS FEE	1791500.
ENGINEERING	1074800.
FREIGHT	24100.
OFFSITE WORK	554200.
TAXES	570100.
SHAKEDOWN	922800.
SPARES	192500.
CONTINGENCY	6379400.

INDIRECT COST SUBTOTAL 14908000.

INTEREST DURING INSTALLATION 4075500.

TOTAL COST 38622200.

TOTAL COST WITH RETROFIT 43553400.

OPERATING COST:

PPSES: 516. QUENCHING - DIRTY WATER UNITS COKE OPTION 5

CAPACITY: 2.834 MILLION TONS/YEAR

CATEGORY	QUANTITY	RATE	ANNUAL COST (
----------	----------	------	---------------

*** UTILITIES ***

WATER	0. MGAL/YR	\$.1595/1000 GAL	0.
ELECTRICITY	26918328. KWH/YR	\$.0266/KWH	716600.
STEAM	-1204241. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	2312143. GAL/YR	\$.4180/GAL	966500.

*** OPERATING LABOR ***

DIRECT	17520. HRS/YR	\$14.34/HR	251300. (A
SUPERVISION	3504. HRS/YR	\$17.20/HR	60300. (B

*** MAINTENANCE & SUPPLIES ***

DIRECT LABOR	78337. HRS/YR	\$14.34/HR	1123700. (C
SUPERVISION	15667. HRS/YR	\$17.20/HR	269500. (D
MATERIALS			676600. (E
SUPPLIES			596600. (F
WATER TREATMENT			0.
SOLID WASTE DISPOSAL	6412. TON/YR	\$ 8.25/TON	52900.

DIRECT OPERATING COST 4714000.

PAYROLL OVERHEAD =20.0% OF A+B+C+D 341000.

PLANT OVERHEAD =50.0% OF A+B+C+D+E+F 1489000.

TOTAL OPERATING COST 6544000.

OPERATING COST IN DOLLARS PER TON - PRODUCTION 2.31

OPERATING COST IN DOLLARS PER TON OF DUST COLLECTED 1020.61

OPERATING COST AS PERCENT OF CAPITAL COST 15.0

INSTALLATION TIME IN WEEKS 130.

ESTIMATED LIFE OF SYSTEM IN YEARS 15.

KWH PER TON CAPACITY 45.4

CAPITAL RECOVERY (13.15% OF TOTAL CAPITAL) 5726100.

ADMINISTRATION OVERHEAD (2.0% OF TOTAL CAPITAL) 871100.

PROPERTY TAXES & INS. (2.0% OF TOTAL CAPITAL) 871100.

TOTAL ANNUALIZED COST - RETROFIT 14012300.

- NEW 13166600.

APPENDIX B

EXAMPLE COMPUTER PRINTOUT FOR COST UPDATE PROGRAM

This appendix illustrates the output of the cost update program. In the example provided, the cost of Option 5, the enclosed hot car for the coke pushing source, has been adjusted by changing the cost basis from fourth quarter 1978 to mid-1979, assuming a 7 percent inflation rate. Also the cost of labor has been increased 10 percent. These increases are arbitrary and used only as an example. When the cost update program is run, one or all of the functions can be updated by using the data cards for whichever cases are to be modified.

COST UPDATE OF COKE OVEN
MODEL COST FUNCTIONS
BASIS: 2079

OPERATING COST:

SOURCE:	2	UNITS COKE	OPTION 5
CAPACITY:	.272 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	2450. MGAL/YR	\$.1600/1000 GAL	392.
ELECTRICITY	1603. KWH/YR	\$.0266/KWH	43.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	258563. GAL/YR	\$.4180/GAL	108079.
*** OPERATING & MAINT LABOR ***			
DIRECT	8000. HRS/YR	\$15.77/HR	126160. (A)
SUPERVISION	1600. HRS/YR	\$17.20/HR	27520. (B)
*** MAINT & SUPPLIES ***			
MATERIALS			114800. (C)
SUPPLIES			38600. (D)
SOLID WASTE DISPOSAL	686. TONS/YR	\$ 8.25	5659.
DIRECT OPERATING COST			421253.
PAYROLL OVERHEAD =20.0% OF A+B			30736.
PLANT OVERHEAD =50.0% OF A+B+C+D			153540.
TOTAL OPERATING COST			423096.
ESTIMATED LIFE OF SYSTEM IN YEARS			20.
CAPITAL RECOVERY (11.70% OF TOTAL CAPITAL)			659888.
ADMINISTRATION OVERHEAD (2.00% OF TOTAL CAPITAL)			112801.
PROPERTY TAXES & INS. (2.00% OF TOTAL CAPITAL)			112801.
TOTAL ANNUALIZED COST- RETROFIT			1308587.
- NEW			1228087.
TOTAL CAPITAL COST - RETROFIT			5640066.
- NEW			5127333.

COST UPDATE OF COKE OVEN
MODEL COST FUNCTIONS
BASIS: 2Q79

OPERATING COST:

SOURCE:	2	UNITS COKE	OPTION 5	
CAPACITY:	.405 MILLION TONS/YEAR			
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)	

*** UTILITIES ***

WATER	3643. MGAL/YR	\$.1600/1000 GAL	583.
ELECTRICITY	2385. KWH/YR	\$.0266/KWH	63.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	384576. GAL/YR	\$.4180/GAL	160753.

*** OPERATING & MAINT LABOR ***

DIRECT	8000. HRS/YR	\$15.77/HR	126160. (A)
SUPERVISION	1600. HRS/YR	\$17.20/HR	27520. (B)

*** MAINT & SUPPLIES ***

MATERIALS		114800. (C)
SUPPLIES		38600. (D)
SOLID WASTE DISPOSAL	1020. TONS/YR \$ 8.25	8415.

DIRECT OPERATING COST 476894.

PAYROLL OVERHEAD =20.0% OF A+B 30736.

PLANT OVERHEAD =50.0% OF A+B+C+D 153540.

TOTAL OPERATING COST 478737.

ESTIMATED LIFE OF SYSTEM IN YEARS 20.

CAPITAL RECOVERY (11.70% OF TOTAL CAPITAL) 712685.

ADMINISTRATION OVERHEAD (2.00% OF TOTAL CAPITAL) 121827.

PROPERTY TAXES & INS. (2.00% OF TOTAL CAPITAL) 121827.

TOTAL ANNUALIZED COST- RETROFIT 1435075.

- NEW 1348135.

TOTAL CAPITAL COST - RETROFIT 6091328.

- NEW 5537571.

COST UPDATE OF COKE OVEN
MODEL COST FUNCTIONS
BASIS: 2Q79

OPERATING COST:

SOURCE:	2	UNITS COKE	OPTION 5
CAPACITY:	.708 MILLION TONS/YEAR		
CATEGORY	QUANTITY	RATE	ANNUAL COST (\$)
*** UTILITIES ***			
WATER	6375. MGAL/YR	\$.1600/1000 GAL	1020.
ELECTRICITY	4173. KWH/YR	\$.0266/KWH	111.
STEAM	0. MLBS/YR	\$ 4.0920/MLBS	0.
FUEL	672958. GAL/YR	\$.4180/GAL	281296.
*** OPERATING & MAINT LABOR ***			
DIRECT	8000. HRS/YR	\$15.77/HR	126160. (A)
SUPERVISION	1600. HRS/YR	\$17.20/HR	27520. (B)
*** MAINT & SUPPLIES ***			
MATERIALS			114800. (C)
SUPPLIES			38600. (D)
SOLID WASTE			
DISPOSAL	1785. TONS/YR	\$ 8.25	14726.
DIRECT OPERATING COST			604234.
PAYROLL OVERHEAD =20.0% OF A+B			30736.
PLANT OVERHEAD =50.0% OF A+B+C+D			153540.
TOTAL OPERATING COST			606076.
ESTIMATED LIFE OF SYSTEM IN YEARS			20.
CAPITAL RECOVERY (11.70% OF TOTAL CAPITAL)			794305.
ADMINISTRATION OVERHEAD (2.00% OF TOTAL CAPITAL)			135779.
PROPERTY TAXES & INS. (2.00% OF TOTAL CAPITAL)			135779.
TOTAL ANNUALIZED COST- RETROFIT			1671939.
- NEW			1575043.
TOTAL CAPITAL COST - RETROFIT			6788936.
- NEW			6171760.

COST UPDATE OF COKE OVEN
MODEL COST FUNCTIONS
BASIS: 2079

REGRESSION ANALYSIS:

SOURCE:	2	UNITS COKE	OPTION 5
CAPITAL COST - NEW	= 453443.0(CAPACITY)	.1938	CAPACITY IN UNITS PER YEAR
CAPITAL COST - RETROFIT	= 498787.3(CAPACITY)	.1938	CAPACITY IN UNITS PER YEAR
ANNUALIZED COST - NEW	= 46504.8(CAPACITY)	.2613	CAPACITY IN UNITS PER YEAR
ANNUALIZED COST - RETROFIT	= 52125.7(CAPACITY)	.2573	CAPACITY IN UNITS PER YEAR

TECHNICAL REPORT DATA <i>(Please read Instructions on the reverse before completing)</i>			
1. REPORT NO. EPA-600/2-79-185		3. RECIPIENT'S ACCESSION NO.	
4. TITLE AND SUBTITLE Cost Effectiveness Model for Pollution Control at Coking Facilities		5. REPORT DATE August 1979	
7. AUTHOR(S) William F. Kemner		6. PERFORMING ORGANIZATION CODE	
9. PERFORMING ORGANIZATION NAME AND ADDRESS PEDCo Environmental, Inc. 11499 Chester Road Cincinnati, Ohio 45242		8. PERFORMING ORGANIZATION REPORT NO.	
12. SPONSORING AGENCY NAME AND ADDRESS EPA, Office of Research and Development Industrial Environmental Research Laboratory Research Triangle Park, NC 27711		10. PROGRAM ELEMENT NO. LAB604	
		11. CONTRACT/GRANT NO. 68-02-2603, Task 44 and 68-02-3074, Task 6	
		13. TYPE OF REPORT AND PERIOD COVERED Task Final; 9/78 - 7/79	
		14. SPONSORING AGENCY CODE EPA/600/13	
15. SUPPLEMENTARY NOTES IERL-RTP project officer Twidwell is no longer with EPA; for details contact Norman Plaks, Mail Drop 62, 919/541-2733.			
16. ABSTRACT The report describes a computer model, developed for coking facilities, that allows the user to determine the optimum mix of pollution control devices to achieve a specified reduction in pollutant emission at the minimum annualized or capital cost. The computer program calculates and displays: the associated cost for each emission control; the total capital and annualized cost for the optimum mix of controls; and the emission levels in pounds of pollutant per ton of coal and tons of pollutant per year for each of the four pollutant types (total suspended solids, benzene-soluble organics, benzo(a)pyrene, and benzene). The program can consider 20 emission sources and 9 control options for each emission source.			
17. KEY WORDS AND DOCUMENT ANALYSIS			
a. DESCRIPTORS		b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group
Pollution Organic Compounds Coking Pyrenes Iron and Steel Industry Cost Effectiveness Mathematical Models Benzene		Pollution Control Stationary Sources Suspended Solids Benzo(a)pyrene	13B 13H 11F 14A 12A 07C
18. DISTRIBUTION STATEMENT Release to Public		19. SECURITY CLASS (This Report) Unclassified	21. NO. OF PAGES 293
		20. SECURITY CLASS (This page) Unclassified	22. PRICE