




Preliminary Design and Initial Testing of a Mobile Electrostatic Precipitator

Interagency
Energy/Environment
R&D Program Report



RESEARCH REPORTING SERIES

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into nine series. These nine broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and a maximum interface in related fields. The nine series are:

1. Environmental Health Effects Research
2. Environmental Protection Technology
3. Ecological Research
4. Environmental Monitoring
5. Socioeconomic Environmental Studies
6. Scientific and Technical Assessment Reports (STAR)
7. Interagency Energy-Environment Research and Development
8. "Special" Reports
9. Miscellaneous Reports

This report has been assigned to the ENVIRONMENTAL PROTECTION TECHNOLOGY series. This series describes research performed to develop and demonstrate instrumentation, equipment, and methodology to repair or prevent environmental degradation from point and non-point sources of pollution. This work provides the new or improved technology required for the control and treatment of pollution sources to meet environmental quality standards.

REVIEW NOTICE

This report has been reviewed by the U.S. Environmental Protection Agency, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policy of the Agency, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

This document is available to the public through the National Technical Information Service, Springfield, Virginia 22161.

Preliminary Design and Initial Testing of a Mobile Electrostatic Precipitator

by

Grady B. Nichols

**Southern Research Institute
2000 Ninth Avenue, South
Birmingham, Alabama 35205**

**Contract No. 68-02-1860
Program Element No. EHE624A**

EPA Project Officer: Dale L. Harmon

**Industrial Environmental Research Laboratory
Office of Energy, Minerals, and Industry
Research Triangle Park, NC 27711**

Prepared for

**U.S. ENVIRONMENTAL PROTECTION AGENCY
Office of Research and Development
Washington, DC 20460**

DISCLAIMER

This report has been reviewed by the Industrial Environmental Research Laboratory, U. S. Environmental Protection Agency, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the U. S. Environmental Protection Agency, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

ABSTRACT

This report describes the factors considered and the general design concepts of a mobile electrostatic precipitator. This pilot scale device is one of a family of laboratory scale control devices utilized by the Industrial Environmental Research Laboratory of the U. S. Environmental Protection Agency located at Research Triangle Park, N. C. The final design and construction of the unit was provided by the Naval Surface Weapons Center at Dahlgren, Virginia.

TABLE OF CONTENTS

	<u>Page</u>
Figures.....	iii
Tables.....	iv
Section I	
Introduction.....	1
Section II	
Discussion.....	2
Section III	
Field Evaluation.....	10
Section IV	
Design Of Additional Items.....	11
Appendix I	
Design Drawings For Use By - Naval Surface Weapons Center for the Mobile Electrostatic Precipitator.....	14-26
Appendix II	
Pilot Electrostatic Precipitator Operating Guide.....	27-31

FIGURES

<u>Number</u>		<u>Page</u>
1	Sodium carbonate injection system for E.P.A. pilot E.S.P.....	12
2	300 cfm cyclone with a D ₅₀ of 5 microns.....	13

TABLES

<u>Number</u>		<u>Page</u>
I	Comparison Of Pilot And Full Scale Electrostatic Precipitator Parameters.....	4
II	Mobile Pilot Electrostatic Precipitator Shakedown Tests NERC Laboratories.....	7
III	Mobile Electrostatic Precipitator Tests.....	8

SECTION I

INTRODUCTION

This report summarizes the work performed under Contract 68-02-1860 to provide the general design and assistance in the evaluation of a mobile electrostatic precipitator. This test facility was constructed for the Industrial Environmental Research Laboratory of the U. S. Environmental Protection Agency at Research Triangle Park, North Carolina, by the Environmental Sciences Branch, of the Naval Surface Weapons Center at Dahlgren, Virginia.

The mobile electrostatic precipitator test facility was designed to assist the Industrial Environmental Research Laboratory in evaluating the applicability of the E.S.P. to a variety of industrial applications. The test facility design included both a pilot scale electrostatic precipitator and a laboratory van. The two units comprise a self sufficient facility with the exception of the requirements for external sources of electrical energy and water.

SECTION II

DISCUSSION

Southern Research Institute was directed to supply a conceptual design for the mobile test facility and to provide assistance to the E.P.A. during the construction and test of the unit. These services were provided as needed during the period of time that the contract was active. The guidelines for this contract specified in the scope of work were:

1. Mobile unit mounted on trailer suitable for highway travel
2. Three inlet and outlet sampling sites included
3. Minimum of four independent electrical sections
4. Secondary voltage and current meters required
5. Operation up to temperature of 480°C
6. Fans and strip heaters to be included
7. Variable intensity rappers required
8. Include optical instrumentation port
9. Provide guidance in design of data sheet
10. Design 300 cfm cyclone with a D_{50} of 5 microns
11. Include gas flow control devices.

In addition the following items were to be considered for inclusion if practical:

1. Lighted view ports in outlet section
2. Utilize standard E.S.P. electrical insulators
3. Wet and dry operation
4. Variable collection electrode spacing
5. Use precipitator vehicle for laboratory van.

The items in the second group were to serve as suggestions for the Naval Surface Weapons Center in the design of the unit, of these, only the view ports were actually incorporated into the final design of the unit.

The initial design for the electrostatic precipitator was transmitted to the Environmental Protection Agency and the Naval Surface Weapon Center on September 24, 1974. The drawings, reduced and included as Appendix I of the report, served as a conceptual design for the pilot precipitator. The Naval Surface Weapon Center developed the final design of the mobile E.S.P. from these suggestions. Meetings were held between the individual parties at Research Triangle Park, Naval Surface Weapons Center and Southern Research Institute, during the design phase for this mobile test facility.

A number of problems were encountered during the development of the device. Electrical sparkover between the corona wire support system and grounded portion of the system occurred. Similarly, electrical sparking occurred from the point that the high voltage connecting is made to the corona frame. These problems were solved during visits to the Naval Surface Weapon Center.

The power supplies that were delivered from Peschel Instruments also required some modifications. Even though the required voltage and current were stated to meet the specified values when connected to a resistive load, they did not when connected to the corona frame. These problems were corrected by the manufacturer when the transformers were returned.

The design conditions selected for the mobile electrostatic precipitator were intended to include typical operating conditions for full scale installations as near as was practical. A comparison between these conditions for the pilot unit and the majority of field installations are given below in Table I.

It is to be noted that the only significant departure from full scale conditions lies in the electrical sectionalization. It is impractical to duplicate this parameter in pilot units because of size and weight requirements. This departure from comparable conditions generally leads to the ability to operate the pilot unit at voltages and average current densities that are somewhat greater in the pilot unit than is possible in a comparable full scale unit. This factor places a constraint on the permissible operating conditions for the pilot unit when attempting to simulate full scale behavior.

A second departure from full scale conditions is related to gas sneaking past electrified regions. It is difficult to estimate the amount by which this differs between pilot and full scale devices. In general, the relative quantity of dust laden gas that bypasses the electrified region is significantly greater in pilot scale devices than in full scale units. Care was exercised in the design of the pilot scale unit to minimize the effect of gas sneaking.

TABLE I
COMPARISON OF PILOT AND FULL SCALE
E.S.P. PARAMETERS

<u>ITEM</u>	<u>PILOT</u>	<u>FULL SCALE</u>
Specific collection area $M^2\text{sec}/M^3$	20-100	20-150
Wire to plate spacing - cm	13	10-15
Wire to wire spacing - cm	18	10-30
Electrical fields in direction of gas flow	2-5	2-12
Gas velocity M/sec	0.5-2.0	1-2.5
Current density nA/cm^2	5-100	5-80
Plate area per T.R. Set M^2	9	50-750

The mobile E.S.P. and laboratory vans were delivered to the Environmental Protection Agency for final checkout. Tests were conducted to verify the performance of the delivered items. The results of these tests and a discussion of the design of the mobile unit were discussed in a paper¹ given in an E.P.A. sponsored symposium in Denver, Colorado, "Particulate Collection Problems Using Electrostatic Precipitators in the Metallurgical Industry."

Southern Research Institute provided the Environmental Protection Agency with a suggested measurement program and sampling port requirements as a part of this contract. The items required to be measured in the mobile pilot scale precipitator are described below. It is desirable to provide sufficient sampling ports such that all measurements can be made simultaneously. The sampling locations for mass loading and particle size distribution measurement should be in a region where a reasonably uniform gas velocity distribution exists. The other measurements may be made in regions of non-uniform flow without significantly deleterious effects. The following measurements must be made at both the inlet and outlet breechings to the precipitator:

1. Mass loading
2. Particle size 0.3 μm and greater
3. Particle size 0.5 μm and smaller
4. Gas velocity and temperature distribution
(can use mass and/or particle size ports)
5. Isokinetic ash sample (dry collection)
6. Particulate resistivity
7. Gas composition
8. Operating temperature

The mass loadings should be made with an EPA Method 5 apparatus. It is desirable to provide for a permanent installation for the control console with semi-permanent sampling rails to support the sampling case and probe.

The sampling ports for the impactors and fine particle sampling should be located at a point that provides for a minimum of interference with the mass train sampling equipment.

The gas velocity distribution can be measured in the sampling points provided for the mass train and size distribution measurements.

Footnote 1. Brumfield, J.L. and Crowson, Fred. "Design and Fabrication of a Mobile Electrostatic Precipitator." Paper #11, Proceedings: Particulate Collection Problems Using ESP's in the Metallurgical Industry EPA-600/2-77-208, Oct. 1977

The sampling points for isokinetic dry ash samples, particulate resistivity, and gas composition can be located at almost any point, since the gas velocity distribution, turbulence, and gas velocity are not critical to these measurements. The dry isokinetic ash collection is necessary for providing a sample of ash for chemical analysis and laboratory resistivity measurements. Since the Method 5 system utilizes washings and dry filter collection, the dry sample is required. The gas composition sampling point is not critical since the high diffusivity gas components readily maintain good mixing throughout the ducts.

A temperature measurement should be provided in both the inlet and outlet duct with recording capability. These measurements provide information about the stability of the source as well as giving an indication of any gas leakage into the precipitator.

A total gas volume measurement on the outlet duct or stack is desirable because it does not include errors inherent in the velocity traverses. A venturi type meter or a calibrated orifice with pressure drop readout is recommended.

It is also necessary to provide ready access to the secondary voltage and current readings from the precipitator power supplies. These readings should be recorded at regular intervals during the test period.

A follow-up to the initial recommendations were submitted as a report to the Environmental Protection Agency on November 24, 1976. This report described a test plan that should serve to both evaluate the performance of the mobile E.S.P. as well as answer some specific questions about the performance of an electrostatic precipitator experiencing some difficulties in operation. This particular field test was not conducted because of some contractual problems between the utility and the E.S.P. supplier.

This test program included base line tests with the normal coal and a test to evaluate the addition of sodium carbonate to improve the performance. The test program summarized below does not include the tests to evaluate the sodium conditioning but rather represents a two week's test period to evaluate the pilot E.S.P.

The two weeks of field tests were designed to characterize the behavior of the E.S.P. pilot plant under actual field test conditions. This includes tests over a range of gas velocities (SCA's) and a range of applied voltages and current densities.

In each field test condition, coal samples, inlet and hopper fly ash samples, Orsat and sulfur oxide samples, and representative impactor substrate samples should be preserved for later analysis.

Flue gas temperatures and flow rates should be recorded together with individual power supply readings.

The electrostatic precipitator tests recommended are as follows:

TABLE II

MOBILE PILOT ELECTROSTATIC PRECIPITATOR
SHAKEDOWN TESTS NERC LABORATORIES

Pretest

- Day 1. Calibrate power supply meters. Prepare gas velocity distribution sampling access.
- 2-3. Gas velocity distribution inlet, Field 1, inlet; Field 5, outlet
4. Volt-ampere curves - cold gas - hot gas no particulate
5. Make-up day and determine range of velocities available.

Particulate tests - two weeks - two tests at each condition

Current density, na/cm ²	15, 40, 15 with high resistivity
Gas velocity, m/sec	0.6, 1.0
Specific collection area ft ² /kcfm	400, 240

Note: The above tests should be conducted at a temperature on the order of 140-160°C (280-300°F).

TABLE III

MOBILE ELECTROSTATIC PRECIPITATOR TESTS

Day 1-2

Connect unit to access port
 Check electrical supply
 Check meters and instrumentation
 Obtain V-I curves - cold gas
 Operate fan
 Run hot gas V-I curves
 Check mass load in pilot with main duct single point
 Check gas temperature-pilot with main duct
 Measure gas velocity distribution - inlet and outlet
 Inspect through view ports

Day 3

Stabilize system at flue gas operating temperature
 Set gas velocity
 Obtain V-I curves
 Select operating points for tests
 Select run times and sampling rates
 Run one complete test
 Mass loadings - inlet and outlet
 Impactors - inlet and outlet
 Resistivity
 Gas analysis

Day 4

Obtain two complete tests -
 gas velocity 1.5 m/sec (5 fps)
 S.C.A. = 160 ft²/kcfm - maximum current density
 Select run times and sampling rates
 Mass loadings, inlet and outlet
 Impactors, inlet and outlet
 Resistivity
 Gas analysis
 Optical density
 Ash and coal samples

Day 5

Repeat Day 4. With current density set at maximum for the inlet field in all sets

Day 6

Repeat Day 5 with current density set at 60% of inlet

Day 7

Reduce data and display for review. Determine if a repeat test is required.

Day 8

Conduct tests at gas velocity of 1 m/sec (SCA = 240)

Day 9

Repeat Day 8 at reduced current density

Day 10

Conduct tests at 0.6 m/sec
 (SCA) = 400)
 Maximum current density

Day 11

Repeat Day 10 at reduced current density.

Southern Research Institute next prepared a Pilot Electrostatic Precipitation Operating Guide for the Environmental Protection Agency. This document is included as Appendix II of this report. This guide describes our approach to the philosophy and operational techniques necessary to conduct an effective pilot electrostatic precipitator research program.

SECTION III

FIELD EVALUATIONS

The mobile electrostatic precipitator test facility was exercised in two field tests. The first test was conducted at a stoker fired steam generation system at the State of Maryland Correctional Institution at Hagarstown, Maryland and the second at the Colstrip Power Station, Montana Power Company, Colstrip, Montana. The results of these two tests were reported to the Industrial Environmental Research Laboratory by the respective contractor-operators Monsanto Research and Aerotherm Division of Acurex.

The Maryland tests were conducted to evaluate the collectability of fly ash resulting from the combustion of a combination of pelletized refuse and coal in the stoker fired boiler. This test also served as the initial field test for the pilot E.S.P. as well as a training exercise for their operating personnel. Southern Research Institute provided assistance in developing the test plan as well as operating suggestions during the test period. The tests included a comparison between the operation of the control device while utilizing coal only and coal plus refuse. Southern Research Institute did not review this report.

The tests at Colstrip, Montana were designed to evaluate the utility of sodium carbonate injection as a means for improving the collection characteristics of fly ash resulting from the combustion of Western low sulfur, low sodium coals. This test consisted of a series of base-line and conditioned tests where the electrical conditioning was provided by the injection of dry sodium carbonate into the particulate laden gas streams at temperatures well below furnace temperatures. The results of the test reported by Aerotherm Division of Acurex Corporation indicate a significant increase in the electrical conditions with a concomitant improvement in the collection efficiency of the pilot precipitator with the injection of the finely divided sodium carbonate into the gas stream.


SECTION IV

DESIGN OF ADDITIONAL ITEMS

Southern Research Institute was also requested to supply designs for a sodium carbonate injection system and a 300 cfm cyclone collector with a D_{50} of five microns. These items were designed as requested. The sodium carbonate injection system was designed according to the sketch shown in Figure 1. Southern Research Institute also supplied to the Environmental Protection Agency a material metering system, a vibra-screw feeder model SCR-20. This system was delivered to the Environmental Protection Agency for use in the shakedown tests at Raleigh-Durham and in the field test at the Colstrip Power Station.

A design for the 300 cfm cyclone was provided to the Environmental Protection Agency as shown in the sketch in Figure 2. We did no fabrication for this cyclone.


WEATHER PROTECTION REQUIRED



1. VIBRASCREW FEEDER SCR-20, 3/8 SCREW, 0 - 0.1 CFH
2. FABRICATED CONNECTION BETWEEN FEEDER & INJECTOR
3. JET INJECTOR, McMASTER-CARR -
P.O. BOX 4355, CHICAGO , CAT. 4977K-11
4. FABRICATED PIPE
5. COVER PLATE APPROX. 6" DIAM., WELDED TO BENT PIPE
6. COMPRESSED AIR SUPPLY LINE, APPROX. 100 PSIG

Figure 1. Sodium carbonate injection system for
E.P.A. pilot E.S.P.

Figure 2. 300 cfm cyclone with a D₅₀ of 5 microns.



TOLERANCES UNLESS OTHERWISE NOTED		DATE		REVISIONS		ZONE NO.	
FRACTIONS	± 1/32	SOUTHERN RESEARCH INSTITUTE BIRMINGHAM, ALABAMA 35203 TITLE 300 CFM D ₅₀ CYCLONE					
DECIMALS	± 0.010						
ANGLES	± 1°						
FINISH							
APPROVED		SCALE 1" = 1'-0" DWG. NO. 2887-1-C-22					
CHECKED		DATE 11-5-74					
DRAWN A. Francis							

APPENDIX I


Design Drawings For Use

by

NAVAL SURFACE WEAPONS CENTER

for the

MOBILE ELECTROSTATIC PRECIPITATOR



LADDER FOR ACCESS TO
TO PLATES, DUCT WORK,
AND ORIFICE PLATE.

REMOVABLE HIGH
VOLTAGE COVERS

REMOVABLE
TOP PANELS
FOR ACCESS

TRUCK HOIST FOR HANDLING
DUCT SECTIONS, PTR COVERS,
SUPPORT FRAMES, POWER SUPPLIES
ETC. MULTIPLE SOCKETS AT
CONVENIENT LOCATIONS.

POWER ON

ANTI-SNEAK Baffle

CORONA WIRE
SUPPORT FRAME

COLLECTION PLATE
SUPPORT FRAME

RAPPER OR
VIBRATOR

THERMAL
INSULATION

SAFETY
RAILING

OUTSIDE DECKING MADE
OF FLOOR GRATING FOR
EASE OF TYING DOWN
DUCT SECTIONS FOR TRAVEL

ANTI-SNEAK Baffle

DUST CONTAINER

TRAILER

TRAILER
JACK ON
ALL CORNERS

PRECIPITATOR

SOUTHERN RESEARCH INSTITUTE
BIRMINGHAM, ALABAMA 35205

TITLE


PORTABLE PILOT PRECIPITATOR

DRAWN BY FRANCIS
DATE 11-19-73

DWG. NO.

2887-1-C-11

CROSS SECTION



ALTERNATE CONSTRUCTIONS
WITH DIFFERENT STRUCTURAL
MEMBERS AND LESS USABLE
HEIGHT.

SOUTHERN RESEARCH INSTITUTE BIRMINGHAM, ALABAMA 35205		TITLE	MOBILE P/L PRECIPITATOR
DRAWN BY: 5	DATE: 9-1-74	DWG. NO.	2887-C-12
			TRAILER/HOPPER INTERFACE

NOTE: ROUND ALL
EDGES - NO SHARP
CORNERS. HIGH VOLTAGE
PARTS TO CLEAR ALL
GROUNDED PARTS AS
FOLLOWS:

5 INCHES FROM FLAT SURFACES
8 INCHES FROM ROUNDED
SURFACES ($\frac{1}{2} R$)

NO SHARP EDGES

TUBING
1" MINIMUM

WIRE SPACING
6" TO 8"
(1.2 TO 1.6 TIMES
WIRE TO PLATE)
WIRES TO BE STRAIGHT
 $\pm \frac{1}{4}$ INCH


SPACE REQUIRED TO
CLEAR EDGE OF HOPPER

APPROX
36"

GREATER
THAN
PLATE
HEIGHT

NOTE THAT CORONA WIRE FRAME IS
SUSPENDED FREELY FROM TWO
INSULATORS. THIS WILL REQUIRE
ACCURATE LEVELLING OF THE
TRAILER FOR OPERATION, BLOCKING
OF THE FRAME FOR TRAVELLING,
AND A SOFT MOUNT TO RELIEVE
STRESS ON THE INSULATOR.

#3-48 UNC
.099 DIA



.100 DIAM
WIRE

CHANGEABLE
WIRE SIZES

WIRE TENSIONING

SOUTHERN RESEARCH INSTITUTE
BIRMINGHAM, ALABAMA 35205

TITLE
MOBILE PILOT PRECIPITATOR


DRAWN *NEP/MS*
DATE 9-16-74

DWG. NO.

2877-1-C-15

CORONA WIRE SUPPORT FRAME

NOTE: ANY PRACTICAL DESIGN IS ACCEPTABLE; PROVIDED THERE IS A RIGID CONSTRUCTION TO SURVIVE RAPPING, A SOFT MOUNT TO ISOLATE RAPPING, AND A GOOD CONTACT TO THE RAPPER



SOUTHERN RESEARCH INSTITUTE
BIRMINGHAM, ALABAMA 35203


DRAWN *AFRANCIS*
DATE 9-16-74

DWG. NO.

2887-1-C-14

TITLE MOBILE PILOT PARTICIPANT

COLLECTION MATERIAL NAME




PIPE AND HOUSING HIGH VOLTAGE
SUPPLY FOR RUGGEDNESS.

SPACING:

R = 5 INCHES TO FLAT SURFACES


R = 8 INCHES TO ROUNDED
SURFACES ($\frac{1}{2} R$)

NO SHARP CORNERS



FLEXIBLE HIGH VOLTAGE CABLE
FOR MINIMUM SPACE REQUIREMENT

SOUTHERN RESEARCH INSTITUTE BIRMINGHAM, ALABAMA 35203		TITLE MOBILE PLANT PRECIPITATION
DRAWN BY DATE 9-10-74	DWG. NO. 22-7-1-C-15	HIGH VOLTAGE LEADS



LOCATION OF ANTI-SNEAK BAFFLES


CLEARANCES:

R = 5 INCHES TO FLAT SURFACES OF OPPOSITE POLARITY

R = 8 INCHES TO ROUNDED SURFACES ($\frac{1}{2}$ " RADIUS)

NO SHARP CORNERS

SOUTHERN RESEARCH INSTITUTE BIRMINGHAM, ALABAMA 35203		TITLE MOBILE PILE PRECIPITATION
DRAWN BY: JAC/LS DATE 7-16-74	DWG. NO. 2:7-1-C-16	ANTI-SNEAK BAFFLES





SOUTHERN RESEARCH INSTITUTE
BIRMINGHAM, ALABAMA 35203

DRAWN BY FRANCIS
DATE 9-16-74

DWG. NO. 2887-1-C-11

TITLE MOBILE PILOT PRECIPITATION

FLOW RECTIFICATION SECTION

DETAIL


SOUTHERN RESEARCH INSTITUTE
BIRMINGHAM, ALABAMA 35203

TITLE
MOBILE PILOT PRECIPITATION

DRAWN BY
DATE 9-17-70

DWG. NO.
25000-C-1A


REVERSIBLE VANED INLET ELBOW



NOTE:
USE EXTREMELY LONG TRANSITION
IN ORDER TO GET SMOOTH TRANSITION
OF FLOW FROM HIGH KINETIC ENERGY
AND VELOCITY TO LOW KINETIC ENERGY
AND VELOCITY. AREA INCREASES 4
TO 8 TIMES, VELOCITY DECREASES 4
TO 8 TIMES, BUT KINETIC ENERGY
DECREASES 21 TO 66 TIMES DEPENDS
ON SIZE DUCTWORK CHOSEN.


SOUTHERN RESEARCH INSTITUTE BIRMINGHAM, ALABAMA 35203		TITLE MOBILE PILOT PRECISION TAILOR
DRAWN BY DATE 9-17-74	OWD. NO. 2897-1-C-19	INLET TRANSITION

ADJUSTABLE
SPOTLIGHT
MOUNTED ON
CEILING OR
WALL



OUTLET TRANSFORM

REPLACE TEMPERED PYREX
SIGHT GLASS WITH TRANSITE
GLASS WHEN TEMPERATURE
IS EXPECTED TO EXCEED 800°F.



DETAIL OF ILLUMINATION
AND VIEW PORTS

SOUTHERN RESEARCH INSTITUTE
BIRMINGHAM, ALABAMA 35205

DRAWN *Francis*
DATE 9-17-74

DWG. NO. 2887-1-C-20

TITLE
MOBILE PILOT FIRE CHILLER

OUTLET TRANSFORM

GENERAL NOTE:

IMPORTANT DIMENSIONS ARE SPECIFIED ON DRAWINGS 2887-1-C-10 THRU 20. OTHER DIMENSIONS AND DESIGN DETAILS MAY BE ALTERED FOR CONVENIENCE OF MANUFACTURE, AVAILABILITY OF MATERIALS OR FREEDOM OF DESIGN.

LABORATORY TRAILER NEEDS:CONTROL SECTION -

CONTROL PANEL
DESK/TABLE WITH CHAIR
CALCULATOR, OFFICE SUPPLIES
FILE FOR DATA AND REFERENCES

LABORATORY SECTION -

SINK AREA: SINK WITH DRAIN
WATER SUPPLY
WATER HEATER
BALANCE AREA: BALANCE
STABLE SUPPORT
STOOL
BENCH AREA: WORK BENCH
SHOCKPROOF GLASS STORAGE
GLASSWARE
LABORATORY EQUIPMENT
110 VAC TERMINAL STRIP
EXPENDABLE SUPPLIES
HOT PLATE, STIRRERS, ETC.

MAINTENANCE AREA

WORK BENCH, VISE, TOOLS
LOCKERS FOR HARD HATS & WORK CLOTHES
STORAGE FOR STAIRS DURING TRAVEL
STORAGE FOR EMPTY SAMPLE CONTAINERS

GENERAL

HEAT AND AIR CONDITIONING
VENTILATION
SIDE DOOR FOR DIRECT ACCESS TO PPTR
LIGHTS (FLUORESCENT FOR LOW PROFILE)
110 VAC CONVENIENCE OUTLETS
STEP STANDS (2)
JACKS
WINDOWS OPTIONAL

COMMERCIAL SOURCE

HARDWARE ITEMS AVAILABLE FROM:
MC MASTER CARR SUPPLY COMPANY
P.O. BOX 4355 CHICAGO, ILL. 60640
CRANE HOIST, 750 LB. CAP. CAT # 32304T
HAND TRUCK, CAT # 262123
TRAILER JACKS # 2942 T16
MAGNETIZED SHIRT LEVEL # 2169
MAINTENANCE WORK BENCH # 477Y22
LABORATORY STOOLS # 4818X21
EXTENSION FLANK FOR ACCESS TO DRIPICE
12" WIDE X 10 FT LONG # 8040 X1
LOCKERS, DOUBLE TIER, 12 X 18, # 4962 X26
TEMPERED PLYWOOD SIGN GLASSES
8 3/8" DIAM X 3/4" THICK # 847 P55
RAPPING VIBRATOR, VARIABLE FREQUENCY
58 MO 61
SQUARE MESH PERFORATED METAL
3/4 SQUARES 57% OPEN 18 GAUGE
9353 X4
TURNBUCKLES, STEEL, 1/2", EYE & EYE
3012 X1
HIGH TEMPERATURE ASBESTOS PACKING FOR
SIGHT GLASSES, ALUMINUM FOIL COVERED
1/2" X 1/2" # 4871
EXHAUST FANS FOR SAMPLING STATIONS
24" FAN WITH INLET SAFETY GUARD
AND AUTOMATIC SHUTTERS # 1916 N11
WALL LADDER, PERMANENT MOUNT
7983 Z

SOUTHERN RESEARCH INSTITUTE
BIRMINGHAM, ALABAMA 35205

TITLE
MOBILE PILOT PRECIPITATOR

DRAWN BY
DATE 9-15-70

DWG. NO.
2887-1-C-21

GENERAL NOTES

APPENDIX II

PILOT ELECTROSTATIC PRECIPITATOR

OPERATING GUIDE

SORI-EAS-77-040

PILOT ELECTROSTATIC PRECIPITATOR
OPERATING GUIDE

by

Grady B. Nichols

Southern Research Institute
2000 Ninth Avenue South
Birmingham, Alabama 35205

Project No. 3419

EPA Project Officer: Dale Harmon

Environmental Protection Agency
Industrial Environmental Research Laboratory
Research Triangle Park, N. C. 27711

Prepared For

INDUSTRIAL ENVIRONMENTAL RESEARCH LABORATORY
ENVIRONMENTAL PROTECTION AGENCY
RESEARCH TRIANGLE PARK, N. C. 27711

January 18, 1977

PILOT ELECTROSTATIC PRECIPITATOR OPERATING GUIDE

Introduction. The operating techniques for utilizing the pilot E.S.P. will be developed as the test personnel become more familiar with the individual characteristics of the particular unit. This document was prepared as a guide for use in the early checkout and performance stages of the device.

Initial Installation and Checkout

The test location should be surveyed prior to moving the test facility to the test site. A sketch of the available space should be prepared and access ports installed. Arrangements for electrical power should be made with plant personnel. A plant contact should be established at this time.

The particulate and gas extraction ports should be located and an acceptable sample extraction nozzle designed. This design should provide for near isokinetic extraction at the mid-range of the anticipated operating volume flow rate.

In some instances, it may be desirable to provide for a sample extraction array and plenum to provide for a more representative sample extraction. In those instances where significant temperature or dust concentration variations occur within the ductwork this alternative should be considered. This plenum design may be equipped with variable cross sections for the sample extraction as a means for maintaining isokinetic sampling over an acceptable range of gas volume flow rates. This variable throat sampling need not always be provided; only in those cases where the fundamental purposes for the test program dictates the need.

The pilot electrostatic precipitator and laboratory trailers should be moved to the test site and located on the predetermined positions. The ductwork should be checked and positioned

to determine if the connections are adequate. The internals of the pilot unit should be inspected and corrected while the electrical connections and ductwork are being installed.

After the electrical connections are complete, the test facility fan should be tested. Air load voltage vs current data should be recorded and compared with previous curves. The ash removal system and other auxiliary equipment should be checked.

Initial Tests

At the completion of the installation, inspection and check-out portion, the system should be activated to pull hot particulate laden gas through the test unit. The test unit should be allowed to thermally equilibrate; after which gas velocity distributions and hot gas voltage vs current data should be recorded and analyzed.

If the gas velocity distribution is inadequate, corrections should be made to the inlet system to obtain an acceptable gas flow quality. The V-I data should be provided in order to select an operating point for the power supplies for the tests.

Initial mass, resistivity and gas analysis tests should be performed on the pilot plant. Parallel tests should generally be conducted in the main flue to assure that representative conditions exist in the test unit. These data should be evaluated prior to the initiation of the main test program.

Experimental Test Program

A test plan should be prepared for the main test program prior to moving the equipment to the test site. This test plan should be reviewed for the test crew and task assignments made. At the beginning of the field experimental program, a shake-down test should be conducted. This evaluates the adequacy of equipment, space and port allowances and smoothness of operation. At the completion of the shakedown test, the results should be compiled and the adequacy of the test plan reviewed. A daily test log should of course be maintained for the test.

The complete test program should now be conducted. It is advisable to conduct review meetings between key test personnel at intervals during the actual tests. At these times the adequacy of the tests and any required modifications to the test plan can be discussed.

At the completion of the test program, each key test person should review his data to ascertain that adequate samples have been collected and preserved. These samples should be carefully labeled and packaged for shipment. The daily test log should be reviewed prior to concluding the tests.

Equipment Preparation

The test facility should be carefully disconnected from the test site and prepared for moving to a new location. Specific packing assignments should be prepared with one person responsible for checking prior to departure.

TECHNICAL REPORT DATA <i>(Please read instructions on the reverse before completing)</i>		
1. REPORT NO. EPA-600/7-78-096	2.	3. RECIPIENT'S ACCESSION NO.
4. TITLE AND SUBTITLE Preliminary Design and Initial Testing of a Mobile Electrostatic Precipitator		5. REPORT DATE June 1978
		6. PERFORMING ORGANIZATION CODE
7. AUTHOR(S) Grady B. Nichols		8. PERFORMING ORGANIZATION REPORT NO.
9. PERFORMING ORGANIZATION NAME AND ADDRESS Southern Research Institute 2000 Ninth Avenue, South Birmingham, Alabama 35205		10. PROGRAM ELEMENT NO. EHE624A
		11. CONTRACT/GRANT NO. 68-02-1860
12. SPONSORING AGENCY NAME AND ADDRESS EPA, Office of Research and Development Industrial Environmental Research Laboratory Research Triangle Park, NC 27711		13. TYPE OF REPORT AND PERIOD COVERED Final; 11/74-1/78
		14. SPONSORING AGENCY CODE EPA/600/13
15. SUPPLEMENTARY NOTES IERL-RTP project officer is Dale L. Harmon, Mail Drop 61, 919/541-2925.		
16. ABSTRACT The report summarizes work done to provide the general design and assistance in evaluating a mobile electrostatic precipitator (ESP) built for the EPA by the Naval Surface Weapons Center, Dahlgren, Virginia. The mobile test facility was designed to aid IERL-RTP in evaluating ESPs in a variety of industrial applications. The test facility design included both a pilot scale ESP and a laboratory van. The two units comprise a self sufficient facility, except for external sources of electricity and water.		
17. KEY WORDS AND DOCUMENT ANALYSIS		
a. DESCRIPTORS	b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group
Air Pollution Electrostatic Precipitators Mobile Equipment Laboratories Design Tests Dust	Air Pollution Control Stationary Sources Particulate	13B 13I 15E 14B 11G
18. DISTRIBUTION STATEMENT	19. SECURITY CLASS (This Report)	21. NO. OF PAGES
Unlimited	Unclassified	38
	20. SECURITY CLASS (This page)	22. PRICE
	Unclassified	