




Emission Reduction on Two Industrial Boilers with Major Combustion Modifications (Data Supplement)

**Interagency
Energy/Environment
R&D Program Report**



RESEARCH REPORTING SERIES

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into nine series. These nine broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and a maximum interface in related fields. The nine series are:

1. Environmental Health Effects Research
2. Environmental Protection Technology
3. Ecological Research
4. Environmental Monitoring
5. Socioeconomic Environmental Studies
6. Scientific and Technical Assessment Reports (STAR)
7. Interagency Energy-Environment Research and Development
8. "Special" Reports
9. Miscellaneous Reports

This report has been assigned to the INTERAGENCY ENERGY-ENVIRONMENT RESEARCH AND DEVELOPMENT series. Reports in this series result from the effort funded under the 17-agency Federal Energy/Environment Research and Development Program. These studies relate to EPA's mission to protect the public health and welfare from adverse effects of pollutants associated with energy systems. The goal of the Program is to assure the rapid development of domestic energy supplies in an environmentally-compatible manner by providing the necessary environmental data and control technology. Investigations include analyses of the transport of energy-related pollutants and their health and ecological effects; assessments of, and development of, control technologies for energy systems; and integrated assessments of a wide range of energy-related environmental issues.

EPA REVIEW NOTICE

This report has been reviewed by the participating Federal Agencies, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the Government, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

This document is available to the public through the National Technical Information Service, Springfield, Virginia 22161.

December 1978

Emission Reduction on Two Industrial Boilers with Major Combustion Modifications (Data Supplement)

by

**K.T. Fisher, J.J. Buening, W.A. Carter,
and S.C. Hunter**

**KVB, Inc.
17332 Irvine Boulevard
Tustin, California 92680**

**Contract No. 68-02-2144
Program Element No. EHE624A**

EPA Project Officer: Robert E. Hall

**Industrial Environmental Research Laboratory
Office of Energy, Minerals, and Industry
Research Triangle Park, NC 27711**

Prepared for

**U.S. ENVIRONMENTAL PROTECTION AGENCY
Office of Research and Development
Washington, DC 20460**

Limitations On Application Of Data Reported

The data cited in this report are test results of measured pollutant emissions from two industrial boilers. These emission levels are not suitable for use in estimating mean emissions from industrial boilers as a class nor are they suitable in compiling areawide emission inventories. They are not suitable for predicting emissions from any one boiler or as regulatory limits or emission standards. Use of emissions as emission standards automatically would place a large proportion of the industrial boiler population in noncompliance.

CONTENTS

	<u>Page</u>
FOREWORD	iv
INSTRUMENTATION	vii
GLOSSARY	viii
CONVERSION FACTORS	ix
SITE LOCATION NUMBER 19	
Industrial Boiler Design Data	1
Mobile Laboratory Data	2
Unit Operating Data	56
Fuel Analyses	108
Particulate and Impactor Data	111
Plume Opacity Data	177
Velocity Traverse Data	194
SO _x Data Sheets	206
SASS Test Data	246
SITE LOCATION NUMBER 38	
Industrial Boiler Design Data	291
Mobile Laboratory Data	292
Control Room Data	312
Fuel Analyses	332
Particulates and Impactor Data	335
Velocity Traverse Data	372
Staged Combustion Air Flow Data	397

FOREWORD

The purpose of this Data Supplement Volume is to document data in greater detail than was practical in the final report for this contract. It is intended to provide the necessary details to other researchers who are interested in performing their own analysis.

Readers are referred to the contract final report for information as to objectives, selection of units, measurement procedures, interpretations and conclusions.¹

All data presented for gaseous emission concentrations of NO, NO_x, CO, HC, SO₂, and SO₃ are expressed in parts per million by volume (ppm) on a dry basis corrected to 3 percent O₂ by volume (dry) in the flue gas.

The data are arranged in this volume by Location Number for Locations 19 and 38. A location is defined as one company or plant in which one or more units were tested. Each boiler tested at a location is identified by a unit number. The contract final report refers to the test number when data are discussed. The test number is of the form XX/YY-ZZ, where XX = location number, YY = unit number, and ZZ = test number on that unit. For sites where only one unit was tested the /YY unit number is deleted.

¹Carter, W. A., et al., "Emissions Reduction on Two Industrial Boilers with Major Combustion Modifications," PB 283 109, EPA 600/7-78-099a, June 1978.

For each unit tested, the data supplement contains the following information:

1. Industrial Boiler Design Data

Design data tabulations include: unit description, installation date, steam conditions, furnace characteristics, burner type and spacing, fuels burned, and design temperatures for fuel, air and stack gas.

2. Mobile Laboratory Data (Gaseous Emissions)

Emission measurements tabulated for each test include test type test load, combustion conditions (excess O₂, CO₂), gaseous emissions (NO_x, NO, CO, HC, SO_x, and SO₂ all at the measured O₂ and at 3% O₂, dry).

3. Unit Operating Data

Control room data tabulated include steam pressure and temperature, combustion air and stack temperatures, fuel flow, fuel temperature and pressure, furnace pressure, and burner air register setting.

4. Fuel Analysis

Laboratory reports of fuel analysis are included.

5. EPA Method 5 Particulates and Cascade Impactor Data

Data sheets for EPA Method 5 include control console data, particulate calculation sheet, and particulate emission calculations. Data sheets for cascade impactors include control console data, cascade impactor weight data, calculated aerodynamic particle size for each stage, and particulate emission calculations.

The impactor used was an Anderson 2000 Model III with the following stage dimensions:

<u>Jet No.</u>	<u>Jet Diameter, cm</u>
1	0.1638
2	0.1253
3	0.0948
4	0.0759
5	0.0567
6	0.0359
7	0.0261
8	0.0251

6. Plume Opacity Observation Record

Opacity observations by EPA Method 9 are recorded.

7. Velocity Traverse Data

Stack traverse data for O₂, velocity and temperature as a function of position in the stack are included.

8. SO_x Data Sheets

SO_x calculation data for each of three runs with the wet chemistry train are included.

9. SASS Test Data (Location 19 only)

Data sheets include sampling conditions, control console data, particulate emission calculations, sample recovery logs, and sample concentration results by atomic absorption, spark source mass spectrometry, gas chromatography, and gas chromatograph-mass spectrograph.

Dash marks entered on the data forms indicate that data were not available.

INSTRUMENTATION

The emission measurements were made with instrumentation contained in a 2.5 by 9 meter (8 by 30 ft) laboratory trailer. The gaseous emission measurements were made with analyzers located in the measurement console in the trailer. The particulate concentration, particulate size, sulfur oxides, and trace species concentration measurements were made with instrumentation prepared in the wet chemistry area of the laboratory and taken to the sample port. The weighing and titration were done in or near the laboratory.

The emission measurement instrumentation used for the program was that shown in Table 1. The operation of the instrumentation is discussed in detail in the contract final report.

TABLE 1. EMISSION MEASUREMENT INSTRUMENTATION

Emission	Symbol	Measurement Method	Equipment Mfgr & Model
Nitric oxide	NO	Chemiluminescent*	Thermo Electron, 10A
Oxides of nitrogen	NO _x	Chemiluminescent*	Thermo Electron, 10A
Carbon monoxide	CO	Spectrometer*	Beckman, 864
Carbon dioxide	CO ₂	Spectrometer*	Beckman, 865
Oxygen	O ₂	Polarographic*	Teledyne, 326A
Hydrocarbons	HC	Flame ionization*	Beckman, 402
Sulfur dioxide	SO ₂	Photometric*	Dupont, 400
Sulfur dioxide and trioxide	SO ₂ , SO ₃	Absorption/titration	KVB Equipment Co.
Total particulate matter	PM	EPA Standard Method 5	Joy Mfg. Co.
Particulate size	--	Cascade impactor	Anderson 2000, Mark III
Smoke spot	K	Reflection	Research Appliance Co.
Opacity	--	EPA Standard Method 9	--
Trace species and organics		EPA SASS Train	Acurex/Aerotherm SASS

*Precision, $\pm$ 1% of Full Scale

GLOSSARY OF SYMBOLS USED ON DATA FORMS

Burner Type

Air	Air Atomizer	NG	Natural Gas
Ring	Natural Gas Ring	#2	No. 2 Grade Fuel Oil
Spud	Natural Gas Gun	#6	No. 6 Grade Fuel Oil
Steam	Steam Atomizer		

Test Fuel

Test Type

Air Reg	Air Register Adjustment
Atom Press	Burner Atomizing Pressure Adjustment
BOOS	Burners Out Of Service
Base	Baseline
BrTune	Boiler Tuneup
Damper	Air Damper Adjustment
HiAir	High Excess Air
HiLoad	High Load
LowAir	Low Excess Air
LowLoad	Low Load
LowNO _x	Low NO _x Condition
NrmlAir	Normal Excess Air
OFA	Overfire Air
SCA	Staged Combustion Air
SteamInjec	Steam Injection
VPH	Variable Combustion Air Temperature
Viscosity	Fuel Oil Viscosity
FGR	Flue Gas Recirculation
SASS	Source Assessment Sampling System

CONVERSION FACTORS

SI Units to Metric or English Units

<u>To Obtain</u>	<u>From</u>	<u>Multiply By</u>	<u>To Obtain ppm at 3% O₂ of</u>	<u>Multiply* Concentration in ng/J by</u>
g/Mcal	ng/J	0.004186	<u>Natural Gas Fuel</u>	
10 ⁶ Btu	GJ	0.948	CO	3.23
Btu	gm cal	3.9685x10 ⁻³	HC	5.65
lb/10 ⁶ Btu	ng/J	0.00233	NO or NO _x	1.96
ft	m	3.281	SO ₂ or SO _x	1.41
in.	cm	0.3937		
ft ²	m ²	10.764	<u>Oil Fuel</u>	
ft ³	m ³	35.314	CO	2.93
lb	kg	2.205	HC	5.13
Fahrenheit	Celsius	$t_F = 9/5(t_C) + 32$	NO or NO _x	1.78
Fahrenheit	Kelvin	$t_F = 1.8t_K - 460$	SO ₂ or SO _x	1.28
psig	Pa	$P_{psig} = (P_{pa})(1.450 \times 10^{-4}) - 14.7$		
psia	Pa	$P_{psia} = (P_{pa})(1.450 \times 10^{-4})$	<u>Coal Fuel</u>	
iwg (39.2 °F)	Pa	$P_{iwg} = (P_{pa})(4.014 \times 10^{-3})$	CO	2.69
10 ⁶ Btu/hr	MW	3.413	HC	4.69
GJ/hr	MW	3.60	NO or NO _x	1.64
			SO ₂ or SO _x	1.18

*These conversions depend on fuel composition.
The values given are for typical fuels.

English and Metric Units to SI Units

<u>To Obtain</u>	<u>From</u>	<u>Multiply By</u>	<u>To Obtain</u> <u>ng/J of</u>	<u>Multiply*</u> <u>Concentration</u> <u>in ppm @ 3% O₂ by</u>
ng/J	lb/10 ⁶ Btu	430	<u>Natural Gas Fuel</u>	
ng/J	g/Mcal	239	CO	0.310
GJ	10 ⁶ Btu	1.055	HC	0.177
m	ft	0.3048	NO or NO _x (as NO ₂)	0.510
cm	in.	2.54	SO ₂ or SO _x	0.709
m ²	ft ²	0.0929	<u>Oil Fuel</u>	
m ³	ft ³	0.02832	CO	0.341
kg	lb	0.4536	HC	0.195
Celsius	Fahrenheit	$t_c = 5/9 (t_F - 32)$	NO or NO _x (as NO ₂)	0.561
Kelvin	Fahrenheit	$t_K = 5/9 (t_F - 32) + 273$	SO ₂ or SO _x	0.780
Pa	psig	$P_{pa} = (P_{psig} + 14.7) (6.895 \times 10^3)$	<u>Coal Fuel</u>	
Pa	psia	$P_{pa} = (P_{psia}) (6.895 \times 10^3)$	CO	0.372
Pa	iwg (39.2 °F)	$P_{pa} = (P_{iwg}) (249.1)$	HC	0.213
MW	10 ⁶ Btu/hr	0.293	NO or NO _x (as NO ₂)	0.611
MW	GJ/hr	0.278	SO ₂ or SO _x	0.850

*These conversions depend on fuel composition.
The values given are for typical fuels.

INDUSTRIAL BOILER DESIGN DATA

Location No. 19

Unit No.

Unit Description

KEELER WATERTUBE BOILER TYPE D
MODEL WB -1-145

Installation Date	1970
Steam Output (lb/hr x 10 ³)	17.5
Design Pressure, psig	250
Operating Pressure, psig	160
Final Steam Temp., °F	SATURATED
Feedwater Temp., °F	220
Furnace Type	WATERTUBE
Furnace Size L-W-H (ft)	9-6-8
Total Heating Surface, ft ²	1881
Radiant Heating Surface, ft ²	288
Convection Heating Surface, ft ²	1593
Furnace Volume, ft ³	430
Burner Description	1 FABER GAS RING AND OIL GUN BURNER
Test Fuel	NAT. GAS, #2 OIL, #6 OIL
Primary Air Temp., °F	AMBIENT
Stack Temp., °F	~490

Comments: BOILER WAS EQUIPPED WITH OVERFIRE AIR
PORTS AND FLUE GAS RECIRCULATION DUCTING

MOBILE LABORATORY DATA

Test No. _____

Test No. 19-3 Date 1/4/77 Location 19 Engr. G. SOTTERUnit No. _____ Fuel #2 Capacity 17500 lbs/hrUnit Type D59-2 Burner Type WB 114.5 FABER

	19-1	19-2	19-3	19-4	19-5
1. Test No.					
2. Date	1/4/77	1/4/77	1/5/77	1/5/77	1/6/77
3. Time	1440	1515	1035	1510	0925
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2 1/2	2 1/2	2 1/2	2 1/2	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.05	2.95	3.18	3.15	3.20
9. NOx (hot) read/3% O ₂ (ppm)*	95 95	93 93	92 93	88 81	105 106
10. NO (hot) read/3% O ₂ (ppm)*	95 95	93 93	92 93	88 81	105 106
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0 0	0 0	0
12. NO (cold) read/3% O ₂ (ppm)*	110 110	108 108	107 108	108 109	119 120
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	9	8	11 11	8 8	4 4
15. Hydrocarbon (ppm) uncor/cor*	0	0	5 5	3 3	2 2
16. Sulfur Dioxide (ppm) uncor/cor*	60 60	80 80	80 81	90 91	70 71
17. Smoke Spot (Bacharach)	0	0	0		
18. Atmos. Temp. (°F/°C)	36 °F	36 °F	18 °F	26	10 °F
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.07	30.07	30.16	30.06	30.19
21. Relative Humidity (%)	65%	65%	87%	63%	87
22. % SULFUR (APPROX FROM SO ₂)	0.10	0.14	0.14	.156	0.12
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. 1 Date _____ Location 19 Engr. G. SOTTERUnit No. _____ Fuel #2 Capacity 17,500 LB/HRUnit Type DS 9-2 Burner Type FABER WB 114.5

	19-6	19-7	19-8	19-9	19-10
1. Test No.	19-6	19-7	19-8	19-9	19-10
2. Date	1-6-77	1-6-77	1-6-77	1-7-77	1-10-77
3. Time	10:30	15:30	1605	1015	0900
4. Load	14500	14500	14500	14500	14500
5. Process Rate	—				
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.12	2.95	2.90	3.05	3.2
9. NO _x (hot) read/3% O ₂ (ppm)*	102	102 102	102 101	88 88	101 102
10. NO (hot) read/3% O ₂ (ppm)*	102	102 102	102 101	88 88	101 102
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0 0	0	0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	117	115 115	117 116	107 107	116 117
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	1	11 11	12 12	11 11	12 12
15. Hydrocarbon (ppm) uncor/cor*	3	5 5	7 7	5 5	5 5
16. Sulfur Dioxide (ppm) uncor/cor*	85 85.4	100 100	90 89	80 80	80 81
17. Smoke Spot (Bacharach)	0			0	0
18. Atmos. Temp. (°F/°C)	14	25°F	25°F	26	34°F
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.19	30.10	30.06	29.60	29.28
21. Relative Humidity (%)	87			90	
22. % S IN FUEL	0.15	.172	.153	.138	.139
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. 2+4 Date 1-10-77 Location 19 Engr. BRIENZAUnit No. _____ Fuel _____ Capacity 12,000Unit Type DS 9-2 Burner Type FABER WB 114.5

	19-11	19-12	19-13	19-14	19-15
1. Test No.	27	28	29	30	31
2. Date	1-10-77	1-10-77	1-10-77	1-10-77	1-11-77
3. Time	0950	1040	1100	1138	0938
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	5.15	0.92	0.59	3.00	3.00
9. NOx (hot) read/3% O ₂ (ppm)*	88 100	88 79	88 78	33 33	91 91
10. NO (hot) read/3% O ₂ (ppm)*	88 100	88 79	88 78	33 33	91 91
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0	0	0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	102 116	106 95	107 94	38 38	105 105
13. Carbon Dioxide (%)	—				
14. Carbon Monoxide (ppm) uncor/cor*	8 9	72-84 65-75	400-580 352-510	8 8	8 8
15. Hydrocarbon (ppm) uncor/cor*	5 5.6	8 7.2	12 10.5	10 10	5 5
16. Sulfur Dioxide (ppm) uncor/cor*	70 79	90 81	90 79	80 80	75 75
17. Smoke Spot (Bacharach)	0	4	5	0	0
18. Atmos. Temp. (°F/°C)	34°F	33°F	33°F	33°F	14°F
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	29.28	29.25	29.24	29.24	30.04
21. Relative Humidity (%)	~100% RAINING	~100% SNOW	~100% SNOW	SNOW	53%
22. % S IN FUEL	.136	.139	.136	.137	.129
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. 4 Date 1-11-77 Location 19 Engr. BRIENZAUnit No. _____ Fuel #2 Capacity 17,500Unit Type DS 9-2 Burner Type FABER WB 114.5

	19-16	19-17	19-18	19-19	19-20
1. Test No.	116	117	118	119	120
2. Date	1-11-77	1-11-77	1-11-77	1-11-77	1-11-77
3. Time	1030	1055	1205	1225	1250
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.00	2.85	2.90	0.70	1.05
9. NO _x (hot) read/3% O ₂ (ppm)*	43 43	32 32	36 36	32 28	38 34
10. NO (hot) read/3% O ₂ (ppm)*	43 43	32 32	36 36	32 28	38 34
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0 0	0 0	0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	50 50	43 43	42 42	37 33	45 40
13. Carbon Dioxide (%)	—				
14. Carbon Monoxide (ppm) uncor/cor*	8 8	10 10	10 10	350 310	62 56
15. Hydrocarbon (ppm) uncor/cor*	3 3	5 5	7 7	7 6.2	5 4.5
16. Sulfur Dioxide (ppm) uncor/cor*	70 70	80 79	70 70	80 71	85 77
17. Smoke Spot (Bacharach)	0	0	0	1	1
18. Atmos. Temp. (°F/°C)	14°F	15°	15°	17	17
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.08	30.10	30.10	30.11	30.11
21. Relative Humidity (%)	53	53	51	51	51
22. %S IN FUEL	.121	.136	.121	.122	.132
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 1/11/77 Location _____ Engr. BRIENZAUnit No. _____ Fuel #2 Capacity _____Unit Type DOV 2 Burner Type FABER WB 114.519-21 19-22 19-23 19-24 19-25

1. Test No.	<u>43</u>		<u>1-25</u>							
2. Date	<u>1/11/77</u>		<u>1/12/77</u>		<u>1/12/77</u>		<u>1/12/77</u>		<u>1/12/77</u>	
3. Time	<u>1330</u>		<u>0750</u>		<u>0845</u>		<u>0905</u>		<u>0920</u>	
4. Load	<u>14500</u>		<u>14500</u>		<u>14500</u>		<u>14500</u>		<u>14500</u>	
5. Process Rate										
6. Flue Diam. or Size, ft	<u>2.5</u>		<u>2.5</u>		<u>2.5</u>		<u>2.5</u>		<u>2.5</u>	
7. Probe Position	<u>CENTER</u>		<u>CENTER</u>		<u>CENTER</u>		<u>CENTER</u>		<u>CENTER</u>	
8. Oxygen (%)	<u>.90</u>		<u>3.00</u>		<u>5.7</u>		<u>5.4</u>		<u>4.8</u>	
9. NOx (hot) read/3% O ₂ (ppm)*	<u>27</u>	<u>24</u>	<u>90</u>	<u>90</u>	<u>75</u>	<u>88</u>	<u>80</u>	<u>92</u>	<u>96</u>	<u>106</u>
10. NO (hot) read/3% O ₂ (ppm)*	<u>27</u>	<u>24</u>	<u>90</u>	<u>90</u>	<u>75</u>	<u>80</u>	<u>80</u>	<u>92</u>	<u>96</u>	<u>106</u>
11. NO ₂ (hot) read/3% O ₂ (ppm)*	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>
12. NO (cold) read/3% O ₂ (ppm)*	<u>32</u>	<u>28</u>	<u>103</u>	<u>103</u>	<u>88</u>	<u>103</u>	<u>92</u>	<u>106</u>	<u>111</u>	<u>123</u>
13. Carbon Dioxide (%)										
14. Carbon Monoxide (ppm) uncor/cor*	<u>45</u>	<u>40</u>								
15. Hydrocarbon (ppm) uncor/cor*	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>	<u>5.8</u>	<u>3</u>	<u>3</u>	<u>5</u>	<u>5</u>
16. Sulfur Dioxide (ppm) uncor/cor*	<u>90</u>	<u>80</u>	<u>75</u>	<u>75</u>	<u>50</u>	<u>58</u>	<u>60</u>	<u>69</u>	<u>65</u>	<u>72</u>
17. Smoke Spot (Bacharach)	<u>0</u>		<u>0</u>		<u>0.5</u>		<u>0</u>		<u>0</u>	
18. Atmos. Temp. (°F/°C)	<u>19</u>		<u>0</u>		<u>0</u>		<u>0</u>		<u>0</u>	
19. Dew Point Temp. (°F/°C)										
20. Atmos. Pressure (in. Hg)	<u>30.15</u>		<u>30.25</u>		<u>30.26</u>		<u>30.26</u>		<u>30.26</u>	
21. Relative Humidity (%)	<u>45</u>		<u>75</u>		<u>75</u>		<u>75</u>		<u>75</u>	
22. % S IN FUEL	<u>.138</u>		<u>.129</u>		<u>.101</u>		<u>.119</u>		<u>.124</u>	
23.										
24.										
25.										
26.										
27.										
28.										
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date JUN 12, 1977 Location _____ Engr. BRIENZAUnit No. _____ Fuel #2 Capacity 17000Unit Type DOY 2 Burner Type WB 114.5 FABER

	19 26	19 27	19 28	19 29	19 30
1. Test No.	101	102	34-1a	103	104
2. Date	1/12/77	1/12/77	1/12/77	1/12/77	1/12/77
3. Time	0940	0950	1230	1245	1300
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	6.3	6.1	3.00	3.00	3.03
9. NOx (hot) read/3% O ₂ (ppm)*	71 87		75 75	73 73	72 72
10. NO (hot) read/3% O ₂ (ppm)*	71 87		75 75	73 73	72 72
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0		0	0	0
12. NO (cold) read/3% O ₂ (ppm)*	88 107	82 99	88 88	88 88	87 87
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*			10 10	10 10	10 10
15. Hydrocarbon (ppm) uncor/cor*	5 6	5	1 1	3 3	3 3
16. Sulfur Dioxide (ppm) uncor/cor*	60 73	60	70 70	70 70	70 70
17. Smoke Spot (Bacharach)	—		4	4	4
18. Atmos. Temp. (°F/°C)	0	0	10	10	10
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.27	30.27	30.24	30.24	30.24
21. Relative Humidity (%)	75	75	55	55	55
22. % S IN FUEL			.121	.121	.121
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 1/12/77 Location 19 Engr. BRIENZAUnit No. _____ Fuel #2 Capacity 17500Unit Type 059-2 Burner Type WB 114.5 FABER

	19-31	19-32	19-33	19-34	19-35
1. Test No.	26	27	28	29	30
2. Date	1/12/77	1/12/77	1/12/77	1/12/77	1/12/77
3. Time	1315	1340	1350	1405	1425
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.00	3.04	3.00	3.10	3.12
9. NO _x (hot) read/3% O ₂ (ppm)*	74	74	62	63	63
10. NO (hot) read/3% O ₂ (ppm)*	74	74	62	63	63
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0	0	0
12. NO (cold) read/3% O ₂ (ppm)*	87	87	72	74	75
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	15	15	80	53	40
15. Hydrocarbon (ppm) uncor/cor*	3	3	3	5	5
16. Sulfur Dioxide (ppm) uncor/cor*	60	60	60	60	60
17. Smoke Spot (Bacharach)	5	6.5	5.5	5.0	4
18. Atmos. Temp. (°F/°C)	12	13	13	13	13
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.24	30.24	30.24	30.24	30.24
21. Relative Humidity (%)	45	45	45	45	45
22.					
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. BRIENZAUnit No. _____ Fuel #2 Capacity 17500Unit Type DS9-2 Burner Type WB 114.5 FABER

	<u>19-36</u>				<u>19-37</u>				<u>19-38</u>				<u>19-39</u>			
1. Test No.	<u>20-21</u>				<u>20-22</u>				<u>20-23</u>				<u>20-24</u>			
2. Date	<u>1/12/77</u>				<u>1/12/77</u>				<u>1/13/77</u>				<u>1/13/77</u>			
3. Time	<u>1445</u>				<u>1500</u>				<u>850</u>				<u>1115</u>			
4. Load	<u>14500</u>				<u>14500</u>				<u>14500</u>							
5. Process Rate																
6. Flue Diam. or Size, ft	<u>2.5</u>				<u>2.5</u>				<u>2.5</u>				<u>2.5</u>			
7. Probe Position	<u>CENTER</u>				<u>CENTER</u>				<u>CENTER</u>				<u>CENTER</u>			
8. Oxygen (%)	<u>1.8</u>				<u>1.8</u>				<u>3.00</u>				<u>3.25</u>			
9. NOx (hot) read/3% O ₂ (ppm)*	<u>83</u>	<u>78</u>	<u>83</u>	<u>78</u>					<u>100</u>							
10. NO (hot) read/3% O ₂ (ppm)*	<u>83</u>	<u>78</u>	<u>83</u>	<u>78</u>					<u>100</u>							
11. NO ₂ (hot) read/3% O ₂ (ppm)*	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>					<u>0</u>							
12. NO (cold) read/3% O ₂ (ppm)*	<u>98</u>	<u>91</u>	<u>97</u>	<u>91</u>					<u>117</u>							
13. Carbon Dioxide (%)																
14. Carbon Monoxide (ppm) uncor/cor*	<u>44</u>	<u>41</u>	<u>52</u>	<u>48</u>												
15. Hydrocarbon (ppm) uncor/cor*	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>					<u>5</u>				<u>5</u>			
16. Sulfur Dioxide (ppm) uncor/cor*	<u>60</u>	<u>56</u>	<u>60</u>	<u>56</u>					<u>60</u>				<u>240</u>			
17. Smoke Spot (Bacharach)	<u>4.5</u>				<u>4.5</u>				<u>0</u>				<u>2</u>			
18. Atmos. Temp. (°F/°C)	<u>13</u>				<u>14</u>				<u>-4</u>				<u>5°F</u>			
19. Dew Point Temp. (°F/°C)																
20. Atmos. Pressure (in. Hg)	<u>30.24</u>				<u>30.24</u>				<u>30.60</u>				<u>30.57</u>			
21. Relative Humidity (%)	<u>45</u>				<u>45</u>											
22.																
23.																
24.																
25.																
26.																
27.																
28.																
29.																
30.																

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis. ¹⁵⁶

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. BRIENZAUnit No. _____ Fuel #6 Capacity 17500Unit Type DS9-2 Burner Type WB 114.5 FABER19-40 19-41 19-42 19-43 19-44

1. Test No.	<u>12-1</u>		<u>12-2</u>		<u>12-3</u>		<u>12-4</u>		<u>12-5</u>	
2. Date	<u>1/13/77</u>		<u>1/13/77</u>		<u>1/13/77</u>		<u>1/13/77</u>		<u>1/14/77</u>	
3. Time	<u>1450</u>		<u>1530</u>		<u>1555</u>		<u>1620</u>		<u>0820</u>	
4. Load	<u>14500</u>		<u>14500</u>		<u>14500</u>		<u>14500</u>		<u>14500</u>	
5. Process Rate										
6. Flue Diam. or Size, ft	<u>2.5</u>		<u>2.5</u>		<u>2.5</u>		<u>2.5</u>		<u>2.5</u>	
7. Probe Position	<u>CENTER</u>		<u>CENTER</u>		<u>CENTER</u>		<u>CENTER</u>		<u>CENTER</u>	
8. Oxygen (%)	<u>3.71</u>		<u>5.21</u>		<u>1.33</u>		<u>.70</u>		<u>3.21</u>	
9. NOx (hot) read/3% O ₂ (ppm)*	<u>207</u>	<u>215</u>	<u>207</u>	<u>236</u>	<u>173</u>	<u>158</u>	<u>160</u>	<u>142</u>	<u>197</u>	<u>199</u>
10. NO (hot) read/3% O ₂ (ppm)*	<u>207</u>	<u>215</u>	<u>207</u>	<u>236</u>	<u>173</u>	<u>158</u>	<u>160</u>	<u>142</u>	<u>197</u>	<u>199</u>
11. NO ₂ (hot) read/3% O ₂ (ppm)*	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>
12. NO (cold) read/3% O ₂ (ppm)*	<u>230</u>	<u>239</u>	<u>224</u>	<u>255</u>	<u>200</u>	<u>183</u>	<u>187</u>	<u>166</u>	<u>217</u>	<u>219</u>
13. Carbon Dioxide (%)										
14. Carbon Monoxide (ppm) uncor/cor*	<u>17</u>	<u>17</u>	<u>19</u>	<u>21</u>	<u>40</u>	<u>36</u>	<u>330</u>	<u>292</u>	<u>8</u>	<u>9</u>
15. Hydrocarbon (ppm) uncor/cor*	<u>4</u>	<u>14</u>	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>	<u>5</u>	<u>2</u>	<u>2</u>
16. Sulfur Dioxide (ppm) uncor/cor*	<u>300</u>	<u>312</u>	<u>270</u>	<u>308</u>	<u>350</u>	<u>320</u>	<u>380</u>	<u>336</u>	<u>330</u>	<u>334</u>
17. Smoke Spot (Bacharach)	<u>1.5</u>		<u>1.5</u>		<u>5</u>		<u>7</u>		<u>2.0</u>	
18. Atmos. Temp. (°F/°C)	<u>7</u>		<u>7</u>		<u>7</u>		<u>7</u>		<u>20</u>	
19. Dew Point Temp. (°F/°C)										
20. Atmos. Pressure (in. Hg)	<u>30.49</u>		<u>30.49</u>		<u>30.49</u>		<u>30.49</u>		<u>30.05</u>	
21. Relative Humidity (%)	<u>53</u>		<u>53</u>		<u>53</u>		<u>53</u>		<u>62</u>	
22. % S IN FUEL	<u>.538</u>		<u>.530</u>		<u>.552</u>		<u>.580</u>		<u>.575</u>	
23.										
24.										
25.										
26.										
27.										
28.										
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. BRIENZAUnit No. _____ Fuel #6 Capacity 17500Unit Type DS9-2 Burner Type WB 114.5 FABER

	19-45	19-46	19-47	19-48	19-49
1. Test No.	141-12	141-13	141-14	141-15	141-16
2. Date	1/14/77	1/14/77	1/14/77	1/14/77	1/14/77
3. Time	0920	0945	1030	1050	1110
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.10	3.08	3.15	3.20	0.82
9. NO _x (hot) read/3% O ₂ (ppm)*	180	181	180	181	177
10. NO (hot) read/3% O ₂ (ppm)*	180	181	180	181	177
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0	0	0
12. NO (cold) read/3% O ₂ (ppm)*	205	206	205	206	200
13. Carbon Dioxide (%)	—	—	—	—	—
14. Carbon Monoxide (ppm) uncor/cor*	16	16	12	12	12
15. Hydrocarbon (ppm) uncor/cor*	2	2	5	5	5
16. Sulfur Dioxide (ppm) uncor/cor*	320	321	320	321	320
17. Smoke Spot (Bacharach)	2.0	2.0	2.0	2.5	5.5
18. Atmos. Temp. (°F/°C)	20	20	20	20	20
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.04	30.04	30.04	30.03	30.03
21. Relative Humidity (%)	62	62	62	62	62
22. % S IN FUEL	.554	.554	.555	.557	.553
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. BRIENZAUnit No. _____ Fuel #6 Capacity 17500Unit Type DS 9-2 Burner Type WB 114.5 FABER19-50 19-51 19-52 19-53 19-54

1. Test No.	<u>149</u>	<u>149-2</u>	<u>9-3</u>	<u>149</u>	<u>52-1a</u>
2. Date	<u>1/14/77</u>	<u>1/14/77</u>	<u>1/17/77</u>	<u>1/17/77</u>	<u>1/17/77</u>
3. Time	<u>1140</u>	<u>1150</u>	<u>1125</u>	<u>1410</u>	<u>1515</u>
4. Load	<u>14500</u>	<u>14500</u>	<u>14500</u>	<u>14500</u>	<u>14500</u>
5. Process Rate					
6. Flue Diam. or Size, ft	<u>2.5</u>	<u>2.5</u>	<u>2.5</u>	<u>2.5</u>	<u>2.5</u>
7. Probe Position	<u>CENTER</u>	<u>CENTER</u>	<u>CENTER</u>	<u>CENTER</u>	<u>CENTER</u>
8. Oxygen (%)	<u>.98</u>	<u>.89</u>	<u>4.8</u>	<u>3.2</u>	<u>2.79</u>
9. NOx (hot) read/3% O ₂ (ppm)*	<u>126</u> <u>113</u>	<u>144</u> <u>129</u>	<u>100</u> <u>111</u>	<u>90</u> <u>91</u>	<u>37</u> <u>37</u>
10. NO (hot) read/3% O ₂ (ppm)*	<u>126</u> <u>113</u>	<u>144</u> <u>129</u>	<u>100</u> <u>111</u>	<u>90</u> <u>91</u>	<u>37</u> <u>37</u>
11. NO ₂ (hot) read/3% O ₂ (ppm)*	<u>0</u> <u>0</u>	<u>0</u> <u>0</u>	<u>0</u>	<u>0</u> <u>0</u>	<u>0</u>
12. NO (cold) read/3% O ₂ (ppm)*	<u>178</u> <u>160</u>	<u>169</u> <u>151</u>	<u>103</u> <u>114</u>	<u>107</u> <u>108</u>	<u>42</u> <u>42</u>
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	<u>50</u> <u>45</u>	<u>180</u> <u>161</u>		<u>10</u> <u>10</u>	<u>15</u> <u>15</u>
15. Hydrocarbon (ppm) uncor/cor*	<u>5</u> <u>5</u>	<u>5</u> <u>5</u>	<u>3</u> <u>3</u>	<u>0</u>	<u>5</u> <u>5</u>
16. Sulfur Dioxide (ppm) uncor/cor*	<u>350</u> <u>314</u>	<u>360</u> <u>322</u>	<u>55</u> <u>61</u>	<u>60</u> <u>61</u>	<u>70</u> <u>70</u>
17. Smoke Spot (Bacharach)	<u>4.5</u>	<u>5</u>	<u>0</u>	<u>0</u>	<u>0</u>
18. Atmos. Temp. (°F/°C)	<u>20</u>	<u>20</u>	<u>-4</u>	<u>1</u>	<u>1</u>
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	<u>30.03</u>	<u>30.03</u>	<u>29.84</u>	<u>29.80</u>	<u>29.80</u>
21. Relative Humidity (%)	<u>65</u>	<u>65</u>	<u>54</u>	<u>54</u>	<u>54</u>
22. % S IN FUEL	<u>.542</u>	<u>.555</u>	<u>.105</u>	<u>.105</u>	<u>.120</u>
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. BRIENZAUnit No. _____ Fuel #2 Capacity 17500Unit Type DS9-2 Burner Type WB 114.5 FABER19-55 19-56 19-57 19-58 19-59

1. Test No.	511a.	561a.	511a.	511a.	511a.
2. Date	1/17/77	1/17/77	1/17/77	1/17/77	1/17/77
3. Time	1525	1535	1555	1610	1620
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	2.72	2.72	3.39	3.22	3.26
9. NOx (hot) read/3% O ₂ (ppm)*	35 34	35 34	27 28	27 27	27 27
10. NO (hot) read/3% O ₂ (ppm)*	35 34	35 34	27 28	27 27	27 27
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0 0	0 0	0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	42 41	40 39	32 33	34 34	34 34
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	25 25	20 20	10 10	10 10	12 12
15. Hydrocarbon (ppm) uncor/cor*	5 5	5 5	5 5	5 5	5 5
16. Sulfur Dioxide (ppm) uncor/cor*	70 69	70 69	60 61	55 55	55 55
17. Smoke Spot (Bacharach)	0	0	0	0	0
18. Atmos. Temp. (°F/°C)	1	1	1	1	1
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.80	30.80	30.80	30.80	30.80
21. Relative Humidity (%)					
22.					
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. BRIENZAUnit No. _____ Fuel # 2 Capacity 17500Unit Type DS9-2 Burner Type WB114.5 FABER

	19-60	19-61	19-62	19-63	19-64
1. Test No.	5J1a	5A2E	5C26	5I2E	5C26
2. Date	1/17/77	1/18/77			
3. Time	1645	1025	1040	1105	1115
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	2.97	1.65	1.65	2.40	2.40
9. NOx (hot) read/3% O ₂ (ppm)*	37 37	35 32	32 30	27 25	27 25
10. NO (hot) read/3% O ₂ (ppm)*	37 37	35 32	32 30	27 25	27 25
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0 0	0 0	0	0
12. NO (cold) read/3% O ₂ (ppm)*	43 43	42 39	37 34	32 31	32 31
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	20 20	340 316	500 465	100 98	100 98
15. Hydrocarbon (ppm) uncor/cor*	3 3	30 28	40 37	5 5	5 5
16. Sulfur Dioxide (ppm) uncor/cor*	60 65	80 74	80 74	70 67	70 67
17. Smoke Spot (Bacharach)	0	4	5	0.2	0.2
18. Atmos. Temp. (°F/°C)	1	0	0	0	0
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.08	29.85	29.85	29.85	29.85
21. Relative Humidity (%)	51	48	48	48	
22. % S IN FUEL	.112	.127	.127	.115	.115
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. BRIENZAUnit No. _____ Fuel #2 Capacity 17500Unit Type D59-2 Burner Type WB 114.5

	19-65	19-66	19-67	19-68				
1. Test No.	5020	5120	5620	5720				
2. Date	1/18/77			1/18/77				
3. Time	1125	1115	1215	1225				
4. Load	14500	14500	14500	14500				
5. Process Rate								
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5				
7. Probe Position	CENTER	CENTER	CENTER	CENTER				
8. Oxygen (%)	2.45	2.45	2.2	2.18				
9. NOx (hot) read/3% O ₂ (ppm)*	26	25	23	22	33	32	33	32
10. NO (hot) read/3% O ₂ (ppm)*	26	25	23	22	33	32	33	32
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0	0	0		0	
12. NO (cold) read/3% O ₂ (ppm)*	30	29	26	25	37	36	38	37
13. Carbon Dioxide (%)								
14. Carbon Monoxide (ppm) uncor/cor*	160	155	600	582	500	478	230	220
15. Hydrocarbon (ppm) uncor/cor*	10	10	100	97	30	29	20	11
16. Sulfur Dioxide (ppm) uncor/cor*	65	63	65	63	60	58	50	48
17. Smoke Spot (Bacharach)	0	0		5.5		4.2		
18. Atmos. Temp. (°F/°C)	0	0		0		0		
19. Dew Point Temp. (°F/°C)								
20. Atmos. Pressure (in. Hg)	29.85	29.85	29.85	29.85				
21. Relative Humidity (%)	48	48	48	48				
22. % S IN FUEL	.108	.108	.100	.083				
23.								
24.								
25.								
26.								
27.								
28.								
29.								
30.								

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 1/18/77 Location 19 Engr. BRIENZAUnit No. _____ Fuel #6 Capacity 17500Unit Type D59-2 Burner Type WB 114.5 FABER

	19-69	19-70	19-71	19-72
1. Test No.	<u>11-3</u>	<u>13A16</u>	<u>12816</u>	<u>13C16</u>
2. Date	<u>1/18/77</u>	<u>1/18/77</u>	<u>1/18/77</u>	<u>1/18/77</u>
3. Time	<u>1415</u>	<u>1545</u>	<u>1600</u>	<u>1640</u>
4. Load	<u>14500</u>	<u>14500</u>	<u>14500</u>	<u>14500</u>
5. Process Rate				
6. Flue Diam. or Size, ft	<u>2.5</u>	<u>2.5</u>	<u>2.5</u>	<u>2.5</u>
7. Probe Position	<u>CENTER</u>	<u>CENTER</u>	<u>CENTER</u>	<u>CENTER</u>
8. Oxygen (%)	<u>3.1</u>	<u>3.22</u>	<u>3.30</u>	<u>3.28</u>
9. NOx (hot) read/3% O ₂ (ppm)*	<u>187</u> <u>188</u>	<u>150</u> <u>152</u>	<u>133</u> <u>137</u>	<u>143</u> <u>145</u>
10. NO (hot) read/3% O ₂ (ppm)*	<u>187</u> <u>188</u>	<u>150</u> <u>152</u>	<u>133</u> <u>137</u>	<u>143</u> <u>145</u>
11. NO ₂ (hot) read/3% O ₂ (ppm)*	<u>0</u>	<u>0</u>	<u>0</u> <u>0</u>	<u>0</u>
12. NO (cold) read/3% O ₂ (ppm)*	<u>210</u> <u>211</u>	<u>166</u> <u>168</u>	<u>147</u> <u>149</u>	<u>160</u> <u>161</u>
13. Carbon Dioxide (%)				
14. Carbon Monoxide (ppm) uncor/cor*	<u>4</u> <u>4</u>	<u>10</u> <u>10</u>	<u>10</u> <u>10</u>	<u>20</u> <u>20</u>
15. Hydrocarbon (ppm) uncor/cor*	<u>5</u> <u>5</u>	<u>3</u> <u>3</u>	<u>5</u> <u>5</u>	<u>5</u> <u>5</u>
16. Sulfur Dioxide (ppm) uncor/cor*	<u>340</u> <u>341</u>	<u>330</u> <u>334</u>	<u>330</u> <u>335</u>	<u>330</u> <u>335</u>
17. Smoke Spot (Bacharach)	<u>3.5</u>	<u>4.8</u>	<u>5.2</u>	<u>6.5</u>
18. Atmos. Temp. (°F/°C)	<u>7</u>	<u>7</u>	<u>7</u>	<u>7</u>
19. Dew Point Temp. (°F/°C)				
20. Atmos. Pressure (in. Hg)	<u>29.77</u>	<u>29.76</u>	<u>29.76</u>	<u>29.76</u>
21. Relative Humidity (%)	<u>45</u>	<u>45</u>	<u>45</u>	<u>45</u>
22. % S IN FUEL	<u>.587</u>	<u>.576</u>	<u>.578</u>	<u>.578</u>
23.				
24.				
25.				
26.				
27.				
28.				
29.				
30.				

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 1/19/77 Location 19 Engr. BRIENZAUnit No. _____ Fuel #2 Capacity 17,500Unit Type DS9-2 Burner Type WB 114.5 FABER

	19-73	19-74	19-75	19-76	19-77
1. Test No.	1-15	2-21	2-21	2-21	1-16
2. Date	1/19/77	1/19/77	1/19/77	1/19/77	1/20/77
3. Time	915	1110	1205	1440	750
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.10	1.15	1.05	1.08	3.00
9. NO _x (hot) read/3% O ₂ (ppm)*	98 98	92 83	92 83	92 83	105 105
10. NO (hot) read/3% O ₂ (ppm)*	98 98	92 83	92 83	92 83	105 105
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0			
12. NO (cold) read/3% O ₂ (ppm)*	112 112	107 97	106 96	107 97	117 117
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	6 6	200 181	300 270	200 181	8 8
15. Hydrocarbon (ppm) uncor/cor*	3 3	3 3	3 3	3 3	- -
16. Sulfur Dioxide (ppm) uncor/cor*	70 70	85 77	85 77	90 81	85 85
17. Smoke Spot (Bacharach)	0	5	4.5	4.5	0
18. Atmos. Temp. (°F/°C)	7	10	14	20	25
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	29.73	29.73	29.72	29.70	29.80
21. Relative Humidity (%)	63	58	51	50	
22. % S IN FUEL	.120	.133	.132		
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 1/20/77 Location 19 Engr. BRIENZAUnit No. _____ Fuel #2 Capacity 17500Unit Type DS9-2 Burner Type WB 114.5 FABER

	19-78	19-79	19-80	19-81	19-82
1. Test No.	2425	5528	3428	3025	3528
2. Date	1/20/77	1/20/77	1/20/77	1/20/77	1/20/77
3. Time	820	840	915	955	1005
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	1.85	1.79	1.77	1.92	1.90
9. NOx (hot) read/3% O ₂ (ppm)*	87 82	83 78	71 66	77 73	76 71
10. NO (hot) read/3% O ₂ (ppm)*	87 82	83 78	71 66	77 73	76 71
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0 0	0 0	0 0	
12. NO (cold) read/3% O ₂ (ppm)*	102 96	95 89	82 77	87 82	86 81
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	44 41	50 47	500 468	140 132	45 42
15. Hydrocarbon (ppm) uncor/cor*	3 3	5 5	20 19	8 8	15 15
16. Sulfur Dioxide (ppm) uncor/cor*	-	-	-	100 94	100 94
17. Smoke Spot (Bacharach)	5.8	5.5	8.0	6.8	7.0
18. Atmos. Temp. (°F/°C)	25	25	25	27	27
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	29.80	29.80	29.80	29.85	29.85
21. Relative Humidity (%)	65	65	65	65	65
22. % S IN FUEL				.162	.162
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 1/20/77 Location 19 Engr. BRIENZUnit No. _____ Fuel #2 Capacity 17500Unit Type 059-2 Burner Type WB 114.5 FABER

	19-82	19-83	19-84	19-85	
1. Test No.	<u>3816</u>	<u>4027</u>	<u>4029</u>	<u>421</u>	
2. Date	<u>1/20/77</u>	<u>1/20/77</u>	<u>1/20/77</u>	<u>1/20/77</u>	
3. Time		<u>1400</u>	<u>1500</u>	<u>1630</u>	
4. Load	<u>14500</u>	<u>14500</u>	<u>14500</u>	<u>14500</u>	
5. Process Rate					
6. Flue Diam. or Size, ft	<u>2.5</u>	<u>2.5</u>	<u>2.5</u>	<u>2.5</u>	
7. Probe Position	<u>CENTER</u>	<u>CENTER</u>	<u>CENTER</u>	<u>CENTER</u>	
8. Oxygen (%)		<u>.85</u>	<u>.70</u>	<u>0.68</u>	
9. NO _x (hot) read/3% O ₂ (ppm)*		<u>29</u> <u>26</u>	<u>30</u> <u>26</u>	<u>31</u> <u>27</u>	
10. NO (hot) read/3% O ₂ (ppm)*		<u>29</u> <u>26</u>	<u>30</u> <u>26</u>	<u>31</u> <u>27</u>	
11. NO ₂ (hot) read/3% O ₂ (ppm)*		<u>0</u> <u>0</u>	<u>0</u> <u>0</u>	<u>0</u>	
12. NO (cold) read/3% O ₂ (ppm)*		<u>35</u> <u>31</u>	<u>36</u> <u>32</u>	<u>37</u> <u>33</u>	
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*		<u>24</u> <u>21</u>	<u>25</u> <u>22</u>	<u>80</u> <u>71</u>	
15. Hydrocarbon (ppm) uncor/cor*		<u>5</u> <u>5</u>	<u>5</u> <u>5</u>	<u>4</u> <u>4</u>	
16. Sulfur Dioxide (ppm) uncor/cor*		<u>85</u> <u>76</u>	<u>90</u> <u>80</u>	<u>78</u> <u>69</u>	
17. Smoke Spot (Bacharach)		<u>0</u>	<u>0</u>	<u>—</u>	
18. Atmos. Temp. (°F/°C)		<u>27</u>	<u>27</u>		
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)		<u>29.86</u>	<u>29.86</u>	<u>29.91</u>	
21. Relative Humidity (%)		<u>65</u>	<u>65</u>	<u>65</u>	
22. <u>% S</u>		<u>0.131</u>	<u>0.137</u>	<u>0.12</u>	
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 1-21-77 Location 19 Engr. 115HUnit No. _____ Fuel #2 Capacity 17.5 KUnit Type D59-2 Burner Type _____

	19-86	19-87	19-88	19-89	19-90
1. Test No.					
2. Date	1-21-77	1-21-77	1-21-77	1-21-77	1-21-77
3. Time	1027	1135	1345	1400	1420
4. Load	14.5K	14.5K	14.5K	14.5K	14.5K
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	2.9	2.8	2.5	2.55	2.55
9. NO _x (hot) read/3% O ₂ (ppm)*	74 74	62 61	67 65	58 57	57 56
10. NO (hot) read/3% O ₂ (ppm)*	72 72	61 60	66 64	58 57	56 55
11. NO ₂ (hot) read/3% O ₂ (ppm)*	2 2	1 1	1 1	0 0	1 1
12. NO (cold) read/3% O ₂ (ppm)*	82 82	70 69	77 75	68 66	66 64
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	32 32	105 104	8 8	64 62	48 47
15. Hydrocarbon (ppm) uncor/cor*	3 3	4 3	0 0	0 0	0 0
16. Sulfur Dioxide (ppm) uncor/cor*	40 40	60 59	80 78	80 78	80 79
17. Smoke Spot (Bacharach)	4.5	6.5	3	6.5	5.5
18. Atmos. Temp. (°F/°C)			23	23	23
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.03	30.03	29.95	29.95	29.95
21. Relative Humidity (%)			60%	60%	60%
22.					
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 1-21-77 Location 19 Engr. M.B.H.Unit No. _____ Fuel #2 oil Capacity 17.5 KUnit Type DS9-2 Burner Type _____

	19-91	19-92	19-93	19-94	19-95
1. Test No.	302C	302C	302C	302C	302C
2. Date	1-21-77	1-21-77	1-21-77	1-21-77	1-21-77
3. Time	1435	1500	1512	1538	1549
4. Load	14.5	14.5	14.5	14.5	14.5
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	2.45	1.6	1.6	1.5	1.55
9. NO _x (hot) read/3% O ₂ (ppm)*	64 62	69 63	64 58	62 57	71 65
10. NO (hot) read/3% O ₂ (ppm)*	62 60	68 63	62 57	61 56	69 63
11. NO ₂ (hot) read/3% O ₂ (ppm)*	2 2	1 0	2 1	1 1	2 2
12. NO (cold) read/3% O ₂ (ppm)*	69 67	78 72	72 66	71 65	73 67
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	104 101	124 114	380 349	400 368	420 386
15. Hydrocarbon (ppm) uncor/cor*	0 0	2 2	4 4	4 4	0 0
16. Sulfur Dioxide (ppm) uncor/cor*	80 78	85 78	80 74	80 74	80 74
17. Smoke Spot (Bacharach)	6.5	5.0	6.5	6.0	7.0
18. Atmos. Temp. (°F/°C)	23	25	25	25	25
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	29.95	29.89	29.89	29.89	29.89
21. Relative Humidity (%)	60%	55%	55%	55%	55%
22.					
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. _____Unit No. _____ Fuel _____ Capacity 17500Unit Type DS9-2 Burner Type WB 114.5 FABER19-96 19-97 19-98 19-99 19-100

1. Test No.	1	2	3	4	5
2. Date	1/24/77	1/24/77	1/24/77	1/24/77	1/27/77
3. Time	825	1020	1130	1450	835
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.10	3.00	3.3	3.10	3.15
9. NOx (hot) read/3% O ₂ (ppm)*	103	195	196	199	197
10. NO (hot) read/3% O ₂ (ppm)*	103	195	196	199	197
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0	0	0
12. NO (cold) read/3% O ₂ (ppm)*	117	118	214	214	212
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	8	4	2	2	4
15. Hydrocarbon (ppm) uncor/cor*	5	10	0	0	5
16. Sulfur Dioxide (ppm) uncor/cor*	60	300	300	280	285
17. Smoke Spot (Bacharach)		0.5	0.5	0	0
18. Atmos. Temp. (°F/°C)	13	20	26	2	26
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.18	30.16	30.14	30.00	29.80
21. Relative Humidity (%)	77	77	77		
22. % S IN FUEL		0.52	.49	.551	.122
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. BRENNERUnit No. _____ Fuel #2 Capacity 17500Unit Type D59-2 Burner Type WB 114.5 FABER

	19-101	19-102	19-103	19-104	19-105
1. Test No.	5416	5616	5416	5816	5016
2. Date	1/25/77	1/25/77	1/25/77	1/25/77	1/25/77
3. Time	1000	1010	1035	1100	1125
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.04	2.95	2.90	2.90	3.00
9. NO _x (hot) read/3% O ₂ (ppm)*	53 53	53 53	34 34	34 34	25 25
10. NO (hot) read/3% O ₂ (ppm)*	53 53	53 53	34 34	34 34	25 25
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0 0	0 0	0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	61 61	61 61	40 40	40 40	27 27
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	6 6	20 20	10 10	10 10	15 15
15. Hydrocarbon (ppm) uncor/cor*	5 5	3 3	3 3	3 3	3 3
16. Sulfur Dioxide (ppm) uncor/cor*	85 85	80 80	80 80	80 80	80 80
17. Smoke Spot (Bacharach)	1.5	4	.5	.5	2
18. Atmos. Temp. (°F/°C)	30	30	30	31	35
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	29.77	29.77	29.75	29.75	29.75
21. Relative Humidity (%)	90	90	90	90	90
22. % S IN FUEL	.146	.138	.138	.138	.138
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. 1003 070Unit No. _____ Fuel _____ Capacity 17500Unit Type DS9-2 Burner Type WB 114.5 FABER

	19-106	19-107	19-108	19-109	19-110
1. Test No.	5522	1.42	12442	13272	12012
2. Date	1/25/77	1/25/77	1/25/77	1/25/77	1/25/77
3. Time	1135	1330	1340	1350	1400
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.00	3.20	3.19	3.07	3.11
9. NOx (hot) read/3% O ₂ (ppm)*	26 26	157 159	157 159	151 151	150 151
10. NO (hot) read/3% O ₂ (ppm)*	26 26	157 159	157 159	151 151	150 151
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0	0	0 0	0
12. NO (cold) read/3% O ₂ (ppm)*	29 29	175 177	174 176	173 173	170 171
13. Carbon Dioxide (%)	—				
14. Carbon Monoxide (ppm) uncor/cor*	16 16	6 6	8 8	15 15	32 32
15. Hydrocarbon (ppm) uncor/cor*	3 3	0 0	2 2	2 2	5 5
16. Sulfur Dioxide (ppm) uncor/cor*	80 80	280 283	280 283	280 280	285 187
17. Smoke Spot (Bacharach)	0.2	3.0	4.5	4.5	5.1
18. Atmos. Temp. (°F/°C)	36	36	36	36	36
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	29.75	29.68	29.68	29.68	29.68
21. Relative Humidity (%)	90	72	72	72	72
22. % S IN FUEL	.138	.488	.488	.483	.494
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 1/25/77 Location 19 Engr. BOEVEAUnit No. _____ Fuel #6 Capacity 17500Unit Type D59-2 Burner Type WB 114.5 FABER

	19-111	19-112	19-113	19-114	19-115
1. Test No.	1	1307	1308	1309	1310
2. Date	1/25/77	1/25/77	1/25/77	1/25/77	1/26/77
3. Time	1420	1435	1500	1510	0900
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.05	3.10	1.75	1.90	3.10
9. NOx (hot) read/3% O ₂ (ppm)*	132 132	130 131	127 119	116 109	108 108
10. NO (hot) read/3% O ₂ (ppm)*	132 132	130 131	127 119	116 109	108 108
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0 0	0 0	0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	150 150	148 149	148 138	133 125	125 126
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	60 60	80 80	100 93	2000 1884	6 6
15. Hydrocarbon (ppm) uncor/cor*	5 5	5 5	12 12	150 141	0 0
16. Sulfur Dioxide (ppm) uncor/cor*	285 286	285 286	320 299	320 301	60 60
17. Smoke Spot (Bacharach)	6.5	7.0	8	10	0
18. Atmos. Temp. (°F/°C)	36	36	36	36	26
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	29.66	29.66	29.66	29.66	29.74
21. Relative Humidity (%)	72	72	72	72	75
22. % S IN FUEL	.493	.493	.515	.520	.103
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 2/16/77 Location 19 Engr. 5Unit No. _____ Fuel 11 Capacity 17500Unit Type 059-2 Burner Type WB 114.5 FABER

	19-116	19-117	19-118	19-119	19-120
1. Test No.	3020	3021	3022	3023	3024
2. Date	1/26/77		2/15/77	2/16/77	2/16/77
3. Time	1040	1200	1410	1035	1110
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.1	3.18	3.2	2.9	6.3
9. NO _x (hot) read/3% O ₂ (ppm)*	82 83	83 84	117 118	100 100	87 107
10. NO (hot) read/3% O ₂ (ppm)*	82 83	83 84	117 118	100 100	87 107
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0 0	0 0	0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	96 97	97 98	132 134	115 114	92 113
13. Carbon Dioxide (%)					
14. Carbon Monoxide (ppm) uncor/cor*	35 35	24 24	9 9	8 8	6 7
15. Hydrocarbon (ppm) uncor/cor*	5 5	0 0	5 5	3 3	2 2.5
16. Sulfur Dioxide (ppm) uncor/cor*	80 81	90 91	80 81	90 90	70 86
17. Smoke Spot (Bacharach)	4	5.5	0	0	0
18. Atmos. Temp. (°F/°C)	26	30	34	19	20
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	29.74	29.70	29.97	30.12	30.11
21. Relative Humidity (%)	75		50%	47%	47%
22. % S IN FUEL FROM SO ₂			.14%	.155%	.148%
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19Engr. G. S. T. R.
TECH. R. 0102-5AUnit No. _____ Fuel #2 OIL Capacity 17500Unit Type D59-2 Burner Type WB 114.5 FABER19-121 19-122 19-123 19-124 19-125

1. Test No.	CALIB.									
2. Date	2/16/77		2/16/77		2/16/77		2/16/77		2/16/77	
3. Time	1135		1150		1205		1210		1225	
4. Load	14500		14500		14500		14500		14500	
5. Process Rate										
6. Flue Diam. or Size, ft	2.5		2.5		2.5		2.5		2.5	
7. Probe Position	CENTER		CENTER		CENTER		CENTER		CENTER	
8. Oxygen (%)	6.2		6.5		6.4		5.75		5.75	
9. NOx (hot) read/3% O ₂ (ppm)*	85	103	83	103	84	104	86	102	87	103
10. NO (hot) read/3% O ₂ (ppm)*	85	103	83	103	84	104	86	102	87	103
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0	0	0	0	0	0	0	0
12. NO (cold) read/3% O ₂ (ppm)*	92	112	92	114	93	115	96	113	98	116
13. Carbon Dioxide (%)										
14. Carbon Monoxide (ppm) uncor/cor*	6	7	8	10	8	10	8	9	8	9
15. Hydrocarbon (ppm) uncor/cor*	0	0	0	0	0	0	0	0	3	4
16. Sulfur Dioxide (ppm) uncor/cor*	70	85	60	75	55	68	55	65	75	89
17. Smoke Spot (Bacharach)	0		0		0					
18. Atmos. Temp. (°F/°C)	20		20		20		22		22	
19. Dew Point Temp. (°F/°C)										
20. Atmos. Pressure (in. Hg)	30.11		30.11		30.11		30.09		30.09	
21. Relative Humidity (%)	47		47		47		45		45	
22. %SULFUR IN FUEL FROM SO ₂	.147		.128		.117		.112		.153	
23.										
24.										
25.										
26.										
27.										
28.										
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. G. SOTTER
 Unit No. _____ Fuel #2 or #6 Capacity 17500 TECH. R. PICINFSSA
 Unit Type PS-2 Burner Type WB 114.5 FABER

19-126 19-127 19-128 19-129 19-130

1. Test No.	CALIB.		CALIB.							
2. Date	2/16/77		2/16/77		2/16/77		2/16/77		2/16/77	
3. Time	1240		1250		1550		1630		1650	
4. Load	14500		14500		14500		14500		14500	
5. Process Rate										
6. Flue Diam. or Size, ft	2.5		2.5		2.5		2.5		2.5	
7. Probe Position	CENTER		CENTER		CENTER		CENTER		CENTER	
8. Oxygen (%)	5.28		6.25		3.25		3.1		2.9	
9. NOx (hot) read/3% O ₂ (ppm)*	88	101	89	102	200	203	136	137	93	93
10. NO (hot) read/3% O ₂ (ppm)*	88	101	89	102	200	203	136	137	93	93
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0	0	0	0	0	0	0	0
12. NO (cold) read/3% O ₂ (ppm)*	99	113	99	113	220	223	147	148	105	104
13. Carbon Dioxide (%)										
14. Carbon Monoxide (ppm) uncor/cor*	8	9	8	9	14	14	24	24	340	338
15. Hydrocarbon (ppm) uncor/cor*	3	3	2	2	7	7	8	8	45	45
16. Sulfur Dioxide (ppm) uncor/cor*	70	80	80	91	330	335	360	322	330	328
17. Smoke Spot (Bacharach)					1		2		2	
18. Atmos. Temp. (°F/°C)	22		22		25		24		24	
19. Dew Point Temp. (°F/°C)										
20. Atmos. Pressure (in. Hg)	30.09		30.09		30.02		30.02		30.02	
21. Relative Humidity (%)	45		45		42		40		40	
22. %SULFUR IN FUEL FROM SO ₂	.138		.158		.578		.624		.566	
23.										
24.										
25.										
26.										
27.										
28.										
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. G. D. T. R.Unit No. _____ Fuel #6 Capacity 17500 TECH. R. P. ROBERTS
P. LEVISTONUnit Type D59-2 Burner Type WB 114.5 FABER

	← 19-131 →				← 19-132 →				19-133	
1. Test No.	19-1293				19-1302				19-131	
2. Date	2/17/77				2/17/77				2/18/77	
3. Time	826				942				820	
4. Load	14500				14500				14500	
5. Process Rate										
6. Flue Diam. or Size, ft	2.5				2.5				2.5	
7. Probe Position	CENTER				CENTER				CENTER	
8. Oxygen (%)	3.20				0.98				3.60	
9. NOx (hot) read/3% O ₂ (ppm)*	193	195	202	209	143	128	150	135	199	206
10. NO (hot) read/3% O ₂ (ppm)*	193	195	202	209	141	127	150	135	199	206
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0	0	2	1	0	0	0	0
12. NO (cold) read/3% O ₂ (ppm)*	223	226	229	237	166	149	167	150	224	232
13. Carbon Dioxide (%)										
14. Carbon Monoxide (ppm) uncor/cor*	25	25	7	7	204	183	120	108	4	4
15. Hydrocarbon (ppm) uncor/cor*	5	5	5	5	18	16	10	9	12	12
16. Sulfur Dioxide (ppm) uncor/cor*	290	293	292	302	370	333	368	330	284	294
17. Smoke Spot (Bacharach)	0				2.5				0	
18. Atmos. Temp. (°F/°C)	15				17				10	
19. Dew Point Temp. (°F/°C)										
20. Atmos. Pressure (in. Hg)	30.11				30.12				30.17	
21. Relative Humidity (%)	58				51				70	
22. %O ₂ IN FUEL FROM SO ₂	0.51				0.57				0.51	
23.										
24.										
25.										
26.										
27.										
28.										
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. G. P. TEEUnit No. _____ Fuel #6 Capacity 17500 P. LANGSTONUnit Type DS9-2 Burner Type WB 114.5 FABER19-134 19-135 19-136 19-137 19-138

1. Test No.	<u>19-132</u>	<u>19-133</u>	<u>19-134</u>	<u>19-135</u>	<u>19-135</u>
2. Date	<u>2/18/77</u>	<u>2/18/77</u>	<u>2/18/77</u>	<u>2/18/77</u>	<u>2/18/77</u>
3. Time	<u>1020</u>	<u>1044</u>	<u>121</u>	<u>145</u>	<u>200</u>
4. Load	<u>14500</u>	<u>14500</u>	<u>14500</u>	<u>14500</u>	<u>14500</u>
5. Process Rate					
6. Flue Diam. or Size, ft	<u>2.5</u>	<u>2.5</u>	<u>2.5</u>	<u>2.5</u>	<u>2.5</u>
7. Probe Position	<u>CENTER</u>	<u>CENTER</u>	<u>CENTER</u>	<u>CENTER</u>	<u>CENTER</u>
8. Oxygen (%)	<u>1.5</u>	<u>1.54</u>	<u>1.65</u>	<u>2.3</u>	<u>2.3</u>
9. NOx (hot) read/3% O ₂ (ppm)*	<u>111</u> <u>103</u>	<u>98</u> <u>90</u>	<u>110</u> <u>102</u>	<u>120</u> <u>116</u>	<u>104</u> <u>100</u>
10. NO (hot) read/3% O ₂ (ppm)*	<u>110</u> <u>102</u>	<u>96</u> <u>89</u>	<u>109</u> <u>101</u>	<u>120</u> <u>116</u>	<u>104</u> <u>100</u>
11. NO ₂ (hot) read/3% O ₂ (ppm)*	<u>1</u> <u>1</u>	<u>2</u> <u>1</u>	<u>1</u> <u>1</u>	<u>0</u> <u>0</u>	<u>0</u> <u>0</u>
12. NO (cold) read/3% O ₂ (ppm)*	<u>127</u> <u>117</u>	<u>111</u> <u>103</u>	<u>126</u> <u>117</u>	<u>138</u> <u>133</u>	<u>120</u> <u>116</u>
13. Carbon Dioxide (%)					<u>13.6</u>
14. Carbon Monoxide (ppm) uncor/cor*	<u>88</u> <u>81</u>	<u>700</u> <u>647</u>	<u>756</u> <u>238</u>	<u>60</u> <u>58</u>	<u>86</u> <u>83</u>
15. Hydrocarbon (ppm) uncor/cor*	<u>30</u> <u>28</u>	<u>30</u> <u>28</u>	<u>125</u> <u>116</u>	<u>25</u> <u>24</u>	<u>15</u> <u>14</u>
16. Sulfur Dioxide (ppm) uncor/cor*	<u>310</u> <u>285</u>	<u>—</u> <u>—</u>	<u>364</u> <u>339</u>	<u>334</u> <u>321</u>	<u>330</u> <u>318</u>
17. Smoke Spot (Bacharach)	<u>2.5</u>	<u>4</u>	<u>2.5</u>	<u>4</u>	<u>1.5</u>
18. Atmos. Temp. (°F/°C)	<u>13</u>	<u>13</u>	<u>30</u>	<u>30</u>	<u>32</u>
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	<u>30.13</u>	<u>30.13</u>	<u>30.05</u>	<u>30.05</u>	<u>30.03</u>
21. Relative Humidity (%)	<u>75</u>	<u>75</u>	<u>40</u>	<u>40</u>	<u>40</u>
22.	<u>0.49</u>	<u>—</u>	<u>0.58</u>	<u>0.55</u>	<u>0.55</u>
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. SOTTERUnit No. _____ Fuel #6 Capacity 17,500 LANGSTONUnit Type DS9-2 Burner Type WB 114.5 FABER

	19-139	19-140	19-141	19-142	19-143
1. Test No.	19-137	19-138	19-139	19-140	19-141 P
2. Date	2/18/77	2/18/77	2/18/77	2/21/77	2/21/77
3. Time	2:17	2:50		09:15	10:00
4. Load	14,500	14,500	14,500	14,500	14,500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	2.0	2.97	2.90	3.14	3.2
9. NOx (hot) read/3% O ₂ (ppm)*	128 121	132 132	108 107	200 201	131 133
10. NO (hot) read/3% O ₂ (ppm)*	128 121	132 132	108 107	200 201	130 131
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0 0	0 0	0 0	1 2
12. NO (cold) read/3% O ₂ (ppm)*	145 137	148 147	123 122	225 227	148 149
13. Carbon Dioxide (%)	14.5	13.9	13.6	12.9	13.5
14. Carbon Monoxide (ppm) uncor/cor*	80 76	20 20	680 676	8 8	24 24
15. Hydrocarbon (ppm) uncor/cor*	30 28	15 15	75 75	5 5	5 5
16. Sulfur Dioxide (ppm) uncor/cor*				340 343	300 303
17. Smoke Spot (Bacharach)	5	1.5	3	0	2.5
18. Atmos. Temp. (°F/°C)	32	32	32	19	
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.03	30.03	30.01	29.83	
21. Relative Humidity (%)	40	40	38	65	
22. % SULFUR IN FUEL (FROM SO ₂)				.59	.52
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. 507-50
204-11241Unit No. _____ Fuel #6, 2 Capacity 17,500Unit Type 059-2 Burner Type WB 114.5 FABER19-144 19-145 19-146

1. Test No.	<u>19-144 I</u>	<u>19-145 I</u>	<u>19-146 I</u>						
2. Date	<u>2/21/77</u>	<u>2/21/77</u>	<u>2/22/77</u>						
3. Time	<u>1145</u>	<u>1440</u>	<u>838</u>						
4. Load	<u>14500</u>	<u>14500</u>	<u>14500</u>						
5. Process Rate									
6. Flue Diam. or Size, ft	<u>2.5</u>	<u>2.5</u>	<u>2.5</u>						
7. Probe Position	<u>CENTER</u>	<u>CENTER</u>	<u>CENTER</u>						
8. Oxygen (%)	<u>3.1</u>	<u>3.1</u>	<u>2.75</u>						
9. NOx (hot) read/3% O ₂ (ppm)*	<u>128</u>	<u>129</u>	<u>125</u>	<u>126</u>	<u>105</u>	<u>104</u>			
10. NO (hot) read/3% O ₂ (ppm)*	<u>128</u>	<u>129</u>	<u>-</u>	<u>-</u>	<u>105</u>	<u>104</u>			
11. NO ₂ (hot) read/3% O ₂ (ppm)*	<u>0</u>	<u>0</u>	<u>-</u>	<u>-</u>	<u>0</u>	<u>0</u>			
12. NO (cold) read/3% O ₂ (ppm)*	<u>145</u>	<u>146</u>	<u>138</u>	<u>138</u>	<u>124</u>	<u>122</u>			
13. Carbon Dioxide (%)	<u>13.6</u>	<u>13.4</u>							
14. Carbon Monoxide (ppm) uncor/cor*	<u>32</u>	<u>32</u>	<u>60</u>	<u>60</u>	<u>16</u>	<u>16</u>			
15. Hydrocarbon (ppm) uncor/cor*	<u>5</u>	<u>5</u>	<u>-</u>	<u>-</u>	<u>11</u>	<u>11</u>			
16. Sulfur Dioxide (ppm) uncor/cor*	<u>300</u>	<u>302</u>	<u>320</u>	<u>322</u>	<u>104</u>	<u>103</u>			
17. Smoke Spot (Bacharach)	<u>3</u>	<u>-</u>	<u>0</u>						
18. Atmos. Temp. (°F/°C)	<u>23</u>				<u>24</u>				
19. Dew Point Temp. (°F/°C)									
20. Atmos. Pressure (in. Hg)	<u>29.89</u>				<u>29.85</u>				
21. Relative Humidity (%)	<u>45</u>				<u>67</u>				
22. % S IN FUEL (FROM SO ₂)	<u>.52</u>	<u>.55</u>	<u>.18</u>						
23.									
24.									
25.									
26.									
27.									
28.									
29.									
30.									

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. SOTTERUnit No. _____ Fuel GAS Capacity 17500 #/hr STEAM

Unit Type _____ Burner Type _____

	19-147	19-148	19-149	19-150	19-151
1. Test No.	19-143	19-144	19-145	19-146	19-147
2. Date	2/22/77	2/22/77	2/22/77	2/22/77	2/22/77
3. Time	10:15	10:40	11:00	11:20	11:35
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.03	7.00	1.85	1.05	0.90
9. NOx (hot) read/3% O ₂ (ppm)*	75 75	50 64	81 76	85 77	85 76
10. NO (hot) read/3% O ₂ (ppm)*	75 75	50 64	81 76	83 75	84 75
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0 0	0 0	2 2	1 1
12. NO (cold) read/3% O ₂ (ppm)*	95 95	60 77	105 99	110 99	108 97
13. Carbon Dioxide (%)	10.2				
14. Carbon Monoxide (ppm) uncor/cor*	4 4	3 4	20 19	212 191	600 537
15. Hydrocarbon (ppm) uncor/cor*	4 4	10 13	5 5	4 4	4 4
16. Sulfur Dioxide (ppm) uncor/cor*	0 0	0 0	0 0	0 0	0 0
17. Smoke Spot (Bacharach)	0	0	0	0	0
18. Atmos. Temp. (°F/°C)	25	25	25	25	25
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	29.83	29.83	29.81	29.81	29.81
21. Relative Humidity (%)	57	57	63	63	63
22.					
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. 60778Unit No. _____ Fuel GAS Capacity 17500 #/hr STEAM

Unit Type _____ Burner Type _____

	19-152	19-153	19-154	19-155	19-156
1. Test No.	19-145	19-146	19-147	19-148	19-149
2. Date	2/22/77	2/22/77	2/22/77	2/22/77	2/22/77
3. Time	13:30	1:38	1:42	1:50	2:15
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.05	3.05	3.05	3.00	2.25
9. NO _x (hot) read/3% O ₂ (ppm)*	54 54			52 52	45 43
10. NO (hot) read/3% O ₂ (ppm)*	54 54			52 52	45 43
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0			0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	69 69	68 68	65 65	66 66	57 55
13. Carbon Dioxide (%)	9.7			9.9	10.2
14. Carbon Monoxide (ppm) uncor/cor*	24 24	22 22	16 16	48 48	680 653
15. Hydrocarbon (ppm) uncor/cor*	7 7			10 10	5 5
16. Sulfur Dioxide (ppm) uncor/cor*	0 0			0 0	0 0
17. Smoke Spot (Bacharach)					
18. Atmos. Temp. (°F/°C)	35	35	35	38	38
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	29.74	29.74	29.74	29.72	29.72
21. Relative Humidity (%)	47	47	47	45	45
22.					
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. _____Unit No. _____ Fuel GAS #6 Capacity 17500Unit Type _____ Burner Type WEBER

	<u>19-157</u>		<u>19-158</u>		<u>19-159</u>					
1. Test No.	<u>11</u>		<u>12</u>		<u>13</u>		<u>14</u>		<u>15</u>	
2. Date	<u>2/22/77</u>		<u>2/23/77</u>		<u>2/23/77</u>		<u>2/23/77</u>		<u>2/23/77</u>	
3. Time	<u>2:25</u>		<u>8:20</u>		<u>9:40</u>		<u>10:40</u>		<u>11:40</u>	
4. Load	<u>14500</u>		<u>14500</u>		<u>14500</u>		<u>14500</u>		<u>14500</u>	
5. Process Rate										
6. Flue Diam. or Size, ft	<u>2.5</u>		<u>2.5</u>		<u>2.5</u>		<u>2.5</u>		<u>2.5</u>	
7. Probe Position	<u>CENTER</u>		<u>CENTER</u>		<u>CENTER</u>		<u>CENTER</u>		<u>CENTER</u>	
8. Oxygen (%)	<u>2.25</u>		<u>2.95</u>		<u>1.75</u>		<u>1.70</u>		<u>1.60</u>	
9. NOx (hot) read/3% O ₂ (ppm)*	<u>51</u>	<u>49</u>	<u>195</u>	<u>194</u>	<u>138</u>	<u>129</u>	<u>138</u>	<u>129</u>	<u>—</u>	<u>—</u>
10. NO (hot) read/3% O ₂ (ppm)*	<u>51</u>	<u>49</u>	<u>195</u>	<u>194</u>	<u>138</u>	<u>129</u>	<u>138</u>	<u>129</u>	<u>—</u>	<u>—</u>
11. NO ₂ (hot) read/3% O ₂ (ppm)*	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>—</u>	<u>—</u>
12. NO (cold) read/3% O ₂ (ppm)*	<u>65</u>	<u>62</u>	<u>223</u>	<u>222</u>	<u>160</u>	<u>150</u>	<u>158</u>	<u>147</u>	<u>155</u>	<u>144</u>
13. Carbon Dioxide (%)	<u>9.5</u>		<u>13.6</u>		<u>14.5</u>		<u>14.6</u>		<u>14.8</u>	
14. Carbon Monoxide (ppm) uncor/cor*	<u>28</u>	<u>27</u>	<u>24</u>	<u>24</u>	<u>96</u>	<u>90</u>	<u>80</u>	<u>75</u>	<u>152</u>	<u>141</u>
15. Hydrocarbon (ppm) uncor/cor*	<u>0</u>	<u>0</u>	<u>9</u>	<u>9</u>	<u>5</u>	<u>5</u>	<u>0</u>	<u>0</u>	<u>—</u>	<u>—</u>
16. Sulfur Dioxide (ppm) uncor/cor*	<u>0</u>	<u>0</u>	<u>310</u>	<u>309</u>	<u>344</u>	<u>322</u>	<u>360</u>	<u>336</u>	<u>—</u>	<u>—</u>
17. Smoke Spot (Bacharach)	<u>—</u>		<u>0</u>		<u>1.5</u>		<u>1.5</u>		<u>—</u>	
18. Atmos. Temp. (°F/°C)	<u>38</u>		<u>37</u>		<u>41</u>		<u>44</u>		<u>44</u>	
19. Dew Point Temp. (°F/°C)										
20. Atmos. Pressure (in. Hg)	<u>29.72</u>		<u>30.07</u>		<u>30.08</u>		<u>30.09</u>			
21. Relative Humidity (%)	<u>45</u>		<u>82</u>		<u>76</u>		<u>73</u>			
22. % S IN FUEL (FROM SO ₂)			<u>.53</u>		<u>.55</u>		<u>.58</u>			
23.										
24.										
25.										
26.										
27.										
28.										
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. 500 7.66
2 AUG 2007Unit No. _____ Fuel #6 OIL Capacity 17500Unit Type _____ + GAS Burner Type WEBER

	19-160	19-161	19-162	19-163	19-164
1. Test No.	19-160	19-161	19-162	19-163	19-164
2. Date	2/23/77	2/23/77	2/23/77	2/23/77	2/24/77
3. Time	2:15	2:35	3:00	3:20	8:05
4. Load	14500	14500	14500	14500	14500
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.02	3.00	3.00	3.00	2.8
9. NOx (hot) read/3% O ₂ (ppm)*	138 138	125 125	126 126	143 143	68 67
10. NO (hot) read/3% O ₂ (ppm)*	138 138	125 125	126 126	143 143	68 67
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0 0	0 0	0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	158 158	143 143	143 143	163 163	91 90
13. Carbon Dioxide (%)		13.8	14.0	14.0	10.7
14. Carbon Monoxide (ppm) uncor/cor*	64 64	88 88	132 132	52 52	18 18
15. Hydrocarbon (ppm) uncor/cor*	10 10	7 7	15 15	3 3	10 10
16. Sulfur Dioxide (ppm) uncor/cor*	330 330	340 340	340 340	340 340	0 0
17. Smoke Spot (Bacharach)	1.5	2	2.5	2.0	
18. Atmos. Temp. (°F/°C)	56				40
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.03				29.93
21. Relative Humidity (%)					
22. %S CALCULATE FROM SO ₂	.57	.59	.59	.59	0
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. _____Unit No. _____ Fuel GAS Capacity 17500

Unit Type _____ Burner Type _____

19-165 19-166 19-167 19-168

1. Test No.									
2. Date	2/24/77	2/24/77	2/24/77	2/24/77					
3. Time	9:00	9:15	9:30	10:00					
4. Load	14500	14500	14500	14500					
5. Process Rate									
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5					
7. Probe Position	CENTER	CENTER	CENTER	CENTER					
8. Oxygen (%)	3.1	3.0	1.73	1.70					
9. NOx (hot) read/3% O ₂ (ppm)*	66	66	68	68	57	53	58	54	
10. NO (hot) read/3% O ₂ (ppm)*	66	66	68	68	57	53	58	54	
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0	0	0	0	0	0	
12. NO (cold) read/3% O ₂ (ppm)*	84	84	86	86	73	68	75	70	
13. Carbon Dioxide (%)	10.6	10.5	11.3	11.3					
14. Carbon Monoxide (ppm) uncor/cor*	20	20	20	20	220	206	56	52	
15. Hydrocarbon (ppm) uncor/cor*	3	3	1	1	1	1	4		
16. Sulfur Dioxide (ppm) uncor/cor*	0	0	0	0	0	0	0		
17. Smoke Spot (Bacharach)									
18. Atmos. Temp. (°F/°C)	42	→							
19. Dew Point Temp. (°F/°C)									
20. Atmos. Pressure (in. Hg)	29.90	→							
21. Relative Humidity (%)	82	→							
22.									
23.									
24.									
25.									
26.									
27.									
28.									
29.									
30.									

*Correction to 3% O₂ should
the value is measured on abe formed if
bas

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. _____Unit No. _____ Fuel #6 OIL Capacity 17500 #/hr STEAM

Unit Type _____ Burner Type _____

	<u>19-169</u> ← <u>19-170</u> →				
1. Test No.	<u>19-165</u>	<u>19-166</u>	<u>19-167</u>	<u>19-168</u>	
2. Date	<u>3/1/77</u>	<u>3/1/77</u>	<u>→</u>	<u>→</u>	
3. Time	<u>0915</u>	<u>1035</u>	<u>1130</u>	<u>1400</u>	
4. Load	<u>14500</u>	<u>14500</u>	<u>14500</u>	<u>14500</u>	
5. Process Rate					
6. Flue Diam. or Size, ft	<u>2.5</u>	<u>2.5</u>	<u>2.5</u>	<u>2.5</u>	
7. Probe Position	<u>CENTER</u>	<u>CENTER</u>	<u>CENTER</u>	<u>CENTER</u>	
8. Oxygen (%)	<u>3.0</u>	<u>4.2</u>	<u>4.2</u>	<u>4.2</u>	
9. NOx (hot) read/3% O ₂ (ppm)*	<u>185</u> <u>185</u>	<u>135</u> <u>145</u>	<u>136</u> <u>146</u>	<u>134</u> <u>144</u>	
10. NO (hot) read/3% O ₂ (ppm)*	<u>185</u> <u>185</u>	<u>135</u> <u>145</u>	<u>136</u> <u>146</u>	<u>134</u> <u>144</u>	
11. NO ₂ (hot) read/3% O ₂ (ppm)*	<u>0</u> <u>0</u>	<u>0</u> <u>0</u>	<u>0</u> <u>0</u>	<u>0</u> <u>0</u>	
12. NO (cold) read/3% O ₂ (ppm)*	<u>215</u> <u>215</u>	<u>150</u> <u>161</u>	<u>152</u> <u>163</u>	<u>153</u> <u>164</u>	
13. Carbon Dioxide (%)	<u>14.0</u>	<u>13.2</u>	<u>13.3</u>	<u>13.2</u>	
14. Carbon Monoxide (ppm) uncor/cor*	<u>17</u> <u>17</u>	<u>25</u> <u>27</u>	<u>8</u> <u>9</u>	<u>10</u> <u>11</u>	
15. Hydrocarbon (ppm) uncor/cor	<u>10</u> <u>10</u>	<u>0</u> <u>0</u>	<u>1</u> <u>1</u>	<u>10</u> <u>11</u>	
16. Sulfur Dioxide (ppm) uncor/cor*	<u>330</u> <u>330</u>	<u>320</u> <u>343</u>	<u>300</u> <u>321</u>	<u>315</u> <u>337</u>	
17. Smoke Spot (Bacharach)		<u>1.5</u>	<u>1.5</u>	<u>1.5</u>	
18. Atmos. Temp. (°F/°C)	<u>32/0</u>	<u>35/2</u>	<u>38/3</u>	<u>40/4</u>	
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	<u>29.99</u>	<u>29.98</u>	<u>29.94</u>	<u>29.89</u>	
21. Relative Humidity (%)	<u>65</u>	<u>45</u>	<u>40</u>	<u>37</u>	
22. <u>705 FROM SO₂</u>	<u>0.57</u>	<u>0.59</u>	<u>0.55</u>	<u>0.58</u>	
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if
the value is measured on a wet basis
not 1
wet 1

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 3-2-77 Location 19 Engr. BWHUnit No. _____ Fuel N.G. Capacity 17500 #/hr

Unit Type _____ Burner Type _____

19-171 19-172 19-173 19-174 19-175

1. Test No.	<u>19-171</u>		<u>19-172</u>		<u>19-173</u>		<u>19-174</u>		<u>19-175</u>	
2. Date	<u>3-2-77</u>		<u>3-2-77</u>		<u>3-2-77</u>		<u>3-2-77</u>		<u>3-2-77</u>	
3. Time	<u>1120</u>		<u>1157</u>		<u>1330</u>		<u>1345</u>		<u>1500</u>	
4. Load										
5. Process Rate										
6. Flue Diam. or Size, ft	<u>2.5</u>		<u>2.5</u>		<u>2.5</u>		<u>2.5</u>		<u>2.5</u>	
7. Probe Position	<u>CENTER</u>		<u>CENTER</u>		<u>CENTER</u>		<u>CENTER</u>		<u>CENTER</u>	
8. Oxygen (%)	<u>3.2</u>		<u>3.05</u>		<u>2.9</u>		<u>3.1</u>		<u>1.5</u>	
9. NO _x (hot) read/3% O ₂ (ppm)*	<u>20</u>	<u>20</u>	<u>85</u>	<u>85</u>	<u>29</u>	<u>29</u>	<u>46</u>	<u>46</u>	<u>36</u>	<u>33</u>
10. NO (hot) read/3% O ₂ (ppm)*	<u>20</u>	<u>20</u>	<u>85</u>	<u>85</u>	<u>29</u>	<u>29</u>	<u>46</u>	<u>46</u>	<u>36</u>	<u>33</u>
11. NO ₂ (hot) read/3% O ₂ (ppm)*	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>
12. NO (cold) read/3% O ₂ (ppm)*	<u>24</u>	<u>24</u>	<u>102.5</u>	<u>102.7</u>	<u>35</u>	<u>35</u>	<u>56</u>	<u>56</u>	<u>46</u>	<u>42</u>
13. Carbon Dioxide (%)	<u>10.6</u>		<u>11.3</u>		<u>10.8</u>		<u>11.1</u>		<u>11.3</u>	
14. Carbon Monoxide (ppm) uncor/cor*	<u>20</u>	<u>20</u>	<u>22</u>	<u>22</u>	<u>12</u>	<u>12</u>	<u>14</u>	<u>14</u>	<u>96</u>	<u>89</u>
15. Hydrocarbon (ppm) uncor/cor*	<u>3</u>	<u>3</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u>0</u>	<u>0</u>
16. Sulfur Dioxide (ppm) uncor/cor*	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>
17. Smoke Spot (Bacharach)										
18. Atmos. Temp. (°F/°C)	<u>34/1</u>		<u>34/1</u>		<u>44/6</u>		<u>44/6</u>		<u>45/7</u>	
19. Dew Point Temp. (°F/°C)										
20. Atmos. Pressure (in. Hg)	<u>30.27</u>		<u>30.27</u>		<u>30.23</u>		<u>30.23</u>		<u>30.22</u>	
21. Relative Humidity (%)	<u>40</u>		<u>40</u>		<u>29</u>		<u>29</u>		<u>25</u>	
22.										
23.										
24.										
25.										
26.										
27.										
28.										
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

Test No. _____

Unit No. _____ Fuel NG Capacity 17500 #/hr

Unit Type _____ Burner Type _____

19-176 19-177

1. Test No.									
2. Date	3-2-77	3-2-77							
3. Time	1526	1541							
4. Load									
5. Process Rate									
6. Flue Diam. or Size, ft	2.5	2.5							
7. Probe Position	CENTER	CENTER							
8. Oxygen (%)	3.75	2.5							
9. NOx (hot) read/3% O ₂ (ppm)*	26	27	19	18					
10. NO (hot) read/3% O ₂ (ppm)*	26	27	19	18					
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0	0					
12. NO (cold) read/3% O ₂ (ppm)*	32	33	23	22					
13. Carbon Dioxide (%)	10.0	10.6							
14. Carbon Monoxide (ppm) uncor/cor*	14	15	16	16					
15. Hydrocarbon (ppm) uncor/cor*	0	0	0	0					
16. Sulfur Dioxide (ppm) uncor/cor*	0	0	0	0					
17. Smoke Spot (Bacharach)									
18. Atmos. Temp. (°F/°C)	45/7	45/7							
19. Dew Point Temp. (°F/°C)									
20. Atmos. Pressure (in. Hg)	30.22	30.22							
21. Relative Humidity (%)	25	25							
22.									
23.									
24.									
25.									
26.									
27.									
28.									
29.									
30.									

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. BWHUnit No. _____ Fuel _____ Capacity 17500 #/hr

Unit Type _____ Burner Type _____

19-17819-179

1. Test No.										
2. Date	3-3-77	3-3-77								
3. Time	0820	1015	1120	1208	1337					
4. Load	14000									
5. Process Rate										
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5					
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER					
8. Oxygen (%)	2.7	3.6	3.6	3.5	3.4					
9. NOx (hot) read/3% O ₂ (ppm)*	98	96	27	28	28	29	28	29	26	27
10. NO (hot) read/3% O ₂ (ppm)*	98	96	27	28	28	29	28	29	26	27
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0	0	0	0	0	0	0	0
12. NO (cold) read/3% O ₂ (ppm)*	113	111	32	33	32	33	32	33	30	31
13. Carbon Dioxide (%)	13.2	13.2	13.0	13.2	13.2					
14. Carbon Monoxide (ppm) uncor/cor*	10	10	18	19	16	17	18	19	18	18
15. Hydrocarbon (ppm) uncor/cor	6	6	0	0	0	0	0	0	0	0
16. Sulfur Dioxide (ppm) uncor/cor*	60	59	80	83	90	93	80	82	80	82
17. Smoke Spot (Bacharach)	0	0	0	—	0					
18. Atmos. Temp. (°F/°C)	26/-3	35/2	40	45/7	48/9					
19. Dew Point Temp. (°F/°C)										
20. Atmos. Pressure (in. Hg)	30-36	30.35	30.34	30.32	30.30					
21. Relative Humidity (%)	71	54	42	34	27					
22. % S IN FUEL FROM SO ₂	0.10	0.14	0.16	0.14	0.14					
23.										
24.										
25.										
26.										
27.										
28.										
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

Test No. _____

Unit No. _____ Fuel #2016 Capacity 17500 #/hr

Unit Type _____ Burner Type _____

5-19-179

[illegible]

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. BWHUnit No. _____ Fuel N.G. Capacity 17500 #/hr

Unit Type _____ Burner Type _____

	19-180	19-181	19-182	19-183	19-184
1. Test No.	19-176	19-177	19-178	19-179	19-180
2. Date	3/4/77	3/4/77	3/4/77	3/4/77	3/4/77
3. Time	0800	0923	0934	0952	1002
4. Load					
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	6.2	3.2	6.15	2.0	1.1
9. NO _x (hot) read/3% O ₂ (ppm)*	55 67	73 74	57 69	78 74	78 71
10. NO (hot) read/3% O ₂ (ppm)*	55 67	73 74	57 69	78 74	78 71
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0 0	0 0	0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	69 84	89 90	68 82	97 92	98 87
13. Carbon Dioxide (%)	9.5	11.0	9.4	11.8	12.0
14. Carbon Monoxide (ppm) uncor/cor*	8 10	19 19	12 15	28 27	1100 995
15. Hydrocarbon (ppm) uncor/cor*	16 19	4 4	1 1	2 2	0 0
16. Sulfur Dioxide (ppm) uncor/cor*	40 49	0 0	0 0	0 0	0 0
17. Smoke Spot (Bacharach)					
18. Atmos. Temp. (°F/°C)	43/6	44/7	44/7	44/7	44/7
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.09	30.08	30.08	30.08	30.05
21. Relative Humidity (%)	86	86	86	86	89
22. % S	0.08	0	0	0	0
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. BWHUnit No. _____ Fuel N. G. Capacity 17500 #/hr

Unit Type _____ Burner Type _____

	19-185	19-186	19-187	19-188	19-189
1. Test No.	1-181	1-182	1-183	1-184	1-185
2. Date	3/4/77	3/4/77	3/4/77	3/4/77	3/4/77
3. Time	1045	1103	1350	1404	1423
4. Load					
5. Process Rate					
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	CENTER	CENTER	CENTER	CENTER	CENTER
8. Oxygen (%)	3.1	2.8	5.0	4.8	4.1
9. NOx (hot) read/3% O ₂ (ppm)*	44 44	40 40	16 18	16 18	22 23
10. NO (hot) read/3% O ₂ (ppm)*	44 44	40 40	16 18	16 18	22 23
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0 0	0 0	0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	56 56	50 49	19.5 22	20 22	27 29
13. Carbon Dioxide (%)	11.3	11.0	9.7	9.7	10.2
14. Carbon Monoxide (ppm) uncor/cor*	60 60	296 293	12 14	12 13	60 64
15. Hydrocarbon (ppm) uncor/cor*	0 0	0 0	0 0	0 0	0 0
16. Sulfur Dioxide (ppm) uncor/cor*	0 0	0 0	0 0	0 0	0 0
17. Smoke Spot (Bacharach)					
18. Atmos. Temp. (°F/°C)	44/7	46/8	48/9	48/9	48/9
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.05	30.02	29.87	29.87	28.87
21. Relative Humidity (%)	89	89	90	90	90
22. % S	0	0	0	0	0
23.					
24.					
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 3/7/77 Location 19 Engr. BWHUnit No. _____ Fuel _____ Capacity 17500 #/hr

Unit Type _____ Burner Type _____

	← 19-190 →				19-191		← 19-192 →			
1. Test No.	19-190				19-191		19-192			
2. Date	3/7/77				3/7/77		3/7/77			
3. Time	0943				1043		1335			
4. Load										
5. Process Rate										
6. Flue Diam. or Size, ft	2.5				2.5		2.5			
7. Probe Position	CENTER				CENTER		CENTER			
8. Oxygen (%)	3.3				3.2		2.8			
9. NOx (hot) read/3% O ₂ (ppm)*	21	21	21	21	183	181	138	149	138	147
10. NO (hot) read/3% O ₂ (ppm)*	21	21	21	21	183	181	138	149	138	147
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0	0	0	0	0	0	0	0
12. NO (cold) read/3% O ₂ (ppm)*	26	26	26	26	203	201	153	164	155	165
13. Carbon Dioxide (%)	9.9				10.6		12.1			
14. Carbon Monoxide (ppm) uncor/cor*	18	18	14	14	28	28	16	17	16	17
15. Hydrocarbon (ppm) uncor/cor	0	0	0	0	2	2	1	1	0	0
16. Sulfur Dioxide (ppm) uncor/cor	20	20	20	20	340	336	300	321	320	341
17. Smoke Spot (Bacharach)	—				—		0			
18. Atmos. Temp. (°F/°C)	35/2				35/2		41/5			
19. Dew Point Temp. (°F/°C)										
20. Atmos. Pressure (in. Hg)	30.07				30.07		30.03			
21. Relative Humidity (%)	72				72		47			
22. % S IN FUEL	0.04				0.04		0.58			
23.										
24.										
25.										
26.										
27.										
28.										
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 3/8/77 Location 19 Engr. BWHUnit No. _____ Fuel NG Capacity 17500 #/hr

Unit Type _____ Burner Type _____

	<u>19-193</u>									
1. Test No.	<u>19-189</u>									
2. Date	<u>3/8/77</u>									
3. Time	<u>0925</u>	<u>0930</u>	<u>0935</u>	<u>0940</u>	<u>0945</u>					
4. Load										
5. Process Rate										
6. Flue Diam. or Size, ft	<u>2.5</u>									
7. Probe Position	<u>28" IN</u>	<u>23" IN</u>	<u>18" IN</u>	<u>13" IN</u>	<u>8" IN</u>					
8. Oxygen (%)	<u>3.25</u>	<u>3.2</u>	<u>3.2</u>	<u>3.2</u>	<u>3.2</u>					
9. NOx (hot) read/3% O ₂ (ppm)*	<u>65</u>	<u>66</u>	<u>66</u>	<u>67</u>	<u>66</u>	<u>67</u>	<u>67</u>	<u>68</u>	<u>67</u>	<u>68</u>
10. NO (hot) read/3% O ₂ (ppm)*	<u>65</u>	<u>66</u>	<u>66</u>	<u>67</u>	<u>66</u>	<u>67</u>	<u>67</u>	<u>68</u>	<u>67</u>	<u>68</u>
11. NO ₂ (hot) read/3% O ₂ (ppm)*	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>
12. NO (cold) read/3% O ₂ (ppm)*	<u>82</u>	<u>83</u>	<u>82</u>	<u>83</u>	<u>83</u>	<u>84</u>	<u>82</u>	<u>83</u>	<u>82</u>	<u>83</u>
13. Carbon Dioxide (%)	<u>10.6</u>	<u>10.6</u>	<u>10.6</u>	<u>10.6</u>	<u>10.6</u>					
14. Carbon Monoxide (ppm) uncor/cor*	<u>24</u>	<u>24</u>	<u>23</u>	<u>23</u>	<u>22</u>	<u>22</u>	<u>24</u>	<u>24</u>	<u>24</u>	<u>24</u>
15. Hydrocarbon (ppm) uncor/cor*	<u>1</u>	<u>1</u>	<u>4</u>	<u>4</u>	<u>4</u>	<u>4</u>	<u>2</u>	<u>2</u>	<u>1</u>	<u>1</u>
16. Sulfur Dioxide (ppm) uncor/cor*	<u>—</u>	<u>—</u>	<u>20</u>	<u>20</u>	<u>10</u>	<u>10</u>	<u>10</u>	<u>10</u>	<u>20</u>	<u>20</u>
17. Smoke Spot (Bacharach)	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
18. Atmos. Temp. (°F/°C)										
19. Dew Point Temp. (°F/°C)										
20. Atmos. Pressure (in. Hg)										
21. Relative Humidity (%)										
22.										
23.										
24.										
25.										
26.										
27.										
28.										
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date _____ Location 19 Engr. BWHUnit No. _____ Fuel N.G. Capacity 17500 #/hr

Unit Type _____ Burner Type _____

S- 19-193 →

1. Test No.	19								
2. Date	3/8/77	3/8/77	3/8/77	3/8/77					
3. Time	0950	1034	1120	1210					
4. Load									
5. Process Rate									
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5					
7. Probe Position	3" IN	CENTER	CENTER	CENTER					
8. Oxygen (%)	3.4	3.3	3.3	3.3					
9. NOx (hot) read/3% O ₂ (ppm)*	—	—	63	64	64	65	65	66	
10. NO (hot) read/3% O ₂ (ppm)*	67	67	63	64	64	65	65	66	
11. NO ₂ (hot) read/3% O ₂ (ppm)*	—	—	0	0	0	0	0	0	
12. NO (cold) read/3% O ₂ (ppm)*	82	83	80	81	80	81	81	82	
13. Carbon Dioxide (%)	10.4	10.6	10.4	10.6					
14. Carbon Monoxide (ppm) uncor/cor*	24	24	21	21	24	24	24	24	
15. Hydrocarbon (ppm) uncor/cor*	0	0	5	5	2	2	2	2	
16. Sulfur Dioxide (ppm) uncor/cor*	10	10	10	10	20	20	10	10	
17. Smoke Spot (Bacharach)									
18. Atmos. Temp. (°F/°C)		40/4	43/6	44/7					
19. Dew Point Temp. (°F/°C)									
20. Atmos. Pressure (in. Hg)		30.28	30.27	30.25					
21. Relative Humidity (%)		50	50	40					
22.									
23.									
24.									
25.									
26.									
27.									
28.									
29.									
30.									

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. 19-1-SASS Date 3-10-77 Location _____ Engr. BLW#Fuel # 60.1 Capacity 17500 #/hr

Unit Type _____ Burner Type _____

1. Test No.	19-1-SASS	→	→	→	→
2. Date	3-10-77	→	→	→	→
3. Time	1120	1200	1300	1406	1500
4. Load	14200				
5. Process Rate	—	—	—	—	—
6. Flue Diam. or Size, ft	2.5	2.5	2.5	2.5	2.5
7. Probe Position	Center	Center	Center	Center	Center
8. Oxygen (%)	2.8	2.8	3.1	2.8	2.8
9. NOx (hot) read/3% O ₂ (ppm)	190 188	185 183	190 191	188 186	185 183
10. NO (hot) read/3% O ₂ (ppm)	190 188	185 183	190 191	188 186	185 183
11. NO ₂ (hot) read/3% O ₂ (ppm)	0 0	0 0	0 0	0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)	213 211	210 208	216 217	213 211	214 212
13. Carbon Dioxide (%)	13.5	14.0	14.0	14.0	14.0
Carbon Monoxide (ppm) uncor/cor	18 18	18 18	16 16	18 18	18 18
15. Hydrocarbon (ppm) uncor/cor	0 0	3 3	1 1	1 1	0 0
16. Sulfur Dioxide (ppm) uncor/cor	340 336	360 356	360 362	360 356	340 336
17. Smoke Spot (Bacharach)	—	—	—	—	—
18. Atmos. Temp. (°F/°C)	56/13	60/16	70	68	68
19. Dew Point Temp. (°F/°C)			58	53	53
20. Atmos. Pressure (in. Hg)	30.21	30.20↓	30.2	30.17	30.17
21. Relative Humidity (%)	42	33	49	35	35
22. % S in Fuel	0.58	0.61	0.62	0.61	0.58
23.					
24.					
25.					
26.					
27.					
28.					
29.					

Data Sheet 6002-2

Test No.

Engr. *BW**

1. Test No.	19-1-SASS								
2. Date	3/10/77								
3. Time	1600								
4. Load									
5. Process Rate	—								
6. Flue Diam. or Size, ft	2.5								
7. Probe Position	Center								
8. Oxygen (%) :	3.1								
9. NOx (hot) read/3% O ₂ (ppm)	193 / 194								
10. NO (hot) read/3% O ₂ (ppm)	193 / 194								
11. NO ₂ (hot) read/3% O ₂ (ppm)	0 / 0								
12. NO (cold) read/3% O ₂ (ppm)	218 / 219								
13. Carbon Dioxide (%)	13.8								
Carbon Monoxide (ppm) uncor/cor	16 / 16								
15. Hydrocarbon (ppm) uncor/cor	1 / 1								
16. Sulfur Dioxide (ppm) uncor/cor	340 / 342								
17. Smoke Spot (Bacharach)	0								
18. Atmos. Temp. (°F/°C)	69								
19. Dew Point Temp. (°F/°C)	54								
20. Atmos. Pressure (in. Hg)	30.17								
21. Relative Humidity (%)	36								
22. %S in Fuel	0.59								
23.									
24.									
25.									
26.									
27.									
28.									
29.									

49

Test No. _____

.. it No. Fuel #6 oil Capacity 17500 #/hr steam

Unit Type _____ Burner Type _____

1. Test No.	19-2-SAS5								
2. Date	3/17/77								
3. Time	1000		1100	1200	1300	1400			
4. Load	14000		14500	14800	14900				
5. Process Rate	—		—	—	—				
6. Flue Diam. or Size, ft	2.5								
7. Probe Position	Center								
8. Oxygen (%)	3.2		2.9	2.8	2.7	3.0			
9. NOx (hot) read/3% O ₂ (ppm)	224	227	210	209	208	206	218	214	215
10. NO (hot) read/3% O ₂ (ppm)	221	224	210	209	208	205	218	214	215
11. NO ₂ (hot) read/3% O ₂ (ppm)	3	3	0	0	0	0	0	0	0
12. NO (cold) read/3% O ₂ (ppm)	248	251	238	237	238	235	245	241	240
13. Carbon Dioxide (%)	13.6		14.0	14.0	14.0	13.6			
Carbon Monoxide (ppm) uncor/cor	24	24	26	26	84	83	30	30	36
15. Hydrocarbon (ppm) uncor/cor	0	0	6	6	5	5	3	3	2
16. Sulfur Dioxide (ppm) uncor/cor	740	748	740	736	740	732	740	728	710
17. Smoke Spot (Bacharach)	1		0.5						
18. Atmos. Temp. (°F/°C)	39		41	44	46	48			
19. Dew Point Temp. (°F/°C)	35		34	38	38	38			
20. Atmos. Pressure (in. Hg)	29.99		29.99	29.98	29.97	29.93			
21. Relative Humidity (%)	67		49	57	47	38			
22. % S in Fuel	1.29		1.27	1.26	1.25	1.22			
23.									
24.									
25.									
26.									
27.									
28.									
29.									

50

MOBILE LABORATORY DATA

Test No. _____

Test No. 19-1 SASS Date 3/17/77 Location _____Engr. BWAUnit No. 1 Fuel #6 Oil Capacity 17500 #/hr steam

Unit Type _____ Burner Type _____

1. Test No.	<u>19-1 SASS</u>						
2. Date	<u>3/17/77</u>						
3. Time	<u>1450</u>						
4. Load							
5. Process Rate	<u>—</u>						
6. Flue Diam. or Size, ft	<u>2.5</u>						
7. Probe Position	<u>Center</u>						
8. Oxygen (%)	<u>3.2</u>						
9. NOx (hot) read/3% O ₂ (ppm)	<u>219</u>	<u>221</u>					
10. NO (hot) read/3% O ₂ (ppm)	<u>219</u>	<u>221</u>					
11. NO ₂ (hot) read/3% O ₂ (ppm)	<u>0</u>	<u>0</u>					
12. NO (cold) read/3% O ₂ (ppm)	<u>255</u>	<u>258</u>					
13. Carbon Dioxide (%)	<u>13.6</u>						
Carbon Monoxide (ppm) uncor/cor	<u>24</u>	<u>24</u>					
15. Hydrocarbon (ppm) uncor/cor	<u>3</u>	<u>3</u>					
16. Sulfur Dioxide (ppm) uncor/cor	<u>730</u>	<u>738</u>					
17. Smoke Spot (Bacharach)							
18. Atmos. Temp. (°F/°C)	<u>50</u>						
19. Dew Point Temp. (°F/°C)	<u>40</u>						
20. Atmos. Pressure (in. Hg)	<u>29.92</u>						
21. Relative Humidity (%)	<u>40</u>						
22. <u>90.5</u> in Fuel	<u>1.27</u>						
23.							
24.							
25.							
26.							
27.							
28.							
29.							

Data Sheet 6002-2

Test No.

Unit No. 1 Fuel #6 Oil Capacity 17500 #/hr steam

Unit Type _____ Burner Type _____

1. Test No.	19-3-SASS				
2. Date	3-21-77				
3. Time	1035	1130	1235	1330	1430
4. Load					
5. Process Rate					
6. Flue Diam. or Size, ft	25				
7. Probe Position	Center				
8. Oxygen (%)	1.7	1.6	2.0	1.7	1.8
9. NOx (hot) read/3% O ₂ (ppm)	163 152	153 142	173 164	170 159	170 159
10. NO (hot) read/3% O ₂ (ppm)	163 152	153 142	173 164	170 159	170 159
11. NO ₂ (hot) read/3% O ₂ (ppm)	0 0	0 0	0 0	0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)	180 168	173 167	195 185	193 180	193 181
13. Carbon Dioxide (%)	14.4	14.4	14.8	14.4	14.4
Carbon Monoxide (ppm) uncor/cor	240 224	470 436	40 38	125 117	80 75
15. Hydrocarbon (ppm) uncor/cor	3 3	5 5	0 0	3 3	- -
16. Sulfur Dioxide (ppm) uncor/cor	180 727	800 742	740 701	780 727	760 713
17. Smoke Spot (Bacharach)	1.0	1.0	1.0	1.0	0.5
18. Atmos. Temp. (°F/°C)	42	44	45	47	51
19. Dew Point Temp. (°F/°C)	37	39	40	42	45
20. Atmos. Pressure (in. Hg)	30.25	30.23	30.20	30.19	30.14
21. Relative Humidity (%)	62	64	65	67	64
22. % S in Fuel	1.25	1.28	1.21	1.25	1.23
23.					
24.					
25.					
26.					
27.					
28.					
29.					

MAX. RECIRC.
SASS
New #6 Oil & Burner Tip

Data Sheet 6002-2

Test No. _____

Engr. BWH

steam

		Baseline			
1. Test No.	19-3 SASS	19-3			
2. Date	3-21-77	3-21-77			
3. Time	1530	1555			
4. Load					
5. Process Rate	—	—			
6. Flue Diam. or Size, ft	2.5	2.5			
7. Probe Position	Center	Center			
8. Oxygen (%)	1.2	2.85			
9. NOx (hot) read/3% O ₂ (ppm)	168/158	237/234			
10. NO (hot) read/3% O ₂ (ppm)	168/158	237/234			
11. NO ₂ (hot) read/3% O ₂ (ppm)	0/0	0/0			
12. NO (cold) read/3% O ₂ (ppm)	193/181	273/270			
13. Carbon Dioxide (%)	14.4	13.8			
Carbon Monoxide (ppm) uncor/cor	85/80	16/16			
15. Hydrocarbon (ppm) uncor/cor	—/—	—/—			
16. Sulfur Dioxide (ppm) uncor/cor	760/713	720/712			
17. Smoke Spot (Bacharach)	0.5	0.5			
18. Atmos. Temp. (°F/°C)	50	50			
19. Dew Point Temp. (°F/°C)	43	43			
20. Atmos. Pressure (in. Hg)	30.12	30.12			
21. Relative Humidity (%)	56	56			
22. % S in Fuel	1.23	1.23			
23.					
24.					
25.					
26.					
27.					
28.					
29.					

MAX. RECIPE
 SASS

BASELINE
 NEW #6 OIL + BURNER
 TIP

53

Test No.

Unit No. 1 Fuel #6 Oil Capacity 17500 # per year

Unit Type _____ Burner Type Faber _____

1. Test No.	19.4 SASS							
2. Date	3-23-77							
3. Time	0930		1030		1140		1230 1340	
4. Load								
5. Process Rate	— — — —							
6. Flue Diam. or Size, ft	2.5							
7. Probe Position	Center							
8. Oxygen (%)	1.5		1.5		1.3		1.9 1.5	
9. NOx (hot) read/3% O ₂ (ppm)	163	150	163	150	158	144	180	170 168 155
10. NO (hot) read/3% O ₂ (ppm)	163	150	163	150	158	144	180	170 165 152
11. NO ₂ (hot) read/3% O ₂ (ppm)	0	0	0	0	0	0	0	0 3 3
12. NO (cold) read/3% O ₂ (ppm)	188	174	188	174	172	163	208	196 193 178
13. Carbon Dioxide (%)	14.4		14.6		14.4		14.2 14.4	
Carbon Monoxide (ppm) uncor/cor	128	118	120	111	238	208	28	26 104 96
15. Hydrocarbon (ppm) uncor/cor	—	—	—	—	—	—	—	— — —
16. Sulfur Dioxide (ppm) uncor/cor	710	655	710	655	680	621	720	679 700 646
17. Smoke Spot (Bacharach)	0.5		0.5		0.5		— 0.5	
18. Atmos. Temp. (°F/°C)	38		40		44		46 46	
19. Dew Point Temp. (°F/°C)	33		35		38		38 37	
20. Atmos. Pressure (in. Hg)	29.84		29.83		29.83		29.83 29.83	
21. Relative Humidity (%)	59		60		58		47 41	
22. % S in Fuel	1.13		1.13		1.07		1.17 1.11	
23.								
24.								
25.								
26.								
27.								
28.								
29.								

54

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 3-23-77 Location _____ Engr. BWKUnit No. _____ Fuel #6 Oil Capacity 17500 #/hr

Unit Type _____ Burner Type _____

		<u>BASELINE</u>			
1. Test No.		19-4 SASS	19-4		
2. Date		3-23-77	3-23-77		
3. Time		14:50	15:05		
4. Load					
5. Process Rate					
6. Flue Diam. or Size, ft		2.5	2.5		
7. Probe Position		Center	Center		
8. Oxygen (%)		1.25	2.8		
9. NOx (hot) read/3% O ₂ (ppm)		165	150	240	237
10. NO (hot) read/3% O ₂ (ppm)		165	150	240	237
11. NO ₂ (hot) read/3% O ₂ (ppm)		0	0	0	0
12. NO (cold) read/3% O ₂ (ppm)		190	173	265	262
13. Carbon Dioxide (%)		14.4	13.8		
14. Carbon Monoxide (ppm) uncor/cor		112	102	22	22
15. Hydrocarbon (ppm) uncor/cor		-	-	-	-
16. Sulfur Dioxide (ppm) uncor/cor		700	638	640	633
17. Smoke Spot (Bacharach)					
18. Atmos. Temp. (°F/°C)		47	47		
19. Dew Point Temp. (°F/°C)		37	37		
20. Atmos. Pressure (in. Hg)		29.83	29.83		
21. Relative Humidity (%)		37	37		
22. % S in Fuel		1.10	1.09		
23.					
24.					
25.					
26.					
27.					
28.					
29.					

Data Sheet 6002-2

UNIT OPERATING DATA

Test No. _____ Date JAN. 77 Location 19 Engr. SOTTERFuel #2 OIL Atom. Type AIR Capacity 17500 LB/HrTest Comments 30" I.D. STACK 4" WALL

	19-2	19-3	19-4	19-5	19-6
1. Test Number	19-3	19-3	19-3	19-3	19-3
2. Date	1/4/77	1/5/77	1/5/77	1/6/77	1/6/77
3. Time	15:15	11:20	15:00	09:45	10:45
4. Load ^{lb/hr}	14500	14300	14200	14000	14000
5. Test Purpose	TEST SERIES 1 BASELINE	#1 BASELINE O ₂ TRAVERSE	#1 BASELINE V TRAVERSE	SO ₂ METHODS #1 BASELINE	→
6. Excess O ₂ Condition	NOMINAL	NOM	NOM	NOM	NOM
7. Cont. Room O ₂ (%)	—	—	—	—	—
8. Pres. Furn/Windbox (iwg)	0.3 1.6	0.25 1.5	0.25 1.4	0.20 1.3	0.20 1.3
9. Uptake (iwg)	-0.24	-0.26	-0.28	-0.28	-0.28
10. Final Stm Press (psig)	100	98	97	97	98
11. Drum Press (psig)	100	99	97	97	98
12. F. Water P/T (psig/°F)	220 224	220 223	222 224	218 223	218 223
13. Air FD Fan Amps	—	8.2	8.6	8.4	8.4
14. Air Temp @ FD Fan/CR (°F)	—	75	90	77	79
15. Stack Temp (°F)	—	520	514	516	515
16. Fuel Flow (GPM) or GPM	2.18	2.20	2.15	2.11	2.14
17. Fuel Pres/Temp (psi/°F)	114 52	120 52	118 54	122 53	122 54
18. Fuel Atom Pres (psig)	29	29	28	28.5	28.5
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	—	—	—	—	—
21. ΔP Pitot FGR Duct (iwg)	0	0	0	0	0
22. ΔP Orif. FGR Duct (iwg)	0	0	0	0	0
23. Temp. FGR Duct (°F)	—	—	—	—	—
24. Pstat FGR Duct (psig)	—	—	—	—	—
25. Pstat S.A. Fan (psig)	—	—	—	—	—
26. Vortex FD Fan Blades	—	40	40	40	40
27. Vortex SA Fan Blades	—	—	—	—	—
28. SA Depth/Flow (ft/cfm)	— —	— —	— —	— —	— —
29. % FGR	—	—	—	—	—
30. Total Oil Burned #2/#6	—	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

STEAM VENT RATE (lb/hr) 8000
TOTAL STEAM DUMPED 7500

6000

7000
35000

5700

7000

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date 6 JAN 77 Location 19 Engr. SCOTTERFuel #2 CIL. Atom. Type AIR Capacity 17500 lb/hr

Test Comments _____

	19-7	19-8	19-9	19-10	19-11
1. Test Number	19-3	19-4	19-5	19-10	2-1
2. Date	1/6/77	1/6/77	1/7/77	1/10/77	1/10/77
3. Time	15:30	16:05	10:15	9:05	9:50
4. Load	14000	14000	14000	14200	14300
5. Test Purpose	BASLINE 1 IMPACTOR	→	BASLINE 1 CHECK	BASLINE 1 CHECK	HIGH C ₂ (ADJ BURNER FUEL CAL)
6. Excess O ₂ Condition	NOM	NOM	NOM	NOM	H1
7. Cont. Room O ₂ (%)	—	—	—	2.5	4.3
8. Pres. Furn/Windbox (iwg)	0.25 1.3	0.25 1.3	0.25 1.4	0.32 1.8	0.60 2.4
9. Uptake (iwg)	-0.26	-0.26	-0.25	-0.24	-0.18
10. Final Stm Press (psig)	98	98	98	98	99
11. Drum Press (psig)	96	97	98	100	99
12. F. Water P/T (psig/°F)	223 225	221 225	221 225	218 226	218 226
13. Air FD Fan Amps	8.6	8.6	8.6	8.8	9.5
14. Air Temp @ FD Fan/CR (°F)	88	88	89	92	94
15. Stack Temp (°F)	511	511	507	513	533
16. Fuel Flow (CFM → GPM)	2.11	2.14	2.13	2.22	2.20
17. Fuel Pres/Temp (psi/°F)	120	120 56	107 58	97 56	97 94
18. Fuel Atom Press (psig)	28	28	28	28	28
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	—	—	—	—	—
21. ΔP Pitot FGR Duct (iwg)	0	0	0	0	0
22. ΔP Orif. FGR Duct (iwg)	0	0	0	0	0
23. Temp. FGR Duct (°F)	—	—	—	—	—
24. Pstat FGR Duct (psig)	—	—	—	—	—
25. Pstat S.A. Fan (psig)	—	—	—	—	—
26. Vortex FD Fan Blades	40	40	(1.18)	1.25	1.75
27. Vortex SA Fan Blades	—	—	—	—	—
28. SA Depth/Flow (ft/cfm)	+	+	+	+	+
29. % FGR	—	—	—	—	—
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0
STEAM VENT RATE (lb/hr)	6000	6000	6500	7000	6500
ATOMIZING AIR PRESS. (PSIG)			23.5	23.9	23.9

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTER
 Fuel #2 OIL Atom. Type AIR Capacity 17500 lb/hr
 Test Comments O₂ VAR

	19-12	19-13	19-14	19-15	19-16
1. Test Number	2-2	2-3	4C-1	1-11	4A-11
2. Date	10 JAN	10 JAN	10 JAN	11 JAN	11 JAN
3. Time	10:30	10:50	11:35	9:30	9:55
4. Load	14,300	14,400	14,200	14,200	14,500
5. Test Purpose	OPT. O ₂	BARELY VISIBLE SMOKE	H1 RECIRC	BASELINE #1	15% RECIRC
6. Excess O ₂ Condition	OPT.	MIN	3%	3%	3%
7. Cont. Room O ₂ (%)	0.2	0	2.1	2.3	2.4
8. Pres.Furn/Windbox(iwg)	0.30 1.4	0.30 1.4	0.90 3.7	0.29 1.6	0.55 2.8
9. Uptake (iwg)	-0.2	-0.20	-0.19	-0.22	-0.21
10. Final Stm Press (psig)	98	98	99	98	97
11. Drum Press (psig)	99	100	99	98	97
12. F. Water P/T (psig/°F)	218 226	215 226	215 224	218 224	218
13. Air FD Fan Amps	8.1	8.1	9.2	8.5	8.8
14. Air Temp @ FD Fan/CR(°F)	92	93	97	78	84
15. Stack Temp (°F)	499	499	560	510	548
16. Fuel Flow (CFM or GPM)	2.14	2.17	2.20	2.23	2.18
17. Fuel Pres/Temp (psi/°F)	107 56	107 56	122 58	122 40	122 40
18. Fuel Atom Pres (psig)	28.6	28.9	29.0	28.8	28.9
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting ^{IN FROM FACE}	+	+	1.0	4.25 CLOSED	3.3
21. ΔP Pitot FGR Duct(iwg)	—	—	—	0.00	0.07
22. ΔP Orif. FGR Duct(iwg)	—	—	0.70	0.00	0.20
23. Temp. FGR Duct (°F)	—	113	520	105	476
24. Pstat FGR Duct (psig)	—	—	—	0.46	5.5
25. Pstat S.A. Fan (psig)	—	—	—	—	—
26. Vortex FD Fan Blades ^{F.D. FAN INLET ΔP, IWG}	0.95	0.94	1.4	1.1	1.2
27. Vortex SA Fan Blades	—	—	—	—	—
28. SA Depth/Flow (ft/cfm)	+	+	+	+	+
29. % FGR	—	—	—	—	—
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

STEAM VENT, lb/hr 7000 7000 7000 5500 5300
 Data Sheet 6003-16
 ATOM. AIR PRESS, PSIG 23.8 23.8 23.9 23.8 23.9

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTERFuel #2 OIL Atom. Type AIR Capacity 17500 lb/hr

Test Comments _____

	19-17	19-18	19-19	19-20	19-21
1. Test Number	4C-2	4B-1	4B-2	4A-2	4C-2
2. Date	11 JAN	11 JAN	11 JAN	11 JAN	11 JAN
3. Time	10:50	12:00	12:20	12:50	1:30
4. Load	14400	14400	14400	14500	14500
5. Test Purpose	MAX. RECIRC	MID RECIRC	MID RECIRC LOW O ₂	LOW RECIRC LOW O ₂	HI RECIRC
6. Excess O ₂ Condition	3%	3%	LOW	LOW	LOW
7. Cont. Room O ₂ (%)	1.9	2.5	0.6	0.4	0.75
8. Pres. Furn/Windbox (iwg)	0.78 3.5	0.72 3.2	0.55 2.7	0.50 2.5	0.72 3.2
9. Uptake (iwg)	-0.20	-0.16	-0.22	-0.22	-0.21
10. Final Stm Press (psig)	98	99	98	98	99
11. Drum Press (psig)	99	99	100	98	99
12. F. Water P/T (psig/°F)	218 225	218 226	220 226	220 226	218 225
13. Air FD Fan Amps	8.9	9.0	8.5	8.4	8.5
14. Air Temp @ FD Fan/CR (°F)	89	92	92	94	95
15. Stack Temp (°F)	560	557	548	541	552
16. Fuel Flow (GPM or GPM)	2.21	2.16	2.26	2.20	2.18
17. Fuel Pres/Temp (psi/°F)	123 40	123 43	123 45	123 45	123 45
18. Fuel Atom Pres (psig)	29.0	29.2	29.2	29.2	29.1
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting IN	0.7	2.8	3.0	3.3	0.7 (MAX)
21. ΔP Pitot FGR Duct (iwg)	0.145	0.11	0.095	0.05	0.15
22. ΔP Orif. FGR Duct (iwg)	0.75	0.40	0.36	0.19	0.80
23. Temp. FGR Duct (°F)	515	510	510	510	518
24. Pstat FGR Duct (psig)	4.3	4.6	~4.4	~4.8	2.4
25. Pstat S.A. Fan (psig)	—	—	—	—	—
26. Vortex FD Fan Blades	1.2	1.2	1.0	1.0	1.0
27. Vortex SA Fan Blades	—	—	—	—	—
28. SA Depth/Flow (ft/cfm)	±	±	±	±	±
29. % FGR	—	—	—	—	—
30. Total Oil Burned #2/#6	±	±	±	±	±
31. Total Gas Burned	0	0	0	0	0

STEAM VENT RATE, lb/hr 5500 5500 5500 5500 5600

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. G. SOTTER
 Fuel #2 OIL Atom. Type AIR Capacity 17,500 lb/hr

Test Comments _____

	19-22		19-23		19-24		19-25		19-26	
1. Test Number	1-12		3-0a		3-0b		3-0c		3-0d	
2. Date	12 JAN 76		12 JAN 76		12 JAN 76		12 JAN 76		12 JAN 76	
3. Time	7:45		8:45		9:00		9:10		9:30	
4. Load	14,000		14,000		14,000		14,300		14,000	
5. Test Purpose	BASELINE CHECK		2 nd AIR CALIBRATION		→		→		→	
6. Excess O ₂ Condition	NOM		H1		H1		H1		H1	
7. Cont. Room O ₂ (%)	3.3		6.5		5.5		5.0		7.0	
8. Pres. Furn/Windbox (iwg)	0.20	1.6	0.5	1.7	0.45	1.7	0.40	1.7	0.55	1.75
9. Uptake (iwg)	-0.26		-0.20		-0.20		-0.22		-0.20	
10. Final Stm Press (psig)	97		97		97		94		98	
11. Drum Press (psig)	98		98		99		99		99	
12. F. Water P/T (psig/°F)	220	224	212	224	215	224	205	224	218	230
13. Air FD Fan Amps	8.5		8.4		8.4		8.4		8.4	
14. Air Temp @ FD Fan/CR (°F)	72		80		80		81		81	
15. Stack Temp (°F)	505		527		525		522		528	
16. Fuel Flow (CFM or GPM)	2.20		2.15		2.16		2.18		2.19	
17. Fuel Pres/Temp (psi/°F)	115	47	115	47	115	47	115	47	115	47
18. Fuel Atom Pres (psig)	29		29		30		30		30	
19. Primary Reg. Setting	-8		-8		-8		-8		-8	
20. FGR Reg. Setting	C (Cross)		C		C		C		C	
21. ΔP Pitot FGR Duct (iwg)	—		—		—		—		—	
22. ΔP Orif. FGR Duct (iwg)	—		0.0		-0.01		-0.01		—	
23. Temp. FGR Duct (°F)	—		95		95		98		98	
24. Pstat FGR Duct (psig)	0.0		0.0		0.0		0.0		0.0	
25. Pstat S.A. Fan (psig)	0		4.2		3.0		2.0		5.4 ^{MAX}	
26. Vortex FD Fan Blades	1.1		1.1		1.1		1.1		1.1	
27. Vortex SA Fan Blades	—		—		—		11.0		10.5	
28. SA Depth/Flow (ft/cfm)	+		5		5		5		5	
29. % FGR	0		0		0		0		0	
30. Total Oil Burned #2/#6	+		+		+		+		+	
31. Total Gas Burned	0		0		0		0		0	

STEAM VENT RATE, LB/HR

5500

5500

5000

6000

5500

ATOMIZING AIR PRESS, PSIG

24.1

24.1

24.1

24.1

24.1

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTERFuel #2 DIESEL Atom. Type AIR Capacity 17,500 LB

Test Comments _____

	19-27	19-28	19-29	19-30	19-31
1. Test Number	3-0e	3A1a	3B1a	3C1a	3D1a
2. Date	12 JAN 77	12 JAN 77	12 JAN 77	12 JAN 77	12 JAN 77
3. Time	9:45	12:30	12:45	1:00	1:10
4. Load	14,000	14,000	14,500	14,500	14,500
5. Test Purpose	2° AIR CAL PROBE FUEL IN	TSC 4' Φ=1.2	TSC 5'	TSC 6'	6'11"
6. Excess O ₂ Condition	H1	NOM	NOM	NOM	NOM
7. Cont. Room O ₂ (%)	6.7	2.8	2.8	2.8	2.7
8. Pres.Furn/Windbox (iwg)	0.57 1.8	0.30 1.2	0.28 1.2	0.28 1.2	0.3 1.2
9. Uptake (iwg)	-0.20	-0.20	-0.22	-0.22	-0.22
10. Final Stm Press (psig)	98	98	96	97	97
11. Drum Press (psig)	100	98	97	98	97
12. F. Water P/T (psig/°F)	205	223 224	221 224	220 224	220 224
13. Air FD Fan Amps	8.5	8.0	8.0	7.9	7.9
14. Air Temp @ FD Fan/CR (°F)	82	82	84	82	82
15. Stack Temp (°F)	526	496	495	493	492
16. Fuel Flow (CFM or GPM)	2.17	2.13	2.11	2.12	2.10
17. Fuel Pres/Temp (psi/°F)	115	115 48	115 48	115 48	115 48
18. Fuel Atom Press (psig)	—	28	28	28	28
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	C	C	C	C	C
21. ΔP Pitot FGR Duct (iwg)	—	—	—	—	—
22. ΔP Orif. FGR Duct (iwg)	—	-0.15	—	—	—
23. Temp. FGR Duct (°F)	—	105	—	—	—
24. Pstat FGR Duct (psig)	—	0.0	—	—	—
25. Pstat S.A. Fan (psig)	5.6	2.9	3.0	3.2	3.4
26. Vortex FD Fan Blades	1.1	0.68	0.68	0.68	0.68
27. Vortex SA Fan Blades	10.5	10.9	10.9	10.9	10.9
28. SA Depth/Flow (ft/cfm)	FULL IN	4.0	5.0	6.0	6'11"
29. % FGR	0	0	0	0	0
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

STREAM VENT RATE, LB/HR — 5000 5500 5500 5300
 ATOMIZING AIR PRESS, PSIG — 24.0 23.9 24.0 23.9

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SC TTRFuel #2 OIL Atom. Type AIR Capacity 17,500 LB/HR

Test Comments _____

	19-32	19-33	19-34	19-35	19-36
1. Test Number	3D1B	3C1B	3B1B	3A1B	3D2a
2. Date	12 JAN 77	12 JAN 77	→	→	→
3. Time	1:30	1:45	1:55	2:10	2:40
4. Load	14,400	14,300	14,200	14,200	14,200
5. Test Purpose	$TSC 7'$ $\phi = 1.3$	$TSC 6'$ $\phi = 1.3$	$TSC 5'$ $\phi = 1.3$	$TSC 4'$ $\phi = 1.3$	$TSC 7'$ $\phi = 1.2$
6. Excess O ₂ Condition	NOM	NOM	NOM	NOM	LO
7. Cont. Room O ₂ (%)	2.7	2.7	2.7	2.8	1.5
8. Pres. Furn/Windbox (iwg)	0.28 1.0	0.28 1.0	0.30 1.0	0.30 1.0	0.22 1.2
9. Uptake (iwg)	-0.20	-0.21	-0.20	-0.20	-0.22
10. Final Stm Press (psig)	97	97	97	98	98
11. Drum Press (psig)	97	98	100	98	98
12. F. Water P/T (psig/°F)	220 224	218 224	216 224	219 225	219
13. Air FD Fan Amps	7.6	7.6	7.6	7.6	8.1
14. Air Temp @ FD Fan/CR (°F)	83	85	84	85	82
15. Stack Temp (°F)	483	488	490	492	498
16. Fuel Flow (CFM or GPM)	2.14	2.11	2.15	2.14	2.12
17. Fuel Pres/Temp (psi/°F)	115 48	115 49	115 48	115 49	115 49
18. Fuel Atom Pres (psig)	28	28	28	28	28
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	C	C	C	C	C
21. ΔP Pitot FGR Duct (iwg)	—	—	—	—	0.0
22. ΔP Orif. FGR Duct (iwg)	—	—	—	—	-0.02
23. Temp. FGR Duct (°F)	—	—	—	—	107
24. Pstat FGR Duct (psig)	—	0.0	—	—	—
25. Pstat S.A. Fan (psig)	5.6	5.4	5.2	4.9	0.8
26. Vortex FD Fan Blades ΔP	0.56	0.56	0.56	0.56	0.79
27. Vortex SA Fan Blades P_s	10.5	10.5	10.5	10.4	10.9
28. SA Depth/Flow (ft/cfm)	6'11"	6'	5'	4'	6'11"
29. % FGR	0	0	0	0	0
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

S. VENT LB/HR 5500 5500 5500 5500 5600
 AT. AIR PRESS. 24.0 24.0 24.0 24.0 24.0

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. _____

Fuel #2 or #6 oil Atom. Type AIR Capacity 17 500 LB/HR

Test Comments _____

	19-37	19-38	19-39	19-40	19-41
1. Test Number	3C 2a	1-13	11-1	12-1	12-2
2. Date	12 JAN 77	13 JAN 77	14 JAN 77	14 JAN 77	14 JAN 77
3. Time	2:50	8:45	11:15	2:45	15:25
4. Load	14,250	14,000	14,100	14,200	14,000
5. Test Purpose	TSC #2 OIL	BASELINE #2 OIL	BASELINE #6 OIL	MED O ₂	H ₁ O ₂
6. Excess O ₂ Condition	LO	NOM	NOM	NOM	H ₁
7. Cont. Room O ₂ (%)	1.7	—	3.4	3.6	5.0
8. Pres. Furn/Windbox (iwg)	0.25 1.2	0.20 1.2	0.25 1.6	0.35 1.8	0.48 2.1
9. Uptake (iwg)	-0.20	-0.24	-0.22	-0.22	-0.22
10. Final Stm Press (psig)	97	98	97	97	98
11. Drum Press (psig)	100	98	97	97	98
12. P. Water P/T (psig/°F)	220 226	215 226	219 226	224 226	225 224
13. Air FD Fan Amps	8.0	8.5	8.4	8.8	9.4
14. Air Temp @ FD Fan/CR (°F)	84	76	80	91	90
15. Stack Temp (°F)	498	499	500	500	512
16. Fuel Flow (CFM or GPM)	2.16	2.14	2.22	2.19	2.13
17. Fuel Pres/Temp (psi/°F)	115 48	119 50	128 194	125 194	119 193
18. Fuel Atom Pres (psig)	28	28	33	33	33
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	C	C	C	C	C
21. AP Pitot FGR Duct (iwg)	—	—	-0.05	—	—
22. AP Orif. FGR Duct (iwg)	—	—	-0.01	—	—
23. Temp. FGR Duct (°F)	—	95	110	—	—
24. Pstat FGR Duct (psig)	—	+0.4	—	—	—
25. Pstat S.A. Fan (psig)	10.9	0	0	0	—
26. Vortex FD Fan Blades	0.79	1.1	1.1	1.2	1.4
27. Vortex SA Fan Blades	—	0	0	0	0
28. SA Depth/Flow (ft/cfm)	6'	+	+	+	+
29. % FGR	0	0	0	0	0
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

ST. VENT LB/HR 5600 5500 5300 6000 5900
 AT AIR PRESS, PSIG 24.0 24.2 26.9 26.8 26.5
 Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. _____

Fuel #6 OIL Atom. Type AIR Capacity 17500 LB/HR

Test Comments _____

	19-42	19-43	19-44	19-45	19-46
1. Test Number	12-3	12-4	11-2	142-1	14A-1a
2. Date	14 JAN 77	14 JAN 77	15 JAN 77	15 JAN 77	15 JAN 77
3. Time	15:50	16:30	08:15	09:10	9:45
4. Load	14,400	14,500	14,200	14,300	14,300
5. Test Purpose	CO	SMOKE	BASLINE PT. II	LO RECIRC	REPEAT PREV AS CHECK
6. Excess O ₂ Condition	LO	LOW	NOM	NOM	NOM
7. Cont. Room O ₂ (%)	0.80	0.70	—	—	—
8. Pres. Furn/Windbox (iwg)	0.25 1.55	0.20 1.65	0.40 1.70	0.70 3.0	0.70 3.0
9. Uptake (iwg)	-0.22	-0.21	-0.21	-0.20	-0.20
10. Final Stm Press (psig)	100	100	99	97	97
11. Drum Press (psig)	98	98	105	99	99
12. F. Water P/T (psig/°F)	222 226	225 226	218 LOW WATER	218 214	218 218
13. Air FD Fan Amps	8.6	8.5	8.8	9.1	9.2
14. Air Temp @ FD Fan/CR (°F)	90	88	90	95	97
15. Stack Temp (°F)	491	492	540	563	563
16. Fuel Flow (CFM or GPM)	2.21	2.22	2.27	2.30	2.27
17. Fuel Pres/Temp (psi/°F)	128 194	129 194	120	195 196	120
18. Fuel Atom Pres (psig)	34	34	33	33	33
19. Primary Reg. Setting	-8	+6	-8	-8	-8
20. FGR Reg. Setting	C	C	C	C	C
21. ΔP Pitot FGR Duct (iwg)	—	—	0.0	+0.20	+0.10
22. ΔP Orif. FGR Duct (iwg)	—	—	-0.02	+0.20	0.195
23. Temp. FGR Duct (°F)	—	—	115	508	511
24. Pstat FGR Duct (psig)	—	—	0.05	5.4	5.4
25. Pstat S.A. Fan (psig)	—	—	—	—	—
26. Vortex FD Fan Blades	0.89	0.86	1.25	1.30	1.30
27. Vortex SA Fan Blades	—	—	—	—	—
28. SA Depth/Flow (ft/cfm)	+	+	+	+	+
29. % FGR	0	0	0	0	0
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

STEAM VENT, LB/HR 5800 6500 5800 4500 4500
 ATOM AIR PRESS, PSIG 26.9 27.0 26.5 26.9 26.9
 DIFFUSER POS. 3" 3" 3" 3 3

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SCTTET

Fuel #6 CIL Atom. Type AIR Capacity 17,500

Test Comments _____

	19-47	19-48	19-49	19-50	19-51
1. Test Number	<u>14B-1</u>	<u>14C-1</u>	<u>14C-2</u>	<u>14A-2</u>	<u>14A-2</u>
2. Date	<u>15 JAN 77</u>	<u>15 JAN 77</u>	<u>15 JAN 77</u>	<u>15 JAN 77</u>	<u>15 JAN 77</u>
3. Time	<u>10:20</u>	<u>10:45</u>	<u>11:10</u>	<u>11:30</u>	<u>11:45</u>
4. Load	<u>14,300</u>	<u>14,300</u>	<u>14,500</u>	<u>14,500</u>	<u>14,400</u>
5. Test Purpose	<u>ME RECIRC</u>	<u>HI RECIRC</u>	<u>HI RECIRC WITH CO</u>	<u>MED. REC. WITH CO</u>	<u>LO RECIRC WITH CO</u>
6. Excess O ₂ Condition	<u>NOM</u>	<u>NOM</u>	<u>LO</u>	<u>LO</u>	<u>LO</u>
7. Cont. Room O ₂ (%)					
8. Pres. Furn/Windbox (iwg)	<u>0.8</u> <u>3.3</u>	<u>0.9</u> <u>3.3</u>	<u>0.75</u> <u>3.3</u>	<u>0.62</u> <u>2.8</u>	<u>0.5</u> <u></u>
9. Uptake (iwg)	<u>-0.20</u>	<u>-0.20</u>	<u>-0.20</u>	<u>-0.22</u>	<u>-0.22</u>
10. Final Stm Press (psig)	<u>98</u>	<u>99</u>	<u>99</u>	<u>99</u>	<u>98</u>
11. Drum Press (psig)	<u>100</u>	<u>100</u>	<u>99</u>	<u>99</u>	<u>100</u>
12. F. Water P/T (psig/°F)	<u>217</u> <u>224</u>	<u>217</u> <u></u>	<u>220</u> <u>224</u>	<u>218</u> <u>224</u>	<u>215</u> <u>224</u>
13. Air FD Fan Amps	<u>9.2</u>	<u>9.4</u>	<u>8.8</u>	<u>8.8</u>	<u>8.9</u>
14. Air Temp @ FD Fan/CR (°F)	<u>97</u>	<u>97</u>	<u>98</u>	<u>97</u>	<u>99</u>
15. Stack Temp (°F)	<u>568</u>	<u>571</u>	<u>562</u>	<u>557</u>	<u>550</u>
16. Fuel Flow (CFM or GPM)	<u>2.24</u>	<u>2.26</u>	<u>2.31</u>	<u>2.26</u>	<u>2.30</u>
17. Fuel Pres/Temp (psi/°F)	<u>120</u> <u>196</u>	<u>121</u> <u>196</u>	<u>120</u> <u>196</u>	<u>121</u> <u>196</u>	<u>120</u> <u>196</u>
18. Fuel Atom Pres (psig)	<u>33</u>	<u>33</u>	<u>33</u>	<u>33</u>	<u>33</u>
19. Primary Reg. Setting	<u>-8</u>	<u>-8</u>	<u>-8</u>	<u>-8</u>	<u>-8</u>
20. FGR Reg. Setting, IN. FACE TO HANDLE	<u>2 7/8</u>	<u>3/4</u> <u>MAX</u>	<u>3/4</u> <u>MAX</u>	<u>3</u>	<u>3</u>
21. ΔP Pitot FGR Duct (iwg)	<u>0.1</u>	<u>0.2-0.6 RAPID</u>	<u>0.1</u>	<u>0.07</u>	<u>0.03</u>
22. ΔP Orif. FGR Duct (iwg)	<u>0.40</u>	<u>0.74</u>	<u>0.82</u>	<u>0.36</u>	<u>0.18</u>
23. Temp. FGR Duct (°F)	<u>547</u>	<u>540</u>	<u>535</u>	<u>515</u>	<u>500</u>
24. Pstat FGR Duct (psig)	<u>5.0</u>	<u>4.5</u>	<u>4.4</u>	<u>5.1</u>	<u>5.5</u>
25. Pstat S.A. Fan (psig)	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
26. Vortex FD Fan Blades	<u>—</u>	<u>1.4</u>	<u>1.05</u>	<u>1.05</u>	<u>1.03</u>
27. Vortex SA Fan Blades	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
28. SA Depth/Flow (ft/cfm)	<u>+</u>	<u>+</u>	<u>+</u>	<u>+</u>	<u>+</u>
29. % FGR	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>
30. Total Oil Burned #2/#6	<u>+</u>	<u>+</u>	<u>+</u>	<u>+</u>	<u>+</u>
31. Total Gas Burned	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>

STEAM VENT RATE, LB/HR 6000 6100 7000 6500 6100
 ATOM. AIR PRESS, PSIG 26.9 26.9 27.0 27.0 27.0
 DIFFUSER POS. 3" 3" 3" 3 3

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTFR
 Fuel #2 Atom. Type AIR Capacity 17,500 LB/HR
 Test Comments _____

	19-52	19-53	19-54	19-55	19-56
1. Test Number	0-2	1-14	5A10	5A10	561a
2. Date	17 JAN 77	17 JAN 77	17 JAN 77	17 JAN 77	17 JAN 77
3. Time	11:30	14:10	15:00	15:15	15:30
4. Load	10,000	14,500	14,200	14,200	14,200
5. Test Purpose	EXTRA-FOR LOW AIR FLOW	#2 BASELINE	#2 $\phi=1.2$ LOW RECIRC		
6. Excess O ₂ Condition	NOM	NOM	NOM	NOM	NOM
7. Cont. Room O ₂ (%)	4.2	3.8	3.0	3.0	2.8
8. Pres.Furn/Windbox(iwg)	0.0 1.0	0.32 1.7	0.50 2.2	0.50 2.2	0.50 2.3
9. Uptake (iwg)	-0.25	-0.23	-0.23	-0.23	-0.23
10. Final Stm Press (psig)	100	99	99	99	99
11. Drum Press (psig)	99	93	98	100	95
12. F. Water P/T (psig/°F)	225 220	223 222	223 222	223 222	223 222
13. Air FD Fan Amps	7.4	8.1	7.6	7.6	7.8
14. Air Temp @ FD Fan/CR(°F)	77	76	85	84	84
15. Stack Temp (°F)	481	518	551	550	550
16. Fuel Flow (CFM or GPM)	1.76	2.07	2.09	2.07	2.15
17. Fuel Pres/Temp (psi/°F)	114 52	113 52	114 54	114 54	114 54
18. Fuel Atom Pres (psig)	23	28	28	28	28
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	C	C	3.4	3.4	3.4
21. ΔP Pitot FGR Duct(iwg)	—	—	0.115	0.115	0.113
22. ΔP Orif. FGR Duct(iwg)	—	—	0.20	0.19	0.19
23. Temp. FGR Duct (°F)	93	97	500	500	500
24. Pstat FGR Duct (psig)	+0.25	0.0	5.3	5.3	5.3
25. Pstat S.A. Fan (psig)	—	—	2.9	3.1	3.3
26. Vortex FD Fan Blades	0.77	1.22	0.68	0.68	0.68
27. Vortex SA Fan Blades	—	—	10.6	10.6	10.6
28. SA Depth/Flow (ft/cfm)	+	+	4	6	6'11"
29. % FGR	0	0			
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

STEAM VENT RATE, LB/HR

5300

4900

4900

4900

Data Sheet 6003-16

ATOM AIR PRESS, PSIG

21.0

24.0

24.0

24.0

24.0

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. _____

Fuel #2 OIL Atom. Type AIR Capacity 17,500 LB/HR

Test Comments P_{STAT} ON FGR DUCT FLUCTUATES $\pm \frac{1}{2}$ IN.

	19-57	19-58	19-59	19-60	19-61
1. Test Number	511a	511a	511a	511a	5A2b
2. Date	17 JAN 77	17 JAN 77	17 JAN 77	17 JAN 77	18 JAN 77
3. Time	15:55	16:05	16:15	16:30	10:15
4. Load	14,000	14,200	14,100	14,500	14,000
5. Test Purpose	MAX RECIRC $\phi=1.2$			LOW RECIRC (12%) $\phi=1.35$	13% FGR $\phi=1.35$
6. Excess O ₂ Condition	NOM	NOM	NOM	NOM	LO (CO)
7. Cont. Room O ₂ (%)	3.0	2.8	3.0	3.0	1.5
8. Pres.Furn/Windbox(iwg)	0.80 3.0	0.79 3.0	0.79 3.0	0.55 2.3	0.50 2.2
9. Uptake (iwg)	-0.20	-0.20	-0.21	-0.22	-0.22
10. Final Stm Press (psig)	99	99	100	100	95
11. Drum Press (psig)	97	97	98	98	96
12. F. Water P/T (psig/°F)	223 222	223 222	224 224	224 224	210 222
13. Air FD Fan Amps	8.0	8.0	8.0	7.9	8.0
14. Air Temp @ FD Fan/CR(°F)	83	84	86	87	82
15. Stack Temp (°F)	563	563	568	555	541
16. Fuel Flow (CFM or GPM)	2.09	2.15	2.10	2.17	2.22
17. Fuel Pres/Temp (psi/°F)	114 54	114 55	114 54	114 54	116 54
18. Fuel Atom Pres (psig)	28	28	28	28	29
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	MAX	MAX	MAX	3.4	3.4
21. ΔP Pitot FGR Duct(iwg)	0.24	0.24	0.24	0.110	0.09
22. ΔP Orif. FGR Duct(iwg)	0.78	0.78	0.78	0.17	0.18
23. Temp. FGR Duct (°F)	535	535	540	505	485
24. Pstat FGR Duct (psig)	4.0	3.9	3.4	4.4	4.3
25. Pstat S.A. Fan (psig)	3.4	3.3	3.1	2.9	2.7
26. Vortex FD Fan Blades	0.76	0.76	0.76	0.71	0.70
27. Vortex SA Fan Blades	10.6	10.6	10.6	10.6	10.8
28. SA Depth/Flow (ft/cfm)	6'11"	6'	4'	4'	4'
29. % FGR					
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

4900 5000 5000 4900 6000
24.0 24.0 24.0 24.0 24.9
Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTER

Fuel #2 OIL Atom. Type AIR (LOW-PRESS) Capacity 17,500 LB/HR

Test Comments _____

	19-62	19-63	19-64	19-65	19-66
1. Test Number	5626	5726	5626	5626	5126
2. Date	18 JAN 77				
3. Time	10:35	10:55	11:10	11:30	11:45
4. Load	14,000	14,100	14,100	14,500	
5. Test Purpose	15% FGR $\phi=1.35$	MAX FGR $\phi=1.35$		MAX FGR $\phi=1.5$	MAX FGR $\phi=1.5$
6. Excess O ₂ Condition	LO (CO)	LO (CO)	LO (CO)	LO (CO)	LO (CO)
7. Cont. Room O ₂ (%)	1.4	1.7	1.5	1.9	1.9
8. Pres.Furn/Windbox(iwg)	0.50 2.2	0.78 3.0	0.80 3.0	0.80 3.0	0.80 3.0
9. Uptake (iwg)	-0.22	-0.21	-0.21	-0.21	-0.20
10. Final Stm Press (psig)	94	94	94	94	94
11. Drum Press (psig)	95	95	95	95	94
12. F. Water P/T (psig/°F)	212 222	210 222	210 222	215 222	215 222
13. Air FD Fan Amps	8.0	8.4	8.4	8.0	8.3
14. Air Temp @ FD Fan/CR (°F)	82	82	85	89	87
15. Stack Temp (°F)	542	559	560	560	560
16. Fuel Flow (CFM or GPM)	2.29	2.21	2.29	2.19	2.21
17. Fuel Pres/Temp (psi/°F)	116 54	116 55	116 54	116 55	117 55
18. Fuel Atom Pres (psig)	29	29	29	29	29
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	3.4	MAX	MAX	MAX	MAX
21. ΔP Pitot FGR Duct(iwg)	0.09	0.20	0.20	0.20	0.20
22. ΔP Orif. FGR Duct(iwg)	0.18	0.79	0.79	0.80	0.80
23. Temp. FGR Duct (°F)	490	529	532	533	535
24. Pstat FGR Duct (psig)	3.9	4.2	4.2	4.2	4.3
25. Pstat S.A. Fan (psig)	3.2	3.2	2.9	4.6	5.1
26. Vortex FD Fan Blades	0.69	0.79	0.79	0.66	0.66
27. Vortex SA Fan Blades	10.8	10.75	10.7	10.4	10.4
28. SA Depth/Flow (ft/cfm)	7'	7'	4'	4'	7'
29. % FGR					
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

6300 5700 5700 5700 5700
24.9 24.9 25.0 25.0
Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SCOTTER

Fuel #2 + #6 Atom. Type AIR Capacity 17,500 LB/HR

Test Comments _____

	#2 OIL 19-69		19-68		#6 OIL → 19-69		19-70		19-71	
1. Test Number	562C		542E		443		13816		13816	
2. Date	18 JAN 77		→		→		→		→	
3. Time	12:05		12:20		14:05		15:30		15:55	
4. Load	14,500		14,600		14,500		14,500		14,500	
5. Test Purpose	15% RECIRC. φ=1.5		→		#6 BASELINE		#6 STAGED φ=1.3		→	
6. Excess O ₂ Condition	LO (CO)		LO		NOM		NOM		NOM	
7. Cont. Room O ₂ (%)	1.7		1.7		2.4		3.0		2.9	
8. Pres. Furn/Windbox (iwg)	0.60	2.3	0.60	2.3	0.48	1.9	0.5	1.4	0.48	1.4
9. Uptake (iwg)	-0.21		-0.21		-0.18		-0.18		-0.18	
10. Final Stm Press (psig)	94		94		95		96		97	
11. Drum Press (psig)	94		94		97		97		97	
12. F. Water P/T (psig/°F)	214	222	215	222	216	220	214	222	215	222
13. Air FD Fan Amps	8.4		8.4		9.0		8.5		8.5	
14. Air Temp @ FD Fan/CR (°F)	89		91		87		96		96	
15. Stack Temp (°F)	548		550		515		510		515	
16. Fuel Flow (CFM or GPM)	2.22		2.21		2.29		2.27		2.29	
17. Fuel Pres/Temp (psi/°F)	117	56	117	56	133	194	133	196	134	196
18. Fuel Atom Pres (psig)	30		30		34		34		34	
19. Primary Reg. Setting	-8		-8		-8		-8		-8	
20. FGR Reg. Setting	3.4		3.4		C		C		C	
21. ΔP Pitot FGR Duct (iwg)	0.10		0.098		—		—		—	
22. ΔP Orif. FGR Duct (iwg)	0.18		0.18		—		—		—	
23. Temp. FGR Duct (°F)	500		500		—		135		—	
24. Pstat FGR Duct (psig)	5.4		5.4		—		—		—	
25. Pstat S.A. Fan (psig)	4.2		4.0		—		5.0		5.4	
26. Vortex FD Fan Blades	0.65		—		1.3		0.68		—	
27. Vortex SA Fan Blades	10.5		10.5		—		10.1		10.1	
28. SA Depth/Flow (ft/cfm)	7'		4'		+		4'		5'	
29. % FGR	—		—		0		0		0	
30. Total Oil Burned #2/#6	+		+		+		+		+	
31. Total Gas Burned	0		0		0		0		0	

STEAM VENT RATE, LB/HR 5500 5800 6000 5700 6500
 ATOM. AIR PRESS., PSIG 25.0 25.0 27.1 27.1 27.1
 Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOFFER
 Fuel #6 & #2 Atom. Type AIR Capacity 17,500

Test Comments _____

	#6 OIL 19-72	#2 OIL 19-73	19-74	19-75	19-76
1. Test Number	3016	1-15	2-2 F	2-2 P	2-2 I
2. Date	18 JAN 77	19 JAN 77			
3. Time	16:05	9:10	11:00	12:20	14:40
4. Load	14,000	14,500	14,300	14,300	14,300
5. Test Purpose	#6 OIL Φ=1.3	#2 BASELINE	LOW O ₂ PARTIC.		LOW O ₂ IMPACTOR
6. Excess O ₂ Condition	NOM	NOM	LO		
7. Cont. Room O ₂ (%)	3.0	3.0	1.0	1.0	1.1
8. Pres.Furn/Windbox(iwg)	0.48 2.0	0.38 1.7	0.28 1.4	0.30 1.4	0.35 1.5
9. Uptake (iwg)	0.198	-0.20	-0.22	-0.22	-0.22
10. Final Stm Press (psig)	97	98	96	97	97
11. Drum Press (psig)	97	100	98	97	97
12. F. Water P/T (psig/°F)	215 222	208 222	210 224	215 222	217 222
13. Air FD Fan Amps	8.5	8.7	8.3	8.7	8.6
14. Air Temp @ FD Fan/CR (°F)	91	74	80	84	88
15. Stack Temp (°F)	520	515	510	513	521
16. Fuel Flow (CFM or GPM)	2.26	2.22	2.22	2.23	2.25
17. Fuel Pres/Temp (psi/°F)	134 196	117 54	119 45	119 45	120 48
18. Fuel Atom Pres (psig)	34	29	29	29	29
19. Primary Reg. Setting	+5	-8	-8	-8	-8
20. FGR Reg. Setting	-	C	C	C	C
21. ΔP Pitot FGR Duct(iwg)	—	—	—	—	—
22. ΔP Orif. FGR Duct(iwg)	—	—	—	—	—
23. Temp. FGR Duct (°F)	—	100	—	—	—
24. Pstat FGR Duct (psig)	—	—	—	—	—
25. Pstat S.A. Fan (psig)	5.4	—	—	—	—
26. Vortex FD Fan Blades	0.71	1.28	0.99	1.05	1.03
27. Vortex SA Fan Blades	10.1	—	—	—	—
28. SA Depth/Flow (ft/cfm)	6'	+	+	+	+
29. % FGR	0	0	0	0	0
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

STEAM VENT RATE, LB/HR 5800 6000 5700 6500 7100
 ATOM. AIR PRESS., PSIG 27.1 24.5 24.1 24.1
 DIFFUSER POS, IN. 4.25 3.0 3.0 3.0

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTERFuel #2 OIL Atom. Type AIR Capacity 17,500 LB/HR

Test Comments _____

	19-77	19-78	19-79	19-80	19-81
1. Test Number	1-6	3A26	3B26	3C26	3E26
2. Date	20 JAN 76	20 JAN 76			
3. Time	07:45	08:30	08:50	09:15	9:55
4. Load	14,000	14,300	14,300	14,300	14,200
5. Test Purpose	#2 BASELINE	$\phi=1.35$ LO O ₂ WITH CO			
6. Excess O ₂ Condition	NOM	LO	LO	LO	LO
7. Cont. Room O ₂ (%)	3.0	1.9	1.9	1.9	1.8
8. Pres. Furn/Windbox (iwg)	0.45 1.7	0.38 1.2	0.38 1.2	0.40 1.25	0.40 1.25
9. Uptake (iwg)	-0.20	-0.20	-0.21	-0.19	-0.20
10. Final Stm Press (psig)	98	97	97	97	98
11. Drum Press (psig)	102	99	100	100	99
12. F. Water P/T (psig/°F)	217 222	213	213 STEAM	215 222	218 222
13. Air FD Fan Amps	8.9	8.1	8.1	8.1	8.2
14. Air Temp @ FD Fan/CR (°F)	87	94	90	90	90
15. Stack Temp (°F)	510	513	511	511	514
16. Fuel Flow (CFM or GPM)	2.14	2.19	2.19	2.21	2.14
17. Fuel Pres/Temp (psi/°F)	117 52	116 51	116 51	116 51	116 52
18. Fuel Atom Pres (psig)	29	29	29	29	29
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	C	C	C	C	C
21. AP Pitot FGR Duct (iwg)	—	—	—	—	—
22. AP Orif. FGR Duct (iwg)	—	—	—	—	—
23. Temp. FGR Duct (°F)	—	—	—	—	—
24. Pstat FGR Duct (psig)	—	—	—	—	—
25. Pstat S.A. Fan (psig)	0	2.5	2.6	2.6	3.0
26. Vortex FD Fan Blades	1.28	0.74	0.74	0.74	0.74
27. Vortex SA Fan Blades	0	10.5	10.5	10.5	10.5
28. SA Depth/Flow (ft/cfm)	+	4	5	5	6
29. % FGR	0	0	0	0	0
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

7000
24.0
3"7000
24.1
37000
24.1
37900
24.1
38000
24.1
3
Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTERFuel #2 OIL Atom. Type AIR Capacity 17,500 LB/HRTest Comments $\Phi = 1.3$ NOT ACHIEVED BECAUSE OF SMOKING AT LOW SECONDARY AIR

	19-82	19-83	19-84	19-85	19-86
1. Test Number	3026	402P	4021	→	3A1b
2. Date	20 JAN 76	→	→	→	21 JAN 76
3. Time	10:05	13:55	15:30	17:00	10:35
4. Load	14,160	14,500	14,600	14,600	13,600
5. Test Purpose	$\Phi = 1.3$ #2 OIL LOW O ₂	V TRAVERSE	H ₁ RECIRC LO O ₂ IMPACTOR	→	REPEAT 19-83 AS BASELINE
6. Excess O ₂ Condition	1.6	LO	LO	LO	NOM
7. Cont. Room O ₂ (%)	1.6	0.7	0.5	—	2.3
8. Pres. Furn/Windbox (iwg)	0.45 1.65	0.80 3.2	0.86 3.2	0.85 3.3	0.38 1.1
9. Uptake (iwg)	-0.18	-0.18	-0.18	-0.18	-0.20
10. Final Stm Press (psig)	98	97	98	98	98
11. Drum Press (psig)	98	97	98	98	98
12. F. Water P/T (psig/°F)	216 222	220 222	220 222	219 222	219 222
13. Air FD Fan Amps	8.0	9.0	9.4	9.4	7.9
14. Air Temp @ FD Fan/ ^{2nd} FAN/ER (°F)	90	95	100 79	93	88 76
15. Stack Temp (°F)	514	581	582	583	492
16. Fuel Flow (CFM/ex GPM)	2.17	2.18	2.24	2.24	2.11
17. Fuel Pres/Temp (psi/°F)	116 51	116 54	116 55	116 54	110 54
18. Fuel Atom Pres (psig)	29	29	29	30	28
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	C	FULL OPEN	C	C	C
21. ΔP Pitot FGR Duct (iwg)	—	—	—	—	—
22. ΔP Orif. FGR Duct (iwg)	—	0.80	0.80	0.80	—
23. Temp. FGR Duct (°F)	—	550	552	555	—
24. Pstat FGR Duct (psig)	—	3.9	2.7	4.1	—
25. Pstat S.A. Fan (psig)	3.0	—	—	—	4.9
26. Vortex FD Fan Blades	0.74	1.10	1.10	1.15	0.56
27. Vortex SA Fan Blades	10.5	—	—	—	—
28. SA Depth/Flow (ft/cfm)	7'	+	+	+	4'
29. % FGR	0	MAX	MAX	MAX	0
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

8000 7000 7300 7500 6500
 24.1 24.1 24.2 25.0 24.0
 3 3 3 3

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTERFuel #2 OIL Atom. Type AIR Capacity 17,500 LBS/LR

Test Comments _____

	19-87	19-88	19-89	19-90	19-91
1. Test Number	<u>3A2C</u>	<u>3A2C</u>	<u>3B2C</u>	<u>3C2C</u>	<u>3D2C</u>
2. Date	<u>21 JAN 76</u>	<u>21 JAN 76</u>	<u>21 JAN 76</u>	<u>→</u>	<u>→</u>
3. Time	<u>11:30</u>	<u>13:45</u>	<u>14:00</u>	<u>14:20</u>	<u>14:35</u>
4. Load	<u>14,200</u>	<u>14,200</u>	<u>14,200</u>	<u>14,200</u>	<u>14,200</u>
5. Test Purpose	<u>SHAKE, TSC</u>	<u>SHAKING 2" AIR</u>	<u>→</u>	<u>→</u>	<u>→</u>
6. Excess O ₂ Condition	<u>L0</u>	<u>L0</u>	<u>L0</u>	<u>L0</u>	<u>L0</u>
7. Cont. Room O ₂ (%)	<u>1.9</u>	<u>2.1</u>	<u>2.0</u>	<u>2.0</u>	<u>2.1</u>
8. Pres. Furn/Windbox (iwg)	<u>0.38</u> <u>1.1</u>	<u>0.40</u> <u>1.05</u>	<u>0.39</u> <u>1.1</u>	<u>0.39</u> <u>1.1</u>	<u>0.39</u> <u>1.1</u>
9. Uptake (iwg)	<u>-0.20</u>	<u>-0.20</u>	<u>-0.20</u>	<u>-0.20</u>	<u>-0.20</u>
10. Final Stm Press (psig)	<u>98</u>	<u>98</u>	<u>98</u>	<u>98</u>	<u>98</u>
11. Drum Press (psig)	<u>98</u>	<u>98</u>	<u>98</u>	<u>98</u>	<u>98</u>
12. F. Water P/T (psig/°F)	<u>221</u> <u>222</u>	<u>221</u> <u>222</u>	<u>220</u> <u>222</u>	<u>220</u> <u>222</u>	<u>220</u> <u>222</u>
13. Air FD Fan Amps	<u>8.0</u>	<u>8.0</u>	<u>7.9</u>	<u>7.8</u>	<u>8.0</u>
14. Air Temp @ FD Fan/CR (°F)	<u>91</u>	<u>94</u>	<u>91</u>	<u>88</u>	<u>89</u>
15. Stack Temp (°F)	<u>498</u>	<u>498</u>	<u>499</u>	<u>502</u>	<u>500</u>
16. Fuel Flow (CFM or GPM)	<u>2.16</u>	<u>2.15</u>	<u>2.18</u>	<u>2.14</u>	<u>2.17</u>
17. Fuel Pres/Temp (psi/°F)	<u>110</u> <u>54</u>	<u>110</u> <u>55</u>	<u>110</u> <u>55</u>	<u>110</u> <u>54</u>	<u>110</u> <u>55</u>
18. Fuel Atom Pres (psig)	<u>28</u>	<u>28</u>	<u>28</u>	<u>28</u>	<u>28</u>
19. Primary Reg. Setting	<u>-8</u>	<u>-8</u>	<u>-8</u>	<u>-8</u>	<u>-8</u>
20. FGR Reg. Setting	<u>C</u>	<u>C</u>	<u>C</u>	<u>C</u>	<u>C</u>
21. ΔP Pitot FGR Duct (iwg)	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
22. ΔP Orif. FGR Duct (iwg)	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
23. Temp. FGR Duct (°F)	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
24. Pstat FGR Duct (psig)	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>
25. Pstat S.A. Fan (psig)	<u>5.0</u>	<u>5.0</u>	<u>5.2</u>	<u>5.5</u>	<u>5.8</u>
26. Vortex FD Fan Blades	<u>0.56</u>	<u>0.58</u>	<u>0.58</u>	<u>0.58</u>	<u>0.58</u>
27. Vortex SA Fan Blades	<u>10.1</u>	<u>10.1</u>	<u>10.3</u>	<u>10.3</u>	<u>10.3</u>
28. SA Depth/Flow (ft/cfm)	<u>4'</u> <u>RADIAL</u>	<u>4'</u> <u>CO-SWIRL</u>	<u>5'</u> <u>CO-SWIRL</u>	<u>6'</u>	<u>6'11"</u>
29. % FGR	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>
30. Total Oil Burned #2/#6	<u>+</u>	<u>+</u>	<u>+</u>	<u>+</u>	<u>+</u>
31. Total Gas Burned	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>

6700 7300 7400 7300 7300
 24.0 24.0 24.0 24.0 24.0
 3" 3" 3 3 3
 Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTERFuel # 2 OIL Atom. Type AIR Capacity 17,500

Test Comments _____

	19-92	19-93	19-94	19-95	
1. Test Number	<u>3A26</u>	<u>3B26</u>	<u>3C26</u>	<u>3D26</u>	
2. Date	<u>21 JAN 76</u>	<u>→</u>	<u>→</u>	<u>→</u>	
3. Time	<u>15:00</u>	<u>15:10</u>	<u>15:30</u>	<u>15:45</u>	
4. Load	<u>14,200</u>	<u>14,200</u>	<u>14,200</u>	<u>14,200</u>	
5. Test Purpose	<u>SMOKE, TSC #2 $\phi=1.2$</u>	<u>→</u>	<u>→</u>	<u>→</u>	
6. Excess O ₂ Condition	<u>LO</u>	<u>LO</u>	<u>LO</u>	<u>LO</u>	
7. Cont. Room O ₂ (%)	<u>1.6</u>	<u>1.4</u>	<u>1.0</u>	<u>0.8</u>	
8. Pres.Furn/Windbox(iwg)	<u>0.33</u> <u>1.1</u>	<u>0.33</u> <u>1.1</u>	<u>0.33</u> <u>1.1</u>	<u>0.33</u> <u>1.1</u>	
9. Uptake (iwg)	<u>-0.21</u>	<u>-0.21</u>	<u>-0.21</u>	<u>-0.21</u>	
10. Final Stm Press (psig)	<u>98</u>	<u>98</u>	<u>98</u>	<u>98</u>	
11. Drum Press (psig)	<u>98</u>	<u>98</u>	<u>98</u>	<u>98</u>	
12. F. Water P/T (psig/°F)	<u>221</u> <u>222</u>	<u>220</u> <u>222</u>	<u>220</u> <u>222</u>	<u>220</u> <u>222</u>	
13. Air FD Fan Amps	<u>8.1</u>	<u>8.2</u>	<u>8.4</u>	<u>8.4</u>	
14. Air Temp @ FD Fan/CR (°F)	<u>91</u>	<u>92</u>	<u>90</u>	<u>88</u>	
15. Stack Temp (°F)	<u>505</u>	<u>504</u>	<u>506</u>	<u>506</u>	
16. Fuel Flow (CFMor GPM)	<u>2.11</u>	<u>2.17</u>	<u>2.20</u>	<u>2.17</u>	
17. Fuel Pres/Temp (psi/°F)	<u>110</u> <u>55</u>	<u>110</u> <u>55</u>	<u>110</u> <u>55</u>	<u>110</u> <u>55</u>	
18. Fuel Atom Pres (psig)	<u>28</u>	<u>28</u>	<u>28</u>	<u>28</u>	
19. Primary Reg. Setting	<u>-8</u>	<u>-8</u>	<u>-8</u>	<u>-8</u>	
20. FGR Reg. Setting	<u>C</u>	<u>C</u>	<u>C</u>	<u>C</u>	
21. ΔP Pitot FGR Duct(iwg)	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	
22. ΔP Orif. FGR Duct(iwg)	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	
23. Temp. FGR Duct (°F)	<u>—</u>	<u>125</u>	<u>—</u>	<u>—</u>	
24. Pstat FGR Duct (psig)	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>	
25. Pstat S.A. Fan (psig)	<u>2.6</u>	<u>2.6</u>	<u>2.9</u>	<u>2.9</u>	
26. Vortex FD Fan Blades	<u>0.67</u>	<u>0.66</u>	<u>0.66</u>	<u>0.67</u>	
27. Vortex SA Fan Blades	<u>10.8</u>	<u>10.7</u>	<u>10.8</u>	<u>10.8</u>	
28. SA Depth/Flow (ft/cfm)	<u>4</u>	<u>5</u>	<u>6</u>	<u>6"11"</u>	
29. % FGR	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	
30. Total Oil Burned #2/#6	<u>+</u>	<u>+</u>	<u>+</u>	<u>+</u>	
31. Total Gas Burned	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	

7300

24.0

3"

7300

24.0

3"

7300

24.0

3"

7300

24.0

3"

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTERFuel #2 + #6 OIL Atom. Type AIR Capacity 17,500 LB/HR

Test Comments _____

	19-96	19-97	19-98	19-99	10-100
1. Test Number	1-16	11-47	11-47	11-45	1-17
2. Date	21 JAN 76	→	→	→	25 JAN 76
3. Time	08:15	10:30	11:40	14:30	08:25
4. Load	14,200	13,800	14,800	14,000	13,700
5. Test Purpose	#2 BASELINE	#6 FUEL LINE PARTIC.	→	→	#2 BASELINE
6. Excess O ₂ Condition	NOM	NOM	NOM	NOM	NOM
7. Cont. Room O ₂ (%)	2.8	2.6	2.7	2.5	—
8. Pres. Furn/Windbox (iwg)	0.40 1.7	0.35 1.6	0.35 1.6	0.38 1.6	0.40 1.7
9. Uptake (iwg)	-0.22	-0.22	-0.22	-0.22	-0.22
10. Final Stm Press (psig)	97	98	98	97	97
11. Drum Press (psig)	98	98	98	98	97
12. F. Water P/T (psig/°F)	210 222	215 222	222 222	216 212	200
13. Air FD Fan Amps	8.2	8.7	8.8	8.8	8.9
14. Air Temp @ FD Fan/CR (°F)	81	85	88	92	85
15. Stack Temp (°F)	520	511	513	517	513
16. Fuel Flow (CFM ex GPM)	2.26	2.22	2.22	2.21	—
17. Fuel Pres/Temp (psi/°F)	118 50	130 192	130 194	129 194	110 54
18. Fuel Atom Pres (psig)	29	32	32	32	27
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	C	C	C	C	C
21. ΔP Pitot FGR Duct (iwg)	—	—	—	—	—
22. ΔP Orif. FGR Duct (iwg)	—	—	—	—	—
23. Temp. FGR Duct (°F)	—	—	—	—	—
24. Pstat FGR Duct (psig)	—	—	—	—	—
25. Pstat S.A. Fan (psig)	—	—	—	—	—
26. Vortex FD Fan Blades	1.3	1.15	1.20	1.20	1.25
27. Vortex SA Fan Blades	—	—	—	—	—
28. SA Depth/Flow (ft/cfm)	+	+	+	+	+
29. % FGR	0	0	0	0	0
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0
	7000	7500	7100	7000	7500
	24.5	26.5	26.2	26.2	22.9
	3"	3"	3	3	3

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTER

Fuel # 2 Atom. Type AIR Capacity 17,500

Test Comments _____

	19-101	19-102	19-103	19-104	19-105
1. Test Number	5A16	5B16	5H16	5B16	5C16
2. Date	25 JAN 76				
3. Time	10:00	10:15	10:35	10:50	11:20
4. Load	14,200	14,200	14,200	14,400	14,500
5. Test Purpose	LO RECIRC $\phi=1.35$		MED RECIRC $\phi=1.35$		MAX RECIRC $\phi=1.35$
6. Excess O ₂ Condition	NOM	NOM	NOM	NOM	NOM
7. Cont. Room O ₂ (%)	2.9	2.8	2.9	2.8	2.7
8. Pres.Furn/Windbox(iwg)	0.52 1.6	0.52 1.6	0.70 2.3	0.70 2.3	0.92 3.1
9. Uptake (iwg)	-0.20	-0.20	-0.20	-0.20	-0.18
10. Final Stm Press (psig)	97	97	96	97	98
11. Drum Press (psig)	99	98	98	98	98
12. F. Water P/T (psig/°F)	218 222	217 222	217 222	215 222	222 222
13. Air FD Fan Amps	8.4	8.0	8.3	8.3	8.6
14. Air Temp @ FD Fan/CR(°F)	100	94	94	99	103
15. Stack Temp (°F)	523	518	549	549	560
16. Fuel Flow (CFM or GPM)	2.28	2.21	2.23	2.28	2.29
17. Fuel Pres/Temp (psi/°F)	110 55	110 56	110 56	110 56	110 56
18. Fuel Atom Pres (psig)	28	28	28	28	28
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting		C	3.4	3.4	MAX
21. ΔP Pitot FGR Duct(iwg)	0.009	—	0.080	0.075	0.18
22. ΔP Orif. FGR Duct(iwg)	0.055	0.055	0.20	0.20	0.80
23. Temp. FGR Duct (°F)	403	406	500	503	540
24. Pstat FGR Duct (psig)	6.1	6.1	5.9	5.4	4.2
25. Pstat S.A. Fan (psig)	5.2	5.9	5.5	5.4	5.3
26. Vortex FD Fan Blades	0.71	0.71	0.71	0.71	0.75
27. Vortex SA Fan Blades	10.1	10.1	10.1	10.1	10.2
28. SA Depth/Flow (ft/cfm)	4	7	7	4'	4
29. % FGR					
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

7000 7000 6500 6500 7100
23-1 23-2 23.4
3" 3" 3 3
Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTFRFuel _____ Atom. Type AIR Capacity 17,500

Test Comments _____

	#2 OIL 19-106	#6 OIL 19-107	19-108	19-109	19-110
1. Test Number		13A1A	13B1A	13C1A	13D1A
2. Date	25 JAN 76				
3. Time	11:35	13:25	13:35	13:50	14:00
4. Load	14500	14500	14500	14500	14500
5. Test Purpose	H ₂ REC'D $\phi=1.35$	$\phi=1.2$			
6. Excess O ₂ Condition	NOM	NOM	NOM	NOM	NOM
7. Cont. Room O ₂ (%)	2.4	2.5	2.5	2.2	2.2
8. Pres. Furn/Windbox (iwg)	0.90 3.1	0.45 1.4	0.47 1.4	0.47 1.4	0.96 1.4
9. Uptake (iwg)	-0.18	-0.18	-0.18	-0.18	-0.18
10. Final Stm Press (psig)	98	98	98	98	98
11. Drum Press (psig)	98	98	98	99	98
12. F. Water P/T (psig/°F)	222 222	222 222	222 222	222 222	222 222
13. Air FD Fan Amps	8.6	8.3	8.3	8.3	8.4
14. Air Temp @ FD Fan/CR (°F)	100	97	94	91	89
15. Stack Temp (°F)	560	507	508	506	504
16. Fuel Flow (CFM or GPM)	—	2.26	2.33	2.29	—
17. Fuel Pres/Temp (psi/°F)	110 56	130 194	129 194	129 194	129 194
18. Fuel Atom Pres (psig)	28	32	32	32	32
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	FULL OPEN	OFF + CLOSED	OFF	OFF	OFF
21. ΔP Pitot FGR Duct (iwg)	0.18	0.00	0.00	—	—
22. ΔP Orif. FGR Duct (iwg)	0.80	0.34	0.00	—	—
23. Temp. FGR Duct (°F)	540	144	138	135	135
24. Pstat FGR Duct (psig)	4.1	~0.05	RE-ZERO 0.00	—	—
25. Pstat S.A. Fan (psig)	5.8	2.8	3.0	3.1	3.2
26. Vortex FD Fan Blades	0.75	0.86	0.86	0.86	0.88 ^{RE-ZERO}
27. Vortex SA Fan Blades	10.1	10.5	10.5	10.5	10.6
28. SA Depth/Flow (ft/cfm)	7	4	5	6	6'11"
29. % FGR		0	0	0	0
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

7200 7000 7100 7400 7400
 23.5 26.0 26.0 26.0 26.0
 3" 3 3 3 3

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTER
 Fuel #6 Atom. Type AIR Capacity 17,500 LB/HR
 Test Comments _____

	19-111	19-112	19-113	19-114	19-115
1. Test Number	3A2C	3D2C	3A2B		
2. Date	25 JAN 76				26 JAN 76
3. Time	14:20	14:30	15:00	15:10	09:00
4. Load	14,500	14,500	14,500	14,500	14,100
5. Test Purpose	750 $\phi=1.5$ STROKE, CO		$\phi=1.3$ STROKE, CO		#2 BASELINE
6. Excess O ₂ Condition	L0	L0	L0	L0	NOM
7. Cont. Room O ₂ (%)	2.1	2.0	1.0	0.8	3.0
8. Pres. Furn/Windbox (iwg)	0.42 1.3	0.41 1.3	0.33 1.2	0.31 1.2	0.50 2.0
9. Uptake (iwg)	-0.19	-0.20	-0.20	-0.20	-0.20
10. Final Stm Press (psig)	98	98	98	98	98
11. Drum Press (psig)	98	98	98	98	100
12. F. Water P/T (psig/°F)	220	222 222	- 222	221 222	215 218
13. Air FD Fan Amps	8.3	8.0	8.0	8.0	9.0
14. Air Temp @ FD Fan/CR (°F)	95	92	91	88	83
15. Stack Temp (°F)	500	496	496	492	532
16. Fuel Flow (CFM $\Rightarrow$ GPM)	2.22	2.27			2.31
17. Fuel Pres/Temp (psi/°F)	129 194	129 194	128 195	128 195	125 54
18. Fuel Atom Pres (psig)	32	32	32	32	30
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	C	C	C	C	C
21. Δ P Pitot FGR Duct (iwg)	—	—	—	—	—
22. Δ P Orif. FGR Duct (iwg)	—	—	—	—	—
23. Temp. FGR Duct (°F)	—	—	—	—	105
24. Pstat FGR Duct (psig)	—	—	—	—	—
25. Pstat S.A. Fan (psig)	4.5	5.1	2.6	2.9	—
26. Vortex FD Fan Blades	0.73	0.72	0.71	0.71	1.45
27. Vortex SA Fan Blades	10.4	10.4	10.6	10.6	—
28. SA Depth/Flow (ft/cfm)	4	6' 11"	4'	7'	+
29. % FGR					
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0
	7400	7400	7400	7500	8000
	26.1	26.1	26.1	26.1	24.9
	3	3	3	3	3

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTERFuel #2 Atom. Type AIR Capacity 17,500 LB/HR

Test Comments _____

	19-116	19-117							
1. Test Number	3626P	3626P							
2. Date	26 JAN 76	→							
3. Time	10:35	11:40							
4. Load	14,500	14,600							
5. Test Purpose	M ¹ P ⁰ PARTICS	→							
6. Excess O ₂ Condition	L0	L0							
7. Cont. Room O ₂ (%)	2.3	2.4							
8. Pres. Furn/Windbox (iwg)	0.50 1.5	0.50 1.5							
9. Uptake (iwg)	-0.18	-0.20							
10. Final Stm Press (psig)	100	100							
11. Drum Press (psig)	100	100							
12. F. Water P/T (psig/°F)	214 222	217 222							
13. Air FD Fan Amps	8.0	8.2							
14. Air Temp @ FD Fan/CR (°F)	87	87							
15. Stack Temp (°F)	520	516							
16. Fuel Flow (CFM or GPM)	2.30	2.27							
17. Fuel Pres/Temp (psi/°F)	125 55	125 55							
18. Fuel Atom Pres (psig)	30	30							
19. Primary Reg. Setting	-8	-8							
20. FGR Reg. Setting	C	C							
21. ΔP Pitot FGR Duct (iwg)	—	—							
22. ΔP Orif. FGR Duct (iwg)	—	—							
23. Temp. FGR Duct (°F)	117	117							
24. Pstat FGR Duct (psig)	—	—							
25. Pstat S.A. Fan (psig)	5.4	5.4							
26. Vortex FD Fan Blades	0.82	0.81							
27. Vortex SA Fan Blades	10.2	10.2							
28. SA Depth/Flow (ft/cfm)	6	6							
29. % FGR	0	0							
30. Total Oil Burned #2/#6	+	+							
31. Total Gas Burned	0	0							

7500 8500
250 250
3 3

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTERFuel #2 Atom. Type _____ Capacity _____

Test Comments _____

	19-118	19-119	19-120	19-121	19-122
1. Test Number	1-17	1-18	CAL	CAL	CAL
2. Date	15 FEB 77	16 FEB 77	→	→	→
3. Time	14:15	10:50	11:20	11:35	11:45
4. Load	13700	14500	14200	14200	
5. Test Purpose	BASELINE	BASELINE	CAL 2°AIR	→	
6. Excess O ₂ Condition	NOM	NOM	H1	H1	
7. Cont. Room O ₂ (%)	2.6 (NO CAL)	2.6 (CAL)	5.6	5.5	
8. Pres. Furn/Windbox (iwg)	0.42 1.8	0.38 1.7	0.70 2.0	0.70 2.0	0.74 2.0
9. Uptake (iwg)	-0.18	-0.21	-0.19	-0.19	-0.17
10. Final Stm Press (psig)	99	98	97		98
11. Drum Press (psig)	99	98	98	98	
12. F. Water P/T (psig/°F)	223 214	200 224	200	217 224	215
13. Air FD Fan Amps	8.4	8.5	8.4	8.4	8.5
14. Air Temp @ FD Fan/CR (°F)	84	84	87	87	86
15. Stack Temp (°F)	510	512	532	528	535
16. Fuel Flow (CFM or GPM)	2.10	2.16	2.19	2.16	2.17
17. Fuel Pres/Temp (psi/°F)	123 51	129 53	129 54	129 53	129 53
18. Fuel Atom Pres (psig)	28	29	29	29	29
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	C	C	C	C	C
21. ΔP Pitot FGR Duct (iwg)	—	—	—	—	—
22. ΔP Orif. FGR Duct (iwg)	0.00	—	—	—	—
23. Temp. FGR Duct (°F)	105	—	—	—	—
24. Pstat FGR Duct (psig)	0.55	—	—	—	—
25. Pstat S.A. Fan (psig)	—	—	10.3	10.2	10.1
26. Vortex FD Fan Blades	1.25	1.15	1.15	1.17	1.17
27. Vortex SA Fan Blades	—	—	5.0	5.6	5.8
28. SA Depth/Flow (ft/cfm)	+	+	4	7	4
29. % FGR	0	0	0	0	0
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

ATOM AIR PRESS, PSIG 23.8 24.0 24.0 24.0 24.0
 STEAM VENT RATE, LB/HR 7000 6500 6000 7000 7500
 DIFFUSER POS., IN.

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SUTTERFuel #2 OIL Atom. Type AIR Capacity 17,500

Test Comments _____

1. Test Number	19-123	19-124	19-125	19-126	19-127
2. Date	16 FEB 77				
3. Time	11:55	12:10	12:20	12:35	12:45
4. Load	13,600	13,700	13,700	13,800	13,900
5. Test Purpose	2° AIR CAL				
6. Excess O ₂ Condition	H1				
7. Cont. Room O ₂ (%)	5.7	5.0		4.8	4.7
8. Pres. Furn/Windbox (iwg)	0.76 2.0	0.68 2.0	0.67 2.0	0.62 1.95	0.61 1.95
9. Uptake (iwg)	-0.18	-0.18	-0.18	-0.20	-0.19
10. Final Stm Press (psig)	98	98		+	
11. Drum Press (psig)					
12. F. Water P/T (psig/°F)	216	218 222		217 222	
13. Air FD Fan Amps	8.6	8.6		8.3	8.3
14. Air Temp @ FD Fan/CR (°F)	89	88	90	86	85
15. Stack Temp (°F)	532	530	530		529
16. Fuel Flow (CFM or GPM)	2.17	2.13	2.19		2.18
17. Fuel Pres/Temp (psi/°F)	129	129	129	53	53
18. Fuel Atom Pres (psig)	29	29	29	29	29
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	C	C	C	C	C
21. ΔP Pitot FGR Duct (iwg)	—	—	—	—	—
22. ΔP Orif. FGR Duct (iwg)	—	—	—	—	—
23. Temp. FGR Duct (°F)	—	—	—	—	—
24. Pstat FGR Duct (psig)	—	—	—	—	—
25. Pstat S.A. Fan (psig)	6.4	3.8	4.2	2.9	3.2
26. Vortex FD Fan Blades	1.17	1.17	1.17	1.17	1.17
27. Vortex SA Fan Blades	10.1	10.5	10.6	10.8	10.8
28. SA Depth/Flow (ft/cfm)	7	4	7	4	7
29. % FGR	0	0	0	0	0
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

24.0
750024.0
7000

24.0

24.0

Data Sheet 6003-16
7000

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTEL

Fuel #6 OIL Atom.Type AIR Capacity _____

Test Comments _____

1. Test Number		19-128	19-129	19-130	19-151
2. Date		16 FEB 77	16 FEB 77	→	17 FEB 77
3. Time		16:00	16:30	16:45	08:25
4. Load		14,000	13,700	13,700	13,900
5. Test Purpose		#6 BASELINE	#6 MAX & RECIRC	→	#6 BASELINE
6. Excess O ₂ Condition		NOM	NOM	NOM	NOM
7. Cont. Room O ₂ (%)		2.7	2.7	2.6	3.0
8. Pres.Furn/Windbox(iwg)		0.34 1.8	0.80 3.0	0.80 3.0	0.34 1.7
9. Uptake (iwg)		-0.21	-0.22	-0.21	-0.22
10. Final Stm Press (psig)		99	98	98	95
11. Drum Press (psig)		98	98	98	99
12. F. Water P/T (psig/°F)		215	215	215 222	199 222
13. Air FD Fan Amps		8.9	8.0	8.0	8.4
14. Air Temp @ FD Fan/CR(°F)		82	100	98	80
15. Stack Temp (°F)		516	568	562	500
16. Fuel Flow (CFM or GPM)		2.23		2.18	2.15
17. Fuel Pres/Temp (psi/°F)		126 192	126 194	126 194	126 194
18. Fuel Atom Pres (psig)		34	34	34	33
19. Primary Reg. Setting		-8	-8	-8	-8
20. FGR Reg. Setting		C	MAX	MAX	C
21. ΔP Pitot FGR Duct(iwg)		—	0.46	0.5	—
22. ΔP Orif. FGR Duct(iwg)		—	0.80	0.80	—
23. Temp. FGR Duct (°F)		—	545	540	102
24. Pstat FGR Duct (psig)		—	4.2	4.2	—
25. Pstat S.A. Fan (psig)		—	10.2	10.0	—
26. Vortex FD Fan Blades		1.25	0.62	0.60	1.2
27. Vortex SA Fan Blades		—	5.7	6.2	—
28. SA Depth/Flow (ft/cfm)		+	4	7	+
29. % FGR		0			0
30. Total Oil Burned #2/#6		+	+	+	+
31. Total Gas Burned		0	0	0	0

25.1 25.1 25.1 25.1
6500 7000 6500 6500
Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTERFuel #6 OIL Atom. Type _____ Capacity _____

Test Comments _____

1. Test Number	19-132	→	19-133	19-134	19-135
2. Date	17 FEB 77	→	18 FEB 77	→	→
3. Time	9:50	11:05	08:15	10:20	10:40
4. Load	14500	13900	13900	13900	13700
5. Test Purpose	LOW O ₂ PARTIC. M5	→	BASELINE	MED RECIRC HI & LO O ₂	→
6. Excess O ₂ Condition	LO	→	NOM	LO	LO
7. Cont. Room O ₂ (%)	0.4	0.4	2.4	1.0	1.2
8. Pres.Furn/Windbox(iwg)	0.20 1.3	0.20 1.3	0.30 1.6	0.6 2.2	0.6 2.2
9. Uptake (iwg)	-0.22	-0.23	-0.23	-0.22	-0.22
10. Final Stm Press (psig)	95	93	92	98	96
11. Drum Press (psig)	95	95	95	98	96
12. F. Water P/T (psig/°F)	214 222	215 222	210 222	215 222	217
13. Air FD Fan Amps	8.0	7.9	8.1	7.4	7.5
14. Air Temp @ FD Fan/CR(°F)	80	79	75	101	104
15. Stack Temp (°F)	490	508	514	553	553
16. Fuel Flow (CFM or GPM)	2.16	2.19	2.20	2.20	2.12
17. Fuel Pres/Temp(psi/°F)	127 191	127 191	133 192	133 197	133 196
18. Fuel Atom Pres (psig)	33	33	33	34	34
19. Primary Reg. Setting	-8	-8	-8	-9	-9
20. FGR Reg. Setting	C	C	C	2.9	2.9
21. ΔP Pitot FGR Duct(iwg)	—	—	—	0.3	—
22. ΔP Orif. FGR Duct(iwg)	—	—	—	0.38	0.39
23. Temp. FGR Duct (°F)	—	—	—	523	522
24. Pstat FGR Duct (psig)	—	—	—	4.9	4.9
25. Pstat S.A. Fan (psig)	—	—	—	10.0	—
26. Vortex FD Fan Blades	0.86	0.84	1.15	0.46	—
27. Vortex SA Fan Blades	—	—	—	5.6	5.9
28. SA Depth/Flow (ft/cfm)	+	+	+	4	5
29. % FGR	0	0	0	—	—
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

25.0 25.0 25.0 25.9 25.9
 6500 5500 5500 10500 9000
 Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTERFuel #6 OIL Atom. Type AIR Capacity _____

Test Comments _____

1. Test Number	19-136	19-137	19-138	19-139	19-140
2. Date	18 FEB 77				
3. Time	13:25	13:45	14:00	14:20	14:50
4. Load	14,600	14,400	14,300	14,300	14,200
5. Test Purpose	MID RECIRC HI Φ	LO RECIRC HI Φ		NO RECIRC HI Φ	LO RECIRC HI Φ
6. Excess O ₂ Condition	LO	LO	LO	LO	NOM
7. Cont. Room O ₂ (%)	1.0	1.7	2.0	1.6	2.5
8. Pres. Furn/Windbox (iwg)	0.63 2.1	0.52 1.7	0.52 1.65	0.43 1.2	0.80 2.5
9. Uptake (iwg)	-0.18	-0.18	-0.20	-0.20	-0.20
10. Final Stm Press (psig)	94	94	94	94	93
11. Drum Press (psig)	94	94	95	95	94
12. F. Water P/T (psig/°F)	216 222	215 222	215 222	214 222	222
13. Air FD Fan Amps	7.2	7.5	7.5	7.2	8.2
14. Air Temp @ FD Fan/CR (°F)	105	105	104	121	107
15. Stack Temp (°F)	549	530	528	513	561
16. Fuel Flow (CFM or GPM)	2.28	2.30	2.23	2.28	2.17
17. Fuel Pres/Temp (psi/°F)	133 192	132 192	133 192	133 192	133 192
18. Fuel Atom Pres (psig)	34	34	34	34	34
19. Primary Reg. Setting	-9	-9	-9	-9	-9
20. FGR Reg. Setting	3.3	3.8	3.7	C	-
21. ΔP Pitot FGR Duct (iwg)	0.4	0.05	—	—	0.1
22. ΔP Orif. FGR Duct (iwg)	0.177	0.043	0.041	0.012 (ZERO DRIET)	0.22
23. Temp. FGR Duct (°F)	497	440	425	335	517
24. Pstat FGR Duct (psig)	5.5	6.2	5.6	—	5.4
25. Pstat S.A. Fan (psig)	9.9	10.0	10.0	10.0	10.0
26. Vortex FD Fan Blades	0.508	0.55	0.55	0.51	0.64
27. Vortex SA Fan Blades	5.6	5.8	5.9	5.8	5.7
28. SA Depth/Flow (ft/cfm)	4	4	5	4	4
29. % FGR				0	
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

Data Sheet 6003-16

	25.5	25.5	25.5	25.5	25.2
	6500	6500	6500	6500	6500
DIFFUSER POS., IN.	2.9	2.9	2.9	2.9	2.9

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTERFuel #6 OIL Atom. Type _____ Capacity _____

Test Comments _____

1. Test Number	19-141	19-142	19-143	→	19-144
2. Date	18 FEB 77	21 FEB 77	→	→	→
3. Time	15:00	09:25	10:20	11:25	12:35
4. Load	14,200	14,200	13,600	13,900	13,900
5. Test Purpose	LO REGRIC HI Φ	#6 BASELINE	HI Φ LOW O ₂ PARTICS	→	→
6. Excess O ₂ Condition	NOM	NOM	SMOKE THRESHOLD	→	→
7. Cont. Room O ₂ (%)	2.2	2.8	3.0	2.8	2.8
8. Pres.Furn/Windbox(iwg)	0.79 2.5	0.35 1.7	0.35 1.7	0.40 1.2	0.41 1.2
9. Uptake (iwg)	-0.19	-0.22	-0.20	-0.19	-0.19
10. Final Stm Press (psig)	93	94	96	95	95
11. Drum Press (psig)	94	95	95	95	95
12. F. Water P/T (psig/°F)	217 222	219 220	215 222	218 222	218 222
13. Air FD Fan Amps	8.0	8.5	7.6	7.6	8.0
14. Air Temp @ FD Fan/CR(°F)	104	83	87	89	91
15. Stack Temp (°F)	562	521	503	508	510
16. Fuel Flow (CFM or GPM)	2.21	2.13	2.17	2.13	2.13
17. Fuel Pres/Temp (psi/°F)	133 192	127 192	129 193	126 195	125 196
18. Fuel Atom Pres (psig)	34	34	34	34	34
19. Primary Reg. Setting	-9	-8	-8	-8	-8
20. FGR Reg. Setting		C	C	C	C
21. ΔP Pitot FGR Duct(iwg)	0.07	—	—	—	—
22. ΔP Orif. FGR Duct(iwg)	0.22	—	—	—	—
23. Temp. FGR Duct (°F)	523	107	—	—	—
24. Pstat FGR Duct (psig)	5.4	—	—	—	—
25. Pstat S.A. Fan (psig)	10.0	—	10.0	10.0	10.0
26. Vortex FD Fan Blades	0.64	1.17	0.53	0.54	0.54
27. Vortex SA Fan Blades	6.2	—	5.9	5.9	5.8
28. SA Depth/Flow (ft/cfm)	7	+	5	5	5
29. % FGR		0	0	0	0
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0	0	0	0

ATOM. AIR	25.1	25.0	25.1	25.1	25.0
STEAM VENT	6500	6500	6000	6400	6300
DIFFUSER	2.9	2.9	2.9	2.9	2.9
OPACITY (APPROX)	.60				

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SCOTTER

Fuel #6, #2, + GAS Atom. Type _____ Capacity _____

Test Comments _____

	#6 OIL	#2 OIL	NATURAL GAS		
1. Test Number	19-145	19-146	19-147	19-148	19-149
2. Date	21 FEB 77	22 FEB 77	22 FEB 77	→	→
3. Time	14:45	08:30	10:05	10:40	11:05
4. Load	14,000	14,100	14,100	13,900	14,600
5. Test Purpose	OPACITY	#2 BASELINE	NATURAL GAS BASELINE	FAN WIRE OPEN	MFD 02
6. Excess O ₂ Condition	SMOKE THRESHOLD	NOM	NOM	H1	MED
7. Cont. Room O ₂ (%)	1.9	2.8	2.8	6.2	1.6
8. Pres. Furn/Windbox (iwg)	0.48 1.3	0.38 1.7	0.48 2.2	0.96 3.8	0.40 2.2
9. Uptake (iwg)	-0.2	-0.21	-0.21	-0.15	-0.21
10. Final Stm Press (psig)	97	95	97	95	95
11. Drum Press (psig)	97	95	97	95	95
12. F. Water P/T (psig/°F)	215 222	216 222	207 222	208 222	217
13. Air FD Fan Amps	7.7	8.2	8.4	11.0	8.4
14. Air Temp @ FD Fan/CR (°F)	104	86	87	85	88
15. Stack Temp (°F)	521	520	538	568	531
16. Fuel Flow (CFM or GPM)	2.22	2.14			
17. Fuel Pres/Temp (psi/°F)	125 196	116 53	4.8	4.75	4.8
18. Fuel Atom Pres (psig)	34	28	88 IWG	88	88
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	C	C	C	C	C
21. ΔP Pitot FGR Duct (iwg)	—	—	0.9	0.1	—
22. ΔP Orif. FGR Duct (iwg)	—	—	0.001	0.001	—
23. Temp. FGR Duct (°F)	131	—	104	102	—
24. Pstat FGR Duct (psig)	—	—	0.9	1.4	—
25. Pstat S.A. Fan (psig)	9.9	—	0	0	—
26. Vortex FD Fan Blades	0.53	1.18	1.33	2.28	1.19
27. Vortex SA Fan Blades	5.9	—	—	—	—
28. SA Depth/Flow (ft/cfm)	5	+	+	+	+
29. % FGR	0	0	0	0	0
30. Total Oil Burned #2/#6	+	+	0 0	0 0	0 0
31. Total Gas Burned	0	0	—	—	—

ATOM AIR
STEAM VENT RATE
DIFFUSER POS.

73.1
750 | 100 : 10
2.9

8000
2.9

Data Sheet 6003-16
6000 7000
2.9 2.9

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTERFuel N. GAS Atom. Type _____ Capacity _____

Test Comments _____

1. Test Number	19-150	19-151	19-152	19-153	19-154
2. Date	22 FEB 77				
3. Time	11:25	11:40	13:30	13:40	13:45
4. Load	14,700	14,500	14,400		
5. Test Purpose	OPT O ₂	H ₁ CO	H ₁ φ	CHANGING: ONLY PROBE DEPTH	
6. Excess O ₂ Condition	OPT	MIN	NOM		
7. Cont. Room O ₂ (%)	0.9	0.8	2.4		
8. Pres. Furn/Windbox (iwg)	0.36 2.0	0.36 2.0	0.54 1.9		
9. Uptake (iwg)	-0.22	-0.22	-0.19		
10. Final Stm Press (psig)	95	95	96		
11. Drum Press (psig)	95	95	96		
12. F. Water P/T (psig/°F)	217 222	217	216		
13. Air FD Fan Amps	8.2	8.2	7.6		
14. Air Temp @ FD Fan/CR (°F)	88	91	101		
15. Stack Temp (°F)	525	523	527		
16. Fuel Flow (CFM or GPM)					
17. Fuel Pres/Temp (psi/°F)	4.8 -	4.8 -	4.8		
18. Fuel Atom Press (psig)	88	88	88		
19. Primary Reg. Setting	-8	-8	-8		
20. FGR Reg. Setting	C	C	C		
21. AP Pitot FGR Duct (iwg)	—	—	—		
22. AP Orif. FGR Duct (iwg)	—	—	—		
23. Temp. FGR Duct (°F)	—	—	—		
24. Pstat FGR Duct (psig)	—	—	—		
25. Pstat S.A. Fan (psig)	—	—	9.6		10.8
26. Vortex FD Fan Blades	1.1	1.1	0.67		
27. Vortex SA Fan Blades	—	—	5.2		5.9
28. SA Depth/Flow (ft/cfm)	+	+	4	5	6
29. % FGR	0	0	0		
30. Total Oil Burned #2/#6	0 0	0 0	0 0		
31. Total Gas Burned	—	—	—		

Data Sheet 6003-16

DIFFUSER POS. 6500 6500 7500
 2.9 2.9 2.9

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. 507 TFCFuel N. GAS Atom. Type _____ Capacity _____

Test Comments _____

1. Test Number	19-155	19-156	19-157		
2. Date	22 FEB 77	→	→		
3. Time	13:55	14:15	14:30		
4. Load	14300	14400	14500		
5. Test Purpose	H1 φ	H1 φ	H1 φ		
6. Excess O ₂ Condition	NOM	LO	LO		
7. Cont. Room O ₂ (%)	2.0	1.2	1.8		
8. Pres. Furn/Windbox (iwg)	0.55 1.9	0.51 1.9	0.50 1.8		
9. Uptake (iwg)	-0.20	-0.18	-0.19		
10. Final Stm Press (psig)	96	96	96		
11. Drum Press (psig)	95	96	96		
12. F. Water P/T (psig/°F)	217	217	217		
13. Air FD Fan Amps	7.9	7.6	7.9		
14. Air Temp @ FD Fan/CR (°F)	98	100	102		
15. Stack Temp (°F)	530	524	522		
16. Fuel Flow (CFM or GPM)					
17. Fuel Pres/Temp (psi/°F)	4.8 -	4.8	4.8		
18. Fuel Atom Pres ^{PING} (psig)	88	88	88		
19. Primary Reg. Setting	-8	-8	-8		
20. FGR Reg. Setting	C	C	C		
21. ΔP Pitot FGR Duct (iwg)	—	—	—		
22. ΔP Orif. FGR Duct (iwg)	—	—	—		
23. Temp. FGR Duct (°F)	—	—	—		
24. Pstat FGR Duct (psig)	—	—	—		
25. Pstat S.A. Fan (psig)	9.7	9.8	9.7		
26. Vortex FD Fan Blades	0.67	0.61	0.60		
27. Vortex SA Fan Blades	5.8	5.8	5.2		
28. SA Depth/Flow (ft/cfm)	7	7	4		
29. % FGR	0	0	0		
30. Total Oil Burned #2/#6	0 0	0 0	0 0		
31. Total Gas Burned	—	—	—		

Data Sheet 6003-16

7500 7600 7800
2.9 2.9 2.9

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTERFuel #6 OIL Atom. Type AIR Capacity _____

Test Comments _____

1. Test Number	19-158	19-159	→	19-160	19-161
2. Date	23 FEB 77	→	→	→	→
3. Time	08:15	09:40	11:20	14:10	14:35
4. Load	14200	14000	13900	14500	14500
5. Test Purpose	#6 BASELINE	M. RECIRC PACIFIC	M. RECIRC IMPACTOR	MED & MED RECIRC	→
6. Excess O ₂ Condition	NOM	NOM	NOM	NOM	NOM
7. Cont. Room O ₂ (%)	2-3	1.0	1.0	2-1	2.2
8. Pres. Furn/Windbox (iwg)	0.40 1.75	0.80 3.5	0.85 3.5	0.83 3.0	0.96 3.1
9. Uptake (iwg)	-0.21	-0.19	-0.20	-0.17	-0.17
10. Final Stm Press (psig)	92	94	95	95	95
11. Drum Press (psig)	95	96	95	95	95
12. F. Water P/T (psig/°F)	193 205	212	214 220	217 222	218 222
13. Air FD Fan Amps	8.2	8.5		8.3	8.4
14. Air Temp @ FD Fan/CR (°F)	85	93	99	108	107
15. Stack Temp (°F)	515	562	563	578	575
16. Fuel Flow (CFM or GPM)					
17. Fuel Pres/Temp (psi/°F)	131 192	130 192	129 192	130	130 192
18. Fuel Atom Pres (psig)	34	34	34	34	34
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	C	WIDE OPEN	WIDE OPEN	3.3	3.3
21. ΔP Pitot FGR Duct (iwg)	—	—	—	0.15	0.15
22. ΔP Orif. FGR Duct (iwg)	—	0.75	—	0.39	0.39
23. Temp. FGR Duct (°F)	110	542	—	540	537
24. Pstat FGR Duct (psig)	—	4.5	—	5.0	5.0
25. Pstat S.A. Fan (psig)	—	—	—	10.5	10.5
26. Vortex FD Fan Blades	1.2	~1.2	1.15	0.92	0.92
27. Vortex SA Fan Blades	—	—	—	2.9	3.2
28. SA Depth/Flow (ft/cfm)	+	+	+	4	7
29. % FGR	0	0	0		
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	0	0		0	0

25.1 25.2 25.2 25.6 25.6
 5000 7000 7200 8000 8100
 2.9 2.9 2.9 2.9 2.9

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTERFuel #6 + NG Atom. Type _____ Capacity _____

Test Comments _____

1. Test Number	19-162	19-163	19-164	19-165	19-166
2. Date	23 FEB 77	→	24 FEB 77	→	→
3. Time	15:00	15:15	08:05	08:50	09:10
4. Load	14,500	14,500	14,700	13,500	13,600
5. Test Purpose	LO RECIRC MED φ	→	NG BASELINE	MED φ	→
6. Excess O ₂ Condition	NOM	NOM	NOM	NOM	NOM
7. Cont. Room O ₂ (%)	2.2	2.2	2.9	3.0	2.9
8. Pres.Furn/Windbox(iwg)	0.88 2.8	0.86 2.7	0.48 2.4	0.50 2.0	0.48 2.0
9. Uptake (iwg)	-0.17	-0.16	-0.19	-0.18	-0.19
10. Final Stm Press (psig)	95	95	94	96	95
11. Drum Press (psig)	95	95	95	96	95
12. F. Water P/T (psig/°F)	218 222	219 222	193 222	203	219 216
13. Air FD Fan Amps	8.4	8.5	8.5		7.9
14. Air Temp @ FD Fan/CR (°F)	166	110	88	89	89
15. Stack Temp (°F)	569	564	521	521	529
16. Fuel Flow (CFMor GPM)					
17. Fuel Pres/Temp (psi/°F)	130 192	130 192	4.75 psi 6	4.75	4.75
18. Fuel Atom Pres (psig)	34	34	88 IWG	88	88
19. Primary Reg. Setting	-8	-8	-8	-8	-8
20. FGR Reg. Setting	3.2	3.2	C	C	C
21. ΔP Pitot FGR Duct(iwg)	0.15	0.12	—	—	—
22. ΔP Orif. FGR Duct(iwg)	0.20	0.20	—	—	—
23. Temp. FGR Duct (°F)	525	525	—	—	—
24. Pstat FGR Duct (psig)	5.5	5.5	—	—	—
25. Pstat S.A. Fan (psig)	10.5	10.5	—	10.5	10.6
26. Vortex FD Fan Blades	0.91	0.89	1.28	0.84	0.83
27. Vortex SA Fan Blades	3.2	2.8	—	2.9	3.4
28. SA Depth/Flow (ft/cfm)	7	4'	+	4'	7'
29. % FGR			0	0	0
30. Total Oil Burned #2/#6	+	+	0 0	0 0	0 0
31. Total Gas Burned	0	0	—	—	—

25.3

8000

2.9

8100

2.9

6500

2.9

Data Sheet 6003-16

8000

2.9

8000

2.9

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SC7712Fuel NG Atom. Type _____ Capacity _____

Test Comments _____

1. Test Number	19-167	19-168			
2. Date	24 FEB 77	→			
3. Time	09:45	09:55			
4. Load	13400	13900			
5. Test Purpose	MED ϕ	→			
6. Excess O ₂ Condition	L0	L0			
7. Cont. Room O ₂ (%)	1.4	1.6			
8. Pres. Furn/Windbox (iwg)	0.40 1.8	0.39 1.8			
9. Uptake (iwg)	-0.19	-0.20			
10. Final Stm Press (psig)	95	95			
11. Drum Press (psig)	95	95			
12. F. Water P/T (psig/°F)	217 220	215			
13. Air FD Fan Amps	7.8	7.7			
14. Air Temp @ FD Fan/CR (°F)	88	89			
15. Stack Temp (°F)	521	513			
16. Fuel Flow (CFM or GPM)					
17. Fuel Pres/Temp (psi/°F)	4.75 PSIG	4.75			
18. Fuel Atom Pres (psig)	88 IWC	88			
19. Primary Reg. Setting	-8	-8			
20. FGR Reg. Setting	C	C			
21. Δ P Pitot FGR Duct (iwg)	—	—			
22. Δ P Orif. FGR Duct (iwg)	—	—			
23. Temp. FGR Duct (°F)	—	—			
24. Pstat FGR Duct (psig)	—	—			
25. Pstat S.A. Fan (psig)	10.5	10.5			
26. Vortex FD Fan Blades	0.68	0.69			
27. Vortex SA Fan Blades	3.2	2.9			
28. SA Depth/Flow (ft/cfm)	7	4			
29. % FGR	0	0			
30. Total Oil Burned #2/#6	0 0	0 0			
31. Total Gas Burned	—	—			

Data Sheet 6003-16

STEAM VENT RATE, LB/HR 7500 7700
 DIFFUSER POS., IN. 2.9 2.9

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTERFuel #6 OIL Atom. Type AIR Capacity _____

Test Comments _____

1. Test Number	19-169	19-170	→	→	
2. Date	1 MAR 77	→	→	→	
3. Time	09:00	10:40	12:10	1:35	
4. Load	14,200	14,100	14,400	14,300	
5. Test Purpose	#6 BASELINE	H ₁ Φ MAX RECIRC	→	→	
6. Excess O ₂ Condition	NOM	LO (MARGINAL STABILITY)	→	→	
7. Cont. Room O ₂ (%)	2.4	4.0	3.7	3.7	
8. Pres. Furn/Windbox (iwg)	0.43 1.9	1.03 3.4	1.03 3.4	1.04 3.4	
9. Uptake (iwg)	-0.20	-0.15	-0.15	-0.15	
10. Final Stm Press (psig)	98	95	94	95	
11. Drum Press (psig)	98	95	94	94	
12. F. Water P/T (psig/°F)	203 222	220 222	217 222	218 222	
13. Air FD Fan Amps	—	—	—	—	
14. Air Temp @ FD Fan/CR (°F)	87	107	104	105	
15. Stack Temp (°F)	520	567	571	570	
16. Fuel Flow (CFM or GPM)	2.21	2.21	2.20	2.17	
17. Fuel Pres/Temp (psi/°F)	127 194	125 196	126 195	124 196	
18. Fuel Atom Pres (psig)	33	33	33	32	
19. Primary Reg. Setting	-8	-8	-8	-8	
20. FGR Reg. Setting	C	WIDE OPEN	WIDE OPEN	WIDE OPEN	
21. ΔP Pitot FGR Duct (iwg)	—	0.18	0.17	-0.17	
22. ΔP Orif. FGR Duct (iwg)	—	0.78	0.78	0.78	
23. Temp. FGR Duct (°F)	—	544	549	550	
24. Pstat FGR Duct (psig)	—	4.4	4.4	4.4	
25. Pstat S.A. Fan (psig)	—	9.9	10.0	10.0	
26. Vortex FD Fan Blades	1.23	0.77	0.78	0.77	
27. Vortex SA Fan Blades	—	5.5	5.6	5.6	
28. SA Depth/Flow (ft/cfm)	+	4	4	4	
29. % FGR	0				
30. Total Oil Burned #2/#6	+	+	+	+	
31. Total Gas Burned	0	0	0	0	

ATOM AIR PRESS, PSIG 24.9 24.5 24.5 24.3
 10500 1400 6700 7300 Data Sheet 6003-16
 DIFFUSER POS., IN. 2.9 2.9 2.9 2.9

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SETTERFuel NAT. GAS Atom. Type GUN Capacity _____Test Comments 32-ORIFACE GUN

1. Test Number	19-171	19-172	19-173	19-174	19-175
2. Date	2 MAR 77	>	>	>	>
3. Time	11:15	11:50	13:30	13:45	14:50
4. Load	14,000	14,200	14,100	14,300	14,400
5. Test Purpose	NGAS WITH MAX RECIRC	GAS GUN BASELINE	MED. RECIRC.	LOW RECIRC	LOW RECIRC
6. Excess O ₂ Condition	NOM	NOM	NOM	NOM	LO
7. Cont. Room O ₂ (%)	3.2	2.7	3.0	3.1	1.6
8. Pres. Furn/Windbox (iwg)	0.81 5.0	0.45 3.8	1.69 4.35	0.59 4.0	0.58 3.8
9. Uptake (iwg)	-0.20	-0.20	-0.17	-0.18	-0.19
10. Final Stm Press (psig)	96	95	96	96	96
11. Drum Press (psig)	95	94	94	95	96
12. F. Water P/T (psig/°F)	214 222	215	217 222	219 222	217 222
13. Air FD Fan Amps					
14. Air Temp @ FD Fan/CR (°F)	93	94	100	100	103
15. Stack Temp (°F)	550	519	530	522	510
16. Fuel Flow (CFM or GPM)					
17. Fuel Pres/Temp (psi/°F)	4.5	4.5	4.5	4.5	4.75
18. Fuel Atom Pres (psig)	78	78	78	78	65
19. Primary Reg. Setting	-4	-4	-4	-4	-4
20. FGR Reg. Setting	WIDE OPEN	C	3.3	3.6	3.6
21. ΔP Pitot FGR Duct (iwg)	0.1	—	0.1	0.0	0.0
22. ΔP Orif. FGR Duct (iwg)	0.55	-0.003	0.139	0.063	0.058
23. Temp. FGR Duct (°F)	525	300	455	450	439
24. Pstat FGR Duct (psig)	4.65	1.1	5.4	5.9	5.3
25. Pstat S.A. Fan (psig)	—	—	0	0	0
26. Vortex FD Fan Blades	1.40	1.37	1.26	1.28	1.25
27. Vortex SA Fan Blades	—	—	—	—	—
28. SA Depth/Flow (ft/cfm)	+	+	+	+	+
29. % FGR					
30. Total Oil Burned #2/#6	+	0 0	0 0	0 0	0 0
31. Total Gas Burned	—	—	—	—	—

DIFFUSER PCS., IN.

6.6

6.6

6.6

6.6

6.6

Data Sheet 6003-16

STEAM VENT

9200

7500

8000

8000

7800

GUN POS., IN.

18.7

18.7

18.7

18.7

18.7

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTER

Fuel NAT. GAS #2 Atom. Type GUN Capacity _____

Test Comments _____

1. Test Number	19-176	19-177	19-178	19-179	→
2. Date	2 MAR 77	→	3 MAR 77	→	→
3. Time	15:25	15:45	08:15	10:20	11:20
4. Load	14,800	15000	14,400	13,600	13,700
5. Test Purpose	MED RECIRC	H ₁ RECIRC	#2 BASELINE	MAX RECIRC	MAX & PARTICS
6. Excess O ₂ Condition	LO	LO-STABLE LIMIT	NOM	LO STABILITY LIMIT	→
7. Cont. Room O ₂ (%)	1.7	1.1	2.1	2.9	2.9
8. Pres.Furn/Windbox(iwg)	0.89 5.1	0.98 5.2	0.46 2.0	0.96 3.2	0.96 3.2
9. Uptake (iwg)	-0.16	-0.18	-0.20	-0.19	-0.19
10. Final Stm Press (psig)	95	95	100	96	96
11. Drum Press (psig)	94	95	100	96	96
12. F. Water P/T (psig/°F)	215 222	216 222	218 222	218 222	218 222
13. Air FD Fan Amps	—	—	—	—	—
14. Air Temp @ FD Fan/CR (°F)	104	102	87	108	109
15. Stack Temp (°F)	541	557	519	556	556
16. Fuel Flow (CFM or GPM)	—	—	—	—	—
17. Fuel Pres/Temp (psi/°F)	4.7	4.7	112	113 56	113 56
18. Fuel Atom Pres (psig)	68	68	29	28	28
19. Primary Reg. Setting	-4	-4	-8	-8	-8
20. FGR Reg. Setting	3.4	1.25	C	WIDE OPEN	WIDE OPEN
21. ΔP Pitot FGR Duct(iwg)	0.0	0.05	—	0.1	0.1
22. ΔP Orif. FGR Duct(iwg)	0.115	0.49	—	0.80	0.81
23. Temp. FGR Duct (°F)	480	525	—	540	540
24. Pstat FGR Duct (psig)	5.3	4.3	—	4.4	4.4
25. Pstat S.A. Fan (psig)	—	—	—	10.1	10.0
26. Vortex FD Fan Blades	1.65	1.46	1.32	0.69	0.68
27. Vortex SA Fan Blades	—	—	—	5.6	5.6
28. SA Depth/Flow (ft/cfm)	+	+	+	4	4
29. % FGR	—	—	—	—	—
30. Total Oil Burned #2/#6	0 0	0 0	0 0	+	+
31. Total Gas Burned	—	—	—	0	0

6.6 6.6 ATOM AIR 24.1 23.9 23.9
 8000 8100 10,000 9500 8000
 18.7 18.7 2.9 3.9 3.9
 Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTERFuel #2 OIL Atom. Type _____ Capacity _____

Test Comments _____

1. Test Number	19-179	→			
2. Date	3 MAR 77	→			
3. Time	13:45	14:45			
4. Load	14,300	14,000			
5. Test Purpose	IMPACTOR	→			
6. Excess O ₂ Condition	STABILITY LIMIT	→			
7. Cont. Room O ₂ (%)	2.6	2.8			
8. Pres. Furn/Windbox (iwg)	1.00 3.2	1.00 3.2			
9. Uptake (iwg)	-0.17	-0.17			
10. Final Stm Press (psig)	.98	.98			
11. Drum Press (psig)	95	95			
12. F. Water P/T (psig/°F)	220 222	220 222			
13. Air FD Fan Amps	—	—			
14. Air Temp @ FD Fan/CR (°F)	116	>116			
15. Stack Temp (°F)	554	552			
16. Fuel Flow (CFM or GPM)					
17. Fuel Pres/Temp (psi/°F)	113 60	113 60			
18. Fuel Atom Pres (psig)	2.8	2.8			
19. Primary Reg. Setting	-8	-8			
20. FGR Reg. Setting	WIDE OPEN	WIDE OPEN			
21. ΔP Pitot FGR Duct (iwg)	0.1	0.1			
22. ΔP Orif. FGR Duct (iwg)	0.75	0.73			
23. Temp. FGR Duct (°F)	537	535			
24. Pstat FGR Duct (psig)	4.4	4.4			
25. Pstat S.A. Fan (psig)	9.8	9.8			
26. Vortex FD Fan Blades	0.68	0.67			
27. Vortex SA Fan Blades	5.5	5.5			
28. SA Depth/Flow (ft/cfm)	4	4			
29. % FGR					
30. Total Oil Burned #2/#6	+	+			
31. Total Gas Burned	0	0			

23.9
 7500 7500
 DIFFUSER POS., IN 3.9 3.9

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 Engr. SOTTERFuel NAT. GAS Atom. Type GUN Capacity _____

Test Comments _____

1. Test Number	19-180	19-181	19-182	19-183	19-184
2. Date	4 MAR 77				
3. Time	08:00	09:00	09:35	09:50	10:00
4. Load	6700	13,800	14,000	14,000	13,900
5. Test Purpose	LOW LOAD	GAS GUN BASELINE	MAX O ₂	LO O ₂	MIN O ₂
6. Excess O ₂ Condition	AS FOUND	NOM	MAX	LO	HI CO
7. Cont. Room O ₂ (%)	4.8	2.6	5.0	2.0	1.0
8. Pres. Furn/Windbox (iwg)	0.00 1.65	0.40 3.9	0.68 5.5	0.32 3.4	0.28 3.1
9. Uptake (iwg)	-0.22	-0.20	-0.19	-0.20	-0.21
10. Final Stm Press (psig)	94	97	97	97	99
11. Drum Press (psig)	92	98	97	98	98
12. F. Water P/T (psig/°F)	225 222	214 222	212 222	213 222	214
13. Air FD Fan Amps	—	—	—	—	—
14. Air Temp @ FD Fan/CR (°F)	84	82	84	85	84
15. Stack Temp (°F)	391	508	522	496	489
16. Fuel Flow (CFM or GPM)					
17. Fuel Pres/Temp (psi/°F)	5.6	4.5	4.5	4.5	4.5
18. Fuel Atom Pres (psig)	25	81	79	79	79
19. Primary Reg. Setting	-3	-4	-4	-4	-4
20. FGR Reg. Setting	C	C	C	C	C
21. ΔP Pitot FGR Duct (iwg)	—	—	—	—	—
22. ΔP Orif. FGR Duct (iwg)	—	—	—	—	—
23. Temp. FGR Duct (°F)	—	—	—	—	—
24. Pstat FGR Duct (psig)	—	—	—	—	—
25. Pstat S.A. Fan (psig)	—	—	—	—	—
26. Vortex FD Fan Blades	0.43	1.40	1.92	1.20	—
27. Vortex SA Fan Blades	—	—	—	—	—
28. SA Depth/Flow (ft/cfm)	+	+	+	+	+
29. % FGR	0	0	0	0	0
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned	—	—	—	—	—

STEAM VENT 0 9500 6.5 6.5 6.5
 Data Sheet 6003-16
 9100 10,000
 18 18.6 18.6

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTERFuel NAT. GAS Atom. Type GUN Capacity _____

Test Comments _____

1. Test Number	19-185	19-186	19-187	19-188	19-189
2. Date	4 MAR 77	→	→	→	→
3. Time	10:45	11:00	13:50	14:05	14:25
4. Load	14,000	14,000	14,000	13,700	13,800
5. Test Purpose	MAX &	→	MAX & HI RECIRC	→	MAX & MED RECIRC
6. Excess O ₂ Condition	NOM	→	STABLE LIMIT	→	60 LIM
7. Cont. Room O ₂ (%)	2.0	1.7	3.9	3.5	2.4
8. Pres.Furn/Windbox(iwg)	0.43 2.5	0.43 2.5	1.00 4.7	0.99 4.7	0.74 4.2
9. Uptake (iwg)	-0.20	-0.20	-0.17	-0.18	-0.18
10. Final Stm Press (psig)	97	97	98	95	95
11. Drum Press (psig)	97	97	97	94	95
12. F. Water P/T (psig/°F)	216 222	218 222	221 221	220	220
13. Air FD Fan Amps	—	—	—	—	—
14. Air Temp @ FD Fan/CR(°F)	90	89	101	103	101
15. Stack Temp (°F)	497	501	531	530	510
16. Fuel Flow (CFM or GPM)					
17. Fuel Pres/Temp (psi/°F)	4.5	4.5	4.5	4.5	4.5
18. Fuel Atom Pres (psig)	80	80	77	77	78
19. Primary Reg. Setting	-4	-4	-3	-3	-3
20. FGR Reg. Setting	C	C	2.1	2.1	
21. ΔP Pitot FGR Duct(iwg)	—	—	0.08	0.09	—
22. ΔP Orif. FGR Duct(iwg)	—	—	0.48	0.50	0.14
23. Temp. FGR Duct (°F)	—	—	504	504	440
24. Pstat FGR Duct (psig)	—	—	6.7	4.8	5.7
25. Pstat S.A. Fan (psig)	10.0	10.0	9.8	9.9	9.9
26. Vortex FD Fan Blades	0.62	0.62	0.91	0.91	0.81
27. Vortex SA Fan Blades	5.4	6.0	5.6	6.1	6.1
28. SA Depth/Flow (ft/cfm)	4	7	4	7	7
29. % FGR	0	0			
30. Total Oil Burned #2/#6	+	+	+	+	+
31. Total Gas Burned					

6.5 6.5 6.5 6.5 6.5
 9500 9500 7000 6000 6900
 18.6 18.6 18.6 18.6 18.6

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. 5077ER

Fuel NAT. GAS + #6 OIL Atom. Type _____ Capacity _____

Test Comments _____

	GAS		GAS		#6		#6		
1. Test Number	19-190		→		19-191		19-192		→
2. Date	7 MAR 77		7 MAR 77		→		→		→
3. Time	09:45		1102		13:35		15:25		1621
4. Load	13700		14000		14500		14300		14400
5. Test Purpose	HI RECIRC PARTICS		HI RECIRC PART. + SOX		#6 BASELINE		REPEAT 170 FOR SOX		→
6. Excess O ₂ Condition	NOM		NOM		NOM		MIN STABLE		→
7. Cont. Room O ₂ (%)	3.0		2.9		1.6		3.0		4.0
8. Pres. Furn/Windbox (iwg)	0.70	4.8	0.73	4.8	0.40	1.8	1.03	3.5	1.04 3.5
9. Uptake (iwg)	-0.22		-0.19		-0.19		-0.16		-0.18
10. Final Stm Press (psig)	95		95		95		95		95
11. Drum Press (psig)	95		90		96		96		96
12. F. Water P/T (psig/°F)	215		216	223	218	222	220	222	219
13. Air FD Fan Amps	—		—		—		—		—
14. Air Temp @ FD Fan/CR (°F)	87		95		86		105		111
15. Stack Temp (°F)	538		540		508		560		558
16. Fuel Flow (CFM or GPM)									
17. Fuel Pres/Temp (psi/°F)	4.75		4.75		129	190	129	190	128 191
18. Fuel Atom Pres (psig)	64		64		33		33		33
19. Primary Reg. Setting	-4		-4		-8		-8		-8
20. FGR Reg. Setting	3.0		3.0		C		WIDE OPEN (0.75)		0.75
21. ΔP Pitot FGR Duct (iwg)	0.05		0.07		—		—		0.05
22. ΔP Orif. FGR Duct (iwg)	0.27		0.27		—		0.72		0.72
23. Temp. FGR Duct (°F)	504		504		117		541		549
24. Pstat FGR Duct (psig)	5.3		5.25		-0.15		4.4		4.4
25. Pstat S.A. Fan (psig)	0		0		—		10.0		9.8
26. Vortex FD Fan Blades	1.50		1.50		1.23		0.81		0.81
27. Vortex SA Fan Blades	—		—		—		5.7		5.6
28. SA Depth/Flow (ft/cfm)	+		+		+		4		4
29. % FGR			—		0				
30. Total Oil Burned #2/#6	0	0	—	—	—				
31. Total Gas Burned	—		—		0		0		0

DIFFUSER POSITION, IN. 6.4 6.4 2.9 2.9 2.9
STEAM VENT RATE, LB/HR 7000 6500 7600 7000 7000
GAS GUN POSITION, IN. 18.6 18.6 — — 7000

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. _____ Date _____ Location 19 _____ Engr. SOTTER
 Fuel NAT. GAS Atom. Type GUN Capacity _____
 Test Comments _____

1. Test Number	19-193	SAME	SAME	SAME	
2. Date	3-8-77	3-8-77	3-8-77	3-8-77	
3. Time	9:25	10:25	11:25	12:20	
4. Load	14,400	14,100	14,200	14,500	
5. Test Purpose	BASFLAME GAS GUN PART.	SAME	SAME	SAME	
6. Excess O ₂ Condition	NORMAL + 50X	SAME	SAME	SAME	
7. Cont. Room O ₂ (%)	3.5	3.5	3.5	3.5	
8. Pres. Furn/Windbox (iwg)	0.42 2.8	.41 2.8	.43 2.81	.43 2.8	
9. Uptake (iwg)	-.21	-.2	-.0.2	-.2	
10. Final Stm Press (psig)	96 -	99 -	96 -	96 -	
11. Drum Press (psig)	96	98	96	95	
12. F. Water P/T (psig/°F)	219 220	211 216	218 220	219 220	
13. Air FD Fan Amps	N.A.	-	-	-	
14. Air Temp @ FD Fan/CR (°F)	87 74	87 75	86 76	86 78	
15. Stack Temp (°F)	512	515	512	513	
16. Fuel Flow (CFM or GPM)					
17. Fuel Pres/Temp (psi/°F)	4.75 -	4.75 -	4.75 -	4.75	
18. Fuel Atom Pres (psig)	64	64	64	65	
19. Primary Reg. Setting	-5 -	-5 -	-5 -	-5 -	
20. FGR Reg. Setting	CLOSED	CLOSED	CLOSED	CLOSED	
21. AP Pitot FGR Duct (iwg)	CL.	CL.	CLDS.	CLOSED	
22. AP Orif. FGR Duct (iwg)	-	-	-	-	
23. Temp. FGR Duct (°F)	-	-	108	118	
24. Pstat FGR Duct (psig)	-	-	-	-	
25. Pstat S.A. Fan (psig)	-	-	-	-	
26. Vortex FD Fan Blades	1.4 "H ₂ O	1.4	1.4	1.38	
27. Vortex SA Fan Blades	-	-	-	-	
28. SA Depth/Flow (ft/cfm)	- -	- -	- -	- -	
29. % FGR	-	-	-	-	
30. Total Oil Burned #2/#6	- -	- -	- -	- -	
31. Total Gas Burned	-	-	-	-	

DIFFUSER POS., IN.

6½

6½

6½

6½

STEAM VENT RATE, LB/HR

7000

10,000

8,200

7,300

GUN POS., IN.

18½

18½

18½

18½

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. 19-15A55 Date 3-10-77 Location 19 Engr. K.Fuel #6 0.1 Atom. Type Air Capacity 17.5

Test Comments _____

	#6		#6		#6		#6		#6	
1. Test Number	19-15A55									
2. Date	3-10-77		3-10-77							
3. Time	11:20		12:00		13:00		14:00		15:10	
4. Load	14.3		14.3		14.3		14.4		14.4	
5. Test Purpose	5A55-BaseL									
6. Excess O ₂ Condition	Normal									
7. Cont. Room O ₂ (%)	2.2		2.1		2.4		2.1		2.0	
8. Drum Press (psig)	96		96		96		96		97	
9. Final Stm Press (psig)	96	-	96	-	96	-	96	-	97	-
10. F. Water P/T (psig/°F)	219	220	218	220	219	221	219	220	219	220
11. Air FD Fan Amps	-		-		door open		-		-	
12. Air Temp@FD Fan/CR(°F)	89	83	94	86	88	87	95	92	97	94
13. Stack Temp (°F)	511		511		512		513		514	
14. Fuel Flow (CPM or GPM)	535/260l.		553/260l.		535.5/260l.		553/260l.		553/260l.	
15. Fuel Pres/Temp(psi/°F)	129	193	129	193	129	194	129	195	129	195
16. Fuel Atom Pres (psig)	32.5		32.3		32.5		32.5		32.5	
17. Pres.Furn/Windbox(iwg)	.42	1.8	.45	1.78	.47	1.8	.47	1.8	.5	1.8
18. Primary Reg. Setting	-8	-	-8	-	-8	-	-8	-	-8	-
19. FGR Reg. Setting	-	-	-	-	-	-	-	-	-	-
20. Uptake (iwg)	-.18		-.18		-.18		-.16		-.16	
21. AP Pitot FGR Duct(iwg)	-		-		-		-		-	
22. AP Orif. FGR Duct(iwg)	-		-		-		-		-	
23. Temp. FGR Duct (°F)	118		119		114		121		124	
24. Pstat FGR Duct (psig)	.45		.5		.55		.5		.5	
25. Pstat S.A. Fan (psig)	-		-		-		-		-	
26. Vortex FD Fan Blades	1.15		1.12		1.16		1.15		1.15	
27. Vortex SA Fan Blades	-		-		-		-		-	
28. SA Depth/Flow (ft/cfm)	-	-	-	-	-	-	-	-	-	-
29. % FGR	0		0		0				0	
30. Total Oil Burned #2/#6	-	-	-	-	-	-	-	-	-	-
31. Total Gas Burned	-		-		-		-		-	
Diffuser Position, in	2.9		2.9		2.9		2.9		2.9	
Steam Vent rate	10.3		10.4		10.5		10.6		10.6	
Oil Gun position, in	-		-		-		-		-	

UNIT OPERATING DATA

Test No. 19-1 SASS Date 3-10-77 Location 19 Engr. KS

Fuel #6 O.I Atom. Type Air Capacity 17.5

Test Comments _____

1. Test Number	19-1 SASS						
2. Date	3-10-77						
3. Time	16:00						
4. Load	14.2						
5. Test Purpose	SASS Test						
6. Excess O ₂ Condition	Baseline Normal						
7. Cont. Room O ₂ (%)	2.2						
8. Drum Press (psig)	97						
9. Final Stm Press (psig)	97	—					
10. F. Water P/T (psig/°F)	219	220					
11. Air FD Fan Amps	Near open						
12. Air Temp@FD Fan/CR(°F)	90	90					
13. Stack Temp (°F)	518						
14. Fuel Flow (CPM or GPM)	55.53/2601.						
15. Fuel Pres/Temp(psi/°F)	129	195					
16. Fuel Atom Pres (psig)	32.5						
17. Pres.Furn/Windbox(iwg)	.5	1.81					
18. Primary Reg. Setting	-8	—					
19. FGR Reg. Setting	—	—					
20. Uptake (iwg)	-165						
21. ΔP Pitot FGR Duct(iwg)	—						
22. ΔP Orif. FGR Duct(iwg)	—						
23. Temp. FGR Duct (°F)	119						
24. Pstat FGR Duct (psig)	5						
25. Pstat S.A. Fan (psig)	—						
26. Vortex FD Fan Blades	1.13						
27. Vortex SA Fan Blades	—						
28. SA Depth/Flow (ft/cfm)	—	—					
29. % FGR	0						
30. Total Oil Burned #2/#6	—	—					
31. Total Gas Burned	—						
Diffuser Position, in	2.9						
Steam vent rate	10.5						

Data Sheet 6003-

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. 19-2 SASS Date 3-17-77 Location 19 Engr. B.
 Fuel #6 Atom. Type Air Atom. Capacity 17.54
 Test Comments Baseline SASS Test

1. Test Number	19-2 SASS									
2. Date	3-17-77									
3. Time	10:00		11:00		12:00		13:00		14:00	
4. Load	13.8		14.6		14.8		14.9		14.7	
5. Test Purpose	SASS Test									
6. Excess O ₂ Condition	Normal									
7. Cont. Room O ₂ (%)	2.6		2.3		1.8		2.0		2.1	
8. Drum Press (psig)	98		97		97		97		97	
9. Final Stm Press (psig)	98	-	97	-	97	-	97	-	97	-
10. F. Water P/T (psig/°F)	220	214	219	215	220	215	219	222	220	220
11. Air FD Fan Amps	-		-		-		-		-	
12. Air Temp@FD Fan/CR (°F)	92	82	91	82	93	85	100	90	99	89
13. Stack Temp (°F)	518		517		512		519		518	
14. Fuel Flow (CFM or GPM)	535/2601		535/2601		535/2601		5285/2601		5165/2601	
15. Fuel Pres/Temp (psi/°F)	131	212	135	212	136	211	135	212	132	212
16. Fuel Atom Pres (psig)	35		35		35.5		35		34.5	
17. Pres. Furn/Windbox (iwg)	.49	2.25	.49	2.25	.5	2.3	.5	2.25	.5	2.25
18. Primary Reg. Setting	-6	-	-6	-	-6	-	-6	-	-6	-
19. FGR Reg. Setting	-	-	-	-	-	-	-	-	-	-
20. Uptake (iwg)	-.18		-.18		-.18		-.16		-.17	
21. ΔP Pitot FGR Duct (iwg)	-		-		-		-		-	
22. ΔP Orif. FGR Duct (iwg)	-		-		-		-		-	
23. Temp. FGR Duct (°F)	114		115		117		121		122	
24. Pstat FGR Duct (psig)	.7		.7		.7		.7		.75	
25. Pstat S.A. Fan (psig)	-		-		-		-		-	
26. Vortex FD Fan Blades	1.28		1.27		1.26		1.25		1.22	
27. Vortex SA Fan Blades	-		-		-		-		-	
28. SA Depth/Flow (ft/cfm)	-	-	-	-	-	-	-	-	-	-
29. % FGR	0		0		0		0		0	
30. Total Oil Burned #2/#6	-	-	-	-	-	-	-	-	-	-
31. Total Gas Burned	-		-		-		-		-	
Diffuser Perit. in	2 7/8"		2 7/8"		2 7/8"		2 7/8"		2 7/8"	
Steam Vent Rate	12.9		10.3		10.4		10.4		10.3	

Sheet 6003-16

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. 19-2 SA65 Date 3-17-77 Location 19 Engr. K.
 Fuel #6 Atom. Type Air Capacity 17.5
 Test Comments Baseline SA65 Test

1. Test Number	19-2 SA65				
2. Date	3-17-77				
3. Time	15:00				
4. Load	14.7				
5. Test Purpose	SA65-Test				
6. Excess O ₂ Condition	Normal				
7. Cont. Room O ₂ (%)	2.4				
8. Drum Press (psig)	97				
9. Final Stm Press (psig)	97 -				
10. F. Water P/T (psig/°F)	219 220				
11. Air FD Fan Amps	-				
12. Air Temp@FD Fan/CR(°F)	90 89				
13. Stack Temp (°F)	518				
14. Fuel Flow (CFM or GPM)	54.86/2600				
15. Fuel Pres/Temp(psi/°F)	132 212				
16. Fuel Atom Pres (psig)	34.5				
17. Pres.Furn/Windbox(iwg)	.52 2.3				
18. Primary Reg. Setting	-6 -				
19. FGR Reg. Setting	- -				
20. Uptake (iwg)	-18				
21. ΔP Pitot FGR Duct(iwg)	-				
22. ΔP Orif. FGR Duct(iwg)	-				
23. Temp. FGR Duct (°F)	119				
24. Pstat FGR Duct (psig)	.75				
25. Pstat S.A. Fan (psig)	-				
26. Vortex FD Fan Blades	1.25				
27. Vortex SA Fan Blades	-				
28. SA Depth/Flow (ft/cfm)	- -				
29. % FGR	0				
30. Total Oil Burned #2/#6	- -				
31. Total Gas Burned	-				
Diffuser Posit. "	27/8				
Steam Vent Rate	10.3				

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. 19-3 SASS Date 3-21-77 Location 19 Engr. LS.Fuel #6 Atom. Type Air Capacity 175Test Comments SASS Test with Hi Recirc. & low air

1. Test Number	19-3 SASS														
2. Date	3-21-77														
3. Time	10:30		11:30		12:30		13:30		14:30						
4. Load	14.2		14.5		14.4		14.4		14.4						
5. Test Purpose	SASS														
6. Excess O ₂ Condition	low														
7. Cont. Room O ₂ (%)	1.1		1.0		1.1		.9		.8						
8. Drum Press (psig)	96		96		96		97		97						
9. Final Stm Press (psig)	96	-	96	-	96	-	97	-	97	-					
10. F. Water P/T (psig/°F)	215	220	220	220	220	220	221	220	221	220					
11. Air FD Fan Amps	-		-		-		-		-						
12. Air Temp@FD Fan/CR(°F)	99	82	100	84	99	84	100	86	102	88					
13. Stack Temp (°F)	550		551		551		551		551						
14. Fuel Flow (CPM or GPM)	52.53/26gal.		52.9/26gal.		53.6/26gal.		52.5/26gal.		53.5/26gal.						
15. Fuel Pres/Temp(psi/°F)	125	222	126	220	123	216	125	223	124	221					
16. Fuel Atom Pres (psig)	33.5		33.5		33.5		33.5		33.5						
17. Pres.Furn/Windbox(iwg)	.8	3.55	.84	3.6	.84	3.6	.86	3.6	.85	3.55					
18. Primary Reg. Setting	-8	-	-8	-	-8	-	-8	-	-8	-					
19. FGR Reg. Setting	100%	open													
20. Uptake (iwg)	-.19		-.2		-.19		-.195		-.195						
21. ΔP Pitot FGR Duct(iwg)	.1		.1		.1		.1		.1						
22. ΔP Orif. FGR Duct(iwg)	.72		.72		.72		.72		.71						
23. Temp. FGR Duct (°F)	541		541		539		540		540						
24. Pstat FGR Duct (psig) ^{H₂O}	4.5		4.5		4.5		4.45		4.4						
25. Pstat S.A. Fan (psig)	-		-		-		-		-						
26. Vortex FD Fan Blades	1.1		1.1		1.1		1.1		1.1						
27. Vortex SA Fan Blades	-		-		-		-		-						
28. SA Depth/Flow (ft/cfm)	-	-	-	-	-	-	-	-	-	-					
29. % FGR	-		-		-		-		-						
30. Total Oil Burned #2/#6	-	-	-	-	-	-	-	-	-	-					
31. Total Gas Burned	-		-		-		-		-						
Steam vent Rate	9.5		8.5		9.2		10.2		10.1						
Atom. Air Press.	25.3		25.1		25		25.3		25.2						
Diffuser Posit.	2 7/8"		2 7/8"		2 7/8"		2 7/8"		2 7/8"						

Data Sheet 6003-15

UNIT OPERATING DATA

Test No. 19-3 SASS Date 3-21-77 Location 19 Engr. KCFuel #6 Atom. Type Air Capacity 17.5Test Comments SASS Test with Hi Recirc. & Low Air

		Baseline					
1. Test Number	19-3 SASS	19-3 SASS					
2. Date	3-21-77	3-21-77					
3. Time	15:30	15:50					
4. Load	14.4	14.5					
5. Test Purpose	SASS Test	Baseline					
6. Excess O ₂ Condition	Low	normal					
7. Cont. Room O ₂ (%)	.9	1.9					
8. Drum Press (psig)	97	97					
9. Final Stm Press (psig)	97 -	97					
10. F. Water P/T (psig/°F)	221 220	221 220					
11. Air FD Fan Amps	-	-					
12. Air Temp@FD Fan/CR(°F)	100 89	98 89					
13. Stack Temp (°F)	550	518					
14. Fuel Flow (CFM or GPM)	545/2601	54/2601					
15. Fuel Pres/Temp (psi/°F)	124 221	124 221					
16. Fuel Atom Pres (psig)	33	33					
17. Pres. Furn/Windbox (iwg)	.855 3.6	.5 1.9					
18. Primary Reg. Setting	-8 -	-8 -					
19. FGR Reg. Setting	100% open	- -					
20. Uptake (iwg)	-.18	-.18					
21. ΔP Pitot FGR Duct (iwg)	.1	-					
22. ΔP Orif. FGR Duct (iwg)	.72	-					
23. Temp. FGR Duct (°F)	536	-					
24. Pstat FGR Duct (psig)	4.4	.55					
25. Pstat S.A. Fan (psig)	-	-					
26. Vortex FD Fan Blades	1.11	1.2					
27. Vortex SA Fan Blades	-	-					
28. SA Depth/Flow (ft/cfm)	- -	- -					
29. % FGR	-	0					
30. Total Oil Burned #2/#6	- -	- -					
31. Total Gas Burned	-	-					
Steam Vent Rate	10.2	10.2					
Atom. Air Press.	25.2	25.1					
Diffuser Pos.	2 7/8"	2 7/8"					

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. 19-4 SA55 Date 3-23-77 Location 19 Engr. Ku
 Fuel # 6 Atom. Type Air Capacity 17.5
 Test Comments SA55 Test with Hi Recirc & low Air

1. Test Number	19-4 SA55								
2. Date	3-23-77								
3. Time	9:30	10:30	11:40	12:30	13:30				
4. Load	14.0	14.1	14.2	14.0	14.1				
5. Test Purpose	SA55 Test								
6. Excess O ₂ Condition	low								
7. Cont. Room O ₂ (%)	.9	.8	.6	.9	.8				
8. Drum Press (psig)	96	96	96	97	97				
9. Final Stm Press (psig)	96	-	96	-	97	-	97	-	
10. F. Water P/T (psig/°F)	218	220	217	220	220	220	221	220	221
11. Air FD Fan Amps	-		-		-		-		
12. Air Temp@FD Fan/CR(°F)	92	76	94	78	96	81	98	84	98
13. Stack Temp (°F)	547		548		548		548		548
14. Fuel Flow (CPM or GPM)	52.5/2 Gal.		53.6/2 Gal		54.9/2 Gal		54.9/2 Gal.		55/2 Gal.
15. Fuel Pres/Temp (psi/°F)	127	221	128	221	123	221	123	222	123
16. Fuel Atom Pres (psig)	34		34.5		34		33.5		33.5
17. Pres. Furn/Windbox (iwg)	.72	3.4	.75	3.4	.75	3.4	.8	3.4	.8
18. Primary Reg. Setting	-8	-	-8	-	-8	-	-8	-	-8
19. FGR Reg. Setting	100% open		-		-		-		
20. Uptake (iwg)	-.19		-.2		-.2		-.16		-.18
21. ΔP Pitot FGR Duct (iwg)	.1		.1		.1		.1		.1
22. ΔP Orif. FGR Duct (iwg)	.74		.74		.74		.75		.75
23. Temp. FGR Duct (°F)	537		538		539		538		536
24. Pstat FGR Duct (psig)	4.35		4.4		4.35		4.4		4.35
25. Pstat S.A. Fan (psig)	-		-		-		-		-
26. Vortex FD Fan Blades	1.05		1.05		1.03		1.0		1.03
27. Vortex SA Fan Blades	-		-		-		-		-
28. SA Depth/Flow (ft/cfm)	-	-	-	-	-	-	-	-	-
29. % FGR	-		-		-		-		-
30. Total Oil Burned #2/#6	-	-	-	-	-	-	-	-	-
31. Total Gas Burned	-		-		-		-		-
Diffuser position "	2 7/8		2 7/8		2 7/8		2 7/8		2 7/8
Air Atom Press psig	26.8		26.9		26.8		26.5		26.2
Steam vented	6.0		8.5		9.0		8.7		9.9

Data Sheet 6003-16

UNIT OPERATING DATA

Test No. 19-45A55 Date 3-23-77 Location 19 Engr. K.Fuel #6 Atom. Type Air Capacity 17.5Test Comments 5A55 Test. Hi Recirc. Low Air

		<u>Baseline</u>			
1. Test Number	19-45A55	19-45A55			
2. Date	3-23-77	3-23-77			
3. Time	14:50	15:05			
4. Load	14.4	14.2			
5. Test Purpose	5A55 Test	Baseline			
6. Excess O ₂ Condition	low	normal			
7. Cont. Room O ₂ (%)	.8	2.1			
8. Drum Press (psig)	97	97			
9. Final Stm Press (psig)	97	97	-	-	
10. F. Water P/T (psig/°F)	221	220	221	220	
11. Air FD Fan Amps	-	-			
12. Air Temp@FD Fan/CR (°F)	98	86	90	84	
13. Stack Temp (°F)	548	518			
14. Fuel Flow (CEM or GPM)	55.8/2601	53.4/2601			
15. Fuel Pres/Temp (psi/°F)	124	222	126	221	
16. Fuel Atom Pres (psig)	33.5	33.5			
17. Pres. Furn/Windbox (iwg)	.81	3.45	.5	1.8	
18. Primary Reg. Setting	-8	-	-	-	
19. FGR Reg. Setting	100% open	closed			
20. Uptake (iwg)	-.2	-.19			
21. ΔP Pitot FGR Duct (iwg)	.1	-			
22. ΔP Orif. FGR Duct (iwg)	.75	-			
23. Temp. FGR Duct (°F)	540	-			
24. Pstat FGR Duct (psig)	4.35	.6			
25. Pstat S.A. Fan (psig)	-	-			
26. Vortex FD Fan Blades	1.01	1.1			
27. Vortex SA Fan Blades	-	-			
28. SA Depth/Flow (ft/cfm)	-	-	-	-	
29. % FGR	-	0			
30. Total Oil Burned #2/#6	-	-	-	-	
31. Total Gas Burned	-	-			

Diffuser Pos. 2 7/8"
 Air Atom. Press. psig 26.1
 steam vented 9.4

2 7/8"
 25.9
 9.3

Data Sheet 6003-16

LOCATION 19

FUEL GAS CHROMATOGRAPHIC ANALYSIS

Test 19-190

March 7, 1977

Oxygen	< 0.009% by volume
Nitrogen	0.29
Carbon Dioxide	0.54
Methane	95.84
C 2	2.92
C 3	0.22
C 4	0.099
C 5	0.039
C 6 plus	0.054
Heating Value	1035 BTU/SCF (dry)

Fuel Date Laboratory No.	#2 Oil 1/6/77 13520	#2 Oil 1/10/77 13520	#2 Oil 1/19/77 14009	#6 Oil 12/15/76 13042	#6 Oil 1/19/77 14009	#6 Oil 2/16/77 14667	#6 Oil 3/2/77 14667	#6 Oil 3/10/77 16554	#6 Oil 3/17/77 16554	#6 Oil 3/21/77 16554	#6 Oil 3/23/77 16554
Carbon, %	86.45	85.62	86.49	87.55	86.91	87.55	87.30	87.23	86.06	86.25	86.55
Hydrogen, %	13.01	12.99	13.17	11.49	11.78	11.40	11.34	11.34	11.11	11.25	11.26
Nitrogen, %	<0.001	<0.001	0.008	0.20	0.20	0.23	0.22	0.23	0.32	0.32	0.30
Sulfur, %	0.16	0.10	0.14	0.56	0.54	0.60	0.60	0.55	1.17	1.18	1.02
Ash, %	<0.001	<0.001	0.001	0.020	0.019	0.034	0.026	0.027	0.025	0.024	0.025
Oxygen, %	0.38	1.09	0.19	0.18	0.55	0.19	0.51	0.62	1.32	0.98	0.85
API Gravity	37.8	37.7	37.5	20.7	20.7	17.0	17.3	17.5	14.3	15.7	15.8
HHV, Btu/lb	19,680	19,680	19,610	18,910	19,000	18,780	18,850	18,850	18,670	18,740	18,750
HHV, kJ/kg	45,775	45,775	45,613	43,984	44,194	43,682	43,845	43,845	43,426	43,589	43,613

PLANT
 LOCATION 19
 OPERATOR C. SOTTER
 DATE 1-6-77
 RUN NO. 19-5
 SAMPLE BOX NO. _____
 METER BOX NO. _____
 METER H _____
 C FACTOR @ _____

METHOD 5 CONTROL CONSOLE READINGS



AMBIENT TEMPERATURE 10°F
 BAROMETRIC PRESSURE 30.25
 ASSUMED MOISTURE, % _____
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. _____
 NOZZLE DIAMETER, IN. 1/2
 PROBE HEATER SETTING _____

Method 5

SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P _g), In. Hg.	Stack Temperature (T _s) °F	Velocity Head (P _s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V _m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet (T _{min.}) °F	Outlet (T _{mout}) °F		
	0935		470	.086	1.45	2210.00		70	370	50
	0950		475	.086	1.45	2223.00		75	365	58
	1005		475	.086	1.45	2235.50		85	360	75
	1020		480	.086	1.45	2249.00		90	365	60
	1035		480	.086	1.45	2261.50		95	365	60
	1048		480	.086	1.45	2272.00		100	365	62
	73 min									
TOTAL			477	.086		6200		AVG.	AVG.	
AVERAGE								AVG.		

110

PARTICULATE CALCULATION SHEET

Test No. 19-5 Date 1-6-76 Location 19 Test Crew R. PIONESEA
 Box No. 1 Sample Probe Position CENTER
 Test Description BASELINE #2 OIL Method 5

Dry Gas Meter Vol. (ft³)
 Final 2272.00
 Initial 2210.00
 Total 62.00

		Impinger Water Vol (ml)				
		1	2	3	S. Gel	Total
Final		180	149	2	681.2	1012.2
Initial		100	100	0	659.0	859.0
Δ Vol		80	49	2	22.2	153.2

Beaker No.	1	3	4	5	6	Filter No. 13	Blank No. 14
Date Weighed	1/5/77					1/5/77	1/5/77
Tare	1 100.0785	101.9848	99.2665	98.9340	100.4849	.8529	.8452
Wt.	2 100.0782	101.9847	99.2663	98.9338	100.4849	.8529	.8454
	3						
	4						
	5						
	6						
Avg	100.0784	101.9848	99.2664	98.9339	100.4849	.8529	.8453
Bottle No.							
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)		
Rinse (ml)	735	485	310	200	200		
Date Weighed or 250 Bake	1/18/77					1/18/77	
Final	1 100.1992	101.9914	99.2727	98.9373	100.4884	.8698	.8452
Wt. 250	2 100.1994	101.9919	99.2724	98.9371	100.4884	.8699	.8453
	3						
	4						
	5						
	6						
Avg	100.1993	101.9917	99.2726	98.9372	100.4887	.8694	.8453
Residue wt	.1209	.0069	.0062	.0033	.0038	.0170	-
Final 250-Tare							
Date Weighed or 650 Bake							
Final	1						
Wt. 650	2						
	3						
	4						
	5						
	6						
Avg							
Residue Wt							
Final 650-Tare							

Comments:

Data Sheet 6002-3

TOTAL PARTICULATE EMISSION CALCULATIONS

Test No. 19-5 Date 1/6/77 Location 19 Engr. C. SOTTEL

Unit No. 1 Fuel #2 OIL Sampling Train and Method EPA Method 5

Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 30.25 in. Hg

Tot. Liquid Collected, V_{lc} 153.2 ml Total Particulate, M_n 147.6 mg

Velocity Head, ΔP .086 iwg Stack Temp., T_s 937 °R Stack Area, A_s 4.9 ft²

Sample Volume, V_m 62.0 ft³ Stack Press., P_{sg} -.2 iwg Excess O₂, XO_2 % 3.2 %

Orifice Press. Diff., H 1.45 iwg Stack Gas Sp. Gravity, G_s 1.00 n.d.

Sample Time, θ 73 min Nozzle Dia., D_n 1/2 in. Meter Temp., T_m 546 °R

*1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 62.86 SCF

2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 7.26 SCF

3. Moisture Content $B_{w0} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.104 N.D.

4. Concentration a. $C = 0.0154 M_n / V_{m_{std}}$.0362 grains/DSCF

b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 5.178×10^{-6} lb/DSCF

c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 8.293×10^{-2} grams/DSCM

5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 411.8 in. w abs.

6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1288 ft/min

7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3612 WSCF/min

b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3236 DSCF/min

8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 1.005 lb/hr

9. XO₂ factor $XO_{2f} = 2090 / (20.9 - XO_2\%)$ 118.1 N.D.

10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 5.638×10^{-2} lb/MMBtu

b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 24.24 ng/joule

11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 95.6 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

SOLID PARTICULATE EMISSION CALCULATIONS

Test No. 19-5 Date 1-6-77 Location _____ Engr. G. SOTTER

Unit No. 1 Fuel #2 OIL Sampling Train and Method _____

Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 30.25 in. Hg

Tot. Liquid Collected, V_{lc} 153.2 ml ~~SOLID~~ ^{SOLID} Particulate, M_n 15.8 mg

Velocity Head, ΔP 0.086 iwg Stack Temp., T_s 937 °R Stack Area, A_s 4.90 ft²

Sample Volume, V_m 62.0 ft³ Stack Press., P_{sg} 0.2 iwg Excess O₂, XO_2 % 3.2 %

Orifice Press. Diff., H 1.45 iwg Stack Gas Sp. Gravity, G_s 1.0 n.d.

Sample Time, θ 7.3 min Nozzle Dia., D_n 1/2 in. Meter Temp., T_m 546 °R

*1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 62.86 SCF

2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 7.26 SCF

3. Moisture Content $B_{wo} = \text{Eq. 2}/(\text{Eq. 1} + \text{Eq. 2})$ 0.104 N.D.

4. Concentration a. $C = 0.0154 M_n/V_{m_{std}}$ 0.00387 grains/DSCF

b. $C = 2.205 \times 10^{-6} M_n/V_{m_{std}}$ 5.542×10^{-7} lb/DSCF

c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 8.878×10^{-3} grams/DSCM

5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 411.8 in. w abs.

6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P T_s} \sqrt{\frac{407}{P_s} \times \frac{1.00}{G_s}}$ 1288 ft/min

7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 36.2 WSCF/min

b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3236 DSCF/min

8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 1.076×10^{-1} lb/hr

9. XO₂ factor $XO_{2f} = 2090/(20.9 - XO_2\%)$ 118.1 N.D.

10. Emission a. $E = \text{Eq. 4b} \times F_m \times \text{Eq. 9}$ 6.03×10^{-3} lb/MMBtu

b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 2.595 ng/joule

11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 95.6 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

No. 20:1

--	--

BASELINE	FINAL METER	2302.14
	START	2272.14
		30.00

Traverse Point Number	Sampling Time (t) Min.	Static Pressure (P_s), In. Hg. wg		Stack Temperature (T_s) °F		Velocity Head (P_s) wg		Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume Meter Reading (V_m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
		Inlet	Outlet	Inlet ($T_{min.}$) °F	Outlet ($T_{mout.}$) °F								
	1520	-0.2		475		0.086		0.65	2272.14	85	NA	NA	NA
	1530								2278.24	90			
	1540								2284.40	90			
	1550								2290.30	95			
	1600								2295.60	100			
	1610								2301.00	103			
	1612:20	↓		↓		↓		↓	2302.14		↓	↓	↓
TOTAL											AVG.	AVG.	
AVERAGE											AVG.		

1-6-77

ANDERSEN CASCADE IMPACTOR DATA

Test No. 19-7 Location 19 Owner _____
 Impactor No. 1 Nozzle Size 3/8 Filter No. 1
 Stack Temperature 475 °F Impactor Flow Rate 0.577 CFM $G = 1.24$

Plate	Tare (g)	Final (g)	Net (g)	%	Cum. %	ECD (μ)
1	27.3058 27.3065 > 27.3061	27.3100	0.0039	16.1	100.0	(12.7) $\times 1.24 = 15.7$
2	28.4141 28.4145 > 28.4143	28.4180	0.0037	15.3	83.9	(8.0) $\rightarrow$ 9.9
3	29.2128 29.2131 > 29.2130	29.2163	0.0033	13.6	68.6	(5.3) $\rightarrow$ 6.6
4	21.9732 21.9735 > 21.9734	21.9760	0.0026	10.7	55.0	(3.7) $\rightarrow$ 4.6
5	17.8934 17.8934 > 17.8934	17.8964	0.0030	12.4	44.3	(2.3) $\rightarrow$ 2.8
6	17.9086 17.9086 > 17.9085	17.9113	0.0028	11.6	31.9	(1.2) $\rightarrow$ 1.5
7	17.9875 17.9869 > 17.9872	17.9895	0.0023	9.5	20.3	(.73) $\rightarrow$.90
8	28.4004 28.4003 > 28.4004	28.4024	0.0020	8.3	10.8	(.49) $\rightarrow$.61
Back Up Filter	21.7915 21.7922 > 21.7919	21.7925	0.0006	2.5	2.5	

Total 0.0242 100.0

PARTICULATE EMISSION CALCULATIONS

Test No. 19-7 Date 1-6-77 Location 19 Engr. _____
 Unit No. _____ Fuel No. 2 Oil Sampling Train and Method Anderson Impactor
 Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 30.06 in. Hg
 Tot. Liquid Collected, V_{lc} 74 ml Total Particulate, M_n 24.2 mg
 Velocity Head, ΔP 0.086 iwg Stack Temp., T_s 935 °R Stack Area, A_s 4.9 ft²
 Sample Volume, V_m 30 ft³ Stack Press., P_{sg} -0.2 iwg Excess O₂, XO_2 % 2.95 %
 Orifice Press. Diff., H 0.65 iwg Stack Gas Sp. Gravity, G_s 1.0 n.d.
 Sample Time, θ 52.3 min Nozzle Dia., D_n 3/8 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 30.17 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc} .104 (30.17 + V_{w_{std}}) = V_{w_{std}}$ 3.50 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$.104 N.D.
4. Concentration
 - a. $C = 0.0154 M_n / V_{m_{std}}$ 0.0124 grains/DSCF
 - b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 1.77×10^{-6} lb/DSCF
 - c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.0283 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 408.6 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1295 ft/min
7. Stack Gas Flow
 - a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3597 WSCF/min
 - b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3223 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 0.342 lb/hr
9. XO₂ factor $XO_{2f} = 2090 / (20.9 - XO_2 \%)$ 116.4 N.D.
10. Emission
 - a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.019 lb/MMBtu
 - b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 8.16 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 114 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636


*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

$$\frac{30.17 \text{ SCF}}{52.3 \text{ min}} = 0.577 \text{ SCFM}$$

PLANT
 LOCATION 19
 OPERATOR
 DATE 1-19-77
 RUN NO. 19-74
 SAMPLE BOX NO.
 METER BOX NO.
 METER H
 C FACTOR @

METHOD 5 CONTROL CONSOLE READINGS



AMBIENT TEMPERATURE
 BAROMETRIC PRESSURE 29.73
 ASSUMED MOISTURE, %
 HEATER BOX SETTING
 PROBE LENGTH, IN. 48
 NOZZLE DIAMETER, IN. 1/2
 PROBE HEATER SETTING

SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P _s), In. Hg.	Stack Temperature (T _s) °F	Velocity Head (P _s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V _m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet (T _{min.}) °F	Outlet (T _{mout}) °F		
	1120		475	.85	1.45	2302.34		65	310	45
	1121	SHUT DOWN				2303.66		-	-	-
RESTART	1128		475	.85	1.45	2303.66		65	310	46
	1137		480	.85	1.45	2311.5		65	305	50
	1145		480	.85	1.45	2321.00		75	340	70
	1157		480	.85	1.45	2330.0		75	340	75
	1207		480	.85	1.45	2338.00		80	325	60
	1217		480	.85	1.45	2347.50		90	330	50
	1227		485	.85	1.45	2355.00		90	330	50
	1238		490	.85	1.45	2364.09				
	71 MIN									
TOTAL						61.75		AVG.	AVG.	
AVERAGE								AVG.		

117

PARTICULATE CALCULATION SHEET

Test No. 19-74 Date 1-19-77 Location 19 Test Crew _____
 Box No. _____ Sample Probe Position _____
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final 2364.09

Initial 2302.34

Total 61.75

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	195	150	10	680.5	
Initial	100	100	0	660.0	
Δ Vol	95	50	10	20.5	175.5

Beaker No.					Filter No.	Blank No.
					15	16
Date Weighed						
Tare	1	104.0052	99.3368	100.1855	.8512	.7999
Wt.	2	104.0051	99.3365	100.1855	.8514	.7999
	3					.8000
	4					
	5					
	6					
Avg		104.0052	99.3367	100.1855	.8513	.7999
Bottle No.						
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)	
Rinse (ml)	490	175	190			
Date Weighed or 250 Bake						
Final	1	104.0740	99.3465	100.1896	.8768	.7999
Wt. 250	2	104.0742	99.3468	100.1895	.8770	.7999
	3					
	4					
	5					
	6					
Avg		104.0741	99.3467	100.1896	.8769	.7999
Residue wt		.0689	.0100	.0041	.0256	0
Final 250-Tare						
Date Weighed or 650 Bake						
Final	1					
Wt. 650	2					
	3					
	4					
	5					
	6					
Avg						
Residue Wt						
Final 650-Tare						

Comments:

Data Sheet 6002-3

SOLID PARTICULATE EMISSION CALCULATIONS

Test No. 19-74 Date 1-19-77 Location 19 Engr. C. SOTTER

Unit No. 1 Fuel #2 OIL Sampling Train and Method Method 5

Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 29.73 in. Hg

Tot. Liquid Collected, V_{lc} 175.5 ml ^{SOLID} ~~Total~~ Particulate, M_n 39.7 mg

Velocity Head, ΔP .085 iwg Stack Temp., T_s 940 °R Stack Area, A_s 4.90 ft²

Sample Volume, V_m 61.75 ft³ Stack Press., P_{sg} .72 iwg Excess O₂, XO_2 % 1.1 %

Orifice Press. Diff., H 1.45 iwg Stack Gas Sp. Gravity, G_s 1.0 n.d.

Sample Time, θ 71 min Nozzle Dia., D_n 1/2 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 61.54 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 8.32 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$.119 N.D.
4. Concentration
 - a. $C = 0.0154 M_n / V_{m_{std}}$ 0.0272 grains/DSCF
 - b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 3.891×10^{-6} lb/DSCF
 - c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 6.233×10^{-2} grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 404.1 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1296 ft/min
7. Stack Gas Flow
 - a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3554 WSCF/min
 - b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3131 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 7.31×10^{-1} lb/hr
9. XO₂ factor $XO_2^f = 2090 / (20.9 - XO_2\%)$ 105.6 N.D.
10. Emission
 - a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$.0138 lb/MMBtu
 - b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 5.95 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 99.4 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

TOTAL PARTICULATE EMISSION CALCULATIONS

Test No. 19-74 Date 1-19-77 Location 19 Engr. G. SOTTER
 Unit No. 1 Fuel #2 OIL Sampling Train and Method Method 5
 Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 29.73 in. Hg
 Tot. Liquid Collected, V_{lc} 175.5 ml Total Particulate, M_n 108.6 mg
 Velocity Head, ΔP .025 iwg Stack Temp., T_s 940 °R Stack Area, A_s 4.90 ft²
 Sample Volume, V_m 61.75 ft³ Stack Press., P_{sg} -.2 iwg Excess O₂, XO_2 % 1.1
 Orifice Press. Diff., H 1.45 iwg Stack Gas Sp. Gravity, G_s 1.0 n.d.
 Sample Time, θ 71 min Nozzle Dia., D_n 1/2 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 61.54 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 8.32 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$.119 N.D.
4. Concentration a. $C = 0.0154 M_n / V_{m_{std}}$ 0.0272 grains/DSCF
 b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 3.89×10^{-6} lb/DSCF
 c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 6.233×10^{-2} grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 404.1 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1296 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3554 WSCF/min
 Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3131 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 7.31×10^{-1} lb/hr
9. XO₂ factor $XO_2 f = 2090 / (20.9 - XO_2 \%)$ 105.6 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.0379 lb/MMBtu
 b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 16.29 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 99.4 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by 530/ T_m (°R) if meter not temp. compensated.

Data Sheet 6002-4

NO. 2 oil

--

$$\frac{3}{8}$$

SCHEMATIC OF STACK CROSS SECTION

[illegible]

121

ANDERSEN CASCADE IMPACTOR DATA

Test No. 19-76 Location 19 Owner _____
 Impactor No. 1 Nozzle Size 3/8 Filter No. _____
 Stack Temperature 480 °F Impactor Flow Rate 0.588 CFM
 $C_T = 1.245$

Plate	Tare (g)	Final (g)	Net (g)	%	Cum. %	ECD (μ)
1	27.3071	27.3102	0.0031	10.5	100.0	(12.5) 15.6
2	28.4153	28.4180	0.0027	9.2	89.5	(7.9) 9.8
3	29.2111	29.2145	0.0034	11.6	80.3	(5.2) 6.5
4	21.9722	21.9757	0.0035	11.9	68.7	(3.7) 4.6
5	17.8959	17.8992	0.0033	11.2	56.8	(2.3) 2.9
6	17.9064	17.9094	0.0030	10.2	45.6	(1.2) 1.5
7	18.0016	18.0033	0.0027	9.2	35.4	(0.73) 0.91
8	28.4008	28.4036	0.0028	9.5	26.2	(0.40) 0.60
Back Up Filter	21.7920	21.7969	0.0049	16.7	16.7	

Total 0.0294 100.0

PARTICULATE EMISSION CALCULATIONS

Test No. 19-76 Date 1/19/77 Location 19 Engr. _____
 Unit No. _____ Fuel No. 2 Oil Sampling Train and Method Anderson Impactor
 Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 29.73 in. Hg
 Tot. Liquid Collected, V_{lc} 85 ml Total Particulate, M_n 29.4 mg
 Velocity Head, ΔP 0.085 iwg Stack Temp., T_s 940 °R Stack Area, A_s 4.90 ft²
 Sample Volume, V_m 30 ft³ Stack Press., P_{sg} -0.2 iwg Excess O₂, $XO_2\%$ 1.08 %
 Orifice Press. Diff., H 0.65 iwg Stack Gas Sp. Gravity, G_s 1.0 n.d.
 Sample Time, θ 51 min Nozzle Dia., D_n 3/8 in. Meter Temp., T_m 542 °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 29.84 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 4.03 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.119 N.D.
4. Concentration
 - a. $C = 0.0154 M_n / V_{m_{std}}$ 0.015 grains/DSCF
 - b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 2.17×10^{-6} lb/DSCF
 - c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.035 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 404.1 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1296 ft/min
7. Stack Gas Flow
 - a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3554 WSCF/min
 - b. $Q_{sd} = \text{Eq. 7a} \times (1. - XO_2\%)$ 3131 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 0.408 lb/hr
9. XO_2 factor $XO_{2f} = 2090 / (20.9 - XO_2\%)$ 105.4 N.D.
10. Emission
 - a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.021 lb/MMBtu
 - b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 9.07 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 119.3 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

$$\frac{30}{51} \frac{ft^3}{min} = 0.588 \frac{ft^3}{min}$$

124

SCHEMATIC OF STACK CROSS SECTION

[illegible]

PARTICULATE CALCULATION SHEET

Test No. 19-83,84 Date 1-20-77 Location _____ Test Crew R. PIONESSA
 Box No. 1 Sample Probe Position CENTER
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final 2460.68
 Initial 2394.52
 Total 66.16

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	210	152	6	682.0	1050.0
Initial	100	100	0	659.0	859.0
Δ Vol	110	52	6	23.0	191.0

Beaker No.	10	11	12	3	1	Filter No. 17	Blank No. 18
Date Weighed	1-5-77						
Tare	1 100.9386	99.8094	100.9727	101.9838	100.0775	.8505	.8039
Wt.	2 100.9385	99.8092	100.9725	101.9839	100.0771	.8505	.8040
	3						
	4						
	5						
	6						
Avg	100.9386	99.8093	100.9726	101.9839	100.0776	.8505	.8040
Bottle No.							
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)		
Rinse (ml)	775	500	350	200	200		
Date Weighed or 250 Bake	1-24-77					1-21-77	
Final	1 100.9756	99.8140	100.9752	101.9855	100.0880	.8655	.8037
Wt. 250	2 100.9752	99.8140	100.9751	101.9855	100.0796	.8656	.8035
	3						
	4						
	5						
	6						
Avg	100.9754	99.8140	100.9752	101.9855	100.0798	.8656	.8036
Residue wt	.0368	.0047	.0026	.0016	.0022	.0151	-.0004
Final 250-Tare							
Date Weighed or 650 Bake							
Final	1						
Wt. 650	2						
	3						
	4						
	5						
	6						
Avg							
Residue Wt							
Final 650-Tare							

Comments:

Data Sheet 6002-3

SOLID PARTICULATE EMISSION CALCULATIONS

Test No. 19-83,84 Date 1-20-77 Location TECH Engr. R. PIONESEA
 Unit No. 1 Fuel #2 OIL Sampling Train and Method Method 5
 Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 29.80 in. Hg
 Tot. Liquid Collected, V_{lc} 191 ml ^{SOLID} ~~LIQUID~~ Particulate, M_n 14.2 mg
 Velocity Head, ΔP .092 iwg Stack Temp., T_s 1000 °R Stack Area, A_s 4.9 ft²
 Sample Volume, V_m 66.16 ft³ Stack Press., P_{sg} -2.25 iwg Excess O₂, $XO_2\%$.85 %
 Orifice Press. Diff., H 1.57 iwg Stack Gas Sp. Gravity, G_s n.d.
 Sample Time, θ 75 min Nozzle Dia., D_n 1/2 in. Meter Temp., T_m °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 66.11 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 9.05 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.120 N.D.
4. Concentration
 - a. $C = 0.0154 M_n / V_{m_{std}}$.0033 grains/DSCF
 - b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$.474 x 10⁻⁶ lb/DSCF
 - c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$.758 x 10⁻² grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 405 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1388 ft/min
7. Stack Gas Flow
 - a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3588 WSCF/min
 - b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3158 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$.898 x 10⁻¹ lb/hr
9. XO₂ factor $XO_{2f} = 2090 / (20.9 - XO_2\%)$ 103.98 N.D.
10. Emission
 - a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$.454 x 10⁻² lb/MMBtu
 - b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 1.95 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 100.4 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by 530/ T_m (°R) if meter not temp. compensated.

Data Sheet 6002-4

TOTAL PARTICULATE EMISSION CALCULATIONS

Test No. 19-83,84 Date 1-20-77 Location 19 TECH R. PIONESEA

Unit No. 1 Fuel #2 OIL Sampling Train and Method Method 5

Pitot Factor, Fs .83 Barometric Pressure, P_{bar} 29.80 in. Hg

Tot. Liquid Collected, V_{lc} 191 ml Total Particulate, M_n 42.5 mg

Velocity Head, ΔP .092 iwg Stack Temp., Ts 1000 °R Stack Area, As 4.90 ft²

Sample Volume, Vm 66.16 ft³ Stack Press., Psg .225 iwg Excess O₂, XO₂ % .85 %

Orifice Press. Diff., H 1.57 iwg Stack Gas Sp. Gravity, Gs n.d.

Sample Time, θ 75 min Nozzle Dia., Dn 1/2 in. Meter Temp., T_m °R

- *1. Sample Gas Volume Vm_{std} = 0.0334 Vm(P_{bar} + H/13.6) 66.11 SCF
2. Water Vapor Vw_{std} = 0.0474 V_{lc} 9.05 SCF
3. Moisture Content Bwo = Eq. 2/(Eq. 1 + Eq. 2) 0.120 N.D.
4. Concentration a. C = 0.0154 Mn/Vm_{std} .0099 grains/DSCF
b. C = 2.205 x 10⁻⁶ Mn/Vm_{std} 1.418 x 10⁻⁶ lb/DSCF
c. C = Eq. 4b x 16.018 x 10³ 2.270 x 10⁻² grams/DSCM
5. Abs. Stack Press. Ps = P_{bar} x 13.6 + Psg 405.0 in. w abs.
6. Stack Gas Speed Vs = 174 Fs √(ΔP/Ts) x (1.00/Gs) 1388 ft/min
7. Stack Gas Flow a. Qsw = Eq. 6 x As x (530/Ts) x (Ps/407) 3588 WSCF/min
Rate @ 70°F b. Qsd = Eq. 7a x (1. - Eq. 3) 3158 DSCF/min
8. Material Flow Ms = Eq. 7b x Eq. 4b x 60 2.687 x 10⁻¹ lb/hr
9. XO₂ factor XO₂f = 2090/(20.9 - XO₂%) 103.98 N.D.
10. Emission a. E = Eq. 4b x Fe x Eq. 9 1.359 x 10⁻² lb/MMBtu
b. E = Eq. 4c x Fm x Eq. 9 x 1000 5.84 ng/joule
11. % Isokinetic I = (14077 x Ts (Vm_{std} + Vw_{std})) / (θ x Vs x Ps x Dn²) 100.4 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply Vm_{std} by 530/T_m (°R) if meter not temp. compensated.

Data Sheet 6002-4

No. 2011

--	--

AMBIENT TEMPERATURE 39.1°
 BAROMETRIC PRESSURE 27.8 in Hg
 ASSUMED MOISTURE, % _____
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. _____
 NOZZLE DIAMETER, IN. 3/8
 PROBE HEATER SETTING _____

ANDERSON IMPACTOR

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P_s), In. Hg. H_2O	Stack Temperature (T_s) °F	Velocity Head (P_s) (inwg)	Pressure Differential Across Orifice Meter (ΔH), In. H_2O	Gas Sample Volume Meter Reading (V_m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet ($T_{min.}$) °F	Outlet ($T_{mout.}$) °F		
	1602:30		540	0.092	0.7	2461.03	100	NA	NA	60
	1615:00					2468.20	120			60
	1630:00					2477.00	110			60
	1645:00		↓			2486.00	100	↓	↓	63
	1655:30			↓	↓	2491.03				
						30.0				
TOTAL								AVG.	AVG.	
AVERAGE								AVG.		

ANDERSEN CASCADE IMPACTOR DATA

Test No. 19-85 Location 19 Owner _____
 Impactor No. 1 Nozzle Size 3/8 Filter No. _____
 Stack Temperature _____ °F Impactor Flow Rate _____ CFM

Plate	Tare (g)	Final (g)	Net (g)	%	Cum. %	ECD (μ)
1	27.3108	27.3124	0.0016	13.6	100.0	(12.5) 15.9
2	28.4147	28.4164	0.0017	14.4	86.4	(7.0) 8.9
3	29.2168	29.2183	0.0015	12.7	72.0	(5.2) 6.6
4	21.9719	21.9734	0.0015	12.7	59.3	(3.7) 4.7
5	17.8959	17.8975	0.0016	13.6	46.6	(2.4) 3.1
6	17.9086	17.9097	0.0011	9.3	33.0	(1.2) 1.5
7	17.9875	17.9888	0.0013	11.0	23.7	(0.73) 0.93
8	28.4043	28.4058	0.0015	12.7	12.7	(0.49) 0.62
Back Up Filter	21.7923	21.7923	0	0	0	0 0

1-20-77

1-21-77

Total 0.0118

PARTICULATE EMISSION CALCULATIONS

Test No. 19-85 Date 1-20-77 Location 19 Engr. _____
 Unit No. 1 Fuel NO.2 OIL Sampling Train and Method Anderson Impactor
 Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 29.80 in. Hg
 Tot. Liquid Collected, V_{lc} 86 ml Total Particulate, M_n 11.8 mg
 Velocity Head, ΔP 0.092 iwg Stack Temp., T_s 1000 °R Stack Area, A_s 4.9 ft²
 Sample Volume, V_m 30.0 ft³ Stack Press., P_{sg} -0.225 iwg* Excess O₂, $XO_2\%$.68 %
 Orifice Press. Diff., H 0.7 iwg Stack Gas Sp. Gravity, G_s 1.0 n.d.
 Sample Time, θ 53 min Nozzle Dia., D_n 3/8 in. Meter Temp., T_m 567 °R

- *1. Sample Gas Volume $V_{mstd} = 0.0334 V_m (P_{bar} + H/13.6)$ 29.41 SCF
2. Water Vapor $V_{wstd} = 0.0474 V_{lc}$ 4.08 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.120 N.D.
4. Concentration a. $C = 0.0154 M_n / V_{mstd}$ 0.00618 grains/DSCF
 b. $C = 2.205 \times 10^{-6} M_n / V_{mstd}$ 0.884 \times 10^{-6} lb/DSCF
 c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.0142 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 405.0 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1388 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3588 WSCF/min
 Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3157 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 0.167 lb/hr
9. XO₂ factor $XO_2 f = 2090 / (20.9 - XO_2\%)$ 103.4 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.00843 lb/MMBtu
 b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 3.624 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{mstd} + V_{wstd})}{\theta \times V_s \times P_s \times D_n^2}$ 114 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

$$\frac{29.91}{52} \text{ SCFM} = 0.575 \text{ Scfm}$$

*Multiply V_{mstd} by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

* Assumed from 462P

131

PARTICULATE CALCULATION SHEET

Test Crew R. PIONESEATest No. 19-97, 98 Date 1-24-77 Location 19

Box No. _____ Sample Probe Position _____

Test Description _____

Dry Gas Meter Vol. (ft³)Final 2554.80Initial 2491.35Total 63.45

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	166	146	3	672.5	987.5
Initial	100	100	0	650.5	850.5
Δ Vol	66	46	3	22.0	137.0

		ACETONE BLANK		H ₂ O BLANK		Filter No. 14	Blank No. 16
Beaker No.	4	5	6	7	8		
Date Weighed	1-21-77						
Tare	1 99.2650	98.9319	100.4839	104.0054	99.3369	.8452	.7999
Wt.	2 99.2650	98.9320	100.4840	104.0054	99.3366	.8454	.7999
	3						.8000
	4						
	5						
	6						
Avg	99.2650	98.9320	100.4840	104.0054	99.3368	.8453	.7999
Bottle No.							
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)		
Rinse (ml)	750	550	350	200	200		
Date Weighed or 250 Bake	1-26-77	1-25-77					
Final	1 99.3202	98.9426	100.5026	104.0048	99.3365	.9228	.7999
Wt. 250	2 99.3200	98.9427	100.5026	104.0046	99.3365	.9228	.7998
	3						
	4						
	5						
	6						
Avg	99.3201	98.9427	100.5026	104.0047	99.3365	.9228	.7999
Residue wt	.0551	.0107	.0186	.0007	.0003	.0775	0
Final 250-Tare							
Date Weighed or 650 Bake							
Final	1						
Wt. 650	2						
	3						
	4						
	5						
	6						
Avg							
Residue Wt							
Final 650-Tare							

Comments:

Data Sheet 6002-3

SOLID PARTICULATE EMISSION CALCULATIONS

Test No. 19-87,98 Date 1-24-77 Location 19 Engr. C. SCOTTER

Unit No. 1 Fuel #6 oil Sampling Train and Method Method 5

Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 30.16 in. Hg

Tot. Liquid Collected, V_{lc} 137.0 ml SOLID Particulate, M_n 171.8 mg

Velocity Head, ΔP .095 iwg Stack Temp., T_s 950 °R Stack Area, A_s 4.90 ft²

Sample Volume, V_m 63.45 ft³ Stack Press., P_{sg} -.225 iwg Excess O₂, XO_2 % 3.15 %

Orifice Press. Diff., H 1.65 iwg Stack Gas Sp. Gravity, G_s n.d.

Sample Time, θ 68 min Nozzle Dia., D_n 1/2 in. Meter Temp., T_m °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 64.17 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 6.49 SCF
3. Moisture Content $B_{w0} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$.092 N.D.
4. Concentration a. $C = 0.0154 M_n / V_{m_{std}}$.0412 grains/DSCF
b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 5.903 lb/DSCF
c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.946×10^{-1} grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 409.95 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / T_s} \sqrt{\frac{407}{P_s} \times \frac{1.00}{G_s}}$ 1367 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3764 WSCF/min
Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3418 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 1.210 lb/hr
9. XO₂ factor $XO_2 f = 2090 / (20.9 - XO_2 \%)$ 117.7 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 6.406×10^{-2} lb/MMBtu
b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 27.56 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 99.2 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

TOTAL PARTICULATE EMISSION CALCULATIONS

Test No. 19-9798 Date 1-24-77 Location 19 Engr. G SOTTER

Unit No. 1 Fuel #6 OIL Sampling Train and Method Method 5

Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 30.16 in. Hg

Tot. Liquid Collected, V_{lc} 137.0 ml Total Particulate, M_n 225.8 mg

Velocity Head, ΔP .095 iwg Stack Temp., T_s 950 °R Stack Area, A_s 4.90 ft²

Sample Volume, V_m 63.45 ft³ Stack Press., P_{sg} -.225 iwg Excess O₂, $XO_2\%$ 3.15 %

Orifice Press. Diff., H 1.65 iwg Stack Gas Sp. Gravity, G_s n.d.

Sample Time, θ 68 min Nozzle Dia., D_n 1/2 in. Meter Temp., T_m °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 64.17 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 6.49 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$.092 N.D.
4. Concentration a. $C = 0.0154 M_n / V_{m_{std}}$.0542 grains/DSCF
b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 7.759×10^{-6} lb/DSCF
c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 1.243×10^{-1} grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 409.95 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / T_s} \times \frac{1.00}{G_s}$ 1367 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3764 WSCF/min
Rate @ 70°F
b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3418 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 1.591 lb/hr
9. XO₂ factor $XO_{2f} = 2090 / (20.9 - XO_2\%)$ 117.7 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 8.42×10^{-2} lb/MMBtu
b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 36.21 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 99.2 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

No. 6 Oil

--

AMBIENT TEMPERATURE 30 °F
 BAROMETRIC PRESSURE 30.00 in Hg
 ASSUMED MOISTURE, % _____
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. 3/8
 NOZZLE DIAMETER, IN. _____
 PROBE HEATER SETTING _____

SCHEMATIC OF STACK CROSS SECTION

[illegible]

135

ANDERSEN CASCADE IMPACTOR DATA

Test No. 19-99 Location 19 Owner _____
 Impactor No. 1 Nozzle Size 3/8 Filter No. _____
 Stack Temperature 485 °F Impactor Flow Rate 0.627 CFM
 (T = 1.245)

Plate	Tare (g)	Final (g)	Net (g)	%	Cum. %	ECD (μ)
1	27.3086	27.3123	0.0037	14.2	100.0	(12.1) 15.1
2	28.4141	28.4179	0.0038	14.5	85.8	(7.7) 9.6
3	29.2135	29.2167	0.0032	12.3	71.3	(5.1) 6.3
4	21.9703	21.9733	0.0030	11.5	59.0	(3.6) 4.5
5	17.8991	17.9007	0.0016	6.1	47.5	(2.3) 2.9
6	17.9123	17.9148	0.0025	9.6	41.4	(1.15) 1.43
7	17.9869	17.9894	0.0025	9.6	31.8	(0.70) 0.87
8	28.4000	28.4022	0.0022	8.4	22.2	(0.46) 0.57
Back Up Filter	21.7922	21.7958	0.0036	13.8	13.8	

Total 0.0261 100.0

PARTICULATE EMISSION CALCULATIONS

Test No. 19-99 Date 1-24-77 Location 19 Engr. _____
 Unit No. 1 Fuel 110.6 Oil Sampling Train and Method Anderson Impactor
 Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 30.00 in. Hg
 Tot. Liquid Collected, V_{lc} _____ ml Total Particulate, M_n 26.1 mg
 Velocity Head, ΔP 0.095 iwg Stack Temp., T_s 945 °R Stack Area, A_s 4.9 ft²
 Sample Volume, V_m 15 ft³ Stack Press., P_{sg} -0.225 iwg Excess O₂, XO_2 % 3.1 %
 Orifice Press. Diff., H 0.74 iwg Stack Gas Sp. Gravity, G_s _____ n.d.
 Sample Time, θ 24 min Nozzle Dia., D_n 0.375 in. Meter Temp., T_m 65 °R

1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 15.06 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 1.52 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.092 N.D. *
4. Concentration
 - a. $C = 0.0154 M_n / V_{m_{std}}$ 0.0267 grains/DSCF
 - b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 3.82×10^{-6} lb/DSCF
 - c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.0612 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 407.78 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1367 ft/min
7. Stack Gas Flow
 - a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3764 WSCF/min
 - b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3417 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 0.783 lb/hr
9. XO₂ factor $XO_{2f} = 2090 / (20.9 - XO_2\%)$ 117.4 N.D.
10. Emission
 - a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.0414 lb/MMBtu
 - b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 17.78 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 117 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

$$\frac{15.06}{24} \text{ SCFM} = 0.627 \text{ SCFM}$$

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

*From 11-4P

2 FACTOR @ 0.83

[illegible]

AMBIENT TEMPERATURE 26.15
 BAROMETRIC PRESSURE 29.72
 ASSUMED MOISTURE, % _____
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. 48
 NOZZLE DIAMETER, IN. 1/2
 PROBE HEATER SETTING _____

SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e) Min.	Static Pressure (P_s), In. Hg. 40	Stack Temperature (T_s) °F	Velocity Head (P_s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V_m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet ($T_{min.}$) °F	Outlet ($T_{mout.}$) °F		
	5	-0.225	500	0.108	1.75	2569.30	80		300	50
	20		505	0.125	1.60	2583.00	85		350	65
	35		510	0.130	1.57	2597.00	92		350	62
	50		510	0.130	1.60	2610.00	100		320	55
	1:05		515	0.130	1.62	2624.00	108		310	55
	1:12		515	0.130	1.60	2629.30	110		310	55
TOTAL	67 min.					60		AVG.	AVG.	
AVERAGE		-0.225	509	0.1255	1.62			AVG.		

138

PARTICULATE CALCULATION SHEET

Test No. 19-116 Date 1-26-77 Location 19 Test Crew _____
 Box No. 1 Sample Probe Position center
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final 2629.30
 Initial 2569.30
 Total 60.0

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	187	142	3	663.0	995.0
Initial	100	100	6	644.8	844.8
Δ Vol	87	42	3	18.2	150.2

Beaker No.	1	3	9	10	11	Filter No. 16	Blank No. 18
Date Weighed	1-25-77					1-25-77	
Tare	1 100.0776	101.9842	100.1851	100.9366		0.7999	0.8033
Wt.	2 100.0776	101.9843	100.1850	100.9366		0.7998	0.8035
	3						
	4						
	5						
	6						
Avg	100.0776	101.9843	100.1851	100.9366		0.7999	0.8034
Bottle No.	1 & 2	3	4				
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)		
Rinse (ml)							
Date Weighed or 250 Bake	2-15-77	2-15-77	2-15-77	1-26-77	1-26-77	1-27-77	1-27-77
Final	1 100.0968	102.0026	100.1885	100.9386	99.8103	0.8375	0.8035
Wt. 250	2 100.0969	102.0029	100.1885	100.9384	99.8104	0.8374	0.8037
	3						
	4						
	5						
	6						
Avg	100.0969	102.0028	100.1885	100.9385	99.8104	0.8375	0.8036
Residue wt	0.0193	0.0185	0.0035	0.0019	0.0010	0.0374	2
Final 250-Tare							
Date Weighed or 650 Bake							
Final	1						
Wt. 650	2						
	3						
	4						
	5						
	6						
Avg							
Residue Wt							
Final 650-Tare							

Comments:

Data Sheet 6002-3

PARTICULATE EMISSION CALCULATIONS

Test No. 19-116 Date 1-26-77 Location 19 Engr. Er. Satter
 Unit No. 1 Fuel #2 oil Sampling Train and Method Method 5
 Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 29.72 in. Hg
 Tot. Liquid Collected, V_{lc} 150.2 ml Total Particulate, M_n 67.6 mg Total
 Velocity Head, ΔP 0.126 iwg Stack Temp., T_s 969 °R Stack Area, A_s 4.9 ft²
 Sample Volume, V_m 60.0 ft³ Stack Press., P_{sg} 0.225 iwg Excess O₂, $XO_2\%$ 3.1 %
 Orifice Press. Diff., H 1.62 iwg Stack Gas Sp. Gravity, G_s n.d.
 Sample Time, θ 67 min Nozzle Dia., D_n 1/2 in. Meter Temp., T_m °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 59.8 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 7.12 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2}/(\text{Eq. 1} + \text{Eq. 2})$ 0.106 N.D.
4. Concentration a. $C = 0.0154 M_n/V_{m_{std}}$ 0.0174 grains/DSCF
 b. $C = 2.205 \times 10^{-6} M_n/V_{m_{std}}$ 2.493 \times 10^{-6} lb/DSCF
 c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 3.993 \times 10^{-2} grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 403.97 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P/T_s} \times \frac{1.00}{G_s}$ 1602 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 4261 WSCF/min
 Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3809 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 0.5698 lb/hr
9. XO₂ factor $XO_2^f = 2090/(20.9 - XO_2\%)$ 117.4 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 2.70 \times 10^{-2} lb/MMBtu
 b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 11.60 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 84.2 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

No. 6 0:1)

--

AMBIENT TEMPERATURE 19.5
BAROMETRIC PRESSURE 30.12 in. Hg
ASSUMED MOISTURE, %
HEATER BOX SETTING
PROBE LENGTH, IN.
NOZZLE DIAMETER, IN. 3/8
PROBE HEATER SETTING

SCHEMATIC OF STACK CROSS SECTION

[illegible]

141

ANDERSEN CASCADE IMPACTOR DATA

Test No. 19-132Location 19

Owner _____

Impactor No. 1Nozzle Size 3/8

Filter No. _____

Stack Temperature 475

°F

Impactor Flow Rate 0.605

CFM

temp. correction factor 1.24

Plate	Tare (g)	Final (g)	Net (g)	%	Cum. %	ECD (μ)
1	27.3071	27.3110	0.0039	11.9	99.9	(12.5) 15.5
2	28.4148	28.4187	0.0039	11.9	88.0	(17.8) 9.7
3	29.2157	29.2194	0.0037	11.3	76.1	(5.2) 6.4
4	21.9716	21.9744	0.0028	8.5	64.8	(3.7) 4.6
5	17.8933	17.8961	0.0028	8.5	56.3	(2.3) 2.9
6	17.9073	17.9102	0.0029	8.8	47.8	(1.2) 1.5
7	18.0006	18.0032	0.0026	7.9	39.0	(0.72) 0.9
8	28.4026	28.4053	0.0027	8.2	31.1	(0.48) 0.6
Back Up Filter	21.7893	21.7968	0.0075	22.9		

0.0328

PARTICULATE EMISSION CALCULATIONS

Test No. 19-132 Date 2-17-77 Location 19 Engr. SOTTER
 Unit No. 1 Fuel #6 Oil Sampling Train and Method Anderson Impactor
 Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 30.12 in. Hg
 Tot. Liquid Collected, V_{lc} _____ ml Total Particulate, M_n 32.8 mg
 Velocity Head, ΔP 6.08 iwg Stack Temp., T_s 935 °R Stack Area, A_s 4.9 ft²
 Sample Volume, V_m 15 ft³ Stack Press., P_{sg} -0.23 iwg Excess O₂, $XO_2\%$.98 %
 Orifice Press. Diff., H 0.7 iwg Stack Gas Sp. Gravity, G_s _____ n.d.
 Sample Time, θ 25 min Nozzle Dia., D_n .375 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 15.116 SCF 0.605 SCFM
 2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 1.81 SCF
 3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ meth 5 .1069 N.D.
 4. Concentration a. $C = 0.0154 M_n / V_{m_{std}}$ 0.0334 grains/DSCF
 b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 4.785×10^{-6} lb/DSCF
 c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.0766 grams/DSCM
 5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 409.4 in. w abs.
 6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1245 ft/min
 7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3479 WSCF/min
 Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3107 DSCF/min
 8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 0.892 lb/hr
 9. XO₂ factor $XO_{2f} = 2090 / (20.9 - XO_2\%)$ 104.9 N.D.
 10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.046 lb/MMBtu
 b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 19.9 ng/joule
 11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 124 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

PLANT'

LOCATION 19

OPERATOR

DATE 2-12-77

RUN NO. 10-137

SAMPLE BOX NO. 17-152

METER BOX NO. 4-11-1091

METER H

2 FACTOR @ 0.83

--	--

AMBIENT TEMPERATURE

BAROMETRIC PRESSURE 30.17

ASSUMED MOISTURE. %

HEATER BOX SETTING _____

PROBE LENGTH, IN. 48

NOZZLE DIAMETER, IN. 0.5

PROBE HEATER SETTING

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P _s), In. Hg. H ₂ O	Stack Temperature (T _s) °F	Velocity Head (P _s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V _m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet (T _{min.}) °F	Outlet (T _{mout}) °F		
	0950	-0.23	465	0.0695	1.46	2645.99	80		320	50
	1005		470	0.0695	1.46	2660.00	85		340	55
	1020		475	0.0695	1.46	2673.0	90		330	62
	1035		475	0.0695	1.46	2686.0	100		330	55
	1050		475	0.0695	1.46	2698.0	105		340	55
	1059:30		490	0.0695	1.46	2705.99	110		340	60
TOTAL	69:30							AVG.	AVG.	
AVERAGE				475		60.0		AVG.		

144

PARTICULATE CALCULATION SHEET

Test No. 19-132 Date 2-17-77 Location 19 Test Crew R. P. Lousso
 Box No. 1 Sample Probe Position _____
 Test Description _____

Dry Gas Meter Vol. (ft ³)		Impinger Water Vol (ml)					Filter No.	Blank No.
Final	Initial	1	2	3	S. Gel	Total		
Final	2705.90	185	143	5	673	1006		
Initial	2645.99	100	100	0	653	853		
Total	60.0	Δ Vol	85	43	5	20	153	

Beaker No.	4	5	6	7	8	18	19
Date Weighed	1-27-77						
Tare	1 99.2687	98.9367	100.4858	104.0069	99.3370	0.8033	0.8434
Wt.	2 99.2685	98.9366	100.4858	104.0068	99.3371	0.8034	0.8436
	3						
	4						
	5						
	6						
Avg	99.2686	98.9367	100.4858	104.0069	99.3371	0.8034	0.8435

Bottle No.	1 & 2	3	4				
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)		
Rinse (ml)	725	550	350	200	200		
Date Weighed or 250 Bake	2-21-77	2-18-77	2-18-77	2-18-77	2-18-77		
Final	1 99.2890	98.9668	100.4869	104.0062	99.3372	0.9428	0.8435
Wt. 250	2 99.2888	98.9668	100.4865	104.0063	99.3374	0.9428	0.8436
	3						
	4						
	5						
	6						
Avg	99.2889	98.9668	100.4867	104.0063	99.3373	0.9428	0.8436
Residue wt	0.0203	0.0301	0.0009	0	0.002	0.1394	0
Final 250-Tare							
Date Weighed or 650 Bake							
Final	1						
Wt. 650	2						
	3						
	4						
	5						
	6						
Avg							
Residue Wt							
Final 650-Tare							

Comments: _____

Data Sheet 6002-3

TOTAL & SOLID PARTICULATE EMISSION CALCULATIONS

Test No. 19-132 Date 2-17-77 Location 19 Engr. Seller
Unit No. 1 Fuel #6 Sampling Train and Method He/H₂S
Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 30.12 in. Hg
Tot. Liquid Collected, V_{lc} 153 ml Total Particulate, M_n 170.4 mgm 501.0 Total
Velocity Head, ΔP 0.0695 iwg Stack Temp., T_s 935 °R Stack Area, A_s 4.90 ft²
Sample Volume, V_m 60.0 ft³ Stack Press., P_{sg} -0.23 iwg Excess O₂, XO_2 % 0.98 %
Orifice Press. Diff., H 1.46 iwg Stack Gas Sp. Gravity, G_s 21 n.d.
Sample Time, θ 69.5 min Nozzle Dia., D_n 1/2 in. Meter Temp., T_m _____ °R
TOTAL SOLID
*1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 60.5756 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 7.2522 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2}/(\text{Eq. 1} + \text{Eq. 2})$ 0.1069 N.D.
4. Concentration a. $C = 0.0154 M_n/V_{m_{std}}$ 0.04848 0.0433 grains/DSCF
b. $C = 2.205 \times 10^{-6} M_n/V_{m_{std}}$ 6.94 \times 10^{-6} 6.2 \times 10^{-6} lb/DSCF
c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.111 9.935 \times 10^{-2} grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 409.40 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P/T_s} \sqrt{\frac{407}{P_s} \times \frac{1.00}{G_s}}$ 1160.78 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3243.12 WSCF/min
Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 2896.43 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 1.206 1.0722 lb/hr
9. XO₂ factor $XO_2 f = 2090/(20.9 - XO_2 \%)$ 104.92 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.0671 0.0600 lb/MMBtu
b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 28.87 25.80 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 108.12 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

147

ANDERSEN CASCADE IMPACTOR DATA

Test No. 19-143 Location 19 Owner _____
 Impactor No. 1 Nozzle Size 3/8 in. Filter No. _____
 Stack Temperature 485 °F Impactor Flow Rate 0.51 CFM
 temp. corr. factor - 1.25

Plate	Tare (g)	Final (g)	Net (g)	%	Cum. %	ECD (μ)
1	27.3106	27.3150	0.0044	13.0	100.0	(13.5) 16.9
2	28.4205	28.4254	0.0049	14.5	87.0	(8.6) 10.8
3	29.2180	29.2224	0.0044	13.0	72.5	(5.6) 7.0
4	21.9731	21.9762	0.0031	9.2	59.5	(3.9) 4.9
5	17.8976	17.9007	0.0031	9.2	50.3	(2.5) 3.1
6	17.9111	17.9137	0.0026	7.7	41.1	(1.29) 1.6
7	18.0004	18.0029	0.0025	7.4	33.4	(0.80) 1.0
8	28.4043	28.4065	0.0022	6.5	26.0	(0.54) 0.7
Back Up Filter	21.7914	21.7980	0.0066	19.5		

0.0338

PARTICULATE EMISSION CALCULATIONS

Test No. 19-143 Date 2-21-77 Location 19 Engr. SOTTER
 Unit No. 1 Fuel #6 Oil Sampling Train and Method _____
 Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 29.89 in. Hg
 Tot. Liquid Collected, V_{lc} _____ ml Total Particulate, M_n 33.8 mg
 Velocity Head, ΔP 0.089 iwg Stack Temp., T_s 945 °R Stack Area, A_s 4.9 ft²
 Sample Volume, V_m 15.00 ft³ Stack Press., P_{sg} -0.2 iwg Excess O₂, $XO_2\%$ 3.1 %
 Orifice Press. Diff., H 0.56 iwg Stack Gas Sp. Gravity, G_s _____ n.d.
 Sample Time, θ 29 min Nozzle Dia., D_n .375 in. Meter Temp., T_m 569 °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 15.0 SCF
 2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 1.57 SCF
 3. Moisture Content $B_{wo} = \text{Eq. 2}/(\text{Eq. 1} + \text{Eq. 2})$ Meth 5 0.095 N.D.
 4. Concentration a. $C = 0.0154 M_n/V_{m_{std}}$ 0.0347 grains/DSCF
 b. $C = 2.205 \times 10^{-6} M_n/V_{m_{std}}$ 4.97×10^{-6} lb/DSCF
 c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.0796 grams/DSCM
 5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 406.3 in. w abs.
 6. Stack Gas Speed $V_s = 174 P_s \sqrt{\Delta P T_s} \sqrt{\frac{407}{P_s}} \times \frac{1.00}{G_s}$ 1325 ft/min
 7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3636.7 WSCF/min
 Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3291 DSCF/min
 8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 0.981 lb/hr
 9. XO₂ factor $XO_{2f} = 2090/(20.9 - XO_2\%)$ 117.4 N.D.
 10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.0538 lb/MMBtu
 b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 23.13 ng/joule
 11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 100.4 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

2 FACTOR @ 0.83

[illegible]

PROBE HEATER SETTING

SCHEMATIC OF STACK CROSS SECTION

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

150

PARTICULATE CALCULATION SHEET

Test No. 19-143 Date 2-21-77 Location 19 Test Crew R. 12
 Box No. 1 Sample Probe Position E
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final 2783.38
 Initial 2721.38
 Total 62.00

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	172	142	5	667.2	986.2
Initial	100	100	0	648.0	848.0
Δ Vol	72	42	5	19.2	138.2

Beaker No.	1	3	9			Filter No.	Blank No.
Date Weighed	2-18-77					2-18-77	1-27-77
Tare	1 100.0790	101.9866	100.1860			0.8435	0.8071
Wt.	2 100.0788	101.9863	100.1860			0.8436	0.8071
	3						
	4						
	5						
	6						
Avg	100.0789	101.9865	100.1860			0.8436	0.8071
Bottle No.	152	3	4				
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)		
Rinse (ml)	750	475	350				
Date Weighed or 250 Bake	2-22-77	2-22-77	2-22-77			2-22-77	2-22-77
Final	1 100.1069	102.0328	100.1969			0.9513	0.8074
Wt. 250	2 100.1068	102.0329	100.1967			0.9512	0.8074
	3						
	4						
	5						
	6						
Avg	100.1069	102.0329	100.1968			0.9513	0.8074
Residue wt	0.028	0.0464	0.0108			0.1077	0.0003
Final 250-Tare							
Date Weighed or 650 Bake							
Final	1						
Wt. 650	2						
	3						
	4						
	5						
	6						
Avg							
Residue Wt							
Final 650-Tare							

Comments:

Data Sheet 6002-3

PARTICULATE EMISSION CALCULATIONS

Test No. 19-143 Date 2-21-77 Location 19 Engr. G. Satter

Unit No. 1 Fuel #6 oil Sampling Train and Method Method 5

Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 29.86 in. Hg

Tot. Liquid Collected, V_{lc} 138.2 ml Total Particulate, M_n 164.9 m gm solid

Velocity Head, ΔP 0.089 iwg Stack Temp., T_s 947 °R Stack Area, A_s 4.90 ft²

Sample Volume, V_m 62.0 ft³ Stack Press., P_{sg} -0.2 iwg Excess O₂, $XO_2\%$ 3.1 %

Orifice Press. Diff., H 1.63 iwg Stack Gas Sp. Gravity, G_s 21 n.d.

Sample Time, θ 67 min Nozzle Dia., D_n 1/2 in. Meter Temp., T _____ °R

*1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$

TOTAL 50.10 SCF

2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$

6.55 SCF

3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$

0.095 N.D.

4. Concentration a. $C = 0.0154 M_n / V_{m_{std}}$

0.0479 0.041 grains/DSCF

b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$

6.85 x 10⁻⁶ 5.86 x 10⁻⁶ lb/DSCF

c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$

0.1097 9.38 x 10⁻² grams/DSCM

5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$

405.9 in. w abs.

6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P T_s} \sqrt{\frac{407}{P_s} \times \frac{1.00}{G_s}}$

1328 ft/min

7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$

3631 WSCF/min

b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$

3286 DSCF/min

8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$

1.155 lb/hr

9. XO₂ factor $XO_2 f = 2090 / (20.9 - XO_2\%)$

117.4 N.D.

10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$

0.074 0.0635 lb/MMBtu

b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$

31.8 27.2 ng/joule

11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$


101.3 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

PLANT _____
 LOCATION _____
 OPERATOR _____
 DATE 2/23/77
 RUN NO. 19-159 #6 oil
 SAMPLE BOX NO. _____
 METER BOX NO. 4-11-1091
 METER H _____
 FACTOR @ _____



AMBIENT TEMPERATURE 41.05
 BAROMETRIC PRESSURE 30.09 in Hg
 ASSUMED MOISTURE, % _____
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. 3/8
 NOZZLE DIAMETER, IN. _____
 PROBE HEATER SETTING _____

ANDERSON IMPACTOR SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P _s), In. Hg. in wg	Stack Temperature (T _s) °F	Velocity Head (P _s) in wg	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume Meter Reading (V_m) ft³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet (T _{min.}) °F	Outlet (T _{out}) °F		
	1115	-0.23	530	0.089	0.54	2861.00	125	NA	NA	70
	1125					2866.00	120			62
	1135					2871.00	120			58
	1145					2876.00	118			58
	30					15.00				

153

ANDERSEN CASCADE IMPACTOR DATA

Test No. 19-159 Location 19 Owner _____
 Impactor No. 1 Nozzle Size 3/8 in. Filter No. _____
 Stack Temperature 530 °F Impactor Flow Rate 0.503 CFM
 Temp. Correction Factor 1.225

Plate	Tare (g)	Final (g)	Net (g)	%	Cum. %	ECD (μ)
1	27.3114	27.3163	0.0049	20.4	100.0	(13.5) 16.5
2	28.4161	28.4205	0.0044	18.3	79.6	(8.6) 10.5
3	29.2165	29.2200	0.0035	14.6	61.3	(5.6) 6.9
4	21.9736	21.9759	0.0025	10.4	46.7	(3.9) 4.8
5	17.8966	17.8988	0.0022	9.2	36.3	(2.5) 3.1
6	17.9116	17.9131	0.0015	6.3	27.1	(1.45) 1.8
7	18.0010	18.0018	0.0008	3.3	20.8	(0.80) 1.0
8	28.4047	28.4055	0.0034	14.2		
Back Up Filter						

Total 0.0240

PARTICULATE EMISSION CALCULATIONS

Test No. 19-159 Date 2-23-77 Location 19 Engr. SCOTTER
 Unit No. 1 Fuel #6 Oil Sampling Train and Method Anderson Impactor
 Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 30.09 in. Hg
 Tot. Liquid Collected, V_{lc} _____ ml Total Particulate, M_t 24.0 mg
 Velocity Head, ΔP 0.089 iwg Stack Temp., T_s 990 °R Stack Area, A_s 4.9 ft²
 Sample Volume, V_m 1500 ft³ Stack Press., P_{sg} -.23 iwg Excess O₂, $XO_2\%$ 1.7 %
 Orifice Press. Diff., H 0.54 iwg Stack Gas Sp. Gravity, G_s _____ n.d.
 Sample Time, θ 30 min Nozzle Dia., D_n .375 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{mstd} = 0.0334 V_m (P_{bar} + H/13.6)$ 15.09 SCF
2. Water Vapor $V_{wstd} = 0.0474 V_{lc}$ 1.85 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2}/(\text{Eq. 1} + \text{Eq. 2})$.109 N.D.
4. Concentration
 - a. $C = 0.0154 M_n/V_{mstd}$ 0.0245 grains/DSCF
 - b. $C = 2.205 \times 10^{-6} M_n/V_{mstd}$ 3.507×10^{-6} lb/DSCF
 - c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.056 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 408.99 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P/T_s} \times \frac{1.00}{G_s}$ 1352 ft/min
7. Stack Gas Flow
 - a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3574 WSCF/min
 - b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3184 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 0.6699 lb/hr
9. XO_2 factor $XO_2^f = 2090/(20.9 - XO_2\%)$ 108.85 N.D.
10. Emission
 - a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.035 lb/MMBtu
 - b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 15.1 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{mstd} + V_{wstd})}{\theta \times V_s \times P_s \times D_n^2}$ 101.2 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply V_{mstd} by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

PLANT

LOCATION 10

OPERATOR 19
R D

DATE 2-22-77

RUN NO. 19-158

SAMPLE BOX NO. 1121

METER BOX NO. 4-4-1001

METER H

3 FACTOR @ 000

--	--

AMBIENT TEMPERATURE

BAROMETRIC PRESSURE

ASSUMED MOISTURE. %

HEATER BOX SETTING

PROBE LENGTH, IN.

NOZZLE DIAMETER. IN

PROBE HEATER SETTING

SCHEMATIC OF STACK CROSS SECTION

156

PARTICULATE CALCULATION SHEET

Test No. 19-159 Date 2-23-77 Location 19 Test Crew R.P.
 Box No. _____ Sample Probe Position _____
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final 2860.64
 Initial 2798.64
 Total 62.0

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	209	135	2	659.0	1005.0
Initial	100	100	2	643.6	843.6
Δ Vol	109	35	2	15.4	161.4

Beaker No. <u>10</u> <u>11</u> <u>12</u>						Filter No. <u>20</u>	Blank No. <u>21</u>
Date Weighed <u>2-18-77</u> →						<u>2-22-77</u>	<u>1-27-77</u>
Tare	1	100.9370	99.8094	100.9694		0.8074	0.8211
Wt.	2	100.9372	99.8094	100.9692		0.8074	0.8211
	3						
	4						
	5						
	6						
Avg		100.9371	99.8094	100.9693		0.8074	0.8211
Bottle No. <u>1 & 2</u> <u>3</u> <u>4</u>							
Content		Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)	
Rinse (ml)		<u>750</u>	<u>485</u>	<u>275</u>			
Date Weighed or 250 Bake <u>2-24-77</u> →						<u>2-24-77</u>	<u>2-24-77</u>
Final	1	100.9565	99.8425	100.9742		0.9623	0.8211
Wt. 250	2	100.9566	99.8427	100.9742		0.9623	0.8211
	3						
	4						
	5						
	6						
Avg		100.9566	99.8426	100.9742		0.9623	0.8211
Residue wt		0.0195	0.0332	0.0049		0.1549	<u>0</u>
Final 250-Tare							
Date Weighed or 650 Bake							
Final	1						
Wt. 650	2						
	3						
	4						
	5						
	6						
Avg							
Residue Wt							
Final 650-Tare							

Comments:

0.143g solids
0.2125g Total

Data Sheet 6002-3

PARTICULATE EMISSION CALCULATIONS

Test No. 19-159 Date 2-23-77 Location 19 Engr. G. S.
Unit No. 1 Fuel #6 oil Sampling Train and Method Meth. 5
Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 30.08 in. Hg
Tot. Liquid Collected, V_{lc} 161.4 ml Total Particulate, M_n 212.5 Total 193 Solid gm
Velocity Head, ΔP 0.089 iwg Stack Temp., T_s 986 °R Stack Area, A_s 4.90 ft²
Sample Volume, V_m 62 ft³ Stack Press., P_{sg} -0.23 iwg Excess O₂, XO_2 % 1.7 %
Orifice Press. Diff., H 1.57 iwg Stack Gas Sp. Gravity, G_s 1 n.d.
Sample Time, θ 63 min Nozzle Dia., D_n 1/2 in. Meter Temp., T_m _____ °R
*1. Sample Gas Volume $V_{mstd} = 0.0334 V_m (P_{bar} + H/13.6)$ Total Solid 62.5287 SCF
2. Water Vapor $V_{wstd} = 0.0474 V_{lc}$ 7.6504 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.1090 N.D.
4. Concentration a. $C = 0.0154 M_n / V_{mstd}$ 0.0523 0.0463 grains/DSCF
b. $C = 2.205 \times 10^{-6} M_n / V_{mstd}$ 7.494 \times 10^{-6} 6.633 \times 10^{-6} lb/DSCF
c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.120 0.1062 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 408.858 in. w abs.
6. Stack Gas Speed $V_s = 174 P_s \sqrt{\Delta P / T_s} \times \frac{1.00}{G_s}$ 1349.81 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3571.45 WSCF/min
Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3182.12 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 1.2664 lb/hr
9. XO₂ factor $XO_2^f = 2090 / (20.9 - XO_2\%)$ 108.85 N.D.
10. Emission a. $E = \text{Eq. 4b} \times Fe \times \text{Eq. 9}$ 0.075 0.0683 lb/MMBtu
b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 32.33 29.36 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{mstd} + V_{wstd})}{\theta \times V_s \times P_s \times D_n^2}$ 112.1 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply V_{mstd} by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

#6 oil

--	--

350 K.

0.9.98 in H₂O

~ 1370

318

318

100

SCHEMATIC OF STACK CROSS SECTION

153

ANDERSEN CASCADE IMPACTOR DATA

Test No. 19-170 Location 19 Owner _____
 Impactor No. 1 Nozzle Size 3/8" Filter No. _____
 Stack Temperature 512 °F Impactor Flow Rate 0.53 CFM

Temp. Corr. Factor = 1.25

Plate	Tare (g)	Final (g)	Net (g)	%	Cum. %	ECD (μ)
1	27.3112	27.3164	0.0052	20.0	100.0	(13.5) 16.9
2	28.4177	28.4219	0.0042	16.1	80.0	(8.5) 10.6
3	29.2172	29.2208	0.0036	13.8	63.9	(5.6) 7.0
4	21.9727	21.9752	0.0025	9.6	50.1	(3.8) 4.75
5	17.8941	17.8962	0.0021	8.1	40.5	(2.5) 3.1
6	17.9089	17.9107	0.0018	6.9	32.4	(1.25) 1.6
7	18.0042	18.0057	0.0015	5.8	25.5	(0.76) 0.95
8	28.4035	28.4051	0.0016	6.2	19.7	(0.53) 0.66
Back Up Filter	21.7916	21.7948	0.0035	13.5		

Total 0.0260

PARTICULATE EMISSION CALCULATIONS

Test No. 19-170 Date 3-1-77 Location 19 Engr. SCATTER

Unit No. 1 Fuel #6 Oil Sampling Train and Method _____

Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 29.98 in. Hg

Tot. Liquid Collected, V_{lc} _____ ml Total Particulate, M_n 26.0 mg

Velocity Head, ΔP 0.115 iwg Stack Temp., T_s 972 °R Stack Area, A_s 4.9 ft²

Sample Volume, V_m 15.79 ft³ Stack Press., P_{sg} -22 iwg Excess O₂, XO_2 % 4.2 %

Orifice Press. Diff., H 0.61 iwg Stack Gas Sp. Gravity, G_s _____ n.d.

Sample Time, θ 30 min Nozzle Dia., D_n .375 in. Meter Temp., T_m 580 °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 15.84 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 1.31 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2}/(\text{Eq. 1} + \text{Eq. 2})$.091 N.D.
4. Concentration
 - a. $C = 0.0154 M_n/V_{m_{std}}$ 0.0253 grains/DSCF
 - b. $C = 2.205 \times 10^{-6} M_n/V_{m_{std}}$ 3.62×10^{-6} lb/DSCF
 - c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.058 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 407.5 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P/T_s} \sqrt{\frac{407}{P_s} \times \frac{1.00}{G_s}}$ 1526 ft/min
7. Stack Gas Flow
 - a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 4082 WSCF/min
 - b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3710 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 0.806 lb/hr
9. XO₂ factor $XO_{2f} = 2090/(20.9 - XO_2\%)$ 125.1 N.D.
10. Emission
 - a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.0418 lb/MMBtu
 - b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 17.96 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 89.5 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

PLANT _____
LOCATION 19
OPERATOR MBH
DATE 3-1-77
RUN NO. 19-170
SAMPLE BOX NO. 1
METER BOX NO. 1
METER H _____
C FACTOR @ 0.83

METHOD 5 CONTROL CONSOLE READINGS

AMBIENT TEMPERATURE 35°F
 BAROMETRIC PRESSURE 29.98
 ASSUMED MOISTURE, % ~13
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. 72
 NOZZLE DIAMETER, IN. 1/2
 PROBE HEATER SETTING 5

SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e) Min.	Static Pressure (P_s), In. Hg. H_2O	Stack Temperature (T_s) °F	Velocity Head (P_s)	Pressure Differential Across Orifice Meter (ΔH), In. H_2O	Gas Sample Volume (V_m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet ($T_{min.}$) °F	Outlet (T_{mout}) °F		
	1123	-0.22	515	0.11	1.77	2876.205		90	345	60
	1138		518	0.11	1.77			93	390	72
	1152		520	0.11	1.77			101	405	68
	1207		520	0.11	1.77			108	425	64
	1223		521	0.11	1.77			116	425	65
	1228		521	0.11	1.77	2936.510		120	420	66
TOTAL								AVG.	AVG.	
AVERAGE			519					AVG.		

162

PARTICULATE CALCULATION SHEET

Test No. 19-170 Date 3-1-77 Location 19 Test Crew G.S. MRH
 Box No. 1 Sample Probe Position stack, ~15" in
 Test Description 100% FGR, low O₂

Dry Gas Meter Vol. (ft³)

Final 2936.510
 Initial 2876.205
 Total 60.305

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	168	137	5	614.0	924
Initial	100	100	2	596.4	798.4
Δ Vol	68	37	3	18.4	127.6

Beaker No.	1	3	5	6	Filter No. 21	Blank No. 22
Date						
Weighted	2-24-77			2-21-77	2-24-77	1-27-77
Tare	1 100.0762	101.9828		98.9317	100.4825	0.8211
Wt.	2 100.0761	101.9828		98.9315	100.4823	0.8211
	3					
	4					
	5					
	6					
Avg	100.0762	101.9828		98.9316	100.4824	0.8211
Bottle No.	1 & 2	3		H ₂ O	Acetone	
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)	
Rinse (ml)	765	475		200	200	
Date						
or 250 Bake	3-2-77	3-2-77		3-2-77	3-2-77	3-2-77
Final	1 100.1916	102.0269		98.9321	100.4839	0.9181
Wt. 250	2 100.1916	102.0271		98.9324	100.4838	0.9181
	3			98.9324		
	4					
	5					
	6					
Avg	100.1916	102.0270		98.9324	100.4838	0.9181
Residue wt						
Final 250-Tare	0.1154	0.0442		+ 0.0008	10.0014	0.0097
Date						
or 650 Bake						
Final	1					
Wt. 650	2					
	3					
	4					
	5					
	6					
Avg						
Residue Wt						
Final 650-Tare						

Comments:

Data Sheet 6002-3

PARTICULATE EMISSION CALCULATIONS

Test No. 19-170 Date 3-1-77 Location 19 Engr. G.S.

Unit No. 1 Fuel #6 oil Sampling Train and Method 5

Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 29.98 in. Hg

Tot. Liquid Collected, V_{lc} 127.6 ml Total Particulate, M_n 159.7 m gm 50.5 ^{solid}

Velocity Head, ΔP 0.11 iwg Stack Temp., T_s 979 °R Stack Area, A_s 4.9 ft²

Sample Volume, V_m 60.305 ft³ Stack Press., P_{sg} -0.22 iwg Excess O₂, XO_2 % 4.2 %

Orifice Press. Diff., H 1.77 iwg Stack Gas Sp. Gravity, G_s 1 n.d.

Sample Time, θ 65 min Nozzle Dia., D_n 0.5 in. Meter Temp., T_m _____ °R

*1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 60.65 SCF ^{Solid Total}

2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 6.05 SCF

3. Moisture Content $B_{wo} = \text{Eq. 2}/(\text{Eq. 1} + \text{Eq. 2})$ 0.091 N.D.

4. Concentration a. $C = 0.0154 M_n/V_{m_{std}}$ 0.0128 0.0406 grains/DSCF

b. $C = 2.205 \times 10^{-6} M_n/V_{m_{std}}$ 1.836 x 10⁻⁶ 5.806 x 10⁻⁶ lb/DSCF

c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.0294 9.3 x 10⁻² grams/DSCM

5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 407.5 in. w abs.

6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P T_s} \sqrt{\frac{407}{P_s}} \times \frac{1.00}{G_s}$ 1498 ft/min

7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3978 WSCF/min

Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3616 DSCF/min

8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 1.260 lb/hr

9. XO₂ factor $XO_2 f = 2090/(20.9 - XO_2 \%)$ 125.1 N.D.

10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.021 0.067 lb/MMBtu

b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 9.1 28.795 ng/joule

11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 92.7 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

#2021

--

AMBIENT TEMPERATURE 50°F
 BAROMETRIC PRESSURE 30.27 in Hg
 ASSUMED MOISTURE, % _____
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. _____
 NOZZLE DIAMETER, IN. 3/8
 PROBE HEATER SETTING _____

SCHEMATIC OF STACK CROSS SECTION

165

ANDERSEN CASCADE IMPACTOR DATA

Test No. 19-179 Location 19 Owner _____
 Impactor No. 1 Nozzle Size 3/8 in. Filter No. _____
 Stack Temperature 540 °F Impactor Flow Rate 0.58 CFM
 Temp. Corr. Factor -1.28

Plate	Tare (g)	Final (g)	Net (g)	%	Cum. %	ECD (μ)
1	27.3127	27.3172	0.0045	17.9	100.0	(125) 16.0
2	28.4184	28.4228	0.0044	17.5	82.1	(8.0) 10.2
3	29.2183	29.2220	0.0037	14.7	64.6	(5.3) 6.8
4	21.9730	21.9762	0.0032	12.7	49.9	(3.75) 4.8
5	17.8951	17.8981	0.0030	12.0	37.2	(2.35) 3.0
6	17.9106	17.9131	0.0025	10.0	25.2	(1.2) 1.5
7	18.0012	18.0032	0.0020	8.0	15.2	(0.75) 0.96
8	28.4053	28.4071	0.0018	7.2	7.2	(0.50) 0.6
Back Up Filter	21.7935	21.7931	-0.0004			

0.0251

PARTICULATE EMISSION CALCULATIONS

Test No. 19-179 Date 3-3-77 Location 19 Engr. _____

Unit No. _____ Fuel #2 oil Sampling Train and Method Anderson Impactor

Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 30.34 in. Hg

Tot. Liquid Collected, V_{lc} _____ ml Total Particulate, M_n 25.1 mg

Velocity Head, ΔP 0.11 iwg Stack Temp., T_s 1000 °R Stack Area, A_s 4.9 ft²

Sample Volume, V_m 40. ft³ Stack Press., P_{sg} -.23 iwg Excess O₂, X_{O_2} 3.5 %

Orifice Press. Diff., H .59 iwg Stack Gas Sp. Gravity, G_s _____ n.d.

Sample Time, θ 113 min Nozzle Dia., D_n .375 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 40.59 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 6.33 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$.135 N.D.
4. Concentration
 - a. $C = 0.0154 M_n / V_{m_{std}}$ 0.00952 grains/DSCF
 - b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 1.364×10^{-6} lb/DSCF
 - c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.0218 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 412.39 in. w abs.
6. Stack Gas Speed $V_s = 174 P_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1505 ft/min
7. Stack Gas Flow
 - a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3960 WSCF/min
 - b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3611 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 0.296 lb/hr.
9. XO₂ factor $XO_2^f = 2090 / (20.9 - XO_2\%)$ 120.1 N.D.
10. Emission
 - a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.0151 lb/MMBtu
 - b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 6.5 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 66.97 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

3 FACTOR @ 0.83

--	--

AMBIENT TEMPERATURE 40
 BAROMETRIC PRESSURE 30.34
 ASSUMED MOISTURE, % _____
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. 48
 NOZZLE DIAMETER, IN. 0.5
 PROBE HEATER SETTING _____

SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P_s), In. Hg. H_2O	Stack Temperature (T_s) °F	Velocity Head (P_s)	Pressure Differential Across Orifice Meter (ΔH), In. H_2O	Gas Sample Volume (V_m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet ($T_{min.}$) °F	Outlet ($T_{mout.}$) °F		
	10:42	-0.23	530	0.11	1.72	2952.50		95	315	80
	10:57		535	0.11	1.72	66.00		100	330	60
	11:12		540	0.11	1.72	81.00		110	330	58
	11:27		540	0.11	1.72	94.00		115	330	58
	11:45		540	0.11	1.72	3010.00		120	330	60
	11:50					3014.00				
TOTAL	60					62.0		AVG.	AVG.	
AVERAGE			540					AVG.		

158

PARTICULATE CALCULATION SHEET

Test No. 19-179 Date 3-3-77 Location 19 Test Crew R. P.
 Box No. 1 Sample Probe Position _____
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final 3014.50
 Initial 2952.50
 Total 62.0

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	182	126	5	611.0	924
Initial	100	100	0	596.0	796
Δ Vol	82	26	5	15	128.0

Beaker No.	4	7	8	9	3	Filter No. 22	Blank No. 23
Date Weighed	2-24-77	2-21-77	2-21-77	2-24-77	3-4-77	3-2-77	1-27-77
Tare	1 99.2643	104.0042	99.3352	100.1831	101.9826	0.7942	0.7884
Wt.	2 99.2644	104.0040	99.3352	100.1830	101.9826	0.7942	0.7885
	3						
	4						
	5						
	6						
Avg	99.2644	104.0041	99.3352	100.1831	101.9826	0.7942	0.7884
Bottle No.	152	3	4	H ₂ O Blank	Imp. H ₂ O		
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)		
Rinse (ml)	400	475	300	200	175		
Date Weighed or 250 Bake	3-4-77						
Final	1 99.2803	104.0104	99.3425	100.1872	101.9912	0.8138	0.7883
Wt. 250	2 99.2803	104.0103	99.3425	100.1871	101.9914	0.8139	0.7882
	3						
	4						
	5						
	6						
Avg	99.2803	104.0103	99.3425	100.1871	101.9913	0.8139	0.7883
Residue wt	0.0159	0.0062	0.0073	+0.004	0.0087	0.0197	5
Final 250-Tare	0.0119		0.0033		0.0047		
Date Weighed or 650 Bake							
Final	1						
Wt. 650	2						
	3						
	4						
	5						
	6						
Avg							
Residue Wt							
Final 650-Tare							

Comments:

Data Sheet 6002-3

PARTICULATE EMISSION CALCULATIONS

Test No. 19-179 Date 3-3-77 Location 19 Engr. G.S.

Unit No. 1 Fuel #2 oil Sampling Train and Method 5

Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 30.34 in. Hg

Tot. Liquid Collected, V_{lc} 128 ml Total Particulate, M_n 25.0 mg ^{19.9 solid} _{total}

Velocity Head, ΔP 0.11 iwg Stack Temp., T_s 1000 °R Stack Area, A_s 4.9 ft²

Sample Volume, V_m 62 ft³ Stack Press., P_{sg} -0.23 iwg Excess O₂, $XO_2\%$ 3.5 %

Orifice Press. Diff., H 1.72 iwg Stack Gas Sp. Gravity, G_s 21 n.d.

Sample Time, θ 68 min Nozzle Dia., D_n 0.5 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{mstd} = 0.0334 V_m (P_{bar} + H/13.6)$ SOLID TOTAL 63.09 SCF
2. Water Vapor $V_{wstd} = 0.0474 V_{lc}$ 6.07 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.088 N.D.
4. Concentration a. $C = 0.0154 M_n / V_{mstd}$ 0.0048 0.0061 grains/DSCF
- b. $C = 2.205 \times 10^{-6} M_n / V_{mstd}$ 0.696×10^{-6} 8.74×10^{-7} lb/DSCF
- c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.0111 0.014 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 412.39 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1505 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3960 WSCF/min
- Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3611 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 0.189 lb/hr
9. XO₂ factor $XO_{2f} = 2090 / (20.9 - XO_2\%)$ 120 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.0077 0.0097 lb/MMBtu
- b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 3.31 4.16 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{mstd} + V_{wstd})}{\theta \times V_s \times P_s \times D_n^2}$ 92.3 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply V_{mstd} by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

PLANT _____
LOCATION 19
OPERATOR R. P.
DATE 3-7-77
RUN NO. 19-190
SAMPLE BOX NO. 1
METER BOX NO. 4-11-1091
METER H _____
C FACTOR @ 0.83

METHOD 5 CONTROL CONSOLE READINGS

AMBIENT TEMPERATURE 35.0 F
 BAROMETRIC PRESSURE 30.07
 ASSUMED MOISTURE, % _____
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. 48
 NOZZLE DIAMETER, IN. 0.5
 PROBE HEATER SETTING _____

SCHEMATIC OF STACK CROSS SECTION

[illegible]

171

PARTICULATE CALCULATION SHEET

Test No. 19-190 Date 3-7-77 Location 19 Test Crew R.P.
 Box No. 1 Sample Probe Position Stack
 Test Description _____

Dry Gas Meter Vol. (ft ³)			Impinger Water Vol (ml)							
Final	Initial	Total	Final	Initial	Δ Vol	1	2	3	S. Gel	Total
316.76	3054.76	62.00	240	100	140	144	100	4	689.0	1077.0
						44	44	4	671.0	871.0
									18.0	206.0

Beaker No.	1	3	5	6	7	Filter No. 23	Blank No. 25
Date Weighed	3-4-77	3-7-77	3-4-77	3-4-77	3-7-77	1-27-77	1-27-77
Tare	1 100.0794	101.9823	98.9340	100.4843	104.0024	0.7884	0.8462
Wt. (	2 100.0793	101.9822	98.9338	100.4841	104.0026	0.7885	0.8465
	3						
	4						
	5						
	6						
Avg	100.0794	101.9823	98.9339	100.4842	104.0025	0.7885	0.8463

Bottle No.	1	3	4				
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)		
Rinse (ml)	825	400	300	200	200		
Date Weighed or 250 Bake	3-8-77	3-8-77					
Final	1 100.0855	101.9857	98.9362	100.4828	104.0037	0.7934	0.8460
Wt. 250	2 100.0854	101.9856	98.9363	100.4828	104.0037	0.7933	0.8461
	3						
	4						
	5						
	6						
Avg	100.0855	101.9857	98.9363	100.4828	104.0037	0.7934	0.8461
Residue wt							
Final 250-Tare	0.0061	0.0034	0.0024	8	0.0012	0.0049	8
Date Weighed or 650 Bake							
Final	1						
Wt. 650	2						
	3						
	4						
	5						
	6						
Avg							
Residue Wt							
Final 650-Tare							

Comments:

Data Sheet 6002-3

PARTICULATE EMISSION CALCULATIONS

Test No. 19-190 Date 3-7-77 Location 19 Engr. G.S.

Unit No. 1 Fuel Not Gas Sampling Train and Method Method 5

Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 30.07 in. Hg

Tot. Liquid Collected, V_{lc} 206 ml Total Particulate, M_n 8.3 m gm solid

Velocity Head, ΔP 0.1125 iwg Stack Temp., T_s 975 °R Stack Area, A_s 4.9 ft²

Sample Volume, V_m 62 ft³ Stack Press., P_{sg} 0.23 iwg Excess O₂, XO_2 % 3.2 %

Orifice Press. Diff., H 1.76 iwg Stack Gas Sp. Gravity, G_s 1 n.d.

Sample Time, θ 65 min Nozzle Dia., D_n 0.5 in. Meter Temp., T_m °R

*1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ TOTAL SOLID 62.54 SCF

2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 9.76 SCF

3. Moisture Content $B_{wO} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.135 N.D.

4. Concentration a. $C = 0.0154 M_n / V_{m_{std}}$ 0.00355 0.00204 grains/DSCF

b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 0.508 x 10⁻⁶ 0.2926 x 10⁻⁶ lb/DSCF

c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.00813 4.69 x 10⁻³ grams/DSCM

5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 402.04 in. w abs.

6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1522 ft/min

7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 4004.6 WSCF/min

b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3464 DSCF/min

8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 6.08 x 10⁻² lb/hr

9. XO₂ factor $XO_2^f = 2090 / (20.9 - XO_2\%)$ 118.08 N.D.

10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.00524 3.02 x 10⁻³ lb/MMBtu

b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 2.253 1.2992 ng/joule

11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 99.79 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by 530/ T_m (°R) if meter not temp. compensated. Data Sheet 6002-4

2 FACTOR @ 0.83

--

PROBE HEATER SETTING

SCHEMATIC OF STACK CROSS SECTION

AVERAGE

174

PARTICULATE CALCULATION SHEET

Test No. 19-193 Date 3-8-77 Location 19 Test Crew R.P.
 Box No. 1 Sample Probe Position 1 stack
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final 3217.2
 Initial 3117.2
 Total 100.0

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	358	235	10	677.5	1280.5
Initial	100	100	0	650.5	850.5
Δ Vol	258	135	10	27.0	430.0

Beaker No. <u>8</u> <u>9</u> <u>10</u>						Filter No. <u>24</u>	Blank No. <u>25</u>
Date Weighed	<u>3-7-77</u>	<u>3-7-77</u>	<u>3-4-77</u>			<u>1-27-77</u>	<u>3-8-77</u>
Tare	<u>1 99.3352</u>	<u>100.1828</u>	<u>100.9384</u>			<u>0.8006</u>	<u>0.8460</u>
Wt.	<u>2 99.3351</u>	<u>100.1828</u>	<u>100.9384</u>			<u>0.8005</u>	<u>0.8461</u>
	<u>3</u>						
	<u>4</u>						
	<u>5</u>						
	<u>6</u>						
Avg	<u>99.3352</u>	<u>100.1828</u>	<u>100.9384</u>			<u>0.8006</u>	<u>0.8461</u>
Bottle No. <u>142</u> <u>3</u> <u>4</u>							
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)		
Rinse (ml)	<u>1025</u>	<u>450</u>	<u>325</u>				
Date Weighed or 250 Bake	<u>3-10-77</u>	<u>3-9-77</u>	<u>3-9-77</u>			<u>3-9-77</u>	<u>3-9-77</u>
Final	<u>1 99.3510</u>	<u>100.1924</u>	<u>100.9408</u>			<u>0.8111</u>	<u>0.8454</u>
Wt. 250	<u>2 99.3510</u>	<u>100.1920</u>	<u>100.9403</u>			<u>0.8111</u>	<u>0.8457</u>
	<u>3</u>	<u>100.1918</u>	<u>100.9405</u>			<u>0.8110</u>	<u>0.8454</u>
	<u>4</u>						
	<u>5</u>						
	<u>6</u>						
Avg	<u>99.3510</u>	<u>100.1920</u>	<u>100.9405</u>			<u>0.8111</u>	<u>0.8456</u>
Residue wt	<u>0.0158</u>	<u>0.0092</u>	<u>0.0021</u>			<u>0.0105</u>	<u>0</u>
Final 250-Tare							
Date Weighed or 650 Bake							
Final	<u>1</u>						
Wt. 650	<u>2</u>						
	<u>3</u>						
	<u>4</u>						
	<u>5</u>						
	<u>6</u>						
Avg							
Residue Wt							
Final 650-Tare							

Comments:

Data Sheet 6002-3

PARTICULATE EMISSION CALCULATIONS

Test No. 19-193 Date 3-8-77 Location 19 Engr. G. S.
Unit No. 1 Fuel Nat. Gas Sampling Train and Method meth. 5
Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 30.28 in. Hg
Tot. Liquid Collected, V_{lc} 430 ml Total Particulate, M_n 21.8 mgm Solid
Velocity Head, ΔP 0.115 iwg Stack Temp., T_s 960 °R Stack Area, A_s 4.9 ft²
Sample Volume, V_m 100 ft³ Stack Press., P_{sg} -0.225 iwg Excess O₂, $XO_2\%$ 3.2 %
Orifice Press. Diff., H 1.8 iwg Stack Gas Sp. Gravity, G_s 21 n.d.
Sample Time, θ 105 min Nozzle Dia., D_n 0.5 in. Meter Temp., T_m _____ °R
TOTAL SOLID
*1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 101.577 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 20.382 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.167 N.D.
4. Concentration a. $C = 0.0154 M_n / V_{m_{std}}$ 0.00578 0.00335 grains/DSCF
b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 0.8273 \times 10^{-6} 0.4807 \times 10^{-6} lb/DSCF ⁴⁻³²³
c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.0133 7.7 \times 10^{-3} grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 400.995 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1521.17 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 4094.8 WSCF/min
Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3410.968 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 9.838 \times 10^{-2} lb/hr
9. XO₂ factor $XO_{2f} = 2090 / (20.9 - XO_2\%)$ 118.08 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 8.555 \times 10^{-3} 4.961 \times 10^{-3} lb/MMBtu
b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 3.679 2.133 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 101.91 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

PLUME OPACITY OBSERVATION RECORD

19-76

Test Run No. 220

LOCATION NO. 19 OBSERVER M. HARETY

OWNER _____ BOILER NO. 1 CAPACITY 18 klb/hr

DATE 1-19-77 FUEL TYPE #2 BURNER TYPE _____

POINT OF EMISSION STACK

POINT OF OBSERVATION ~ 200' FROM STACK AT 90° TO WIND DIRECTION
SUN ON RT AT 90° TO OBSERVATION POINT.

TEST			Test Load k#/hr	Opacity %	WIND		Sky Cond.	Sun Posi- tion	Comments
No.	Time am/pm	Type			Speed mph	Direct			
1	1400	LO O ₂ #2 OIL	14	0	0-5	S.E.	CLOUDY HAZY	90° TO RT.	
2	1405			0					
3	1410			0					
4	1415			0					
5	1420			0					THERMAL PLUME IS VISIBLE AGAINST CLOUDS
6	1425			0					
7	1430			0					
8	1435			0					
9	1448			5					
10	1509			0-5					
11	1510			5					
12	1511			0-5					
13	1512			0					
14	1513			0-5					
15	1514			0					
16	1515			0					

PLUME OPACITY OBSERVATION RECORD

Test Run No. 19-74, 75

LOCATION NO. 19 OBSERVER M. HAGERTY

OWNER _____ BOILER NO. 1 CAPACITY ~18 klb/hr

DATE 1-19-77 FUEL TYPE #2 OIL BURNER TYPE _____

POINT OF EMISSION STACK

POINT OF OBSERVATION ~200' FROM STACK AT 90° TO WIND DIRECTION, SUN ON RT. AT 90° TO OBSERVATION POINT.

No.	TEST		Test Load k#/hr	Opacity %	WIND		Sky Cond.	Sun Position	Comments
	Time am/pm	Type			Speed mph	Direct			
1	1400	20 O ₂ #2 OIL	14	0	0-5	S.E	CLOUDY HAZY	90° TO RT.	
2	1405			0					
3	1410			0					
4	1415			0					
5	1420			0					
6	1425			0					
7	1430			0					
8	1435			0					
9	1448			5					
10	1509			0-5					
11	1510			5					
12	1511			0-5					
13	1512			0					
14	1513			0-5					
15	1514			0					
16	1515			0					

PLUME OPACITY OBSERVATION RECORD

Test Run No. 19-83,84

LOCATION NO. 19 OBSERVER M. HABERTY
 OWNER _____ BOILER NO. 1 CAPACITY _____ klb/hr
 DATE 1-20-77 FUEL TYPE #2 OIL BURNER TYPE _____

POINT OF EMISSION STACK

POINT OF OBSERVATION ~ 300' FROM STACK @ 90° TO WIND DIRECTION,
SUN @ 90° TO RT. FROM OBSERVATION POINT

No.	TEST		Test Load k#/hr	Opacity %	WIND		Sky Cond.	Sun Posi- tion	Comments
	Time am/pm	Type			Speed mph	Direct			
1	1620	LO O ₂ 40% FER	14	0	0-5	S.E	HAZY	90° TO RT.	ATMOSPHERIC HAZE ~ 5%
2	1625			0					
3	1630			0					
4	1631			0					
5	1632			0					
6	1633			0					
7	1634			0					
8	1635			0					
9	1640			0					
10	1645			0					
11	1650			0					
12	1651			0					
13	1652			0					
14	1653			0					
15	1654			0					
16	1655			0					

PLUME OPACITY OBSERVATION RECORD

Test Run No. 19-117

LOCATION NO. 19 OBSERVER SOTTER
 OWNER _____ BOILER NO. 1 CAPACITY 17,500 klb/hr
 DATE 1-26-77 FUEL TYPE #2 BURNER TYPE FABER

POINT OF EMISSION STACK
 POINT OF OBSERVATION ACROSS STREET, 45° TO WIND DIRECTION,
SUN 20° TO RT FROM OBSERVATION POINT. ~ 2 STACK
HEIGHTS FROM STACK

TEST			Test Load k#/hr	Opacity %	WIND		Sky Cond.	Sun Posi- tion	Comments
No.	Time am/pm	Type			Speed mph	Direct			
1	1155	H1 2 MIN O ₂		20			PARTLY CLOUDY	BEHIND OBSERVER + CLOUDS	OPACITY FLUCTUATING
2				20					
3				0					
4				5					
5				10					
6				15					
7				5					
8				10					
9				5					
10	1158			25					
11				15					
12				30					
13				15					
14				10					
15				10					
16				15					

Test Run No. 19-117

DATE 1/26/77 FUEL TYPE _____ BURNER TYPE _____

POINT OF OBSERVATION

60-25

PLUME OPACITY OBSERVATION RECORD

19-132

Test Run No. 12 P/3/7

LOCATION NO. 19 OBSERVER MBH

OWNER _____ BOILER NO. _____ CAPACITY _____ klb/hr

DATE 2-12-77 FUEL TYPE _____ BURNER TYPE _____

POINT OF EMISSION _____

POINT OF OBSERVATION ~ 150 ft North-East of building

No.	TEST Time	Type	Test Load k#/hr	Opacity %	WIND		Sky Cond.	Sun Posi- tion	Comments
	pm				Speed mph	Direct			
1	start 11:58			5	10-15	NW	clear		
2	11:58:15								
3	:30								
4	:45								
5	11:59								
6	:15								
7	:30								
8	:45								
9	12:00								
10	:15								
11	:30								
12	:45								
13	12:01								
14	:15								
15	:30								
16	:45								

PLUME OPACITY OBSERVATION RECORD

Test Run No. 19-140

LOCATION NO. 19 OBSERVER M. B. H.

OWNER _____ BOILER NO. _____ CAPACITY _____ klb/hr

DATE 2-21-77 FUEL TYPE _____ BURNER TYPE _____

POINT OF EMISSION stack

POINT OF OBSERVATION ~100 ft. North East of stack

TEST			Test Load k#/hr	Opacity %	WIND		Sky Cond.	Sun Posi- tion	Comments
No.	Time am/pm	Type			Speed mph	Direct			
1	14:45			25	15-20		clear sky		
2	:15			25					
3	:30			20					
4	:45			25					
5	14:46			20					
6	:15			25					
7	:30			30					
8	:45			25					
9	14:47			20					
10	:15			20					
11	:30			15					
12	:45			25					
13	14:48			20					
14	:15			20					
15	:30			25					
16	:45			30	↓		↓		

PLUME OPACITY OBSERVATION RECORD

Test Run No. 19-159

LOCATION NO. 19 OBSERVER MBH
 OWNER _____ BOILER NO. 1 CAPACITY _____ klb/hr
 DATE 2-23-77 FUEL TYPE #6 BURNER TYPE _____

POINT OF EMISSION stack

POINT OF OBSERVATION 100 feet NE of stack

No.	TEST		Test Load k#/hr	Opacity %	WIND		Sky Cond.	Sun Posi- tion	Comments
	Time am/pm	Type			Speed mph	Direct			
1	11:40			0	5-10	W.	clear		
2	11:45			0					
3	11:30			0					
4	11:45			0					
5	11:41			0					
6	11:15			0					
7	11:30			0					
8	11:45			0					
9	11:42			0					
10	11:15			0					
11	11:30			0					
12	11:45			0					
13	11:43			0					
14	11:15			0					
15	11:30			0					
16	11:45			0					

PLUME OPACITY OBSERVATION RECORD

Test Run No. 19-165

LOCATION NO. 19 OBSERVER MBH

OWNER _____ BOILER NO. _____ CAPACITY _____ klb/hr

DATE 3-1-77 FUEL TYPE _____ BURNER TYPE _____

POINT OF EMISSION stack

POINT OF OBSERVATION ~ 100 ft. NE of stack

TEST No.	Time am/pm	Type	Test Load k#/hr	Opacity %	WIND		Sky Cond.	Sun Posi- tion	Comments
					Speed mph	Direct			
1	9:23			0	~ 10	S.E.	clear		
2	:15			0					
3	:30			0					
4	:45			0					
5	9:24			0					
6	:15			0					
7	:30			0					
8	:45			0					
9	9:25			0					
10	:15			0					
11	:30			0					
12	:45			0					
13	9:26			0					
14	:15			0					
15	:30			0					
16	:45			0	↓	↓	↓		

PLUME OPACITY OBSERVATION RECORD

Test Run No. 19-170

LOCATION NO. 19 OBSERVER MBH

OWNER _____ BOILER NO. 1 CAPACITY _____ klb/hr

DATE 3-1-77 FUEL TYPE #6 oil BURNER TYPE _____

POINT OF EMISSION Stack

POINT OF OBSERVATION 100 ft. NE of stack

No.	TEST		Test Load k#/hr	Opacity %	WIND		Sky Cond.	Sun Position	Comments
	Time am/pm	Type			Speed mph	Direct			
1	14:10			0	15-20	E.	clear		
2	15			0					
3	30			0					
4	45			0					
5	14:11			0					
6	15			0					
7	30			0					
8	45			0					
9	14:12			0					
10	15			0					
11	30			0					
12	45			0					
13	14:13			0					
14	15			0					
15	30			0					
16	45			0					

PLUME OPACITY OBSERVATION RECORD

Test Run No. 19-179

LOCATION NO. 19 OBSERVER M.B.H.

OWNER _____ BOILER NO. 1 CAPACITY _____ klb/hr

DATE 3-3-77 FUEL TYPE #2 BURNER TYPE _____

POINT OF EMISSION Stack

POINT OF OBSERVATION ~100 ft. NE of stack

TEST No.	Time am/pm	Type	Test Load k#/hr	Opacity %	WIND		Sky Cond.	Sun Posi- tion	Comments
					Speed mph	Direct			
1	13:43			0	0-5	NW	Hazy clouds		
2	1:15			0					
3	1:30			0					
4	1:45			0					
5	13:44			0					
6	1:15			0					
7	1:30			0					
8	1:45			0					
9	13:45			0					
10	1:15			0					
11	1:30			0					
12	1:45			0					
13	13:46			0					
14	1:15			0					
15	1:30			0					
16	1:45			0					

PLUME OPACITY OBSERVATION RECORD

Test Run No. 19-190

LOCATION NO. 19 OBSERVER MBH

OWNER _____ BOILER NO. 1 CAPACITY _____ klb/hr

DATE 3-7-77 FUEL TYPE N.G. BURNER TYPE _____

POINT OF EMISSION stack

POINT OF OBSERVATION ~100 ft N.E. of stack

TEST			Test Load k#/hr	Opacity %	WIND		Sky Cond.	Sun Posi- tion	Comments
No.	Time am/pm	Type			Speed mph	Direct			
1	11:24			0	5-10	E	cloudy		
2	1:15			0					
3	1:30			0					
4	1:45			0					
5	11:25			0					
6	1:15			0					
7	1:30			0					
8	1:45			0					
9	11:26			0					
10	1:15			0					
11	1:30			0					
12	1:45			0					
13	11:27			0					
14	1:15			0					
15	1:30			0					
16	1:45			0					

PLUME OPACITY OBSERVATION RECORD

Test Run No. 19-1 SASS

LOCATION NO. 19 OBSERVER MBH

OWNER _____ BOILER NO. _____ CAPACITY _____ klb/hr

DATE 3-10-77 FUEL TYPE #6 OIL BURNER TYPE _____

POINT OF EMISSION _____

POINT OF OBSERVATION ~100 feet north of stack

TEST			Test Load k#/hr	Opacity %	WIND		Sky Cond.	Sun Posi- tion	Comments
No.	Time am/pm	Type			Speed mph	Direct			
1	1115	SASS		0	0-5	S.W.	CLEAR		
2	1130			0					
3	1145			0					
4	1200			0					
5	1215			0					
6	1230			0					
7	1245			0					
8	1300			0					
9	1315			0					
10	1330			0					
11	1345			0					
12	1400			0					
13	1415			0					
14	1430			0					
15	1445			0					
16	1500			0					

PLUME OPACITY OBSERVATION RECORD

Test Run No. 19-15ASS

LOCATION NO. 19 OBSERVER MBH

OWNER _____ BOILER NO. _____ CAPACITY _____ klb/hr

DATE 3-10-77 FUEL TYPE #6 OIL BURNER TYPE

POINT OF EMISSION _____

POINT OF OBSERVATION ~ 100 feet north of stack

[illegible]

PLUME OPACITY OBSERVATION RECORD

Test Run No. 19-2 SASS

LOCATION NO. 19 OBSERVERS MBH/HJB

OWNER _____ BOILER NO. _____ CAPACITY _____ klb/hr

DATE 3-17-77 FUEL TYPE _____ BURNER TYPE _____

POINT OF EMISSION _____

POINT OF OBSERVATION N/00' EAST OF TRAILER

[illegible]

Test Run No. 19-35A55

POINT OF EMISSION _____

POINT OF OBSERVATION ~ 100 feet East _____

[illegible]

Test Run No. 19-4/5055

POINT OF EMISSION _____

POINT OF OBSERVATION ~100' East of emission point

[illegible]


VELOCITY TRAVERSE

Project: _____ Test Description: _____
 Date: _____
 Location: 19 _____
 Unit: 1 _____
 Test: 19-1,3 Personnel: _____
 Fuel: #2 OIL _____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_s)
 Pitot Tube Coefficient: .83 (C_p)

$$V_s = 85.48 C_p \left[\frac{T_s \Delta P}{P_s M_s} \right]^{1/2}$$

Stack Cross Section



Time	Traverse Point Port Depth	Velocity Head (in. H ₂ O)	Gas Temp. (°F)	Gas Temp. (°R)	Molecular Wt.	Velocity (ft/sec)	O ₂ Conc. (% Dry)
		ΔP		T_s	M_s	V_s	
	0	.060	460	920			3.17
	2	.085	450	910		25.5	3.20
	4						3.15
	6	.085	462	922		25.7	3.16
	8						3.16
	10						3.17
	12	.085	470	930		25.8	3.13
	14						3.13
	16						3.14
	18	.090	475	935		26.6	3.13
	20						3.10
	22						3.08
	24	.085	460	920		25.6	3.08
	26						3.08
	28						3.07

6002-13

Project: _____ Test Description: _____

Project: _____ Test Description: _____

Date: 1-19-77

Location: 19

Unit: /

Test: 19-7475 Personnel:

Fuel: # 2 OIL

Barometric Press. (in. Hg): _____

Absolute Static Press. in Stack (in. Hg): _____ (P_B)

Pitot Tube Coefficient: _____ (C_p)

$$V_S = 85.48 C_P \left[\frac{T_{S\Delta P}}{P_{S M_S}} \right]^{1/2}$$

Stack Cross Section

A blank sheet of graph paper with a grid pattern. The grid consists of small squares formed by thin black lines. There are approximately 20 columns and 20 rows of squares visible on the page. The paper is otherwise empty, with no text or markings other than the grid itself.[illegible]

6002-13

Project: _____	Test Description: _____
Date: <u>1-20-77</u>	_____
Location: <u>19</u>	_____
Unit: <u>1</u>	_____
Test: <u>19-83,84</u>	Personnel: _____
Fuel: <u>#2 OIL</u>	_____
Barometric Press. (in. Hg): <u>29.8</u>	_____
Absolute Static Press. in Stack (in. Hg): _____	(P _s)
Pitot Tube Coefficient: <u>.83</u>	(C _p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{SM} S} \right]^{1/2}$$

[illegible]

196

Project: _____ Test Description: _____
Date: 1-24-77 _____
Location: 19 _____
Unit: 1 _____
Test: 19-97, 98 Personnel: R. PIONESEA
Fuel: #6 OIL _____
Barometric Press. (in. Hg): 30.16 _____
Absolute Static Press. in Stack (in. Hg): _____ (P_g)
Pitot Tube Coefficient: .83 (C_D)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

[illegible]

197

Test Description:

Date: 1-26-77

location: 19 _____

Unit: /

Test: 19-116 Personnel:

Fuel: #2 oil

Barometric Press. (in. Hg): 29.72

Absolute Static Press. in Stack (in. ⁴⁰Hg): - .225 (P₈)

Pitot Tube Coefficient: 0.83 (C_p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

[illegible]

198

Project: _____ Test Description: _____
Date: 2-17-77 _____
Location: 19 _____
Unit: 1 _____
Test: 19-132 Personnel: G. Sotter
Fuel: #6 O.I. _____
Barometric Press. (in. Hg): 30.12 _____
Absolute Static Press. in Stack (in. ^{Hg} Hg): -0.23 (1)
Pitot Tube Coefficient: 0.83 (0)

A blank 20x20 grid for graphing. The grid consists of 20 columns and 20 rows of small squares, forming a larger square area. The grid is used for plotting the graph of the function $y = \frac{1}{2}x^2$.

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

[illegible]

199

Project: _____ Test Description: _____
Date: 2-21-77 _____
Location: 19 _____
Unit: _____
Test: 19-143 Personnel: _____
Fuel: #6 oil _____
Barometric Press. (in. Hg): 29.81 _____
Absolute Static Press. in Stack (in. Hg): ^{14.0} -0.2 (P_g)
Pitot Tube Coefficient: 0.83 (C_p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_S M_S} \right]^{1/2}$$

[illegible]

200

Test Description: Meth 5

Date: 2-23-77

Location: 19

Unit: /

Test: 19-159 Personnel: R. P.

Fuel: _____

Barometric Press. (in. Hg): 30.08

Absolute Static Press. in Stack (in. ^{H₂O} Hg): -23 (P.)

Pitot Tube Coefficient: 0.83 (C_p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

A blank 20x20 grid for graphing, consisting of 20 columns and 20 rows of squares.

[illegible]

201

Test Description: _____

Date: 3-1-77

Unit: 1

Fuel: #6 oil

Absolute Static Press. in Stack (in. Hg): -0.22

Pitot Tube Coefficient: 0.83

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_S M_S} \right]^{1/2}$$

[illegible]

6002-13

Project: _____	Test Description: _____
Date: <u>3-3-77</u>	_____
Location: <u>19</u>	_____
Unit: <u>1</u>	_____
Test: <u>19-179</u>	Personnel: <u>G.S.</u>
Fuel: <u>#2 oil</u>	_____

Barometric Press. (in. Hg): 30.34
Absolute Static Press. in Stack (in. Hg): -0.23 (P_s)
Pitot Tube Coefficient: 0.83 ^{H₂O} (C_p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

[illegible]

203

Project: _____ Test Description: _____

Date: 3-7-77

Date: 3-7-77

Location: 19 _____

Unit: /

Test: 19-190 Personnel:

Encl: Not FBI


Fuel: NE1. E-83
Barometric Press. (in Hg): 30.03

Barometric Press. (In. Hg): 30.01

Absolute Static Press. in Stack (in. Hg): -0.23 (P_s)

Pitot Tube Coefficient: 0.83 (C_p)

$$(V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M} S} \right]^{1/2}$$



6002-13

Project: _____	Test Description: _____
Date: <u>3-8-77</u>	_____
Location: <u>19</u>	_____
Unit: <u>1</u>	_____
Test: <u>19-193</u>	Personnel: _____
Fuel: <u>Nat. Gas</u>	_____

Barometric Press. (in. Hg): 30.28
Absolute Static Press. in Stack (in. Hg): 0.225 (P_s)
Pitot Tube Coefficient: 0.83 (C_p)

$$V_S = 85.48 C_P \left[\frac{T_{S\Delta P}}{P_{SM_S}} \right]^{1/2}$$

[illegible]

205

Date 1/5/77

K V B. INC.

Test No. 19-3

SOx DATA SHEET

TEST NO. 19-3 UNIT NO. _____ FUEL _____ LOAD _____ klb/hr Location 19
CAL. BOTTLE 1120 ppm ± 2%

Box No.	X-1	X-1			
Time	1105	1125			
Temp. in Gas Meter	62	69			
Press. in Gas Meter	0	0			
Meter Reading	0.000	1.000			
Barom. Press.	30.08	30.08			
Percent Oxygen					
N ₂ Purge Time	1210	1230			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ _____ %

A = Ml of lead perchlorate used for sample =

B = Ml of lead perchlorate used for bland =

N = Normality of lead perchlorate titrant =

F = Dilution factor =

T = Average temp. in gas meter =

V = Volume of gas sample ft³ =

P = Barometric pressure =

p = Pressure in gas meter =

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

lb/MBtu =

ng/J =

C = pollutant concentration, g/dscm

F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu

from Fed. Reg. 9/11/74 p 32856

60-14

rev. 1/2/75

Test No. 19-3

SOx DATA SHEET

TEST NO. 19-3 UNIT NO. _____ FUEL _____ LOAD _____ klb/hr _____ Location 19
CAL BOTTLE 1120ppm $\pm 2\%$

Box No.	X-2	X-2		
Time	1130	1144		
Temp. in Gas Meter	68	72		
Press. in Gas Meter				
Meter Reading	0.000	1.000		
Barom. Press.				
Percent Oxygen				
N ₂ Purge Time	1145	1205		

$$\text{Calculation: } \text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$$

Excess O₂ _____ g

A = Ml of lead perchlorate used for sample =

B = Ml of lead perchlorate used for bland =

N = Normality of lead perchlorate titrant =

F = Dilution factor

T = Average temp. in gas meter

V = Volume of gas sample ft³ =

P = Barometric pressure

p = Pressure in gas meter

Concentration, C, ppm =

gm/dscm

Emission ,E, g/Mcal =

1b/MBtu =

$$\text{ng/J} =$$

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

C = pollutant concentration, g/dscm
F, volume factor = dscm/10⁴ gal

_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 32856

[illegible]

60-14
rev. 1/2/75

Date 1/6/77

K V B. INC.

Test No. 19-5

SOx DATA SHEET

TEST NO. 19-5 UNIT NO. _____ FUEL 201L LOAD _____ klb/hr _____ Location 19
START FINISH

Box No.	X-1	X-1			
Time	0930	0953			
Temp. in Gas Meter	29	36			
Press. in Gas Meter	6	6			
Meter Reading	0.000	3.000			
Barom. Press.	30.19	30.19			
Percent Oxygen	3.12	3.12			
N ₂ Purge Time	1000	1020			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ _____ %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	9.0	3.2	
B = Ml of lead perchlorate used for bland =	2.50		
N = Normality of lead perchlorate titrant =	0.01079		
F = Dilution factor =	10	1	
T = Average temp. in gas meter =			
V = Volume of gas sample ft ³ =			
P = Barometric pressure =			
p = Pressure in gas meter =			
Concentration, C, ppm =	91.6	1.0	
, gm/dscm =			
Emission, E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm
F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 3285660-14
rev. 1/2/75

Date 1/6/77

K V B, INC.

Test No. 19-5SOx DATA SHEETTEST NO. 19-5 UNIT NO. _____ FUEL #20/L LOAD _____ klb/hr _____ Location _____

Box No.	X-2	X-2			
Time	0958	1029			
Temp. in Gas Meter	34	34			
Press. in Gas Meter	0	0			
Meter Reading	0.000	3.000			
Barom. Press.	30.19	30.19			
Percent Oxygen	3.12	3.12			
N ₂ Purge Time	1035	1055			

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 3.12 %

A = Ml of lead perchlorate used for sample =
 B = Ml of lead perchlorate used for bland =
 N = Normality of lead perchlorate titrant =
 F = Dilution factor =
 T = Average temp. in gas meter =
 V = Volume of gas sample ft³ =
 P = Barometric pressure =
 p = Pressure in gas meter =

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

lb/MBtu =

ng/J =

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
 from Fed. Reg. 9/11/74 p 32856

SO ₂	SO ₃	SO _x
9.0	3.10	
10	1	
91.6	0.85	

60-14
 rev. 1/2/75

Date 1/6/77

K V B. INC.

Test No. 19-5SOx DATA SHEETTEST NO. 19-5 UNIT NO. _____ FUEL #2016 LOAD _____ klb/hr _____ Location _____

Box No.	X-1	X-1			
Time	1030	1055			
Temp. in Gas Meter	34	38			
Press. in Gas Meter	0	0			
Meter Reading	0.000	3.000			
Barom. Press.	30.19	30.19			
Percent Oxygen	3.12	3.12			
N ₂ Purge Time	1100	1125			

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ _____ %

A = Ml of lead perchlorate used for sample =

B = Ml of lead perchlorate used for bland =

N = Normality of lead perchlorate titrant =

F = Dilution factor =

T = Average temp. in gas meter =

V = Volume of gas sample ft³ =

P = Barometric pressure =

p = Pressure in gas meter =

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

lb/MBtu =

ng/J =

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm

F, volume factor = _____ dscm/10⁴ calfrom Fed. Reg. 9/11/74 p 32856 _____ dscf/10⁴ Btu

SO ₂	SO ₃	SO _x
8.7	3.5	
10	1	
82.9	1.4	

60-14
rev. 1/2/75

Date 1-19-77

K V B. INC.

Test No. 19-74

SOX DATA SHEET

TEST NO. 19-74 UNIT NO. _____ FUEL #20/L LOAD _____ klb/hr _____ Location 19

Box No.	X-1	X-1			
Time	1115	1130			
Temp. in Gas Meter	70	72			
Press. in Gas Meter	0	0			
Meter Reading	0	1.0			
Barom. Press.	29.73	29.73			
Percent Oxygen					
N ₂ Purge Time	1134	1201			

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$

Excess O₂ _____ %

A = Ml of lead perchlorate used for sample =

B = Ml of lead perchlorate used for bland =

N = Normality of lead perchlorate titrant =

F = Dilution factor =

T = Average temp. in gas meter (°R) =

V = Volume of gas sample ft³ =

P = Barometric pressure =

p = Pressure in gas meter =

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

lb/MBtu =

ng/J =

$$E = CF \left[\frac{2090}{20.9 - x_{\text{O}_2}} \right]$$

where

C = pollutant concentration, g/dscm

F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu

from Fed. Reg. 9/11/74 p 32856

SO ₂	SO ₃	SO _x
10.2	32.6	
9.5	9.5	
0.01079	0.01079	
10	1	
531	531	
1.0	1.0	
29.73	29.73	
0	0	
33	106.8	

BAD PURGE : DELETE

60-14

rev. 1/2/75

Date 1-19-77

K V B, INC.

Test No. 19-74SOx DATA SHEETTEST NO. 1974 UNIT NO. _____ FUEL # 2 OIL LOAD _____ klb/hr _____ Location 19
START FINISH

Box No.	X-2	X-2			
Time	1143	1200			
Temp. in Gas Meter	80	78			
Press. in Gas Meter	0	0			
Meter Reading	0	1.0			
Barom. Press.	29.73	29.73			
Percent Oxygen					
N ₂ Purge Time	1205	1231			

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ _____ %

A = Ml of lead perchlorate used for sample =
 B = Ml of lead perchlorate used for bland =
 N = Normality of lead perchlorate titrant =
 F = Dilution factor =
 T = Average temp. in gas meter (°R) =
 V = Volume of gas sample ft³ =
 P = Barometric pressure =
 p = Pressure in gas meter =

SO ₂	SO ₃	SO _x
12.2	10.1	
9.5	9.5	
0.01079	0.01079	
10	1	
539	539	
1.0	1.0	
29.73	29.73	
0	0	
126.7	2.8	

Concentration, C, ppm =
 , gm/dscm =
 Emission , E, g/Mcal =

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

lb/MBtu =
 ng/J =

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
 from Fed. Reg. 9/11/74 p 32856

60-14
 rev. 1/2/75

Date 1-19-77

K V B, INC.

Test No. 19-74

SOX DATA SHEET

TEST NO. 19-74 UNIT NO. _____ FUEL #20/L LOAD _____ klb/hr Location 19

Box No.	X-1	X-1			
Time	1215	1230			
Temp. in Gas Meter	80	80			
Press. in Gas Meter	0	0			
Meter Reading	0	1.0			
Barom. Press.	29.73	29.73			
Percent Oxygen					
N ₂ Purge Time	1235	1205			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$

Excess O₂ _____ %

A = Ml of lead perchlorate used for sample =

B = Ml of lead perchlorate used for bland =

N = Normality of lead perchlorate titrant =

F = Dilution factor =

T = Average temp. in gas meter (°R) =

V = Volume of gas sample ft³ =

P = Barometric pressure =

p = Pressure in gas meter =

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

lb/MBtu =

ng/J =

$$E = CF \left[\frac{2090}{20.9 - xO_2} \right]$$

where

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu

from Fed. Reg. 9/11/74 p 32856

SO ₂	SO ₃	SO _x
10.9	31.5	
9.5	9.5	
0.01079	0.01079	
10	1	
540	540	
1.0	1.0	
29.73	29.73	
0	0	
65.8	103.4	

BAD PURGE: DELETE

60-14
 rev. 1/2/75

Date 1-20-77

K V B. INC.

Test No. 19-78

SOx DATA SHEET

TEST NO. 19-78 UNIT NO. _____ FUEL #20/L LOAD _____ klb/hr Location 19
CAL BOTTLE 1120 PPM ± 2%

Box No.	<u>X-1</u>	<u>X-1</u>			
Time	<u>0822</u>	<u>0835</u>			
Temp. in Gas Meter	<u>71</u>	<u>70</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.05</u>			
Barom. Press.	<u>29.80</u>	<u>29.80</u>			
Percent Oxygen	<u>0</u>	<u>0</u>			
N ₂ Purge Time	<u>0847</u>	<u>0913</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 0 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>36.4</u>	<u>10.7</u>	
B = Ml of lead perchlorate used for bland =	<u>9.0</u>	<u>9.0</u>	
N = Normality of lead perchlorate titrant =	<u>.01079</u>	<u>.01079</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>531°R</u>	<u>531°R</u>	
V = Volume of gas sample ft ³ =	<u>1.05</u>	<u>1.05</u>	
P = Barometric pressure =	<u>29.80</u>	<u>29.80</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>1204</u>	<u>7</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm
F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 3285660-14
rev. 1/2/75

Date 1-20-78

K V B, INC.

Test No. 19-78

SOx DATA SHEET

TEST NO. 19-78 UNIT NO. _____ FUEL #2 OIL LOAD _____ klb/hr Location 19

Box No.	<u>X-2</u>	<u>X-2</u>			
Time	<u>0924</u>	<u>0937</u>			
Temp. in Gas Meter	<u>78</u>	<u>76</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.0</u>			
Barom. Press.	<u>29.80</u>	<u>29.80</u>			
Percent Oxygen	<u>0</u>	<u>0</u>			
N ₂ Purge Time	<u>0944</u>	<u>1007</u>			

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 0 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>33.6</u>	<u>10.1</u>	
B = Ml of lead perchlorate used for bland =	<u>9.0</u>	<u>9.0</u>	
N = Normality of lead perchlorate titrant =	<u>.01079</u>	<u>.01079</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>537</u>	<u>537</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>29.80</u>	<u>29.80</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>1147</u>	<u>5</u>	
, gm/dscm =			
Emission ,E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm
F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 3285660-14
rev. 1/2/75

Date 1-20-77

K V B. INC.

Test No. 19-83

SOx DATA SHEET

TEST NO. 19-83 UNIT NO. _____ FUEL #2 OIL LOAD 14.5 klb/hr Location 19

Box No.	<u>2-1</u>	<u>2-1</u>			
Time	<u>1420</u>	<u>1434</u>			
Temp. in Gas Meter	<u>83</u>	<u>83</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.0</u>			
Barom. Press.	<u>29.80</u>	<u>29.80</u>			
Percent Oxygen	<u>.9</u>	<u>.9</u>			
N ₂ Purge Time	<u>1440</u>	<u>1500</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 0.9 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>5.9</u>	<u>4.8</u>	
B = Ml of lead perchlorate used for bland =	<u>3.5</u>	<u>3.5</u>	
N = Normality of lead perchlorate titrant =	<u>.01079</u>	<u>.01079</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>543</u>	<u>543</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>29.80</u>	<u>29.80</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>113</u>	<u>6.1</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
 from Fed. Reg. 9/11/74 p 32856

60-14
 rev. 1/2/75

Date 1-20-77

K V B, INC.

Test No. 19-83

SOx DATA SHEET

TEST NO. 19-83 UNIT NO. _____ FUEL # 2 oil LOAD 14.5 klb/hr Location 19

Box No.	<u>7-2</u>	<u>7-2</u>			
Time	<u>1444</u>	<u>1458</u>			
Temp. in Gas Meter	<u>84</u>	<u>88</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.0</u>			
Barom. Press.	<u>29.80</u>	<u>29.80</u>			
Percent Oxygen	<u>.9</u>	<u>.9</u>			
N ₂ Purge Time	<u>1503</u>	<u>1525</u>			

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ .9 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>5.8</u>	<u>4.6</u>	
B = Ml of lead perchlorate used for bland =	<u>3.5</u>	<u>3.5</u>	
N = Normality of lead perchlorate titrant =	<u>.01079</u>	<u>.01079</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>546</u>	<u>546</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>29.80</u>	<u>29.80</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>109</u>	<u>5.2</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - x_{\text{O}_2}} \right]$$

where

C = pollutant concentration, g/dscm
F, volume factor = dscm/10⁴ cal dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 3285660-14
rev. 1/2/75

Date 1-20-77

K V B, INC.

Test No. 19-83

SOx DATA SHEET

TEST NO. 19-83 UNIT NO. _____ FUEL #2 OIL LOAD 14.5 klb/hr Location 19

Box No.	<u>X-1</u>	<u>X-1</u>			
Time	<u>1512</u>	<u>1524</u>			
Temp. in Gas Meter	<u>90</u>	<u>88</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.0</u>			
Barom. Press.	<u>29.80</u>	<u>29.80</u>			
Percent Oxygen	<u>.9</u>	<u>.9</u>			
N ₂ Purge Time					

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ .9 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>5.2</u>	<u>4.6</u>	
B = Ml of lead perchlorate used for bland =	<u>3.5</u>	<u>3.5</u>	
N = Normality of lead perchlorate titrant =	<u>.01079</u>	<u>.01079</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>549</u>	<u>549</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>29.80</u>	<u>29.80</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>81</u>	<u>5.2</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
 from Fed. Reg. 9/11/74 p 32856

60-14
 rev. 1/2/75

Date 1-24-77

K V B, INC.

Test No. 19-97

SOx DATA SHEET

TEST NO. 19-97 UNIT NO. _____ FUEL #6014 LOAD 13.8 klb/hr Location 19

Box No.	<u>7-1</u>	<u>7-1</u>			
Time	<u>1022</u>	<u>1055</u>			
Temp. in Gas Meter	<u>86</u>	<u>87</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>2.700</u>			
Barom. Press.	<u>30.16</u>	<u>30.16</u>			
Percent Oxygen					
N ₂ Purge Time	<u>1104</u>	<u>1125</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ _____ %

A = Ml of lead perchlorate used for sample =
 B = Ml of lead perchlorate used for bland =
 N = Normality of lead perchlorate titrant =
 F = Dilution factor =
 T = Average temp. in gas meter =
 V = Volume of gas sample ft³ =
 P = Barometric pressure =
 p = Pressure in gas meter =

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

lb/MBtu =

ng/J =

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu

from Fed. Reg. 9/11/74 p 32856

SO ₂	SO ₃	SO _x
<u>22.1</u>	<u>6.1</u>	
<u>4.1</u>	<u>4.1</u>	
<u>.01079</u>	<u>.01079</u>	
<u>10</u>	<u>1</u>	
<u>547</u>	<u>547</u>	
<u>2.700</u>	<u>2.700</u>	
<u>30.16</u>	<u>30.16</u>	
<u>0</u>	<u>0</u>	
<u>313</u>	<u>3.5</u>	

60-14
rev. 1/2/75

Date 1-24-77

K V B. INC.

Test No. 19-97

SOx DATA SHEET

TEST NO. 19-97 UNIT NO. _____ FUEL #6 LOAD 13.8 klb/hr Location _____

Box No.	<u>X-2</u>	<u>X-2</u>			
Time	<u>1100</u>	<u>1130</u>			
Temp. in Gas Meter	<u>87</u>	<u>88</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>2.200</u>			
Barom. Press.	<u>30.16</u>	<u>30.16</u>			
Percent Oxygen					
N ₂ Purge Time	<u>1135</u>	<u>1155</u>			

Calculation: $SO_3 \text{ or } SO_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ _____ %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>15.0</u>	<u>5.8</u>	
B = Ml of lead perchlorate used for bland =	<u>4.1</u>	<u>4.1</u>	
N = Normality of lead perchlorate titrant =	<u>.01079</u>	<u>.01079</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>548</u>	<u>548</u>	
V = Volume of gas sample ft ³ =	<u>2.200</u>	<u>2.200</u>	
P = Barometric pressure =	<u>30.16</u>	<u>30.16</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>297</u>	<u>3.6</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
E = CF $\left[\frac{2090}{20.9 - xO_2} \right]$ lb/MBtu =			
where $\left[\frac{2090}{20.9 - xO_2} \right]$ ng/J =			

C = pollutant concentration, g/dscm
F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 3285660-14
rev. 1/2/75

Date 1-24-77

K V B, INC.

Test No. 19-97SO_x DATA SHEETTEST NO. 19-97 UNIT NO. _____ FUEL #6 OIL LOAD 12.8 klb/hr Location _____

Box No.	<u>2-1</u>	<u>2-1</u>		
Time	<u>1135</u>	<u>1136</u>		
Temp. in Gas Meter	<u>89</u>	<u>90</u>		
Press. in Gas Meter	<u>0</u>	<u>0</u>		
Meter Reading	<u>0</u>	<u>2.700</u>		
Barom. Press.	<u>30.16</u>	<u>30.16</u>		
Percent Oxygen				
N ₂ Purge Time	<u>1157</u>			

Calculation: SO₃ or SO₂, ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ _____ %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>23.1</u>	<u>6.0</u>	
B = Ml of lead perchlorate used for bland =	<u>4.1</u>	<u>4.1</u>	
N = Normality of lead perchlorate titrant =	<u>.01079</u>	<u>.01079</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>550</u>	<u>550</u>	
V = Volume of gas sample ft ³ =	<u>2.700</u>	<u>2.700</u>	
P = Barometric pressure =	<u>30.16</u>	<u>30.16</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>332</u>	<u>3.3</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm
F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 3285660-14
rev. 1/2/75

Date 1-26-77

K V B. INC.

Test No. 19-116

SOx DATA SHEET

TEST NO. 19-116 UNIT NO. _____ FUEL #2014 LOAD 14.5 klb/hr Location 19

Box No.	<u>2</u>	<u>2</u>			
Time	<u>0957</u>	<u>1020</u>			
Temp. in Gas Meter	<u>77</u>	<u>77</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>3.000</u>			
Barom. Press.	<u>29.72</u>	<u>29.72</u>			
Percent Oxygen					
N ₂ Purge Time	<u>1025</u>	<u>1045</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$

Excess O₂ _____ %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>8.2</u>	<u>3.7</u>	
B = Ml of lead perchlorate used for bland =	<u>2.6</u>	<u>2.6</u>	
N = Normality of lead perchlorate titrant =	<u>.01079</u>	<u>.01079</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>537</u>	<u>537</u>	
V = Volume of gas sample ft ³ =	<u>3.000</u>	<u>3.000</u>	
P = Barometric pressure =	<u>29.72</u>	<u>29.72</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>87</u>	<u>1.7</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
E = CF $\left[\frac{2090}{20.9 - x_{CO_2}} \right]$ lb/MBtu =			
where ng/J =			

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
 from Fed. Reg. 9/11/74 p 32856

60-14
 rev. 1/2/75

Date 1-26-77

K V B. INC.

Test No. 19-116

SOx DATA SHEET

TEST NO. 19-116 UNIT NO. _____ FUEL #2 oil LOAD 14.5 klb/hr Location 19

Box No.	<u>1</u>	<u>1</u>			
Time	<u>1025</u>	<u>1055</u>			
Temp. in Gas Meter	<u>78</u>	<u>80</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>3.000</u>			
Barom. Press.	<u>29.72</u>	<u>29.72</u>			
Percent Oxygen					
N ₂ Purge Time	<u>1100</u>	<u>1120</u>			

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$

Excess O₂ _____ %

A = Ml of lead perchlorate used for sample =

B = Ml of lead perchlorate used for bland =

N = Normality of lead perchlorate titrant =

F = Dilution factor =

T = Average temp. in gas meter =

V = Volume of gas sample ft³ =

P = Barometric pressure =

p = Pressure in gas meter =

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

lb/MBtu =

ng/J =

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
 from Fed. Reg. 9/11/74 p 32856

SO ₂	SO ₃	SO _x
<u>8.0</u>	<u>3.4</u>	
<u>2.6</u>	<u>2.6</u>	
<u>.01079</u>	<u>.01079</u>	
<u>10</u>	<u>1</u>	
<u>539</u>	<u>539</u>	
<u>3.000</u>	<u>3.000</u>	
<u>29.72</u>	<u>29.72</u>	
<u>0</u>	<u>0</u>	
<u>84</u>	<u>1.25</u>	

60-14
 rev. 1/2/75

Date 1-26-77

K V B, INC.

Test No. 19-116

SOx DATA SHEET

TEST NO. 19-116 UNIT NO. _____ FUEL #2 OIL LOAD 14.5 klb/hr Location 19

Box No.	<u>1</u>	<u>1</u>			
Time	<u>1057</u>	<u>1125</u>			
Temp. in Gas Meter	<u>81</u>	<u>93</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>2.017</u>			
Barom. Press.	<u>29.72</u>	<u>29.72</u>			
Percent Oxygen					
N ₂ Purge Time	<u>1125</u>	<u>1145</u>			

Calculation: $SO_3 \text{ or } SO_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ _____ %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>5.5</u>	<u>2.8</u>	
B = Ml of lead perchlorate used for bland =	<u>2.6</u>	<u>2.6</u>	
N = Normality of lead perchlorate titrant =	<u>.01079</u>	<u>.01079</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>546</u>	<u>546</u>	
V = Volume of gas sample ft ³ =	<u>2.017</u>	<u>2.017</u>	
P = Barometric pressure =	<u>29.72</u>	<u>29.72</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>50</u>	<u>.47</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
E = CF $\left[\frac{2090}{20.9 - xO_2} \right]$ lb/MBtu =			
where ng/J =			

C = pollutant concentration, g/dscm

F, volume factor = _____ dscm/10⁴ calfrom Fed. Reg. 9/11/74 p 32856 _____ dscf/10⁴ Btu60-14
rev. 1/2/75

Date 2-17-77

K V B, INC.

Test No. 19-132

SOx DATA SHEET

TEST NO. 19-132 UNIT NO. _____ FUEL #6 LOAD 14.5 klb/hr Location 19

Box No.	<u>X-2</u>	<u>X-2</u>			
Time	<u>0938</u>	<u>0957</u>			
Temp. in Gas Meter	<u>68</u>	<u>72</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.0</u>			
Barom. Press.	<u>30.12</u>	<u>30.12</u>			
Percent Oxygen	<u>.98</u>	<u>.98</u>			
N ₂ Purge Time	<u>1004</u>	<u>1029</u>			

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ .98 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>11.76</u>	<u>3.4</u>	
B = Ml of lead perchlorate used for bland =	<u>2.4</u>	<u>2.4</u>	
N = Normality of lead perchlorate titrant =	<u>.0107</u>	<u>.0107</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>530</u>	<u>530</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>30.12</u>	<u>30.12</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>423</u>	<u>4.5</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
 from Fed. Reg. 9/11/74 p 32856

60-14
 rev. 1/2/75

Date 2-17-77

K V B, INC.

Test No. 19-132

SOx DATA SHEET

TEST NO. 19-132 UNIT NO. _____ FUEL #6 LOAD 14.5 klb/hr Location 19

Box No.	<u>2-1</u>	<u>2-1</u>			
Time	<u>1011</u>	<u>1026</u>			
Temp. in Gas Meter	<u>78</u>	<u>82</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.0</u>			
Barom. Press.	<u>30.12</u>	<u>30.12</u>			
Percent Oxygen	<u>.95</u>	<u>.95</u>			
N ₂ Purge Time	<u>1032</u>	<u>1113</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$

Excess O₂ .95 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>11.8</u>	<u>3.4</u>	
B = Ml of lead perchlorate used for bland =	<u>2.4</u>	<u>2.4</u>	
N = Normality of lead perchlorate titrant =	<u>.0107</u>	<u>.0107</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>540</u>	<u>540</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>30.12</u>	<u>30.12</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>434</u>	<u>4.6</u>	
, gm/dscm =			
Emission ,E, g/Mcal =			
E = CF $\left[\frac{2090}{20.9 - x_{O_2}} \right]$ lb/MBtu =			
where ng/J =			

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
 from Fed. Reg. 9/11/74 p 32856

60-14
 rev. 1/2/75

Date 2-17-77

K V B, INC.

Test No. 19-132

SOx DATA SHEET

TEST NO. 19-132 UNIT NO. _____ FUEL *6 LOAD 14.5 klb/hr Location 19

Box No.	<u>X-2</u>	<u>X-2</u>			
Time	<u>1043</u>	<u>1104</u>			
Temp. in Gas Meter	<u>82</u>	<u>83</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.0</u>			
Barom. Press.	<u>30.12</u>	<u>30.12</u>			
Percent Oxygen	<u>.95</u>	<u>.95</u>			
N ₂ Purge Time	<u>1115</u>	<u>1142</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ .95 %

A = Ml of lead perchlorate used for sample =

B = Ml of lead perchlorate used for bland =

N = Normality of lead perchlorate titrant =

F = Dilution factor =

T = Average temp. in gas meter =

V = Volume of gas sample ft³ =

P = Barometric pressure =

p = Pressure in gas meter =

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

$$E = CF \left[\frac{2090}{20.9 - xO_2} \right]$$

where

lb/MBtu =

ng/J =

C = pollutant concentration, g/dscm

F, volume factor = $\frac{\text{dscm}}{\text{dscm}/10^4 \text{ cal}}$ $\frac{\text{dscf}}{10^4} \text{ Btu}$

from Fed. Reg. 9/11/74 p 32856

SO ₂	SO ₃	SO _x
<u>13.0</u>	<u>3.7</u>	
<u>2.4</u>	<u>2.4</u>	
<u>.0107</u>	<u>.0107</u>	
<u>10</u>	<u>1</u>	
<u>542</u>	<u>542</u>	
<u>1.0</u>	<u>1.0</u>	
<u>30.12</u>	<u>30.12</u>	
<u>0</u>	<u>0</u>	
<u>489</u>	<u>6</u>	

60-14

rev. 1/2/75

Date 2-21-77

K V B. INC.

Test No. 19-143

SOx DATA SHEET

TEST NO. 19-143 UNIT NO. _____ FUEL #6 LOAD 13.6 klb/hr Location 19

Box No.	<u>7-2</u>	<u>7-2</u>			
Time	<u>1017</u>	<u>1034</u>			
Temp. in Gas Meter	<u>80</u>	<u>80</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.0</u>			
Barom. Press.	<u>29.81</u>	<u>29.81</u>			
Percent Oxygen	<u>3.1</u>	<u>3.1</u>			
N ₂ Purge Time	<u>1037</u>	<u>1106</u>			

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 3.1 %

A = Ml of lead perchlorate used for sample =
 B = Ml of lead perchlorate used for bland =
 N = Normality of lead perchlorate titrant =
 F = Dilution factor =
 T = Average temp. in gas meter =
 V = Volume of gas sample ft³ =
 P = Barometric pressure =
 p = Pressure in gas meter =

SO ₂	SO ₃	SO _x
<u>11.9</u>	<u>5.4</u>	
<u>4.5</u>	<u>4.5</u>	
<u>.0107</u>	<u>.0107</u>	
<u>10</u>	<u>1</u>	
<u>540</u>	<u>540</u>	
<u>1.0</u>	<u>1.0</u>	
<u>29.81</u>	<u>29.81</u>	
<u>0</u>	<u>0</u>	
<u>344</u>	<u>4.2</u>	

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

$$E = CF \left[\frac{2090}{20.9 - x_{\text{O}_2}} \right]$$

where

lb/MBtu =

ng/J =

C = pollutant concentration, g/dscm

F, volume factor = $\frac{\text{dscm}}{10^4 \text{ cal}}$ $\frac{\text{dscf}}{10^4 \text{ Btu}}$

from Fed. Reg. 9/11/74 p 32856

60-14
rev. 1/2/75

Date 2-21-77

K V B. INC.

Test No. 19-143

SOx DATA SHEET

TEST NO. 19-143 UNIT NO. _____ FUEL #6 LOAD 13.6 klb/hr _____ Location 19

Box No.	<u>2-1</u>	<u>2-1</u>			
Time	<u>1045</u>	<u>1104</u>			
Temp. in Gas Meter	<u>80</u>	<u>81</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.0</u>			
Barom. Press.	<u>29.81</u>	<u>29.81</u>			
Percent Oxygen	<u>3.1</u>	<u>3.1</u>			
N ₂ Purge Time					

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$

Excess O₂ 3.1 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>12.0</u>	<u>5.1</u>	
B = Ml of lead perchlorate used for bland =	<u>4.5</u>	<u>4.5</u>	
N = Normality of lead perchlorate titrant =	<u>.0107</u>	<u>.0107</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>540</u>	<u>540</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>29.81</u>	<u>29.81</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>348</u>	<u>2.7</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
E = CF $\left[\frac{2090}{20.9 - x_{\text{O}_2}} \right]$ lb/MBtu =			
where $\left[\frac{2090}{20.9 - x_{\text{O}_2}} \right]$ ng/J =			

C = pollutant concentration, g/dscm

F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
 from Fed. Reg. 9/11/74 p 32856

60-14
 rev. 1/2/75

Date 2-21-77

K V B, INC.

Test No. 19-143

SOx DATA SHEET

TEST NO. 19-143 UNIT NO. _____ FUEL #6 LOAD 13.6 klb/hr Location 19

Box No.	<u>2-2</u>	<u>2-2</u>		
Time	<u>1119</u>	<u>1141</u>		
Temp. in Gas Meter	<u>84</u>	<u>90</u>		
Press. in Gas Meter	<u>0</u>	<u>0</u>		
Meter Reading	<u>0</u>	<u>1.0</u>		
Barom. Press.	<u>29.81</u>	<u>29.81</u>		
Percent Oxygen	<u>3.1</u>	<u>3.1</u>		
N ₂ Purge Time	<u>1146</u>	<u>1215</u>		

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$

Excess O₂ 3.1 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>12.6</u>	<u>5.6</u>	
B = Ml of lead perchlorate used for bland =	<u>4.5</u>	<u>4.5</u>	
N = Normality of lead perchlorate titrant =	<u>.0107</u>	<u>.0107</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>547</u>	<u>547</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>29.81</u>	<u>29.81</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>381</u>	<u>5.2</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
 from Fed. Reg. 9/11/74 p 32856

60-14
 rev. 1/2/75

Date 2-23-77

K V B, INC.

Test No. 19-159SOx DATA SHEETTEST NO. 19-159 UNIT NO. _____ FUEL #6 LOAD 14.0 klb/hr _____ Location 19

Box No.	<u>X-1</u>	<u>X-1</u>			
Time	<u>0942</u>	<u>0959</u>			
Temp. in Gas Meter	<u>108</u>	<u>109</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.0</u>			
Barom. Press.	<u>30.08</u>	<u>30.08</u>			
Percent Oxygen	<u>1.75</u>	<u>1.75</u>			
N ₂ Purge Time	<u>1005</u>	<u>1033</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$

Excess O₂ 1.75 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>14.0</u>	<u>7.4</u>	
B = Ml of lead perchlorate used for bland =	<u>6.7</u>	<u>6.7</u>	
N = Normality of lead perchlorate titrant =	<u>.0107</u>	<u>.0107</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>568</u>	<u>568</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>30.08</u>	<u>30.08</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>354</u>	<u>3.3</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm

F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 3285660-14
rev. 1/2/75

Date 2-23-77

K V B, INC.

Test No. 19-159

SOx DATA SHEET

TEST NO. 19-159 UNIT NO. _____ FUEL #6 LOAD 14.0 klb/hr Location 19

Box No.	<u>X-2</u>	<u>X-2</u>		
Time	<u>1012</u>	<u>1030</u>		
Temp. in Gas Meter	<u>109</u>	<u>109</u>		
Press. in Gas Meter	<u>0</u>	<u>0</u>		
Meter Reading	<u>0</u>	<u>1.0</u>		
Barom. Press.	<u>30.08</u>	<u>30.08</u>		
Percent Oxygen	<u>1.7</u>	<u>1.7</u>		
N ₂ Purge Time	<u>1035</u>	<u>1105</u>		

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 1.7 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>14.4</u>	<u>7.2</u>	
B = Ml of lead perchlorate used for bland =	<u>6.7</u>	<u>6.7</u>	
N = Normality of lead perchlorate titrant =	<u>.0107</u>	<u>.0107</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>569</u>	<u>569</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>30.08</u>	<u>30.08</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>374</u>	<u>2.4</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - xO_2} \right]$$

where

C = pollutant concentration, g/dscm
F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 3285660-14
rev. 1/2/75

Date 2-23-74

K V B. INC.

Test No. 19-159

SOx DATA SHEET

TEST NO. 19-159 UNIT NO. _____ FUEL #6 LOAD 14.0 klb/hr Location 19

Box No.	<u>2-1</u>	<u>2-1</u>			
Time	<u>1044</u>	<u>1104</u>			
Temp. in Gas Meter	<u>110</u>	<u>110</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.0</u>			
Barom. Press.	<u>30.08</u>	<u>30.08</u>			
Percent Oxygen	<u>1.7</u>	<u>1.7</u>			
N ₂ Purge Time	<u>1107</u>	<u>1129</u>			

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 1.7 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>14.2</u>	<u>7.1</u>	
B = Ml of lead perchlorate used for bland =	<u>6.7</u>	<u>6.7</u>	
N = Normality of lead perchlorate titrant =	<u>.0107</u>	<u>.0107</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>570</u>	<u>570</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>30.08</u>	<u>30.08</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>331</u>	<u>1.7</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
E = CF $\left[\frac{2090}{20.9 - x_{\text{O}_2}} \right]$ lb/MBtu =			
where ng/J =			

C = pollutant concentration, g/dscm
F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 3285660-14
rev. 1/2/75

Date 3-1-77

K V B. INC.

Test No. 19-170

SOx DATA SHEET

TEST NO. 19-170 UNIT NO. _____ FUEL #6 LOAD 14.1 klb/hr Location 19

Box No.	<u>2</u>	<u>2</u>			
Time	<u>1103</u>	<u>1123</u>			
Temp. in Gas Meter	<u>105</u>	<u>109</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.00</u>			
Barom. Press.	<u>29.98</u>	<u>29.98</u>			
Percent Oxygen	<u>4.2</u>	<u>4.2</u>			
N ₂ Purge Time	<u>1126</u>	<u>1156</u>			

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$

Excess O₂ 4.2 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>16.2</u>	<u>8.6</u>	
B = Ml of lead perchlorate used for bland =	<u>6.9</u>	<u>6.9</u>	
N = Normality of lead perchlorate titrant =	<u>.0101</u>	<u>.0101</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>567</u>	<u>567</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>29.98</u>	<u>29.98</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>426</u>	<u>7.8</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
 from Fed. Reg. 9/11/74 p 32856

60-14
 rev. 1/2/75

Date 3-1-77

K V B, INC.

Test No. 19-170

SOX DATA SHEET

TEST NO. 19-170 UNIT NO. _____ FUEL #6 LOAD 141 klb/hr Location 19

Box No.	<u>1</u>	<u>1</u>			
Time	<u>1136</u>	<u>1155</u>			
Temp. in Gas Meter	<u>111</u>	<u>112</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.000</u>			
Barom. Press.	<u>29.98</u>	<u>29.98</u>			
Percent Oxygen	<u>4.2</u>	<u>4.2</u>			
N ₂ Purge Time	<u>1202</u>	<u>1232</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$

Excess O₂ 4.2 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>13.2</u>	<u>8.4</u>	
B = Ml of lead perchlorate used for bland =	<u>6.9</u>	<u>6.9</u>	
N = Normality of lead perchlorate titrant =	<u>.0101</u>	<u>.0101</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>571</u>	<u>571</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>29.98</u>	<u>29.98</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>290</u>	<u>6.9</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
E = CF $\left[\frac{2090}{20.9 - x_{O_2}} \right]$ lb/MBtu =			
where			ng/J =

C = pollutant concentration, g/dscm
 F, volume factor = $\frac{\text{dscm}}{10^4 \text{ cal}}$

$\frac{\text{dscf}}{10^4 \text{ Btu}}$
 from Fed. Reg. 9/11/74 p 32856

60-14
 rev. 1/2/75

Date 3-1-77

K V B, INC.

Test No. 19-170SOx DATA SHEETTEST NO. 19-170 UNIT NO. _____ FUEL #6 LOAD 14.1 klb/hr Location 19

Box No.	<u>2</u>	<u>2</u>			
Time	<u>1211</u>	<u>1231</u>			
Temp. in Gas Meter	<u>113</u>	<u>116</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.000*</u>			
Barom. Press.	<u>29.98</u>	<u>29.98</u>			
Percent Oxygen	<u>4.2</u>	<u>4.2</u>			
N ₂ Purge Time	<u>1325</u>	<u>1325</u>			

* METER STUCK ON THIS TEST

Calculation: SO₃ or SO₂, ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 4.2 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>12.7</u>	<u>7.0</u>	
B = Ml of lead perchlorate used for bland =	<u>6.9</u>	<u>6.9</u>	
N = Normality of lead perchlorate titrant =	<u>.0101</u>	<u>.0101</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>574</u>	<u>574</u>	
V = Volume of gas sample ft ³ =	<u>1.00</u>	<u>1.00</u>	
P = Barometric pressure =	<u>29.98</u>	<u>29.98</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>269</u>	<u>.4</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm
F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 32856DO NOT USE THIS
TEST IN AVE.60-14
rev. 1/2/75

Date 2-3-77

K V B, INC.

Test No. 19-179

SOx DATA SHEET

TEST NO. 19-179 UNIT NO. _____ FUEL #201 LOAD _____ klb/hr _____ Location 19

Box No.	<u>X-1</u>	<u>X-1</u>			
Time	<u>1032</u>	<u>1050</u>			
Temp. in Gas Meter	<u>90</u>	<u>98</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.000</u>			
Barom. Press.	<u>30.34</u>	<u>30.34</u>			
Percent Oxygen	<u>3.6</u>	<u>3.6</u>			
N ₂ Purge Time	<u>1052</u>	<u>1122</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 3.6 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>8.4</u>	<u>6.4</u>	
B = Ml of lead perchlorate used for bland =	<u>6.2</u>	<u>6.2</u>	
N = Normality of lead perchlorate titrant =	<u>.0101</u>	<u>.0101</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>554</u>	<u>554</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>30.34</u>	<u>30.34</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>97</u>	<u>8.8</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
lb/MBtu =			
ng/J =			

$$E = CF \left[\frac{2090}{20.9 - \%O_2} \right]$$

where

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
 from Fed. Reg. 9/11/74 p 32856

60-14
 rev. 1/2/75

Date 3-3-77

K V B, INC.

Test No. 19-179SOx DATA SHEETTEST NO. 19-179 UNIT NO. _____ FUEL #2 oil LOAD _____ klb/hr Location 19

Box No.	<u>X-2</u>	<u>X-2</u>			
Time	<u>1102</u>	<u>1120</u>			
Temp. in Gas Meter	<u>99</u>	<u>100</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.000</u>			
Barom. Press.	<u>30.34</u>	<u>30.34</u>			
Percent Oxygen	<u>3.6</u>	<u>3.6</u>			
N ₂ Purge Time	<u>1124</u>	<u>1153</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 3.6 %

A = Ml of lead perchlorate used for sample =

B = Ml of lead perchlorate used for bland =

N = Normality of lead perchlorate titrant =

F = Dilution factor =

T = Average temp. in gas meter =

V = Volume of gas sample ft³ =

P = Barometric pressure =

p = Pressure in gas meter =

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

E = CF $\left[\frac{2090}{20.9 - x_{O_2}} \right]$ lb/MBtu =where $\left[\frac{2090}{20.9 - x_{O_2}} \right]$ ng/J =

C = pollutant concentration, g/dscm

F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 32856

SO ₂	SO ₃	SO _x
<u>8.4</u>	<u>6.4</u>	
<u>6.2</u>	<u>6.2</u>	
<u>.0101</u>	<u>.0101</u>	
<u>10</u>	<u>1</u>	
<u>560</u>	<u>560</u>	
<u>1.0</u>	<u>1.0</u>	
<u>30.34</u>	<u>30.34</u>	
<u>0</u>	<u>0</u>	
<u>98</u>	<u>8.9</u>	

60-14
rev. 1/2/75

Date 3-3-77

K V B, INC.

Test No. 19-179

SOx DATA SHEET

TEST NO. 19-179 UNIT NO. _____ FUEL #2 OIL LOAD _____ klb/hr Location 19

Box No.	<u>X-1</u>	<u>X-1</u>			
Time	<u>1139</u>	<u>1150</u>			
Temp. in Gas Meter	<u>100</u>	<u>100</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.0</u>			
Barom. Press.	<u>30.34</u>	<u>30.34</u>			
Percent Oxygen	<u>3.5</u>	<u>3.5</u>			
N ₂ Purge Time	<u>1156</u>	<u>1315</u>			

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$

Excess O₂ 3.5 %

A = Ml of lead perchlorate used for sample =

B = Ml of lead perchlorate used for bland =

N = Normality of lead perchlorate titrant =

F = Dilution factor =

T = Average temp. in gas meter =

V = Volume of gas sample ft³ =

P = Barometric pressure =

p = Pressure in gas meter =

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

lb/MBtu =

ng/J =

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm

F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 32856

SO ₂	SO ₃	SO _x
<u>8.5</u>	<u>6.4</u>	
<u>6.2</u>	<u>6.2</u>	
<u>.0101</u>	<u>.0101</u>	
<u>10</u>	<u>1</u>	
<u>560</u>	<u>560</u>	
<u>1.0</u>	<u>1.0</u>	
<u>30.34</u>	<u>30.34</u>	
<u>0</u>	<u>0</u>	
<u>102</u>	<u>8.9</u>	

60-14
rev. 1/2/75

Date 3-7-77

K V B, INC.

Test No. 19-190

SOx DATA SHEET

TEST NO. 19-190 UNIT NO. _____ FUEL ^{NAT.}GAS LOAD _____ klb/hr Location 19

Box No.	<u>X-2</u>	<u>X-2</u>			
Time	<u>0952</u>	<u>1009</u>			
Temp. in Gas Meter	<u>99</u>	<u>99</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.0</u>			
Barom. Press.	<u>30.07</u>	<u>30.07</u>			
Percent Oxygen	<u>3.2</u>	<u>3.2</u>			
N ₂ Purge Time	<u>1015</u>	<u>1040</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 3.2 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>6.3</u>	<u>5.6</u>	
B = Ml of lead perchlorate used for bland =	<u>5.5</u>	<u>5.5</u>	
N = Normality of lead perchlorate titrant =	<u>.0101</u>	<u>.0101</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>559</u>	<u>559</u>	
V = Volume of gas sample ft ³ =	<u>1.0</u>	<u>1.0</u>	
P = Barometric pressure =	<u>30.07</u>	<u>30.07</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>37</u>	<u>.6</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
E = CF $\left[\frac{2090}{20.9 - x_{O_2}} \right]$ lb/MBtu =			
where ng/J =			

C = pollutant concentration, g/dscm

F, volume factor = _____ dscm/10⁴ calfrom Fed. Reg. 9/11/74 p 32856 _____ dscf/10⁴ Btu60-14
rev. 1/2/75

Date 3-7-77

K V B. INC.

Test No. 19-190

SOx DATA SHEET

TEST NO. 19-190 UNIT NO. _____ FUEL NAT. GAS LOAD _____ klb/hr Location 17

Box No.	<u>2-1</u>	<u>2-1</u>			
Time	<u>1021</u>	<u>1037</u>			
Temp. in Gas Meter	<u>99</u>	<u>100</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.00</u>			
Barom. Press.	<u>30.07</u>	<u>30.07</u>			
Percent Oxygen	<u>3.2</u>	<u>3.2</u>			
N ₂ Purge Time	<u>1042</u>	<u>1115</u>			

Calculation: SO₃ or SO₂, ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 3.2 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>6.9</u>	<u>6.0</u>	
B = Ml of lead perchlorate used for bland =	<u>5.5</u>	<u>5.5</u>	
N = Normality of lead perchlorate titrant =	<u>.0101</u>	<u>.0101</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>560</u>	<u>560</u>	
V = Volume of gas sample ft ³ =	<u>1.00</u>	<u>1.00</u>	
P = Barometric pressure =	<u>30.07</u>	<u>30.07</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>66</u>	<u>2</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
E = CF $\left[\frac{2090}{20.9 - x_{O_2}} \right]$ lb/MBtu =			
where			
			ng/J =

C = pollutant concentration, g/dscm
F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 3285660-14
rev. 1/2/75

Date 3-7-77

K V B, INC.

Test No. 19-190

SOX DATA SHEET

TEST NO. 19-190 UNIT NO. _____ FUEL ^{NAT.} GAS LOAD _____ klb/hr Location 19

Box No.	<u>X-2</u>	<u>X-2</u>			
Time	<u>1055</u>	<u>1112</u>			
Temp. in Gas Meter	<u>102</u>	<u>102</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.00</u>			
Barom. Press.	<u>30.07</u>	<u>30.07</u>			
Percent Oxygen	<u>3.2</u>	<u>3.2</u>			
N ₂ Purge Time	<u>1118</u>	<u>1140</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 3.2 %

A = Ml of lead perchlorate used for sample =
 B = Ml of lead perchlorate used for bland =
 N = Normality of lead perchlorate titrant =
 F = Dilution factor =
 T = Average temp. in gas meter =
 V = Volume of gas sample ft³ =
 P = Barometric pressure =
 p = Pressure in gas meter =

SO ₂	SO ₃	SO _x
<u>6.3</u>	<u>5.8</u>	
<u>5.5</u>	<u>5.5</u>	
<u>.0101</u>	<u>.0101</u>	
<u>10</u>	<u>1</u>	
<u>562</u>	<u>562</u>	
<u>1.00</u>	<u>1.00</u>	
<u>30.07</u>	<u>30.07</u>	
<u>0</u>	<u>0</u>	
<u>38</u>	<u>1.5</u>	

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

lb/MBtu =

ng/J =

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

C = pollutant concentration, g/dscm

F, volume factor = _____ dscm/10⁴ cal_____ dscf/10⁴ Btu

from Fed. Reg. 9/11/74 p 32856

60-14

rev. 1/2/75

Date 3-7-77

K V B. INC.

Test No. 19-192

SOx DATA SHEET

TEST NO. 19-192 UNIT NO. _____ FUEL #6 LOAD _____ klb/hr _____ Location _____

Box No.	<u>2-1</u>	<u>2-1</u>			
Time	<u>1522</u>	<u>1540</u>			
Temp. in Gas Meter	<u>101</u>	<u>103</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.000</u>			
Barom. Press.	<u>30.07</u>	<u>30.07</u>			
Percent Oxygen	<u>4.2</u>	<u>4.2</u>			
N ₂ Purge Time	<u>1546</u>	<u>1611</u>			

Calculation: $\text{SO}_3 \text{ or } \text{SO}_2, \text{ ppm} = \frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$

Excess O₂ 4.2 %

A = Ml of lead perchlorate used for sample =

B = Ml of lead perchlorate used for bland =

N = Normality of lead perchlorate titrant =

F = Dilution factor =

T = Average temp. in gas meter =

V = Volume of gas sample ft³ =

P = Barometric pressure =

p = Pressure in gas meter =

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

$$E = CF \left[\frac{2090}{20.9 - x_{O_2}} \right]$$

where

lb/MBtu =

ng/J =

C = pollutant concentration, g/dscm
F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
from Fed. Reg. 9/11/74 p 32856

SO ₂	SO ₃	SO _x
<u>12.6</u>	<u>5.8</u>	
<u>5.6</u>	<u>5.6</u>	
<u>.0101</u>	<u>.0101</u>	
<u>10</u>	<u>1</u>	
<u>562</u>	<u>562</u>	
<u>1.000</u>	<u>1.000</u>	
<u>30.07</u>	<u>30.07</u>	
<u>0</u>	<u>0</u>	
<u>317</u>	<u>9</u>	

60-14
rev. 1/2/75

Date 3-7-77

K V B, INC.

Test No. 19-192

SOx DATA SHEET

TEST NO. 19-192 UNIT NO. _____ FUEL #6 LOAD _____ klb/hr Location 19

Box No.	<u>X-2</u>	<u>X-2</u>			
Time	<u>1552</u>	<u>1609</u>			
Temp. in Gas Meter	<u>104</u>	<u>104</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.00</u>			
Barom. Press.	<u>30.07</u>	<u>30.07</u>			
Percent Oxygen	<u>4.1</u>	<u>4.1</u>			
N ₂ Purge Time	<u>1613</u>	<u>1641</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$

Excess O₂ 4.1 %

	SO ₂	SO ₃	SO _x
A = Ml of lead perchlorate used for sample =	<u>12.1</u>	<u>5.1</u>	
B = Ml of lead perchlorate used for bland =	<u>5.6</u>	<u>5.6</u>	
N = Normality of lead perchlorate titrant =	<u>.0101</u>	<u>.0101</u>	
F = Dilution factor =	<u>10</u>	<u>1</u>	
T = Average temp. in gas meter =	<u>564</u>	<u>564</u>	
V = Volume of gas sample ft ³ =	<u>1.00</u>	<u>1.00</u>	
P = Barometric pressure =	<u>30.07</u>	<u>30.07</u>	
p = Pressure in gas meter =	<u>0</u>	<u>0</u>	
Concentration, C, ppm =	<u>296</u>	<u>0</u>	
, gm/dscm =			
Emission, E, g/Mcal =			
E = CF $\left[\frac{2090}{20.9 - xO_2} \right]$ lb/MBtu =			
where ng/J =			

C = pollutant concentration, g/dscm
 F, volume factor = _____ dscm/10⁴ cal

_____ dscf/10⁴ Btu
 from Fed. Reg. 9/11/74 p 32856

60-14
 rev. 1/2/75

Date 3-7-77

K V B, INC.

Test No. 19-192

SOx DATA SHEET

TEST NO: _____ UNIT NO. _____ FUEL _____ LOAD _____ klb/hr _____ Location _____

Box No.	<u>X-3</u>	<u>X-3</u>			
Time	<u>1623</u>	<u>1639</u>			
Temp. in Gas Meter	<u>105</u>	<u>107</u>			
Press. in Gas Meter	<u>0</u>	<u>0</u>			
Meter Reading	<u>0</u>	<u>1.000</u>			
Barom. Press.	<u>30.07</u>	<u>30.07</u>			
Percent Oxygen	<u>4.1</u>	<u>4.1</u>			
N ₂ Purge Time	<u>1643</u>	<u>1710</u>			

Calculation: SO_3 or SO_2 , ppm = $\frac{(A - B) \times N \times F \times (460 + T) \times 24}{V (P + p)}$ Excess O₂ 4.1 %

A = Ml of lead perchlorate used for sample =

B = Ml of lead perchlorate used for bland =

N = Normality of lead perchlorate titrant =

F = Dilution factor =

T = Average temp. in gas meter =

V = Volume of gas sample ft³ =

P = Barometric pressure =

p = Pressure in gas meter =

Concentration, C, ppm =

, gm/dscm =

Emission, E, g/Mcal =

E = CF $\left[\frac{2090}{20.9 - x_{O_2}} \right]$ lb/MBtu =

where $\left[\frac{2090}{20.9 - x_{O_2}} \right]$ ng/J =

C = pollutant concentration, g/dscm

F, volume factor = $\frac{\text{dscm}}{10^4 \text{ cal}}$

$\frac{\text{dscf}}{10^4 \text{ Btu}}$

from Fed. Reg. 9/11/74 p 32856

SO ₂	SO ₃	SO _x
<u>11.8</u>	<u>8.1</u>	
<u>5.6</u>	<u>5.6</u>	
<u>.0101</u>	<u>.0101</u>	
<u>10</u>	<u>1</u>	
<u>566</u>	<u>566</u>	
<u>1.00</u>	<u>1.00</u>	
<u>30.07</u>	<u>30.07</u>	
<u>0</u>	<u>0</u>	
<u>283</u>	<u>11</u>	

60-14
rev. 1/2/75

KVB

SASS SAMPLING CONDITIONS

Test Site Location 19

Sample Port Location Stack Exit (Test 19-1 SASS)

Stack Conditions: Stack Velocity _____ ft/min $\div 60 = V_s =$ 24.9 ft/sec

Stack Temp. 513 °F + 460 = $T_s =$ 973 °R

Stack Moisture; $B_{wo} =$ 0.10 est.

Particulate Loading (Method 5), $C =$ N.A. grams/DSm³

Probe Nozzle Size for 4.0 ACFM (wet) through cyclones at 400 °F:

$$\text{Isokinetic Size} = 0.1192 \times \sqrt{T_s/V_s} = \underline{0.745} \text{ inches}$$

$$\text{Closest Actual Nozzle Size, } D_n = \underline{0.75} \text{ inches}$$

$$\% \text{ Isokinetic @ 4 WACFM, Actual Nozzle} = 1.421 \times T_s / (V_s \times D_n^2) = \underline{98.71} \%$$

If % Iso not in range of 90 to 110%, Adjust Cyclone Flow by:

$$Q_{cyc} = 2.814 \times (\% \text{ Iso}) \times V_s \times D_n^2 / T_s = \underline{4.0} \text{ wet ACFM (4.05 for 100\%)}$$

If % Iso @ 4 WACFM is greater than 110, use (% Iso) = 110

If % Iso @ 4 WACFM is less than 90, use (% Iso) = 90

Orifice Pressure Differential, H

$$\text{Meter Temp., } T_m = \underline{151} \text{ °F} + 460 = \underline{612} \text{ °R (use 560 °R for estimate)}$$

$$\text{Meter Flow Rate, } Q_m = Q_{cyc} \times T_m \times (1. - B_{wo}) / 860 = \underline{2.56} \text{ DCFM}$$

$$\text{Orifice No. (1, 2, 3)} = \underline{2}, J = \underline{0.78}, D_o = \underline{0.281}, J \times D_o^2 = \underline{0.062}$$

$$\text{Orifice Press Diff., } H = 1.108 \times (Q_m / J D_o^2)^2 / T_m = \underline{2.82} \text{ in. H}_2\text{O}$$

Dry Gas Volume to be Collected (5 hour run)

$$V_m = Q_m \times 60 \times 5 = \underline{702} \text{ DCF (683.63)}$$

Estimated Condensate Collection

$$V_{lc} = V_m \times 530 \times B_{wo} / [0.0474 \times T_m \times (1. - B_{wo})] = \underline{1557} \text{ ml (1209)}$$

Estimated Particulate Collection

$$M_n = C \times V_m \times 530 / (T_m \times 35.3) = \underline{\quad} \text{ grams } 0.4289 \text{ by SASS}$$

KVB

SASS SAMPLING CONDITIONS

Test Site Location 19

Sample Port Location Stack Exit (Test 19-2 SASS)

Stack Conditions: Stack Velocity _____ ft/min $\div 60 = V_s = \underline{23.8}$ ft/sec

Stack Temp. 515 °F + 460 = $T_s = \underline{975}$ °R

$AP = 0.1$

$T_s = 515^\circ F$

Stack Moisture; $B_{wo} = \underline{0.090 \text{ est. (new oil)}}$

Particulate Loading (Method 5), $C = \underline{\hspace{1cm}}$ grams/DSm³

Probe Nozzle Size for 4.0 ACFM (wet) through cyclones at 400 °F:

Isokinetic Size = $0.1192 \times \sqrt{T_s/V_s} = \underline{0.76}$ inches

Closest Actual Nozzle Size, $D_n = \underline{0.75}$ inches

% Isokinetic @ 4 WACFM, Actual Nozzle = $1.421 \times T_s / (V_s \times D_n^2) = \underline{103.5}$ %

If % Iso not in range of 90 to 110%, Adjust Cyclone Flow by:

$Q_{cyc} = 2.814 \times (\% \text{ Iso}) \times V_s \times D_n^2 / T_s = \underline{4.0}$ wet ACFM

If % Iso @ 4 WACFM is greater than 110, use (% Iso) = 110

If % Iso @ 4 WACFM is less than 90, use (% Iso) = 90

Orifice Pressure Differential, H

Meter Temp., $T_m = \underline{128}$ °F + 460 = 588 °R (use 560 °R for estimate)

Meter Flow Rate, $Q_m = Q_{cyc} \times T_m \times (1. - B_{wo}) / 860 = \underline{2.37}$ DCFM

Orifice No. (1, 2, 3) = 2, $J = \underline{0.78}$, $D_o = \underline{0.281}$, $J \times D_o^2 = \underline{0.062}$

Orifice Press Diff., $H = 1.108 \times (Q_m / J D_o^2)^2 / T_m = \underline{2.89}$ in. H₂O

Dry Gas Volume to be Collected (5 hour run)

$V_m = Q_m \times 60 \times 5 = \underline{711}$ DCF (700)

Estimated Condensate Collection

$V_{lc} = V_m \times 530 \times B_{wo} / [0.0474 \times T_m \times (1. - B_{wo})] = \underline{1404}$ ml (1222)

Estimated Particulate Collection

$M_n = C \times V_m \times 530 / (T_m \times 35.3) = \underline{\hspace{1cm}}$ grams 2.7416g
247

KVB

SASS SAMPLING CONDITIONS

Test Site Location 19

Sample Port Location Stack Exit 19-3 SASS

Stack Conditions: Stack Velocity _____ ft/min $\div 60 = V_s =$ 24.19 ft/sec

$\Delta P = 0.1$
 $T_s = 550^\circ F$ Stack Temp. 550 $^\circ F + 460 = T_s =$ 1010 $^\circ R$

Stack Moisture; $B_{wo} =$ 0.09

Particulate Loading (Method 5), $C =$ _____ grams/DSm³

Probe Nozzle Size for 4.0 ACFM (wet) through cyclones at 400 $^\circ F$:

Isokinetic Size = $0.1192 \times \sqrt{T_s/V_s} =$ 0.77 inches

Closest Actual Nozzle Size, $D_n =$ 0.75 inches

% Isokinetic @ 4 WACFM, Actual Nozzle = $1.421 \times T_s / (V_s \times D_n^2) =$ 105.5 %

If % Iso not in range of 90 to 110%, Adjust Cyclone Flow by:

$Q_{cyc} = 2.814 \times (\% \text{ Iso}) \times V_s \times D_n^2 / T_s =$ 4.0 wet ACFM

If % Iso @ 4 WACFM is greater than 110, use (% Iso) = 110

If % Iso @ 4 WACFM is less than 90, use (% Iso) = 90

Orifice Pressure Differential, H

Meter Temp., $T_m =$ 100 $^\circ F + 460 =$ 560 $^\circ R$ (use 560 $^\circ R$ for estimate)

Meter Flow Rate, $Q_m = Q_{cyc} \times T_m \times (1. - B_{wo}) / 860 =$ 2.37 DCFM

Orifice No. (1, 2, 3) = 2, $J = 0.78$, $D_o = 0.281$, $J \times D_o^2 = 0.062$

Orifice Press Diff., $H = 1.108 \times (Q_m / J D_o^2)^2 / T_m =$ 2.89 in. H₂O use 2.9

Dry Gas Volume to be Collected (5 hour run)

$V_m = Q_m \times 60 \times 5 =$ 711 DCF

Estimated Condensate Collection

$V_{lc} = V_m \times 530 \times B_{wo} / [0.0474 \times T_m \times (1. - B_{wo})] =$ 1404 ml

Estimated Particulate Collection

$M_n = C \times V_m \times 530 / (T_m \times 35.3) =$ _____ grams

KVB

SASS SAMPLING CONDITIONS

Test Site Location 19 TEST 19-4 SASS

Sample Port Location STACK EXIT

Stack Conditions: Stack Velocity _____ ft/min $\div 60 = V_s = \frac{(22.75)}{22.11}$ ft/sec

$\Delta p = 0.085$ Stack Temp. 533 °F + 460 = $T_s = 993$ °R

Δp CHANGED TO 0.09 DURING TEST) Stack Moisture; $B_{wo} = .09$

Particulate Loading (Method 5), $C = \underline{\hspace{1cm}}$ grams/DSm³

Probe Nozzle Size for 4.0 ACFM (wet) through cyclones at 400 °F:

Isokinetic Size = $0.1192 \times \sqrt{T_s/V_s} = .798$ inches (.7875)

Closest Actual Nozzle Size, $D_n = .75$ inches

% Isokinetic @ 4 WACFM, Actual Nozzle = $1.421 \times T_s / (V_s \times D_n^2) = \frac{113.5}{110.2}$ %

If % Iso not in range of 90 to 110%, Adjust Cyclone Flow by:

$Q_{cyc} = 2.814 \times (\% \text{ Iso}) \times V_s \times D_n^2 / T_s = 3.88$ wet ACFM (3.99)

If % Iso @ 4 WACFM is greater than 110, use (% Iso) = 110

If % Iso @ 4 WACFM is less than 90, use (% Iso) = 90

Orifice Pressure Differential, H

Meter Temp., $T_m = 100$ °F + 460 = 560 °R (use 560 °R for estimate)

Meter Flow Rate, $Q_m = Q_{cyc} \times T_m \times (1. - B_{wo}) / 860 = 2.299$ DCFM (2.364)

Orifice No. (1, 2, 3) = 2, $J = 0.78$, $D_o = 0.281$, $J \times D_o^2 = 0.062$

Orifice Press Diff., $H = 1.108 \times (Q_m / J D_o^2)^2 / T_m = \frac{2.72}{(2.87)}$ in. H₂O

Dry Gas Volume to be Collected (5 hour run)

$V_m = Q_m \times 60 \times 5 = 689.7$ DCF

Estimated Condensate Collection

$V_{lc} = V_m \times 530 \times B_{wo} / [0.0474 \times T_m \times (1. - B_{wo})] = 1361$ ml

Estimated Particulate Collection

$M_n = C \times V_m \times 530 / (T_m \times 35.3) = \underline{\hspace{1cm}}$ grams

KVB, INC. TRACE SPECIES AND ORGANICS SAMPLING DATA

Project: EPA Personnel: R. PIONESSA Barometric Press: 30.17
M. HAGERTY
 Date: 3-10-77
 Location: 19
 Unit: _____ Probe Nozzle Diameter (inches): 0.750 (Dn)
 Test: 19-1 SASS Absolute Static Press. in Stack (in. ^{H₂O} ~~Hg~~): -0.21 (Ps)
 Fuel: #6 OIL Pitot Tube Coefficient: 0.83 (Cp)

T I M E		Traverse Point Depth	Pitot ΔP (in H ₂ O)	Orifice ΔP (in H ₂ O)	Cum. Meter Volume (ft ³)	Pump Suction (in. Hg)	T E M P E R A T U R E (° F)						O ₂ Conc. dry	
Real	Elapsed						Stack	Probe	XAD-2	Impinger Out	Oven	Meter In/Out		
1115	0	Center 15" in	0.11	2.82	814.107	5.9	513	400?	61	98	400	119	111	
1145	30				882.000	6.2	511	395	64	86	394	141	124	
1215	60				949.000	6.5	513	400	62	82	399	148	132	
1245	90				016.000	7.0	512	400	62	80	401	155	139	
1315	120		✓		084.000			OUT OF SERVICE						
					CHANGED		DES	S	I	C	A	N	T	
1320	120		* 0.18/0.11		084.000	7.0	513 500S	VERY HOT TO TOUCH	62	112	406	153	143	
1350	150		0.11		156.000	7.0	LOOSE CONNECTION	BROKEN T/C WIRE	62	100	400	156	145	
1420	180				224.000	7.5	508	POSSIBLE SHORT IN	64	88	401	158	147	
1450	210				290.000	7.7	509	HEATER LINES	58	91	403	157	145	
1520	240				364.000	8.0	510		63	79	405	157	146	
1550	270				430.000	8.0	510		64	77	406	157	145	
1620	300	✓	✓	✓	497.700	8.5	510	✓	70	76	405	157	146	
*	NOW USING JOY PITOT PROBE & INCLINE MANOMETER/POSSIBLE HOLE IN (ACU THERM) STATIC PROBE DUE TO SHORT													

KVB, INC. TRACE SPECIES AND ORGANICS SAMPLING DATA

Project: EPA PHASE III SASS Personnel: R. PIDNESSA
M. HAGERTY Barometric Press: 29.99 - 1000 HRS
 Date: 3-17-77 29.92 - 1500 HRS
 Location: 19
 Unit: _____ Probe Nozzle Diameter (inches): 3/4 (Dn)
 Test: 19-2-SASS Absolute Static Press. in Stack (in. Hg): -0.20 (Ps)
 Fuel: #6 OIL Pitot Tube Coefficient: 0.83 (Cp)

T I M E		Traverse Point Depth	Pitot ΔP (in H ₂ O)	Orifice ΔP (in H ₂ O)	Cum. Meter Volume (ft ³)	Pump Suction (in. Hg)	T E M P E R A T U R E (° F)						O ₂ Conc. % dry
Real	Elapsed						Stack	Probe	XAD-2	Impinger Out	Oven	Meter In/Out	
0955	0	15" IN	0.10	2.9	500.532	7.2	515	387	61	67	401	97 92	
1025	30				568.000	8.2	511	398	64	77	400	119 102	
1055	60				639.000	9.0	512	399	61	80	402	126 109	
1125	90				709.000	9.9	512	408	64	77	402	130 114	
1155	120				779.000	10.9	514	409	65	78	402	132 118	
1225	150				849.109	11.7	513	406	66	74	403	131 119	
1227	150				849.109	11.7	513	406	66	74	403	131 119	
1257	180				921.000	13.0	516	409	65	87	403	132 119	
1327	210				988.000	14.0	515	410	64	81	403	135 120	
1357	240				1058.000	15.0	512	404	62	81	403	136 122	
1427	270				129.000	16.0	521	407	62	83	405	139 125	
1457	300				199.167	11.5	510	402	64	79	404	145 130	

251

KVB, INC. TRACE SPECIES AND ORGANICS SAMPLING DATA

Project: EPA PHASE III SASS Personnel: Proctor Barometric Press: 30.19 ^{1800 1150}
 Date: 3-21-77 46.55-0
 Location: 19
 Unit: _____ Probe Nozzle Diameter (inches): .75 (Dn)
 Test: LO NOx 19-3 SASS Absolute Static Press. in Stack (in. Hg): -22 (Ps)
 Fuel: #6 OIL Pitot Tube Coefficient: .83 ^{H₂O} (Cp)

T I M E		Traverse Point Depth	Pitot ΔP (in H ₂ O)	Orifice ΔP (in H ₂ O)	Cum. Meter Volume (ft ³)	Pump Suction (in. Hg)	T E M P E R A T U R E (° F)						O ₂ Conc. % dry
Real	Elapsed						Stack	Probe	XAD-2	Impinger Out	Oven	Meter In/Out	
1030	0	15" in	.10	2.9	203.052	7.4	553	402	60	86	405	112 109	
1100	30	"	.10	2.9	222.500	8.0	553	403	61	81	403	134 118	
1130	60	"	.10	2.9	342.200	8.5	559	409	54	78	403	141 126	
1200	90	"	.10	2.9	412.000	9.8	562	411	61	88	405	146 131	
1230	120	"	.10	2.9	486.000	11.5	561	409	62	86	405	145 133	
1300	150	"	.10	2.9	552.950	12.1	559	407	62	86	404	140 134	
				CHANGED DIFFUSICANT									
1302	150	15" in	.10	2.9	552.950	12.5	559	404	60	107	406	146 135	
1332	180	"	.10	2.9	624.400	13.1	554	406	57	108	407	150 138	
1402	210	"	.10	2.9	691.400	13.9	564	406	70	102	405	133 129	
1432	240	"	.10	2.9	765.300	15.0	557	407	66	98	404	133 122	
1502	270	"	.10	2.9	835.100	16.0	544	408	61	95	407	146 130	
1532	300	"	.10	2.9	905.500	16.6	545	409	66	95	404	149 135	

KVB, INC. TRACE SPECIES AND ORGANICS SAMPLING DATA

Project: EPA PHASE III Personnel: PIONESSA Barometric Press: 29.83 1200 HRS
 Date: 3-23-77
 Location: 19
 Unit: _____ Probe Nozzle Diameter (inches): .75 (Dn)
 Test: 19-4 SASS Absolute Static Press. in Stack (in. ^{Hg}): -.21 (Ps)
 Fuel: #6 OIL Pitot Tube Coefficient: .83 (Cp)

T I M E		Traverse Point Depth	Pitot ΔP (in H ₂ O)	Orifice ΔP (in H ₂ O)	Cum. Meter Volume (ft ³)	Pump Suction (in. Hg)	T E M P E R A T U R E (° F)						O ₂ Conc. % dry	
Real	Elapsed						Stack	Probe	XAD-2	Impinger Out	Oven	Meter In/Out		
0930	0	15" in	.10	2.9	907.074	7.5	524	402	54	67	395	100/94		
1000	30	"	.085	2.72	978.000	8.0	532	400	59	78	398	124/106		
1030	60	"	.09	2.87	046.200	8.2	532	397	59	74	399	129/113		
1100	90	"	.09	2.87	114.500	9.2	533	400	61	75	400	131/117		
1130	120	"	.109	2.87	186.000	10.0	533	402	60	74	399	132/119		
1200	150	"	.09	2.87	255.930	10.9	540	401	59	89	401	136/122		
				CHANGED		DESSICANT								
1202	150	15" in	.09	2.87	255.930	11.0	538	407	58	96	403	131/121		
1232	180	"	.09	2.87	327.000	11.4	537	402	59	91	402	136/122		
1302	210	"	.09	2.87	397.600	12.0	538	402	59	86	401	137/123		
1332	240	"	.09	2.87	468.200	12.5	532	395	60	76	400	139/123		
1402	270	"	.09	2.87	539.700	13.0	533	398	60	84	401	140/126		
1432	300	"	.09	2.87	610.571	13.6	533	397	60	90	402	139/126		

253

PARTICULATE EMISSION CALCULATIONS

Test No. 19-1 SASS Date 3-10-77 Location 19 Engr. HB
 Unit No. _____ Fuel #6 Oil Sampling Train and Method SASS Train
 Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 30.17 in. Hg
 Tot. Liquid Collected, V_{lc} 1208 ⁽¹⁾ ml Total Particulate, M_n 428.9 ⁽²⁾ mg
 Velocity Head, ΔP 0.11 iwg Stack Temp., T_s 971 °R Stack Area, A_s 4.90 ft²
 Sample Volume, V_m 683.6 ft³ Stack Press., P_{sg} -0.21 iwg Excess O₂, XO_2 2.9 %
 Orifice Press. Diff., H 2.82 iwg Stack Gas Sp. Gravity, G_s 1 n.d.
 Sample Time, θ 300 min Nozzle Dia., D_n 0.75 in. Meter Temp., T_m 604 °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 693.6 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 57.2 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.076 N.D.
4. Concentration
 - a. $C = 0.0154 M_n / V_{m_{std}}$ 0.0095 grains/DSCF
 - b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 1.36×10^{-6} lb/DSCF
 - c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 2.18×10^{-2} grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 410.1 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P T_s} \sqrt{\frac{407}{P_s} \times \frac{1.00}{G_s}}$ 1487 ft/min
7. Stack Gas Flow
 - a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 4107 WSCF/min
 - b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3702 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ _____ lb/hr
9. XO₂ factor $XO_2 f = 2090 / (20.9 - XO_2 \%)$ 116.1 N.D.
10. Emission
 - a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 1.46×10^{-2} lb/MMBtu
 - b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 6.26 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 99.7 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.
 (1) does not include moisture from dessicant
 (2) From TS&O data sheet 6002-15

Data Sheet 6002-4

PARTICULATE EMISSION CALCULATIONS

Test No. M-2 SASS Date 3-17-77 Location 19 Engr. HB
 Unit No. _____ Fuel #6 O.L Sampling Train and Method SASS Train
 Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 29.99 in. Hg
 Tot. Liquid Collected, V_{lc} 1327 ml Total Particulate, M_n 2741.6 mg
 Velocity Head, ΔP 0.10 iwg Stack Temp., T_s 974 °R Stack Area, A_s 4.90 ft²
 Sample Volume, V_m 698.6 ft³ Stack Press., P_{sg} -0.20 iwg Excess O₂, $XO_2\%$ 3.0 %
 Orifice Press. Diff., H 2.90 iwg Stack Gas Sp. Gravity, G_s 1 n.d.
 Sample Time, θ 300 min Nozzle Dia., D_n 0.75 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 704.7 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 62.9 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2}/(\text{Eq. 1} + \text{Eq. 2})$ 0.082 N.D.
4. Concentration a. $C = 0.0154 M_n/V_{m_{std}}$ 0.0599 grains/DSCF
 b. $C = 2.205 \times 10^{-6} M_n/V_{m_{std}}$ 8.578 \times 10^{-6} lb/DSCF
 c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.137 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 407.66 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P T_s} \sqrt{\frac{407}{P_s} \times \frac{1.00}{G_s}}$ 1424 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3803 WSCF/min
 Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3492 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 1.797 lb/hr
9. XO₂ factor $XO_{2f} = 2090/(20.9 - XO_2\%)$ 116.8 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.092 lb/MMBtu
 b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 39.6 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 107.4 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

(1) does not include H₂O in dessicant

PARTICULATE EMISSION CALCULATIONS

Test No. 19-35ASS Date 3-21-77 Location 19 Engr. HB
 Unit No. _____ Fuel #6 Oil Sampling Train and Method SASS Train
 Pitot Factor, Fs 0.83 Barometric Pressure, P_{bar} 30.19 in. Hg
 Tot. Liquid Collected, V_{lc} 1384 ml Total Particulate, M_n 4698.1 mg
 Velocity Head, ΔP 0.10 iwg Stack Temp., Ts 1016 °R Stack Area, As 4.90 ft²
 Sample Volume, Vm 702.4 ft³ Stack Press., Psg -0.22 iwg Excess O₂, XO₂ % 1.8 %
 Orifice Press. Diff., H 2.9 iwg Stack Gas Sp. Gravity, Gs 1 n.d.
 Sample Time, θ 300 min Nozzle Dia., Dn 0.75 in. Meter Temp., T_m 134 °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 713.3 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 65.6 SCF
3. Moisture Content Bwo = Eq. 2/(Eq. 1 + Eq. 2) 0.084 N.D.
4. Concentration a. C = 0.0154 Mn/Vm_{std} 0.1014 grains/DSCF
 b. C = 2.205 x 10⁻⁶ Mn/Vm_{std} 1.452 x 10⁻⁵ lb/DSCF
 c. C = Eq. 4b x 16.018 x 10³ 0.233 grams/DSCM
5. Abs. Stack Press. Ps = P_{bar} x 13.6 + Psg 410.4 in. w abs.
6. Stack Gas Speed Vs = 174 Fs $\sqrt{\Delta P T_s} \sqrt{\frac{407}{P_s} \times \frac{1.00}{G_s}}$ 1450 ft/min
7. Stack Gas Flow a. Qsw = Eq. 6 x As x $\frac{530}{T_s} \times \frac{P_s}{407}$ 3736 WSCF/min
 Rate @ 70°F b. Qsd = Eq. 7a x (1. - Eq. 3) 3422 DSCF/min
8. Material Flow Ms = Eq. 7b x Eq. 4b x 60 2.982 lb/hr
9. XO₂ factor XO₂f = 2090/(20.9 - XO₂%) 109.4 N.D.
10. Emission a. E = Eq. 4b x Fe x Eq. 9 0.146 lb/MMBtu
 b. E = Eq. 4c x Fm x Eq. 9 x 1000 63.1 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 110.9 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply Vm_{std} by 530/T_m (°R) if meter not temp. compensated.

Data Sheet 6002-4

PARTICULATE EMISSION CALCULATIONS

Test No. 19-4 SASS Date 3-23-77 Location 19 Engr. #13
 Unit No. _____ Fuel #6 oil Sampling Train and Method SASS Train
 Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 29.83 in. Hg
 Tot. Liquid Collected, V_{lc} 1295 ml Total Particulate, M_n 3844.6 mg
 Velocity Head, ΔP 0.09 iwg Stack Temp., T_s 994 °R Stack Area, A_s 4.9 ft²
 Sample Volume, V_m 703.46 ft³ Stack Press., P_{sg} -0.21 iwg Excess O₂, $XO_2\%$ 1.5 %
 Orifice Press. Diff., H 2.87 iwg Stack Gas Sp. Gravity, G_s 1 n.d.
 Sample Time, θ 300 min Nozzle Dia., D_n 0.75 in. Meter Temp., T_m 584 °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 705.8 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 61.4 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.080 N.D.
4. Concentration a. $C = 0.0154 M_n / V_{m_{std}}$ 0.0839 grains/DSCF
 b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 1.201×10^{-5} lb/DSCF
 c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.1924 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 405.48 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 1368 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 3562 WSCF/min
 Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 3277 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 2.36 lb/hr
9. XO₂ factor $XO_{2f} = 2090 / (20.9 - XO_2\%)$ 107.7 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.119 lb/MMBtu
 b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 51.28 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 114.7 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

KVB

TRACE SPECIES AND ORGANICS TEST SAMPLE RECOVERY LOG

Test No. 19-1 Date 3/10/77 Location 19

Sample Port Position MID-POINT / STACK / ~15" IN

Container Number	Sample Description	Container Type	Net wt/vol.	Comment
674	H ₂ O BLANK	NAL	1000 ml	
675	IPA BLANK	NAL	1000 ml	
684	50-50 BLANK	NAL	950 ml	
685	SIL.NIT. / AM.PER. SU.	NAL	1000 ml	BLANK
571	XAD-2 BLANK	NAL	402 ml	
715	PRIME/IDM	NAL	0.0605g	SOLIDS
592	"	GL	289 ml	H ₂ O wash
591	"	GL	385 ml	50-50 wash
725	3M	NAL	0.0457g	SOLIDS
589	"	GL	163 ml	H ₂ O
730	1M	NAL	0.0037g	SOLIDS
485	"	GL	175 ml	50-50
491	"	GL	190 ml	H ₂ O
463	FILTER	P/D	0.3190 g	SOLIDS
478	"	GL	72 ml	50-50
484	"	GL	130 ml	H ₂ O
522	1 ST IMPINGER	NAL	891 ml	SOLUTION
590	"	GL	289 ml	IPA
667	2 ND IMPINGER	NAL	792 ml	SOLUTION
588	"	GL	258 ml	IPA
586	"	GL	240 ml	H ₂ O
668	3 RD IMPINGER	NAL	725 ml	SOLUTION
585	"	GL	300 ml	IPA
584	"	GL	238 ml	H ₂ O
536	XAD-2	GL	150 g	RESIN
676	"	NAL	895 ml	CONDENSATE
486	"	GL	200 ml	"
583	"	GL	260 ml	RINSE 50-50

497 " GL 150 ml
19-1LF No. 6 OIL Data Sheet KVB 6002-15 H₂O
GL 500 ml OIL SAMPLE

Keeler Boiler

TEST 19 FUELS TABLE								
POLLUTANT	SAMPLE NUMBER							
	19-1 LF ⁺	19-1 LF ⁺ dup	19-2 LF ⁺	19-2 LF ⁺ dup	19-3 LF ⁺	19-3 LF ⁺ dup	19-4 LF ⁺	19-4 LF ⁺ dup
Antimony	<25	<25	<25	<25	<25	<25	<25	<25
Arsenic	<2	<2	<2	<2	<2	<2	<2	<2
Barium	<5	<5	<5	<5	<5	<5	15	10
Beryllium	<0.3	<0.3	<0.3	<0.3	<0.3	<0.3	<0.3	<0.3
Cadmium	<0.3	<0.3	<0.3	<0.3	<0.3	<0.3	<0.3	<0.3
Calcium	31	30	31	43	<10	<10	<10	<10
Chromium	<5	<5	<5	<5	<5	<5	<5	<5
Cobalt	<10	<10	<10	<10	<10	<10	<10	<10
Copper	<3	<3	<3	<3	<3	<3	<3	<3
Iron	35	25	12	15	7	13	30	14
Lead	<3	<3	<3	<3	<3	<3	6	<3
Manganese	0.5	0.1	1.4	0.8	<0.5	<0.5	<0.5	<0.5
Mercury	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
Nickel	3.5	3.5	14	15	<10	<10	<10	<10
Selenium	<1	<1	<1	<1	<1	<1	<1	<1
Tellurium	<25	<25	<25	<25	<25	<25	<25	<25
Tin	<25	<25	<25	<25	<25	<25	<25	<25
Titanium	<250	<250	<250	<250	<250	<250	<250	<250
Vanadium	25	25	40	40	50	55	55	45
Zinc	6	4	3	4	5	<5	<5	5
Chloride	<18.3	—	<11.6	—	<34.4	—	<46.3	—
Fluoride	38.7	—	45.8	—	34.6	—	41.0	—
Nitrates	—	—	—	—	—	—	—	—
Sulfates	—	—	—	—	—	—	—	—

⁺ mg/g

KEELER BOILER

TEST 19-1		TABLE STACK - #6 OIL BASELINE							
POLLUTANT		SAMPLE NUMBER							
	571*	685*	674*	684*	675*				
Antimony	<27	<0.5	<0.5	<0.5	<0.5				
Arsenic	<1	<0.005	<0.005	<0.005	<0.005				
Barium	<11	<0.1	<0.1	<0.1	<0.1				
Beryllium	<0.5	<0.005	<0.005	<0.005	<0.005				
Cadmium	<0.5	0.01	<0.005	<0.005	<0.005				
Calcium	9.3	0.49	0.12	0.25	0.16				
Chromium	2.7	0.05	0.05	0.05	0.05				
Cobalt	5.9	<0.2	<0.2	<0.2	<0.2				
Copper	1.6	0.03	<0.02	<0.02	<0.02				
Iron	20	0.23	0.12	0.17	0.15				
Lead	<2.7	0.06	<0.05	<0.05	<0.05				
Manganese	0.5	0.02	<0.01	<0.01	0.02				
Mercury	<0.02	<0.005	<0.005	<0.005	<0.005				
Nickel	<2.7	<0.05	<0.05	<0.05	<0.05				
Selenium	<1	<0.01	<0.01	<0.01	<0.01				
Tellurium	<27	<0.3	<0.3	<0.3	<0.3				
Tin	<54	<1	<1	<1	<1				
Titanium	<16	<1	<1	<1	<1				
Vanadium	<11	<0.1	<0.1	<0.1	<0.1				
Zinc	1.6	0.20	0.10	0.11	0.08				
Chloride	25.5	83.4	<0.5	<0.5	0.54				
Fluoride	28.8	0.77	0.12	<0.1	<0.1				
Nitrates	<0.2	2.0	<0.01	0.02	0.06				
Sulfates	<50	31200	4.0	4.0	2.0				

* pg/g
 pg/ml

KVB

TRACE SPECIES AND ORGANICS TEST SAMPLE RECOVERY LOG

Test No. 19-2 Date 3-17-77 Location 19

Sample Port Position MID-POINT STACK / ~15" IN

Container Number	Sample Description	Container Type	Net wt/vol.	Comment
566	NO ₂ / PROBE / 10M	NAL	1.6620	SOLIDS
493	"	GL	115	50/50
489	"	GL	210	"
629	"	GL	140	H ₂ O
483	"	GL	225	"
716	3 M	NAL	0.4443	SOLIDS
619	"	GL	190	50/50
620	"	GL	200	H ₂ O
720	1M	NAL	0.2196	SOLIDS
621	"	GL	140	50/50
622	"	GL	165	H ₂ O
538	FILTER	PETRI	0.4157	SOLIDS
625	"	GL	90	50/50
626	"	GL	130	H ₂ O
521	1 ST IMP.	NAL	985	SOLUTION
499	"	GL	232	IPA
481	"	GL	205	H ₂ O
666	2 ND IMP.	NAL	782	SOLUTION
477	"	GL	125	IPA
487	"	GL	200	H ₂ O
670	3 RD IMP.	NAL	755	SOLUTION
617	"	GL	165	IPA
623	"	GL	198	H ₂ O
533	XAD-2	WMGL		RESIN
520	"	NAL	950	CONDENSATE
490	"	GL	105	"
495	"	GL	230	50/50
618	"	GL	230	H ₂ O

KEELER BOILER

TEST 19-2		TABLE		STACK - #6 OIL BASELINE				
POLLUTANT		SAMPLE NUMBER						
	566 ⁺	716 ⁺	720 ⁺	538 ⁺	A [*]	B [*]	B [*] dupli- cate	533 ⁺
Antimony	<38	<210	<250	<500	<0.5	<0.5	<0.5	<25
Arsenic	<1.5	33	<10	200	0.018	<0.005	0.01	<1
Barium	38	460	6000	800	<0.1	<0.1	<0.1	<10
Beryllium	<0.8	<4.2	<5	<10	<0.005	<0.005	<0.005	<0.5
Cadmium	0.8	<4.2	<5	<10	0.005	0.34	0.33	<1
Calcium	1900	1900	3500	4800	0.67	0.34	0.30	40
Chromium	72	140	310	240	0.14	14	14	8.5
Cobalt	120	310	940	1600	<0.2	0.3	0.3	1
Copper	46	50	100	460	0.06	0.14	0.13	<1
Iron	5400	7200	32000	21000	2.7	69	68	28
Lead	150	<20	<25	1000	0.14	<0.05	<0.05	<2
Manganese	51	75	210	250	0.17	0.70	0.69	2
Mercury	<0.03	<0.17	<0.2	<0.4	<0.005	<0.005	<0.005	<0.02
Nickel	1900	2200	9000	30000	0.77	8.9	8.7	<2
Selenium	<1.5	<8	<10	<20	<0.01	<0.01	<0.01	<1
Tellurium	<38	<210	<250	<500	<0.3	<0.3	<0.3	<25
Tin	<76	<420	<500	<1000	<1	<1	<1	<50
Titanium	460	<1200	2500	<3000	<1	<1	<1	<150
Vanadium	6300	10000	43000	89000	2.5	0.2	0.2	<10
Zinc	400	400	1300	4900	1.8	0.13	0.14	10
Chloride	279	—	—	11600	2.12	<0.5	<0.5	<10
Fluoride	205	134	909	<2	<0.1	0.16	0.23	15
Nitrates	113	—	—	39.5	0.28	0.88	3.80	3.61
Sulfates	14200	—	—	457000	11.0	262	250	66.6

489,493, 495,
483,629, 618
619,620,
621,622,
625,626

KEELER BOILER

TEST 19-2		TABLE		STACK - #6 OIL BASELINE				
POLLUTANT		SAMPLE NUMBER						
	533 ⁺ duplicate	C ₁ ⁺	C*	C* duplicate				
Antimony	<25	no metal analyses on sub-one samples	<0.5	<0.5				
Arsenic	<1		<0.005	<0.005				
Barium	50		<0.1	<0.1				
Beryllium	<0.5		<0.005	<0.005				
Cadmium	<0.5		0.02	0.015				
Calcium	10		0.14	0.10				
Chromium	7		1.4	1.3				
Cobalt	2		<0.2	<0.2				
Copper	1		0.04	0.05				
Iron	27		4.3	4.0				
Lead	<2		<0.05	<0.05				
Manganese	2		0.08	0.07				
Mercury	<0.02		<0.005	<0.005				
Nickel	<2		0.7	0.7				
Selenium	<1		<0.01	<0.01				
Tellurium	<25		<0.3	<0.3				
Tin	<50		<1	<1				
Titanium	<150		<1	<1				
Vanadium	<10		<0.1	<0.1				
Zinc	1.5		0.09	0.12				
Chloride	<11	—	61.2	59.0				
Fluoride	18	—	0.70	0.65				
Nitrates	2.20	0.40	—	—				
Sulfates	69.9	19600	—	—				

520,490,
521,499,
481
520,490,
521,499,
481,666,
477,487,
670,617,
623

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 • AREA CODE 312 728-8484
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to



To: Mr. John C. Michalovic
Calspan Corporation
Post Office Box 235
Buffalo, NY 14221

Date: July 1, 1977

Analyst: S. Sweeney

P. O. No.: 27810

Sample No.: Test 19-2 D 566, 716, 720, 538 5/18/77

IAD No.: 97-A345-134-21

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	<0.7	Terbium	0.3	Ruthenium		Vanadium	MC
Thorium	1	Gadolinium	1	Molybdenum	MC	Titanium	330
Bismuth	0.3	Europium	0.3	Niobium	0.4	Scandium	0.2
Lead	380	Samarium	2	Zirconium	5	Calcium	MC
Thallium		Neodymium	19	Yttrium	1	Potassium	MC
Mercury	NR	Praseodymium	11	Strontium	110	Chlorine	32
Gold		Cerium	22	Rubidium	1	Sulfur	MC
Platinum		Lanthanum	190	Bromine	0.7	Phosphorus	MC
Iridium		Barium	MC	Selenium	10	Silicon	MC
Osmium		Cesium	0.1	Arsenic	18	Aluminum	MC
Rhenium		Iodine	0.4	Germanium	0.8	Magnesium	MC
Tungsten	0.8	Tellurium	0.3	Gallium	12	Sodium	MC
Tantalum		Antimony	26	Zinc	MC	Fluorine	=59
Hafnium	0.5	Tin	3	Copper	280	Oxygen	NR
Lutetium	0.1	Indium	STD	Nickel	MC	Nitrogen	NR
Ytterbium	0.7	Cadmium	0.6	Cobalt	MC	Carbon	NR
Thulium	0.1	Silver	7	Iron	MC	Boron	18
Erbium	0.5	Palladium		Manganese	140	Beryllium	0.4
Holmium	0.7	Rhodium		Chromium	96	Lithium	4
Dysprosium	1					Hydrogen	NR

NR — Not Reported

All elements not reported <0.1 ppm

Approved:

264

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 • AREA CODE 312 726-8494
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to

To: Mr. John C. Michalovic
Calspan Corporation
Post Office Box 235
Buffalo, NY 14221



Date: July 1, 1977

Analyst: S. Sweeney

P. O. No.: 27810

Sample No.: Test 19-2 E 533 5/18/77

IAD No.: 97-A345-134-21

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.2
Thorium		Gadolinium		Molybdenum	11	Titanium	2
Bismuth		Europium		Niobium		Scandium	<0.1
Lead	<2	Samarium		Zirconium	3	Calcium	46
Thallium		Neodymium		Yttrium		Potassium	28
Mercury	NR	Praseodymium		Strontium	0.2	Chlorine	3
Gold		Cerium	<0.6	Rubidium	<0.1	Sulfur	93
Platinum		Lanthanum		Bromine	2	Phosphorus	6
Iridium		Barium	1	Selenium		Silicon	39
Osmium		Cesium		Arsenic	0.4	Aluminum	6
Rhenium		Iodine	0.5	Germanium		Magnesium	5
Tungsten		Tellurium		Gallium	<0.3	Sodium	14
Tantalum		Antimony	1	Zinc	3	Fluorine	=6
Hafnium		Tin	<1	Copper	2	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.6	Nitrogen	NR
Ytterbium		Cadmium	<0.7	Cobalt	<0.1	Carbon	NR
Thulium		Silver	<0.8	Iron	6	Boron	11
Erbium		Palladium		Manganese	0.1	Beryllium	
Holmium		Rhodium		Chromium	0.5	Lithium	INT
Dysprosium						Hydrogen	NR

NR - Not Reported

All elements not reported <0.4 ppm weight

INT-Interference Sample was thermally ashed @ 350° C for one hour in a laboratory furnace in a quartz crucible prior to analysis.

Approved: *[Signature]*

265

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 • AREA CODE 312 728-8494
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to



To: Mr. John G. Michalovic
Calspan Corporation
Post Office Box 235
Buffalo, NY 14221

Date: July 5, 1977

Analyst: S. Sweeney

P. O. No.: 27810

Sample No.: Test 19-2 F Composites B & C 5/18/77

IAD No.: 97-A345-134-21

CONCENTRATION IN $\mu\text{g/ml}$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	≤ 0.005	Terbium		Ruthenium		Vanadium	0.03
Thorium	≤ 0.006	Gadolinium		Molybdenum	0.2	Titanium	0.006
Bismuth		Europium		Niobium		Scandium	≤ 0.001
Lead	0.009	Samarium		Zirconium	0.004	Calcium	≥ 8
Thallium		Neodymium		Yttrium		Potassium	3
Mercury	NR	Praseodymium	< 0.001	Strontium	0.003	Chlorine	0.1
Gold	< 0.001	Cerium	0.001	Rubidium	< 0.001	Sulfur	MC
Platinum		Lanthanum	0.002	Bromine	0.04	Phosphorus	0.9
Iridium		Barium	0.02	Selenium	0.003	Silicon	1
Osmium		Cesium	0.002	Arsenic	0.005	Aluminum	0.05
Rhenium		Iodine	0.005	Germanium		Magnesium	0.08
Tungsten		Tellurium		Gallium	< 0.001	Sodium	> 1
Tantalum		Antimony		Zinc	0.08	Fluorine	≈ 0.04
Hafnium		Tin	0.002	Copper	0.06	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.8	Nitrogen	NR
Ytterbium		Cadmium	0.03	Cobalt	0.04	Carbon	NR
Thulium		Silver	MC	Iron	5	Boron	0.001
Erbium		Palladium		Manganese	0.2	Beryllium	
Holmium		Rhodium		Chromium	4	Lithium	≤ 0.001
Dysprosium						Hydrogen	NR

NR - Not Reported

All elements not reported $< 0.001 \mu\text{g/ml}$

Sample was thermally ashed @ 3500 C for one hour in a laboratory furnace in a quartz crucible

Approved: *M. Sweeney*

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 - AREA CODE 312 728-8484
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to

To: Mr. John C. Michalovic
Calspan Corporation
Post Office Box 235
Buffalo, NY 14221



Date: July 14, 1977

Analyst: S. Sweeney

P. O. No.: 27810

Sample No.: Test 19-2 G LF #6 Fuel Oil 5-18-77

IAD No.: 97-A345-134-21

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	250
Thorium		Gadolinium		Molybdenum	6	Titanium	0.8
Bismuth		Europium		Niobium		Scandium	<0.1
Lead	0.8	Samarium		Zirconium	0.9	Calcium	210
Thallium		Neodymium		Yttrium		Potassium	23
Mercury	NR	Praseodymium		Strontium	1	Chlorine	3
Gold		Cerium		Rubidium		Sulfur	MC
Platinum		Lanthanum		Bromine		Phosphorus	29
Iridium		Barium	8	Selenium	<0.5	Silicon	23
Osmium		Cesium		Arsenic	0.4	Aluminum	19
Rhenium		Iodine		Germanium		Magnesium	24
Tungsten		Tellurium		Gallium		Sodium	210
Tantalum		Antimony		Zinc	3	Fluorine	=5
Hafnium		Tin	<0.4	Copper	2	Oxygen	NR
Lutetium		Indium	STD	Nickel	56	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	3	Carbon	NR
Thulium		Silver		Iron	63	Boron	0.6
Erbium		Palladium		Manganese	0.3	Beryllium	
Holmium		Rhodium		Chromium	0.4	Lithium	<0.1
Dysprosium						Hydrogen	NR

NR - Not Reported

All elements not reported <0.1 ppm weight

Sample was thermally ashed @ 350°C for one hour in a laboratory furnace in a quartz crucible prior to analysis

Approved:

M. J. Sweeney

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 328 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 • AREA CODE 312 728-8484
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to

To: Mr. John C. Michalovic
Calspan Corporation
Post Office Box 235
Buffalo, NY 14221



Date: July 14, 1977

Analyst: S. Sweeney

P. O. No.: 27810

Sample No.: Test 19-2 G LF #6 Fuel Oil Duplicate
5-18-77

IAD No.: 97-A345-134-21

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	430
Thorium		Gadolinium		Molybdenum	6	Titanium	1
Bismuth		Europium		Niobium		Scandium	<0.1
Lead	<1	Samarium		Zirconium	<0.4	Calcium	190
Thallium		Neodymium		Yttrium		Potassium	63
Mercury	NR	Praseodymium		Strontium	0.3	Chlorine	1
Gold		Cerium		Rubidium		Sulfur	MC
Platinum		Lanthanum		Bromine		Phosphorus	11
Iridium		Barium	2	Selenium	<1	Silicon	19
Osmium		Cesium		Arsenic	0.2	Aluminum	8
Rhenium		Iodine		Germanium		Magnesium	27
Tungsten		Tellurium		Gallium		Sodium	≥650
Tantalum		Antimony		Zinc	4	Fluorine	≈3
Hafnium		Tin	<0.5	Copper	2	Oxygen	NR
Lutetium		Indium	STD	Nickel	47	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	2	Carbon	NR
Thulium		Silver		Iron	19	Boron	1
Erbium		Palladium		Manganese	0.3	Beryllium	
Holmium		Rhodium		Chromium	0.4	Lithium	0.4
Dysprosium						Hydrogen	NR

NR — Not Reported

All elements not reported <0.2 ppm weight

Sample was thermally ashed @ 350°C for one hour in a laboratory furnace in a quartz crucible

Approved: *M. Sweeney*

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 - AREA CODE 312 726-8434
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to



To: Mr. John C. Michalovic
Calspan Corporation
P. O. Box 235
Buffalo, NY 14221

Date: July 1, 1977

Analyst: S. Sweeney

P. O. No.:

Sample No.: Test 19-1 H

IAD No.: 97-A345-134-21

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.1
Thorium		Gadolinium		Molybdenum	9	Titanium	0.9
Bismuth		Europium		Niobium		Scandium	<0.1
Lead	≤1	Samarium		Zirconium	2	Calcium	16
Thallium		Neodymium		Yttrium		Potassium	26
Mercury	NR	Praseodymium		Strontium	0.5	Chlorine	7
Gold		Cerium		Rubidium	0.2	Sulfur	2
Platinum		Lanthanum		Bromine	1	Phosphorus	4
Iridium		Barium	1	Selenium		Silicon	24
Osmium		Cesium	≤0.1	Arsenic	≤0.3	Aluminum	3
Rhenium		Iodine	≤0.3	Germanium		Magnesium	6
Tungsten		Tellurium		Gallium	≤0.2	Sodium	9
Tantalum		Antimony		Zinc	9	Fluorine	≤4
Hafnium		Tin		Copper	2	Oxygen	NR
Lutetium		Indium	STD	Nickel	2	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	≤0.1	Carbon	NR
Thulium		Silver	≤0.3	Iron	2	Boron	12
Erbium		Palladium		Manganese	<0.1	Beryllium	
Holmium		Rhodium		Chromium	2	Lithium	<0.1
Dysprosium						Hydrogen	NR

NR - Not Reported

All elements not reported <0.3ppm weight

Sample was thermally ashed @350° C for one hour in a laboratory furnace in a quartz crucible prior to analysis

Approved: *M. Y. [Signature]*

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 • AREA CODE 312 728-8484
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to

To: Mr. John G. Michalovic
Calspan Corporation
Post Office Box 235
Buffalo, NY 14221



Date: July 5, 1977

Analyst: S. Sweeney

P. O. No.: 27810

Sample No.: Test 19-11 685 5/18/77

IAD No.: 97-A345-134-21

CONCENTRATION IN $\mu\text{g/ml}$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	0.01	Terbium		Ruthenium		Vanadium	0.004
Thorium	≤ 0.01	Gadolinium		Molybdenum	0.1	Titanium	0.4
Bismuth		Europium		Niobium		Scandium	≤ 0.001
Lead	0.02	Samarium		Zirconium	*0.08	Calcium	6
Thallium		Neodymium		Yttrium		Potassium	5
Mercury	NR	Praseodymium		Strontium	0.01	Chlorine	0.2
Gold		Cerium		Rubidium	< 0.001	Sulfur	MC
Platinum		Lanthanum	0.01	Bromine	0.009	Phosphorus	4
Iridium		Barium	0.03	Selenium	≤ 0.02	Silicon	1
Osmium		Cesium	0.007	Arsenic	0.01	Aluminum	0.1
Rhenium		Iodine	0.003	Germanium	≤ 0.001	Magnesium	0.4
Tungsten	0.02	Tellurium		Gallium		Sodium	> 3
Tantalum		Antimony	≤ 0.003	Zinc	1	Fluorine	≈ 6
Hafnium		Tin	0.05	Copper	0.04	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.7	Nitrogen	NR
Ytterbium		Cadmium	0.002	Cobalt	0.09	Carbon	NR
Thulium		Silver	MC	Iron	0.2	Boron	0.009
Erbium		Palladium		Manganese	0.004	Beryllium	
Holmium		Rhodium		Chromium	2	Lithium	0.02
Dysprosium						Hydrogen	NR

*Heterogeneous
NR — Not Reported

All elements not reported $< 0.001 \mu\text{g/ml}$

Sample was thermally ashed @ 3500 C for one hour in a laboratory furnace in a quartz crucible

Approved: *[Signature]*

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 - AREA CODE 312 726-8434
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to

To: Mr. John G. Michalovic
Calspan Corporation
Post Office Box 235
Buffalo, NY 14221



Date: July 5, 1977

Analyst: S. Sweeney

P. O. No.: 27810

Sample No.: Test 19-1 J674 5/18/77

IAD No.: 97-A345-134-21

CONCENTRATION IN $\mu\text{g/ml}$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	≤ 0.05	Terbium		Ruthenium		Vanadium	0.002
Thorium	≤ 0.06	Gadolinium		Molybdenum	0.08	Titanium	0.1
Bismuth		Europium		Niobium		Scandium	≤ 0.004
Lead	0.03	Samarium		Zirconium	0.04	Calcium	MC
Thallium		Neodymium		Yttrium		Potassium	MC
Mercury	NR	Praseodymium		Strontium	0.09	Chlorine	0.2
Gold	≤ 0.005	Cerium	0.009	Rubidium	0.001	Sulfur	MC
Platinum		Lanthanum	0.02	Bromine	0.02	Phosphorus	MC
Iridium		Barium	0.02	Selenium	≤ 0.009	Silicon	0.9
Osmium		Cesium	≤ 0.002	Arsenic	≤ 0.003	Aluminum	0.8
Rhenium		Iodine	0.007	Germanium		Magnesium	1
Tungsten		Tellurium		Gallium		Sodium	MC
Tantalum		Antimony		Zinc	0.09	Fluorine	≈ 3
Hafnium		Tin		Copper	0.03	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.02	Nitrogen	NR
Ytterbium		Cadmium	≤ 0.01	Cobalt	≤ 0.01	Carbon	NR
Thulium		Silver	≤ 0.007	Iron	0.1	Boron	0.006
Erbium		Palladium		Manganese	0.01	Beryllium	
Holmium		Rhodium		Chromium	0.02	Lithium	≤ 0.001
Dysprosium						Hydrogen	NR

NR - Not Reported

All elements not reported < 0.1 ppm weight

Approved:

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICE: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 - AREA CODE 312 728-8484
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to

To: Mr. John G. Michalovic
Calspan Corporation
Post Office Box 235
Buffalo, NY 14221



Date: July 1, 1977

Analyst: S. Sweeney

P. O. No.: 27810

Sample No.: Test 19-1 K 684 5/18/77

IAD No.: 97-A345-134-21

CONCENTRATION IN $\mu\text{g/ml}$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.002
Thorium		Gadolinium		Molybdenum	0.2	Titanium	0.08
Bismuth		Europium		Niobium		Scandium	<0.002
Lead	<0.04	Samarium		Zirconium	0.02	Calcium	2
Thallium		Neodymium		Yttrium		Potassium	0.5
Mercury	NR	Praseodymium		Strontium	0.07	Chlorine	1
Gold		Cerium	<0.01	Rubidium	<0.002	Sulfur	6
Platinum		Lanthanum		Bromine	0.06	Phosphorus	2
Iridium		Barium	0.2	Selenium	<0.01	Silicon	0.6
Osmium		Cesium	<0.003	Arsenic	<0.004	Aluminum	0.04
Rhenium		Iodine	0.008	Germanium		Magnesium	0.9
Tungsten		Tellurium		Gallium		Sodium	3
Tantalum		Antimony		Zinc	0.2	Fluorine	≈3
Hafnium		Tin		Copper	0.05	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.06	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	<0.001	Carbon	NR
Thulium		Silver	<0.02	Iron	0.09	Boron	0.008
Erbium		Palladium		Manganese	0.004	Beryllium	
Holmium		Rhodium		Chromium	0.04	Lithium	<0.001
Dysprosium						Hydrogen	NR

NR - Not Reported

All elements not reported <0.01 $\mu\text{g/ml}$

Sample was thermally ashed @ 3500° C for one hour in a laboratory furnace in a quartz crucible

Approved: 

272

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 220 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 • AREA CODE 312 726-8424
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to

To: Mr. John G. Michalovic
Calspan Corporation
Post Office Box 235
Buffalo, NY 14221



Date: July 1, 1977

Analyst: S. Sweeney

P. O. No.: 27810

Sample No.: Test 19-1 L 675 5/18/77

IAD No.: 97-A345-134-21

CONCENTRATION IN $\mu\text{g/ml}$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	≤ 0.01
Thorium		Gadolinium		Molybdenum	0.4	Titanium	0.2
Bismuth		Europium		Niobium		Scandium	≤ 0.007
Lead	≤ 0.2	Samarium		Zirconium	≤ 0.1	Calcium	0.9
Thallium		Neodymium		Yttrium		Potassium	1
Mercury	NR	Praseodymium		Strontium	0.02	Chlorine	2
Gold		Cerium		Rubidium	0.01	Sulfur	3
Platinum		Lanthanum		Bromine	0.09	Phosphorus	0.6
Iridium		Barium	≤ 0.1	Selenium	≤ 0.06	Silicon	1
Osmium		Cesium	≤ 0.02	Arsenic	≤ 0.02	Aluminum	0.2
Rhenium		Iodine		Germanium		Magnesium	0.4
Tungsten		Tellurium		Gallium	≤ 0.03	Sodium	0.8
Tantalum		Antimony		Zinc	0.1	Fluorine	=1
Hafnium		Tin		Copper	0.05	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.07	Nitrogen	NR
Ytterbium		Cadmium		Cobalt		Carbon	NR
Thulium		Silver		Iron	0.2	Boron	0.03
Erbium		Palladium		Manganese	0.006	Beryllium	
Holmium		Rhodium		Chromium	0.04	Lithium	0.003
Dysprosium						Hydrogen	NR

NR — Not Reported

All elements not reported $\leq 0.04 \mu\text{g/ml}$

*Heterogeneous

Approved:

KVB Analysis Data

<u>Test</u>	<u>Sample Number</u>	<u>POM's</u>	<u>PCB's</u>
19-1	LF	*	*
19-2	533	< 0.1 ug/g	< 1 ug/g
	533 (duplicate)	< 0.1 ug/g	< 1 ug/g
	C	< 1 ug/l	< 1 ug/l
	C (duplicate)	< 1 ug/l	< 1 ug/l
	LF	*	*

*Sample extracts too concentrated to be able to determine an analytical value.

KVB

TRACE SPECIES AND ORGANICS TEST SAMPLE RECOVERY LOG

Test No. 19-3 Date 3-21-77 Location 19

Sample Port Position MID-POINT/STACK / - 15" IN

Container Number	Sample Description	Container Type	Net wt/vol.	Comment
722	N02/PROBE/10 m.	NAL	2.4163	SOLIDS
633	" " "	GL	160	50/50
628	" " "	GL	225	"
639	" " "	GL	210	H ₂ O
638	" " "	GL	210	"
723	3 m	NAL	1.0724	SOLIDS
634	"	GL	206	50/50
640	"	GL	208	H ₂ O
726	1 m	NAL	1.2120	SOLIDS
641	"	GL	187	50/50
642	"	GL	187	H ₂ O
539	FILTER	P.D.	1.9974	SOLIDS
643	"	GL	82	50/50
644	"	GL	164	H ₂ O
673	IMPINGER #1	NAL	938	SOLUTION
635	"	GL	191	IPA
630	"	GL	162	H ₂ O
519	IMPINGER #2	NAL	787	SOLUTION
631	"	GL	180	IPA
636	"	GL	160	H ₂ O
686	IMPINGER #3	NAL	737	SOLUTION
637	"	GL	149	IPA
632	"	GL	140	H ₂ O
537	XAD-2	GL	-	RESIN
665	"	NAL	1020	CONDENSATE
624	"	GL	152	"
627	"	GL	205	50/50
647	"	GL	215	"
653	"	GL	58	H ₂ O
659	"	GL	225	"
688	H ₂ O BLANK	NAL	1000	BLANK

KEELER BOILER

TEST 19-3		TABLE							STACK - #6 OIL LOW NO _x COND.	
POLLUTANT		SAMPLE NUMBER								
	722 ⁺	723 ⁺	726 ⁺	539 ⁺	A*	B*	537 ⁺	C ₁ *		
Antimony	<50	<2500	<830	<170	<0.5	<0.5	<25			
Arsenic	4	<100	<33	33	0.01	0.005	7			
Barium	480	<1000	<330	730	<0.1	<0.1	75			
Beryllium	<1	<50	<17	<3.3	<0.005	<0.005	<0.5			
Cadmium	<1	<50	<17	<3.3	<0.005	0.015	<0.5			
Calcium	1900	3500	3000	2100	15	0.20	<5.0			
Chromium	69	950	300	180	0.05	8.4	8			
Cobalt	104	450	300	807	<0.2	<0.2	1.5			
Copper	43	<50	<150	200	0.11	0.11	0.5			
Iron	5200	4400	6500	20000	1.9	38	31			
Lead	—	—	—	—	0.11	<0.05	—			
Manganese	49	200	117	160	0.16	0.57	2.0			
Mercury	0.5	<2.0	<0.67	<0.13	<0.005	<0.005	<0.02			
Nickel	970	1700	3000	13000	0.5	5.9	<2.5			
Selenium	<2.0	<5000	<33	<6.7	0.04	0.04	<1.0			
Tellurium	<50	<2500	<830	<170	<0.3	<0.3	<25			
Tin	<100	<5000	<1700	<330	<1	<1	<50			
Titanium	600	<15,000	5000	<1000	<1	<1	<150			
Vanadium	5400	7000	14000	43000	1.4	<0.1	<10			
Zinc	281	250	350	3000	0.59	0.08	1.5			
Chloride	<30	<97	—	1710	<0.5	1.6	<11	—		
Fluoride	54	—	—	<1	<0.1	<0.1	18	—		
Nitrates	43.0	67.0	—	46.1	0.30	0.92	<0.2	0.42		
Sulfates	8910	14000	—	170,000	16.0	135	289	10200		

633,628, 627,647 665,624
639,638, 653,659 673,635,
634,640, 630
641,642,
643,644

KEELER BOILER

TEST 19-3			TABLE		STACK - #6 OIL LOW NO _x COND.				
POLLUTANT			SAMPLE NUMBER						
	C*	C* dupli- cate							
Antimony	<0.5	<0.5							
Arsenic	0.005	<0.005							
Barium	<0.1	<0.1							
Beryllium	<0.005	<0.005							
Cadmium	0.020	0.010							
Calcium	0.11	0.20							
Chromium	1.5	1.4							
Cobalt	<0.2	<0.2							
Copper	0.05	<0.02							
Iron	5.1	4.9							
Lead	<0.05	<0.05							
Manganese	0.12	0.11							
Mercury	<0.005	<0.005							
Nickel	2.0	0.72							
Selenium	0.020	<0.010							
Tellurium	<0.3	<0.3							
Tin	<1	<1							
Titanium	<1	<1							
Vanadium	<0.1	<0.1							
Zinc	4.9	0.10							
Chloride	27.2	26.0							
Fluoride	0.40	0.44							
Nitrates	—	—							
Sulfates	—	—							

665, 624,
673, 635,
630, 519,
631, 636,
686, 637,
632

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 • AREA CODE 312 726-8484
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to



To: Mr. John C. Michalovic
Calspan Corporation
Post Office Box 235
Buffalo, NY 14221

Date: July 1, 1977

Analyst: S. Sweeney

P. O. No.: 27810

Sample No.: Test 19-3 D 722, 723, 726, 539

IAD No.: 97-A345-134-21

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	2	Terbium	0.2	Ruthenium		Vanadium	MC
Thorium	≤1	Gadolinium	0.7	Molybdenum	970	Titanium	300
Bismuth		Europium	0.3	Niobium	0.7	Scandium	0.2
Lead	160	Samarium	2	Zirconium	7	Calcium	MC
Thallium		Neodymium	12	Yttrium	2	Potassium	MC
Mercury	NR	Praseodymium	7	Strontium	42	Chlorine	160
Gold		Cerium	19	Rubidium	0.8	Sulfur	>800
Platinum		Lanthanum	60	Bromine	2	Phosphorus	MC
Iridium		Barium	460	Selenium	3	Silicon	MC
Osmium		Cesium	0.8	Arsenic	7	Aluminum	>130
Rhenium		Iodine	1	Germanium	0.6	Magnesium	MC
Tungsten	≤0.7	Tellurium	0.8	Gallium	11	Sodium	>330
Tantalum		Antimony	*20	Zinc	570	Fluorine	≈46
Hafnium		Tin	5	Copper	70	Oxygen	NR
Lutetium		Indium	STD	Nickel	MC	Nitrogen	NR
Ytterbium		Cadmium	0.4	Cobalt	400	Carbon	NR
Thulium		Silver	5	Iron	MC	Boron	1
Erbium	0.2	Palladium		Manganese	44	Beryllium	0.1
Holmium	0.4	Rhodium		Chromium	33	Lithium	2
Dysprosium	0.8					Hydrogen	NR

*Heterogeneous

NR - Not Reported

All elements not reported <0.1 ppm weight

Approved:

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 - AREA CODE 312 726-8424
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-778-9521

Reply to

To: Mr. John C. Michalovic
Calspan Corporation
P. O. Box 235
Buffalo, NY 14221



Date: July 1, 1977

Analyst: S. Sweeney

P. O. No.:

Sample No.: Test 19-3 E 537

IAD No.: 97-A345-134-21

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	≤1	Terbium		Ruthenium		Vanadium	0.6
Thorium	≤1	Gadolinium		Molybdenum	*18	Titanium	2
Bismuth		Europium		Niobium		Scandium	≤0.1
Lead	1	Samarium		Zirconium	1	Calcium	25
Thallium		Neodymium		Yttrium		Potassium	20
Mercury	NR	Praseodymium		Strontium	0.1	Chlorine	21
Gold	1	Cerium	0.2	Rubidium	<0.1	Sulfur	21
Platinum		Lanthanum	0.4	Bromine	1	Phosphorus	11
Iridium		Barium	0.4	Selenium	≤0.4	Silicon	45
Osmium		Cesium	≤0.1	Arsenic	1	Aluminum	3
Rhenium		Iodine	0.3	Germanium		Magnesium	16
Tungsten		Tellurium		Gallium	≤0.1	Sodium	47
Tantalum		Antimony	17	Zinc	3	Fluorine	≈26
Hafnium		Tin	0.4	Copper	4	Oxygen	NR
Lutetium		Indium	STD	Nickel	3	Nitrogen	NR
Ytterbium		Cadmium	≤0.3	Cobalt	<0.1	Carbon	NR
Thulium		Silver	0.7	Iron	10	Boron	4
Erbium		Palladium		Manganese	0.2	Beryllium	
Holmium		Rhodium		Chromium	5	Lithium	<0.1
Dysprosium						Hydrogen	NR

NR - Not Reported

All elements not reported <0.2ppm weight

*Heterogeneous Sample was thermally ashed @3500° C for one hour in a laboratory furnace in a quartz crucible prior to analysis.

Approved: *M. Sweeney*

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 - AREA CODE 312 726-8434
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to

To: Mr. John C. Michalovic
Calspan Corporation
Post Office Box 235
Buffalo, NY 14221



Date: July 5, 1977

Analyst: S. Sweeney

P. O. No.: 27810

Sample No.: Test 19-3 F Composite B & C 5/18/77

IAD No.: 97-A345-134-21

CONCENTRATION IN $\mu\text{g/ml}$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	0.1	Terbium		Ruthenium		Vanadium	0.02
Thorium	≤ 0.06	Gadolinium		Molybdenum	0.3	Titanium	2
Bismuth		Europium		Niobium	≤ 0.02	Scandium	≤ 0.009
Lead	0.05	Samarium		Zirconium	0.04	Calcium	MC
Thallium		Neodymium		Yttrium	≤ 0.008	Potassium	MC
Mercury	NR	Praseodymium		Strontium	1	Chlorine	8
Gold	≤ 0.02	Cerium	0.01	Rubidium	0.003	Sulfur	MC
Platinum		Lanthanum	0.03	Bromine	0.3	Phosphorus	MC
Iridium		Barium	2	Selenium	0.4	Silicon	3
Osmium		Cesium	0.03	Arsenic	0.02	Aluminum	> 7
Rhenium		Iodine	0.02	Germanium		Magnesium	MC
Tungsten		Tellurium		Gallium	≤ 0.006	Sodium	MC
Tantalum		Antimony	0.1	Zinc	2	Fluorine	≈ 0.3
Hafnium		Tin	≤ 0.03	Copper	0.4	Oxygen	NR
Lutetium		Indium	STD	Nickel	1	Nitrogen	NR
Ytterbium		Cadmium	≤ 0.01	Cobalt	0.01	Carbon	NR
Thulium		Silver	MC	Iron	4	Boron	0.002
Erbium		Palladium		Manganese	0.2	Beryllium	0.001
Holmium		Rhodium		Chromium	2	Lithium	0.04
Dysprosium						Hydrogen	NR

NR - Not Reported

All elements not reported $< 0.006 \mu\text{g/ml}$

Approved:

M. J. Sweeney

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 • AREA CODE 312 728-8434
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to

To: Mr. John C. Michalovic
Calspan Corporation
Post Office Box 235
Buffalo, NY 14221



Date: July 14, 1977

Analyst: S. Sweeney

P. O. No.: 27810

Sample No.: Test 19-3 G LF #6 Fuel Oil 5/18/77

IAD No.: 97-A345-134-21

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	140
Thorium		Gadolinium		Molybdenum	8	Titanium	1
Bismuth		Europium		Niobium	<0.4	Scandium	<0.2
Lead	<1	Samarium		Zirconium	0.6	Calcium	48
Thallium		Neodymium		Yttrium		Potassium	8
Mercury	NR	Praseodymium		Strontium	1	Chlorine	2
Gold		Cerium		Rubidium	<0.1	Sulfur	MC
Platinum		Lanthanum		Bromine	<0.5	Phosphorus	11
Iridium		Barium	6	Selenium	1	Silicon	19
Osmium		Cesium		Arsenic	0.5	Aluminum	2
Rhenium		Iodine		Germanium		Magnesium	27
Tungsten		Tellurium		Gallium		Sodium	72
Tantalum		Antimony		Zinc	2	Fluorine	≈4
Hafnium		Tin		Copper	2	Oxygen	NR
Lutetium		Indium	STD	Nickel	26	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	2	Carbon	NR
Thulium		Silver	2	Iron	13	Boron	0.7
Erbium		Palladium		Manganese	0.6	Beryllium	
Holmium		Rhodium		Chromium	3	Lithium	<0.1
Dysprosium						Hydrogen	NR

NR — Not Reported

All elements not reported <0.2 ppm weight

Sample was thermally ashed @ 350° C for one hour in a laboratory furnace in a quartz crucible prior to analysis.

Approved:

M. J. Sweeney
Laboratory Analyst

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 328 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 • AREA CODE 312 728-8434
INSTRUMENTAL ANALYSIS DIVISION, 1435 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE: 303-278-9521

Reply to

To: Mr. John C. Michalovic
Calspan Corporation
Post Office Box 235
Buffalo, NY 14221



Date: July 14, 1977

Analyst: S. Sweeney

P. O. No.: 27810

Sample No.: Test 19-3 G LF #6 Fuel Oil Duplicate
5-18-77

IAD No.: 97-A345-134-21

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	150
Thorium		Gadolinium		Molybdenum	10	Titanium	1
Bismuth		Europium		Niobium	≤0.2	Scandium	≤0.1
Lead	≤0.8	Samarium		Zirconium	0.6	Calcium	38
Thallium		Neodymium		Yttrium		Potassium	16
Mercury	NR	Praseodymium		Strontium	0.8	Chlorine	0.9
Gold		Cerium		Rubidium	0.04	Sulfur	MC
Platinum		Lanthanum		Bromine		Phosphorus	8
Iridium		Barium	2	Selenium	0.8	Silicon	17
Osmium		Cesium		Arsenic	0.3	Aluminum	1
Rhenium		Iodine		Germanium		Magnesium	17
Tungsten		Tellurium		Gallium		Sodium	50
Tantalum		Antimony		Zinc	3	Fluorine	≈2
Hafnium		Tin		Copper	1	Oxygen	NR
Lutetium		Indium	STD	Nickel	20	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	2	Carbon	NR
Thulium		Silver	≤0.2	Iron	15	Boron	0.8
Erbium		Palladium		Manganese	0.3	Beryllium	
Holmium		Rhodium		Chromium	0.2	Lithium	≤0.1
Dysprosium						Hydrogen	NR

NR - Not Reported

All elements not reported <0.2 ppm weight

Sample was thermally ashed @ 350°C for one hour in a laboratory furnace in a quartz crucible prior to analysis.

Approved: 

KVB Analysis Data (Cont.)

<u>Test</u>	<u>Sample Number</u>	<u>POM's</u>	<u>PCB's</u>
19-3	537	< 0.1 ug/g	< 1 ug/g
	537 (duplicate)	< 0.1 ug/g	< 1 ug/g
	722	< 1 ug/g	< 1 ug/g
	B	— 1450 ug/l	< 1 ug/l
	C	2 ug/l	< 1 ug/l
	LF	*	*
	LF (duplicate)	*	.*

*Sample extracts too concentrated to be able to determine an analytical value.

KVB

TRACE SPECIES AND ORGANICS TEST SAMPLE RECOVERY LOG

Test No. 19-4SAS Date 3-23-77 Location 19

Sample Port Position STACK CENTER 15" m

Container Number	Sample Description	Container Type	Net wt/vol.	Comment
728	NO2 / PROCL / 10 m	NAL	1.5802	SOLIDS
645	"	GL	215	50/50
646	"	GL	210	"
649	"	GL	230	H2O
650	"	GL	225	"
732	3 m	NAL	.9878	SOLIDS
651	"	GL	190	50/50
652	"	GL	165	H2O
734	1 m	NAL	.3263	SOLIDS
654	"	GL	165	50/50
655	"	GL	150	H2O
540	FILTER	P. DISH	.9503	SOLIDS
656	"	GL	125	50/50
657	"	GL	85	H2O
695	#1 IMPINGER	NAL	890	SOLUTION
658	"	GL	165	IPA
660	"	GL	180	H2O
696	#2 IMPINGER	NAL	875	SOLUTION
661	"	GL	170	IPA
662	"	GL	180	H2O
698	#3 IMPINGER	NAL	605	SOLUTION
663	"	GL	80	IPA
664	"	GL	140	H2O
535	XAD-2	GL	—	RESIN
697	"	NAL	1000	CONDENSATE
648	"	GL	175	"
581	"	GL	230	50/50
582	"	GL	305	H2O

KEELER BOILER

TEST 19-4		TABLE STACK - #6 OIL LOW NO _x COND.						
POLLUTANT	SAMPLE NUMBER							
	728 ⁺	732 ⁺	734 ⁺	540 ⁺	A*	B*	535 ⁺	C ₁ *
Antimony	<50	<100	<125	<100	<0.5	<0.5	<22	
Arsenic	20	20	50	46.3	0.005	<0.005	6.2	
Barium	140	2400	625	652	<0.1	<0.1	85	
Beryllium	<1.0	<2.0	<2.5	<2	<0.005	<0.005	<0.45	
Cadmium	<1.0	<2.0	<2.5	<2	<0.005	0.040	<0.45	
Calcium	2000	840	4700	<60000	0.35	0.12	<4.5	
Chromium	37	56	115	109	0.10	8.3	6.2	
Cobalt	95	110	270	<24	<0.2	<0.2	3.1	
Copper	28	30	33	156	0.05	0.54	7.6	
Iron	2700	2440	8600	11600	1.2	46	29	
Lead	—	—	—	—	<0.05	<0.05	—	
Manganese	30	34	73	114	0.16	0.62	1.3	
Mercury	<0.04	<0.08	<0.1	<0.08	<0.005	<0.005	<0.02	
Nickel	1000	1320	8200	12600	1.1	20	<2.2	
Selenium	<2.0	<4.0	<5.0	<4	<0.01	<0.01	<0.89	
Tellurium	<50	<100	<125	<100	<0.3	<0.3	<22	
Tin	<100	<200	<250	<250	<1	<1	<45	
Titanium	<300	<600	<750	<420	<1	<1	<130	
Vanadium	<20	5800	14000	36800	1.1	<0.1	<0.89	
Zinc	3.0	174	300	2170	2.7	27	5.4	
Chloride	<28	<53	—	446	<0.5	<0.5	30.0	—
Fluoride	—	274	323	<1	<0.1	0.17	25	—
Nitrates	49.5	35.0	—	<20	0.16	0.76	1.87	0.28
Sulfates	7890	12700	—	199000	10	212	449	16500
					645, 646, 649, 650, 651, 652, 654, 655, 656, 657	581, 582	697, 648, 695, 658, 660	

645, 646,
649, 650,
651, 652,
654, 655,
656, 657

581,
582

697, 648,
695, 658,
660

KEELER BOILER

TEST 19-4		TABLE STACK - #6 OIL LOW NO _x COND.						
POLLUTANT		SAMPLE NUMBER						
	C*							
Antimony	<0.5							
Arsenic	<0.005							
Barium	<0.1							
Beryllium	<0.005							
Cadmium	<0.005							
Calcium	0.77							
Chromium	1.2							
Cobalt	<0.2							
Copper	0.08							
Iron	3.1							
Lead	<0.05							
Manganese	0.08							
Mercury	<0.005							
Nickel	3.2							
Selenium	<0.010							
Tellurium	<0.3							
Tin	<1							
Titanium	<1							
Vanadium	<0.1							
Zinc	9.7							
Chloride	41.0							
Fluoride	0.10							
Nitrates	—							
Sulfates	—							

697,648,
695,658,
660,696,
661,662,
698,663,
664

KVB Analysis Data (Cont.)

<u>Test</u>	<u>Sample Number</u>	<u>POM's</u>	<u>PCB's</u>
19-4	535 LF	< 0.1 ug/g *	< 1 ug/g *

*Sample extracts too concentrated to be able to determine an analytical value.

POM QUANTIFICATION

Component	Blank 684	Blank-K 571	Test 19-2 #533	Test 19-3 #537
Anthracene	0.71 ng	10.0 ng	367 ng	57.8 ng
Phenanthrene	--	--	--	2.3
Methyl Anthracenes	--	1.9	24.1	15.4
Fluoranthene	0.21	1.0	136	16.3
Pyrene	--	--	6.1	6.3
Benzo(c)phenanthrene	--	--	0.26	--
Chrysene	--	--	2.9	0.52
Benz(a)anthracene	--	--	--	--
Methyl Chrysenes	--	--	--	--
Benzo Fluoranthenes	--	--	0.80	0.87
Benz(a)pyrene	--	--	0.48	--
Benz(e)pyrene	--	--	0.49	--
Perylene	--	--	--	--
Indeno(1,2,3-cd)pyrene	--	--	--	--
Benzo(ghi)perylene	--	--	--	--

INDUSTRIAL BOILER DESIGN DATA

Location No. *38* Unit No.

Unit Description

VERTICAL CE WATERTUBE BOILER

Steam Output (lb/hr x 10 ³)	<i>45</i>
Final Steam Temp., °F	<i>SATURATED</i>
Burner Description	<i>1 PEABODY GAS RING</i>
Test Fuel	<i>NATURAL GAS ; #6 OIL</i>
Primary Air Temp, °F	<i>~350</i>
Stack Temp, °F	<i>430-550</i>

Comments:

*THE UNIT WAS MODIFIED TO INCORPORATE
SIDEFIRE CAPABILITY.*

MOBILE LABORATORY DATA

Test No. _____

Test No. 200-2320 Date 5/24/76 Location 38 Engr. _____Unit No. _____ Fuel NO. 6 Capacity 45 K#/hr

FURNACE

Unit Type C.E. VERTICAL Burner Type PEABODY STEAM

1. Test No.	200-23	200-24			
2. Date					
3. Time					
4. Load K#/hr	38	38			
5. Process Rate					
6. Flue Diam. or Size, ft					
7. Probe Position					
8. Oxygen (%) HOT/COLD	2.95	2.9	2.9	2.9	
9. NOx (hot) read/3% O ₂ (ppm)*			271	297	
10. NO (hot) read/3% O ₂ (ppm)*	245	268	270	296	
11. NO ₂ (hot) read/3% O ₂ (ppm)*			1	1	
12. NO (cold) read/3% O ₂ (ppm)*	300	298	298	296	
13. Carbon Dioxide (%) (BOILER EXIT)	13.8	13.8			
14. Carbon Monoxide (ppm) uncor/cor*					
15. Hydrocarbon (ppm) uncor/cor*					
16. Sulfur Dioxide (ppm) uncor/cor*					
17. Smoke Spot (Bacharach)					
18. Atmos. Temp. (°F/°C) DRY/WET	70/56	70/57			
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	29.8	29.75			
21. Relative Humidity (%)					
22. STACK O ₂	6.8	6.75			
23. WATER CONTENT (% VOL.)	10	10			
24. NO STACK	233	295	245	309	
25. CO HOT/COLD/STACK	-258	-	22	22	16
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 5/25/76 Location 38 Engr. _____Unit No. _____ Fuel NO. 6 Capacity 45 K#/hrUnit Type C.E. VERTICAL Burner Type PEARODY STEAM

1. Test No.	200-25	201-12	202-4	202-4A	
2. Date					
3. Time					
4. Load					
5. Process Rate					
6. Flue Diam. or Size, ft					
7. Probe Position					
8. Oxygen (%) HOT / COLD	2.9	2.8	1.55	1.55	2.6 2.65 2.7
9. NOx (hot) read/3% O ₂ (ppm)*	260	285	232	238	185 200
10. NO (hot) read/3% O ₂ (ppm)*	260	285	232	238	185 200
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0	0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	288	285	245	227	265 259 230 226
13. Carbon Dioxide (%) BOILER EXIT	14.0	15.0	14.1	14.1	
14. Carbon Monoxide (ppm) uncor/cor*					
15. Hydrocarbon (ppm) uncor/cor*					
16. Sulfur Dioxide (ppm) uncor/cor*					
17. Smoke Spot (Bacharach)					
18. Atmos. Temp. (°F/°C) DRY/WET	58	51	59	51	58 52
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)		29.93			
21. Relative Humidity (%)					
22. STACK O ₂	6.7	5.7	6.2	6.4	
23. WATER CONTENT (% VOL.)	10	10.7		10.1	
24. NO STACK	220	277	188	221	220 268 185 228
25. CO HOT COLD STACK	26	22	16	46-8050 60 80	30 55 32 29
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 5/26/76 Location 38 Engr. _____Unit No. _____ Fuel NO. 6 Capacity 45 K#/hrUnit Type C-E. VERTICAL Burner Type PEABODY STEAM

1. Test No.	200-26	201-13	201-14	202-5	
2. Date					
3. Time					
4. Load					
5. Process Rate					
6. Flue Diam. or Size, ft					
7. Probe Position					
8. Oxygen (%) <u>HOT/COLD</u>	2.4	1.6	1.5	2.55	2.45
9. NOx (hot) read/3% O ₂ (ppm)*				225	242
10. NO (hot) read/3% O ₂ (ppm)*				220	237
11. NO ₂ (hot) read/3% O ₂ (ppm)*				5	5
12. NO (cold) read/3% O ₂ (ppm)*	277	268	250	232	248
13. Carbon Dioxide (%) <u>BOILER EXIT</u>		15	15	14.4	
14. Carbon Monoxide (ppm) uncor/cor*					
15. Hydrocarbon (ppm) uncor/cor*					
16. Sulfur Dioxide (ppm) uncor/cor*					
17. Smoke Spot (Bacharach)					
18. Atmos. Temp. (°F/°C) <u>DRY/WET</u>		58	52	67	56
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)		30.05		29.87	
21. Relative Humidity (%)					
22. <u>STACK O₂</u>	6.5	5.8	6.05	6.4	
23. <u>WATER CONTENT (% VOL)</u>				10.2	
24. <u>NO (STACK)</u>	227	282	195	231	195
25.					
26.					
27.					
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 5/27/76 Location 38 Engr. _____Unit No. _____ Fuel NO. 6 Capacity 45 L#/hrUnit Type C.E. VERTICAL Burner Type PEABODY STEAM

1. Test No.	200-27		201-15		203-28			
2. Date								
3. Time								
4. Load								
5. Process Rate								
6. Flue Diam. or Size, ft								
7. Probe Position								
8. Oxygen (%) <u>HOT/COLD</u>	2.3	2.3	1.55	1.6	3.3	3.35		
9. NO _x (hot) read/3% O ₂ (ppm)*	175	185	220	226	155	173		
10. NO (hot) read/3% O ₂ (ppm)*	172	182	220	226	155	173		
11. NO ₂ (hot) read/3% O ₂ (ppm)*	3	3	0	0	0	0		
12. NO (cold) read/3% O ₂ (ppm)*	290	279	270	251	180	184		
13. Carbon Dioxide (%) <u>BOILER EXIT</u>	14.6		15.0		13.2			
14. Carbon Monoxide (ppm) uncor/cor*								
15. Hydrocarbon (ppm) uncor/cor*								
16. Sulfur Dioxide (ppm) uncor/cor*								
17. Smoke Spot (Bacharach)								
18. Atmos. Temp. (°F/°C) <u>DRY/WET</u>			65	57	75	60		
19. Dew Point Temp. (°F/°C)								
20. Atmos. Pressure (in. Hg)			30.10		30.16			
21. Relative Humidity (%)								
22. <u>STACK O₂</u>	6.25		5.85		7.0			
23. <u>WATER CONTENT (% VOL.)</u>	10.3		10.7		9.8			
24. <u>NO (STACK)</u>	135	165	209	248	147	189		
25.								
26.								
27.								
28.								
29.								
30.								

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

2006-1,2 6-01-76
 Test No. 2016-1,2,3 Date 6-02-76 Location 38 Engr. WN, T.D.

Unit No. _____ Fuel GAS Capacity 45 K#/hr

Unit Type C.E. VERTICAL Burner Type PEABODY - RING

1. Test No.	2006-1		2006-2		2016-1		2016-2		2016-3	
2. Date			6/02/76							
3. Time										
4. Load (K#/hr)	41.5		40.0		40.0		40.0		39.8	
5. Process Rate										
6. Flue Diam. or Size, ft										
7. Probe Position										
8. Oxygen (%) COLD LINE/HEATED LINE	1.25	1.40	1.6	1.5	4.0	4.1	2.5	2.5	3.95	
9. NOx (hot) read/3% O ₂ (ppm)*	144		162		148		165			
10. NO (hot) read/3% O ₂ (ppm)*	144		162		148		164			
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0		0		0		1			
12. NO (cold) read/3% O ₂ (ppm)*	157	143	174	161	160	169	180	175	162	
13. Carbon Dioxide (%)	11		10.5		9.5		10			
14. Carbon Monoxide (ppm) uncor/cor*										
15. Hydrocarbon (ppm) uncor/cor*										
16. Sulfur Dioxide (ppm) uncor/cor*										
17. Smoke Spot (Bacharach)										
18. Atmos. Temp. (°F/°C) DRY/WET	66	65	58.5	55	64	56	66	57.5		
19. Dew Point Temp. (°F/°C)										
20. Atmos. Pressure (in. Hg)	29.85		30.04		30.15		30.16			
21. Relative Humidity (%)										
22. STACK O ₂	5.8		6.2		8.0		6.6		7.75	
23. NO (STACK)	122	144	131	159	122	169	138	172	124	
24. CO COLD LINE/HOT LINE/STACK							12	12	10	20 - 11
25. CO ₂ COLD LINE/HOT LINE, STACK	11.0	11.0	8.3	10.5	10.5	7.8	9.5	9.5	7.1	10 10 7.4
26.										
27.										
28.										
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. 2016-4,5,6 Date 6-2-76 Location 38 Engr. _____Unit No. _____ Fuel GAS Capacity 45 k#/hrUnit Type C.E. VERTICAL Burner Type PEABODY - RING

1. Test No.	2016-4		2016-5		2016-6			
2. Date								
3. Time								
4. Load (k#/hr)	40.0		39.2		40.5			
5. Process Rate								
6. Flue Diam. or Size, ft								
7. Probe Position								
8. Oxygen (%) COLD LINE/HOT LINE	2.9	2.9	1.25		1.45	1.50		
9. NO _x (hot) read/3% O ₂ (ppm)*	156				148			
10. NO (hot) read/3% O ₂ (ppm)*	156				148			
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0				0			
12. NO (cold) read/3% O ₂ (ppm)*	166	165	152	139	164	151		
13. Carbon Dioxide (%)	10		10.5		11.0			
14. Carbon Monoxide (ppm) uncor/cor*								
15. Hydrocarbon (ppm) uncor/cor*								
16. Sulfur Dioxide (ppm) uncor/cor*								
17. Smoke Spot (Bacharach)								
18. Atmos. Temp. (°F/°C) DRY/WET	68	58						
19. Dew Point Temp. (°F/°C)								
20. Atmos. Pressure (in. Hg)	30.15							
21. Relative Humidity (%)								
22. STACK O ₂	7.0		5.85		6.0			
23. NO (STACK)	129	166	114	135	124	149		
24. CO COLD LINE/HOT LINE	10	10	2000		280	130-250		
25. CO (STACK)	7		2000		300			
26. CO ₂ COLD LINE/HOT LINE	10	10	10.5		11.0	11.0		
27. CO ₂ (STACK)	7.6		8		8.3			
28.								
29.								
30.								

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 6/3/76 Location 38 Engr. _____
 Unit No. _____ Fuel GAS Capacity 45 k#/hr
 Unit Type C.F. VERTICAL Burner Type PEABODY - RING

1. Test No.	2006-3		204-1		204-2		204-3		204-4	
2. Date										
3. Time										
4. Load (k#/hr)	39.0		38.0		38.0		38.3		38.5	
5. Process Rate										
6. Flue Diam. or Size, ft										
7. Probe Position										
8. Oxygen (%) ^{COLD LINE/HOT LINE}	2.7	2.7	2.95	2.80	2.6	2.6	2.9	3.05	3.0	2.95
9. NOx (hot) read/3% O ₂ (ppm)*	154		112		114		136		136	
10. NO (hot) read/3% O ₂ (ppm)*	154		112		114		136		134	
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0		0		0		0		2	
12. NO (cold) read/3% O ₂ (ppm)*	166	163	125	125	130	127	152	151	164	164
13. Carbon Dioxide (%)	10		12.6		12.6		12.6		12.6	
14. Carbon Monoxide (ppm) uncor/cor*										
15. Hydrocarbon (ppm) uncor/cor*										
16. Sulfur Dioxide (ppm) uncor/cor*										
17. Smoke Spot (Baeharach) NUMBER	0		1		0		0		0	
18. Atmos. Temp. (°F/°C) DRY/WET	53	52	60.5	55	67	57	76	69	75	58
19. Dew Point Temp. (°F/°C)										
20. Atmos. Pressure (in. Hg)	30.24		30.24		30.24		30.24		30.23	
21. Relative Humidity (%)										
22. STACK O ₂	6.9		7.0		6.8		7.0		6.95	
23. STACK NO	129	165	95	122	103	131	118	152	126	161
24. CO ^{COLD LINE/HOT LINE}	8	6	18	16	8	11	6	4	7	8
25. STACK CO	4		16		7		4		3	
26. CO ₂ ^{COLD LINE/HOT LINE}	10	10	12.6	12.6	12.6	12.6	12.6	12.6	12.6	12.6
27. STACK CO ₂	7.6		9.8		9.8		9.8		10	
28. PORTS OPEN			SCA PORTS 14+15		SCA PORTS 12+13		SCA PORTS 10+11		SCA PORTS 8+9	
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 6/3/76 Location 38 Engr. _____

Unit No. _____ Fuel GAS Capacity 45 k#/hr

Unit Type C.E. VERTICAL Burner Type RING

1. Test No.	204-5	204-6	2006-4		
2. Date					
3. Time					
4. Load					
5. Process Rate					
6. Flue Diam. or Size, ft					
7. Probe Position					
8. Oxygen (%) COLD LINE/HOT LINE	2.75	2.75	2.7	2.7	2.8
9. NOx (hot) read/3% O ₂ (ppm)*	108			136	
10. NO (hot) read/3% O ₂ (ppm)*	107			136	
11. NO ₂ (hot) read/3% O ₂ (ppm)*	1			0	
12. NO (cold) read/3% O ₂ (ppm)*	134	132	144	142	179
13. Carbon Dioxide (%)	12.6	10	10		
14. Carbon Monoxide (ppm) uncor/cor*					
15. Hydrocarbon (ppm) uncor/cor					
16. Sulfur Dioxide (ppm) uncor/cor*					
17. Smoke Spot (Bacharach)					
18. Atmos. Temp. (°F/°C) DRY/WET	69	62	69	62	
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)	30.23	30.23			
21. Relative Humidity (%)					
22. STACK O ₂	6.75	6.75	6.7		
23. STACK NO	103	130	110	139	138
24. CO COLD LINE/HOT LINE	11	12	26	6	6
25. STACK CO	10	35	5		
26. CO ₂ COLD LINE/HOT LINE	12.6	12.6	10	10	10
27. STACK CO ₂	10	7.4	7.6		
28. PORTS OPEN	SCA 6+7	SCA 12+13	BASELINE		
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 6-4-76 Location 38 Engr. _____
 Unit No. _____ Fuel GAS Capacity 45 k#/hr
 Unit type C.E. VERTICAL Burner Type _____

1. Test No.	200-6-5		201-6-7		201-6-8		204-7		204-8	
2. Date										
3. Time										
4. Load #/hr	41,000		40,500		40,000		39,500		39,500	
5. Process Rate										
6. Flue Diam. or Size, ft										
7. Probe Position										
8. Oxygen (%) COLD LINE/HEATED LINE	2.3	2.3	2.78	2.53	3.4	3.35	2.7	2.7	2.95	3.00
9. NO _x (hot) read/3% O ₂ (ppm)*	148	172	156	181	142	172	110	129	109	130
10. NO (hot) read/3% O ₂ (ppm)*	148	172	148	172	146	176	108	126	106	126
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	8	9	0	0	2	3	3	4
12. NO (cold) read/3% O ₂ (ppm)*	184	177	186	184	176	180	134	132	140	140
13. Carbon Dioxide (%)	10.5		10.5		10.0		10.25		10.00	
14. Carbon Monoxide (ppm) uncor/cor*										
15. Hydrocarbon (ppm) uncor/cor*										
16. Sulfur Dioxide (ppm) uncor/cor*										
17. Smoke Spot (Bacharach) NUMBER	1									
18. Atmos. Temp. (°F/°C)	62.5		64		66		75		75	
19. Dew Point Temp. (°F/°C)	53.5		55		57		60		60	
20. Atmos. Pressure (in. Hg)	30.37		30.37		30.37		30.37		30.37	
21. Relative Humidity (%)										
22. STACK O ₂	6.5		6.9		7.2		6.9		7.0	
23. NO (ROOF) / CORR.	142	176	144	184	137	179	106	135	108	139
24. CO COLD LINE/HOT LINE	3	5	5	6	6	8	6	6	22	22
25. CO (ROOF LINE)	3		3		6		4		22	
26. CO ₂ COLD LINE/HOT LINE	10.5	10.5	10.5	10.5	10.0	10.0	10.25	10.25	10.00	10.00
27. CO ₂ (ROOF LINE)	8.0		8.0		7.4		7.6		7.6	
28. WATER CONTENT (% VOL)	16.4		16.2		15.5		16.1		15.8	
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 6/7 Location 38 Engr. W. NAZIMOWITZ
 Unit No. _____ Fuel GAS Capacity _____
 Unit Type C.E. VERTICAL Burner Type _____

1. Test No.	200-6-6		204-9		204-10		204-11		204-12	
2. Date										
3. Time										
4. Load (#/hr)	39K		39K		39K		39K		38.5K	
5. Process Rate										
6. Flue Diam. or Size, ft										
7. Probe Position										
8. Oxygen (%) COLD LINE/HOT LINE	2.3	2.3	2.25		2.5	2.6	2.4	2.45	2.35	2.35
9. NOx (hot) read/3% O ₂ (ppm)*	152	175			94	110	111	129	94	109
10. NO (hot) read/3% O ₂ (ppm)*	152	175			92	107	111	129	93	108
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0			2	3	0	0	1	1
12. NO (cold) read/3% O ₂ (ppm)*	170	164	114	111	114	111	141	137	118	114
13. Carbon Dioxide (%)	10.5		10.5		10.25		10.0		10.0	
14. Carbon Monoxide (ppm) uncor/cor*										
15. Hydrocarbon (ppm) uncor/cor*					8		4		8	
16. Sulfur Dioxide (ppm) uncor/cor*										
17. Smoke Spot (Dacharach) NUMBER					0		0		0	
18. Atmos. Temp. (°F/°C)	63.5		69		69		78		81	
19. Dew Point Temp. (°F/°C)	61.0		63		63		68		68	
20. Atmos. Pressure (in. Hg)	30.00						29.90		29.90	
21. Relative Humidity (%)										
22. STACK O ₂	6.45		6.4		6.6		6.5		6.5	
23. WATER CONTENT (% VOL.)	16.4				16.1		16.3		16.4	
24. NO (ROOF) /CORR	131	179	88	109	88	110	111	138	94	117
25. CO COLD LINE/HOT LINE	35	12	122		58	42	11	10	6	6
26. CO ROOF LINE	6		100		55		8		5	
27. CO ₂ COLD LINE/HOT LINE	10.5	10.5	10.5	10.5	10.25	10.00	10.0	10.0	10.0	10.0
28. CO ₂ ROOF LINE	7.8		7.8		7.8		7.8		7.8	
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. 204 Date 1-17-78 Location 38 Engr. W.N. + R.P.Unit No. _____ Fuel GAS Capacity _____Unit Type C.E. VERTICAL Burner Type RING

1. Test No.	204-13		204-14		204-15		204-16		204-17	
2. Date										
3. Time										
4. Load #/hr	39 K		39 K		39 K		38500		38500	
5. Process Rate										
6. Flue Diam. or Size, ft										
7. Probe Position										
8. Oxygen (%) COLD LINE/HOT LINE	1.7	1.7	1.25	1.45	4.1	4.15	3.0	3.0	1.9	1.95
9. NOx (hot) read/3% O ₂ (ppm)*	105	118	116	129	105	132	106	126	92	105
10. NO (hot) read/3% O ₂ (ppm)*	104	117	116	129	103	129	106	126	94	107
11. NO ₂ (hot) read/3% O ₂ (ppm)*	1	1	0	0	2	3	0	0	0	0
12. NO (cold) read/3% O ₂ (ppm)*	135	126	145	132	129	137	128	128	116	109
13. Carbon Dioxide (%)	10.5		11.0		9.1		9.75		10.5	
14. Carbon Monoxide (ppm) uncor/cor*										
15. Hydrocarbon (ppm) uncor/cor*	7		7		2		3		3	
16. Sulfur Dioxide (ppm) uncor/cor*										
17. Smoke Spot (Bacharach) NUMBER	0		0		0		0		0	
18. Atmos. Temp. (°F/°C)	83		83						79	
19. Dew Point Temp. (°F/°C)	68		68						69	
20. Atmos. Pressure (in. Hg)	29.9		29.9						29.9	
21. Relative Humidity (%)										
22. STACK	6.0		5.7		7.8		6.95		6.25	
23. WATER CONTENT (% VOL)	16.9		17.2		14.8		15.8		16.8	
24. NO (ROOF) / CORR.	104	124	112	132	101	138	100	128	92	112
25. CO COLD LINE/HOT LINE	39	29	216	58	6	6	5	6	66	66
26. CO ROOF LINE	39		49		3		3		39	
27. CO ₂ COLD LINE/HOT LINE	10.5	10.5	11.0	11.0	9.1	9.1	9.75	9.75	10.5	10.5
28. CO ₂ ROOF LINE	8.3		8.3		7.1		7.4		8.0	
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 6-8-76 Location 38 Engr. W. V. ZIMMERMANUnit No. _____ Fuel GAS Capacity _____Unit Type C.E. VERTICAL Burner Type _____

1. Test No.	205-1		205-2		205-3		205-4		205-5	
2. Date										
3. Time										
4. Load #/hr	40,000		40,000		40,000		40,000		40,000	
5. Process Rate										
6. Flue Diam. or Size, ft										
7. Probe Position										
8. Oxygen (%) COLD LINE/HOT LINE	2.25	2.55	2.2	2.25	2.45	2.45	2.2	2.15	2.55	
9. NOx (hot) read/3% O ₂ (ppm)*	151	175	157	181	165	191	103	117		
10. NO (hot) read/3% O ₂ (ppm)*	149	173	156	180	165	191	102	116		
11. NO ₂ (hot) read/3% O ₂ (ppm)*	2	2	1	1	0	0	1	1		
12. NO (cold) read/3% O ₂ (ppm)*	190	185	205	196	205	199	127	122	122	119
13. Carbon Dioxide (%)	10.75		10.5		10.5		10.5			
14. Carbon Monoxide (ppm) uncor/cor*										
15. Hydrocarbon (ppm) uncor/cor*	5		4		4		2			
16. Sulfur Dioxide (ppm) uncor/cor*										
17. Smoke Spot (Bacharach) NUMBER	0		1				1			
18. Atmos. Temp. (°F/°C)	74				83		86			
19. Dew Point Temp. (°F/°C)	66				66		70			
20. Atmos. Pressure (in. Hg)	30.02				30.00		29.95			
21. Relative Humidity (%)										
22. STACK O ₂ %	6.55		6.25		6.35		6.05		6.2	
23. WATER CONTENT (% VOL.)	16.2		16.5		16.3		16.5			
24. NO (ROOF) / CORR.	149	186	159	194	160	197	98	118	96	117
25. CO COLD LINE/HOT LINE	11	11	10	10	12	12	10	8	6	
26. CO ROOF LINE	10		10		11		8		6	
27. CO ₂ COLD LINE/HOT LINE	10.75	10.75	10.5	10.5	10.5	10.5	10.5	10.5	10.5	
28. CO ₂ ROOF LINE	8.3		8.0		8.0		8.3		8.3	
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 6/8, 6/9 Location 38 Engr. W. NAZIMOWITZUnit No. _____ Fuel GAS Capacity _____Unit Type CE VERTICAL Burner Type _____

6/9

1. Test No.	205-6	205-7	205/4-8	2006-8	2006-9
2. Date					
3. Time					
4. Load (#/hr)	40,500	39,500	38,500	40,000	40,300
5. Process Rate					
6. Flue Diam. or Size, ft					
7. Probe Position					
8. Oxygen (%) COLD LINE/HOT LINE	1.7 1.7	2.35 2.25	2.4 2.4	2.3 2.35	2.35 2.45
9. NOx (hot) read/3% O ₂ (ppm)*	104 117	117 134	88 102	152 176	126 146
10. NO (hot) read/3% O ₂ (ppm)*	104 117	119 137	88 102	152 176	126 146
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0 0	0 0	0 0	0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	125 117	154 149	108 105	170 164	144 139
13. Carbon Dioxide (%)	10.75	10.5	10.5	10.5	10.5
14. Carbon Monoxide (ppm) uncor/cor*					
15. Hydrocarbon (ppm) uncor/cor*					
16. Sulfur Dioxide (ppm) uncor/cor*					
17. Smoke Spot (Baeharach) NUMBER	1				
18. Atmos. Temp. (°F/°C)		86		66	69
19. Dew Point Temp. (°F/°C)		70		63	64
20. Atmos. Pressure (in. Hg)	29.94	29.89	29.87	29.97	29.99
21. Relative Humidity (%)					
22. STACK O ₂ %	5.55	6.4	6.5	6.45	6.5
23. WATER CONTENT (% VOL)	16.9	16.5	16.4	16.4	16.3
24. NO (ROOF) / CORR.	98 114	118 146	84 104	130 161	110 137
25. CO COLD LINE/HOT LINE	16 6	6 5	5 5	19 19	19 20
26. CO ROOF LINE	3	4	2	12	12
27. CO ₂ COLD LINE/HOT LINE	10.75 10.75	10.5 10.5	10.5 10.5	10.5 10.5	10.5 10.5
28. CO ₂ ROOF LINE	8.3	7.8	8.0	7.8	7.8
29.			VPH +	BASELINE	VARIABLE REGISTER
30.			SCA 647		FULL OPEN

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 6/9/76 Location 38 Engr. W. NAZIMCHWITZUnit No. _____ Fuel GAS Capacity _____Unit Type CE VERTICAL Burner Type _____

1. Test No.	200G-10	200G-11	200G-12	200G-13	200G-14
2. Date					
3. Time					
4. Load (k#/hr)	38.0	39.5	40.5	40.7	40.7
5. Process Rate					
6. Flue Diam. or Size, ft					
7. Probe Position					
8. Oxygen (%) COLD LINE/HOT LINE	1.0	1.35	2.5	1.55	1.8 1.8
9. NOx (hot) read/3% O ₂ (ppm)*					160 180
10. NO (hot) read/3% O ₂ (ppm)*					160 180
11. NO ₂ (hot) read/3% O ₂ (ppm)*					0 0
12. NO (cold) read/3% O ₂ (ppm)*	110 99	126 115	186 181	178 165	205 192
13. Carbon Dioxide (%)	9.7	10.5	10.25	10.75	10.75
14. Carbon Monoxide (ppm) uncor/cor*	2000	2000	29	250	
15. Hydrocarbon (ppm) uncor/cor*	8	6	6	8	
16. Sulfur Dioxide (ppm) uncor/cor*					
17. Smoke Spot (Bacharach)					
18. Atmos. Temp. (°F/°C)					
19. Dew Point Temp. (°F/°C)					
20. Atmos. Pressure (in. Hg)		29.99		29.99	29.99
21. Relative Humidity (%)					
22. STACK O ₂ %					6.25
23. WATER CONTENT (% VOL.)					16.8
24. NO (ROOF) / CORR.					157 192
25. CO COLD LINE/HOT LINE	2000	2000	29	250	26 28
26. CO ROOF LINE					28
27. CO ₂ COLD LINE/HOT LINE	9.7	10.5	10.25	10.75	10.75 10.75
28. CO ₂ ROOF LINE					8.0
29.	VR low	VR low			
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 6/9 Location 38 Engr. W. NAZIMOWITZUnit No. _____ Fuel GAS Capacity 45 k#/hrUnit Type CE VERTICAL Burner Type _____

1. Test No.	200G-15		200G-16		204-18		204-19		204-20	
2. Date										
3. Time										
4. Load (k#/hr)	40.5		40.5		40.0		39.8		40.0	
5. Process Rate										
6. Flue Diam. or Size, ft										
7. Probe Position										
8. Oxygen (%) COLD LINE / HEATED LINE	2.35	2.45	2.4	2.4	2.25	2.35	3.45	3.55	2.8	2.85
9. NOx (hot) read/3% O ₂ (ppm)*	178	207	152	176	88	102	112	137	96	113
10. NO (hot) read/3% O ₂ (ppm)*	180	209	157	182	88	102	112	137	96	113
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0	0	0	0	0	0	0	0	0
12. NO (cold) read/3% O ₂ (ppm)*	212	205	198	192	107	103	140	144	120	119
13. Carbon Dioxide (%)	10.5		10.5		10.5		9.75		10.25	
14. Carbon Monoxide (ppm) uncor/cor*										
15. Hydrocarbon (ppm) uncor/cor*	5		4		2		2		3	
16. Sulfur Dioxide (ppm) uncor/cor*										
17. Smoke Spot (Bacharach)										
18. Atmos. Temp. (°F/°C)	79		87		80		81		83	
19. Dew Point Temp. (°F/°C)	68		70		71		70		70	
20. Atmos. Pressure (in. Hg)	29.98		29.96		29.93		29.93		29.92	
21. Relative Humidity (%)										
22. STACK O ₂ %	6.75		6.7		6.4		7.35		6.8	
23. WATER CONTENT (% VOL.)	16.3		16.4		16.4		15.3		15.9	
24. NO (ROOF) / CORR.	165	208	150	189	80	99	109	144	92	117
25. CO COLD LINE / HOT LINE	19	26	10	10	286	200	12	12	29	29
26. CO ROOF LINE	16		6		200		10		26	
27. CO ₂ COLD LINE / HOT LINE	10.5	10.25	10.5	10.5	10.5	10.5	9.75	9.75	10.25	10.25
28. CO ₂ ROOF LINE	8.0		7.8		8.0		7.4		7.8	
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 6/10 Location 38 Engr. W. NAZIM

Unit No. _____ Fuel GAS Capacity 45 K#/hr

Unit Type CE VERTICAL Burner Type _____

1. Test No.	200G-17		200G-17A		200G-17B		200G-17C		200G-17D	
2. Date										
3. Time										
4. Load (K#/hr)	39.5		39.5		39.5		39.5		39.5	
5. Process Rate										
6. Flue Diam. or Size, ft										
7. Probe Position										
8. Oxygen (%) COLD LINE/HOT LINE	2.2	2.3	4.4		2.9		2.25		2.4	
9. NOx (hot) read/3% O ₂ (ppm)*	154	177								
10. NO (hot) read/3% O ₂ (ppm)*	154	177								
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0								
12. NO (cold) read/3% O ₂ (ppm)*	169	162	152	165	171	170	178	171	157	152
13. Carbon Dioxide (%)	10.5		8.7		10.25		10.5		10.5	
14. Carbon Monoxide (ppm) uncor/cor*			10		6		10		12	
15. Hydrocarbon (ppm) uncor/cor*	3									
16. Sulfur Dioxide (ppm) uncor/cor*										
17. Smoke Spot (Baeharach) NUMBER	1									
18. Atmos. Temp. (°F/°C)	72									
19. Dew Point Temp. (°F/°C)	69									
20. Atmos. Pressure (in. Hg)	30.07									
21. Relative Humidity (%)										
22. STACK O ₂ %	6.5		6.45							
23. WATER CONTENT (% VOL)	16.45									
24. NO (ROOF)/CORR.	130	162	135	167						
25. CO COLD LINE/HOT LINE	12	10	10		6		10		12	
26. CO ROOF LINE	10		6							
27. CO ₂ COLD LINE/HOT LINE	10.5	10.5	8.7		10.25		10.25		10.5	
28. CO ₂ ROOF LINE	8.0		8.0							
29.										
30.										

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 6/10 Location 38 Engr. W. NAZIMOWITZUnit No. _____ Fuel GAS Capacity 45 k#/hrUnit Type CE VERTICAL Burner Type _____

BASELINE

1. Test No.	2006-17E	204-21	204-22	204/5-23	204/5-24
2. Date					
3. Time					
4. Load (k#/hr)	39.5	39.6	39.6	39.0	39.0
5. Process Rate					
6. Flue Diam. or Size, ft					
7. Probe Position					
8. Oxygen (%) COLD LINE/HOT LINE	3.2	2.83 2.85	2.75 2.9	2.45 2.5	2.45
9. NOx (hot) read/3% O ₂ (ppm)*		93 110	110 131	68 79	
10. NO (hot) read/3% O ₂ (ppm)*		92 108	109 130	68 79	
11. NO ₂ (hot) read/3% O ₂ (ppm)*		1 2	1 1	0 0	
12. NO (cold) read/3% O ₂ (ppm)*	151 153	108 107	128 126	83 81	76 74
13. Carbon Dioxide (%)	10.5	10.25	10.00	10.25	10.25
14. Carbon Monoxide (ppm) uncor/cor*					
15. Hydrocarbon (ppm) uncor/cor*					
16. Sulfur Dioxide (ppm) uncor/cor*					
17. Smoke Spot (Bacharach)					
18. Atmos. Temp. (°F/°C)	78	82.5	87	90.5	92
19. Dew Point Temp. (°F/°C)	69	71.5	72.5	71.5	71
20. Atmos. Pressure (in. Hg)	30.05	30.00	29.99	29.94	29.90
21. Relative Humidity (%)					
22. STACK O ₂ %	6.5	6.85	6.9	6.45	6.5
23. WATER CONTENT (% VOL.)		16	15.9	16.3	
24. NO (ROOF) /CORR.	140 174	82 104	98 125	64 79	60 75
25. CO COLD LINE/HOT LINE	12	35 32	29 32	166 137/232	18
26. CO ROOF LINE	6	46	<92>	470	72
27. CO ₂ COLD LINE/HOT LINE	10.5	10.25 10.25	10.0 10.0	10.25 10.25	10.25
28. CO ₂ ROOF LINE	8.0	7.8	7.6	8.00	7.8
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 6/10 Location 38 Engr. W. NAZIMOWITZ
 Unit No. _____ Fuel GAS Capacity 45 k#/hr
 Unit Type CE VERTICAL Burner Type _____

1. Test No.	204/5-25	204/5-26	204/5-27	204/5-28	204/5-29
2. Date					
3. Time					
4. Load (k#/hr)	39.0	39.4	39.0	39.0	39.0
5. Process Rate					
6. Flue Diam. or Size, ft					
7. Probe Position					
8. Oxygen (%) COLD LINE/HOT LINE	2.6	2.55	2.52	2.3 2.4	2.3
9. NOx (hot) read/3% O ₂ (ppm)*				42 49	
10. NO (hot) read/3% O ₂ (ppm)*				42 49	
11. NO ₂ (hot) read/3% O ₂ (ppm)*				0 0	
12. NO (cold) read/3% O ₂ (ppm)*	76 74	48 47	49 48	52 50	58 56
13. Carbon Dioxide (%)	10.0	10.0	10.0	10.0	10.25
14. Carbon Monoxide (ppm) uncor/cor*					
15. Hydrocarbon (ppm) uncor/cor*	4	4	4	3	
16. Sulfur Dioxide (ppm) uncor/cor*					
17. Smoke Spot (Bacharach) NUMBER	1				
18. Atmos. Temp. (°F/°C)	90	86	84	79.5	79
19. Dew Point Temp. (°F/°C)	71	71	70	68	67
20. Atmos. Pressure (in. Hg)	29.89	29.89	29.88	29.88	29.88
21. Relative Humidity (%)					
22. STACK O ₂ %	6.55	6.15	6.35	6.25	6.35
23. WATER CONTENT (% VOL.)				16.4	
24. NO (ROOF) /CORR.	61 76	38 46	37 46	40 49	44 54
25. CO COLD LINE/HOT LINE	39	810	910/1250	49/12 58	26
26. CO ROOF LINE	49	470	550/730	100/174	26/35
27. CO ₂ COLD LINE/HOT LINE	10.0	10.0	10.0	10.0 10.25	10.25
28. CO ₂ ROOF LINE	7.8	8.0	8.0	8.0	8.0
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 6/11/76 Location 38 Engr. W. NAZIMOWITZUnit No. _____ Fuel GAS Capacity 45 k# / hrUnit Type CE VERTICAL Burner Type _____

	204/5-30	204/5-31	204/5-32	2006-18	2006-19
1. Test No.					
2. Date					
3. Time					
4. Load (k# / hr)	39.0	39.0	39.0	39.5	39.5
5. Process Rate					
6. Flue Diam. or Size, ft					
7. Probe Position					
8. Oxygen (%) COLD / HEATED	2.25	2.0	1.9	2.05 2.1	1.98 1.98
9. NOx (hot) read/3% O ₂ (ppm)*				145 166	118 135
10. NO (hot) read/3% O ₂ (ppm)*				145 166	118 135
11. NO ₂ (hot) read/3% O ₂ (ppm)*				0 0	0 0
12. NO (cold) read/3% O ₂ (ppm)*	49 47	52 49	68 64	164 156	138 131
13. Carbon Dioxide (%)	10.25	10.5	10.5	10.5	10.5
14. Carbon Monoxide (ppm) uncor/cor*	58 56				
15. Hydrocarbon (ppm) uncor/cor*					
16. Sulfur Dioxide (ppm) uncor/cor*					
17. Smoke Spot (Bacharach) NUMBER				1	
18. Atmos. Temp. (°F/°C)				74	77.5
19. Dew Point Temp. (°F/°C)				68.5	69.0
20. Atmos. Pressure (in. Hg)				29.78	29.77
21. Relative Humidity (%)					
22. STACK O ₂ %		6.15	6.18	6.5	6.35
23. NO (ROOF) / CORR.	47 45	42 51	54 66	126 156	104 128
24. CO COLD LINE / HOT LINE	58 56	106 / 152	450	16 12	
25. CO ROOF LINE		66 / 137	160	10	
26. CO ₂ COLD LINE / HOT LINE	10.25	10.5	10.5	10.5 10.5	
27. CO ₂ ROOF LINE		8.0	8.0	7.8	
28.					
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

MOBILE LABORATORY DATA

Test No. _____

Test No. _____ Date 6/11/76 Location 38 Engr. W. NAZIMOWITZ
 Unit No. _____ Fuel GAS Capacity 45 k#/hr
 Unit Type CE VERTICAL Burner Type _____

1. Test No.	2006-20	2006-21	2006-22	2006-23	
2. Date					
3. Time					
4. Load (k#/hr)	39.5				
5. Process Rate					
6. Flue Diam. or Size, ft					
7. Probe Position					
8. Oxygen (%) COLD/HEATED	2.8	2.85	4.05	—	2.4 — 1.8 —
9. NO _x (hot) read/3% O ₂ (ppm)*	110	130			
10. NO (hot) read/3% O ₂ (ppm)*	110	130			
11. NO ₂ (hot) read/3% O ₂ (ppm)*	0	0			
12. NO (cold) read/3% O ₂ (ppm)*	137	136	132	140	152 147 152 143
13. Carbon Dioxide (%)	10.0				
14. Carbon Monoxide (ppm) uncor/cor*					
15. Hydrocarbon (ppm) uncor/cor*	4				
16. Sulfur Dioxide (ppm) uncor/cor*					
17. Smoke Spot (Bacharach)					
18. Atmos. Temp. (°F/°C)	81	83	83	84	
19. Dew Point WET BULB Temp. (°F/°C)	69	70	70	70	
20. Atmos. Pressure (in. Hg)	29.75	29.73	29.73	29.73	
21. Relative Humidity (%)					
22. STACK O ₂ %	6.95	7.8	6.6	6.2	
23. WATER CONTENT (% Vol.)	16.0				
24. NO (ROOF) /CORR.	107	137	103	141	118 148 116 141
25. CO COLD LINE/HOT LINE	10	10	6	6	232
26. CO ROOF LINE	6	3	6	470	
27. CO ₂ COLD LINE/HOT LINE	10.0	10.0			
28. CO ₂ ROOF LINE	7.6				
29.					
30.					

*Correction to 3% O₂ should not be performed if the value is measured on a wet basis.

Data Sheet 6002-2

KVB

Test No. _____

Engr. _____

CONTROL ROOM DATA

Test Number 202+203 Date 5/19/76 - 5/20/76

Unit Number _____ Owner _____

Fuel #6 Location 38

Capacity (K#/hr) 45

Furnace Type _____ Burner Type _____ 5/20/76

	TIME OF DAY EDT										1100		1530		1100			
1. Test Number	202-3		200-22		203-26A		203-26B		203-27A									
2. Load (K#/hr)	35-34		38		38		39		38									
3. Control Method Auto/Hand	LOW PREHEAT		TODAY'S		SCA SO ₂ + PARTICULATE		PARTIC.		SCA SO ₂ + PARTICULATE									
4. Staged Air Port Open	BURNER FULLY OPEN		BASELINE		14 + 15				14 + 15									
5. STACK O ₂	129%		—		15% THRU SCA				7.1									
6. Oxygen/Air Level (%) FURN. EXIT NOT COLO	2.6	2.6	—	3.4	3.5	3.5	3.1	3.2		3.3								
7. LOW-DRAWN Pressure (psig)	133		—		139													
8. Final Steam Press/Temp (psig/°F)	140	—	—		142		—											
9. Fuel-Air Ratio Setting OIL LOADING	45	57	38	77	38	64	36	65	38	65								
10. Feedwater Press/Temp (psig/°F)	—	260	—			267	—											
11. Air Flow Primary/Secondary()	—		—		—													
12. Air Temp Primary/Secondary (°F)	—		—		—													
13. Fan Setting FD/ID	62	84	65	77	50	77	53	77	54	80								
14. Register Setting (%open C.C.)	—		—		—		—		—									
15. Fuel Flow (lb/hr) * GAL/MIN	5.90		6.0		5.9		5.9		5.83									
16. Fuel Press/Temp (psig/°F)	90	218	90	220	91	220	90	220	91	220								
17. Fuel Atomization Press (psig)	112		112		114		115		114									
18. Pressure Furnace/Windbox (iwg)	-.2	1.3	-.2	1.7	-.2	1.15	-.18	1.1	-.20	1.2								
19. Smoke Meter SPOT	8		—		7		—		7									
20. Stack Temp. (°F)	518		—		424		426		427									
21. Boiler Outlet Press (iwg)	-.73		-.70		-.7		-.7		-.8									
22. Boiler Outlet Temp. (°F)	635		—		630		640		635									
23. ^{FA FLOW} Air Heater Inlet Temp. (°F)	80	252	—		86	—	92	—	92	—								
24. Air Heater Outlet Temp. (°F) / IWG		-1.8		-1.8	—	-1.9		-1.8		-1.9								
25. Windbox Temperature (°F)	1	2	3	120	125	124	225	275	190	300	296	210	315	—	230	305	—	220
26.	4	5	WGB	130	140	128	290	295		340	—		330	—		320	—	
27. MASTER	83		32		28		27		42									
28. NO FURNACE EXIT (COLO) PPM	225	220							ANALYZER BROKEN DOWN									

*Fuel flow in lb/hr needed for efficiency calculation.

*BOILER TEMP. - COOLERS READOUT

4/76
60-33

KVB

Test No. _____

 Engr. W.N.

CONTROL ROOM DATA

 Test Number _____ Date 5/24/76

Unit Number _____ Owner _____

 Fuel NO. 6 Location 38

 Capacity (K#/hr) 45

 Furnace Type CE VERTICAL Burner Type _____

	5/24/76	5/24/76	5/25/76	5/25/76	5/25/76
1. Test Number	200-23		200-24	200-25	201-12
2. Load (K#/hr)	38		38	38.2	38.8
3. Control Method Auto/Hand	HAND		✓	✓	✓
4. Staged Air Port Open	NONE		✓	✓	✓
5.	BASLINE PARTIC. + SPK		BASLINE HYDRACTOR	BASLINE	LOW O ₂
6. Oxygen/Air Level (%)					
7. LINE Steam Pressure (psig)	139		139	138	137
8. Final Steam Press/Temp (psig/°F)	146		147	145	145
9. Fuel-Air Ratio Setting /OIL LOAD	30/84	✓	✓	34/78	34/72
10. Feedwater Press/Temp (psig/°F)	272		278	274	275
11. Air Flow Primary/Secondary ()					
12. Air Temp Primary/Secondary (°F)	86		84	74	76
13. Fan Setting FD/ID	64 76		64 76	62 75	57 64
14. Register Setting (%open C.C.)	100%		100%	100%	100%
15. Fuel Flow (lb/hr)*	5.8		5.8	5.9	5.9
16. Fuel Press/Temp (psig/°F)	91 218		91 218	92 217	91 217
17. Fuel Atomization Press (psig)	115		115	115	115
18. Pressure Furnace/Windbox (iwg)	-0.2 1.6		-0.2 1.6	-0.2 1.5	-1.9 1.35
19. Smoke Meter	3 ^Δ		4 ^Δ	3 ^Δ	7
20. Stack Temp. (°F)	430*		442*	437	427
21. Boiler Outlet Press (iwg)	-.75		-.75	-.76	-.65
22. Boiler Outlet Temp. (°F)	650		650	645	630
23. Air Heater Inlet Temp. (°F)					
24. Air Heater Outlet Temp. (°F) / 1mg	1/-1.8		1/-1.8	1/-1.85	1/-1.6
25. Windbox Temperature (°F) 1/4	283/298		281/298	272/290	275/292
26.					
27. MASTER CONTROL	18		26	40	40
28.					

*Fuel flow in lb/hr needed for efficiency calculation.
 *HARD TO READ. NO AMBER LIGHT. I 5-10 DEG.

Δ GREENISH

 4/76
 60-33

KVB

Test No. _____

Engr. W.N.

CONTROL ROOM DATA

Test Number 202,200,201 Date 5/25/75, 5/26/75

Unit Number _____ Owner _____

Fuel NO. 6 Location _____Capacity (K#/hr) 45Furnace Type CE VERTICAL Burner Type PEABODY STAN. ATOM.

	1450	1500	5/26		
1. Test Number	202-4	202-4A	200-26	201-13	201-14
2. Load (K#/hr)	34.0	34	38.5	38.5	39.0
3. Control Method Auto/Hand	HAND	✓	HAND	✓	✓
4. Staged Air Port Open	NONE	✓	NONE	✓	✓
5.	LOW TEMP.	✓	BASELINE	LOW O ₂	LOW O ₂
6. Oxygen/Air Level (%)	MAX BYPASS			IMPACTOR	SO ₂
7. ⁽¹⁰⁰⁾ Drum Pressure (psig)		138	137	137	137
8. Final Steam Press/Temp (psig/°F)		145	145	145	145
9. Fuel-Air Ratio Setting	34/68	✓ ✓		28/78	28/80
10. Feedwater Press/Temp (psig/°F)		278	275	275	276
11. Air Flow Primary/Secondary ()					
12. Air Temp Primary/Secondary (°F)		76	77	80	81
13. Fan Setting FD/ID	68 80	61 84	60 72	56 61	58 66
14. Register Setting (%open C.C.)	100%	100%	100%	100%	100%
15. Fuel Flow (lb/hr)*		5.85		5.9	5.85
16. Fuel Press/Temp (psig/°F)	92 216	92 216	92 216	90 217	92 218
17. Fuel Atomization Press (psig)	115	115	115	114	115
18. Pressure Furnace/Windbox (iwg)	-0.03 1.55	-0.2 1.2	-0.2 1.4	-0.2 1.2	-0.2 1.35
19. Smoke Meter	3	4		6	6
20. Stack Temp. (°F)	550	550		430	430
21. Boiler Outlet Press (iwg)		-0.75		-0.7	-0.65
22. Boiler Outlet Temp. (°F)	650	650	635	630	640
23. Air Heater Inlet Temp. (°F)					
24. Air Heater Outlet Temp. (°F)		-1.85		-1.7	-1.7
25. Windbox Temperature (°F)	1/4	120/130		270/287	280/295
26.					
27. BOILER MASTER	32	32		46	32
28.					

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____

Engr. W.N.

CONTROL ROOM DATA

Test Number 202, 200, 201, 203 Date 5/26/76, 5/27/76

Unit Number _____ Owner _____

Fuel NO. 6 Location 38Capacity (K#/hr) 45Furnace Type CE VERTICAL Burner Type PEABODY - STAN, ATOM.5/26 5/27

1. Test Number	202-5	200-27	201-15	203-28	
2. Load (K#/hr)	34.0	38.0	38.8	38.5	
3. Control Method Auto/Hand	HAND	HAND	✓	✓	
4. Staged Air Port Open	NONE	NONE	✓	14 + 15	
5.	VPH LOW TEMP	BASELINE	LOW O2		
6. Oxygen/Air Level (%)	IMPACTOR + 50x		METHOD 5 PARTIC.	IMPACTOR	
7. ^{LINE} Drum Pressure (psig)	138	137	137	138	
8. Final Steam Press/Temp (psig/°F)	145	144	145	145	
9. Fuel-Air Ratio Setting /OIL LOADER	28/76	37/71	—	—	
10. Feedwater Press/Temp (psig/°F)	277	273	275	277	
11. Air Flow Primary/Secondary ()					
12. Air Temp Primary/Secondary (°F)	82	76	80 to 85	89 to 90	
13. Fan Setting FD/ID	62 84	60 71	58 66	50 80	
14. Register Setting (%open C.C.)	100%	100%	100%	100%	
15. Fuel Flow (lb/hr)*	5.8 +			5.98	
16. Fuel Press/Temp (psig/°F)	92 217	92 218	92 218	91 218	
17. Fuel Atomization Press (psig)	115	115	115	115	
18. Pressure Furnace/Windbox (iwg)	-0.2 1.2	-0.2 1.5	-0.2 1.35	-0.2 1.1	
19. Smoke Meter	3	4			
20. Stack Temp. (°F)	540		430	450	
21. Boiler Outlet Press (iwg)	-.72	-.73	-.6	.8	
22. Boiler Outlet Temp. (°F)	650	638	630	650	
23. Air Heater Inlet Temp. (°F)					
24. Air Heater Outlet Temp. (°F)	-1.85	-1.8	-1.5	-2.0	
25. Windbox Temperature (°F)	1/4	272/285	276/293		
26.	1/2/4	126/127/135	280/292	313/326	
27. MASTER CONTROL	60	46			
28.					

*Fuel flow in lb/hr needed for efficiency calculation.

↓ REG IN
AND END
OF TEST

4/76
60-33

KVB

Test No. _____

Engr. W. N.

CONTROL ROOM DATA

Test Number 2006-1 Date 6/1/76

Unit Number _____ Owner _____

Fuel NATURAL GAS Location 38

Capacity (K#/hr) 45

Furnace Type C.E. VERTICAL Burner Type PEABODY - RING

6/1/76 6/2/76

1. Test Number	2006-1	2006-2	2016-1	2016-2	2016-3
2. Load (K#/hr)	41.5	40.0	40.0	40.0	39.8
3. Control Method Auto/Hand	HAND	HAND	✓	✓	✓
4. Staged Air Port Open	NONE	NONE	✓	✓	✓
5.	BASELINE	BASELINE	MAX O ₂	MID O ₂	HIGH O ₂
6. Oxygen/Air Level (%)	1.25	1.6	4.0	2.65	4.0
7. LINE Drum Pressure (psig)	138	136	137	137	137
8. Final Steam Press/Temp (psig/°F)	146	145	145	145	146
9. Fuel-Air Ratio Setting					
10. Feedwater Press/Temp (psig/°F)	270	272	272	274	275
11. Air Flow Primary/Secondary ()					
12. Air Temp Primary/Secondary (°F)	80	79	80	86	85
13. Fan Setting FD/ID	88 90	69 77	94 96	74 84	84 96
14. Register Setting (%open C.C.)	73	73	✓	✓	
15. Fuel Flow (lb/hr)*					
16. Fuel Press/Temp (psig/°F)	3.8 68	3.5 68	3.5 68	3.5 70	3.5 70
17. Fuel Atomization Press (psig)					
18. Pressure Furnace/Windbox (iwg)	-0.15 3.3	-.2 2.7	-.2 3.3	-.2 2.95	-.2 3.2
19. Smoke Meter		1	0	0	0
20. Stack Temp. (°F)		434	452	440	454
21. Boiler Outlet Press (iwg)	-.8	-.75	-.88	-.8	-.88
22. Boiler Outlet Temp. (°F)	668	650	670	660	670
23. Air Heater Inlet Temp. (°F)					
24. Air Heater Outlet Temp. (°F) Temp (°F) PRESS (iwg)	-2.05	-1.85	-2.2	-2.0	-2.2
25. Windbox Temperature (°F)	1 / 4 270/285	275/290	271/285	280/292	276/290
26.					
27. GAS SETTINGS AUTO/HAND	46/38	41/34	1/34	1/34	1/34
28. CONTROL SUPPLY PRESS PSIG	9	8.5	8.5	8.5	8.5

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____
Engr. W.N.

CONTROL ROOM DATA

Test Number 2016-4 Date 6/2/76
Unit Number _____ Owner _____
Fuel NATURAL GAS Location _____
Capacity (K#/hr) 45 K
Furnace Type C.E. VERTICAL Burner Type RING

	6/2/76 →				6/3	6/3
1. Test Number	2016-4	2016-5	2016-6	2006-3	204-1	
2. Load (K#/hr)	40.0	39.2	40.5	39.0	38.0	
3. Control Method Auto/Hand	HAND	✓	HAND	✓	✓	
4. Staged Air Port Open	NONE	✓	NONE	✓		
5.	MID O ₂	LOW O ₂	LOW O ₂	BASELINE	SCA	
6. Oxygen/Air Level (%)	2.9	1.25	1.45	2.7	2.95	
7. Drum Pressure (psig)	138	138	139	136	137	
8. Final Steam Press/Temp (psig/°F)	146	146	148	144	145	
9. Fuel-Air Ratio Setting						
10. Feedwater Press/Temp (psig/°F)	275	275	275	270	272	
11. Air Flow Primary/Secondary()						
12. Air Temp Primary/Secondary (°F)	84	86	86	64	78	
13. Fan Setting FD/ID	75 85	65 72	67 74	71 80	54 82	
14. Register Setting (%open C.C.)	73%	73	73	73	73	
15. Fuel Flow (lb/hr)*						
16. Fuel Press/Temp (psig/°F)	3.5 70	3.5 70	3.5 70	3.3 66	3.5 68	
17. Fuel Atomization Press (psig)						
18. Pressure Furnace/Windbox (iwg)	-0.2 3.0	-0.22 2.5	-0.21 2.6	-0.17 3.0	-0.2 2.2	
19. Smoke Meter	0		1	0	1	
20. Stack Temp. (°F)	—	—	432	435	444	
21. Boiler Outlet Press (iwg)	-0.8	-0.7	-0.7	-0.72	-0.79	
22. Boiler Outlet Temp. (°F)	665	640	645	650	650	
23. Air Heater Inlet Temp. (°F)						
24. Air Heater Outlet Temp. (°F) PRESS	-2.0	-1.75	-1.75	-1.9	-2.0	
25. Windbox Temperature (°F) 1 / 4	280/292	281/294	281/295	267/281	295/310	
26.						
27. GAS SETTING	34	✓	34	32	32	
28. CONTROL PRESS	8.5	✓	8.5	8.1	8.0	

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____

Engr. _____

CONTROL ROOM DATA

Test Number _____ Date 6/3/76
 Unit Number _____ Owner _____
 Fuel NATURAL GAS Location 38
 Capacity (K#/hr) 45
 Furnace Type C.E. VERTICAL Burner Type RING

1. Test Number	204-2	204-3	204-4	204-5	204-6
2. Load (K#/hr)	38.0	38.3	38.5	38.5	38.5
3. Control Method Auto/Hand	HAND	HAND	✓	✓	✓
4. Staged Air Port Open	12 + 13	10 + 11	8 + 9	6 + 7	12 + 13
5.	SCA	SCA	SCA	SCA	SCA
6. Oxygen/Air Level (%)	2.6	2.9	3.0	2.75	2.7
7. Drum Pressure (psig)	137	137	138	138	✓
8. Final Steam Press/Temp (psig/°F)	145	145	146	146	✓
9. Fuel-Air Ratio Setting					
10. Feedwater Press/Temp (psig/°F)	272	274	275	275	✓
11. Air Flow Primary/Secondary (iwg)	3.3	3.3	3.3	3.4	3.5
12. Air Temp Primary/Secondary (°F)	81	89	87	87	84
13. Fan Setting FD/ID	54 81	54 81	54 81	✓ ✓	54 83
14. Register Setting (%open C.C.)	73%				→
15. Fuel Flow (lb/hr)*					
16. Fuel Press/Temp (psig/°F)	3.3 70	3.3 73	3.3 72	3.3 72	3.3 70
17. Fuel Atomization Press (psig)					
18. Pressure Furnace/Windbox (iwg)	-.2 2.1	-.2 2.1	-.2 2.1	-.2 2.2	-.2 2.15
19. Smoke Meter	0	0	0	0	0
20. Stack Temp. (°F)	450	454	453	452	—
21. Boiler Outlet Press (iwg)	-.77	-.77	-.78	-.78	-.78
22. Boiler Outlet Temp. (°F)	665	660	662	660	668
23. Air Heater Inlet Temp. (°F)					
24. Air Heater Outlet Temp. (°F) PRESS.	-1.9	-1.9	-1.9	-1.9	-1.95
25. Windbox Temperature (°F) 1 / 4	305/316	311/324	310/326	312/328	311/325
26.					
27. GAS CONTROL SETTING/PRESS	31/8.1	32/8.1	32/8.1	✓/✓	✓/✓
28.					

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____
Engr. WN

CONTROL ROOM DATA

Test Number _____ Date 6/3/76, 6/4/76
Unit Number _____ Owner _____
Fuel NATURAL GAS Location _____
Capacity (K#/hr) 45
Furnace Type C.E. VERTICAL Burner Type RING

	6/3/76				6/4/76			
1. Test Number	2006-4				2006-5	2016-7	2016-8	
2. Load (K#/hr)	39.2				41.0	40.5	40.0	
3. Control Method Auto/Hand	HAND				HAND	HAND	HAND	
4. Staged Air Port Open	NONE				NONE	NONE	NONE	
5.	BASELINE				BASELINE	O ₂ RANGE	O ₂ RANGE	
6. Oxygen/Air Level (%)	2.7				2.3	2.8	3.4	
7. Drum Pressure (psig)	137				132.5	137	138	
8. Final Steam Press/Temp (psig/°F)	146				143	145	146	
9. Fuel-Air Ratio Setting								
10. Feedwater Press/Temp (psig/°F)	275				261	262	262	
11. Air Flow Primary/Secondary (iwg)	4.7				4.8	4.9	5.2	
12. Air Temp Primary/Secondary (°F)	82				81	82	84	
13. Fan Setting FD/ID	70	80			70	82	73	83
14. Register Setting (%open C.C.)	73%						→	
15. Fuel Flow (lb/hr)*								
16. Fuel Press/Temp (psig/°F)	3.3	69			3.5	69	3.5	70
17. Fuel Atomization Press (psig)								
18. Pressure Furnace/Windbox (iwg)	-0.2	2.9			-0.22	2.9	-0.20	3.0
19. Smoke Meter					1			
20. Stack Temp. (°F)					436	443	452	
21. Boiler Outlet Press (iwg)	-.75				-.80	-.79	-.82	
22. Boiler Outlet Temp. (°F)	650				655	660	670	
23. Air Heater Inlet Temp. (°F)								
24. Air Heater Outlet Temp. (°F) PRESS	-1.9				-1.95	-2.0	-2.2	
25. Windbox Temperature (°F) 1/4	280/296				275/290	275/290	275/294	
26.								
27. GAS SETTING/CONTROL PRESS	32/8.2				34/8.8	34/8.7	34/8.7	
28.								

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____

Engr. _____

CONTROL ROOM DATA

Test Number 204-7 Date 6-4-76
 Unit Number _____ Owner _____
 Fuel NATURAL GAS Location 38
 Capacity (K#/hr) 45
 Furnace Type C.E. VERTICAL Burner Type RING

1. Test Number	204-7	204-8							
2. Load (K#/hr)	39.5	39.5							
3. Control Method Auto/Hand	HAND	HAND							
4. Staged Air Port Open	6 + 7	4 + 15							
5.	SCA	SCA							
6. Oxygen/Air Level (%)	2.7	2.95							
7. Drum Pressure (psig)	138	138							
8. Final Steam Press/Temp (psig/°F)	145	145							
9. Fuel-Air Ratio Setting									
10. Feedwater Press/Temp (psig/°F)	266	269							
11. Air Flow Primary/Secondary (iwg)	3.5	3.7							
12. Air Temp Primary/Secondary (°F)	88	88							
13. Fan Setting FD/ID	58 85	58 85							
14. Register Setting (%open C.C.)	73	→							
15. Fuel Flow (lb/hr)*									
16. Fuel Press/Temp (psig/°F)	3.5 71	3.5 71							
17. Fuel Atomization Press (psig)									
18. Pressure Furnace/Windbox (iwg)	-0.2 2.4	-0.2 2.3							
19. Smoke Meter									
20. Stack Temp. (°F)	463	459							
21. Boiler Outlet Press (iwg)	-0.80	-0.81							
22. Boiler Outlet Temp. (°F)	667	660							
23. Air Heater Inlet Temp. (°F)									
24. Air Heater Outlet Temp. (°F) PRESS	-2.0	-2.0							
25. Windbox Temperature (°F) 1/4	305/325	305/322							
26.									
27. GAS CONTROL SETTING/PRESS.	34/8.9	34/8.8							
28.									

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____

Engr. _____

CONTROL ROOM DATA

Test Number _____ Date 6-7-76
 Unit Number _____ Owner _____
 Fuel NATURAL GAS Location 38
 Capacity (K#/hr) 45 K
 Furnace Type C.E. VERTICAL Burner Type RING

1. Test Number	2006-6	204-9	204-10	204-11	204-12
2. Load (K#/hr)	39.0	39.0	39.0	39.0	38.5
3. Control Method Auto/Hand	HAND	HAND	HAND	HAND	HAND
4. Staged Air Port Open	NONE	14+15	14+15	8+9	6+7
5.		SCA	SCA	SCA	SCA
6. Oxygen/Air Level (%)	2.3	2.25	2.5	2.4	2.35
7. ^{LINE} Drum Pressure (psig)	137	136	137	136	138
8. Final Steam Press/Temp (psig/°F)	145	145	145	145	145
9. Fuel-Air Ratio Setting					
10. Feedwater Press/Temp (psig/°F)	275	275	276	277	277
11. Air Flow Primary/Secondary () iwg	4.6	3.3	3.3	3.3	3.3
12. Air Temp Primary/Secondary (°F)	82	81	86	90	92
13. Fan Setting FD/ID	70 80	55 81	55 82	55 82	55 82
14. Register Setting (%open C.C.)	73 %				→
15. Fuel Flow (lb/hr)*					
16. Fuel Press/Temp (psig/°F)	3.5 69	3.5 68	3.5 71	3.5 72	3.5 74
17. Fuel Atomization Press (psig)					
18. Pressure Furnace/Windbox (iwg)	-0.2 2.9	-0.2 2.2	-0.2 2.2	-0.2 2.2	-0.2 2.2
19. Smoke Meter	0	0	0	0	0
20. Stack Temp. (°F)	435		450	455	459
21. Boiler Outlet Press (iwg)	-0.75	-7.5	-7.9	-7.9	-7.9
22. Boiler Outlet Temp. (°F)	650	652	654	660	660
23. Air Heater Inlet Temp. (°F)					
24. Air Heater Outlet Temp. (°F) PRESS	-1.9	-1.9	-1.95	-1.95	-1.95
25. Windbox Temperature (°F) 1 / 4	275/292	299/315	302/318	310/325	315/332
26.					
27. GAS SETTING / CONTROL PRESS.	33.5/8.5	33.5/8.5	34/8.5	34/8.5	34/8.5
28.		30.13			

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____

Engr. W.N.

CONTROL ROOM DATA

Test Number _____ Date 6-7-76

Unit Number _____ Owner _____

Fuel NATURAL GAS Location _____

Capacity (K#/hr) 45


Furnace Type CE VERTICAL Burner Type RING BURNER

6/7/76

1. Test Number	204-13	204-14	204-15	204-16	204-17
2. Load (K#/hr)	39.0	39.0	39.0	38.5	38.5
3. Control Method Auto/Hand	HAND	HAND	HAND	HAND	HAND
4. Staged Air Port Open	6+7	6+7	6+7	6+7	6+7
5.	SCA	SCA	SCA	SCA	SCA
6. Oxygen/Air Level (%)	1.7	1.25	4.1	3.0	1.9
7. Drum Pressure (psig)	138	138	138	140	141
8. Final Steam Press/Temp (psig/°F)	148	146	146	149	149
9. Fuel-Air Ratio Setting					
10. Feedwater Press/Temp (psig/°F)	276	278	279	279	279
11. Air Flow Primary/Secondary ()	3.4	3.3	4.0	3.6	3.2
12. Air Temp Primary/Secondary (°F)	94	94	94	95	94
13. Fan Setting FD/ID	55 77	55 74	66 98	59 85	54 80
14. Register Setting (%open C.C.)	73%				→
15. Fuel Flow (lb/hr)*					
16. Fuel Press/Temp (psig/°F)	3.5 74	3.5 74	3.5 74	3.5 74	3.5 74
17. Fuel Atomization Press (psig)					
18. Pressure Furnace/Windbox (iwg)	-2 2.2	-1.8 2.2	-2.0 2.65	-2.0 2.40	-2 2.2
19. Smoke Meter					
20. Stack Temp. (°F)	448	444	475		460
21. Boiler Outlet Press (iwg)	-.71	-.69	-.89	-.79	-.75
22. Boiler Outlet Temp. (°F)	645	641	670	662	655
23. Air Heater Inlet Temp. (°F)					
24. Air Heater Outlet Temp. (°F) PRESS.	-1.8	-1.75	-2.25	-2.0	-1.05
25. Windbox Temperature (°F) 1/4	310/325	306/322	310/330	315/335	319/337
26.					
27. GAS SETTING / CONTROL PRESS.	33.5/8.5	33.5/8.5	33.5/8.5	33.5/8.5	33.5/8.5
28.					

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33



KVB

Test No. _____
Engr. _____

CONTROL ROOM DATA

Test Number _____ Date 6-8-76
Unit Number _____ Owner _____
Fuel NATURAL GAS Location 38
Capacity (K#/hr) 45
Furnace Type C.E. VERTICAL Burner Type RING

6/8 51m. Preheat → Full By Pass

1. Test Number	2006-7	205-1	205-2	205-3	205-4
2. Load (K#/hr)	39.5	40.0	40.0	40.0	35.0
3. Control Method Auto/Hand	HAND	HAND	HAND	HAND	HAND
4. Staged Air Port Open	NONE	NONE	NONE	NONE	NONE
5.	BASELINE	VPH	VPH	VPH	VPH
6. Oxygen/Air Level (%)	2.55	2.25	2.2	2.45	2.2
7. ^{1/2} Drum Pressure (psig)	138	138	134.5	134.5	135
8. Final Steam Press/Temp (psig/°F)	147	145	143	143	144
9. Fuel-Air Ratio Setting					
10. Feedwater Press/Temp (psig/°F)	265	275	273	274	274
11. Air Flow Primary/Secondary ()	4.6	4.8	4.7	4.8	2.8
12. Air Temp Primary/Secondary (°F)	83	91	92	198	93
13. Fan Setting FD/ID	70	80	70	80	73
14. Register Setting (%open C.C.)	73%				
15. Fuel Flow (lb/hr)*					
16. Fuel Press/Temp (psig/°F)	3.5	69	3.4	70	3.4
17. Fuel Atomization Press (psig)					
18. Pressure Furnace/Windbox (iwg)	-2	2.9	-2	2.8	-2.2
19. Smoke Meter	1		1		1
20. Stack Temp. (°F)	440	461	463	465	533
21. Boiler Outlet Press (iwg)	-.75	-.75	-.75	-.73	-.73
22. Boiler Outlet Temp. (°F)	650	650	649	650	650
23. Air Heater Inlet Temp. (°F)					
24. Air Heater Outlet Temp. (°F) PRESS.	-1.9	-1.85	-1.85	-1.85	-1.9
25. Windbox Temperature (°F) 1 / 4	275/290	336/345	344/350	344/350	136/145
26. 2/3/5		340/340/358	341/-/356	341/-/357	142/-/156
27. GAS SETTING/CONTROL PRESSURE	33.5/8.5	33.5/8.5	33.5/8.5	33.5/8.3	32.5/8.4
28.					

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____

Engr. _____

CONTROL ROOM DATA

Test Number _____ Date 6-8-76

Unit Number _____ Owner _____

Fuel NATURAL GAS Location 38

Capacity (K#/hr) 45

Furnace Type C.F. VERTICAL Burner Type RING

	Full By Pass		1/2 By-pass		1/2 By Pass			
1. Test Number	205-5		205-6		205-7		205/4-8	
2. Load (K#/hr)	34.6		40.5		39.5		38.5	
3. Control Method Auto/Hand	HAND		HAND		HAND		HAND	
4. Staged Air Port Open	NONE		NONE		NONE		6 + 7	
5.	VPH		VPH		VPH		SCA + VPH	
6. Oxygen/Air Level (%)	2.55		1.7		2.35			
7. ^{1/2} Drum Pressure (psig)	136		136		136		140	
8. Final Steam Press/Temp (psig/°F)	144		144		144		149	
9. Fuel-Air Ratio Setting								
10. Feedwater Press/Temp (psig/°F)	274		274		275		279	
11. Air Flow Primary/Secondary (iwg)	2.9				3.8		2.9	
12. Air Temp Primary/Secondary (°F)	95		96		98	102	97	
13. Fan Setting FD/ID	76	96	85	98	74	84	59	88
14. Register Setting (%open C.C.)	73%						→	
15. Fuel Flow (lb/hr)*								
16. Fuel Press/Temp (psig/°F)	3.4	74	3.7	75	3.4	75	3.5	75
17. Fuel Atomization Press (psig)								
18. Pressure Furnace/Windbox (iwg)	-20	2.5	-20	2.6	-22	2.7	-20	2.2
19. Smoke Meter			1					
20. Stack Temp. (°F)			545		464		487	
21. Boiler Outlet Press (iwg)	-.75		-.78		-.80		-.79	
22. Boiler Outlet Temp. (°F)	656		661		650		660	
23. Air Heater Inlet Temp. (°F)								
24. Air Heater Outlet Temp. (°F) PRESS.	-1.95		-2.0		-1.95		-2.0	
25. Windbox Temperature (°F) 1 / 4	135/140		135/140		225/280		240/300	
26. 2 / 5	140/152		138/150		229/286		240/298	
27. GAS SETTING / CONTROL PRESSURE	32.5/8.2		35.5/9.1		33/8.4		33/8.5	
28.								

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. 200G-8, 9, 10, 11, 12

Engr. _____

CONTROL ROOM DATA

Test Number _____ Date 6-9-76

Unit Number _____ Owner _____

Fuel GAS Location 38

Capacity (K#/hr) 45

Furnace Type C.E. VERTICAL Burner Type RING

1. Test Number	200G-8	200G-9	200G-10	200G-11	200G-12
2. Load (K#/hr)	40.0	40.3	38.0	39.5	40.5
3. Control Method Auto/Hand	HAND	HAND	HAND	HAND	HAND
4. Staged Air Port Open	NONE	NONE	NONE	NONE	NONE
5.	BASELINE	REGISTER SETTINGS	REGISTER SETTING CHANGE		
6. Oxygen/Air Level (%)	2.3	2.35			
7. ^{LINE} Drum Pressure (psig)	135	135	135	135	135
8. Final Steam Press/Temp (psig/°F)	144	144	143	144	144
9. Fuel-Air Ratio Setting					
10. Feedwater Press/Temp (psig/°F)	275	273	274	274	274
11. Air Flow Primary/Secondary (iwg)	4.6	4.5	6.0	6.0	5.7
12. Air Temp Primary/Secondary (°F)	83	83	88	89	89
13. Fan Setting FD/ID	72 82	72 82	83 69	83 82	97 98
14. Register Setting (%open C.C.)	73.2%	100%	39.7%	39.7%	46.4%
15. Fuel Flow (lb/hr)*					
16. Fuel Press/Temp (psig/°F)	3.5 70	3.5 71	3.5 72	3.5 72	3.5 72
17. Fuel Atomization Press (psig)					
18. Pressure Furnace/Windbox (iwg)	-2 2.9	-2 2.75	-2 4.58	-45 4.4	-60 4.0
19. Smoke Meter	1				
20. Stack Temp. (°F)	434	436	429		450
21. Boiler Outlet Press (iwg)	-80	-78	-65	-90	-1.16
22. Boiler Outlet Temp. (°F)	650	650	630	650	665
23. Air Heater Inlet Temp. (°F)					
24. Air Heater Outlet Temp. (°F) PRESS.	-1.95	-1.95	-1.6	-2.0	-2.4
25. Windbox Temperature (°F) 1/4	275/290	279/291	279/293	284/297	288/300
26. 2/5	275/297	275/299	283/301	288/305	291/310
27. GAS SETTING/CONTROL PRESSURE	34/8.7	34/8.7	34/8.7	34/8.7	34/8.7
28.					

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____

Engr. _____

CONTROL ROOM DATA

Test Number _____ Date 6-9-76

Unit Number _____ Owner _____

Fuel GAS Location 38

Capacity (K#/hr) 45

Furnace Type C.E. VERTICAL Burner Type RING

1. Test Number	200G-13	200G-14	200G-15	200G-16	204-18
2. Load (K#/hr)	40.7	40.7	40.5	40.5	40.0
3. Control Method Auto/Hand	HAND	HAND	HAND	HAND	HAND
4. Staged Air Port Open	NONE	NONE	NONE	NONE	14 + 15
5.					
6. Oxygen/Air Level (%)	1.55	1.8			2.25
7. ^{LINE} Drum Pressure (psig)	135	135	135	135	135
8. Final Steam Press/Temp (psig/°F)	144	144	144	144	144
9. Fuel-Air Ratio Setting					
10. Feedwater Press/Temp (psig/°F)	274	274	274	274	275
11. Air Flow Primary/Secondary () iwg	5.7	5.5	5.5	5.3	3.4
12. Air Temp Primary/Secondary (°F)	92	93	94	98	96
13. Fan Setting FD/ID	97 84	97 81	97 87	97 85	58 83
14. Register Setting (%open C.C.)	46.4%	53.1%	53.1%	59.8%	73.2%
15. Fuel Flow (lb/hr)*					
16. Fuel Press/Temp (psig/°F)	3.5 72	3.5 73	3.5 74	3.5 75	3.5 75
17. Fuel Atomization Press (psig)					
18. Pressure Furnace/Windbox (iwg)	-35 4.0	-20 3.8	-30 3.75	-20 3.5	-20 2.25
19. Smoke Meter					
20. Stack Temp. (°F)	443	441	448	449	450
21. Boiler Outlet Press (iwg)	-.90	-.75	-.90	-.79	-.75
22. Boiler Outlet Temp. (°F)	661	665	670	665	653
23. Air Heater Inlet Temp. (°F)					
24. Air Heater Outlet Temp. (°F) PRESS.	-2.0	-1.9	-2.1	-2.0	-1.9
25. Windbox Temperature (°F) 1 / 4	295/300	290/299	295/300	290/300	310/325
26. 2 / 5	292/308	290/302	293/294	294/306	310/329
27. GAS SETTING/CONTROL PRESS	34/8.8	34/8.7	34/8.7	34/8.7	34/8.8
28.					

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____

Engr. _____

CONTROL ROOM DATA

Test Number _____ Date _____

Unit Number _____ Owner _____

Fuel GAS Location 38

Capacity (K#/hr) 45

Furnace Type C.E. VERTICAL Burner Type RING

	6-9-76	6-9-76	6-10-76		
1. Test Number	204-19	204-20	200G-17	200G-17E	204-21
2. Load (K#/hr)	39.8	40.0	39.5	40.0	39.6
3. Control Method Auto/Hand	HAND	HAND	HAND	✓	HAND
4. Staged Air Port Open	14 + 15	14 + 15	NONE	✓	14 + 15
5.			BASELINE	✓	SCA
6. Oxygen/Air Level (%)	3.45	2.8	2.2		
7. ^{LINE} Drum Pressure (psig)	135.5	135.5	135	✓	135
8. Final Steam Press/Temp (psig/°F)	144	144	144	144	143
9. Fuel-Air Ratio Setting					
10. Feedwater Press/Temp (psig/°F)	275	275	274	✓	274
11. Air Flow Primary/Secondary (iwg)	3.8	3.5	4.5	4.5	3.3
12. Air Temp Primary/Secondary (°F)	98	98	88	92	94
13. Fan Setting FD/ID	65 90	60 86	71 80	✓	58 84
14. Register Setting (%open C.C.)	73.2	73.2	73.2	✓	73.2
15. Fuel Flow (lb/hr)*					
16. Fuel Press/Temp (psig/°F)	3.5 75	3.5 75	3.5 72	3.5 76	3.5 76
17. Fuel Atomization Press (psig)					
18. Pressure Furnace/Windbox (iwg)	-2 2.5	-2 2.3	-2 2.85	-2.2 2.80	-1.9 2.2
19. Smoke Meter					
20. Stack Temp. (°F)	455	456	434		450
21. Boiler Outlet Press (iwg)	-.81	-.80	-.75	-.75	-.78
22. Boiler Outlet Temp. (°F)	660	655	650	651	657
23. Air Heater Inlet Temp. (°F)					
24. Air Heater Outlet Temp. (°F) PRESS.	-2.05	-2.0	-1.9	-1.9	-2.0
25. Windbox Temperature (°F) 1 / 4	310/325	310/325	278/293	281/296	306/321
26. 2 / 5	306/331	310/335	276/301	1288	306/327
27. GAS SETTING/CONTROL PRESS.	34/8.7	34/8.7	34/8.9		34/8.8
28.					

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____
Engr. _____

CONTROL ROOM DATA

Test Number 204-22 Date 6/10/76
Unit Number _____ Owner _____
Fuel NATURAL GAS Location 38
Capacity (K#/hr) 45
Furnace Type CE VERTICAL Burner Type RING
6/10/76

1. Test Number	204-22	204/5-23	204/5-24	-25	-26
2. Load (K#/hr)	39.6	39.0	39.0	39.0	39.4
3. Control Method Auto/Hand	HAND	✓	✓	✓	✓
4. Staged Air Port Open	12 + 13	12 + 13	14 + 15	14 + 15, 12 + 13	14 + 15, 12 + 13 FD
5.	SCA	Before Full Op.			→
6. Oxygen/Air Level (%)	2.75				
7. LINE Drum Pressure (psig)	135	135	✓	✓	135
8. Final Steam Press/Temp (psig/°F)	143	143	✓	✓	143
9. Fuel-Air Ratio Setting					
10. Feedwater Press/Temp (psig/°F)	273	272	✓	✓	275
11. Air Flow Primary/Secondary (iwg)	3.3	2.1 ^{84/100}	2.1 ^{84/100}		1.8 ^{84/100}
12. Air Temp Primary/Secondary (°F)	96	100	100	100	100
13. Fan Setting FD/ID	58 86	58 99	✓ ✓	✓ ✓	58 99
14. Register Setting (%open C.C.)	73.2%	73	✓		73.2
15. Fuel Flow (lb/hr)*					
16. Fuel Press/Temp (psig/°F)	3.5 76	3.5 78	✓ ✓	✓ 79	3.5 78
17. Fuel Atomization Press (psig)					
18. Pressure Furnace/Windbox (iwg)	-20 2.2	-20 1.8	-22 1.8	-17 1.8	-15 1.6
19. Smoke Meter		1			1
20. Stack Temp. (°F)	458	553	547		565
21. Boiler Outlet Press (iwg)	-8.2	-7.8	-8.1	-7.3	-7.5
22. Boiler Outlet Temp. (°F)	675	672	660	662	685
23. Air Heater Inlet Temp. (°F)					
24. Air Heater Outlet Temp. (°F) PRESS.	-2.0	-2.0	-2.05	-2.0	-2.0
25. Windbox Temperature (°F) 1/4	318/330	144/151	141/150	139/149	139/145
26. 2/5	320/325	155/146	154/144	152/143	142/152
27. GAS SETTING/CONTROL PRESSURE	34/8.9	34/8.8	✓		34/8.9
28.					

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____

Engr. _____

CONTROL ROOM DATA

Test Number _____ Date 6-10-76

Unit Number _____ Owner _____

Fuel NAT. GAS Location 38

Capacity (K#/hr) 45

Furnace Type CE VERTICAL Burner Type _____

						VERY SLIGHT BOILER VIBRATION	
1. Test Number	204/5-27	204/5-28	204/5-29	204/5-30	-31		
2. Load (K#/hr)	39.0	39.5	39.0	39.0	39.0		
3. Control Method Auto/Hand	HAND	HAND	HAND	HAND	✓		
4. Staged Air Port Open	14+15 OPEN (12+13) 1/2 OPEN (6+7) 1/3	1/2 (6+7)	6+7 OPEN	6+7	6+7 FULL OPEN		
5.		14+15	14+15 OPEN	14+15	14+15 1/2 OPEN		
6. Oxygen/Air Level (%)							
7. ^{6"V"} Drum Pressure (psig)	134	134	136.5	137	✓		
8. Final Steam Press/Temp (psig/°F)	143	145	146	145	✓		
9. Fuel-Air Ratio Setting							
10. Feedwater Press/Temp (psig/°F)	275	272	280	277	✓		
11. Air Flow Primary/Secondary ()	1.8	1.8	1.8	1.8	2.1		
12. Air Temp Primary/Secondary (°F)	98	93	92	92	92		
13. Fan Setting FD/ID	48 98	48 98	48 98	44 98	46 98		
14. Register Setting (%open C.C.)	73.2	73.2	73.2	73.2	✓		
15. Fuel Flow (lb/hr)*							
16. Fuel Press/Temp (psig/°F)	3.5 76	3.6 75	3.6 75	3.6 75	3.5 75		
17. Fuel Atomization Press (psig)							
18. Pressure Furnace/Windbox (iwg)	-1.14 1.6	-1.15 1.65	-1.10 1.75	-1.14 1.6	-1.2 1.65		
19. Smoke Meter							
20. Stack Temp. (°F)			556				
21. Boiler Outlet Press (iwg)	-.72	-.72	-.70	-.74	.78		
22. Boiler Outlet Temp. (°F)	671	675	678	680	676		
23. Air Heater Inlet Temp. (°F)							
24. Air Heater Outlet Temp. (°F) ^{DIFFERENCE} (iwg)	-2.0	-2.0	-2.0	-2.0	-2.1		
25. Windbox Temperature (°F)	114 140/145	130/140	130/140	130/140	130/139		
26.	215 140/150	134/147	133/144	134/135	144/132		
27. GAS SETTING/CONTROL PRESSURE	34/8.9	34/9.0	34/9.0	34/9.0	✓/8.9		
28.							

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____

Engr. _____

CONTROL ROOM DATA

Test Number _____ Date 6/10/76 , 6/11/76

Unit Number _____ Owner _____

Fuel NAT. GAS Location 38

Capacity (K#/hr) 45

Furnace Type CE VERTICAL Burner Type RING

	6/10/76	6/11/76	6/11/76	6/11/76	6/11/76
1. Test Number	204/5-32	2006-18	2006-19	2006-20	2006-21
2. Load (K#/hr)	39.2	39.5	39.5	39.5	39.5
3. Control Method Auto/Hand	HAND	HAND	HAND	HAND	HAND
4. Staged Air Port Open	6+7	NONE	NONE	NONE	NONE
5.					
6. Oxygen/Air Level (%)		2.05	1.98	2.8	4.05
7. Drum Pressure (psig)	137	134.5	136	136.5	130.5
8. Final Steam Press/Temp (psig/°F)	145	144	145	145	144
9. Fuel-Air Ratio Setting					
10. Feedwater Press/Temp (psig/°F)	278	273	262	267	269
11. Air Flow Primary/Secondary ()	1.8	4.5	4.0	4.5	5.0
12. Air Temp Primary/Secondary (°F)	91	89	91	94	96
13. Fan Setting FD/ID	54 100	70 78	68 77	72 82	97 93
14. Register Setting (%open C.C.)			100%	100%	100%
15. Fuel Flow (lb/hr)*					
16. Fuel Press/Temp (psig/°F)	3.5 75	3.4 73	3.4 73	3.4 74	3.4
17. Fuel Atomization Press (psig)					
18. Pressure Furnace/Windbox (iwg)	-1.2 +1.8	-1.2 +2.7	-1.22 +2.4	-1.9 2.65	-1.2 2.95
19. Smoke Meter		1			
20. Stack Temp. (°F)		425	425	430	
21. Boiler Outlet Press (iwg)	-1.8	-1.70	-1.76	-1.75	-1.85
22. Boiler Outlet Temp. (°F)	676	645	642	650	660
23. Air Heater Inlet Temp. (°F)					
24. Air Heater Outlet Temp. (°F) ^{PH/1000}	-2-0	-1.8	-1.8	-1.9	-2.15
25. Windbox Temperature (°F)	114 129/138	282/295	285/299	286/300	285/300
26.	215 143/132	287/291	290/296	290/296	290/296
27. GAS SETTING/CONTROL PRESSURE	34/9	33.5/8.5	33.5/8.5	33/8.5	33/8.4
28.					

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

KVB

Test No. _____

Engr. _____

CONTROL ROOM DATA

Test Number _____ Date 6/11/76

Unit Number _____ Owner _____

Fuel NAT. GAS Location 38

Capacity (K#/hr) 45

Furnace Type CE VERTICAL Burner Type RING

6/11/76 →

1. Test Number	2006-22	2006-23							
2. Load (K#/hr)	39.5	39.4							
3. Control Method Auto/Hand	HAND	✓							
4. Staged Air Port Open	NONE	✓							
5.									
6. Oxygen/Air Level (%)									
7. ¹¹⁴² Drum Pressure (psig)	136.5	✓							
8. Final Steam Press/Temp (psig/°F)	145	✓							
9. Fuel-Air Ratio Setting									
10. Feedwater Press/Temp (psig/°F)	265	275							
11. Air Flow Primary/Secondary ()	4.2	4.0							
12. Air Temp Primary/Secondary (°F)	100	101							
13. Fan Setting FD/ID	70	78	67	74					
14. Register Setting (%open C.C.)	100%	100%							
15. Fuel Flow (lb/hr)*									
16. Fuel Press/Temp (psig/°F)	3.4	76	3.4	78					
17. Fuel Atomization Press (psig)									
18. Pressure Furnace/Windbox (iwg)	- .2	2.5	- .2	2.4					
19. Smoke Meter									
20. Stack Temp. (°F)									
21. Boiler Outlet Press (iwg)	- .71	- .70							
22. Boiler Outlet Temp. (°F)	643	640							
23. Air Heater Inlet Temp. (°F)									
24. Air Heater Outlet Temp. (°F) ^{PRESSURE} _{iwg}	-1.85	-1.76							
25. Windbox Temperature (°F)	1/4 294/305	295/306							
26.	2/5 396/302	303/298							
27. GAS SETTING/CONTROL PRESSURE	33/8.4	✓/✓							
28.									

*Fuel flow in lb/hr needed for efficiency calculation.

4/76
60-33

Location 38

Fuel Gas Analysis

<u>Gas</u>	<u>Concentration, % by Volume</u>
Methane	96.99
Ethane	1.98
Propane	0.10
Butanes	.04
Pentanes	.01
Hexanes	.00
Carbon Dioxide	.60
Oxygen	.00
Nitrogen	.28
Water Vapor	.00

Higher Heating Value = 1,011 Btu/SCF

Location 38
Fuel Oil Analysis

<u>T E S T S</u>		<u>R E S U L T S</u>	
		<u>LAB. NO. G3393</u>	<u>LAB. NO. G3430</u>
GRAVITY, API @ 60°F		15.2	15.2
FLASH, PM CC		214°F	218°F
VISC., SU @ 160°F		359sec.	358sec.
VISC. SU @ 220°F		118sec.	119sec.
SULFUR, ASTM		1.88%	1.88%
B.T.U. PER POUND	NET	17425	17462
	GROSS	18449	18484
CARBON		86.21%	86.26%
HYDROGEN		11.22%	11.20%
NITROGEN		0.32%	0.30%
OXYGEN		0.34%	0.29%
ASH		0.03%	0.07%

PLANT 38
 LOCATION 38
 OPERATOR R.P. & G.C.
 DATE 5-7-77
 RUN NO. 201-7
 SAMPLE BOX NO.
 METER BOX NO.
 METER H 1.72
 C FACTOR 0.9

METHOD 5 CONTROL CONSOLE READINGS



AMBIENT TEMPERATURE
 BAROMETRIC PRESSURE 24.30
 ASSUMED MOISTURE, % 11.0
 HEATER BOX SETTING
 PROBE LENGTH, IN. 72" 30Y
 NOZZLE DIAMETER, IN. 3/8
 PROBE HEATER SETTING
 UPPER LOCATION

SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P _s), In. Hg.	Stack Temperature (T _s) °F	Velocity Head (P _s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V _m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet (T _{min.}) °F	Outlet (T _{max.}) °F		
20"	1653	-0.21	420	.25	1.1	803.4007	74	76	320	50
INSIDE STACK	1708		420	.25	1.1	812.9000	90	78	320	50
	1720		420	.25	1.1	820.1000	100	82	320	50
	1735		420	.25	1.1	828.6000	102	88	320	50
	1810		420	.25	1.1	850.5000	115	98	320	60
	1834		420	.25	1.1	864.4007	115	100	320	50
TOTAL						61.0000	99	87		
AVERAGE			420	.25	1.1		93	87	320	50

332

PARTICULATE CALCULATION SHEET

Test No. 201-7 Date 5-7-76 Location 38 Test Crew RR
 Box No. _____ Sample Probe Position 20" INSIDE OF DUCT
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final _____

Initial _____

Total _____

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	345	58	2	659.2	
Initial	100	100	0	646.6	
Δ Vol	245	-42	2	12.6	217.6

Beaker No. <u>2</u> <u>1</u>						Filter No. <u>1</u>	Blank No.
Date Weighed							
Tare	1	84.6649	85.9114			.6886	
Wt.	2	84.6582	85.9113			.6886	
	3	84.6571				.6886	
	4						
	5						
	6						
Avg		84.6601	85.9114			.6886	
Bottle No.							
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)		
Rinse (ml)							
Date Weighed or 250 Bake							
Final	1	84.8751	86.1104			.8641	
Wt. 250	2	84.8751	86.1104			.8641	
	3					.8641	
	4						
	5						
	6						
Avg		84.8751	86.1104			.8641	
Residue wt		.2150	.1990			.1755	
Final 250-Tare							
Date Weighed or 650 Bake							
Final	1						
Wt. 650	2						
	3						
	4						
	5						
	6						
Avg							
Residue Wt							
Final 650-Tare							

Comments:

Data Sheet 6002-3

LOW AIR.

PARTICULATE EMISSION CALCULATIONS

Test No. 201-7 Date 5-7-76 Location 38 Engr. R.P.

Unit No. 2 Fuel #6 Sampling Train and Method METHOD #5

Pitot Factor, P_s .89 Barometric Pressure, P_{bar} 29.30 in. Hg

Tot. Liquid Collected, V_{lc} 217.6 ml Total Particulate, M_n 589.5 mg

Velocity Head, ΔP 0.25 iwg Stack Temp., T_s 880 °R Stack Area, A_s 11.0 ft²

Sample Volume, V_m 61 ft³ Stack Press., P_{sg} -0.01 iwg Excess O₂, $XO_2\%$ 2.6 %

Orifice Press. Diff., H 1.1 iwg Stack Gas Sp. Gravity, G_s 1.05 n.d.

Sample Time, θ 101 min Nozzle Dia., D_n 3/8 in. Meter Temp., T_m 553 °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 59.86 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 10.31 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2}/(\text{Eq. 1} + \text{Eq. 2})$ 0.1469 N.D.
4. Concentration a. $C = 0.0154 M_n/V_{m_{std}}$ 0.1517 grains/DSCF
b. $C = 2.205 \times 10^{-6} M_n/V_{m_{std}}$.00002171 lb/DSCF
c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.3476 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 398.2 in. w abs.
6. Stack Gas Speed $V_s = 174 P_s \sqrt{\Delta P/T_s} \sqrt{\frac{407}{P_s} \times \frac{1.00}{G_s}}$ 2264 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 14,708 WSCF/min
Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 12,548 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 16.34 lb/hr
9. XO₂ factor $XO_{2f} = 2090/(20.9 - XO_2\%)$ 114.2 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_m \times \text{Eq. 9}$.2285 lb/MMBtu
b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 98.25 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 68 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

333

--

CONCENTRATION

CONCENTRATION

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P_s), In. Hg. iwg	Stack Temperature (T_s) °F	Velocity Head (P_s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V_m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temptrature °F	Temperature of Gas Leaving Condenser on Last Impinger °F	
							Inlet ($T_{min.}$) °F	Outlet (T_{mout}) °F			
		0.09	350	.25	1.25	904.6020	62	58	320	50	
	13		370	.26	1.25	912.6000	70	60	320	55	
	15		375	.25	1.25	922.1000	77	66	320	60	
	15		390	.25	1.25	931.6000	75	68	310	60	
	15		395	.25	1.25	941.4000	72	67	320	60	
	15		392	.25	1.25	951.1000	73	67	320	60	
	15		385	.25	1.25	960.6000	73	66	320	57	
	8	↓	385	.25	1.25	965.6020	76	67	320	60	
			NOTE: ALL OTHER T_s MEASUREMENTS ARE						420-430 °F.		
			THESE MUST BE IN ERROR								
TOTAL	96					61.0000		64.88 AVG.	AVG.		
AVERAGE			380				72.25	AVG. 68			

PARTICULATE CALCULATION SHEET

Test No. 200-14 Date 5/12/76 Location 38 Test Crew A.P.
 Box No. _____ Sample Probe Position _____
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final _____
 Initial _____
 Total _____

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	240	81	1		
Initial	100	100	0		
Δ Vol	140	-19	1		136.5

Beaker No. <u>4</u> <u>3</u>					Filter No. <u>2</u>	Blank No.
Date Weighed						
Tare	1	102.0466		103.1887		.6871
Wt.	2	102.0455		103.1898		.6871
	3					
	4					
	5					
	6					
Avg		102.0460		103.1892		.6871
Bottle No.						
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)	
Rinse (ml)						
Date Weighed or 250 Bake						
Final	1	102.2178		103.3032		.8552
Wt. 250	2	102.2178		103.3032		.8563
	3					
	4					
	5					
	6					
Avg		102.2178		103.3032		.8558
Residue wt						
Final 250-Tare		.1718		.1140		.1687
Date Weighed or 650 Bake						
Final	1					
Wt. 650	2					
	3					
	4					
	5					
	6					
Avg						
Residue Wt						
Final 650-Tare						

Comments:

Data Sheet 6002-3

BASELINE
PARTICULATE EMISSION CALCULATIONS

Test No. 205-14 Date 5/12/76 Location 38 Engr. FP
Unit No. _____ Fuel #6 Sampling Train and Method _____
Pitot Factor, F_s 0.89 Barometric Pressure, P_{bar} 29.27 in. Hg
Tot. Liquid Collected, V_{lc} 136.5 ml Total Particulate, M_n 454.5 mg
Velocity Head, ΔP 0.25 iwg Stack Temp., T_s 880 °R Stack Area, A_s 11.0 ft²
Sample Volume, V_m 61 ft³ Stack Press., P_{sg} 0.09 iwg Excess O₂, XO_2 % 2.6 %
Orifice Press. Diff., H 1.25 iwg Stack Gas Sp. Gravity, G_s 1.05 n.d.
Sample Time, θ 96 min Nozzle Dia., D_n 3/8 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 59.82 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 6.47 SCF
3. Moisture Content $B_{wv} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.098 N.D.
4. Concentration a. $C = 0.0154 M_n / V_{m_{std}}$ 0.1170 grains/DSCF
b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 0.0001675 lb/DSCF
c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.2683 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 400.7 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 2259 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 14734 WSCF/min
Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 13290 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 13.36 lb/hr
9. XO₂ factor $XO_{2f} = 2090 / (20.9 - XO_2 \%)$ 114.2 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$.1764 lb/MMBtu
b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 75.83 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 67 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

1) USE 420°F, 380°F OF FIELD DATA SHEET DECLARED TO BE IN ERROR

PLANT _____
LOCATION 38
OPERATOR _____
DATE 5/12
RUN NO. 200-14
SAMPLE BOX NO. _____
METER BOX NO. _____
METER H _____
C FACTOR @ _____

METHOD 5 CONTROL CONSOLE READINGS

--

AMBIENT TEMPERATURE	70
BAROMETRIC PRESSURE	29.40
ASSUMED MOISTURE, %	11
HEATER BOX SETTING	
PROBE LENGTH, IN.	20"
NOZZLE DIAMETER, IN.	3/8
PROBE HEATER SETTING	

SCHEMATIC OF STACK CROSS SECTION

CASCADE IMPACTOR

Traverse Point Number	Sampling Time (t) Min.	Static Pressure (P_s), In. Hg.	Stack Temperature (T_s) °F	Velocity Head (P_s)	Pressure Differential Across Orifice Meter (ΔH), In. H_2O	Gas Sample Volume (V_m) ft^3	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet ($T_{min.}$) °F	Outlet ($T_{out.}$) °F		
	1542	0.09	NOT MEAS.	—	20	965.7080	68	60	—	50
	1552	↓		—	1.8	975.1	72	62	—	55
	1602	↓		—	1.4	979.9	75	65	—	55
	1612	↓		—	1.6	988.3	76	67	—	55
TOTAL						20.6		AVG. 64	AVG.	
AVERAGE							73	AVG. 68		

ω
ω
∞

Test No. 200-14

CASCADE IMPACTOR DATA SHEET

TEST RUN NO. 200-14 LOCATION 38 DATE 5-11-76
 IMPACTOR NO. 1 CYCLONE NO. NONE OPERATOR RP + GC
 SAMPLE POINT LOCATION EAST UPPER PORT, 20" INSIDE
 SUBSTRATE COATING NONE FUEL #6 TEST LOAD 40 klb/hr
 IMPACTOR ORIENTATION NOZZLE DOWN FLOW THRU IMPACTOR 0.69 CFM
 FLUE STATIC PRESSURE 0.09 inH₂O, VELOCITY _____
 NOZZLE DIA. 3/8 INCH IMPACTOR PRESSURE DROP — END TIME 1612
 GAS METER END 986.3 CF START TIME 1542
 GAS METER START 965.7 CF DURATION 30 MIN
 GAS VOLUME 20.6 CF FLOW RATE 0.67 CFM
 AMBIENT TEMPERATURE 80 °F PRESSURE 29.40 IN Hg. HUMIDITY _____ %
 FLUE GAS MOLECULAR WT. _____, TEMP. 428 °F, DENSITY _____ g/cc, VISCOSITY _____ POISE

	Stage Number						Stage Blank
	1	2	3	4	5	6	
Foil + Sample, g	.7529	.7513	.7448	.7456	.7522	.7572	.7668
Unused Foil, g	.7529	.7492	.7406	.7422	.7589	.7616	.7668
Sample, g	0	.0021	.0042	.0034	—	—	0
Correction for Blank, g	0	0	0	0	0	0	
Final Sample, g	0	.0021	.0042	.0034	—	—	
D_{50}	29.5	14.0	5.3	2.4	1.35	0.60	

FILTER NO. 2 Sample #2 Blank #3

FILTER + SAMPLE, g	.1621	.1361
FILTER TARE, g	.1438	.1361
SAMPLE, g	.0183	0
CORRECTION FOR BLANK, g	0	
FINAL SAMPLE, g	.0183	

FULL CONTAINER, g _____

EMPTY CONTAINER, g _____

CYCLONE CATCH, g NONE

340

--

UPPER LOCATION

SCHEMATIC OF STACK CROSS SECTION

[illegible]

Test No. 200-18

CASCADE IMPACTOR DATA SHEET

TEST RUN NO. 200-18 LOCATION 38 DATE 5-14-76

IMPACTOR NO. 1 CYCLONE NO. NONE OPERATOR R P

SAMPLE POINT LOCATION EAST UPPER PORT, 20" INSIDE

SUBSTRATE COATING NONE FUEL #6 TEST LOAD 38 klb/hr

IMPACTOR ORIENTATION NOZZLE DOWN FLOW THRU IMPACTOR _____ CFM

FLUE STATIC PRESSURE _____ inH₂O, VELOCITY _____

NOZZLE DIA. 1/4 INCH IMPACTOR PRESSURE DROP _____ END TIME 1645

GAS METER END 1006.0064 CF START TIME 1600

GAS METER START 988.8013 CF DURATION 45 MIN

GAS VOLUME 17.2051 CF FLOW RATE _____ CFM

AMBIENT TEMPERATURE _____ °F PRESSURE _____ IN Hg. HUMIDITY _____ %

FLUE GAS MOLECULAR WT. _____, TEMP. 395 °F, DENSITY _____ g/cc, VISCOSITY _____ POISE

	Stage Number						Stage Blank
	1	2	3	4	5	6	
Foil + Sample, g	.7647	.7466	.7519	.7549	.7503	.7624	.7668
Unused Foil, g	.7592	.7489	.7509	.7484	.7504	.7669	
Sample, g	.0055	—	.0010	.0065	—	—	0
Correction for Blank, g	0	0	0	0	0	0	
Final Sample, g							

FILTER NO.	Sample	Blank
FILTER + SAMPLE, g	.1619	.1320
FILTER TARE, g	.1361	.1320
SAMPLE, g	.0251	0
CORRECTION FOR BLANK, g	0	
FINAL SAMPLE, g	.0251	

FULL CONTAINER, g _____

EMPTY CONTAINER, g _____

CYCLONE CATCH, g NONE

PLANT 38
 LOCATION 38
 OPERATOR RP
 DATE 5-20-76
 RUN NO. 203-26A
 SAMPLE BOX NO. _____
 METER BOX NO. EN-45-1
 METER H _____
 C FACTOR @ _____

METHOD 5 CONTROL CONSOLE READINGS



AMBIENT TEMPERATURE _____
 BAROMETRIC PRESSURE _____
 ASSUMED MOISTURE, % 10
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. _____
 NOZZLE DIAMETER, IN. 3/8
 PROBE HEATER SETTING _____

SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P _s), In. Hg.	Stack Temperature (T _s) °F	Velocity Head (P _s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V _m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temptrature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet (T _{min.}) °F	Outlet (T _{mout}) °F		
IN 20"	1115		425	.35	1.0	7.0000	VACUUM PUMP BAD.			
	STOP 1116		—	—		7.5000				
	RESTART 1150		425	.35	4.0	8.3000	70	64	320	55
	1200		425	.35	4.0	17.2000	82	67	320	60
	1210		425	.35	4.0	27.6000	90	71	320	60
	1220		425	.35	4.0	38.1000	94	75	320	60
	1230		429	.35	4.0	49.5000	86	76	310	60
	1240		428	.35	4.0	60.9000	88	73	320	60
	1248		428	.35	4.0	68.8000	90	75	320	60
TOTAL								AVG.	AVG.	
AVERAGE								AVG.		

PARTICULATE CALCULATION SHEET

Test No. 203-26A Date 5-20-76 Location 38 Test Crew _____
 Box No. _____ Sample Probe Position _____
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final _____
 Initial _____
 Total _____

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	230	67	2	668.85	
Initial	100	100	0	654.25	
Δ Vol	130	-33	2	14.60	113.6

Beaker No.	7	5	6			Filter No. 3	Blank No. 4
Date Weighed							
Tare	1 102.4673	100.4803	100.0144			.6693	.6704
Wt.	2 102.4674	100.4805	100.0148			.6694	.6706
	3						
	4						
	5						
	6						
Avg	102.4674	100.4804	100.0146			.6694	.6705
Bottle No.							
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)		
Rinse (ml)							
Date Weighed or 250 Bake							
Final	1 102.5500	100.4963	100.0706			.8276	.6706
Wt. 250	2 102.5503	100.4963	100.0708			.8278	.6705
	3 102.5505	100.4964	100.0710			.8279	
	4						
	5						
	6						
Avg	102.5503	100.4963	100.0708			.8278	.6706
Residue wt	.0829	.0159	.0562			.1584	0
Final 250-Tare							
Date Weighed or 650 Bake							
Final	1						
Wt. 650	2						
	3						
	4						
	5						
	6						
Avg							
Residue Wt							
Final 650-Tare							

Comments:

Data Sheet 6002-3

PARTICULATE EMISSION CALCULATIONS

Test No. 203-26A Date 5-20-76 Location 38 Engr. _____
 Unit No. _____ Fuel _____ Sampling Train and Method _____
 Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 29.72 in. Hg
 Tot. Liquid Collected, V_{lc} 113.6 ml Total Particulate, M_n 313.4 mg
 Velocity Head, ΔP .35 iwg Stack Temp., T_s 886 °R Stack Area, A_s 7.47 ft²
 Sample Volume, V_m 61 ft³ Stack Press., P_{sg} 0.09 iwg Excess O₂, XO_2 % 3.3 %
 Orifice Press. Diff., H 4.0 iwg Stack Gas Sp. Gravity, G_s _____ n.d.
 Sample Time, θ 59 min Nozzle Dia., D_n 3/8 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 61.15 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 5.38 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.0809 N.D.
4. Concentration a. $C = 0.0154 M_n / V_{m_{std}}$ 0.0789 grains/DSCF
 b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 1.13×10^{-5} lb/DSCF
 c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 1.81×10^{-1} grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 404.2 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 2551 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 11,132 WSCF/min
 Rate @ 70°F
 b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 10,231 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 6.936 lb/hr
9. XO₂ factor $XO_2 f = 2090 / (20.9 - XO_2 \%)$ 118.8 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 1.22×10^{-1} lb/MMBtu
 b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 5.26×10^1 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 97.0 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

METHOD 5 CONTROL CONSOLE READINGS

AMBIENT TEMPERATURE _____
 BAROMETRIC PRESSURE _____
 ASSUMED MOISTURE, % 10
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. 72"
 NOZZLE DIAMETER, IN. 3/8"
 PROBE HEATER SETTING _____

SCHEMATIC OF STACK CROSS SECTION

[illegible]

PARTICULATE CALCULATION SHEET

Test No. 203-268 Date 5-20-76 Location 38 Test Crew _____
 Box No. _____ Sample Probe Position _____
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final _____
 Initial _____
 Total _____

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	197	105	3	619.52	
Initial	100	100	0	605.50	
Δ Vol	97	5	3	14.02	119.02

Beaker No. <u>10</u> <u>8</u> <u>9</u>					Filter No. <u>4</u>	Blank No. <u>5</u>
Date Weighed						
Tare	1	103.1676	99.2092	98.8323		.6706 .5803
Wt.	2	103.1676	99.2094	98.8323		.6705 .5804
	3					
	4					
	5					
	6					
Avg		103.1676	99.2093	98.8323		.6706 .5804
Bottle No.						
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)	
Rinse (ml)						
Date Weighed or 250 Bake						
Final	1	103.3000	99.2230	98.8760		.8501 .5802
Wt. 250	2	103.3000	99.2231	98.8763		.8503 .5804
	3	103.3002	99.2233	98.8764		.8506
	4					
	5					
	6					
Avg		103.3001	99.2232	98.8762		.8503 .5803
Residue wt		.1325	.0139	.0439		.1797 0
Date Weighed or 650 Bake						
Final	1					
Wt. 650	2					
	3					
	4					
	5					
	6					
Avg						
Residue Wt						
Final 650-Tare						

Comments:

Data Sheet 6002-3

PARTICULATE EMISSION CALCULATIONS

Test No. 203-26B Date 5-20-76 Location 38 Engr. _____

Unit No. _____ Fuel _____ Sampling Train and Method _____

Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 29.72 in. Hg

Tot. Liquid Collected, V_{lc} 119.02 ml Total Particulate, M_p 370.0 mg

Velocity Head, ΔP .35 iwg Stack Temp., T_s 901 °R Stack Area, A_s 7.47 ft²

Sample Volume, V_m 61.0 ft³ Stack Press., P_{sg} .09 iwg Excess O₂, XO_2 % 3.1 %

Orifice Press. Diff., H 4.0 iwg Stack Gas Sp. Gravity, G_s 1 n.d.

Sample Time, θ 55 min Nozzle Dia., D_n 3/8 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 61.15 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 5.64 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$.084 N.D.
4. Concentration
 - a. $C = 0.0154 M_p / V_{m_{std}}$.093 grains/DSCF
 - b. $C = 2.205 \times 10^{-6} M_p / V_{m_{std}}$ 1.33×10^{-5} lb/DSCF
 - c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 2.14×10^{-1} grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 404.3 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \times \frac{1.00}{G_s}$ 2573 ft/min
7. Stack Gas Flow
 - a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 11,232 WSCF/min
 - b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 10,288 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 8.21 lb/hr
9. XO₂ factor $XO_2 f = 2090 / (20.9 - XO_2 \%)$ 117.4 N.D.
10. Emission
 - a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 1.44×10^{-1} lb/MMBtu
 - b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 62.2 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 105.3 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

AMBIENT TEMPERATURE _____
BAROMETRIC PRESSURE 29.6
ASSUMED MOISTURE, % 10
HEATER BOX SETTING _____
PROBE LENGTH, IN. _____
NOZZLE DIAMETER, IN. 1/4
PROBE HEATER SETTING _____

10/20/27 OK

SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e) Min.	Static Pressure (P _s), In. Hg.	Stack Temperature (T _s) °F	Velocity Head (P _s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V _m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet (T _{min.}) °F	Outlet (T _{out}) °F		
STACK,	1116		426	.35	.83	147.8084	91	90	—	60
EAST LOWER PORT	1126		427	.35	.83	152.7000	96	90	—	60
	1136		428	.35	.83	157.9000	96	90	—	65
	1146		427	.35	.83	162.9000	91	87		65
	1156		427	.35	.83	168.1000	89	84		65
	1201		427	.35	.83	170.8032	92	84		65
TOTAL								AVG.	AVG.	
AVERAGE	45 min		427	.35	.83	22.9948		AVG.		

Test No. 203-27

CASCADE IMPACTOR DATA SHEET

TEST RUN NO. 203-27 LOCATION 38 DATE MAY 21, 1976
 IMPACTOR NO. _____ CYCLONE NO. NONE OPERATOR RP, Sr
 SAMPLE POINT LOCATION STALK EAST LOWER FORT
 SUBSTRATE COATING GREASE FUEL _____ TEST LOAD _____ klb/hr
 IMPACTOR ORIENTATION NOZZLE DOWN FLOW THRU IMPACTOR _____ CFM
 FLUE STATIC PRESSURE _____ inH₂O, VELOCITY _____
 NOZZLE DIA. 1/4 INCH IMPACTOR PRESSURE DROP _____ END TIME _____
 GAS METER END _____ CF START TIME _____
 GAS METER START _____ CF DURATION 45 MIN
 GAS VOLUME 22.9948 CF FLOW RATE _____ CFM
 AMBIENT TEMPERATURE _____ °F PRESSURE _____ IN Hg. HUMIDITY _____ %
 FLUE GAS MOLECULAR WT. _____, TEMP. _____ °F, DENSITY _____ g/cc, VISCOSITY _____ POISE

	Stage Number						Stage Blank
	1	2	3	4	5	6	
Foil + Sample, g	.7618	.7490	.7595	.7482	.7596	.7553	.7517
Unused Foil, g	.7609	.7466	.7563	.7461	.7590	.7548	.7518
Sample, g	.0009	.0024	.0032	.0021	.0006	.0005	0
Correction for Blank, g	0	0	0	0	0	0	
Final Sample, g	.0009	.0024	.0032	.0021	.0006	.0005	

	4 Sample	5 Blank
FILTER NO.		
FILTER + SAMPLE, g	.1616	.1343
FILTER TARE, g	.1323	.1343
SAMPLE, g	.0293	0
CORRECTION FOR BLANK, g	0	
FINAL SAMPLE, g	.0293	

FULL CONTAINER, g _____

EMPTY CONTAINER, g _____

CYCLONE CATCH, g NONE

PLANT 38
LOCATION 38
OPERATOR RP
DATE 5-24-76
RUN NO. 200-24
SAMPLE BOX NO. _____
METER BOX NO. EN 45-1
METER H _____
Z FACTOR @ .89

METHOD 5 CONTROL CONSOLE READINGS

AMBIENT TEMPERATURE _____
 BAROMETRIC PRESSURE _____
 ASSUMED MOISTURE, % _____
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. _____
 NOZZLE DIAMETER, IN. 3/8
 PROBE HEATER SETTING _____

SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e) Min.	Static Pressure (P_s), In. Hg.	Stack Temperature (T_s) °F	Velocity Head (P_s)	Pressure Differential Across Orifice Meter (ΔH), In. H_2O	Gas Sample Volume (V_m) ft^3	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet ($T_{min.}$) °F	Outlet ($T_{mout.}$) °F		
STACK EAST	1410		426	.48	5.4	182.2010	82	74	320	60
LOWER PORT	1425		425	.48	4.8	200.4000	93	76	320	75
STOP	1426		—	.45	—	201.4017	—	—	—	—
RESTART	1456		425	.45	4.8	201.9034	95	74	320	60
	1511		425	.45	4.6	219.6000	90	76	320	70
	1526		425	.45	4.5	238.0000	90	76	320	68
	1532					243.7027				
TOTAL	52					61.0000		AVG.	AVG.	
AVERAGE								AVG.		

PARTICULATE CALCULATION SHEET

Test No. 200-24 Date 5-24-76 Location 38 Test Crew _____
 Box No. _____ Sample Probe Position _____
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final _____
 Initial _____
 Total 61.0000

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	<u>167</u>	<u>115</u>	<u>3</u>	<u>656.62</u>	
Initial	<u>100</u>	<u>100</u>	<u>0</u>	<u>630.42</u>	
Δ Vol	<u>67</u>	<u>15</u>	<u>3</u>	<u>26.20</u>	<u>111.20</u>

Beaker No.					Filter No. 5	Blank No. 6
13						
11						
12						
Date Weighed						
Tare 1	<u>99.4123</u>	<u>81.6736</u>	<u>101.3034</u>		<u>.5803</u>	<u>.5851</u>
Wt. 2	<u>99.4124</u>	<u>81.6736</u>	<u>101.3035</u>		<u>.5804</u>	<u>.5851</u>
3						
4						
5						
6						
Avg	<u>99.4124</u>	<u>81.6736</u>	<u>101.3035</u>		<u>.5804</u>	<u>.5851</u>
Bottle No.						
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)	
Rinse (ml)						
Date Weighed or 250 Bake						
Final 1	<u>99.5923</u>	<u>81.6831</u>	<u>101.3686</u>		<u>.7282</u>	<u>.5850</u>
Wt. 250 2	<u>99.5925</u>	<u>81.6831</u>	<u>101.3689</u>		<u>.7284</u>	<u>.5851</u>
3	<u>99.5926</u>		<u>101.3700</u>		<u>.7286</u>	
4						
5						
6						
Avg	<u>99.5925</u>	<u>81.6831</u>	<u>101.3688</u>		<u>.7284</u>	<u>.5851</u>
Residue wt	<u>.1801</u>	<u>.0095</u>	<u>.0633</u>		<u>.1480</u>	<u>0</u>
Final 250-Tare						
Date Weighed or 650 Bake						
Final 1						
Wt. 650 2						
3						
4						
5						
6						
Avg						
Residue Wt						
Final 650-Tare						

Comments:

Data Sheet 6002-3

PARTICULATE EMISSION CALCULATIONS

Test No. 200-24 Date 5-24-76 Location _____ Engr. _____

Unit No. _____ Fuel _____ Sampling Train and Method _____

Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 29.75 in. Hg

Tot. Liquid Collected, V_{lc} 111.20 ml Total Particulate, M_n 400.9 m gm

Velocity Head, ΔP .45 iwg Stack Temp., T_s 885 °R Stack Area, A_s 7.47 ft²

Sample Volume, V_m 61.0 ft³ Stack Press., P_{sg} .09 iwg Excess O₂, XO_2 % 2.9 %

Orifice Press. Diff., H 4.8 iwg Stack Gas Sp. Gravity, G_s _____ n.d.

Sample Time, θ 52 min Nozzle Dia., D_n 3/8 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 61.33 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 5.27 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2}/(\text{Eq. 1} + \text{Eq. 2})$ 0.079 N.D.
4. Concentration
 - a. $C = 0.0154 M_n/V_{m_{std}}$ 0.101 grains/DSCF
 - b. $C = 2.205 \times 10^{-6} M_n/V_{m_{std}}$ 1.44×10^{-5} lb/DSCF
 - c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 2.31×10^{-1} grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 404.7 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P/T_s} \sqrt{\frac{407}{P_s}} \times \frac{1.00}{G_s}$ 2890 ft/min
7. Stack Gas Flow
 - a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 12,857 WSCF/min
 - b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 11,841 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 10.23 lb/hr
9. XO₂ factor $XO_2 f = 2090/(20.9 - XO_2 \%)$ 116.1 N.D.
10. Emission
 - a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.154 lb/MMBtu
 - b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 66.38 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 97.0 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

METHOD 5 CONTROL CONSOLE READINGS

IMPORTER

ය
හ
ය

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P_s), In. Hg.	Stack Temperature (T_s) °F	Velocity Head (P_s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V_m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet ($T_{min.}$) °F	Outlet ($T_{mout.}$) °F		
EAST PORT	1647		435	.45	.68	261.0000	78	75		55
LOWER	1657		442	.45	.68	265.5000	79	74		55
	1707		442	.45	.68	270.0000	79	74		55
	1717		442	.45	.68	274.1000	78	74		55
	1727		442	.45	.68	278.9000	79	75		60
	1732		442			281.3058	82	76		60
TOTAL	45					20.3058		AVG.	AVG.	
AVERAGE								AVG.		

Test No. 200-24CASCADE IMPACTOR DATA SHEET

TEST RUN NO. 200-24 LOCATION 38 DATE 5-24-76
 IMPACTOR NO. _____ CYCLONE NO. NONE OPERATOR R.P. Sr.
 SAMPLE POINT LOCATION LOWER EAST PORT (STACK)
 SUBSTRATE COATING NONE FUEL _____ TEST LOAD _____ klb/hr
 IMPACTOR ORIENTATION NOZZLE DOWN FLOW THRU IMPACTOR _____ CFM
 FLUE STATIC PRESSURE _____ inH₂O, VELOCITY _____
 NOZZLE DIA. 1/4 INCH IMPACTOR PRESSURE DROP _____ END TIME _____
 GAS METER END _____ CF START TIME _____
 GAS METER START _____ CF DURATION 45 MIN
 GAS VOLUME 20.3058 CF FLOW RATE _____ CFM
 AMBIENT TEMPERATURE _____ °F PRESSURE _____ IN Hg. HUMIDITY _____ %
 FLUE GAS MOLECULAR WT. _____, TEMP. _____ °F, DENSITY _____ g/cc, VISCOSITY _____ POISE

	Stage Number						Stage Blank
	1	2	3	4	5	6	
Foil + Sample, g	.7451	.7432	.7492	.7482	.7410	.7493	.7516
Unused Foil, g	.7447	.7427	.7485	.7467	.7401	.7487	.7516
Sample, g	.0004	.0005	.0007	.0015	.0009	.0006	0
Correction for Blank, g	0	0	0	0	0	0	
Final Sample, g	.0004	.0005	.0007	.0015	.0009	.0006	

	5	6
FILTER NO.	Sample	Blank
FILTER + SAMPLE, g	.1591	.1375
FILTER TARE, g	.1343	.1375
SAMPLE, g	.0248	0
CORRECTION FOR BLANK, g	0	
FINAL SAMPLE, g	.0248	

FULL CONTAINER, g _____
 EMPTY CONTAINER, g _____
 CYCLONE CATCH, g NONE

METHOD 5 CONTROL CONSOLE READINGS

AMBIENT TEMPERATURE _____
BAROMETRIC PRESSURE _____
ASSUMED MOISTURE, % _____
HEATER BOX SETTING _____
PROBE LENGTH, IN. _____
NOZZLE DIAMETER, IN. 3/8
PROBE HEATER SETTING _____

SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P_s), In. Hg.	Stack Temperature (T_s) °F	Velocity Head (P_s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V_m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet ($T_{min.}$) °F	Outlet ($T_{mout.}$) °F		
LOWER EAST STACK	1100		426	.31	3.5	324.6025	90	82	320	50
	1110		426	.31	3.5	334.2000	110	87	320	50
	1120		426	.31	3.5	345.2000	112	90	320	70
	1130		427	.31	3.5	354.6000	112	90	320	70
	1140		428	.31	3.5	364.9000	117	92	320	70
	1150		428	.31	3.5	375.2000	117	92	320	70
	1159		428	.31	3.5	385.6025	114	92	320	70
TOTAL	59					61.0000		AVG.	AVG.	
AVERAGE								AVG.		

PARTICULATE CALCULATION SHEET

Test Crew _____

Test No. 201-12 Date 5-25-76 Location _____
 Box No. _____ Sample Probe Position _____
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final _____
 Initial _____
 Total _____

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	172	130	3	689.82	
Initial	100	100	0	669.00	
Δ Vol	72	30	3	20.82	125.82

Beaker No. <u>17</u> <u>14</u> <u>15</u>					Filter No. <u>6</u>	Blank No. <u>7</u>
Date Weighed						
Tare	1	85.9074	84.6185	77.4904		
Wt.	2	85.9078	84.6184	77.4904	.5851	.5849
	3				.5851	.5849
	4					
	5					
	6					
Avg		85.9076	84.6185	77.4904	.5851	.5849
Bottle No.						
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)	
Rinse (ml)						
Date Weighed or 250 Bake						
Final	1	85.9681	84.6451	77.5356	.7620	.5849
Wt. 250	2	85.9683	84.6451	77.5357	.7621	.5849
	3	85.9684			.7624	
	4					
	5					
	6					
Avg		85.9683	84.6451	77.5357	.7622	.5849
Residue wt						
Final 250-Tare			.0266	.0453	.1771	0
Date Weighed or 650 Bake						
Final	1					
Wt. 650	2					
	3					
	4					
	5					
	6					
Avg						
Residue Wt						
Final 650-Tare						

Comments:

Data Sheet 6002-3

PARTICULATE EMISSION CALCULATIONS

Test No. 201-12 Date 5-25-76 Location _____ Engr. _____

Unit No. _____ Fuel _____ Sampling Train and Method _____

Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 29.93 in. Hg

Tot. Liquid Collected, V_{lc} 125.82 ml Total Particulate, M_n 309.7 mg

Velocity Head, ΔP .31 iwg Stack Temp., T_s 887 °R Stack Area, A_s 7.47 ft²

Sample Volume, V_m 6.0 ft³ Stack Press., P_{sg} 0.09 iwg Excess O₂, $XO_2\%$ 1.55 %

Orifice Press. Diff., H 3.5 iwg Stack Gas Sp. Gravity, G_s 1 n.d.

Sample Time, θ 59 min Nozzle Dia., D_n 3/8 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 61.50 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 5.96 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.088 N.D.
4. Concentration
 - a. $C = 0.0154 M_n / V_{m_{std}}$ 0.0776 grains/DSCF
 - b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 1.11×10^{-5} lb/DSCF
 - c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$.1779 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 407.1 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P T_s} \sqrt{\frac{407}{P_s} \times \frac{1.00}{G_s}}$ 2394 ft/min
7. Stack Gas Flow
 - a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 10,690 WSCF/min
 - Rate @ 70°F
 - b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 9,750 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 6.49 lb/hr
9. XO₂ factor $XO_{2f} = 2090 / (20.9 - XO_2\%)$ 108.0 N.D.
10. Emission
 - a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.110 lb/MMBtu
 - b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 47.6 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 104.2 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

PLANT 38
 LOCATION 38
 OPERATOR _____
 DATE 5-25-76
 RUN NO. 202-4
 SAMPLE BOX NO. _____
 METER BOX NO. EN 45-1
 METER H _____
 C FACTOR @ _____

METHOD 5 CONTROL CONSOLE READINGS



AMBIENT TEMPERATURE _____
 BAROMETRIC PRESSURE _____
 ASSUMED MOISTURE, % _____
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. _____
 NOZZLE DIAMETER, IN. 3/8
 PROBE HEATER SETTING _____

SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P _s), In. Hg.	Stack Temperature (T _s) °F	Velocity Head (P _s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V _m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet (T _{min.}) °F	Outlet (T _{mout}) °F		
LOWER EAST	1515		550	.34	3.3	414.2005	68	67	320	50
STACK IN 20"	1525		550	.34	3.3	423.0000	74	67	320	50
	1535		550	.34	3.3	433.9000	75	67	320	50
	1545		550	.34	3.3	444.4000	77	67	320	50
	1555		550	.34	3.3	453.5000	77	67	320	50
	1605		550	.34	3.3	463.4000	78	67	320	50
	1618		550	.34	3.3	475.2005				
TOTAL						61.0		AVG.	AVG.	
AVERAGE								AVG.		

358

PARTICULATE CALCULATION SHEET

Test No. 202-4 Date 5-25-76 Location _____ Test Crew _____
 Box No. _____ Sample Probe Position _____
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final _____
 Initial _____
 Total _____

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	204	117	2	629.30	
Initial	180	100	0	614.62	
Δ Vol	104	17	2	14.68	137.68

Beaker No. <u>20</u> <u>18</u> <u>19</u>					Filter No. <u>7</u>	Blank No. <u>8</u>
Date Weighed					.5849	.5770
Tare	1	102.0406	103.1827	86.5893	.5849	.5772
Wt.	2	102.0408	103.1833	86.5894		
	3					
	4					
	5					
	6					
Avg		102.0407	103.1825	86.5894	.5849	.5771
Bottle No.						
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)	
Rinse (ml)						
Date Weighed or 250 Bake						
Final	1	102.1437	103.2023	86.6395	.7464	.5771
Wt. 250	2	102.1440	103.2025	86.6396	.7464	.5771
	3	102.1441	103.2024		.7466	
	4					
	5					
	6					
Avg		102.1439	103.2024	86.6396	.7465	.5771
Residue wt						
Final 250-Tare		.1032	.0199	.0502	.1616	0
Date Weighed or 650 Bake						
Final	1					
Wt. 650	2					
	3					
	4					
	5					
	6					
Avg						
Residue Wt						
Final 650-Tare						

Comments:

Data Sheet 6002-3

PARTICULATE EMISSION CALCULATIONS

Test No. 202-4 Date 5-25-76 Location 38 Engr. _____
 Unit No. _____ Fuel _____ Sampling Train and Method _____
 Pitot Factor, F_s .83 Barometric Pressure, P_{bar} 29.93 in. Hg
 Tot. Liquid Collected, V_{lc} 137.68 ml Total Particulate, M_n 334.9 mg
 Velocity Head, ΔP .34 iwg Stack Temp., T_s 1010 °R Stack Area, A_s 7.47 ft²
 Sample Volume, V_m 61.0 ft³ Stack Press., P_{sg} 0.09 iwg Excess O₂, XO_2 % 2.6 %
 Orifice Press. Diff., H 3.3 iwg Stack Gas Sp. Gravity, G_s 1 n.d.
 Sample Time, θ 63 min Nozzle Dia., D_n 3/8 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 61.47 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 6.53 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2}/(\text{Eq. 1} + \text{Eq. 2})$ 0.096 N.D.
4. Concentration a. $C = 0.0154 M_n/V_{m_{std}}$ 0.084 grains/DSCF
 b. $C = 2.205 \times 10^{-6} M_n/V_{m_{std}}$ 1.20×10^{-5} lb/DSCF
 c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 1.924×10^{-1} grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 407.1 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P T_s} \sqrt{\frac{407}{P_s} \times \frac{1.00}{G_s}}$ 2676 ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 10,490 WSCF/min
 Rate @ 70°F b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 9,483 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 6.83 lb/hr
9. XO₂ factor $XO_2^f = 2090/(20.9 - XO_2\%)$ 114.2 N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$.126 lb/MMBtu
 b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 54.38 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 100.2 %

	Oil	Gas	Coal
F_e SC Feet/10 ⁴ Btu	92.2	87.4	98.2
F_m SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

AMBIENT TEMPERATURE
BAROMETRIC PRESSURE
ASSUMED MOISTURE, %
HEATER BOX SETTING
PROBE LENGTH, IN.
NOZZLE DIAMETER, IN.
PROBE HEATER SETTING

IMPACTOR

SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P_s), In. Hg.	Stack Temperature (T_s) °F	Velocity Head (P_s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V_m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet ($T_{min.}$) °F	Outlet ($T_{mout.}$) °F		
LOWER EAST	1114		423	.32	.74	480.2024	67	64		50
STACK IN 20"	1124		422	.32	.74	485.2000	73	68		50
	1134		421	.32	.74	490.2000	76	71		50
	1144		421	.32	.74	494.8000	78	73		50
	1154		424	.32	.74	499.6000	76	73		50
	1159		424	.32	.74	502.3065	74	72		50
TOTAL								AVG.	AVG.	
AVERAGE						22.1041		AVG.		

Test No. 38

CASCADE IMPACTOR DATA SHEET

TEST RUN NO. 201-13 LOCATION 38 DATE MAY 26, 1976
 IMPACTOR NO. _____ CYCLONE NO. NONE OPERATOR R. P. Sr.
 SAMPLE POINT LOCATION STACK LOWER EAST PORT
 SUBSTRATE COATING NONE FUEL _____ TEST LOAD _____ klb/hr
 IMPACTOR ORIENTATION NOZZLE DOWN FLOW THRU IMPACTOR _____ CFM
 FLUE STATIC PRESSURE _____ in H₂O, VELOCITY _____
 NOZZLE DIA. 1/4 INCH IMPACTOR PRESSURE DROP _____ END TIME _____
 GAS METER END _____ CF START TIME _____
 GAS METER START _____ CF DURATION 45 MIN.
 GAS VOLUME 22,1041 CF FLOW RATE _____ CFM
 AMBIENT TEMPERATURE _____ °F PRESSURE _____ IN Hg. HUMIDITY _____ %
 FLUE GAS MOLECULAR WT. _____, TEMP. _____ °F, DENSITY _____ g/cc, VISCOSITY _____ POISE

	Stage Number						Stage Blank
	1	2	3	4	5	6	
Foil + Sample, g	.7511	.7652	.7637	.7466	.7480	.7523	.7595
Unused Foil, g	.7476	.7594	.7583	.7441	.7470	.7516	.7595
Sample, g	.0035	.0058	.0054	.0025	.0010	.0007	0
Correction for Blank, g	0	0	0	0	0	0	
Final Sample, g	.0035	.0058	.0054	.0025	.0010	.0007	

FILTER NO.	6	7
	Sample	Blank
FILTER + SAMPLE, g	.1621	.1341
FILTER TARE, g	.1375	.1342
SAMPLE, g	.0246	0
CORRECTION FOR BLANK, g	0	
FINAL SAMPLE, g	.0246	


FULL CONTAINER, g _____

EMPTY CONTAINER, g _____

CYCLONE CATCH, g NONE

PLANT 38
 LOCATION 38
 OPERATOR _____
 DATE 5-26-76
 RUN NO. 202-5
 SAMPLE BOX NO. _____
 METER BOX NO. EN-45-1
 METER H _____
 C FACTOR @ _____

METHOD 5 CONTROL CONSOLE READINGS



AMBIENT TEMPERATURE _____
 BAROMETRIC PRESSURE _____
 ASSUMED MOISTURE, % _____
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. _____
 NOZZLE DIAMETER, IN. 1/4
 PROBE HEATER SETTING _____

IMPACTOR

SCHEMATIC OF STACK CROSS SECTION

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P _s), In. Hg.	Stack Temperature (T _s) °F	Velocity Head (P _s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V _m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet (T _{min.}) °F	Outlet (T _{mout}) °F		
EAST LOWER	1600		530	.30	.6	724.7019	85	82		50
STACK IN 20"	1610		538	.30	.6	729.2000	80	80		50
	1620		542	.30	.6	733.3000	81	79		55
	1630		542	.30	.6	737.5000	80	78		55
	1640		546	.30	.6	741.7000	80	77		55
	1645		547	.30	.6	744.0000	80	78		55
TOTAL	45 min									
AVERAGE						19.2981		AVG.	AVG.	
								AVG.		

363

Test No. 202-5

CASCADE IMPACTOR DATA SHEET

TEST RUN NO. 202-5 LOCATION 38 DATE 5-26-76
 IMPACTOR NO. 1 CYCLONE NO. NONE OPERATOR R.P. Sr.
 SAMPLE POINT LOCATION LOUVER DOOR STAIR EAST
 SUBSTRATE COATING None FUEL TEST LOAD klb/hr
 IMPACTOR ORIENTATION NOZZLE DOWN FLOW THRU IMPACTOR CFM
 FLUE STATIC PRESSURE inH₂O, VELOCITY
 NOZZLE DIA. 1/4 INCH IMPACTOR PRESSURE DROP END TIME
 GAS METER END CF START TIME
 GAS METER START CF DURATION 45 MIN.
 GAS VOLUME 19.2981 CF FLOW RATE CFM
 AMBIENT TEMPERATURE °F PRESSURE IN Hg. HUMIDITY %
 FLUE GAS MOLECULAR WT. , TEMP. °F, DENSITY g/cc, VISCOSITY POISE

	Stage Number						Stage Blank
	1	2	3	4	5	6	
Foil + Sample, g	.7417	.7543	.7408	.7583	.7453	.7384	.7595
Unused Foil, g	.7404	.7516	.7397	.7571	.7448	.7380	.7595
Sample, g	.0013	.0027	.0011	.0012	.0005	.0004	0
Correction for Blank, g	0	0	0	0	0	0	
Final Sample, g	.0013	.0027	.0011	.0012	.0005	.0004	

FILTER NO.	7 Sample	8 Blank
FILTER + SAMPLE, g	.1607	.1350
FILTER TARE, g	.1342	.1350
SAMPLE, g	.0265	0
CORRECTION FOR BLANK, g	0	
FINAL SAMPLE, g	.0265	

FULL CONTAINER, g
 EMPTY CONTAINER, g
 CYCLONE CATCH, g NONE

PARTICULATE CALCULATION SHEET

Test Crew _____

Test No. 201-15 Date 5-27-76 Location _____
 Box No. _____ Sample Probe Position _____
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final _____
 Initial _____
 Total _____

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final	198	120	2	689.85	
Initial	100	100	0	671.80	
Δ Vol	98	20	2	18.05	138.05

Beaker No.					Filter No. 8	Blank No. 9
Date Weighed						
Tare	1	101.6364	84.6563	102.3461	.5770	.5642
Wt.	2	101.6365	84.6555	102.3461	.5772	.5642
	3					.5641
	4					
	5					
	6					
Avg		101.6365	84.6559	102.3461	.5771	.5642
Bottle No.						
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)	
Rinse (ml)						
Date Weighed or 250 Bake						
Final	1	101.6690	84.6896	102.3868	.7554	.5641
Wt. 250	2	101.6690	84.6897	102.3869	.7554	.5642
	3	101.6692		102.3868	.7556	.5644
	4					
	5					
	6					
Avg		101.6691	84.6897	102.3868	.7555	.5642
Residue wt	.0326		.0338	.0407	.1784	0
Final 250-Tare						
Date Weighed or 650 Bake						
Final	1					
Wt. 650	2					
	3					
	4					
	5					
	6					
Avg						
Residue Wt						
Final 650-Tare						

Comments:

Data Sheet 6002-3

PARTICULATE EMISSION CALCULATIONS

Test No. 201-15 Date 5-27-76 Location _____ Engr. _____

Unit No. _____ Fuel _____ Sampling Train and Method _____

Pitot Factor, F_s 0.83 Barometric Pressure, P_{bar} 30.16 in. Hg

Tot. Liquid Collected, V_{lc} 138.05 ml Total Particulate, M_n 285.5 mg

Velocity Head, ΔP .34 iwg Stack Temp., T_s 888 °R Stack Area, A_s 7.47 ft²

Sample Volume, V_m 61.0 ft³ Stack Press., P_{sg} 0.09 iwg Excess O₂, XO_2 % 1.6 %

Orifice Press. Diff., H 3.9 iwg Stack Gas Sp. Gravity, G_s 1 n.d.

Sample Time, θ 57 min Nozzle Dia., D_n 3/8 in. Meter Temp., T_m _____ °R

- *1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ 62.03 SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ 6.54 SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ 0.095 N.D.
4. Concentration
 - a. $C = 0.0154 M_n / V_{m_{std}}$ 0.0708 grains/DSCF
 - b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ 1.015×10^{-5} lb/DSCF
 - c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ 0.163 grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ 410.3 in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P / P_s} \sqrt{\frac{407}{P_s} \times \frac{1.00}{G_s}}$ 2499 ft/min
7. Stack Gas Flow
 - a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ 11,231 WSCF/min
 - b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ 10,164 DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ 6.190 lb/hr
9. XO₂ factor $XO_{2f} = 2090 / (20.9 - XO_2 \%)$ 108.3 N.D.
10. Emission
 - a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ 0.101 lb/MMBtu
 - b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ 43.7 ng/joule
11. % Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ 104.3 %

	Oil	Gas	Coal
Fe SC Feet/10 ⁴ Btu	92.2	87.4	98.2
Fm SC Meters/10 ⁴ joules	0.002475	0.002346	0.002636

*Multiply $V_{m_{std}}$ by $530/T_m$ (°R) if meter not temp. compensated.

Data Sheet 6002-4

ω
α
α

--

AMBIENT TEMPERATURE _____
 BAROMETRIC PRESSURE _____
 ASSUMED MOISTURE, % _____
 HEATER BOX SETTING _____
 PROBE LENGTH, IN. _____
 NOZZLE DIAMETER, IN. 1/4 _____
 PROBE HEATER SETTING _____

Traverse Point Number	Sampling Time (e)Min.	Static Pressure (P_s), In. Hg.	Stack Temperature (T_s) °F	Velocity Head (P_s)	Pressure Differential Across Orifice Meter (ΔH), In. H ₂ O	Gas Sample Volume (V_m) ft ³	Gas Sample Temperature at Dry Gas Meter		Sample Box Temperature °F	Temperature of Gas Leaving Condenser on Last Impinger °F
							Inlet ($T_{min.}$) °F	Outlet (T_{mout}) °F		
LOWER EAST	1400		450	.35	.78	918.7000	85	87		65
STACK IN 20"	1410		450	.35	.78	923.3000	86	86		60
	1420		450	.35	.78	928.3000	86	84		60
	1430		450	.35	.78	933.2000	86	83		60
	1440		449	.35	.78	938.3000	87	83		60
	1445		449	.35	.78	940.6068				
TOTAL	45					21.9068		AVG.	AVG.	
AVERAGE								AVG.		

Test No. 203-28

CASCADE IMPACTOR DATA SHEET

TEST RUN NO. 203-28 LOCATION 38 DATE 5-27-76
 IMPACTOR NO. 1 CYCLONE NO. NONE OPERATOR R. P. Sr.
 SAMPLE POINT LOCATION STACK LOWER EAST PORT
 SUBSTRATE COATING NONE FUEL _____ TEST LOAD _____ klb/hr
 IMPACTOR ORIENTATION _____ FLOW THRU IMPACTOR _____ CFM
 FLUE STATIC PRESSURE _____ inH₂O, VELOCITY _____
 NOZZLE DIA. 1/4 INCH IMPACTOR PRESSURE DROP _____ END TIME _____
 GAS METER END _____ CF START TIME _____
 GAS METER START _____ CF DURATION 45 MIN.
 GAS VOLUME 21.9068 CF FLOW RATE _____ CFM
 AMBIENT TEMPERATURE _____ °F PRESSURE _____ IN Hg. HUMIDITY _____ %
 FLUE GAS MOLECULAR WT. _____, TEMP. _____ °F, DENSITY _____ g/cc, VISCOSITY _____ POISE

	Stage Number						Stage Blank
	1	2	3	4	5	6	
Foil + Sample, g	.7364	.7405	.7602	.7521	.7472	.7358	.7595
Unused Foil, g	.7349	.7384	.7578	.7503	.7467	.7355	.7595
Sample, g	.0015	.0021	.0024	.0018	.0005	.0003	0
Correction for Blank, g	0	0	0	0	0	0	
Final Sample, g	.0015	.0021	.0024	.0018	.0005	.0003	

FILTER NO.	8	9
	Sample	Blank
FILTER + SAMPLE, g	.1602	.1334
FILTER TARE, g	.1350	.1335
SAMPLE, g	.0252	0
CORRECTION FOR BLANK, g	0	
FINAL SAMPLE, g	.0252	

FULL CONTAINER, g _____

EMPTY CONTAINER, g _____

CYCLONE CATCH, g NONE

Test Description:

Date: 5/26/76

Unit: _____


Fuel: _____

Absolute Static Press. in Stack (in. Hg): _____ (P_B)


Pitot Tube Coefficient: (C_p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$


NEARBY - DOWNSIDE DISTURBANCE: WINDBOX 1.2 FURNACE 1.2
INLET TEMP 76° FP SETTING 61° ID 84



Stack Cross Section


[illegible]

6002-13




SAMPLING PLANE

ED OUTLET



Stack Cross Section



Project: _____ Test Description: _____
 Date: 5/27/76 _____
 Location: 38 _____
 Unit: _____
 Test: 201-15 Personnel: _____
 Fuel: _____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_s)
 Pitot Tube Coefficient: _____ (C_p)

$$V_s = 85.48 C_p \left[\frac{T_s \Delta P}{P_s M_s} \right]^{1/2}$$

201-15 203-28
 87° 91°

Time	Traverse Point Port	Depth	Velocity Head (in. H ₂ O)	Gas Temp. (°F)	Gas Temp. (°R)	Molecular Wt.	Velocity (ft/sec)	O ₂ Conc. (% Dry)
			ΔP		T _s	M _s	V _s	
		0	.05	.025				
		2	.05					
		4	.05	.03				
		6	.05					
		8	.05	.04				
		10	.05					
		12	.05	.025				
		14	.05					
		16	.05	.03				
		18	.05	.02-.03				
		20	.05	.03				
		22	.05					
		24	.05	.025				
		26	.05					
		28	.05	.015-.025				
		30	.05					
		32	.05	.02-.03	.015-.03			
		34	.05					
		36	.05					

6002-13

Project: _____	Test Description: _____
Date: _____	
Location: <u>38</u>	
Unit: _____	
Test: <u>203-28</u>	Personnel: _____
Fuel: _____	

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_B)
 Pitot Tube Coefficient: _____ (C_p)

$$V_S = 85.48 C_P \left[\frac{T_{S\Delta P}}{P_{SM_S}} \right]^{1/2} \quad T_{16} = 100^\circ F$$

[illegible]

372

Project: _____	Test Description: _____
Date: <u>6/3/76</u>	_____
Location: <u>38</u>	_____
Unit: _____	_____
Test: <u>204-2</u>	Personnel: _____
Fuel: _____	_____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_g)
 Pitot Tube Coefficient: _____ (C_p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

[illegible][illegible]

373

Project: _____	Test Description: _____
Date: <u>6/5/76</u>	
Location: <u>38</u>	
Unit: _____	
Test: <u>204-3</u>	Personnel: _____
Fuel: _____	
Barometric Press. (in. Hg): _____	
Absolute Static Press. in Stack (in. Hg): _____	
Pitot Tube Coefficient: _____	

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

[illegible]

374


VELOCITY TRAVERSE

Project: _____ Test Description: _____
 Date: 6/3/76 _____
 Location: _____
 Unit: _____
 Test: 204-6 Personnel: _____
 Fuel: _____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_s)
 Pitot Tube Coefficient: _____ (C_p)

$$V_s = 85.48 C_p \left[\frac{T_s \Delta P}{P_s M_s} \right]^{1/2}$$

Stack Cross Section



Time	Traverse Point Port	Depth	Velocity Head (in. H ₂ O)	Gas Temp. (°F)	Gas Temp. (°R)	Molecular Wt.	Velocity (ft/sec)	O ₂ Conc. (% Dry)
			$\frac{1}{2} \Delta P$		T_s	M_s	V_s	
		1	.61 .45					
		3	.47 .36					
		5	.39 .32					
		7	.35 .30					
		9	.34 .27					
		11	.35 .25					
		13	.31 .23					
		15	.20 .18					
		17	.26 .27					
		19	.26 .30					
		21	.26 .33					
		23	.3 .34					
		25	.28 .35					
		27	.28 .34					
		29	.23 .33					
		31	.21 .22					

6002-13

Project: _____	Test Description: _____
Date: <u>6-4-76</u>	_____
Location: <u>38</u>	_____
Unit: _____	_____
Test: <u>204-7</u>	Personnel: _____
Fuel: _____	_____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_s)
 Pitot Tube Coefficient: _____ (C_p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_S M_S} \right]^{1/2}$$

SCA

[illegible]

3 7 6

VELOCITY TRAVERSE

Project: _____ Test Description: _____
 Date: 6/4/76 _____
 Location: 38 _____
 Unit: _____
 Test: 2016-8 Personnel: _____
 Fuel: _____


Barometric Press. (in. Hg): _____

Absolute Static Press. in Stack (in. Hg): 5.2 (P_a)

Pitot Tube Coefficient: _____ (C_p)

$$V_s = 85.48 C_p \left[\frac{T_s \Delta P}{P_{sM} S} \right]^{1/2}$$

Stack Cross Section



FD

Time	Traverse Point Port	Depth	Velocity Head (in. H ₂ O)		Gas Temp. (°F)	Gas Temp. (°R)	Molecular Wt.	Velocity (ft/sec)	O ₂ Conc. (% Dry)
			1	ΔP 2		T _s	M _s	V _s	
		1	.87	.59	.70	84.5			
		3	.80	.56	.65				
		5	.70	.50	.60				
		7	.61	.47	.52				
		9	.52	.45	.48				
		11	.48	.42	.47				
		13	.49	.35	.45				
		15	.46	.30	.28				
		17	.20	.37	.28				
		19	.40	.45	.38				
		21	.67	.50	.46				
		23	.56	.59	.48				
		25	.54	.70	.55				
		27	.54	.62					
		29	.62	.75					
		31	.67	.80					

6002-13

Project: _____	Test Description: _____
Date: <u>6/7/77</u>	_____
Location: <u>38</u>	_____
Unit: _____	_____
Test: <u>204-11</u>	Personnel: _____
Fuel: _____	_____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_s)
 Pitot Tube Coefficient: _____ (C_p)

$$V_S = 85.48 C_P \left[\frac{T_{SAP}}{P_{SMS}} \right]^{1/2}$$

SCA

[illegible]

378

Project: _____	Test Description: _____
Date: <u>6/7/76</u>	_____
Location: <u>38</u>	_____
Unit: _____	_____
Test: <u>204-11</u>	Personnel: _____
Fuel: _____	_____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_g)
 Pitot Tube Coefficient: _____ (C_p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

A full-page view of a blank sheet of graph paper. The grid consists of small squares formed by thin black lines. There are approximately 20 columns and 20 rows of squares visible on the page.

FD

[illegible]

379

Project: _____	Test Description: _____
Date: <u>6/7/76</u>	_____
Location: <u>38</u>	_____
Unit: _____	_____
Test: <u>204-13</u>	Personnel: _____
Fuel: _____	_____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_g)
 Pitot Tube Coefficient: _____ (C_p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

SCA

[illegible]

380

Project: _____ Test Description: _____
Date: 6/7/76 _____
Location: 38 _____
Unit: _____
Test: 204-14 Personnel: _____
Fuel: _____
Barometric Press. (in. Hg): _____
Absolute Static Press. in Stack (in. Hg): _____
Pitot Tube Coefficient: _____

A blank sheet of graph paper with a grid pattern. The grid consists of small squares formed by thin black lines. There are approximately 20 columns and 20 rows of squares. A thicker vertical line runs down the left side, creating a margin. A thicker horizontal line runs across the top, creating a header area. The rest of the page is filled with the standard grid pattern.

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

FD

[illegible]

381

Project: _____	Test Description: _____
Date: <u>6/7/76</u>	_____
Location: <u>38</u>	_____
Unit: _____	_____
Test: <u>204-14</u>	Personnel: _____
Fuel: _____	_____
Barometric Press. (in. Hg): _____	
Absolute Static Press. in Stack (in. Hg): _____	
Pitot Tube Coefficient: _____	

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

SCA

[illegible]

382


VELOCITY TRAVERSE

Project: _____ Test Description: _____
 Date: 6/7/76 _____
 Location: _____
 Unit: _____
 Test: 204-15 Personnel: _____
 Fuel: _____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_g)
 Pitot Tube Coefficient: _____ (C_p)

$$V_s = 85.48 C_p \left[\frac{T_s \Delta P}{P_s M_s} \right]^{1/2}$$

Stack Cross Section




Time	Traverse Point		Velocity Head		Gas Temp.	Gas Temp.	Molecular	Velocity	O ₂
	Port	Depth	(in. H ₂ O)		(°F)	(°R)	Wt.	(ft/sec)	(% Dry)
		in.	(1) ΔP	(2)		T _s	M _s	V _s	
		1	.69	.52	.51				
		5	.56	.39					
		9	.43	.36	.35				
		13	.35	.36					
	FD	17	.22	.36	.34				
		21	.29	.39					
		25	.31	.38	.35				
		29	.43	.49					
		31	.44	.46	.47				
		#7	#7	#18					
		.4	.19	.14					
		1.5	.16	.17					
	SCA	3.0	.16	.19					
		7	.16	.17					
		8.5	.15	.16					
		9.1	.11	.14					

6002-13

VELOCITY TRAVERSE

Project: _____ Test Description: _____
 Date: 6/7/76 _____
 Location: _____
 Unit: _____
 Test: 204-16 Personnel: _____
 Fuel: _____
 Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_s)
 Pitot Tube Coefficient: _____ (C_p)

Stack Cross Section



$$V_s = 85.48 C_p \left[\frac{T_s \Delta P}{P_{sM} S_s} \right]^{1/2}$$

Time	Traverse Point Port	Depth in.	Velocity Head (in. H ₂ O) ① ΔP ②	Gas Temp. (°F)	Gas Temp. (°R) T _s	Molecular Wt. M _s	Velocity (ft/sec) V _s	O ₂ Conc. (% Dry)
		1	.62 .46					
		5	.57 .38					
		9	.43 .32					
		13	.37 .32					
	FD	17	.29 .31					
		21	.30 .30					
		25	.22 .33					
		29	.26 .38					
		31	.32 .36					
			#7 #8					
		.4	.14					
		1.5	.16					
	SCA	3.0	.18					
		7	.17					
		8.5	.16					
		9.1	.13					


6002-13

VELOCITY TRAVERSE

Project: _____ Test Description: _____
 Date: 6/7/76 _____
 Location: _____
 Unit: _____
 Test: 204-17 Personnel: _____
 Fuel: _____
 Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_S)
 Pitot Tube Coefficient: _____ (C_P)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_S M_S} \right]^{1/2}$$

Stack Cross Section



Time	Traverse Point Port	Depth	Velocity Head (in. H ₂ O)	Gas Temp. (°F)	Gas Temp. (°R)	Molecular Wt.	Velocity (ft/sec)	O ₂ Conc. (% Dry)
		in.	① ΔP ②		T _S	M _S	V _S	
		1	.61 .38					
		5	.37 .30					
		9	.31 .27					
		13	.30 .26					
		17	.24 .26					
		21	.26 .32					
		25	.25 .33					
		29	.23 .27					
		31	.23 .25					
		#17						
		.4	.13					
		1.5	.16					
		3.0	.18					
		7	.18					
		8.5	.17					
		9-1	.13					

6002-13

Project: _____	Test Description: _____
Date: <u>6/8/76</u>	_____
Location: _____	_____
Unit: _____	_____
Test: <u>205-6</u>	Personnel: _____
Fuel: _____	_____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_s)
 Pitot Tube Coefficient: _____ (C_p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

BYPASS DUCT
FULL OPEN

A blank 20x20 grid for graphing, consisting of 20 columns and 20 rows of squares.

[illegible]

386

Project: _____ Test Description: _____
Date: 6/8/76 _____
Location: _____
Unit: _____
Test: 205-7 Personnel: _____
Fuel: _____
Barometric Press. (in. Hg): _____
Absolute Static Press. in Stack (in. Hg): _____
Pitot Tube Coefficient: _____

[illegible]

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{SM} S} \right]^{1/2} \quad \frac{1}{2} \text{ BYPASS}$$

[illegible]

387

Project: _____	Test Description: _____
Date: <u>6/8/76</u>	_____
Location: _____	_____
Unit: _____	_____
Test: <u>205/4-8</u>	Personnel: _____
Fuel: _____	_____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_s)
 Pitot Tube Coefficient: _____ (C_p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_S M_S} \right]^{1/2}$$

[illegible]

388

Project: _____ Test Description: _____
Date: 6/8/76 _____
Location: _____
Unit: _____
Test: 205/4-8 _____ Personnel: _____
Fuel: _____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_g)
 Pitot Tube Coefficient: _____ (C_p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

[illegible][illegible]

389

Project: _____	Test Description: _____
Date: <u>6-9-76</u>	_____
Location: _____	_____
Unit: _____	_____
Test: <u>2006-15</u>	Personnel: _____
Fuel: _____	_____
Barometric Press. (in. Hg): _____	
Absolute Static Press. in Stack (in. Hg): _____	
Pitot Tube Coefficient: _____	

A blank 20x20 grid for graphing, consisting of 20 columns and 20 rows of squares.

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_{S M S}} \right]^{1/2}$$

[illegible]

390

Project: _____ Test Description: _____
Date: 6/10/76 _____
Location: _____
Unit: _____
Test: 204-21 _____ Personnel: _____
Fuel: _____
Barometric Press. (in. Hg): _____
Absolute Static Press. in Stack (in. Hg): _____
Pitot Tube Coefficient: _____

A blank sheet of graph paper with a grid pattern. The grid consists of small squares formed by thin black lines. There are approximately 20 columns and 20 rows of squares. A thicker vertical line runs down the left side, creating a margin. A thicker horizontal line runs across the middle, dividing the page into two equal halves.

$$V_S = 85.48 C_P \left[\frac{T_{SAP}}{P_{SMS}} \right]^{1/2}$$

[illegible]

391


VELOCITY TRAVERSE

Project: _____ Test Description: _____
 Date: 6/10/76 _____
 Location: _____
 Unit: _____
 Test: 204-22 Personnel: _____
 Fuel: _____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_a)
 Pitot Tube Coefficient: _____ (C_p)

$$V_s = 85.48 C_p \left[\frac{T_s \Delta P}{P_s M_s} \right]^{1/2}$$

Stack Cross Section




Time	Traverse Point Port	Depth	Velocity Head (in. H ₂ O)	Gas Temp. (°F)	Gas Temp. (°R)	Molecular Wt.	Velocity (ft/sec)	O ₂ Conc. (% Dry)
			#17 ΔP #18		T _s	M _s	V _s	
		.4	.18 .21					
		1.5	.24 .24					
		3.0	.25 .26					
		7.0	.25 .25					
		8.5	.24 .24					
		9.6	.19 .22					
			① ②					
		1"	.61 .47					
		5	.42 .36					
		9	.36 .31					
		13	.33 .30					
	FD	17	.22 .32					
		21	.27 .34					
		25	.30 .37					
		29	.32 .21					
		33	.33 .38					

6002-13

VELOCITY TRAVERSE

Project: _____ Test Description: _____
 Date: 6/10/76 _____
 Location: _____
 Unit: _____
 Test: 204-25 Personnel: _____
 Fuel: _____
 Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): _____ (P_s)
 Pitot Tube Coefficient: _____ (C_p)

Stack Cross Section



$$V_s = 85.48 C_p \left[\frac{T_s \Delta P}{P_s M_s} \right]^{1/2}$$

Time	Traverse Point Port	Depth	Velocity Head (in. H ₂ O)	Gas Temp. (°F)	Gas Temp. (°R)	Molecular Wt.	Velocity (ft/sec)	O ₂ Conc. (% Dry)
			#17 ΔP #18		T _s	M _s	V _s	
		.4	.34 .44					
		1.5	.47 .49					
		3.0	.51 .54					
		7.0	.50 .52					
		8.5	.45 .47					
		9.6	.34 .39					
		1"	.55					
		3"	.61					
		5	.63					
		7	.59					
		9	.67					
		11	.66					
		13	.59					
		15	.59					
		17	.70					
		18	.67					

EXPANSION
DUCT

6002-13

Project: _____	Test Description: _____
Date: <u>6/16/76</u>	_____
Location: _____	_____
Unit: _____	_____
Test: <u>204/5-29</u>	Personnel: _____
Fuel: _____	_____

Barometric Press. (in. Hg): _____
 Absolute Static Press. in Stack (in. Hg): 2.1 (P_B)
 Pitot Tube Coefficient: _____ (C_p)

$$V_S = 85.48 C_P \left[\frac{T_S \Delta P}{P_S M_S} \right]^{1/2}$$

Time	Traverse Point Port Depth	Velocity Head (in. H ₂ O)	Gas Temp. (°F)	Gas Temp. (°R)	Molecular Wt.	Velocity (ft/sec)	O ₂ Conc. (% Dry)
		#17LP #18		T _S	M _S	V _S	
		.39 .41	95°				
		.47 .47					
		.48 .48					
		.48 .48					
		.45 .44					
		.33 .40					
		1 .56					
		3 .61					
		5 .60					
		7 .56					
		9 .61					
		11 .64					
		13 .65					
		15 .60					
		17 .66					

394

STAGED COMBUSTION AIR FLOW DATA

KVB

Test No. _____

Test No. 203-26 Date 5/20/76 Test Type _____Boiler No. _____ Location No. 38 Capacity _____ 10^3 lb/hr Burner Type _____Test Fuel No 6 Test Load _____ 10^3 lb/hr P_{∞} 29.720"

PITOT TRAVERSE @ 11.45

5/27

Test No.	203-26	DIST INTG DUCT	TEST 17	POINT 17	TEST 18	POINT 18				203 -28	
Windbox °F/iwg		.4"	.16 .15	AVG. .155	.18 .21	.21 .20	AVG .205				
T ₁ /P ₁		1.5	.16 .17	.165	.18 .23	.24 .23	.23				
T ₂ /P ₂		3.0	.18 .18	.18	.19 .24	.23 .24	.23				
T ₃ /P ₃		7.0	.18 .17	.175	.20 .23	.24 .24	.23				
T ₄ /P ₄		8.5	.16 .16	.16	.19 .23	.21 .22	.22				
Furnace °F/iwg		9.1	.13 .12	.125	.15 .17	.13 .18	.16				
		AVFC.		.16			.213				
SC Ports °F/iwg											
T ₆ /P ₆											
T ₇ /P ₇											
T ₈ /P ₈											
T ₉ /P ₉											
T ₁₀ /P ₁₀											
T ₁₁ /P ₁₁											
T ₁₂ /P ₁₂											
T ₁₃ /P ₁₃											
T ₁₄ /P ₁₄ iwq	15									15	
T ₁₅ /P ₁₅	14									14	
T ₁₆ /P ₁₆	103									100	
T ₁₇ /P ₁₇	102										
T ₁₈ /P ₁₈											
T ₁₉ /P ₁₉											
T ₂₀ /P ₂₀											

4/76
60-32

STAGED COMBUSTION AIR FLOW DATA

KVB

Test No. _____

Test No. 203-27 Date 5/21/76 Test Type _____

Boiler No. _____ Location No. _____ Capacity _____ 10^3 lb/hr Burner Type _____

Test Fuel No 6 Test Load _____ 10^3 lb/hr

Test No.	POINT #17 ΔP			#13 ΔP									
Windbox °F/iwg	<u>.4"</u>	<u>.11</u>	<u>.12</u>	<u>.115</u>	<u>.16</u>	<u>.15</u>	<u>.155</u>						
T ₁ /P ₁	<u>1.5</u>	<u>.15</u>	<u>.16</u>	<u>.155</u>	<u>.17</u>	<u>.17</u>	<u>.17</u>						
T ₂ /P ₂	<u>3</u>	<u>.15</u>	<u>.16</u>	<u>.155</u>	<u>.18</u>	<u>.18</u>	<u>.18</u>						
T ₃ /P ₃	<u>7</u>	<u>.16</u>	<u>.15</u>	<u>.155</u>	<u>.19</u>	<u>.18</u>	<u>.185</u>						
T ₄ /P ₄	<u>8.5</u>	<u>.14</u>	<u>.14</u>	<u>.14</u>	<u>.14</u>	<u>.16</u>	<u>.15</u>						
Furnace °F/iwg	<u>9.1</u>	<u>.08</u>	<u>.10</u>	<u>.09</u>	<u>.13</u>	<u>.12</u>	<u>.125</u>						
AVG.				<u>.135</u>			<u>.161</u>						
SC Ports °F/iwg													
T ₆ /P ₆													
T ₇ /P ₇	<u>P_∞ 22.60"</u>												
T ₈ /P ₈	<u>CONTROL RM.</u>												
T ₉ /P ₉	<u>T DRY 83</u>												
T ₁₀ /P ₁₀	<u>WET 68</u>												
T ₁₁ /P ₁₁	<u>R.H. 50</u>												
T ₁₂ /P ₁₂													
T ₁₃ /P ₁₃													
T ₁₄ /P ₁₄													
T ₁₅ /P ₁₅													
T ₁₆ /P ₁₆													
T ₁₇ /P ₁₇													
T ₁₈ /P ₁₈													
T ₁₉ /P ₁₉													
T ₂₀ /P ₂₀													

STAGED COMBUSTION AIR FLOW DATA

KVBTest No. 204-Test No. 204-2 Date 6/3/76, 6/4 Test Type _____Boiler No. _____ Location No. _____ Capacity 45 10³ lb/hr Burner Type RUGTest Fuel N. GAS Test Load 38 10³ lb/hr

Test No.	204-1	204-2	204-3	204-4	204-5	204-6	204-7						
Windbox °F/iwg													
T ₁ /P ₁													
T ₂ /P ₂													
T ₃ /P ₃													
T ₄ /P ₄													
Furnace °F/iwg													
SC Ports °F/iwg													
T ₆ /P ₆					15.5		15.5						
T ₇ /P ₇					100/15		100/14.5						
T ₈ /P ₈				1/15									
T ₉ /P ₉				100/15.5									
T ₁₀ /P ₁₀			1/17										
T ₁₁ /P ₁₁			102/15										
T ₁₂ /P ₁₂		92/15											
T ₁₃ /P ₁₃		15											
T ₁₄ /P ₁₄													
T ₁₅ /P ₁₅													
T ₁₆ /P ₁₆		96/21	104/21	1/21			102/21						
T ₁₇ /P ₁₇													
T ₁₈ /P ₁₈													
T ₁₉ /P ₁₉													
T ₂₀ /P ₂₀													

STAGED COMBUSTION AIR FLOW DATA

KVB

Test No. _____

Test No. 204-10 Date 6/7/76 Test Type SCA
 Boiler No. _____ Location No. 58 Capacity 45 10^3 lb/hr Burner Type FLNG
 Test Fuel N.G. Test Load _____ 10^3 lb/hr

Test No.		204-10	204-11	204-12	204-13	204-14	204-15	-16	-17			
Windbox °F/iwg												
T ₁ /P ₁												
T ₂ /P ₂												
T ₃ /P ₃												
T ₄ /P ₄												
Furnace °F/iwg												
SC Ports °F/iwg												
T ₆ /P ₆					9.0	7.5	15.5	15.5	15.2			
T ₇ /P ₇				15.0	8.9	7.0	15.0	15.0	14.9			
T ₈ /P ₈			15.0									
T ₉ /P ₉			15.0									
T ₁₀ /P ₁₀												
T ₁₁ /P ₁₁												
T ₁₂ /P ₁₂												
T ₁₃ /P ₁₃												
T ₁₄ /P ₁₄			15.5									
T ₁₅ /P ₁₅			13.5									
T ₁₆ /P ₁₆ °F/iwg			102/21	106		108	110	109	109	109		
T ₁₇ /P ₁₇				20.8		12.2	10.0	20.5	20.7	20.5		
T ₁₈ /P ₁₈												
T ₁₉ /P ₁₉												
T ₂₀ /P ₂₀												

STAGED COMBUSTION AIR FLOW DATA

KVB

Test No. _____

Test No. 204 8-26 Date 6/9-6/10/76 Test Type _____Boiler No. _____ Location No. 38 Capacity _____ 10^3 lb/hr Burner Type 146Test Fuel NAT. GAS Test Load ~40 10^3 lb/hr

Test No.	204-14-8	204-18	204-19	204-20	204-21	204-22	-23	-24	-25	-26
Windbox °F/iwg										
T ₁ /P ₁										
T ₂ /P ₂										
T ₃ /P ₃										
T ₄ /P ₄										
Furnace °F/iwg										
SC Ports °F/iwg										
T ₆ /P ₆	15.5									
T ₇ /P ₇	14.9									
T ₈ /P ₈										
T ₉ /P ₉										
T ₁₀ /P ₁₀										
T ₁₁ /P ₁₁										
T ₁₂ /P ₁₂					0.1	14.0		0	1.5	11.0
T ₁₃ /P ₁₃					0.1	14.0		-0.1	1.5	11.0
T ₁₄ /P ₁₄		15.2	15.5	15.4	15.0	0		15.0	14.0	12.0
T ₁₅ /P ₁₅		13.2	13.2	13.2	12.8	0		13.0	12.3	10.0
T ₁₆ /P ₁₆	114/20.5	112/	114/	114/	110/	110		117	118	116
T ₁₇ /P ₁₇						19.8				
T ₁₈ /P ₁₈	20.5	20.4	20.4	20.4	19.9	19.8		20	19	16
T ₁₉ /P ₁₉										
T ₂₀ /P ₂₀										

KVB

Test No. _____ Date 6/10/76 Test Type _____

Boiler No. _____ Location No. 38 Capacity _____ 10^3 lb/hr Burner Type RING

Test Fuel NAT. GAS Test Load ≈ 40 10³ lb/hr

4/76
60-32

TECHNICAL REPORT DATA
(Please read Instructions on the reverse before completing)

1. REPORT NO. EPA-600/7-78-099b		2.		3. RECIPIENT'S ACCESSION NO.	
4. TITLE AND SUBTITLE Emission Reduction on Two Industrial Boilers with Major Combustion Modifications (Data Supplement)				5. REPORT DATE December 1978	
				6. PERFORMING ORGANIZATION CODE	
7. AUTHOR(S) K. T. Fisher, J. J. Buening, W. A. Carter, and S. C. Hunter				8. PERFORMING ORGANIZATION REPORT NO. KVB 6004-734a	
9. PERFORMING ORGANIZATION NAME AND ADDRESS KVB, Inc. 17332 Irvine Boulevard Tustin, California 92680				10. PROGRAM ELEMENT NO. EHE624A	
				11. CONTRACT/GRANT NO. 68-02-2144	
12. SPONSORING AGENCY NAME AND ADDRESS EPA, Office of Research and Development Industrial Environmental Research Laboratory Research Triangle Park, NC 27711				13. TYPE OF REPORT AND PERIOD COVERED Supplement; 1/76 - 1/78	
				14. SPONSORING AGENCY CODE EPA/600/13	
15. SUPPLEMENTARY NOTES IERL-RTP project officer is Robert E. Hall, Mail Drop 65, 919/541-2477. The supplement documents detailed test data reported in the final report, EPA-600/7-78-099a.					
16. ABSTRACT The report provides raw data from a study of the effects on air pollutant emissions of extensive combustion modifications on two industrial boilers. The supplement is intended for researchers who wish to perform their own detailed calculations.					
17. KEY WORDS AND DOCUMENT ANALYSIS					
a. DESCRIPTORS		b. IDENTIFIERS/OPEN ENDED TERMS		c. COSATI Field/Group	
Air Pollution	Particle Size	Air Pollution Control	13B	14B	
Combustion	Flue Gases	Stationary Sources	21B		
Boilers	Circulation	Combustion Modification	13A		
Burners	Fuel Oil	Industrial Boilers			
Nitrogen Oxides	Natural Gas	Particulate; Excess Air	07B		
Smoke	Trace Elements	Staged Combustion		06A	
Fossil Fuels	Organic Compounds	Trace Species	21D	07C	
18. DISTRIBUTION STATEMENT Unlimited		19. SECURITY CLASS (This Report) Unclassified		21. NO. OF PAGES 411	
		20. SECURITY CLASS (This page) Unclassified		22. PRICE	