

Research and Development

ENVIRONMENTAL ASSESSMENT
OF A COMMERCIAL BOILER FIRED WITH
A COAL/WASTE PLASTIC MIXTURE
Volume II. Data Supplement

Prepared for

Office of Air Quality Planning and Standards

Prepared by

Air and Energy Engineering Research
Laboratory
Research Triangle Park NC 27711

RESEARCH REPORTING SERIES

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into nine series. These nine broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and a maximum interface in related fields. The nine series are:

1. Environmental Health Effects Research
2. Environmental Protection Technology
3. Ecological Research
4. Environmental Monitoring
5. Socioeconomic Environmental Studies
6. Scientific and Technical Assessment Reports (STAR)
7. Interagency Energy-Environment Research and Development
8. "Special" Reports
9. Miscellaneous Reports

This report has been assigned to the INTERAGENCY ENERGY-ENVIRONMENT RESEARCH AND DEVELOPMENT series. Reports in this series result from the effort funded under the 17-agency Federal Energy/Environment Research and Development Program. These studies relate to EPA's mission to protect the public health and welfare from adverse effects of pollutants associated with energy systems. The goal of the Program is to assure the rapid development of domestic energy supplies in an environmentally-compatible manner by providing the necessary environmental data and control technology. Investigations include analyses of the transport of energy-related pollutants and their health and ecological effects; assessments of, and development of, control technologies for energy systems; and integrated assessments of a wide range of energy-related environmental issues.

EPA REVIEW NOTICE

This report has been reviewed by the participating Federal Agencies, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the Government, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

This document is available to the public through the National Technical Information Service, Springfield, Virginia 22161.

February 1985

ENVIRONMENTAL ASSESSMENT OF A COMMERCIAL BOILER
FIRED WITH A COAL/WASTE PLASTIC MIXTURE

Volume II
Data Supplement

By

R. DeRosier, H. I. Lips, and L. R. Waterland
Acurex Corporation
Energy & Environmental Division
555 Clyde Avenue
P.O. Box 7555
Mountain View, California 94039

EPA Contract 68-02-3188

EPA Project Officer: Joseph A. McSorley
Air and Energy Engineering Research Laboratory
Research Triangle Park, North Carolina 27711

For

U.S. ENVIRONMENTAL PROTECTION AGENCY
Office of Research and Development
Washington, DC 20460

CONTENTS

<u>Section</u>	<u>Page</u>
1 Introduction	1-1
2 Preliminary Tests and Equipment Calibration	2-1
3 Boiler Operating Data	3-1
4 Sampling Data Sheets	4-1
4.1 Continuous Monitor Emission Data	4-3
4.2 Field Data Sheets for EPA Method 5/8, SASS, HCl, and VOST Trains	4-19
5 Analytical Results	5-1
5.1 Fuel and Ash Sample Proximate and Ultimate Analyses	5-3
5.2 Particulate Emissions from SASS Samples	5-7
5.3 Particulate and Sulfur Oxides Emissions from EPA Method 5/8 Samples	5-15
5.4 HCl Emissions from HCl Train Samples	5-25
5.5 Trace Element and Leachable Anion Analyses	5-35
5.6 Total Chromatographable Organics (TCO), Gravimetric Organics (GRAV), Gas Chromatography/ Mass Spectrometry (GC/MS), and Infrared Spectra (IR) of Total Sample Extracts	5-83
5.7 Liquid Chromatography (LC) Separation and IR Spectra of LC Fractions	5-97
5.8 GC/MS Analyses of VOST Traps	5-141
5.9 N ₂ O Analyses by GC/ECD	5-145
5-10 Bioassay Results	5-149

SECTION 1

INTRODUCTION

The purpose of this data supplement is to document data in greater detail than was possible in Volume I (Technical Results) of this report. It is intended to provide sufficient detail for researchers to perform their own analysis of the data obtained. Readers are referred to the technical volume for objectives, description of source emission results, data interpretation, and conclusions.

The remaining sections of this data supplement contain the following information:

Section 2 -- Preliminary Tests and Equipment Calibration: stack velocity traverse and nozzle sizing calculations, equipment calibration records

Section 3 -- Boiler Operating Data: pressures, temperatures, and flowrates; efficiency calculations using the ASME heat loss method

Section 4 -- Sampling Data Sheets: continuous monitor data sheets; operating data tables for EPA Method 5/8 (for particulate mass emissions, SO₂ and SO₃ sampling), SASS (for trace element and semi- and nonvolatile organic sampling), HCl train, and VOST (for volatile organic sampling)

Section 5 -- Analytical Results: fuel and ash sample proximate and ultimate analyses; SASS particulate emissions; Method 5 particulate

emissions; Method 8 sulfur oxides emissions; HCl emissions; trace element emissions by spark source mass spectrometry (SSMS), atomic absorption spectroscopy (AAS), and other methods, and leachable anions analyses by ion chromatography; total chromatographable organic (TCO) and gravimetric (GRAV) results, determination of semivolatile organic priority pollutants by gas chromatography/mass spectrometry (GC/MS), infrared (IR) spectra of total sample extracts; liquid chromatography (LC) separation results with IR spectra of eluted fractions; analyses of VOST traps by GC/MS; N₂O analyses by gas chromatography/electron capture detector; and biological assay reports.

SECTION 2
PRELIMINARY TESTS AND EQUIPMENT CALIBRATION

TRAVERSE POINT LOCATION FOR CIRCULAR DUCTS



PLANT _____
DATE _____
SAMPLING LOCATION _____
INSIDE OF FAR WALL TO
OUTSIDE OF NIPPLE. (DISTANCE A) _____
INSIDE OF NEAR WALL TO
OUTSIDE OF NIPPLE. (DISTANCE B) _____
STACK I.D., (DISTANCE A - DISTANCE B) _____
NEAREST UPSTREAM DISTURBANCE _____
NEAREST DOWNSTREAM DISTURBANCE _____
CALCULATOR _____

SCHEMATIC OF SAMPLING LOCATION


[illegible]

Look at 1-26 [HRC, VA. - 1-1 - 100% SCHEMATIC]

CC 100%
- 5-15



1'12" (SCHEMATIC)



PRELIMINARY VELOCITY TRAVERSE

PLANT _____
DATE _____
LOCATION _____
STACK I.D. _____
BAROMETRIC PRESSURE, in. Hg _____
STACK GAUGE PRESSURE, in. H₂O _____
OPERATORS _____

SCHEMATIC OF TRAVERSE POINT LAYOUT

TRAVERSE POINT NUMBER	VELOCITY HEAD (Δp_s), in. H ₂ O	STACK TEMPERATURE (T_s), °F
1	0.00	275
2	0.00	275
3	0.00	275
4	0.00	275
5	0.00	275
6	0.00	275
7	0.00	275
8	0.00	275
9	0.00	275
10	0.00	275
11	0.00	275
12	0.00	275
13	0.00	275
14	0.00	275
15	0.00	275
16	0.00	275
17	0.00	275
18	0.00	275
19	0.00	275
20	0.00	275
21	0.00	275
22	0.00	275
23	0.00	275
24	0.00	275
25	0.00	275
26	0.00	275
27	0.00	275
28	0.00	275
29	0.00	275
30	0.00	275
31	0.00	275
32	0.00	275
33	0.00	275
34	0.00	275
35	0.00	275
36	0.00	275
37	0.00	275
38	0.00	275
39	0.00	275
40	0.00	275
41	0.00	275
42	0.00	275
43	0.00	275
44	0.00	275
45	0.00	275
46	0.00	275
47	0.00	275
48	0.00	275
49	0.00	275
50	0.00	275
51	0.00	275
52	0.00	275
53	0.00	275
54	0.00	275
55	0.00	275
56	0.00	275
57	0.00	275
58	0.00	275
59	0.00	275
60	0.00	275
61	0.00	275
62	0.00	275
63	0.00	275
64	0.00	275
65	0.00	275
66	0.00	275
67	0.00	275
68	0.00	275
69	0.00	275
70	0.00	275
71	0.00	275
72	0.00	275
73	0.00	275
74	0.00	275
75	0.00	275
76	0.00	275
77	0.00	275
78	0.00	275
79	0.00	275
80	0.00	275
81	0.00	275
82	0.00	275
83	0.00	275
84	0.00	275
85	0.00	275
86	0.00	275
87	0.00	275
88	0.00	275
89	0.00	275
90	0.00	275
91	0.00	275
92	0.00	275
93	0.00	275
94	0.00	275
95	0.00	275
96	0.00	275
97	0.00	275
98	0.00	275
99	0.00	275
100	0.00	275
AVERAGE	0.00	275.8

[illegible]

ISOKINETIC NOZZLE CALCULATION
AND
SAMPLING RATE CALCULATION

Plant ROCK CAGES
Date JUL 6, 1983
Sample Location SAW HOUSE
Test No./Type 1-M5-8

Performed by BARRETT

$$N_d = \left(\frac{\Delta H T_s}{K T_m \Delta P} \right)^{.25}$$

where: N_d = Nozzle diameter (inches)

Average pressure differential across the orifice meter (in. H ₂ O)	ΔH	1.5
Temperature stack gas, average (°F)	T_s	275.8
Temperature of gas meter, average (°F)	T_m	70
Stack gas velocity pressure (in H ₂ O)	ΔP	0.055
$\left(\frac{(\quad)(\quad + 460)}{(\quad)(\quad + 460)(\quad)} \right)^{.25}$	N_d	.461

$$\Delta H = K (N_d)^4 \frac{T_m}{T_s} (\Delta P)$$

where: ΔH = Pressure differential across the orifice meter (in H₂O)

Nozzle diameter, actual (inches)	N_d	.387
Temperature of gas meter (°F)	T_m	
Temperature of stack gas (°F)	T_s	
Stack gas velocity pressure (in H ₂ O)	ΔP	
$\left((\quad)(\quad)^4 \frac{(\quad + 460)}{(\quad + 460)} (\quad) \right)$	ΔH	
Magic number $(\quad)^4$	$K(N_d)^4$	

ISOKINETIC SAMPLING WORKSHEET

Plant ROCKO FALLES

Performed by BARKAL'S

Date 7/7/83

Sample Location SAIL HOUSE

Test No./Type 1-M-5-8

$$K = \frac{782.687 (C_p)^2 (1-B_{wo})^2 P_s M_d}{K_o^2 M_s P_m}$$

where: K = Contant of fixed and assumed parameters (dimensionless)

Pitot coefficient (dimensionless)	C_p	0.800
Water vapor in the gas stream (proportion by volume)	B_{wo}	0.075
Absolute stack gas pressure (in. Hg)	P_s	7.10
Molecular weight, stack gas dry (lb/lb-mole)	M_d	CO ₂ 12 O ₂ 7 N ₂ 28
Orifice coefficient (dimensionless)	K_o	0.725
Molecular weight, stack gas wet (lb/lb-mole) $M_d(1-B_{wo}) + 18(B_{wo})$	M_s	.
Abolute meter pressure (in. Hg)	P_m	27.24
$\frac{782.687 (\quad)^2 (1- \quad)^2 (\quad) (\quad)}{(\quad)^2 (\quad) (\quad)}$	K	841.373

PRELIMINARY VELOCITY TRAVERSE

PLANT _____
DATE _____
LOCATION _____
STACK I.D. _____
BAROMETRIC PRESSURE, in. Hg _____
STACK GAUGE PRESSURE, in. H₂O _____
OPERATORS _____

SCHEMATIC OF TRAVERSE POINT LAYOUT

TRAVERSE POINT NUMBER	VELOCITY HEAD (Δp_s) , in. H ₂ O	STACK TEMPERATURE (T _s), °F
	0.06	372
	0.06	322
	0.05	392
	0.05	316
	0.03	305
	0.02	274
AVERAGE	0.0467	309.2

TRAVERSE POINT NUMBER	VELOCITY HEAD (Δp_s), in. H ₂ O	STACK TEMPERATURE (T_s), °F
1	0.00	100
2	0.00	100
3	0.00	100
4	0.00	100
5	0.00	100
6	0.00	100
7	0.00	100
8	0.00	100
9	0.00	100
10	0.00	100
11	0.00	100
12	0.00	100
13	0.00	100
14	0.00	100
15	0.00	100
16	0.00	100
17	0.00	100
18	0.00	100
19	0.00	100
20	0.00	100
21	0.00	100
22	0.00	100
23	0.00	100
24	0.00	100
25	0.00	100
26	0.00	100
27	0.00	100
28	0.00	100
29	0.00	100
30	0.00	100
31	0.00	100
32	0.00	100
33	0.00	100
34	0.00	100
35	0.00	100
36	0.00	100
37	0.00	100
38	0.00	100
39	0.00	100
40	0.00	100
41	0.00	100
42	0.00	100
43	0.00	100
44	0.00	100
45	0.00	100
46	0.00	100
47	0.00	100
48	0.00	100
49	0.00	100
50	0.00	100
51	0.00	100
52	0.00	100
53	0.00	100
54	0.00	100
55	0.00	100
56	0.00	100
57	0.00	100
58	0.00	100
59	0.00	100
60	0.00	100
61	0.00	100
62	0.00	100
63	0.00	100
64	0.00	100
65	0.00	100
66	0.00	100
67	0.00	100
68	0.00	100
69	0.00	100
70	0.00	100
71	0.00	100
72	0.00	100
73	0.00	100
74	0.00	100
75	0.00	100
76	0.00	100
77	0.00	100
78	0.00	100
79	0.00	100
80	0.00	100
81	0.00	100
82	0.00	100
83	0.00	100
84	0.00	100
85	0.00	100
86	0.00	100
87	0.00	100
88	0.00	100
89	0.00	100
90	0.00	100
91	0.00	100
92	0.00	100
93	0.00	100
94	0.00	100
95	0.00	100
96	0.00	100
97	0.00	100
98	0.00	100
99	0.00	100
100	0.00	100
AVERAGE		

ISOKINETIC NOZZLE CALCULATION
AND
SAMPLING RATE CALCULATION

Plant Rock of Ages

Performed by Barlow

Date 7/8/83

Sample Location SALT HOUSE

Test No./Type 2 M-5-8

$$N_d = \left(\frac{\Delta H T_s}{K T_m \Delta P} \right)^{.25}$$

where: N_d = Nozzel diameter (inches)

Average pressure differential across the orifice meter (in. H ₂ O)	ΔH	1.5
Temperature stack gas, average (°F)	T_s	300.2
Temperature of gas meter, average (°F)	T_m	80
Stack gas velocity pressure (in H ₂ O)	ΔP	.047
$\left(\frac{(\quad)(\quad + 460)}{(\quad)(\quad + 460)(\quad)} \right)^{.25}$	N_d	.482

$$\Delta H = K (N_d)^4 \frac{T_m}{T_s} (\Delta P)$$

where: ΔH = Pressure differential across the orifice meter (in H₂O)

Nozzel diameter, actual (inches)	N_d	.387
Temperature of gas meter (°F)	T_m	
Temperature of stack gas (°F)	T_s	
Stack gas velocity pressure (in H ₂ O)	ΔP	
$\left((\quad)(\quad)^4 \frac{(\quad + 460)}{(\quad + 460)} (\quad) \right)$	ΔH	
Magic number <u>839.439</u> $(.387)^4$	$K(N_d)^4$	18.84

ISOKINETIC SAMPLING WORKSHEET

Plant ROCK OF AGES

Performed by Zakus

Date 7/8/83

Sample Location SAW ~~MAN~~ HOUSE


Test No./Type 2-M-58

$$K = \frac{782.687 (C_p)^2 (1-B_{wo})^2 P_s M_d}{K_o^2 M_s P_m}$$

where: K = Contant of fixed and assumed parameters (dimensionless)

Pitot coefficient (dimensionless)	C_p	.800
Water vapor in the gas stream (proportion by volume)	B_{wo}	.075
Absolute stack gas pressure (in. Hg)	P_s	- .10
Molecular weight, stack gas dry (lb/lb-mole)	M_d	20.2 - 7 23 - 13 M _{air} - 29
Orifice coefficient (dimensionless)	K_o	1.02 .725
Molecular weight, stack gas wet (lb/lb-mole) $M_d(1-B_{wo}) + 18(B_{wo})$	M_s	
Abolute meter pressure (in. Hg)	P_m	24.6
$\frac{782.687 (\quad)^2 (1 - \quad)^2 (\quad) (\quad)}{(\quad)^2 (\quad) (\quad)}$	K	339.939

NOZZLE MEASUREMENT



DIAMETER
DIMENSION

A _____

B _____

C _____

D _____

E _____

F _____

AVG. _____

NOZZLE SERIAL

DATE

RECORDED BY

CONTROL MODULE CALIBRATION

Module I.D. D-554
Date 5-13 / 5-16-83

Barometric Pressure (in. Hg) 30.12 - 30.16
Primary Meter I.D. _____

Ambient Temperature (°F) 70° - 67°
Operator J. A. Smith

2-12

Orifice Size	Orifice Reading ΔH (in H ₂ O)	Primary Meter Gas Volume V_p (ft ³)	Meter Box Gas Volume V_d (ft ³)	Temperature						Time t (min)	Meter Correction Factor α	Orifice Coefficient K_o			
				Primary Meter			Meter Box Meter								
				Inlet T_{pi} (°F)	Outlet T_{po} (°F)	Average T_p (°F)	Inlet T_{di} (°F)	Outlet T_{do} (°F)	Average T_d (°F)						
Small Orifice 0.187															
Medium Orifice 0.281	1.5	15.695	16.000	70	70	70	70	72	80	71	80	75.8°	37.6	1.010	0.753
	1.0	14.195	14.615	70	70	70	70	80	83	80	81	81°	24.4	1.011	0.739
	2.5	10.400	10.720	70	70	70	70	83	87	81	81	83°	11.9	1.012	0.701
	4.0	18.710	19.190	67	67	67	67	79	83	73	76	77.8°	16.9	1.015	0.705
Large Orifice 0.358															

$$\alpha = \frac{V_d (P_B + \frac{\Delta H}{13.6}) (T_p + 460)}{V_p (P_B) (T_d + 460)}$$

$$K_o = \frac{V_p}{0.0001 \sqrt{\frac{\Delta H (T_d + 460)}{P_B (28.96)}}}$$

Orifice	Avg. α	Avg. K_o
Small		
Medium	1.012	0.725
Large		

Date 4/13/82
 Time
 Barometric Pressure 29.88
 Ambient Temperature 19.5°C

Orifice Meter
 Orifice Magnhectic 81212 08 59
 Primary Calibration Meter 445598
 Control Module D 555

Operators SCHOLTZ
 Wet Bulb Temperature

METER CALIBRATION DATA

Orifice Manometer ΔH_{ref} (in. wg.)	Orifice Magnhectic ΔH_c (in. wg.)	Primary Meter ΔH_p (in. wg.)	Dry Test Meter P_{dg} (in. wg.)	Gas Volume Primary Meter V_p (ft. ³)	Gas Volume Dry Test Meter V_d (ft. ³)	Temperature						Time t (min.)	γ	K_D	16317-V	
						Primary Meter			Dry Test Meter							
						Inlet, T_{pi} (°F)	Outlet, T_{po} (°F)	Avg., T_{pa} (°F)	Inlet, T_{di} (°F)	Outlet, T_{do} (°F)	Avg., T_{da} (°F)					
	0.2															
	0.4															
# 1	0.6			964.643	360.315	64	63		73	75		20 min	0.7	sec		
	0.8			973.408	369.209	65	64		74	76						
	1.0															
# 2	1.2			974.081	369.838	64	63		73	74		20 min	0.2	sec		
	1.4			976.255	382.256	64	64		76	75						
	1.6															
# 3	1.8			1002.675	398.885	64	64		75	79		20 min	0.9	sec		
	2.0			1017.839	414.273	64	65		76	77						
	2.2															
# 4	2.4			1048.407	445.230	65	65		79	77		20 min	0.7	sec		
	2.6			1065.610	462.720	66	66		80	78						
	2.8															
	3.0															
	3.2															
	3.4															
	3.6															
	3.8															
	4.0															
	4.2															
	4.4															
	4.6															
	4.8															
	5.0															
Average																

$$\gamma = 0.9908$$

$$K_D = 0.7126$$

SECTION 3
BOILER OPERATING DATA

7-6-83

Time	Feedwater flow (total gal)	Feedwater temperature (°F)	Steam pressure (psig)	Fuel flow (lb/hr nominal setting)	Comment
430					Start fuel feed, boiler on
625	20.0	--	--	--	
645	231.1	60	7	300	
705	268.6	60	7	300	
715	281.7	60	7	300	
730	335.0	58	2	300	
750	400.0	56	2	300	
805	457.6	56	2	300	
825	552.4	56	0	300	Increase feedwater flow
840	626.0	56	0	300	
945	1,057.0	56	2	300	
1000	1,151.0	56	2	300	
1030	1,381.1	56	2	300	
1100	1,550.0	54	1.5	300	
1130	1,738.3	56	2	300	
1145	1,846.0	54	2.5	300	
1200	1,939.0	55	2.5	300	SASS start; Method 5/8 start
1215	2,044.8	54	2	300	
1230	2,148.0	54	2	300	
1245	2,217.9	54	2.5	300	
1300	2,311.2	54	3	300	
1315	2,425.7	54	3	300	Method 5/8 stop
1330	2,515.7	54	2	300	
1400	2,710.3	54	2	300	
1415	2,795.1	54	2.5	300	
1430	2,873.5	54	2	300	
1445	2,970.1	54	1.5	300	
1500	3,035.9	54	2	300	
1515	3,120.2	54	2	300	HCl start
1530	3,204.9	54	2.5	300	
1545	3,243.8	54	3	300	HCl stop
1600	3,387.8	54	3	300	
1615	3,487.5	54	2	300	
1630	3,562.1	54	2	300	
1645	3,645.4	54	2	300	SASS stop
1700	3,720.3	54	2	300	
1715	3,802.0	54	2.5	300	
1730	3,890.6	54	2	300	Terminate fuel flow

Total fuel fed = 3,094 lb. Collect 405 lb bottom ash, 12.5 lb cyclone hopper ash

SUMMARY SHEET

ASME TEST FORM
FOR ABBREVIATED EFFICIENCY TEST

PTC 4.1-a (1964)

TEST NO. 1				BOILER NO.				DATE				
OWNER OF PLANT				LOCATION								
TEST CONDUCTED BY				OBJECTIVE OF TEST				DURATION				
BOILER, MAKE & TYPE				RATED CAPACITY								
STOKER, TYPE & SIZE				BURNER, TYPE & SIZE								
PULVERIZER, TYPE & SIZE				STATE				SIZE AS FIRED				
FUEL USED				MINE				COUNTY				
PRESSURES & TEMPERATURES				FUEL DATA								
1	STEAM PRESSURE IN BOILER DRUM	psia	17.2	COAL AS FIRED PROX. ANALYSIS				% wt	OIL			
2	STEAM PRESSURE AT S. H. OUTLET	psia		37	MOISTURE				27.2	51	FLASH POINT F*	
3	STEAM PRESSURE AT R. H. INLET	psia		38	VOL MATTER				74.1	52	Sp. Gravity Deg. API*	
4	STEAM PRESSURE AT R. H. OUTLET	psia		39	FIXED CARBON				57.1	53	VISCOSITY AT SSU* BURNER SSF	
5	STEAM TEMPERATURE AT S. H. OUTLET	F		40	ASH				8.8	44	TOTAL HYDROGEN % wt	
6	STEAM TEMPERATURE AT R. H. INLET	F		TOTAL					41	Btu per lb		
7	STEAM TEMPERATURE AT R. H. OUTLET	F		41	Btu per lb AS FIRED				13			
8	WATER TEMP. ENTERING (ECON.) (BOILER)	F	54	42	ASH SOFT TEMP.* ASTM METHOD					GAS % VOL		
9	STEAM QUALITY % MOISTURE OR P. P. M.			COAL OR OIL AS FIRED ULTIMATE ANALYSIS					54	CO		
10	AIR TEMP. AROUND BOILER (AMBIENT)	F	83	43	CARBON				84.5	55	CH ₄ METHANE	
11	TEMP. AIR FOR COMBUSTION (This is Reference Temperature) †	F	83	44	HYDROGEN				5.2	56	C ₂ H ₂ ACETYLENE	
12	TEMPERATURE OF FUEL	F		45	OXYGEN				11.6	57	C ₂ H ₄ ETHYLENE	
13	GAS TEMP. LEAVING (Boiler) (Econ.) (Air Htr.)	F	700	46	NITROGEN				1.5	58	C ₂ H ₆ ETHANE	
14	GAS TEMP. ENTERING AH (If conditions to be corrected to guarantee)	F		47	SULPHUR				1.2	59	H ₂ S	
UNIT QUANTITIES				40	ASH				8.8	60	CO ₂	
15	ENTHALPY OF SAT. LIQUID (TOTAL HEAT)	Btu/lb	182.1	37	MOISTURE				1.7	61	H ₂ HYDROGEN	
16	ENTHALPY OF (SATURATED) (SUPERHEATED) STM.	Btu/lb	1153.3	TOTAL					TOTAL			
17	ENTHALPY OF SAT. FEED TO (BOILER) (ECON.)	Btu/lb	22.1	COAL PULVERIZATION					TOTAL HYDROGEN % wt			
18	ENTHALPY OF REHEATED STEAM R. H. INLET	Btu/lb		48	GRINDABILITY INDEX*					62	DENSITY 68 F ATM. PRESS.	
19	ENTHALPY OF REHEATED STEAM R. H. OUTLET	Btu/lb		49	FINENESS % THRU 50 M*					63	Btu PER CU FT	
20	HEAT ABS/LB OF STEAM (ITEM 16 - ITEM 17)	Btu/lb	1131.2	50	FINENESS % THRU 200 M*					41	Btu PER LB	
21	HEAT ABS/LB R. H. STEAM (ITEM 19 - ITEM 18)	Btu/lb		64	INPUT-OUTPUT EFFICIENCY OF UNIT %				ITEM 31 x 100 ITEM 29			
22	DRY REFUSE (ASH PIT + FLY ASH) PER LB AS FIRED FUEL	lb/lb	3.4	HEAT LOSS EFFICIENCY				Btu/lb A. F. FUEL	% of A. F. FUEL			
23	Btu PER LB IN REFUSE (WEIGHTED AVERAGE)	Btu/lb	727	65	HEAT LOSS DUE TO DRY GAS							
24	CARBON BURNED PER LB AS FIRED FUEL	lb/lb	1.38	66	HEAT LOSS DUE TO MOISTURE IN FUEL							
25	DRY GAS PER LB AS FIRED FUEL BURNED	lb/lb	1.74	67	HEAT LOSS DUE TO H ₂ O FROM COMB. OF H ₂					4.0		
HOURLY QUANTITIES				68	HEAT LOSS DUE TO COMBUST. IN REFUSE							
26	ACTUAL WATER EVAPORATED	lb/hr		69	HEAT LOSS DUE TO RADIATION							
27	REHEAT STEAM FLOW	lb/hr		70	UNMEASURED LOSSES							
28	RATE OF FUEL FIRING (AS FIRED wt)	lb/hr		71	TOTAL							
29	TOTAL HEAT INPUT (Item 28 x Item 41) 1000	kB/hr		72	EFFICIENCY = (100 - Item 71)							
30	HEAT OUTPUT IN BLOW-DOWN WATER	kB/hr										
31	TOTAL HEAT OUTPUT (Item 26 x Item 20) + (Item 27 x Item 21) + Item 30 1000	kB/hr										
FLUE GAS ANAL. (BOILER) (ECON) (AIR HTR) OUTLET												
32	CO ₂	% VOL	12.0									
33	O ₂	% VOL	7.0									
34	CO	% VOL	0.1									
35	N ₂ (BY DIFFERENCE)	% VOL	80.9									
36	EXCESS AIR	%	47									

* Not Required for Efficiency Testing

3-4

† For Point of Measurement See Par. 7.2.8.1-PTC 4.1-1964

CALCULATION SHEET

ASME TEST FORM
FOR ABBREVIATED EFFICIENCY TEST

Revised September, 1965

OWNER OF PLANT	TEST NO.	BOILER NO.	DATE
30	HEAT OUTPUT IN BOILER BLOW-DOWN WATER = LB OF WATER BLOW-DOWN PER HR x $\frac{\text{ITEM 15} - \text{ITEM 17}}{1000}$		lbB/hr
24	If impractical to weigh refuse, this item can be estimated as follows DRY REFUSE PER LB OF AS FIRED FUEL = $\frac{\% \text{ ASH IN AS FIRED COAL}}{100 - \% \text{ COMB. IN REFUSE SAMPLE}}$ CARBON BURNED PER LB AS FIRED FUEL = $\frac{\text{ITEM 43}}{100} - \left[\frac{\text{ITEM 22} \times \text{ITEM 23}}{14,500} \right]$		NOTE: IF FLUE DUST & ASH PIT REFUSE DIFFER MATERIALLY IN COMBUSTIBLE CONTENT, THEY SHOULD BE ESTIMATED SEPARATELY. SEE SECTION 7, COMPUTATIONS.
25	DRY GAS PER LB AS FIRED FUEL = $\frac{11\text{CO}_2 + 8\text{O}_2 + 7(\text{N}_2 + \text{CO})}{3(\text{CO}_2 + \text{CO})} \times (\text{LB CARBON BURNED PER LB AS FIRED FUEL} + \frac{3}{8} \text{ S})$ = $11 \times \frac{\text{ITEM 32}}{100} + 8 \times \frac{\text{ITEM 33}}{100} + 7 \left(\frac{\text{ITEM 35}}{100} + \frac{\text{ITEM 34}}{100} \right) \times \left[\frac{\text{ITEM 24}}{267} + \frac{\text{ITEM 47}}{267} \right]$		
36	EXCESS AIR† = $100 \times \frac{\text{O}_2 - \frac{\text{CO}}{2}}{.2682\text{N}_2 - (\text{O}_2 - \frac{\text{CO}}{2})} = 100 \times \frac{\text{ITEM 33} - \frac{\text{ITEM 34}}{2}}{.2682(\text{ITEM 35}) - (\text{ITEM 33} - \frac{\text{ITEM 34}}{2})}$		
HEAT LOSS EFFICIENCY			
65	HEAT LOSS DUE TO DRY GAS = $\text{LB DRY GAS PER LB AS FIRED FUEL} \times C_p \times (t_{\text{vg}} - t_{\text{air}}) = \frac{\text{ITEM 25}}{\text{Unit}} \times 0.24 \times (\text{ITEM 13}) - (\text{ITEM 11})$		$\frac{65}{41} \times 100 =$
66	HEAT LOSS DUE TO MOISTURE IN FUEL = $\text{LB H}_2\text{O PER LB AS FIRED FUEL} \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA \& T GAS LVG}) - (\text{ENTHALPY OF LIQUID AT T AIR})] = \frac{\text{ITEM 37}}{100} \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA \& T ITEM 13}) - (\text{ENTHALPY OF LIQUID AT T ITEM 11})]$		$\frac{66}{41} \times 100 =$
67	HEAT LOSS DUE TO H ₂ O FROM COMB. OF H ₂ = $9\text{H}_2 \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA \& T GAS LVG}) - (\text{ENTHALPY OF LIQUID AT T AIR})] = 9 \times \frac{\text{ITEM 44}}{100} \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA \& T ITEM 13}) - (\text{ENTHALPY OF LIQUID AT T ITEM 11})]$		$\frac{67}{41} \times 100 =$
68	HEAT LOSS DUE TO COMBUSTIBLE IN REFUSE = $\frac{\text{ITEM 22}}{\text{Unit}} \times \frac{\text{ITEM 23}}{\text{Unit}} =$		$\frac{68}{41} \times 100 =$
69	HEAT LOSS DUE TO RADIATION* = $\frac{\text{TOTAL BTU RADIATION LOSS PER HR}}{\text{LB AS FIRED FUEL} - \text{ITEM 28}}$		$\frac{69}{41} \times 100 =$
70	UNMEASURED LOSSES**		$\frac{70}{41} \times 100 =$
71	TOTAL		
2	EFFICIENCY = $(100 - \text{ITEM 71})$		

† For rigorous determination of excess air see Appendix 9.2 - PTC 4.1-1964

* If losses are not measured, use ABMA Standard Radiation Loss Chart, Fig. 8, PTC 4.1-1964

** Unmeasured losses listed in PTC 4.1 but not tabulated above may be provided for by assigning a mutually agreed upon value for Item 70.

7-7-83

Time	Feedwater flow (total gal)	Feedwater temperature (°F)	Steam pressure (psig)	Fuel flow (lb/hr nominal setting)	Comment
530					Start fuel feed, boiler on
830	4,733.5	55	2	300	
845	4,799.4	55	2.5	300	
900	4,860.9	56	2	400	SASS start; increase fuel flow
915	4,924.8	54	3	400	Method 5/8-2 start
930	5,012.7	54	2	400	
945	5,097.8	55	2.5	400	
1000	5,185.3	55	2	400	
1015	5,278.0	54	2.5	400	
1030	5,363.0	54	3.5	400	Method 5/8-2 stop
1045	5,473.6	54	2.5	400	
1100	5,555.1	54	4	400	
1115	5,660.8	54	3	400	
1130	5,785.9	54	3	400	
1145	5,892.1	55	3.5	400	HCl-2 start
1215	6,093.0	55	3	400	HCl-2 stop
1230	6,196.4	55	3	400	
1245	6,287.5	55	4	400	
1300	6,391.6	54	4	400	
1315	6,483.5	54	4	400	
1330	6,603.1	54	4	400	HCl-3 start
1345	6,708.1	54	3.5	400	
1400	6,816.5	54	3.5	400	SASS stop, HCl-3 stop
1415	6,922.7	54	3.5	400	
1430	7,003.8	54	3.5	400	
1445	7,111.2	54	3	400	
1500	7,237.2	54	4.5	400	
1515	7,320.0	54	3.5	400	
1530	7,417.7	54	4	300	
1545	7,503.8	54	7	200	VOST start
1600	7,585.2	55	7	200	
1615	7,670.0	55	7.5	200	VOST stop
1630	7,747.0	54	4.5	200	Method 5/8-3 start
1645	7,815.6	56	2	200	
1700	7,887.0	56	1	200	
1715	7,948.1	57	1	200	
1730	7,976.1	57	1	200	
1745	8,018.6	57	(0.5)	200	Method 4/8-3 stop
1752	8,032.0	57	0	200	Terminate fuel flow

Total fuel feed = 2,976.5 lb = 2,489 lb coal + 487.5 lb PET. Collect 237.5 lb bottom ash, 8 lb cyclone hopper ash.

ASME TEST FORM
FOR ABBREVIATED EFFICIENCY TEST

PTC 4.1-a(1964)

TEST NO. 2		BOILER NO.		DATE 7-1-64		
LOCATION		OBJECTIVE OF TEST		DURATION		
BOILER, MAKE & TYPE		RATED CAPACITY				
TOKER, TYPE & SIZE		BURNER, TYPE & SIZE				
FUEL USED COAL, 1-5 MINE		COUNTY		STATE		
PRESSURES & TEMPERATURES		FUEL DATA		SIZE AS FIRED		
1	STEAM PRESSURE IN BOILER DRUM	psia	17.7	COAL AS FIRED PROX. ANALYSIS	% wt	OIL
2	STEAM PRESSURE AT S. H. OUTLET	psia		37	MOISTURE	51
3	STEAM PRESSURE AT R. H. INLET	psia		38	VOL MATTER	52
4	STEAM PRESSURE AT R. H. OUTLET	psia		39	FIXED CARBON	53
5	STEAM TEMPERATURE AT S. H. OUTLET	F		40	ASH	44
6	STEAM TEMPERATURE AT R. H. INLET	F		TOTAL		41
7	STEAM TEMPERATURE AT R. H. OUTLET	F		41	Btu per lb AS FIRED	
8	WATER TEMP. ENTERING (ECON.) (BOILER)	F	55	42	ASH SOFT TEMP.* ASTM METHOD	
9	STEAM QUALITY % MOISTURE OR P. P. M.			COAL OR OIL AS FIRED ULTIMATE ANALYSIS		54
10	AIR TEMP. AROUND BOILER (AMBIENT)	F	80	43	CARBON	55
11	TEMP. AIR FOR COMBUSTION (This is Reference Temperature) †	F	80	44	HYDROGEN	56
12	TEMPERATURE OF FUEL	F		45	OXYGEN	57
13	GAS TEMP. LEAVING (Boiler) (Econ.) (Air Htr.)	F	385	46	NITROGEN	58
14	GAS TEMP. ENTERING AH (If conditions to be corrected to guarantee)	F		47	SULPHUR	59
15	UNIT QUANTITIES			40	ASH	60
16	ENTHALPY OF SAT. LIQUID (TOTAL HEAT)	Btu/lb	180	37	MOISTURE	61
17	ENTHALPY OF (SATURATED) (SUPERHEATED) STM.	Btu/lb	102	TOTAL		TOTAL
18	ENTHALPY OF SAT. FEED TO (BOILER) (ECON.)	Btu/lb	23.1	COAL PULVERIZATION		TOTAL HYDROGEN % wt
19	ENTHALPY OF REHEATED STEAM R. H. INLET	Btu/lb		48	GRINDABILITY INDEX*	62
20	ENTHALPY OF REHEATED STEAM R. H. OUTLET	Btu/lb		49	FINESS % THRU 50 M*	63
21	HEAT ABS/LB OF STEAM (ITEM 16 - ITEM 17)	Btu/lb	113.2	50	FINESS % THRU 200 M*	41
22	HEAT ABS/LB R. H. STEAM (ITEM 19 - ITEM 18)	Btu/lb		64	INPUT-OUTPUT EFFICIENCY OF UNIT %	ITEM 31 x 100 / ITEM 29
23	DRY REFUSE (ASH PIT + FLY ASH) PER LB AS FIRED FUEL	lb/lb	0.084	HEAT LOSS EFFICIENCY		Btu/lb A. F. FUEL
24	Btu PER LB IN REFUSE (WEIGHTED AVERAGE)	Btu/lb	194.2	65	HEAT LOSS DUE TO DRY GAS	7.8
25	CARBON BURNED PER LB AS FIRED FUEL	lb/lb	1.708	66	HEAT LOSS DUE TO MOISTURE IN FUEL	2.6
26	DRY GAS PER LB AS FIRED FUEL BURNED	lb/lb	13.75	67	HEAT LOSS DUE TO H ₂ O FROM COMB. OF H ₂	1.3
HOURLY QUANTITIES				68	HEAT LOSS DUE TO COMBUST. IN REFUSE	
27	ACTUAL WATER EVAPORATED	lb/hr		69	HEAT LOSS DUE TO RADIATION	
28	REHEAT STEAM FLOW	lb/hr		70	UNMEASURED LOSSES	
29	RATE OF FUEL FIRING (AS FIRED wt)	lb/hr		71	TOTAL	23.0
30	TOTAL HEAT INPUT (Item 28 x Item 41) / 1000	kB/hr		72	EFFICIENCY = (100 - Item 71)	7%
31	HEAT OUTPUT IN BLOW-DOWN WATER	kB/hr				
32	TOTAL HEAT OUTPUT (Item 26 x Item 20) + (Item 27 x Item 21) + Item 30 / 1000	kB/hr				
FLUE GAS ANAL. (BOILER) (ECON) (AIR HTR) OUTLET						
33	CO ₂	% VOL	12.9			
34	O ₂	% VOL	5.2			
35	CO	% VOL	0.1			
36	N ₂ (BY DIFFERENCE)	% VOL	77			
37	EXCESS AIR	%	77			

* Not Required for Efficiency Testing

† For Point of Measurement See Par. 7.2.8.1-PTC 4.1-1964

ASME TEST FORM CALCULATION SHEET FOR ABBREVIATED EFFICIENCY TEST

Revised September, 1965

OWNER OF PLANT	TEST NO.	BOILER NO.	DATE
30	HEAT OUTPUT IN BOILER BLOW-DOWN WATER = LB OF WATER BLOW-DOWN PER HR x $\frac{\text{ITEM 15} - \text{ITEM 17}}{1000}$		kB/hr
24	If impractical to weigh refuse, this item can be estimated as follows DRY REFUSE PER LB OF AS FIRED FUEL = $\frac{\% \text{ ASH IN AS FIRED COAL}}{100 - \% \text{ COMB. IN REFUSE SAMPLE}}$ CARBON BURNED PER LB AS FIRED FUEL = $\frac{\text{ITEM 43}}{100} - \left[\frac{\text{ITEM 22}}{14,500} \times \frac{\text{ITEM 23}}{19,500} \right]$		NOTE: IF FLUE DUST & ASH PIT REFUSE DIFFER MATERIALLY IN COMBUSTIBLE CONTENT, THEY SHOULD BE ESTIMATED SEPARATELY. SEE SECTION 7, COMPUTATIONS.
25	DRY GAS PER LB AS FIRED FUEL = $\frac{11\text{CO}_2 + 8\text{O}_2 + 7(\text{N}_2 + \text{CO})}{3(\text{CO}_2 + \text{CO})} \times (\text{LB CARBON BURNED PER LB AS FIRED FUEL} + \frac{3}{8})$ = $11 \times \frac{\text{ITEM 32}}{3} + 8 \times \frac{\text{ITEM 33}}{3} + 7 \left(\frac{\text{ITEM 35}}{3} + \frac{\text{ITEM 34}}{3} \right) \times \left[\frac{\text{ITEM 24}}{267} + \frac{\text{ITEM 47}}{267} \right]$		
36	EXCESS AIR = $100 \times \frac{\text{O}_2 - \frac{\text{CO}}{2}}{.2682\text{N}_2 - (\text{O}_2 - \frac{\text{CO}}{2})} = 100 \times \frac{\text{ITEM 33} - \frac{\text{ITEM 34}}{2}}{.2682(\text{ITEM 35}) - (\text{ITEM 33} - \frac{\text{ITEM 34}}{2})}$		
HEAT LOSS EFFICIENCY			
65	HEAT LOSS DUE TO DRY GAS = $\text{LB DRY GAS PER LB AS FIRED FUEL} \times C_p \times (t_{\text{vg}} - t_{\text{air}})$	ITEM 25 x 0.24 (ITEM 13) - (ITEM 11)	$\frac{65}{41} \times 100 = 7.3$
66	HEAT LOSS DUE TO MOISTURE IN FUEL = $\text{LB H}_2\text{O PER LB AS FIRED FUEL} \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA \& T GAS LVG}) - (\text{ENTHALPY OF LIQUID AT T AIR})]$	ITEM 37 x [(ENTHALPY OF VAPOR AT 1 PSIA \& T ITEM 13) - (ENTHALPY OF LIQUID AT T ITEM 11)]	$\frac{66}{41} \times 100 =$
67	HEAT LOSS DUE TO H ₂ O FROM COMB. OF H ₂ = $9\text{H}_2 \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA \& T GAS LVG}) - (\text{ENTHALPY OF LIQUID AT T AIR})]$	$9 \times \frac{\text{ITEM 44}}{100} \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA \& T ITEM 13}) - (\text{ENTHALPY OF LIQUID AT T ITEM 11})]$	$\frac{67}{41} \times 100 =$
68	HEAT LOSS DUE TO COMBUSTIBLE IN REFUSE = $\frac{\text{ITEM 22}}{14,500} \times \frac{\text{ITEM 23}}{19,500}$		$\frac{68}{41} \times 100 = 1.2$
69	HEAT LOSS DUE TO RADIATION* = $\frac{\text{TOTAL BTU RADIATION LOSS PER HR}}{\text{LB AS FIRED FUEL} - \text{ITEM 28}}$		$\frac{69}{41} \times 100 =$
70	UNMEASURED LOSSES**		$\frac{70}{41} \times 100 =$
71	TOTAL		
2	EFFICIENCY = (100 - ITEM 71)		

† For rigorous determination of excess air see Appendix 9.2 - PTC 4.1-1964

* If losses are not measured, use ABMA Standard Radiation Loss Chart, Fig. 8, PTC 4.1-1964

** Unmeasured losses listed in PTC 4.1 but not tabulated above may be provided for by assigning a mutually agreed upon value for Item 70.

SECTION 4
SAMPLING DATA SHEETS

4.1 CONTINUOUS MONITOR EMISSION DATA

4.2 FIELD DATA SHEETS FOR EPA METHOD 5/8, SASS, HC1, AND VOST TRAINS

4.1 CONTINUOUS MONITOR EMISSION DATA

Plant Ref 1 A
 Location Amesbury, Windsor Ave.
 Date 7/1/83

CONTINUOUS MONITOR FIELD DATA

Time (24-hr clock)	Ambient Temperature (°F)		Barometric Pressure (in. Hg)	Instrument Van Temperature (°F)	Heated Sample Line Analysis (Wet)							Cold Sample Line Analysis (Dry)									
	WBT	DBT			Sample Location Specify: Inlet or Outlet	NO ^a (ppm)	NO _x +NH ₃ ^b (ppm)	NO _x ^c (ppm)	NO ₂ ^d (ppm)	NH ₃ ^e (ppm)	Sample Gas Temperature (°F)	Sample Location Specify: Inlet or Outlet	NO (ppm)	NO _x (ppm)	NO ₂ (ppm)	O ₂ (%)	CO ₂ (%)	CO (%)	CO (ppm)	TUHC (ppm)	Sample Gas Temperature (°F)
11:50				75"									210		6.5	12.5		40	10	1/4	
11:55				1									210		6.6	12.5		130	10	1/4	
12:00													210		6.7	12.2		17	10	1/4	
12:05				0									210		7.0	11.9		40	0	0	
12:10				1"									205		7.5	11.6		120	10	1/4	
12:15													205		7.5	11.7		120	10	1/4	
12:20													210		7.0	12.0		110	10	1/4	
12:25													210		6.9	12.3		110	10	1/4	
12:30						Ambient							150								
12:35						Ambient															
12:40						57.4°C							150		13.6	7.8		50	0	0	
12:45													150		12.5	7.1		70	0	0	
12:50													150		12.1	7.8		80	0	0	

^aNO = direct sample measurement (no conversion)
^bNO_x + NH₃ = sample path through stainless steel converter
^cNO_x = sample path through molybdenum converter

^dNO₂ = NO_x - NO
^eNH₃ = (NO_x + NH₃) - NO_x

Notes:

Plant Al. L. S. S.
 Location San Diego, B. N.
 Date 7-6-85

CONTINUOUS MONITOR FIELD DATA

Time (24-hr clock)	Ambient Temperature (°F)		Barometric Pressure (in. Hg)	Instrument Van Temperature (°F)	Heated Sample Line Analysis (Wet)							Cold Sample Line Analysis (Dry)									
					Sample Location Specify: Inlet or Outlet	NO ^a (ppm)	NO _x +NH ₃ ^b (ppm)	NO _x ^c (ppm)	NO ₂ ^d (ppm)	NH ₃ ^e (ppm)	Sample Gas Temperature (°F)	Sample Location Specify: Inlet or Outlet	NO (ppm)	NO _x (ppm)	NO ₂ (ppm)	O ₂ (%)	CO ₂ (%)	CO (%)	CO (ppm)	TUHC (ppm)	Sample Gas Temperature (°F)
	WBT	DBT																			
1255														155		140	8.4	8.3	65	0	
1300														155		140	8.4	8.3	95	0	
1305														160		140	8.6		120	0	
1310						6.1								215		65	12.1		170	0	
1315														220		65	12.1		170	0	
1320														210		65	12.1		160	11	
1325														200		70	12.2		175	12	
1330														195		65	12.5		170	11	
1335														170	19	65	12.6		170	9	
1340														165		68	12.6		175	9	
1345														165		68	12.5		170	6	
1350														170		65	12.7		200	16	
1355														170		70	12.7		200	12	

^aNO = direct sample measurement (no conversion)
^bNO_x + NH₃ = sample path through stainless steel converter
^cNO_x = sample path through molybdenum converter

^dNO₂ = NO_x - NO
^eNH₃ = (NO_x + NH₃) - NO_x

Notes:

Plant Rockwell Ag.
 Location Southern River
 Date 7-6-83

CONTINUOUS MONITOR FIELD DATA

Time (24-hr clock)	Ambient Temperature (°F)		Barometric Pressure (in. Hg)	Instrument Van Temperature (°F)	Heated Sample Line Analysis (Wet)							Cold Sample Line Analysis (Dry)									
	WBT	DBT			Sample Location Specify: Inlet or Outlet	NO ^a (ppm)	NO _x +NH ₃ ^b (ppm)	NO _x ^c (ppm)	NO ₂ ^d (ppm)	NH ₃ ^e (ppm)	Sample Gas Temperature (°F)	Sample Location Specify: Inlet or Outlet	NO (ppm)	NO _x (ppm)	NO ₂ (ppm)	O ₂ (%)	CO ₂ (%)	CO (%)	CO (ppm)	TUHC (ppm)	Sample Gas Temperature (°F)
1400														200		6.5	12.9		210	10	
1405														200		6.0	13.4		210	8	
1410														205		6.0	13.2		210	10	
1415														210		6.3	12.9		210	10	
1420														195		6.7	11.3		200	12	
1425														200		7.2	11.6		200	12	
1430														195		7.5	10.9		200	13	
1435														190		8.5	10.1		200	15	
1440														195		7.2	9.7		210	14	
1445														175		9.1	9.7		200	14	
1450														190		8.5	10.3		200	13	
1455														200		7.8	10.6		190	11	
1500														200		7.0	11.5		190	11	

^aNO = direct sample measurement (no conversion)
^bNO_x + NH₃ = sample path through stainless steel converter
^cNO_x = sample path through molybdenum converter

^dNO₂ = NO_x - NO
^eNH₃ = (NO_x + NH₃) - NO_x

Notes:

Plant Rich of Ag
 Location San Juan Bldg
 Date 1-6-83

CONTINUOUS MONITOR FIELD DATA

Time (24-hr clock)	Ambient Temperature (°F)		Barometric Pressure (in. Hg)	Instrument Van Temperature (°F)	Heated Sample Line Analysis (Wet)							Cold Sample Line Analysis (Dry)									
	WBT	DBT			Sample Location Specify: Inlet or Outlet	NO ^a (ppm)	NO _x +NH ₃ ^b (ppm)	NO _x ^c (ppm)	NO ₂ ^d (ppm)	NH ₃ ^e (ppm)	Sample Gas Temperature (°F)	Sample Location Specify: Inlet or Outlet	NO (ppm)	NO _x (ppm)	NO ₂ (ppm)	O ₂ (%)	CO ₂ (%)	CO (%)	CO (ppm)	TUHC (ppm)	Sample Gas Temperature (°F)
1505													200		70	11.6		160	11		
1510													200		70	11.6		170	13		
1515							STACK						130		12	6.5		110	1		
1520													110		12	6.5		100	0		
1525													130		12.5	6.1		100	0		
1530													130		12.6	6.3		90	0		
1535													130		12.5	6.3		90	0		
1540													130		12.3	6.5		90	0		
1545							Boiler (10 ppm)								6.2	17.5		150	7		
1550													170		6.2	12.5		150	1		
1555													170		6.1	12.9		150	0		
1600													200		6.6	12.5		150	3		
1605													200		6.5	12.3		150			

^aNO = direct sample measurement (no conversion)
^bNO_x + NH₃ = sample path through stainless steel converter
^cNO_x = sample path through molybdenum converter

^dNO₂ = NO_x - NO
^eNH₃ = (NO_x + NH₃) - NO_x

Notes:

Plant Rock of Ages
 Location San House Butler
 Date 7-6-83

CONTINUOUS MONITOR FIELD DATA

Time (24-hr clock)	Ambient Temperature (°F)		Barometric Pressure (in. Hg)	Instrument Van Temperature (°F)	Heated Sample Line Analysis (Wet)							Cold Sample Line Analysis (Dry)								
					Sample Location Specify: Inlet or Outlet	NO ^a (ppm)	NO _x +NH ₃ ^b (ppm)	NO _x ^c (ppm)	NO ₂ ^d (ppm)	NH ₃ ^e (ppm)	Sample Gas Temperature (°F)	Sample Location Specify: Inlet or Outlet	NO (ppm)	NO _x (ppm)	NO ₂ (ppm)	O ₂ (%)	CO ₂ (%)	CO (%)	CO (ppm)	TUHC (ppm)
	WBT	DBT																		
1610														185	6.9	12.2		150	8	
1615														185	7.2	12.2		160	7	
1620														185	7.4	12.1		160	11	
1625														195	6.9	12.3		170	13	
1630														200	6.5	12.3		180	11	
1635														200	7.0	11.9		180		
1640														200	7.3	11.5		200		
1645														210	7.5	11.2		220		
1650														210	7.3	11.4		200		
1655														210	7.2	11.5		230		
1700														210	7.0	11.6		210		
1705																				
1710																				

^aNO = direct sample measurement (no conversion)
^bNO_x + NH₃ = sample path through stainless steel converter
^cNO_x = sample path through molybdenum converter

^dNO₂ = NO_x - NO
^eNH₃ = (NO_x + NH₃) - NO_x

Notes:

Plant Mich. of Igss
 Location San Huan B. 100
 Date 7-7-83

CONTINUOUS MONITOR FIELD DATA

Time (24-hr clock)	Ambient Temperature (°F)		Barometric Pressure (in. Hg)	Instrument Van Temperature (°F)	Heated Sample Line Analysis (Wet)							Cold Sample Line Analysis (Dry)									
	WBT	DBT			Sample Location Specify: Inlet or Outlet	NO ^a (ppm)	NO _x +NH ₃ ^b (ppm)	NO _x ^c (ppm)	NO ₂ ^d (ppm)	NH ₃ ^e (ppm)	Sample Gas Temperature (°F)	Sample Location Specify: Inlet or Outlet	NO (ppm)	NO _x (ppm)	NO ₂ (ppm)	O ₂ (%)	CO ₂ (%)	CO (%)	CO (ppm)	TUHC (ppm)	Sample Gas Temperature (°F)
0900			28.60										165		105	8.2		230	3		
0905													200		76	11.1		210	3		
0910													100		70	11.4		200	3		
0915													165		6.1	12.2		200	3		
0920													210		6.5	12.0		210	3		
0925													200		6.6	11.5		200	3		
0930													145		6.3	11.1		260	3		
0935													170		6.0	12.6		230	3		
0940													200		6.4	12.0		170	3		
0945													200		6.7	11.4		165	3		
0950													200		7.1	11.0		165	3		
0955											7.16°C (transition)		165		6.1	7.3		125	3		
1000													165		7.8	8.4		70	2		

^aNO = direct sample measurement (no conversion)
^bNO_x + NH₃ = sample path through stainless steel converter
^cNO_x = sample path through molybdenum converter

^dNO₂ = NO_x - NO
^eNH₃ = (NO_x + NH₃) - NO_x

Notes:

Plant Rock & Lys
 Location San House Bldg.
 Date 7-1-63

CONTINUOUS MONITOR FIELD DATA

Time (24-hr clock)	Ambient Temperature (°F)		Barometric Pressure (in. Hg)	Instrument Van Temperature (°F)	Heated Sample Line Analysis (Wet)							Cold Sample Line Analysis (Dry)									
	WBT	DBT			Sample Location Specify: Inlet or Outlet	NO ^a (ppm)	NO _x +NH ₃ ^b (ppm)	NO _x ^c (ppm)	NO ₂ ^d (ppm)	NH ₃ ^e (ppm)	Sample Gas Temperature (°F)	Sample Location Specify: Inlet or Outlet	NO (ppm)	NO _x (ppm)	NO ₂ (ppm)	O ₂ (%)	CO ₂ (%)	CO (%)	CO (ppm)	TUHC (ppm)	Sample Gas Temperature (°F)
1005													160			88	8.2		70	78.2	
1010													160			87	8.4		55	9	
1015													160			83	8.9		60	1	
1020													175			79	9.2		50	1	
1025													195			73	9.9		65	1	
1030							130.2486						200			5.1	12.6		100	3	
1035													195	195		6.3	12.60		25	3	
1040													195			6.3	12.0		75	3	
1045													195			6.3	11.9		85	3	
1050													200			5.4	12.9		95	2	
1055													195			4.5	13.3		105	1	
1100													155			6.0	11.1		70	1	
1105													115			7.4	9.3		55	2	

^aNO = direct sample measurement (no conversion)
^bNO_x + NH₃ = sample path through stainless steel converter
^cNO_x = sample path through molybdenum converter

^dNO₂ = NO_x - NO
^eNH₃ = (NO_x + NH₃) - NO_x

Notes:

Plant Rock at Lys
 Location Southeast Corner
 Date 1-7-83

CONTINUOUS MONITOR FIELD DATA

Time (24-hr clock)	Ambient Temperature (°F)		Barometric Pressure (in. Hg)	Instrument Van Temperature (°F)	Heated Sample Line Analysis (Wet)							Cold Sample Line Analysis (Dry)									
	WBT	DBT			Sample Location Specify: Inlet or Outlet	NO ^a (ppm)	NO _x +NH ₃ ^b (ppm)	NO _x ^c (ppm)	NO ₂ ^d (ppm)	NH ₃ ^e (ppm)	Sample Gas Temperature (°F)	Sample Location Specify: Inlet or Outlet	NO (ppm)	NO _x (ppm)	NO ₂ (ppm)	O ₂ (%)	CO ₂ (%)	CO (%)	CO (ppm)	TUHC (ppm)	Sample Gas Temperature (°F)
1110													135			6.8	16.1		45	1	
1115													120			7.8	8.8		26	2	
1120													120			7.8	8.7		15	2	
1125																					
1130																					
1135																					
1140																					
1145																					
1150																					
1155																					
1200																					
1205																					
1210																					

^aNO = direct sample measurement (no conversion)
^bNO_x + NH₃ = sample path through stainless steel converter
^cNO_x = sample path through molybdenum converter

^dNO₂ = NO_x - NO
^eNH₃ = (NO_x + NH₃) - NO_x

Notes:

Plant Rock of Ages
 Location San Jose Border
 Date 7-7-83

CONTINUOUS MONITOR FIELD DATA

Time (24-hr clock)	Ambient Temperature (°F)		Barometric Pressure (in. Hg)	Instrument Van Temperature (°F)	Heated Sample Line Analysis (Wet)							Cold Sample Line Analysis (Dry)									
					Sample Location Specify: Inlet or Outlet	NO ^a (ppm)	NO _x +NH ₃ ^b (ppm)	NO _x ^c (ppm)	NO ₂ ^d (ppm)	NH ₃ ^e (ppm)	Sample Gas Temperature (°F)	Sample Location Specify: Inlet or Outlet	NO (ppm)	NO _x (ppm)	NO ₂ (ppm)	O ₂ (%)	CO ₂ (%)	CO (%)	CO (ppm)	THC (ppm)	Sample Gas Temperature (°F)
	WBT	DBT																			
1215														205		4.0	14.1		75	2	
1220														200		3.5	14.7		170	2	
1225														190		3.4	14.4		130	3	
1230														176		2.6	15.8		145	4	
1235														95		2.4	14.6		1120 ^x	3	
1240														190		3.2	15.1		105	3	
1245														200		3.4	14.6		100	3	
1250														175		3.1	15.0		135	2	
1255														185		3.8	14.3		125	2	
1300														195		3.6	14.2		115	2	
1305														205		3.2	14.1		90	3	
1310														175		4.0	13.9		90	2	
1315						57	400	72	1.05	15.7	100	200	127	8							

^aNO = direct sample measurement (no conversion)
^bNO_x + NH₃ = sample path through stainless steel converter
^cNO_x = sample path through molybdenum converter

^dNO₂ = NO_x - NO
^eNH₃ = (NO_x + NH₃) - NO_x

Notes:

Plant Rock of Ages
 Location San Juan Bldg
 Date 7-7-83

CONTINUOUS MONITOR FIELD DATA

Time (24-hr clock)	Ambient Temperature (°F)		Barometric Pressure (in. Hg)	Instrument Van Temperature (°F)	Heated Sample Line Analysis (Wet)						Cold Sample Line Analysis (Dry)										Sample Gas Temperature (°F)
	WBT	DBT			Sample Location Specify: Inlet or Outlet	NO ^a (ppm)	NO _x +NH ₃ ^b (ppm)	NO _x ^c (ppm)	NO ₂ ^d (ppm)	NH ₃ ^e (ppm)	Sample Gas Temperature (°F)	Sample Location Specify: Inlet or Outlet	NO (ppm)	NO _x (ppm)	NO ₂ (ppm)	O ₂ (%)	CO ₂ (%)	CO (%)	CO (ppm)	TUHC (ppm)	
1320								57.0	12.0				150		9.6	5.6		40	3		
1325													110		9.6	5.8		25	3		
1330													95		9.5	5.6		35	3		
1335													90		10.0	4.9		09	4		
1340								130.0	12.0				195		3.4	13.8		20	75		
1345													185		3.5	13.4		115	40		
1350													160		4.0	12.8		110	38		
1355													125		4.1	12.5		125	26		
1400													115		3.4	13.3		140	20		
1405													140		3.5	13.2		170	15		
1410													205		3.4	13.5		175	12		
1415													200		3.5	13.5		200	9		
1420													190		3.2	13.7		455	12		

^aNO = direct sample measurement (no conversion)
^bNO_x + NH₃ = sample path through stainless steel converter
^cNO_x = sample path through molybdenum converter

^dNO₂ = NO_x - NO
^eNH₃ = (NO_x + NH₃) - NO_x

Notes:

Plant Rock of Ages
 Location South House Boiler
 Date 7-1-83

CONTINUOUS MONITOR FIELD DATA

Time (24-hr clock)	Ambient Temperature (°F)		Barometric Pressure (in. Hg)	Instrument Van Temperature (°F)	Heated Sample Line Analysis (Wet)							Cold Sample Line Analysis (Dry)									
	WBT	DBT			Sample Location Specify: Inlet or Outlet	NO ^a (ppm)	NO _x +NH ₃ ^b (ppm)	NO _x ^c (ppm)	NO ₂ ^d (ppm)	NH ₃ ^e (ppm)	Sample Gas Temperature (°F)	Sample Location Specify: Inlet or Outlet	NO (ppm)	NO _x (ppm)	NO ₂ (ppm)	O ₂ (%)	CO ₂ (%)	CO (%)	CO (ppm)	TUHC (ppm)	Sample Gas Temperature (°F)
1425													175		3.4	14.1		425	13		
1430													185		3.4	14.7		375	1		
1435													175		3.1	14.4		520	10		
1440													175		2.9	14.4		220	19		
1445													200		4.1	13.7		265	5		
1450													190		3.1	14.7		265	4		
1455													190		2.5	15.2		235	3		
1500													190		2.5	15.0		285	3		
1505													195		3.0	14.0		215	2		
1510													190		3.9	13.1		175	3		
1515													190		4.1	12.9		205	3		
1520													180		4.0	12.9		195	3		
1525													185		3.9	12.8		200	3		

^aNO = direct sample measurement (no conversion)
^bNO_x + NH₃ = sample path through stainless steel converter
^cNO_x = sample path through molybdenum converter

^dNO₂ = NO_x - NO
^eNH₃ = (NO_x + NH₃) - NO_x

Notes:

Plant Rock of Ages
 Location Saw Mill Boiler
 Date 7-1-83

CONTINUOUS MONITOR FIELD DATA

Time (24-hr clock)	Ambient Temperature (°F)		Barometric Pressure (in. Hg)	Instrument Van Temperature (°F)	Heated Sample Line Analysis (Wet)							Cold Sample Line Analysis (Dry)									
	WBT	DBT			Sample Location Specify: Inlet or Outlet	NO ^a (ppm)	NO _x +NH ₃ ^b (ppm)	NO _x ^c (ppm)	NO ₂ ^d (ppm)	NH ₃ ^e (ppm)	Sample Gas Temperature (°F)	Sample Location Specify: Inlet or Outlet	NO (ppm)	NO _x (ppm)	NO ₂ (ppm)	O ₂ (%)	CO ₂ (%)	CO (%)	CO (ppm)	TUHC (ppm)	Sample Gas Temperature (°F)
1530													185		3.2	13.3		195	4		
1535													165		3.6	12.2		185	4		
1540													100		2.4	13.2		1050	150		
1545													110		3.1	12.6		565	22		
1550													115		2.9	13.3		630	15		
1555													135		3.6	13.5		325	4		
1600													175		5.1	12.1		170	0		
1605																					
1610																					
1615																					
1620																					
1625																					
1630																					

^aNO = direct sample measurement (no conversion)
^bNO_x + NH₃ = sample path through stainless steel converter
^cNO_x = sample path through molybdenum converter

^dNO₂ = NO_x - NO
^eNH₃ = (NO_x + NH₃) - NO_x

Notes:

VOID
DATA

WATER CONTAMINATION

CONTINUOUS MONITOR FIELD DATA

Plant _____

Location _____

Date _____

Time (24-hr clock)	Ambient Temperature (°F)		Barometric Pressure (in. Hg)	Instrument Van Temperature (°F)	Heated Sample Line Analysis (Wet)							Cold Sample Line Analysis (Dry)									
	WBT	DBT			Sample Location Specify: Inlet or Outlet	NO ^a (ppm)	NO _x +NH ₃ ^b (ppm)	NO _x ^c (ppm)	NO ₂ ^d (ppm)	NH ₃ ^e (ppm)	Sample Gas Temperature (°F)	Sample Location Specify: Inlet or Outlet	NO (ppm)	NO _x (ppm)	NO ₂ (ppm)	O ₂ (%)	CO ₂ (%)	CO (%)	CO (ppm)	TUHC (ppm)	Sample Gas Temperature (°F)
1635					COLD DATA - WATER CONTAMINATION																
1640													145		^{x25} 2.8	9.2		190			
1645													140		^{x35} 2.8	8.8		210			
1650													140		^{x25} 8.1	8.6		225			
1655													146		8.7	8.7		225			
1700													150		8.4	8.3					
1705													135								
1710																					
1715																					
1720																					
1725																					
1730																					
1735																					

^aNO = direct sample measurement (no conversion)
^bNO_x + NH₃ = sample path through stainless steel converter
^cNO_x = sample path through molybdenum converter

^dNO₂ = NO_x - NO
^eNH₃ = (NO_x + NH₃) - NO_x

Notes:

4.2 FIELD DATA SHEETS FOR EPA METHOD 5/8, SASS, HCl, AND VOST TRAINS

Probe Length and Type 5' P100
 Nozzle Size & I.D. 3/8"
 Pitot Coefficient & I.D. 0.800
 Assumed Moisture 0.075
 Molecular Weight, Dry, (M_d) _____
 Meter Box Number NAAP-1
 Meter Coefficient 725
 α Factor 1.012
 $K =$ 241.275
 $K(N_d)^4 = 41.4 \times (3.87)^4 = 18.273$
 $\Delta H = K(N_d)^4 \left(\frac{T_m}{T_s} \right) (P)$

SASS Condensate _____
Total Volume 4.1

Traverse Point Number	Sampling Time, min	Clock Time (24-hr) Clock	Gas Meter Reading (V _m), ft 3	Velocity Head (ΔP _v), in. H ₂ O	Orifice Pressure Differential (ΔH), in. H ₂ O		Temperature of							Pump Vacuum in. Hg	Avg. √ΔP
					Desired	Actual	Stack	Probe	Impinger	Organic Module	Oven	Gas Meter			
												In	Out		
	0	1120	Init. 593.941												
A-1	5		596.1	0.555	01	01	00		62		175	60	61		0.04
2	10		599.82	0.555	02	02	00		55		180	60	61		0.04
3	15		601.49	0.555	01	01	00		56		20	60	62		0.04
4	20		603.92	0.555	02	02	20		54		195	60	63	12	0.04
5	25		606.22	0.555	00	00	27.5		53		185	70	61	9.5	0.04
6	30		609.015	0.555	00	00	26.5		50		185	70	70	9.0	0.04
7	35		610.605	0.555	02	02	25.0		—		20	70	68	8	0.04
8	40		614.11	0.555	02	02	20.0		—		20	70	68	8	0.04
9	45		617.23	0.555	01	01	20.0		—		195	70	70	8.0	0.04

7602/5/81/Rev 1

Comments: * H₂Tf 0.1 M, 60°C, 6 h, 0.1 M

Traverse Point Number	Clock Time (24-hr) Clock		Gas Meter Reading (V _m), ft ³	Velocity Head (ΔP _s), in. H ₂ O	Orifice Pressure Differential (ΔH), in. H ₂ O		Temperature °F					Gas Meter		Pump Vacuum in. Hg	Avg. ΔP
	Sampling Time, min	Init.					Stack	Probe	Impinger	Organic Module	Oven				
					Desired	Actual						In	Out		
B-10	50		619.557	.085	.59	.57	300		—		175	71	71	0	.20
B-11	55		621.725	.085	.59	.57	292		—		160	71	71	0	.20
B-12	60	1315	624.071	.085	.59	.57	280		—		160	71	71	0	.20
				</											

69.5

Run No. 1-1007Date 7-6-87Sampling Location 1007

Comments:

FIELD DATA

Page 1 of

Plant Rock of Face
 Date 7-6-82
 Sample Location Sand House
 Sample Type SASS
 Run Number 1
 Operator P. W. Kaufmann
 Ambient Temperature
 Barometric Pressure 28.24
 Static Pressure, (H₂O) -1.0
 Filter Number(s)

Impinger Volumes
 Initial Final Net Gain
500 40
500 -4
500 4
 Silica Gel
 106
 1317

Probe Length and Type 3 standard
 Nozzle Size & I.D. 1.40
 Pitot Coefficient & I.D. 0.6000 .82
 Assumed Moisture 7.5%
 Molecular Weight, Dry, (M_d)
 Meter Box Number 016
 Meter Coefficient 3.514
 α Factor 0.923

K = N/A
 $K(N_d)^4 = \text{ } \times (\text{ })^4 = \text{ }$
 $\Delta H = K(N_d)^4 \left(\frac{T_m}{T_s} \right) (P)$

Leak Check: Initial at 12 " Hg, .03 CFM OM. #2MP
 Pitot Leak Check: Initial at 10 " Hg, .05 CFM end of run
5.6

SASS Condensate 1.5
 Total Volume 9647

Traverse Point Number	Sampling Time, min	Clock Time (24-hr) Clock	Gas Meter Reading (V _m), ft ³	Velocity Head (ΔP _s), in. H ₂ O	Orifice Pressure Differential (ΔH), in. H ₂ O		Temperature °F							Pump Vacuum in. Hg	Avg. √ΔP
							Desired	Actual	Stack	Probe	Impinger	Organic Module	Oven		
					In	Out									
	0	1149	Intt. 787.728												
	10		825.61	0.05	2.14	2.1	259	398		60	405	65	65	15	
	20		865.0	0.05	2.14	2.1	289	373		58	402	41	65	15	
	30		903.01	0.045	2.13	2.0	216	385		58	401	71	66	15	
	40		941.250	0.045	2.15	2.1	270	382		57	399	73	67	15	
	50		980.7	0.055	2.5	2.0	273	403		56	405	67	67	14	
	60		1018.8	0.06	2.15	2.1	279	406		57	400	72	66	14	
	70		1058.1	0.06	2.17	2.0	288	371		58	397	76	67	17	
	80			0.06	2.17	2.1	288	371		58	397	76	67	17	
	90														

7602/5/81/Rev 1

Comments:

40 min

dec 11 change p

inst 1227

ICAL DATA

Plant Rock of Ages 7735.61 Sample No. 5455-1
 Sampling Location _____ Run No. 1
 Recovered By _____ Recovery Date 7/16/53 Run Date 7/16/53
 Comments _____
 Analyst Responsible _____
 Calculations and Report Reviewed By _____ Report Date _____

FILTERS USED

No. _____

CYCLONES

	Used (yes/no)	Pretared Container (No.)
10 μ	_____	_____
3 μ	_____	_____
1 μ	_____	_____

IMPINGER VOLUMES

	Initial	Final
First (H ₂ O ₂)	<u>500</u> ml	<u>540</u> ml
Second (APS + AgNO ₃)	<u>500</u> ml	<u>458</u> ml
Third (APS + AgNO ₃)	<u>500</u> ml	<u>504</u> ml
TOTALS	<u>1500</u> ml	<u>1502</u> ml

Gain 02 ml

SILICA GEL WEIGHTS

	Initial	Final
	<u>800.0</u> g	<u>956.0</u> g
	<u>800.0</u> g	<u>931.7</u> g
	_____ g	_____ g
TOTALS	<u>1600.0</u> g	<u>1887.7</u> g

Gain 287.7 g

CONDENSATE

TOTAL VOLUME COLLECTED _____ ml
 Volume Neat _____ ml
 Volume Extracted _____ ml
 Volume CH₂Cl₂ Extract (3 x _____ ml) _____ ml

Extracted Condensate: pH Neat _____
 Amount 96% HNO₃ added _____
 pH Final _____

TOTAL GAIN _____ ml

Page of _____

Probe Length and Type 7 1800
 Nozzle Size & I.D. 1/4"
 Pitot Coefficient & I.D. 0.822
 Assumed Moisture 6675
 Molecular Weight, Dry, (M_d) 28.9
 Meter Box Number D554 - 10.8 PSI
 Meter Coefficient 1725
 α Factor 1.013
 $K =$ 341313
 $K(N_d)^4 = \underline{\hspace{1cm}} \times (\underline{\hspace{1cm}})^4 = \underline{\hspace{1cm}}$
 $\Delta H = K(N_d)^4 \left(\frac{T_m}{T_s} \right) (P)$

SASS Condensate _____
Total Volume 1.2

[illegible]

7602/5/81/Rev 1

Comments:

4-26

ISOKINETIC CALCULATIONS - USEPA: M/5 BASIS

ROCK OF AGES - NO. 1

RUN NUMBER	1-SASS	1-M5/8	1-HCL
DATE OF TEST	7-6-83	7-6-83	7-6-83
OPERATOR	PWK	VB	VB
METER VOLUME, CF	992.884	30.22	16.145
METER COEF	0.973	1.012	1.012
BAROMETRIC PRES, HG	28.24	28.24	28.21
DELTA H, IN H2O	2.012	0.703	0.74
METER TEMP, DEG F	68.6	69.5	64.8
STACK TEMP, DEG F	274.3	295.3	279
CONDENSATE, ML	964.7	54.1	11.3
PERCENT CO2	7.1	7.1	7.1
PERCENT O2	12.2	12.2	12.2
PERCENT CO	0	0	0
PERCENT N2	80.7	80.7	80.7
STATIC PRES, IN H2O	-0.1	-0.1	-0.1
PITOT COEF	0.79	0.79	0
SQRT DELTA P, IN H2O	0.234	0.231	0
STACK AREA, SQ FT	2.405	2.405	0
NOZZLE DIAM, IN	1.24	0.387	0
TEST TIME, MIN	260	60	30
MASS PARTICULATE, G	0	0	0
F-FACTOR, DSCF/MBTU	0		
VOLUME, DSCF	967.246	28.161	15.165
WATER VAPOR, SCF	45.408	2.546	0.532
PERCENT MOISTURE	0.045	0.083	0.034
MOLECULAR WT DRY, LB/LB	29.624	29.624	29.624
MOLECULAR WT WET, LB/LB	29.10	28.66	29.23
STACK PRES, IN HG	28.23	28.23	28.20
STACK VELOCITY, FT/SEC	14.94	15.07	0.00
MASS FLOW, DSCFM	1,397	1,316	0
MASS FLOW, ACFM	2,156	2,175	0
PERCENT EXCESS AIR			
PERCENT ISOKINETIC	76.421	105.109	#DIV/0!
GRAIN LOADING, GR/DSCF	0.00000	0.00000	0.00000
GRAIN LOADING, GR/ACF	0.00000	0.00000	0.00000
EMISSION RATE, LB/HR-STD	0.00000	0.00000	0.00000
EMISSION RATE, LB/MBTU			

Plant _____
Date _____
Sample Location _____
Sample Type _____
Run Number _____
Operator _____
Ambient Temperature _____
Barometric Pressure 28.60
Static Pressure, (H_2O) -0.10
Filter Number(s) _____

<u>Impinger Volumes</u>		
<u>Initial</u>	<u>Final</u>	<u>Net Gain</u>
<u>501.9</u>	<u>501.8</u>	<u>79.9</u>
<u>538.4</u>	<u>570.0</u>	<u>31.6</u>
<u>538.6</u>	<u>551.3</u>	<u>12.7</u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>

<u>Silica Gel</u>	
<u>44.2 g</u>	<u>46.1 g</u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>

Probe Length and Type _____
 Nozzle Size & I.D. _____
 Pitot Coefficient & I.D. _____
 Assumed Moisture _____
 Molecular Weight, Dry, (M_d) _____
 Meter Box Number _____
 Meter Coefficient _____
 Factor _____
 $K = \frac{83.2}{13.9}$
 $K(N_d)^4 = 8.39^{3.9} (1.38)^4 = 18.54$
 $\Delta H = K(N_d)^4 \left(\frac{T_m}{T_s} \right) (P)$

Leak Check: Initial at $\frac{15}{11}$ " Hg, $\frac{.025}{.013}$ CFM
Final at $\frac{11}{11}$ " Hg, $\frac{.013}{.013}$ CFM
Pitot Leak Check: $\frac{11}{11}$ " Hg, $\frac{.013}{.013}$ CFM

SASS Condensate _____
Total Volume 24.3

Traverse Point Number	Sampling Time, min	Clock Time (24-hr) Clock	Gas Meter Reading (V _m), ft ³	Velocity Head (ΔP _v), in. H ₂ O	Orifice Pressure Differential (ΔH), in. H ₂ O		Temperature °F							Pump Vacuum in. Hg	Avg. ΔP
					Desired	Actual	Stack	Probe	Impinger	Organic Module	Oven	Gas Meter			
												In	Out		
	α	0915	Init. 648.735												
B-1	5		651.53	.07	.90	.90	338		79			250	83	86	7
2	10		652.815	.045	.58	.58	338		79			250	86	86	5
3	15		656.40	.06	.76	.76	351		76			250	86	86	6
4	20		658.78	.05	.64	.64	338		76			247	86	85	5
5	25		661.01	.05	.65	.64	327		78			247	86	88	5
6	30		663.487	.05	.66	.66	325		76			247	87	87	5
	*	0935													
A-1	35	0954	666.35	.07	.92	.92	319		71				84	87	7
A-2	40		669.18	.07	.93	.93	332		69			242	99	98	7

7602/5/81/Rev 1

Comments: * changed ports

4-28

Plant West of Agua
 Date 7/7/83
 Sample Location Smash House
 Sample Type SASS
 Run Number #2
 Operator Donna L. Quinn
 Ambient Temperature -70
 Barometric Pressure 28.60
 Static Pressure, (H₂O) -0.10
 Filter Number(s) _____

Impinger Volumes

Initial	Final	Net Gain
800	800	0
800	800	0
800	800	0
800	800	0
800	800	0
800	800	0
800	800	0
800	800	0
800	800	0

Silica Gel

SASS Condensate

Total Volume

Probe Length and Type 344
 Nozzle Size & I.D. _____
 Pitot Coefficient & I.D. 0.80
 Assumed Moisture 7.5
 Molecular Weight, Dry, (M_d) _____
 Meter Box Number 5
 Meter Coefficient 3.514
 α Factor 0.973
 K = N/A
 $K(N_d)^4 = \text{---} \times (\text{---})^4 = \text{N/A}$
 $\Delta H = K(N_d)^4 \left(\frac{T_m}{T_s} \right) (P)$

$$\Delta H = T_m * .004$$

Leak Check: Initial at _____ " Hg, 0.35 CFM
 Final at _____ " Hg, 0.20 CFM
 Pitot Leak Check: _____

Traverse Point Number	Sampling Time, min	Clock Time (24-hr) Clock	Gas Meter Reading (V _m), ft ³	Velocity Head (ΔP _v), in. H ₂ O	Orifice Pressure Differential (ΔH), in. H ₂ O		Temperature Of							Pump Vacuum in. Hg	Avg. √ΔP	
					Desired	Actual	Stack	Probe	Impinger	Organic Module	Oven	Gas Meter				
												In	Out			
	0	0910	Init. 783.60													
	10	0915	822.0	.065	2.23	2.2	279	410			70	411	93	95	15	
	20	0925	860.0	.07	2.23	2.1	292	410			69	410	103	98	15	
	30	0935	897.9	.065	2.23	2.1	296	408			68	412	114	106	15	
	40	0945	936.2	.065	2.28	2.2	311	406			67	414	118	109	15	
	50	0952	974.5	.065	2.28	2.0	292	405			67	414	109	109	19	
	60	1002	012.6	.06	2.28	2.0	289	411			61	415	114	107	19	
	70	1012	049.3	.065	2.28	2.0	269	41			61	418	113	107	19	
	80	1022	085.8	.06	2.28	1.9	304	409			63	421	113	108	19	
	90	1032	-----	.06	2.28	1.85	298	404			63	422	115	110	20	

7602/5/81/Rev 1

Comments: STOP AT MIN 40 TO CHANGE FROM PORT A TO PORT B

Traverse Point Number	Clock Time (24-hr) Clock	Gas Meter Reading (V _m), ft ³	Velocity Head (ΔP _s), in. H ₂ O	Orifice Pressure Differential (ΔH), in. H ₂ O		Temperature °F					Gas Meter		Pump Vacuum in. Hg	Avg. ΔP
	Sampling Time, min	Init.		Desired	Actual	Stack	Probe	Impinger	Organic Module	Oven	In	Out		
	1032 40													
	100	156.5	.055	228	1.8	303	415		65	420	113	111	20	
	110	190.637	.055	228	1.7	321	415		68	419	109	109	20	
	120	230.5	.06	224	2.25	283	309		70	412	99	103	15	
	130	269.0	.06	224	2.25	292	391		67	415	114	106	15	
	140	306.7	.06	224	2.2	295	402		67	417	117	109	5	
	150	344.8	.065	229	2.1	290	414		71	420	113	112	19	
	160	382.2	.065	229	1.9	295	390		71	412	111	111	19	
	170	418.4	.07	229	1.9	288	406		77	413	111	110	20	
	180	453.2	.065	229	1.8	290	402		75	402	105	107	20	
	RESTART 12:55 190	492.2	.06	226	2.2	297	405		71	409	100	103	15	
	200	530.8	.06	226	2.1	292	295		71	410	105	103	15	
	210	568.5	.065	226	2.1	280	401		68	411	103	102	19	
	220	606.0	.065	228	2.0	292	414		71	414	105	100	19	
	230	641.5	.065	228	1.9	272	399		73	410	105	105	19	
	240	676.2	.065	226	1.8	257	400		73	415	109	109	20	
	250	710.6	.065	226	1.75	271	410		79	407	105	100	20	
	260	743.509	.065	226	1.7	275	415		71	414	106	105	20	

Run No. 2-SASSDate 7-7-83Sampling Location SAW HOLE

Comments: STOP AT M.N. 110 TO CHANGE FILTER & SILICA GEL. Restart 11:15
 STOP AT M.N. 180 TO CHANGE FILTER & SILICA GEL. Restart 12:55
 Final 100% check entire train. ΔH 0.10"
 ΔP 2.2"

SASS ANALYTICAL DATA

Plant Rock of Ages 7735 61 Sample No. SASS-2
 Sampling Location _____ Run No. 2
 Recovered By _____ Recovery Date 7/7/83 Run Date 7/7/83
 Comments _____
 Analyst Responsible _____
 Calculations and Report Reviewed By _____ Report Date _____

FILTERS USED

No. 380
357
346

CYCLONES

	Used (yes/no)	Pretared Container (No.)
10 μ	_____	_____
3 μ	_____	_____
1 μ	_____	_____

IMPINGER VOLUMES

	Initial	Final	
First (H ₂ O ₂)	<u>500</u> ml	<u>570.0</u> ml	
Second (APS + AgNO ₃)	<u>500</u> ml	<u>452.0</u> ml	
Third (APS + AgNO ₃)	<u>500</u> ml	<u>405.0</u> ml	
TOTALS	_____ ml	_____ ml	Gain _____ ml

SILICA GEL WEIGHS

	Initial	Final	
<u>800.0</u> g	<u>989.9</u> g		
<u>800.0</u> g	<u>998.8</u> g		
<u>800.0</u> g	<u>914.2</u> g		
TOTALS	_____ g	_____ g	Gain _____ g

CONDENSATE

TOTAL VOLUME COLLECTED _____ ml

Volume Neat _____ ml

Volume Extracted _____ ml

Volume CH₂Cl₂ Extract (3 x _____ ml) _____ ml

Extracted Condensate: pH Neat _____

Amount 96% HNO₃ added _____

pH Final _____

TOTAL GAIN _____ ml

Probe Length and Type 5 ft x 1/2 x
 Nozzle Size & I.D. 3/8" 7
 Pitot Coefficient & I.D. 0.800
 Assumed Moisture 0.75
 Molecular Weight, Dry, (M_d)
 Meter Box Number NAPP-0254
 Meter Coefficient 1.25
 α Factor 0.012
 $K =$ $\frac{44}{11.3} \cdot 1.3$
 $K(N_d)^4 =$ $\times$ $^4 =$ 18.8
 $\Delta H = K(N_d)^4 \left(\frac{T_m}{T_s} \right) (P)$

SASS Condensate _____
Total Volume - 58

[illegible]

7602/5/81/Rev 1

Comments:

4-33

ISOKINETIC CALCULATIONS - USEPA: M/5 BASIS

ROCK OF AGES - NO. 2

RUN NUMBER	2-SASS	2-M5/8	2-HCL
DATE OF TEST	7-7-83	7-7-83	7-7-83
OPERATOR	PWK	VB	VB
METER VOLUME, CF	960.049	31.853	14.871
METER COEF	0.973	1.012	1.012
BAROMETRIC PRES, HG	28.6	28.6	28.6
DELTA H, IN H2O	1.988	0.813	0.74
METER TEMP, DEG F	107.7	90	94.5
STACK TEMP, DEG F	290.5	329	324.7
CONDENSATE, ML	1097.9	39.2	15.7
PERCENT CO2	7.5	7.5	7.5
PERCENT O2	8.8	8.8	8.8
PERCENT CO	0	0	0
PERCENT N2	83.7	83.7	83.7
STATIC PRES, IN H2O	-0.1	-0.1	-0.1
PITOT COEF	0.79	0.79	0.79
SQRT DELTA P, IN H2O	0.251	0.248	0.245
STACK AREA, SQ FT	2.405	2.405	2.405
NOZZLE DIAM, IN	1.24	0.387	0.387
TEST TIME, MIN	260	60	30
MASS PARTICULATE, G	0	0	0
F-FACTOR, DSCF/MBTU			
VOLUME, DSCF	881.833	28.948	13.403
WATER VAPOR, SCF	51.678	1.845	0.739
PERCENT MOISTURE	0.055	0.060	0.052
MOLECULAR WT DRY, LB/LB	29.552	29.552	29.552
MOLECULAR WT WET, LB/LB	28.91	28.86	28.95
STACK PRES, IN HG	28.59	28.59	28.59
STACK VELOCITY, FT/SEC	16.15	16.38	16.11
MASS FLOW, DSCFM	1,480	1,421	1,417
MASS FLOW, ACFM	2,331	2,363	2,325
PERCENT EXCESS AIR			
PERCENT ISOKINETIC	65.762	100.057	92.915
GRAIN LOADING, GR/DSCF	0.00000	0.00000	0.00000
GRAIN LOADING, GR/ACF	0.00000	0.00000	0.00000
EMISSION RATE, LB/HR-STD	0.00000	0.00000	0.00000
EMISSION RATE, LB/MBTU			

Plant ROCK OF ASSES
 Date 7/1/83
 Sample Location SWL HOUSE
 Sample Type M-5 S
 Run Number 3
 Operator BARKUS
 Ambient Temperature 70
 Barometric Pressure 28.60
 Static Pressure, (H₂O) -1.0
 Filter Number(s) _____

Impinger Volumes

Initial	Final	Net Gain
520.0	487.4	-32.4
545.8	555.1	39.3
502.2	552.4	10.2
671.4	687.6	

 Silica Gel

Probe Length and Type 5" PYREX
 Nozzle Size & I.D. 1/32" / 945
 Pitot Coefficient & I.D. .820
 Assumed Moisture 2.75
 Molecular Weight, Dry, (M_d) _____
 Meter Box Number 0554
 Meter Coefficient .725
 α Factor 1.012
 K = 834.939
 $K(N_d)^4 = 834.939^4 (1.387)^4 = 1884$
 $\Delta H = K(N_d)^4 \left(\frac{T_m}{T_s} \right) (P)$

Leak Check: Initial at 20 " Hg, 1024 CFM
 Final at 13 " Hg, 1015 CFM
 Pitot Leak Check: ☒

SASS Condensate

Total Volume

32.7

4-35

Traverse Point Number	Sampling Time, min	Clock Time (24-hr) Clock	Gas Meter Reading (V _m), ft ³	Velocity Head (ΔP _v), in. H ₂ O	Orifice Pressure Differential (ΔH), in. H ₂ O		Temperature Of							Avg. √ΔP
							Stack	Probe	Impinger	Organic Module	Oven	Gas Meter		Pump Vacuum in. Hg
												In	Out	
			Init. 724.608		Desired	Actual								
A-1	5		727.64	.07	.94	.94	310		61		245	81	88	7.5
2	10		730.409	.07	.94	.94	300		62		245	91	87	7.5
3	15		733.49	.07	.96	.96	293		65		244	88	86	7.5
4	20		736.43	.07	.97	.97	288		78		230	88	88	7.5
5	25		739.37	.07	.98	.98	280		68		255	88	85	7.5
6	30		742.252	.065	.91	.91	278		69		258	88	88	7.5
			745.74	.09	1.27	1.27	276		66		260	88	90	7.5
B-1	35		745.74	.09	1.27	1.27	276		66		260	88	90	7.5
2	40		748.68	.09	1.29	1.29	265		66			90	90	9.0

7602/5/81/Rev 1

Comments: * changed

Probe Length and Type _____
 Nozzle Size & I.D. 3/8"
 Pitot Coefficient & I.D. 0.900
 Assumed Moisture _____
 Molecular Weight, Dry, (M_d) _____
 Meter Box Number NAPP-0554
 Meter Coefficient 726
 α Factor 1.012
 $K =$ 641.373
 $K(N_d)^4 =$ _____ $\times$ (_____)⁴ = 18373
 $\Delta H = K(N_d)^4 \left(\frac{T_m}{T_s} \right) (P)$

SASS Condensate _____
Total Volume 17.22

[illegible]

7602/5/81/Rev 1

Comments:

4-37

ISOKINETIC CALCULATIONS - USEPA: M/5 BASIS

ROCK OF AGES - NO. 3

RUN NUMBER	3-M5/8	3-HCL
DATE OF TEST	7-7-83	7-7-83
OPERATOR	VB	VB
METER VOLUME, CF	36.383	13.856
METER COEF	1.012	1.012
BAROMETRIC PRES, HG	28.6	28.6
DELTA H, IN H2O	0.976	0.647
METER TEMP, DEG F	88.4	91
STACK TEMP, DEG F	276.7	326.8
CONDENSATE, ML	32.7	17.2
PERCENT CO2	7.5	7.5
PERCENT O2	8.8	8.8
PERCENT CO	0	0
PERCENT N2	83.7	83.7
STATIC PRES, IN H2O	-0.1	-0.1
PITOT COEF	0.79	0.79
SQRT DELTA P, IN H2O	0.263	0.257
STACK AREA, SQ FT	2.405	2.405
NOZZLE DIAM, IN	0.387	0.387
TEST TIME, MIN	60	30
MASS PARTICULATE, G	0	0
F-FACTOR, DSCF/MBTU	0	0
VOLUME, DSCF	33.176	12.564
WATER VAPOR, SCF	1.539	0.810
PERCENT MOISTURE	0.044	0.061
MOLECULAR WT DRY, LB/LB	29.552	29.552
MOLECULAR WT WET, LB/LB	29.04	28.85
STACK PRES, IN HG	28.59	28.59
STACK VELOCITY, FT/SEC	16.73	16.95
MASS FLOW, DSCFM	1,580	1,474
MASS FLOW, ACFM	2,414	2,446
PERCENT EXCESS AIR		
PERCENT ISOKINETIC	103.100	83.741
GRAIN LOADING, GR/DSCF	0.00000	0.00000
GRAIN LOADING, GR/ACF	0.00000	0.00000
EMISSION RATE, LB/HR-STD	0.00000	0.00000
EMISSION RATE, LB/MBTU		

~~VOST FIELD~~
ACUREX CORPORATION
~~AMBIENT AIR / PERSONNEL MONITORING LOG~~

COMPANY Rock of Lee LOCATION DEFENSE PROJECT NO. 20-0000 RECORDED BY 10/1/10

DATE	RUN NO.	LOCATION AND OR PERSON	POLLUTANT	CLOCK TIME (24-HOUR)		ELAPSED TIME (MIN)	FLOW RATE (UNITS ____)		AVERAGE FLOW	TOTAL VOLUME SAMPLED (UNITS ____)	SAMPLE I.D.	COMMENTS/NOTES: BAROMETRIC PRESSURE, RELATIVE HUMIDITY, AMBIENT TEMP., ETC.
				START	FINISH		START	STOP				
7/6/10	2	1-2	VOST	1553			77			70°F	-2" Hg	77°F
				1558			77			70°F	-2	77°F
				1603			77			69°F	-2	79°F
				1608			75.5			70°F	-2	81°F
				1613			75.5			71°F	-2	83°F
		4A + 5										

SECTION 5
ANALYTICAL RESULTS

- 5.1 FUEL AND ASH SAMPLE PROXIMATE AND ULTIMATE ANALYSES
- 5.2 PARTICULATE EMISSIONS FROM SASS SAMPLES
- 5.3 PARTICULATE AND SULFUR OXIDES EMISSIONS FROM EPA METHOD 5/8 SAMPLES
- 5.4 HCl EMISSIONS FROM HCl TRAIN SAMPLES
- 5.5 TRACE ELEMENT AND LEACHABLE ANION ANALYSES
- 5.6 TOTAL CHROMATOGRAPHABLE ORGANICS (TCO), GRAVIMETRIC ORGANICS (GRAV), GAS CHROMATOGRAPHY/MASS SPECTROMETRY (GC/MS), AND INFRARED SPECTRA (IR) OF TOTAL SAMPLE EXTRACTS
- 5.7 LIQUID CHROMATOGRAPHY (LC) SEPARATION AND IR SPECTRA OF LC FRACTIONS
- 5.8 GC/MS ANALYSES OF VOST TRAPS
- 5.9 N₂O ANALYSES BY GC/ECD
- 5.10 BIOASSAY RESULTS

5.1 FUEL AND ASH SAMPLE PROXIMATE AND ULTIMATE ANALYSES

In the following, the sample denoted cyclone ash test 3 is a blind duplicate of the cyclone ash test 1 sample.

LABORATORY CERTIFICATE

CURTIS & TOMPKINS, LTD.

ESTABLISHED 1878

Bulk Oil & Chemical Surveyors, Samplers & Weighers
Analytical & Consulting Chemists

SOUTHERN DIVISION
401 Canal Street
Wilmington, CA 90748
213-548-6740
TWX 910-345-6820
ANALYST WILN

290 Division Street
San Francisco, CA 94103
415-861-1863
Telex: 171042
CABLE: ANALYST SFO

FOOD TECHNOLOGISTS
ENVIRONMENTAL ANALYSTS
MEMBERS, OFFICIAL CHEMISTS
AND/OR SAMPLERS FOR GOVERNMENT
AGENCIES AND TRADE ORGANIZATIONS

Laboratory No. 83n160
Preliminary No. 4625

Reported 12/14/83
Sampled -----
Received 11/22/83

For ACUREX CORPORATION

Report on 11 samples of Products

Mark

- 1) 819449, RA Coal, Test 1
- 2) 819485, RA Pet, Test 2
- 3) 819478, RA Coal, Pet, Test 2
- 4) 900209, DM Coal Water Slurry
- 5) 819498, RA Bottom Ash, Test 1
- 6) 819498, RA Bottom Ash, Test 2
- 7) 819476, RA Cyclone Ash, Test 1
- 8) 819504, RA Cyclone Ash, Test 2
- 9) 819457, RA Cyclone Ash, Test 3
- 10) 819475, RA Composite Particulate, Test 1
- 11) 819475, RA Composite Particulate, Test 2

P.O. RB59186A Rel 7

SEE ATTACHED FOR RESULTS

Curtis & Tompkins Ltd.

SAMPLES DISCARDED 30 DAYS AFTER RECEIPT UNLESS OTHERWISE REQUESTED

83n160

ULTIMATE ANALYSIS - Dry Basis, %	1	2	3	4	5	6	7	8	9	10	11
Carbon -----	71.50	73.80	73.10	83.50	16.70	21.20	30.90	33.60	30.90	14.50	21.10
Hydrogen-----	5.30	10.30	5.60	5.30	0.14	0.17	1.40	0.92	1.07	1.54	1.10
Nitrogen (1st Test) -----	1.51	0.08	1.27	1.52	0.20	0.35	1.00	1.20	1.06	1.00	0.48
Nitrogen (2nd Test) -----	1.53	0.16	1.48	1.62							
Nitrogen (3rd Test) -----	1.58	0.20	1.40	1.66							
Sulfur (1st Test) -----	0.092 ^a	0.07	0.63	0.84	0.24	0.18	4.50	2.90	4.60		
Sulfur (2nd Test) -----	0.055 ^a	0.10	0.65	0.90							
Sulfur (3rd Test) -----	0.098 ^a	0.08	0.68	0.95							
Ash -----	8.78	1.66	7.02	4.41	81.59	0.54	51.06	51.04	48.39	61.40	42.71
Oxygen(by Difference)-----	12.50	13.93	12.29	4.09	1.08	77.48	10.94	10.08	13.79	21.56	34.61
Chloride -----	0.20	0.07	0.23	0.20	0.05	0.08	0.20	0.26	0.19		

ON PROXIMATE ANALYSIS - Dry Basis, %

Gross Heating Value											
BTU per Lb. -----	13,825	12,870	13,670	15,020	600	1,600	4,940	5,340	4,700		
Volatile Matter -----	34.14	92.92	42.33	30.69							
Fixed Carbon -----	57.08	5.42	50.65	64.90							
Ash -----	8.78	1.66	7.02	4.41	81.59	0.54	51.06	51.04	48.39	61.40	42.71
Moisture (as Rec'd) -----	2.73	0.53	1.43	44.07	0.15	0.14	8.73	3.99	8.97		

^a J. Vale of Curtis and Thompkins reported by phone to H. Lips of Acurex on March 23, 1984, that the sulfur analyses for sample 1 were 0.92, 0.95, and 0.98 for the three tests, respectively (authors)

Curtis & Thompkins Inc.

5.2 PARTICULATE EMISSIONS FROM SASS SAMPLES

ACUREX ANALYTICAL REPORT

Sample of: CMEA/Rock of Ages

Sample Date: 7-7-83

Requested By: L. Waterland

I.D. Number: 307735-62

Analytical Method: SASS-1 Particulate Weights

Date of Analysis: 7/15 - 7/22-83

Lab I.D. Number	Component	Analytical Result	Unit
819461	SASS probe wash	1.5993 1.4276 tare <u>0.1717</u> net	g ↓
819456	10 μ cyclone	0.0877	
819457	3 μ cyclone	0.2156	
819458	1 μ cyclone	0.0793	
819463	Filter 354 (#1)	1.3160 1.0341 tare <u>0.2819</u> net	
819464	Filter 360 (#2)	1.1973 1.1419 tare <u>0.0554</u> net	

Analysis By Brewster

5-9 Date 7-22-83

ISOKINETIC PERFORMANCE WORKSHEET & PARTICULATE CALCULATIONS

Plant Rock of Ages

Performed by DaRos

Date 7-6-83

Sample Location San House

Test No./Type 1 - SASS

Barometric Pressure (in. Hg)	P_b	28.24
Meter volume (std), $17.64 \left(\frac{V_m}{\alpha} \right) \left(\frac{P_b + \frac{\Delta H}{13.6}}{T_m + 460} \right)$ $17.64 \left(\frac{(\quad)}{(972)} \right) \left(\frac{(28.24) + \frac{(2.012)}{13.6}}{(68.6) + 460} \right)$	$V_{m \text{ std}}$	967.246
Volume of liquid collected (grams)	V_{l_c}	964.7
Volume of liquid at standard condition (scf) $V_{l_c} \times 0.04707$	$V_{w \text{ std}}$	45.408
Stack gas proportion of water vapor $\frac{V_{w \text{ std}}}{V_{w \text{ std}} + V_{m \text{ std}}}, \frac{(45.408)}{(45.408) + (\quad)}$	B_{w0}	0.045
Molecular weight, stack gas dry (lb/lb-mole) $(\% \text{ CO}_2 \times 0.44) + (\% \text{ O}_2 \times 0.32) + (\% \text{ N}_2 + \% \text{ CO} \times 0.28)$ $(7.1 \times 0.44) + (12.2 \times 0.32) + (80.7 + \quad \times 0.28)$	M_d FROM MPR Avg.	29.624
Molecular weight, stack gas wet (lb/lb-mole) $M_d(1-B_{w0}) + 18(B_{w0}), (29.624)(1-0.045) + 18(0.045)$	M_s	29.10
Absolute stack pressure (in. Hg) $P_b + \frac{P_{\text{stack}} (\text{in. H}_2\text{O})}{13.6}, (28.24) + \frac{(-0.1)}{13.6}$	P_s	28.23

Temperature stack gas, average (°F)	T_s	274.3
Stack velocity (fps) $85.49 (C_p) (\sqrt{\Delta P_{s \text{ avg}}}) \sqrt{\frac{T_{s \text{ avg}} + 460}{P_s M_s}}$ $85.49 (.79)(\sqrt{.234})^2 \sqrt{\frac{(274.3) + 460}{(28.23)(29.10)}}$	$V_{s(\text{avg})}$	14.94
Total sample time (minutes)	θ	260
Nozzle diameter, actual (inches)	N_d	1.240
Percent isokinetic (%) $\frac{17.33 (T_s + 460)(V_w \text{ std} + V_m \text{ std})}{\theta V_s P_s N_d^2}$ $\frac{17.33 (\text{ } + 460)((\text{ }) + (\text{ }))}{(\text{ })(\text{ })(\text{ })(\text{ })^2}$	%I	76.421
Area of stack (ft ²) $\pi = 3.1416$ $\pi r^2 \div 144, \quad \pi (10.5")^2 \div 144$	A_s	2.405
Stack gas volume at standard conditions (dscfm) $60 (1 - B_{wo}) V_{s \text{ avg}} A_s \left(\frac{528}{T_s \text{ avg} + 460} \right) \left(\frac{P_s}{29.92} \right)$ $60 (1 - \text{ })(\text{ })(\text{ }) \left(\frac{528}{\text{ } + 460} \right) \left(\frac{(\text{ })}{(29.92)} \right)$	ACFM Q_s	2,156 1,397
Particulate matter concentration, dry (gr/dscf) $15.432 \frac{M_p (\text{grams})}{V_{m \text{ std}}}, \quad 15.432 \frac{(0.8190)}{(96.246)}$	$C_{s(\text{std})}$	0.01308
Emission rate of particulate matter (lb/hr) $0.00857 (Q_s) C_{s(\text{std})}, \quad 0.00857 (\text{ })(\text{ })$	E_p	

ACUREX ANALYTICAL REPORT

Sample of: CMEA/Box of Ages

Sample Date: 7-7-83

Requested By: L. Wintersland

I.D. Number: 307735-62

Analytical Method: SAAS-2 Particulate Weights

Date of Analysis: 7/19 - 7/22/83

Lab I.D. Number	Component	Analytical Result	Unit
819482	Probe wash	1.5820 1.4321 <u>tare</u> 0.1499 net	g
819492	10µ cyclone	0.1181	
819493	3µ cyclone	0.3160	
819494	1µ cyclone	broken	
819475	Filter 346	1.3105 1.1292 <u>tare</u> 0.1813 net	
819495	Filter 357	1.2937 1.1488 <u>tare</u> 0.1449 net	
819486	Filter 380	1.2947 1.1560 <u>tare</u> 0.1387 net	

Analysis By Brewster

Date 7-22-83

ISOKINETIC PERFORMANCE WORKSHEET & PARTICULATE CALCULATIONS

Plant Rock of AgesPerformed by D. ResDate 7-7-83Sample Location Saw HouseTest No./Type 2-SASS

Barometric Pressure (in. Hg)	P_b	28.60
Meter volume (std), $17.64 \left(\frac{V_m}{\alpha} \right) \left(\frac{P_b + \frac{\Delta H}{13.6}}{T_m + 460} \right)$ $17.64 \left(\frac{960.049}{(973)} \right) \left(\frac{(28.60) + \frac{(1.988)}{13.6}}{(107.7) + 460} \right)$	$V_{m \text{ std}}$	881.833
Volume of liquid collected (grams)	V_{l_c}	1097.9
Volume of liquid at standard condition (scf) $V_{l_c} \times 0.04707$	$V_{w \text{ std}}$	51.678
Stack gas proportion of water vapor $\frac{V_{w \text{ std}}}{V_{w \text{ std}} + V_{m \text{ std}}}, \frac{(51.678)}{(51.678) + (881.833)}$	B_{w0}	0.055
Molecular weight, stack gas dry (lb/lb-mole) $(\% \text{ CO}_2 \times 0.44) + (\% \text{ O}_2 \times 0.32) + (\% \text{ N}_2 + \% \text{ CO} \times 0.28)$ $(7.5 \times 0.44) + (8.8 \times 0.32) + (83.7 + \text{ } \times 0.28)$	M_d From MPR Avg	29.552
Molecular weight, stack gas wet (lb/lb-mole) $M_d(1-B_{w0}) + 18(B_{w0}), (29.552)(1-0.055) + 18(0.055)$	M_s	28.91
Absolute stack pressure (in. Hg) $P_b + \frac{P_{\text{stack}} (\text{in. H}_2\text{O})}{13.6}, (28.60) + \frac{(-0.1)}{13.6}$	P_s	28.59

Temperature stack gas, average (°F)	T_s	290.5
Stack velocity (fps) $85.49 (C_p) (\sqrt{4P_{s \text{ avg}}}) \sqrt{\frac{T_{s \text{ avg}} + 460}{P_s M_s}}$ $85.49 (.79) (.251) \sqrt{\frac{(290.5) + 460}{(28.57)(28.91)}}$	$V_{s(\text{avg})}$	16.15
Total sample time (minutes)	θ	260
Nozzle diameter, actual (inches)	N_d	1.240
Percent isokinetic (%) $\frac{17.33 (T_s + 460)(V_w \text{ std} + V_m \text{ std})}{\theta V_s P_s N_d^2}$ $\frac{17.33 (\text{ } + 460)((\text{ }) + (\text{ }))}{(\text{ })(\text{ })(\text{ })(\text{ })^2}$	%I	65.762
Area of stack (ft ²) $\pi = 3.1416$ $\pi r^2 \div 144, \quad \pi (10.5)^2 \div 144$	A_s	2.405
Stack gas volume at standard conditions (dscfm) $60 (1 - B_{wo}) V_{s \text{ avg}} A_s \left(\frac{528}{T_{s \text{ avg}} + 460} \right) \left(\frac{P_s}{29.92} \right)$ $60 (1 - \text{ })(\text{ })(\text{ }) \left(\frac{528}{\text{ } + 460} \right) \left(\frac{(\text{ })}{(29.92)} \right)$	ACFM Q_s	2,331 1,480
Particulate matter concentration, dry (gr/dscf) $15.432 \frac{M_p(\text{grams})}{V_m \text{ std}}, \quad 15.432 \frac{(\text{ })}{(\text{ })}$	$C_{s(\text{std})}$	
Emission rate of particulate matter (lb/hr) $0.00857 (Q_s) C_{s(\text{std})}, \quad 0.00857 (\text{ })(\text{ })$	E_p	

* 1 cycle lost

5.3 PARTICULATE AND SULFUR OXIDES EMISSIONS FROM EPA METHOD 5/8 SAMPLES

ACUREX ANALYTICAL REPORT

Sample of: CMEA/Rock of Ages

Sample Date: 7/6 - 7/7/83

Requested By: L. Waterland

I.D. Number: 307735.62

Analytical Method: M/S Filter Weights

Date of Analysis: 7-22-83

Lab I.D. Number	Component	Analytical Result	Unit
819571	Filter Blank	$ \begin{array}{r} 0.47655 \\ 0.47385 \text{ tare} \\ \hline 0.00270 \text{ net} \end{array} $	g ↓
819566	M/S Filter, test 1	$ \begin{array}{r} 0.52386 \\ 0.47819 \text{ tare} \\ \hline 0.04567 \text{ net} \end{array} $	
819472	M/S Filter, test 2	$ \begin{array}{r} 0.53376 \\ 0.47424 \text{ tare} \\ \hline 0.05952 \text{ net} \end{array} $	
819490	M/S Filter, test 3	$ \begin{array}{r} 0.50041 \\ 0.47654 \text{ tare} \\ \hline 0.02387 \text{ net} \end{array} $	

Analysis By: Murray

5-17 Date: 7-22-83

ACUREX ANALYTICAL REPORT

Sample of: CMEA/Rock of Mfgs

Sample Date: 7-26-7/7/83

Requested By: L. Waterland

I.D. Number: 307735-62

Analytical Method: Sulfate analyses of Method 8 impinger

Date of Analysis: 7-25-83

Lab I.D. Number	Component	Analytical Result	Unit
819569	80% LAA blank	0.5	mg SO ₃
819567	MSR-1 1st impinger	5.7	
819470	MSR-2 1st impinger	4.6	
819491	MSR-3 1st impinger	2.5	
819570	69% H ₂ O ₂ blank	3.2	mg SO ₂
819568	MSR-1 2+3 impingers	963.4	
819471	MSR-2 2+3 impingers	946.9	
819487	MSR-3 2+3 impingers	490.8	
Lot 0282 audit		355.4	mg SO ₂ /dsum
Samples : 4xxx		2345.4	
8xxx		873.5	
9xxx			

Analysis By Murray

Date 7-25-83

ISOKINETIC PERFORMANCE WORKSHEET & PARTICULATE CALCULATIONS

Plant Rock of AgesPerformed by D. K. Co.Date 7-6-83Sample Location Saw HouseTest No./Type 1 - MS/8

Barometric Pressure (in. Hg)	P_b	28.24
Meter volume (std), $17.64 \left(\frac{V_m}{\alpha} \right) \left(\frac{P_b + \frac{\Delta H}{13.6}}{T_m + 460} \right)$ $17.64 \left(\frac{(30.22)}{(1.012)} \right) \left(\frac{(28.24) + \frac{(1.703)}{13.6}}{(69.5) + 460} \right)$	$V_{m \text{ std}}$	28.161
Volume of liquid collected (grams)	V_{l_c}	54.1
Volume of liquid at standard condition (scf) $V_{l_c} \times 0.04707$	$V_{w \text{ std}}$	2.546
Stack gas proportion of water vapor $\frac{V_{w \text{ std}}}{V_{w \text{ std}} + V_{m \text{ std}}}, \frac{(2.546)}{(2.546) + (28.161)}$	B_{wo}	0.083
Molecular weight, stack gas dry (lb/lb-mole) $(\% \text{ CO}_2 \times 0.44) + (\% \text{ O}_2 \times 0.32) + (\% \text{ N}_2 + \% \text{ CO} \times 0.28)$ $(7.1 \times 0.44) + (12.2 \times 0.32) + (80.7 + \text{ } \times 0.28)$	M_d From MPR Avg.	29.624
Molecular weight, stack gas wet (lb/lb-mole) $M_d(1-B_{wo}) + 18(B_{wo}), (29.624)(1-0.083) + 18(0.083)$	M_s	28.66
Absolute stack pressure (in. Hg) $P_b + \frac{P_{\text{stack}} (\text{in. H}_2\text{O})}{13.6}, (28.24) + \frac{(-0.1)}{13.6}$	P_s	28.23

Temperature stack gas, average (°F)	T_s	295.3
Stack velocity (fps) $85.49 (C_p) (\sqrt{\Delta P_{s \text{ avg}}}) \sqrt{\frac{T_{s \text{ avg}} + 460}{P_s M_s}}$ $85.49 (.79) (.231) \sqrt{\frac{(295.3 + 460)}{(28.23)(28.66)}}$	$V_{s(\text{avg})}$	15.07
Total sample time (minutes)	θ	60
Nozzle diameter, actual (inches)	N_d	0.387
Percent isokinetic (%) $17.33 (T_s + 460)(V_w \text{ std} + V_m \text{ std})$ $\frac{\theta V_s P_s N_d^2}{17.33 (\text{ } + 460)((\text{ }) + (\text{ }))}$ $\frac{(\text{ })(\text{ })(\text{ })(\text{ })^2}{(\text{ })(\text{ })(\text{ })(\text{ })^2}$	%I	105.109
Area of stack (ft ²) $\pi = 3.1416$ $\pi r^2 \div 144, \quad \pi (10.5")^2 \div 144$	A_s	2.405
Stack gas volume at standard conditions (dscfm) $60 (1 - B_{wo}) V_{s \text{ avg}} A_s \left(\frac{528}{T_{s \text{ avg}} + 460} \right) \left(\frac{P_s}{29.92} \right)$ $60 (1 - \text{ })(\text{ })(\text{ }) \left(\frac{528}{\text{ } + 460} \right) \left(\frac{(\text{ })}{(29.92)} \right)$	ACFM Q_s	2,175 1,316
Particulate matter concentration, dry (gr/dscf) $15.432 \frac{M_p(\text{grams})}{V_m \text{ std}}, \quad 15.432 \frac{(20.187)}{(28.161)}$	$C_{s(\text{std})}$	0.02355
Emission rate of particulate matter (lb/hr) $0.00857 (Q_s) C_{s(\text{std})}, 0.00857 (\text{ })(\text{ })$	E_p	$\frac{963.7}{28.161} = 34.2 \frac{\text{mg}}{\text{dscf}}$

$$SO_3 = \frac{5.7}{28.161} = 0.202 \frac{\text{mg}}{\text{dscf}}$$

ISOKINETIC PERFORMANCE WORKSHEET & PARTICULATE CALCULATIONS

Plant Rock of Ages

Performed by DA Ros

Date 7-7-83

Sample Location Saw House

Test No./Type 2 - MS/8

Barometric Pressure (in. Hg)	P_b	28.60
Meter volume (std), $17.64 \left(\frac{V_m}{\alpha} \right) \left(\frac{P_b + \frac{\Delta H}{13.6}}{T_m + 460} \right)$ $17.64 \left(\frac{31.853}{(1.012)} \right) \left(\frac{(28.60) + \frac{(0.813)}{13.6}}{(90) + 460} \right)$	$V_{m \text{ std}}$	28.948
Volume of liquid collected (grams)	V_{l_c}	39.2
Volume of liquid at standard condition (scf) $V_{l_c} \times 0.04707$	$V_{w \text{ std}}$	1.845
Stack gas proportion of water vapor $\frac{V_{w \text{ std}}}{V_{w \text{ std}} + V_{m \text{ std}}}, \frac{(1.845)}{(1.845) + (28.948)}$	B_{w0}	0.060
Molecular weight, stack gas dry (lb/lb-mole) $(\% \text{ CO}_2 \times 0.44) + (\% \text{ O}_2 \times 0.32) + (\% \text{ N}_2 + \% \text{ CO} \times 0.28)$ $(7.5 \times 0.44) + (8.8 \times 0.32) + (83.7 + \text{ } \times 0.28)$	M_d	29.552
Molecular weight, stack gas wet (lb/lb-mole) $M_d(1 - B_{w0}) + 18(B_{w0}), (29.552)(1 - 0.060) + 18(0.060)$	M_s	28.86
Absolute stack pressure (in. Hg) $P_b + \frac{P_{\text{stack}} (\text{in. H}_2\text{O})}{13.6}, (28.60) + \frac{(-0.1)}{13.6}$	P_s	28.59

Temperature stack gas, average (°F)	T_s	329
Stack velocity (fps) $85.49 (C_p) (\sqrt{4P_{s \text{ avg}}}) \sqrt{\frac{T_{s \text{ avg}} + 460}{P_s M_s}}$ $85.49 (.79) (.248) \sqrt{\frac{(329) + 460}{(28.57)(28.86)}}$	$V_{s(\text{avg})}$	16.38
Total sample time (minutes)	θ	60
Nozzle diameter, actual (inches)	N_d	0.387
Percent isokinetic (%) $17.33 (T_s + 460)(V_w \text{ std} + V_m \text{ std})$ $\frac{\theta V_s P_s N_d^2}{17.33 (\text{ } + 460)((\text{ }) + (\text{ }))}$ $\frac{(\text{ })(\text{ })(\text{ })(\text{ })^2}{(\text{ })(\text{ })(\text{ })(\text{ })^2}$	%I	100.057
Area of stack (ft ²) $\pi = 3.1416$ $\pi r^2 \div 144, \quad \pi (\text{ })^2 \div 144$	A_s	2.405
Stack gas volume at standard conditions (dscfm) $60 (1 - B_{wo}) V_{s \text{ avg}} A_s \left(\frac{528}{T_{s \text{ avg}} + 460} \right) \left(\frac{P_s}{29.92} \right)$ $60 (1 - \text{ })(\text{ })(\text{ }) \left(\frac{528}{\text{ } + 460} \right) \left(\frac{(\text{ })}{(29.92)} \right)$	A_{CFM} Q_s	2,363 1,421
Particulate matter concentration, dry (gr/dscf) $15.432 \frac{M_p(\text{grams})}{V_m \text{ std}}, \quad 15.432 \frac{(208682)}{(28.948)}$	$C_{s(\text{std})}$	0.03029
Emission rate of particulate matter (lb/hr) $0.00857 (Q_s) C_{s(\text{std})}, 0.00857 (\text{ })(\text{ })$	E_p	$SO_2 = \frac{946.9}{28.948} = 32.7 \text{ mg/dscf}$

ISOKINETIC PERFORMANCE WORKSHEET & PARTICULATE CALCULATIONS

Plant Rock of Ages

Performed by D. A. Ros

Date 7-7-83

Sample Location Saw House

Test No./Type 3 - M5/8

Barometric Pressure (in. Hg)	P_b	28.60
Meter volume (std), $17.64 \left(\frac{V_m}{\alpha} \right) \left(\frac{P_b + \frac{\Delta H}{13.6}}{T_m + 460} \right)$ $17.64 \left(\frac{(36.388)}{(1.012)} \right) \left(\frac{(28.60) + \frac{(4.76)}{13.6}}{(88.4) + 460} \right)$	$V_{m \text{ std}}$	33.176
Volume of liquid collected (grams)	V_{l_c}	32.7
Volume of liquid at standard condition (scf) $V_{l_c} \times 0.04707$	$V_{w \text{ std}}$	1.539
Stack gas proportion of water vapor $\frac{V_{w \text{ std}}}{V_{w \text{ std}} + V_{m \text{ std}}}, \frac{(1.539)}{(1.539) + (33.176)}$	B_{w_o}	0.044
Molecular weight, stack gas dry (lb/lb-mole) $(\% \text{ CO}_2 \times 0.44) + (\% \text{ O}_2 \times 0.32) + (\% \text{ N}_2 + \% \text{ CO} \times 0.28)$ $(7.5 \times 0.44) + (8.8 \times 0.32) + (83.7 + \text{ } \times 0.28)$	M_d From MPR Avg	27.552
Molecular weight, stack gas wet (lb/lb-mole) $M_d(1 - B_{w_o}) + 18(B_{w_o}), (27.552)(1 - 0.044) + 18(0.044)$	M_s	27.04
Absolute stack pressure (in. Hg) $P_b + \frac{P_{\text{stack}} (\text{in. H}_2\text{O})}{13.6}, (28.60) + \frac{(-0.1)}{13.6}$	P_s	28.59

Temperature stack gas, average (°F)	T_s	276.7
Stack velocity (fps) $85.49 (C_p) (\sqrt{\Delta P_{s \text{ avg}}}) \sqrt{\frac{T_{s \text{ avg}} + 460}{P_s M_s}}$ $85.49 (.79) (.263) \sqrt{\frac{(276.7) + 460}{(28.57)(29.04)}}$	$V_{s(\text{avg})}$	16.73
Total sample time (minutes)	θ	60
Nozzle diameter, actual (inches)	N_d	0.387
Percent isokinetic (%) $17.33 (T_s + 460)(V_w \text{ std} + V_m \text{ std})$ $\frac{\theta V_s P_s N_d^2}{17.33 (\text{ } + 460)((\text{ }) + (\text{ }))}$ $\frac{(\text{ })(\text{ })(\text{ })(\text{ })^2}{(\text{ })(\text{ })(\text{ })(\text{ })^2}$	%I	103.100
Area of stack (ft ²) $\pi = 3.1416$ $\pi r^2 \div 144, \quad \pi (10.5)^2 \div 144$	A_s	2.405
Stack gas volume at standard conditions (dscfm) $60 (1 - B_{wo}) V_{s \text{ avg}} A_s \left(\frac{528}{T_{s \text{ avg}} + 460} \right) \left(\frac{P_s}{29.92} \right)$ $60 (1 - \text{ })(\text{ })(\text{ }) \left(\frac{528}{\text{ } + 460} \right) \left(\frac{(\text{ })}{(29.92)} \right)$	ACFM Q_s	2,414 1,580
Particulate matter concentration, dry (gr/dscf) $15.432 \frac{M_p(\text{grams})}{V_{m \text{ std}}}, \quad 15.432 \frac{(0.0217)}{(33.176)}$	$C_{s(\text{std})}$	0.00985
Emission rate of particulate matter (lb/hr) $0.00857 (Q_s) C_{s(\text{std})}, \quad 0.00857 (\text{ })(\text{ })$	E_p $SO_2 = \frac{490.8}{33.176} = 14.8 \frac{\text{mg}}{\text{dscf}}$	

5.4 HCl EMISSIONS FROM HCl TRAIN SAMPLES

Acurex

Attention: Larry Waterland

October 6, 1983

Acurex ID#: 8309-035


Customer PO#: 307736.62

Subject: Vermont Chloride Determinations; received 7/7/83

The above samples were analyzed for chloride by argentometric titration.

	<u>Sample #</u>	<u>Volume, mL</u>	<u>Total Chloride, mg/L</u>	<u>Total Chloride, mg</u>
<i>To-3</i>	819474	405	310	130
<i>Blank</i>	819447	143	13	2

Prepared by:


Stephen Guinnane
Analyst

Approved by:


Greg Nicoll
Operations Manager

SG/GN/ats

ISOKINETIC PERFORMANCE WORKSHEET & PARTICULATE CALCULATIONS

Plant _____

Performed by _____

Date _____

Sample Location _____

Test No./Type _____

Barometric Pressure (in. Hg)	P_b	...
Meter volume (std), $17.64 \left(\frac{V_m}{\alpha} \right) \left(\frac{P_b + \frac{\Delta H}{13.6}}{T_m + 460} \right)$ $17.64 \left(\frac{(\dots)}{(\dots)} \right) \left(\frac{(\dots) + \frac{(\dots)}{13.6}}{(\dots) + 460} \right)$	$V_{m \text{ std}}$	12.10
Volume of liquid collected (grams)	V_{l_c}	...
Volume of liquid at standard condition (scf) $V_{l_c} \times 0.04707$	$V_{w \text{ std}}$	0.522
Stack gas proportion of water vapor $\frac{V_{w \text{ std}}}{V_{w \text{ std}} + V_{m \text{ std}}}, \frac{(\dots)}{(\dots) + (\dots)}$	B_{wo}	0.04
Molecular weight, stack gas dry (lb/lb-mole) $(\% \text{ CO}_2 \times 0.44) + (\% \text{ O}_2 \times 0.32) + (\% \text{ N}_2 + \% \text{ CO} \times 0.28)$ $(\dots \times 0.44) + (\dots \times 0.32) + (\dots + \dots \times 0.28)$	M_d	27.02
Molecular weight, stack gas wet (lb/lb-mole) $M_d(1-B_{wo}) + 18(B_{wo}), (27.02)(1-0.04) + 18(0.04)$	M_s	27.23
Absolute stack pressure (in. Hg) $P_b + \frac{P_{\text{stack}} (\text{in. H}_2\text{O})}{13.6}, (\dots) + \frac{(\dots)}{13.6}$	P_s	29.20

Temperature stack gas, average (°F)	T_s	
Stack velocity (fps) $85.49 (C_p) (\sqrt{\Delta P_s \text{ avg}}) \sqrt{\frac{T_s \text{ avg} + 460}{P_s M_s}}$ $85.49 () (\sqrt{ }) \sqrt{\frac{() + 460}{()()}}$	$V_{s(\text{avg})}$	
Total sample time (minutes)	θ	
Nozzle diameter, actual (inches)	N_d	
Percent isokinetic (%) $17.33 (T_s + 460)(V_w \text{ std} + V_m \text{ std})$ $\frac{\theta V_s P_s N_d^2}{17.33 (+ 460)(() + ())}$ $\frac{() () () ()^2}{() () () ()^2}$	%I	
Area of stack (ft ²) $\pi = 3.1416$ $\pi r^2 \div 144, \pi ()^2 \div 144$	A_s	
Stack gas volume at standard conditions (dscfm) $60 (1 - B_{wo}) V_{s \text{ avg}} A_s \left(\frac{528}{T_s \text{ avg} + 460} \right) \left(\frac{P_s}{29.92} \right)$ $60 (1 -) () () \left(\frac{528}{ + 460} \right) \left(\frac{()}{(29.92)} \right)$	Q_s	
Particulate matter concentration, dry (gr/dscf) $15.432 \frac{M_p(\text{grams})}{V_m \text{ std}}, 15.432 \frac{()}{()}$	$C_{s(\text{std})}$	
Emission rate of particulate matter (lb/hr) $0.00857 (Q_s) C_{s(\text{std})}, 0.00857 () ()$	E_p	

* Impinger solution destroyed
in transit

7602/5/81/Rev 1

ISOKINETIC PERFORMANCE WORKSHEET & PARTICULATE CALCULATIONS

Plant _____

Performed by _____

Date _____

Sample Location _____

Test No./Type _____

Barometric Pressure (in. Hg)	P_b	
Meter volume (std), $17.64 \left(\frac{V_m}{\alpha} \right) \left(\frac{P_b + \frac{\Delta H}{13.6}}{T_m + 460} \right)$ $17.64 \left(\frac{(\quad)}{(\quad)} \right) \left(\frac{(\quad) + \frac{(\quad)}{13.6}}{(\quad) + 460} \right)$	$V_m \text{ std}$	
Volume of liquid collected (grams)	V_{lc}	
Volume of liquid at standard condition (scf) $V_{lc} \times 0.04707$	$V_w \text{ std}$	
Stack gas proportion of water vapor $\frac{V_w \text{ std}}{V_w \text{ std} + V_m \text{ std}}, \frac{(\quad)}{(\quad) + (\quad)}$	B_{wo}	
Molecular weight, stack gas dry (lb/lb-mole) $(\% \text{ CO}_2 \times 0.44) + (\% \text{ O}_2 \times 0.32) + (\% \text{ N}_2 + \% \text{ CO} \times 0.28)$ $(\quad \times 0.44) + (\quad \times 0.32) + (\quad + \quad \times 0.28)$	M_d	27.552
Molecular weight, stack gas wet (lb/lb-mole) $M_d(1-B_{wo}) + 18(B_{wo}), (27.552)(1-0.0523) + 18(0.0523)$	M_s	28.15
Absolute stack pressure (in. Hg) $P_b + \frac{P_{\text{stack}} (\text{in. H}_2\text{O})}{13.6}, (\quad) + \frac{(\quad)}{13.6}$	P_s	28.57

Temperature stack gas, average (°F)	T_s	
Stack velocity (fps) $85.49 (C_p) (\sqrt{4P_{s \text{ avg}}}) \sqrt{\frac{T_{s \text{ avg}} + 460}{P_s M_s}}$ $85.49 (\quad) (\sqrt{ \quad }) \sqrt{\frac{(\quad) + 460}{(\quad) (\quad)}}$	$V_{s(\text{avg})}$	
Total sample time (minutes)	θ	
Nozzle diameter, actual (inches)	N_d	
Percent isokinetic (%) $17.33 (T_s + 460)(V_w \text{ std} + V_m \text{ std})$ $\frac{\theta V_s P_s N_d^2}{17.33 (\quad + 460)((\quad) + (\quad))}$ $\frac{(\quad)(\quad)(\quad)(\quad^2)}{(\quad)(\quad)(\quad)(\quad^2)}$	%I	92.95
Area of stack (ft ²) $\pi = 3.1416$ $\pi r^2 \div 144, \quad \pi (\quad)^2 \div 144$	A_s	2.405
Stack gas volume at standard conditions (dscfm) $60 (1 - B_{wo}) V_{s \text{ avg}} A_s \left(\frac{528}{T_{s \text{ avg}} + 460} \right) \left(\frac{P_s}{29.92} \right)$ $60 (1 - \quad) (\quad) (\quad) \left(\frac{528}{ \quad + 460 } \right) \left(\frac{ (\quad) }{ (29.92) } \right)$	Q_s	2.025
Particulate matter concentration, dry (gr/dscf) $15.432 \frac{M_p (\text{grams})}{V_{m \text{ std}}}, \quad 15.432 \frac{ (\quad) }{ (\quad) }$	$C_{s(\text{std})}$	— ϕ
Emission rate of particulate matter (lb/hr) $0.00857 (Q_s) C_{s(\text{std})}, \quad 0.00857 (\quad) (\quad)$	E_p	

** Impinger solution destroyed
in transit*

7602/5/81/Rev 1

ISOKINETIC PERFORMANCE WORKSHEET & PARTICULATE CALCULATIONS

Plant _____

Performed by _____

Date _____

Sample Location _____

Test No./Type _____

Barometric Pressure (in. Hg)	P_b	_____
Meter volume (std), $17.64 \left(\frac{V_m}{\alpha} \right) \left(\frac{P_b + \frac{\Delta H}{13.6}}{T_m + 460} \right)$ $17.64 \left(\frac{(\text{_____})}{(\text{_____})} \right) \left(\frac{(\text{_____}) + \frac{(\text{_____})}{13.6}}{(\text{_____}) + 460} \right)$	$V_{m \text{ std}}$	12.564
Volume of liquid collected (grams)	V_{l_c}	_____
Volume of liquid at standard condition (scf) $V_{l_c} \times 0.04707$	$V_{w \text{ std}}$	0.591
Stack gas proportion of water vapor $\frac{V_{w \text{ std}}}{V_{w \text{ std}} + V_{m \text{ std}}}, \frac{(\text{_____})}{(\text{_____}) + (\text{_____})}$	B_{wo}	0.047
Molecular weight, stack gas dry (lb/lb-mole) $(\% \text{ CO}_2 \times 0.44) + (\% \text{ O}_2 \times 0.32) + (\% \text{ N}_2 + \% \text{ CO} \times 0.28)$ $(\text{_____} \times 0.44) + (\text{_____} \times 0.32) + (\text{_____} + \text{_____} \times 0.28)$	M_d	28.95
Molecular weight, stack gas wet (lb/lb-mole) $M_d(1-B_{wo}) + 18(B_{wo}), (\text{_____})(1-\text{_____}) + 18(\text{_____})$	M_s	28.95
Absolute stack pressure (in. Hg) $P_b + \frac{P_{\text{stack}} (\text{in. H}_2\text{O})}{13.6}, (\text{_____}) + \frac{(\text{_____})}{13.6}$	P_s	28.95

Temperature stack gas, average (°F)	T_s	
Stack velocity (fps) $85.49 (C_p) (\sqrt{\Delta P_s \text{ avg}}) \sqrt{\frac{T_s \text{ avg} + 460}{P_s M_s}}$ $85.49 (1.47) (\sqrt{2.4}) \sqrt{\frac{(24.7) + 460}{(29.92)(2.4)}}$	$V_{s(\text{avg})}$	16.15
Total sample time (minutes)	θ	
Nozzle diameter, actual (inches)	N_d	
Percent isokinetic (%) $17.33 (T_s + 460)(V_w \text{ std} + V_m \text{ std})$ $\frac{\theta V_s P_s N_d^2}{17.33 (\text{ } + 460)((\text{ }) + (\text{ }))}$ $\frac{(\text{ })(\text{ })(\text{ })(\text{ }^2)}{(\text{ })(\text{ })(\text{ })(\text{ }^2)}$	%I	10.14
Area of stack (ft ²) $\pi = 3.1416$ $\pi r^2 \div 144, \pi (\text{ }^2) \div 144$	A_s	2.405
Stack gas volume at standard conditions (dscfm) $60 (1 - B_{wo}) V_{s \text{ avg}} A_s \left(\frac{528}{T_s \text{ avg} + 460} \right) \left(\frac{P_s}{29.92} \right)$ $60 (1 - \text{ })(\text{ })(\text{ }) \left(\frac{528}{\text{ } + 460} \right) \left(\frac{(\text{ })}{(29.92)} \right)$	Q_s	1.476
Particulate matter ^{HCR} concentration, dry (mg/dscf) $15.432 \frac{M_p (\text{grams})}{V_m \text{ std}}, 15.432 \frac{(\text{ } \text{mg})}{(\text{ } \text{dscf})}$	$C_{s(\text{std})}$	9.55
Emission rate of particulate matter (lb/hr) $0.00857 (Q_s) C_{s(\text{std})}, 0.00857 (\text{ })(\text{ })$	E_p	

5.5 TRACE ELEMENT AND LEACHABLE ANION ANALYSES

In the following, the botton ash test 3 sample is a blind duplicate of the bottom ash test 2 sample and the cyclone ash test 3 sample is a blind audit sample consisting of NBS 1633a flyash.

COMMERCIAL TESTING & ENGINEERING CO.



Reply to

Instrument Analysis Division
490 Orchard Street
Golden, CO 80401

Phone: 303-278-9521

January 9, 1983

Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94042

RE: IAD #97-N182-116-28
Subcontract #SW59159A
Release #11

Analytical Report

Twenty-eight samples were received for analysis on November 30, 1983. These samples were assigned our IAD identification #97-N182-116-28.

Trace element determinations using Spark Source Mass Spectrometry per EPA level 1 protocol will be reported in separate reports upon completion of analysis.

Arsenic and Antimony were determined on four of the samples using hydride generation atomic absorption spectrophotometry. Mercury was determined on all twenty-eight samples using flameless cold vapor atomic absorption spectrophotometry.

The results of these determinations are presented in Table No. I and No. II and are reported in parts per million (ppm) by weight on an "as received" basis.




Table No. I
(ppm by Weight)

<u>Sample ID</u>	<u>Arsenic (As)</u>	<u>Antimony (Sb)</u>
819454 RA Imp 2 and 3, Test 1	≤0.001	0.003
819455 RA Imp 2 and 3, Blank, Test 1	≤0.001	≤0.001
819467 RA Imp 2 and 3, Test 2	0.001	0.002
819469 RA Imp 2 and 3, Blank, Test 2	≤0.001	≤0.001

Table No. II
(ppm by Weight)

<u>Sample ID</u>	<u>Mercury (Hg)</u>
819463 RA Filter + 1μ, Test 1	0.09
819475 RA Filter, Test 2	0.11
819458 RA Filter Blank	0.03
819456 RA 10μ + 3μ, Test 1	5.0
819492 RA 10μ + 3μ, Test 2	6.0
819459 RA XAD-2, Test 1	0.23
819465 RA XAD-2, Test 2	0.24
819461 RA XAD-2, Blank	0.03
819452 RA Imp 1, Test 1	0.002
819466 RA Imp 1, Test 2	0.010
819448 RA Imp 1, Blank	≤0.001
819449 RA Coal, Test 1	0.09
819485 RA PET, Test 2	0.35
819478 RA Coal/PET, Test 2	0.20
819488 RA Bottom Ash, Test 1	≤0.01
819495 RA Bottom Ash Leachate, Test 1	0.002
819498 RA Bottom Ash, Test 2	≤0.01
819496 RA Bottom Ash Leachate, Test 2	≤0.001
819493 RA Bottom Ash, Test 3	0.02
819476 RA Cyclone Ash, Test 1	0.78
819482 RA Cyclone Ash Leachate, Test 1	≤0.001
819504 RA Cyclone Ash, Test 2	1.15
819486 RA Cyclone Ash Leachate, Test 2	≤0.001
819464 RA Cyclone Ash, Test 3	0.11
819454 RA Imp 2 and 3, Test 1	0.008
819455 RA Imp 2 and 3 Blank, Test 1	≤0.001
819467 RA Imp 2 and 3, Test 2	0.011
819469 RA Imp 2 and 3 Blank, Test 2	≤0.001



If you have any questions concerning these results, please call.

Harold A. Connell
Assistant Laboratory Manager

Robert L. Taylor 2 Jan '84
Robert L. Taylor, Ph.D., Manager
Instrumental Analysis Division

HAC/gh

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to



To: Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039

Date: January 4, 1984

Analyst: G. Meagher

P. O. No.: Subcontract #SW59159A
Release #11

Sample No.: 819449

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N182-116-28

RA coal, test 1

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	2	Terbium	0.2	Ruthenium		Vanadium	40
Thorium	5	Gadolinium	0.7	Molybdenum	27	Titanium	MC
Bismuth		Europium	0.3	Niobium	*12	Scandium	35
Lead	3	Samarium	1	Zirconium	31	Calcium	MC
Thallium		Neodymium	7	Yttrium	10	Potassium	MC
Mercury	NR	Praseodymium	3	Strontium	110	Chlorine	270
Gold		Cerium	18	Rubidium	5	Sulfur	590
Platinum		Lanthanum	25	Bromine	21	Phosphorus	100
Iridium		Barium	100	Selenium	*130	Silicon	MC
Osmium		Cesium	0.5	Arsenic	11	Aluminum	MC
Rhenium		Iodine	1	Germanium	1	Magnesium	MC
Tungsten		Tellurium		Gallium	16	Sodium	MC
Tantalum		Antimony	<1	Zinc	53	Fluorine	~830
Hafnium		Tin	0.5	Copper	14	Oxygen	NR
Lutetium		Indium	STD	Nickel	2	Nitrogen	NR
Ytterbium		Cadmium	1	Cobalt	8	Carbon	NR
Thulium		Silver		Iron	MC	Boron	30
Erbium		Palladium		Manganese	8	Beryllium	9
Holmium		Rhodium		Chromium	120	Lithium	74
Dysprosium		*Heterogeneous				Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.2 ppm

MC — Major Component >1000 ppm

INT — Interference

Approved: 5-40

Robert L. Taylor
3 Feb-84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to



To: Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039

Date: January 4, 1984

Subcontract #SW59159A
P. O. No.: Release #11

Analyst: G. Meagher

Sample No.: 819488
RA bottom ash,
test 1
SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS
CONCENTRATION IN PPM WEIGHT

IAD No.: 97-N182-116-28

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	9	Terbium	0.8	Ruthenium		Vanadium	44
Thorium	14	Gadolinium	3	Molybdenum	6	Titanium	MC
Bismuth		Europium	2	Niobium	9	Scandium	30
Lead	9	Samarium	7	Zirconium	34	Calcium	MC
Thallium	1	Neodymium	14	Yttrium	11	Potassium	MC
Mercury	NR	Praseodymium	7	Strontium	210	Chlorine	98
Gold		Cerium	22	Rubidium	8	Sulfur	320
Platinum		Lanthanum	30	Bromine	4	Phosphorus	740
Iridium		Barium	350	Selenium	13	Silicon	MC
Osmium		Cesium	2	Arsenic	4	Aluminum	MC
Rhenium		Iodine	2	Germanium	1	Magnesium	MC
Tungsten	1	Tellurium	≤0.2	Gallium	10	Sodium	MC
Tantalum	0.9	Antimony	4	Zinc	11	Fluorine	MC
Hafnium	3	Tin	0.8	Copper	18	Oxygen	NR
Lutetium	0.3	Indium	STD	Nickel	160	Nitrogen	NR
Ytterbium	1	Cadmium	0.4	Cobalt	22	Carbon	NR
Thulium	0.2	Silver	0.5	Iron	MC	Boron	31
Erbium	2	Palladium		Manganese	13	Beryllium	22
Holmium	2	Rhodium		Chromium	50	Lithium	120
Dysprosium	3					Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.1 ppm

MC — Major Component > 1000 ppm

INT — Interference

5- 41 Approved:

Robert L. Daylen
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-8, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

Reply to

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521



To: Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039

Date: January 4, 1984

Analyst: G. Meagher

Subcontract #SW59159A
P. O. No.: Release #11

Sample No.: 819495 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS IAD No.: 97-N182-116-28
RA bottom ash
leachate, test 1 CONCENTRATION IN $\mu\text{g/mL}$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.02
Thorium		Gadolinium		Molybdenum	0.1	Titanium	0.3
Bismuth		Europium		Niobium	≤ 0.001	Scandium	≤ 0.001
Lead	≤ 0.004	Samarium		Zirconium	0.003	Calcium	MC
Thallium		Neodymium		Yttrium	0.001	Potassium	MC
Mercury	NR	Praseodymium		Strontium	0.6	Chlorine	0.5
Gold		Cerium	0.001	Rubidium	0.008	Sulfur	MC
Platinum		Lanthanum		Bromine	0.03	Phosphorus	0.1
Iridium		Barium	0.06	Selenium	0.1	Silicon	4
Osmium		Cesium		Arsenic	0.03	Aluminum	0.5
Rhenium		Iodine	0.002	Germanium	0.002	Magnesium	4
Tungsten		Tellurium		Gallium	0.01	Sodium	MC
Tantalum		Antimony	≤ 0.004	Zinc	0.03	Fluorine	≈ 4
Hafnium		Tin		Copper	0.01	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.01	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	≤ 0.001	Carbon	NR
Thulium		Silver	≤ 0.002	Iron	0.06	Boron	0.2
Erbium		Palladium		Manganese	0.002	Beryllium	
Holmium		Rhodium		Chromium	0.02	Lithium	3
Dysprosium						Hydrogen	NR

STD - Internal Standard

NR - Not Reported

All elements not detected $< 0.001 \mu\text{g/mL}$

MC - Major Component $> 10 \mu\text{g/mL}$

INT - Interference

Approved: 5-42

Robert L. Joyner
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to

To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7535
Mountain View, CA 94039



Date: February 3, 1984

Analyst: G. Meagher

P. O. No.: Subcontract SW 59159A Release Number 11 Project 7601

Sample No.: 819476

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N182-116-28

RA cylcone ash,
test 1

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	2	Terbium	0.2	Ruthenium		Vanadium	85
Thorium	2	Gadolinium	0.9	Molybdenum	8	Titanium	MC
Bismuth	0.4	Europium	0.4	Niobium	4	Scandium	26
Lead	14	Samarium	3	Zirconium	8	Calcium	MC
Thallium	2	Neodymium	3	Yttrium	5	Potassium	MC
Mercury	NR	Praseodymium	1	Strontium	90	Chlorine	250
Gold		Cerium	4	Rubidium	2	Sulfur	MC
Platinum		Lanthanum	6	Bromine	49	Phosphorus	MC
Iridium		Barium	130	Selenium	170	Silicon	MC
Osmium		Cesium	0.4	Arsenic	52	Aluminum	MC
Rhenium		Iodine	3	Germanium	4	Magnesium	MC
Tungsten	0.5	Tellurium	0.4	Gallium	19	Sodium	MC
Tantalum	0.4	Antimony	6	Zinc	37	Fluorine	≈260
Hafnium	0.3	Tin	1	Copper	34	Oxygen	NR
Lutetium	<0.1	Indium	STD	Nickel	79	Nitrogen	NR
Ytterbium	0.5	Cadmium	0.4	Cobalt	6	Carbon	NR
Thulium	0.2	Silver	0.5	Iron	MC	Boron	110
Erbium	0.5	Palladium		Manganese	11	Beryllium	7
Holmium	0.7	Rhodium		Chromium	51	Lithium	79
Dysprosium	1					Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.1 ppm

MC — Major Component > 1000 ppm

INT — Interference

Approved: 5-43

Robert L. Jaylen
3 Feb-84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

Reply to

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521



To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94039

Date: February 3, 1984

Analyst: G. Meagher

Subcontract #SW59159A
P. O. No.: Release #11 Project #7601

Sample No.: 819482 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N182-116-28

RA cyclone ash, leachate
Test 1
CONCENTRATION IN $\mu\text{g/ml}$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	0.69	Terbium	0.06	Ruthenium		Vanadium	7.4
Thorium	0.31	Gadolinium	0.23	Molybdenum	0.22	Titanium	MC
Bismuth	0.005	Europium	0.09	Niobium	0.19	Scandium	0.85
Lead	0.27	Samarium	0.76	Zirconium	0.95	Calcium	MC
Thallium	0.21	Neodymium	0.72	Yttrium	1.2	Potassium	MC
Mercury	NR	Praseodymium	0.34	Strontium	MC	Chlorine	6.6
Gold		Cerium	0.85	Rubidium	0.63	Sulfur	MC
Platinum		Lanthanum	1.2	Bromine	0.51	Phosphorus	MC
Iridium		Barium	2.1	Selenium	0.80	Silicon	MC
Osmium		Cesium	0.05	Arsenic	4.1	Aluminum	MC
Rhenium		Iodine	0.008	Germanium	0.22	Magnesium	MC
Tungsten	0.03	Tellurium	0.01	Gallium	6.5	Sodium	MC
Tantalum	0.03	Antimony	0.15	Zinc	MC	Fluorine	MC
Hafnium	0.03	Tin	0.02	Copper	MC	Oxygen	NR
Lutetium	0.03	Indium	STD	Nickel	4.0	Nitrogen	NR
Ytterbium	0.27	Cadmium	0.17	Cobalt	7.4	Carbon	NR
Thulium	0.04	Silver	0.008	Iron	MC	Boron	1.8
Erbium	0.30	Palladium		Manganese	MC	Beryllium	0.32
Holmium	0.40	Rhodium		Chromium	3.7	Lithium	>4.1
Dysprosium	0.63					Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.001 $\mu\text{g/ml}$
> 10 $\mu\text{g/ml}$

MC — Major Component

INT — Interference

Approved: 5-44

Robert L. Daylen
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to

To: Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039



Date: January 4, 1984

Analyst: G. Meagher

P. O. No.: Subcontract #SW59159A

Release #11

Sample No.: 819456

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N182-116-28

RA 10 μ + 3 μ , test 1

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	9	Terbium	2	Ruthenium		Vanadium	940
Thorium	20	Gadolinium	6	Molybdenum	84	Titanium	MC
Bismuth	6	Europium	3	Niobium	48	Scandium	73
Lead	460	Samarium	17	Zirconium	240	Calcium	MC
Thallium	40	Neodymium	28	Yttrium	82	Potassium	MC
Mercury	NR	Praseodymium	24	Strontium	MC	Chlorine	850
Gold		Cerium	150	Rubidium	72	Sulfur	MC
Platinum		Lanthanum	87	Bromine	220	Phosphorus	MC
Iridium		Barium	MC	Selenium	MC	Silicon	MC
Osmium		Cesium	11	Arsenic	MC	Aluminum	MC
Rhenium		Iodine	29	Germanium	56	Magnesium	MC
Tungsten	8	Tellurium	3	Gallium	830	Sodium	MC
Tantalum	2	Antimony	150	Zinc	MC	Fluorine	$\approx$ 880
Hafnium	2	Tin	43	Copper	722	Oxygen	NR
Lutetium	0.4	Indium	STD	Nickel	830	Nitrogen	NR
Ytterbium	3	Cadmium	14	Cobalt	64	Carbon	NR
Thulium	0.8	Silver	35	Iron	MC	Boron	MC
Erbium	4	Palladium		Manganese	MC	Beryllium	31
Holmium	6	Rhodium		Chromium	MC	Lithium	>530
Dysprosium	9					Hydrogen	NR

STD - Internal Standard

NR - Not Reported

All elements not detected < 0.2 ppm

MC - Major Component >1000 ppm

INT - Interference

Approved: 5-45

Robert L. Jeyar
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

Reply to

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521



To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94039

Date: February 3, 1984

Analyst: G. Meagher

P. O. No.: Subcontract SW59159A Release 11 Project 7601

Sample No.: 819463

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N182-116-28

RA filter + 1u, test 1

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	62	Terbium	1	Ruthenium		Vanadium	66
Thorium	25	Gadolinium	4	Molybdenum	65	Titanium	MC
Bismuth	20	Europium	3	Niobium	14	Scandium	10
Lead	600	Samarium	12	Zirconium	68	Calcium	MC
Thallium	31	Neodymium	32	Yttrium	58	Potassium	MC
Mercury	NR	Praseodymium	14	Strontium	420	Chlorine	470
Gold		Cerium	61	Rubidium	15	Sulfur	MC
Platinum		Lanthanum	61	Bromine	250	Phosphorus	MC
Iridium		Barium	940	Selenium	400	Silicon	MC
Osmium		Cesium	4	Arsenic	550	Aluminum	MC
Rhenium		Iodine	6	Germanium	39	Magnesium	MC
Tungsten	12	Tellurium	2	Gallium	350	Sodium	MC
Tantalum	2	Antimony	51	Zinc	860	Fluorine	MC
Hafnium	1	Tin	30	Copper	440	Oxygen	NR
Lutetium	0.3	Indium	STD	Nickel	210	Nitrogen	NR
Ytterbium	2	Cadmium	77	Cobalt	100	Carbon	NR
Thulium	0.4	Silver	12	Iron	MC	Boron	MC
Erbium	1	Palladium		Manganese	67	Beryllium	29
Holmium	2	Rhodium		Chromium	150	Lithium	>370
Dysprosium	3					Hydrogen	NR

STD - Internal Standard

NR - Not Reported

All elements not detected < 0.1 ppm

MC - Major Component > 1000 ppm

INT - Interference

Approved:
5-46

Robert L. Taylor
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to



To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94039

Date: February 3, 1984

Analyst: G. Meagher

P. O. No.: Subcontract SW 59159A Release Number 11 Project 7601

Sample No.: 819459
RA XAD-2,
test 1

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS
CONCENTRATION IN PPM WEIGHT

IAD No.: 97-N182-116-28

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.1
Thorium		Gadolinium		Molybdenum	0.4	Titanium	5
Bismuth		Europium		Niobium		Scandium	≤0.04
Lead	0.3	Samarium		Zirconium	0.05	Calcium	10
Thallium		Neodymium		Yttrium		Potassium	8
Mercury	NR	Praseodymium		Strontium	0.1	Chlorine	13
Gold		Cerium		Rubidium	0.1	Sulfur	20
Platinum	*0.1	Lanthanum		Bromine	0.3	Phosphorus	2
Iridium		Barium	0.8	Selenium	0.5	Silicon	10
Osmium		Cesium	0.2	Arsenic	0.07	Aluminum	3
Rhenium		Iodine	0.07	Germanium	≤0.07	Magnesium	27
Tungsten		Tellurium	0.05	Gallium	0.1	Sodium	40
Tantalum		Antimony		Zinc	2	Fluorine	≈22
Hafnium		Tin	0.07	Copper	0.6	Oxygen	NR
Lutetium		Indium	STD	Nickel	2	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	0.1	Carbon	NR
Thulium		Silver		Iron	12	Boron	0.07
Erbium		Palladium		Manganese	0.4	Beryllium	
Holmium		Rhodium		Chromium	1	Lithium	1
Dysprosium		*Probable Contamination from sample prep				Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.001 µg/mL

MC — Major Component > 100 µg/mL

INT — Interference

Approved: 5-47

Robert L. Drayton
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to



To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94039

Date: February 3, 1984

Analyst: G. Meagher

P. O. No.: Subcontract SW 59159A Release Number 11 Project 7601

Sample No.: 819461

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS
RA XAD-2, blank

IAD No.: 97-N182-116-28

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.02
Thorium		Gadolinium		Molybdenum	0.1	Titanium	0.3
Bismuth		Europium		Niobium		Scandium	≤0.01
Lead	0.3	Samarium		Zirconium	0.02	Calcium	42
Thallium		Neodymium		Yttrium		Potassium	3
Mercury	NR	Praseodymium		Strontium	0.1	Chlorine	6
Gold		Cerium		Rubidium		Sulfur	4
Platinum	*0.1	Lanthanum		Bromine	0.1	Phosphorus	0.6
Iridium		Barium	0.3	Selenium	0.04	Silicon	14
Osmium		Cesium		Arsenic	<0.01	Aluminum	0.5
Rhenium		Iodine	0.05	Germanium	<0.01	Magnesium	11
Tungsten		Tellurium		Gallium	0.1	Sodium	28
Tantalum		Antimony		Zinc	0.8	Fluorine	≈13
Hafnium		Tin		Copper	0.3	Oxygen	NR
Lutetium		Indium	STD	Nickel	1	Nitrogen	NR
Ytterbium		Cadmium	≤0.02	Cobalt	≤0.02	Carbon	NR
Thulium		Silver		Iron	1	Boron	0.04
Erbium		Palladium		Manganese	0.1	Beryllium	
Holmium		Rhodium		Chromium	0.3	Lithium	0.3
Dysprosium		*Probable contamination from sample preparation.				Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.01 ppm

MC — Major Component > 100 ppm

INT — Interference

Approved: 5-48

Robert L. Joyner
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-8, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to



To: Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039

Date: January 4, 1984

Subcontract #SW59159A
P. O. No.: Release #11

Analyst: G. Meagher

Sample No.: 819452 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS
RA Imp 1, test 1 CONCENTRATION IN $\mu\text{g/mL}$

IAD No.: 97-N182-116-28

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.006
Thorium		Gadolinium		Molybdenum	*0.02	Titanium	0.2
Bismuth		Europium		Niobium		Scandium	0.004
Lead	0.6	Samarium		Zirconium	0.01	Calcium	1
Thallium	0.07	Neodymium		Yttrium		Potassium	*1
Mercury	NR	Praseodymium		Strontium	0.04	Chlorine	0.1
Gold		Cerium		Rubidium		Sulfur	4
Platinum		Lanthanum		Bromine	0.02	Phosphorus	0.3
Iridium		Barium	0.3	Selenium	0.1	Silicon	6
Osmium		Cesium		Arsenic	≤ 0.004	Aluminum	0.2
Rhenium		Iodine		Germanium		Magnesium	4
Tungsten		Tellurium		Gallium	0.06	Sodium	1
Tantalum		Antimony		Zinc	2	Fluorine	≈ 0.3
Hafnium		Tin	0.3	Copper	0.5	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.2	Nitrogen	NR
Ytterbium		Cadmium	0.05	Cobalt	0.01	Carbon	NR
Thulium		Silver	0.08	Iron	1	Boron	0.005
Erbium		Palladium		Manganese	0.04	Beryllium	
Holmium		Rhodium		Chromium	0.2	Lithium	0.05
Dysprosium		*Heterogeneous				Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected $< 0.006 \mu\text{g/mL}$

MC — Major Component $> 10 \mu\text{g/mL}$

INT — Interference

Approved: 5-49

Robert L. Joyner
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

Reply to

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521



To: Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039

Date: January 4, 1984

Subcontract #SW59159A

Analyst: G. Meagher

P. O. No.: Release #11

Sample No.: 819448

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N182-116-28

RA Imp 1 blank

CONCENTRATION IN $\mu\text{g/mL}$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	<0.001
Thorium		Gadolinium		Molybdenum	0.1	Titanium	0.03
Bismuth		Europium		Niobium		Scandium	0.001
Lead		Samarium		Zirconium	0.02	Calcium	0.2
Thallium		Neodymium		Yttrium		Potassium	0.1
Mercury	NR	Praseodymium		Strontium	0.006	Chlorine	0.1
Gold		Cerium		Rubidium		Sulfur	0.2
Platinum		Lanthanum		Bromine	0.03	Phosphorus	0.2
Iridium		Barium	0.03	Selenium	0.006	Silicon	0.4
Osmium		Cesium		Arsenic	0.002	Aluminum	0.1
Rhenium		Iodine	0.005	Germanium		Magnesium	0.3
Tungsten		Tellurium		Gallium	0.007	Sodium	0.8
Tantalum		Antimony	≤ 0.01	Zinc	0.05	Fluorine	≈ 0.2
Hafnium		Tin	0.2	Copper	0.004	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.01	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	0.07	Carbon	NR
Thulium		Silver		Iron	0.7	Boron	
Erbium		Palladium		Manganese	0.01	Beryllium	
Holmium		Rhodium		Chromium	0.03	Lithium	0.004
Dysprosium						Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < $0.002 \mu\text{g/mL}$

MC — Major Component > $10 \mu\text{g/mL}$

INT — Interference

Approved:

5-50

Robert L. Daylen
3 Feb-84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to

To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94039



Date: February 3, 1984

Analyst: G. Meagher

P. O. No.: Subcontract SW59159A Release 11 Project 7601

Sample No.: 819478

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N182-116-28

RA coal/PET, test 2

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	2	Terbium		Ruthenium		Vanadium	11
Thorium	4	Gadolinium		Molybdenum	17	Titanium	MC
Bismuth	2	Europium		Niobium	2	Scandium	9
Lead	28	Samarium	1	Zirconium	8	Calcium	MC
Thallium		Neodymium	4	Yttrium	4	Potassium	MC
Mercury	NR	Praseodymium	2	Strontium	24	Chlorine	110
Gold		Cerium	4	Rubidium	2	Sulfur	MC
Platinum		Lanthanum	6	Bromine	10	Phosphorus	170
Iridium		Barium	41	Selenium	4	Silicon	MC
Osmium		Cesium	0.9	Arsenic	3	Aluminum	MC
Rhenium		Iodine	0.9	Germanium	≤0.1	Magnesium	MC
Tungsten		Tellurium		Gallium	5	Sodium	MC
Tantalum	3	Antimony	24	Zinc	10	Fluorine	≈71
Hafnium		Tin	0.9	Copper	27	Oxygen	NR
Lutetium		Indium	STD	Nickel	340	Nitrogen	NR
Ytterbium		Cadmium	2	Cobalt	9	Carbon	NR
Thulium		Silver		Iron	MC	Boron	14
Erbium		Palladium		Manganese	17	Beryllium	0.8
Holmium		Rhodium		Chromium	43	Lithium	5
Dysprosium						Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.1 ppm

MC — Major Component > 1000 ppm

INT — Interference

Approved: 5-51

Robert L. Taylor
3 Feb-84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

Reply to

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94039



Date: February 3, 1984

Analyst: G. Meagher

P. O. No.: Subcontract No. SW59159A Release 11 Project 7601

Sample No.: 819485

RA PET, test
#2

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N182-116-28

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.4
Thorium		Gadolinium		Molybdenum	8	Titanium	84
Bismuth	0.5	Europium		Niobium		Scandium	<0.1
Lead	32	Samarium		Zirconium	0.2	Calcium	53
Thallium	0.3	Neodymium		Yttrium	<0.1	Potassium	11
Mercury	NR	Praseodymium		Strontium	<0.1	Chlorine	99
Gold		Cerium	<0.1	Rubidium	<0.1	Sulfur	15
Platinum		Lanthanum		Bromine		Phosphorus	53
Iridium		Barium	17	Selenium		Silicon	530
Osmium		Cesium		Arsenic	<0.1	Aluminum	MC
Rhenium		Iodine	<0.1	Germanium	<0.1	Magnesium	40
Tungsten	0.8	Tellurium		Gallium	3	Sodium	180
Tantalum		Antimony	22	Zinc	6	Fluorine	≈200
Hafnium		Tin		Copper	38	Oxygen	NR
Lutetium		Indium	STD	Nickel	290	Nitrogen	NR
Ytterbium		Cadmium	2	Cobalt	13	Carbon	NR
Thulium		Silver		Iron	22	Boron	0.7
Erbium		Palladium		Manganese	4	Beryllium	
Holmium		Rhodium		Chromium	11	Lithium	22
Dysprosium						Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.1 ppm
> 1000 ppm

MC — Major Component

INT — Interference

Approved:

5-52

Robert L. Taylor
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

Reply to

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521



To: Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039

Date: January 4, 1984

Subcontract #SW59159A
P. O. No.: Release #11

Analyst: G. Meagher

Sample No.: 819498
RA bottom ash,
test 2

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS
CONCENTRATION IN PPM WEIGHT

IAD No.: 97-N182-116-28

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	22	Terbium	3	Ruthenium		Vanadium	24
Thorium	31	Gadolinium	8	Molybdenum	16	Titanium	MC
Bismuth		Europium	4	Niobium	15	Scandium	41
Lead	52	Samarium	15	Zirconium	92	Calcium	MC
Thallium	4	Neodymium	32	Yttrium	62	Potassium	MC
Mercury	NR	Praseodymium	10	Strontium	510	Chlorine	36
Gold		Cerium	42	Rubidium	25	Sulfur	270
Platinum		Lanthanum	66	Bromine	5	Phosphorus	MC
Iridium		Barium	MC	Selenium	17	Silicon	MC
Osmium		Cesium	5	Arsenic	7	Aluminum	MC
Rhenium		Iodine	0.7	Germanium	4	Magnesium	MC
Tungsten	4	Tellurium	0.3	Gallium	63	Sodium	MC
Tantalum	5	Antimony	15	Zinc	23	Fluorine	≈250
Hafnium	5	Tin	2	Copper	48	Oxygen	NR
Lutetium	0.9	Indium	STD	Nickel	150	Nitrogen	NR
Ytterbium	7	Cadmium	4	Cobalt	110	Carbon	NR
Thulium	1	Silver	0.6	Iron	MC	Boron	130
Erbium	4	Palladium		Manganese	72	Beryllium	24
Holmium	5	Rhodium		Chromium	220	Lithium	>400
Dysprosium	8					Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected <0.1 ppm

MC — Major Component >1000 ppm

INT — Interference

Approved: 5-53

Robert L. Jager
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

Reply to

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521



To: Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039

Date: January 4, 1984

Analyst: G. Meagher

Subcontract #SW59159A
P. O. No.: Release #11

Sample No.: 819496 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS
RA bottom ash
leachate, test 2 CONCENTRATION IN $\mu\text{g/mL}$

IAD No.: 97-N182-116-28

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.05
Thorium		Gadolinium		Molybdenum	0.5	Titanium	0.2
Bismuth		Europium		Niobium	0.003	Scandium	≤ 0.002
Lead	0.009	Samarium		Zirconium	0.01	Calcium	MC
Thallium		Neodymium		Yttrium	0.009	Potassium	MC
Mercury	NR	Praseodymium		Strontium	3	Chlorine	3
Gold		Cerium		Rubidium	0.02	Sulfur	MC
Platinum		Lanthanum		Bromine	0.08	Phosphorus	0.3
Iridium		Barium	0.3	Selenium	0.1	Silicon	5
Osmium		Cesium		Arsenic	0.01	Aluminum	MC
Rhenium		Iodine	0.01	Germanium	0.01	Magnesium	0.9
Tungsten	0.02	Tellurium		Gallium	0.09	Sodium	MC
Tantalum		Antimony	0.2	Zinc	0.06	Fluorine	≈ 7
Hafnium		Tin		Copper	0.03	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.02	Nitrogen	NR
Ytterbium		Cadmium	0.004	Cobalt	≤ 0.003	Carbon	NR
Thulium		Silver	≤ 0.004	Iron	0.6	Boron	0.4
Erbium		Palladium		Manganese	0.005	Beryllium	
Holmium		Rhodium		Chromium	0.06	Lithium	0.07
Dysprosium						Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected $< 0.002 \mu\text{g/mL}$

MC — Major Component $> 10 \mu\text{g/mL}$

INT — Interference

Approved: 5-54

Robert L. Jaylen
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

Reply to

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521



To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94039

Date: February 3, 1984

Analyst: G. Meagher

P. O. No.: Subcontract SW 59159A Release Number 11 Project 7601

Sample No.: 819504
RA cyclone ash,
test 2

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS
CONCENTRATION IN PPM WEIGHT

IAD No.: 97-N182-116-28

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	12	Terbium	0.6	Ruthenium		Vanadium	45
Thorium	11	Gadolinium	2	Molybdenum	20	Titanium	MC
Bismuth	1	Europium	0.8	Niobium	9	Scandium	8
Lead	70	Samarium	4	Zirconium	19	Calcium	MC
Thallium	14	Neodymium	15	Yttrium	11	Potassium	MC
Mercury	NR	Praseodymium	7	Strontium	170	Chlorine	250
Gold		Cerium	22	Rubidium	5	Sulfur	MC
Platinum		Lanthanum	35	Bromine	77	Phosphorus	MC
Iridium		Barium	360	Selenium	130	Silicon	MC
Osmium		Cesium	2	Arsenic	70	Aluminum	MC
Rhenium		Iodine	8	Germanium	8	Magnesium	MC
Tungsten	2	Tellurium	0.4	Gallium	22	Sodium	MC
Tantalum	1	Antimony	26	Zinc	88	Fluorine	~380
Hafnium	≤0.7	Tin	5	Copper	45	Oxygen	NR
Lutetium	0.2	Indium	STD	Nickel	39	Nitrogen	NR
Ytterbium	1	Cadmium	8	Cobalt	10	Carbon	NR
Thulium	0.4	Silver	1	Iron	MC	Boron	840
Erbium	2	Palladium		Manganese	27	Beryllium	10
Holmium	3	Rhodium		Chromium	68	Lithium	380
Dysprosium	5					Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.1 ppm
> 1000 ppm

MC — Major Component

INT — Interference

Approved: 5-55

Robert L. Daylen
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to



To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94039

Date: February 3, 1984

Analyst: G. Meagher

P. O. No.: Subcontract SW 59159A Release Number 11 Project 7601

Sample No.: 819486

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N182-116-28

RA cyclone ash leachate,
test 2

CONCENTRATION IN $\mu\text{g/ml}$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	0.05	Terbium	0.007	Ruthenium		Vanadium	0.3
Thorium	0.01	Gadolinium	0.03	Molybdenum	0.02	Titanium	MC
Bismuth		Europium	0.01	Niobium	0.005	Scandium	0.1
Lead	0.1	Samarium	0.06	Zirconium	0.01	Calcium	MC
Thallium	0.09	Neodymium	0.2	Yttrium	0.5	Potassium	MC
Mercury	NR	Praseodymium	0.08	Strontium	4	Chlorine	0.7
Gold		Cerium	0.2	Rubidium	0.1	Sulfur	MC
Platinum		Lanthanum	0.3	Bromine	0.08	Phosphorus	MC
Iridium		Barium	0.05	Selenium	0.2	Silicon	MC
Osmium		Cesium	0.02	Arsenic	0.2	Aluminum	MC
Rhenium		Iodine	0.001	Germanium	0.07	Magnesium	MC
Tungsten	≤ 0.003	Tellurium	0.001	Gallium	5	Sodium	MC
Tantalum	0.005	Antimony	0.05	Zinc	12	Fluorine	MC
Hafnium	0.004	Tin	0.003	Copper	6	Oxygen	NR
Lutetium	0.002	Indium	STD	Nickel	0.8	Nitrogen	NR
Ytterbium	0.03	Cadmium	0.1	Cobalt	1	Carbon	NR
Thulium	0.002	Silver		Iron	MC	Boron	0.2
Erbium	0.008	Palladium		Manganese	MC	Beryllium	0.07
Holmium	0.01	Rhodium		Chromium	1	Lithium	>2
Dysprosium	0.02					Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.001 $\mu\text{g/mL}$

MC — Major Component

INT — Interference

5-56

Approved:

Robert L. Taylor
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to

To: Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039



Date: January 4, 1984

Subcontract #SW59159A
P. O. No.: Release #11

Analyst: G. Meagher

Sample No.: 819492

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N182-116-28

RA 10 μ + 3 μ , test 2 CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	9	Terbium	2	Ruthenium		Vanadium	320
Thorium	8	Gadolinium	8	Molybdenum	140	Titanium	MC
Bismuth	20	Europium	3	Niobium	29	Scandium	50
Lead	890	Samarium	20	Zirconium	56	Calcium	MC
Thallium	42	Neodymium	48	Yttrium	64	Potassium	MC
Mercury	NR	Praseodymium	22	Strontium	690	Chlorine	MC
Gold		Cerium	75	Rubidium	22	Sulfur	MC
Platinum		Lanthanum	90	Bromine	220	Phosphorus	MC
Iridium		Barium	830	Selenium	680	Silicon	MC
Osmium		Cesium	4	Arsenic	810	Aluminum	MC
Rhenium		Iodine	12	Germanium	44	Magnesium	MC
Tungsten	19	Tellurium	6	Gallium	290	Sodium	MC
Tantalum	4	Antimony	680	Zinc	MC	Fluorine	$\approx$ 340
Hafnium	3	Tin	35	Copper	650	Oxygen	NR
Lutetium	1	Indium	STD	Nickel	MC	Nitrogen	NR
Ytterbium	10	Cadmium	67	Cobalt	74	Carbon	NR
Thulium	0.8	Silver	36	Iron	MC	Boron	MC
Erbium	4	Palladium		Manganese	200	Beryllium	43
Holmium	6	Rhodium		Chromium	MC	Lithium	>540
Dysprosium	9					Hydrogen	NR

STD - Internal Standard

NR - Not Reported

All elements not detected < 0.2 ppm

MC - Major Component > 1000 ppm

INT - Interference

Approved:

5-57

Robert E. Day Jr.
3 Feb-84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

Reply to

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94039



Date: February 3, 1984

Analyst: G. Meagher

P. O. No.: Subcontract SW 59159A Release Number 11 Project 7601

Sample No.: 819475
RA Filter,
test 2

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N182-116-28

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	78	Terbium	0.2	Ruthenium	.	Vanadium	170
Thorium	2	Gadolinium	1	Molybdenum	170	Titanium	110
Bismuth	86	Europium	0.3	Niobium	2	Scandium	13
Lead	MC	Samarium	2	Zirconium	6	Calcium	MC
Thallium	96	Neodymium	4	Yttrium	7	Potassium	MC
Mercury	NR	Praseodymium	1	Strontium	71	Chlorine	MC
Gold		Cerium	3	Rubidium	96	Sulfur	MC
Platinum		Lanthanum	3	Bromine	240	Phosphorus	MC
Iridium		Barium	53	Selenium	300	Silicon	MC
Osmium		Cesium	16	Arsenic	MC	Aluminum	MC
Rhenium		Iodine	7	Germanium	330	Magnesium	MC
Tungsten	33	Tellurium	8	Gallium	MC	Sodium	MC
Tantalum	4	Antimony	MC	Zinc	MC	Fluorine	≈310
Hafnium		Tin	250	Copper	MC	Oxygen	NR
Lutetium		Indium	STD	Nickel	MC	Nitrogen	NR
Ytterbium		Cadmium	700	Cobalt	240	Carbon	NR
Thulium		Silver	19	Iron	MC	Boron	MC
Erbium	≤0.2	Palladium		Manganese	MC	Beryllium	25
Holmium	≤0.3	Rhodium		Chromium	MC	Lithium	>312
Dysprosium	≤0.5					Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.1 ppm
MC — Major Component > 500 ppm

INT — Interference

Approved:

Robert L. Taylor
3 Feb-84

5-58

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to

To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94039



Date: February 3, 1984

Analyst: G. Meagher

P. O. No.: Subcontract SW 59159A Release Number 11 Project 7601

Sample No.: 819465
RA XAD-2,
test 2

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N182-116-28

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.03
Thorium		Gadolinium		Molybdenum	2	Titanium	1
Bismuth		Europium		Niobium		Scandium	<0.01
Lead	0.2	Samarium		Zirconium	≤0.04	Calcium	2
Thallium		Neodymium		Yttrium		Potassium	2
Mercury	NR	Praseodymium		Strontium	0.08	Chlorine	49
Gold		Cerium		Rubidium	≤0.01	Sulfur	21
Platinum	*0.2	Lanthanum		Bromine	0.4	Phosphorus	7
Iridium		Barium	0.4	Selenium	0.5	Silicon	33
Osmium		Cesium	0.2	Arsenic	0.03	Aluminum	2
Rhenium		Iodine	0.09	Germanium	0.02	Magnesium	4
Tungsten		Tellurium		Gallium	0.06	Sodium	6
Tantalum		Antimony		Zinc	0.8	Fluorine	≈91
Hafnium		Tin		Copper	0.2	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.3	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	0.1	Carbon	NR
Thulium		Silver		Iron	6	Boron	0.1
Erbium		Palladium		Manganese	0.1	Beryllium	
Holmium		Rhodium		Chromium	1	Lithium	0.1
Dysprosium		*Probable contamination from sample preparation.				Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.02 ppm

MC — Major Component > 100 ppm

INT — Interference

Approved:

5-59

Robert L. Dwyer
3 Feb-84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to



To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94039

Date: February 3, 1984

Analyst: G. Meagher

P. O. No.: Subcontract SW59159A Release 11 Project 7601

Sample No.: 819466
RA Imp 1, test 2

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N182-116-28

CONCENTRATION IN $\mu\text{g/mL}$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.02
Thorium		Gadolinium		Molybdenum	0.3	Titanium	0.4
Bismuth		Europium		Niobium	0.002	Scandium	≤ 0.002
Lead		Samarium		Zirconium	0.003	Calcium	MC
Thallium		Neodymium		Yttrium		Potassium	0.5
Mercury	NR	Praseodymium		Strontium	0.02	Chlorine	MC
Gold		Cerium		Rubidium	0.006	Sulfur	MC
Platinum		Lanthanum		Bromine	0.1	Phosphorus	0.4
Iridium		Barium	0.03	Selenium	0.3	Silicon	MC
Osmium		Cesium	0.007	Arsenic	0.009	Aluminum	0.6
Rhenium		Iodine	*0.2	Germanium	0.001	Magnesium	2
Tungsten		Tellurium	0.003	Gallium	0.03	Sodium	MC
Tantalum		Antimony	0.007	Zinc	0.3	Fluorine	MC
Hafnium		Tin	0.01	Copper	0.3	Oxygen	NR
Lutetium		Indium	STD	Nickel	MC	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	0.7	Carbon	NR
Thulium		Silver	0.02	Iron	MC	Boron	0.006
Erbium		Palladium		Manganese	2	Beryllium	
Holmium	≤ 0.1	Rhodium		Chromium	MC	Lithium	0.04
Dysprosium		*Heterogeneous				Hydrogen	NR

STD - Internal Standard

NR - Not Reported

All elements not detected $\leq 0.002 \mu\text{g/mL}$

MC - Major Component $> 10 \mu\text{g/mL}$

INT - Interference

Approved:

5-60

Robert L. Daylen
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to



To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94039

Date: February 3, 1984

Analyst: G. Meagher

P. O. No.: Subcontract No. SW59159A Release 11 Project 7601

Sample No.: 819493
RA Bottom Ash
test #3

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS
CONCENTRATION IN PPM WEIGHT

IAD No.: 97-N182-116-28

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	16	Terbium	2	Ruthenium		Vanadium	140
Thorium	32	Gadolinium	5	Molybdenum	9	Titanium	MC
Bismuth		Europium	2	Niobium	39	Scandium	73
Lead	17	Samarium	11	Zirconium	270	Calcium	MC
Thallium	<0.4	Neodymium	42	Yttrium	41	Potassium	MC
Mercury	NR	Praseodymium	22	Strontium	400	Chlorine	230
Gold		Cerium	49	Rubidium	22	Sulfur	MC
Platinum		Lanthanum	56	Bromine	6	Phosphorus	MC
Iridium		Barium	890	Selenium	18	Silicon	MC
Osmium		Cesium		Arsenic	8	Aluminum	MC
Rhenium		Iodine	3	Germanium	3	Magnesium	MC
Tungsten	2	Tellurium		Gallium	28	Sodium	MC
Tantalum	2	Antimony	29	Zinc	55	Fluorine	MC
Hafnium	3	Tin	2	Copper	110	Oxygen	NR
Lutetium	0.4	Indium	STD	Nickel	220	Nitrogen	NR
Ytterbium	4	Cadmium	0.6	Cobalt	64	Carbon	NR
Thulium	1	Silver	0.3	Iron	MC	Boron	78
Erbium	3	Palladium		Manganese	42	Beryllium	10
Holmium	5	Rhodium		Chromium	430	Lithium	>530
Dysprosium	7					Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.2 ppm

MC — Major Component

INT — Interference

Approved:

5-61

Robert L. Taylor
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

Reply to

To: Acurex Corporation
555 Clyde Avenue
P.O. Box 7555
Mountain View, CA 94039



Date: February 3, 1984

Analyst: G. Meagher

P. O. No.: Subcontract SW 59159A Release Number 11 Project: 7601

Sample No.: 319464 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS IAD No.: 97-N182-116-28
RA cyclone ash, test 3

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	9	Terbium	0.6	Ruthenium		Vanadium	44
Thorium	14	Gadolinium	2	Molybdenum	6	Titanium	MC
Bismuth		Europium	1	Niobium	13	Scandium	15
Lead	32	Samarium	5	Zirconium	28	Calcium	MC
Thallium	3	Neodymium	10	Yttrium	12	Potassium	MC
Mercury	NR	Praseodymium	9	Strontium	210	Chlorine	13
Gold		Cerium	30	Rubidium	28	Sulfur	220
Platinum		Lanthanum	34	Bromine	5	Phosphorus	MC
Iridium		Barium	310	Selenium	13	Silicon	MC
Osmium		Cesium	4	Arsenic	18	Aluminum	MC
Rhenium		Iodine	0.2	Germanium	7	Magnesium	MC
Tungsten	1	Tellurium	0.2	Gallium	19	Sodium	MC
Tantalum	1	Antimony	5	Zinc	24	Fluorine	=610
Hafnium	1	Tin	2	Copper	14	Oxygen	NR
Lutetium	0.2	Indium	STD	Nickel	31	Nitrogen	NR
Ytterbium	1	Cadmium	0.8	Cobalt	10	Carbon	NR
Thulium	0.4	Silver	0.2	Iron	MC	Boron	27
Erbium	0.8	Palladium		Manganese	9	Beryllium	5
Holmium	1	Rhodium		Chromium	42	Lithium	>370
Dysprosium	2					Hydrogen	NR

STD - Internal Standard

NR - Not Reported

All elements not detected < 0.1 ppm

MC - Major Component > 1000 ppm

INT - Interference

Approved:
5-62

Robert L. Daylen
3 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-9300

ROBERT L. TAYLOR, Ph.D.
MANAGER
INSTRUMENTAL ANALYSIS DIVISION



PLEASE ADDRESS ALL CORRESPONDENCE TO:
490 ORCHARD ST., GOLDEN, CO 80401
OFFICE TEL. (303) 278-9521

June 8, 1984

Mr. Christopher Mann
Acurex Corporation
P.O. Box 7555
Mountain View, CA 94039

RE: IAD #97-N815-116-18
Subcontract #SW 59159A
Release #13

Analytical Report


Eighteen samples, previously analyzed for trace elements by spark source mass spectrometry under our IAD identification #97-N182-116-28, were logged in under our IAD identification #97-N815-116-18 on February 22, 1984.


Chlorine and Fluorine were determined using specific ion electrode methodology. Boron and Phosphorus were determined colorimetrically.

Depending on sample type and the amount of sample available, Sulfur was determined turbidimetrically or by X-ray fluorescence spectrometry while the remaining elemental analysis was performed using either atomic absorption/emission spectrophotometry or X-ray fluorescence spectrometry.

The results of these determinations are presented in the following tables. Samples #1, 2, 3, 4, 6, 7, 8, 10, 12, 13, 15, 17 and 18 are reported in weight per cent (Wt.%) on an "as received" basis. Samples #5, 9, 11, 14 and 16 are reported in micrograms per millilitres (µg/mL) on an "as received" basis.

If you have any questions concerning these results, please call.


Harold A. Connell
Assistant Lab Manager


Robert L. Taylor, Ph.D., Mng'r.
Instrumental Analysis Div.

as



Charter Member

Table No. I
(Wt. % - As Received)

Parameter	819463
	RA Filter + 1 μ , Test 1
Aluminum (Al)	5.39
Boron (B)	*
Calcium (Ca)	11.05
Fluorine (F)	*
Iron (Fe)	8.21
Potassium (K)	4.39
Lithium (Li)	*
Magnesium (Mg)	1.54
Sodium (Na)	3.37
Phosphorus (P)	12.20
Sulfur (S)	3.31
Silicon (Si)	**
Titanium (Ti)	0.51

* Insufficient sample for analysis.

** Unable to analyze due to contamination
from the fiberglass filter.



Table No. II
(Wt. % - As Received)

Parameter	819475
	RA Filter, Test 2
Aluminum (Al)	1.30
Arsenic (As)	0.13
Boron (B)	*
Calcium (Ca)	0.25
Chlorine (Cl)	0.03 (300 µg/g)
Chromium (Cr)	0.02 (200 µg/g)
Copper (Cu)	0.02 (180 µg/g)
Iron (Fe)	3.94
Potassium (K)	2.86
Lithium (Li)	*
Magnesium (Mg)	<0.1
Manganese (Mn)	0.04 (400 µg/g)
Sodium (Na)	0.57
Nickel (Ni)	0.03 (250 µg/g)
Phosphorus (P)	3.93
Lead (Pb)	4.69
Sulfur (S)	2.58
Antimony (Sb)	<0.01 (<100 µg/g)
Silicon (Si)	3.89
Zinc (Zn)	0.10

* Insufficient sample for analysis.

Table No. III
(Wt. %-As Received)

<u>Parameter</u>	<u>319456</u>	
	<u>RA 10_u + 3_u, Test 1</u>	
Aluminum (Al)	7.58	
Arsenic (As)	0.05	(490 μ g/g)
Boron (B)	0.02	(230 μ g/g)
Barium (Ba)	0.19	
Calcium (Ca)	1.32	
Chromium (Cr)	0.004	(40 μ g/g)
Iron (Fe)	10.79	
Potassium (K)	1.17	
Lithium (Li)	0.10	(950 μ g/g)
Magnesium (Mg)	0.43	
Manganese (Mn)	0.09	(900 μ g/g)
Sodium (Na)	0.45	
Phosphorus (P)	1.67	
Sulfur (S)	1.59	
Selenium (Se)	≤ 0.001	(≤ 10 μ g/g)
Silicon (Si)	12.81	
Strontium (Sr)	0.12	
Titanium (Ti)	0.68	
Zinc (Zn)	0.06	(610 μ g/g)

Table No. IV
(Wt. % - As Received)

<u>Parameter</u>	819492
	<u>RA 10μ+ 3μ, Test 2</u>
Aluminum (Al)	9.03
Boron (B)	≤ 0.008 (≤ 80 $\mu\text{g/g}$)
Calcium (Ca)	1.37
Chlorine (Cl)	0.42
Chromium (Cr)	0.14
Iron (Fe)	11.22
Potassium (K)	1.22
Lithium (Li)	0.02 (200 $\mu\text{g/g}$)
Magnesium (Mg)	0.40
Sodium (Na)	0.52
Nickel (Ni)	0.03 (250 $\mu\text{g/g}$)
Phosphorus (P)	1.71
Sulfur (S)	3.06
Silicon (Si)	14.97
Titanium (Ti)	0.83
Zinc (Zn)	0.07 (680 $\mu\text{g/g}$)

Table No. V
($\mu\text{g/mL}$ -As Received)

<u>Parameter</u>	<u>819466</u>	
	<u>RA Imp</u>	<u>1, Test 2</u>
Calcium (Ca)	2.2	
Chlorine (Cl)	4,500	(0.45%)
Chromium (Cr)	96	
Fluorine (F)	42	
Iron (Fe)	450	
Sodium (Na)	2,000	(0.20%)
Nickel (Ni)	71	
Sulfur (S)	7,700	(0.77%)
Silicon (Si)	12	



Table No. VI
(Wt. % - As Received)

<u>Parameter</u>	819449
	<u>RA Coal, Test 1</u>
Aluminum (Al)	1.19
Calcium (Ca)	0.19
Iron (Fe)	0.34
Potassium (K)	0.12
Magnesium (Mg)	0.05 (480 µg/g)
Sodium (Na)	0.05 (520 µg/g)
Silicon (Si)	1.87
Titanium (Ti)	0.05 (540 µg/g)

Table No. VII
(Wt. % As Received)

<u>Parameter</u>	<u>819485</u> <u>RA PET, Test 2</u>
Silicon (Si)	0.07



Table No. VIII
(Wt.-% As Received)

<u>Parameter</u>	<u>819488</u> <u>RA Bottom Ash, Test 1</u>
Aluminum (Al)	12.89
Calcium (Ca)	1.19
Fluorine (F)	≤ 0.01
Iron (Fe)	4.75
Potassium (K)	1.24
Magnesium (Mg)	0.46
Sodium (Na)	0.56
Silicon (Si)	21.16
Titanium (Ti)	0.68

Table No. IX
($\mu\text{g}/\text{mL}$ -As Received)

<u>Parameter</u>	819495
	<u>RA Bottom Ash Leachate, Test 1</u>
Calcium (Ca)	110
Potassium (K)	7.3
Magnesium (Mg)	4.7
Sulfur (S)	110

Table No. X
(Wt. % - As Received)

<u>Parameter</u>	819498
	<u>RA Bottom Ash, Test 2</u>
Aluminum (Al)	16.43
Barium (Ba)	0.10 (985 µg/g)
Calcium (Ca)	2.59
Fluorine (F)	≤0.01
Iron (Fe)	3.86
Potassium (K)	1.14
Lithium (Li)	0.005 (54 µg/g)
Magnesium (Mg)	0.47
Sodium (Na)	0.52
Phosphorus (P)	0.10
Sulfur (S)	0.54
Silicon (Si)	21.27
Titanium (Ti)	0.74

5-73

COMMERCIAL TESTING & ENGINEERING CO.



Table No. XI
($\mu\text{g/mL}$ -As Received)

<u>Parameter</u>	<u>819496</u> <u>RA Bottom Ash Leachate, Test 2</u>
Aluminum (Al)	14
Calcium (Ca)	53
Potassium (K)	5.1
Sodium (Na)	7.1
Sulfur (S)	90

Table No. XII
(Wt.% -As Received)

<u>Parameter</u>	819493
	<u>RA Bottom Ash, Test 3</u>
Aluminum (Al)	16.84
Barium (Ba)	0.10
Calcium (Ca)	1.14
Fluorine (F)	≤0.01
Iron (Fe)	3.94
Potassium (K)	1.20
Lithium (Li)	0.008 (75 µg/g)
Magnesium (Mg)	0.34
Sodium (Na)	0.42
Phosphorus (P)	0.09
Silicon (Si)	20.88
Sulfur (S)	0.11
Titanium (Ti)	0.74

5-75

COMMERCIAL TESTING & ENGINEERING CO.



Table No. XIII
(Wt. % - As Received)

<u>Parameter</u>	<u>819476</u> <u>RA Cyclone Ash, Test 1</u>
Aluminum (Al)	5.62
Calcium (Ca)	0.67
Iron (Fe)	9.52
Potassium (K)	0.51
Magnesium (Mg)	0.15
Sodium (Na)	0.26
Phosphorus (P)	0.27
Sulfur (S)	4.05
Silicon (Si)	8.20
Titanium (Ti)	0.35



Table No. XIV
($\mu\text{g/mL}$ -As Received)

<u>Parameter</u>	<u>819482</u>	
	<u>RA Cyclone Ash Leachate, Test 1</u>	
Aluminum (Al)	1,500	(0.15%)
Calcium (Ca)	1.8	
Copper (Cu)	18	
Fluorine (F)	42	
Iron (Fe)	1,100	(0.11%)
Potassium (K)	140	
Lithium (Li)	4.7	
Magnesium (Mg)	110	
Manganese (Mn)	24	
Sodium (Na)	170	
Phosphorus (P)	0.02	
Sulfur (S)	15,300	(1.53%)
Silicon (Si)	89	
Strontium (Sr)	24	
Titanium (Ti)	4.4	
Zinc (Zn)	44	



Table No. XV
(Wt. % - As Received)

<u>Parameter</u>	819504
	<u>RA Cyclone Ash, Test 2</u>
Aluminum (Al)	6.66
Calcium (Ca)	2.27
Iron (Fe)	11.27
Potassium (K)	0.64
Magnesium (Mg)	0.43
Sodium (Na)	0.27
Phosphorus (P)	0.33
Sulfur (S)	2.81
Silicon (Si)	9.84
Titanium (Ti)	0.45



Table No. XIV
($\mu\text{g/mL}$ -As Received)

<u>Parameter</u>	<u>819486</u> <u>RA Cyclone Ash Leachate, Test 2</u>
Aluminum (Al)	1,100 (0.11%)
Calcium (Ca)	1.9
Fluorine (F)	38
Iron (Fe)	540
Potassium (K)	56
Lithium (Li)	4.4
Magnesium (Mg)	96
Manganese (Mn)	18
Sodium (Na)	170
Phosphorus (P)	≤ 0.01
Sulfur (S)	3,900 (0.39%)
Silicon (Si)	210
Titanium (Ti)	0.5

Table No. XVII
(Wt. %-As Received)

<u>Parameter</u>	819464
	<u>RA Cyclone Ash, Test 3</u>
Aluminum (Al)	13.57
Calcium (Ca)	1.28
Iron (Fe)	9.35
Potassium (K)	1.75
Lithium (Li)	0.01 (110 µg/g)
Magnesium (Mg)	0.47
Sodium (Na)	0.24
Phosphorus (P)	0.16
Silicon (Si)	21.43
Titanium (Ti)	0.76



Table No. XVIII
(Wt. % - As Received)

<u>Parameter</u>	<u>819478</u>	
	<u>RA Coal/PET, Test 2</u>	
Aluminum (Al)	1.56	
Calcium (Ca)	0.09	(930 µg/g)
Iron (Fe)	0.38	
Potassium (K)	0.09	(910 µg/g)
Magnesium (Mg)	0.04	(370 µg/g)
Sodium (Na)	0.04	(370 µg/g)
Silicon (Si)	1.37	
Titanium (Ti)	0.05	(480 µg/g)

DATA REPORTING FORM

CUSTOMER CMEA DATE January 13, 1984
 CUSTOMER CONTRACT NO. 307736.62 ACUREX CONTRACT NO. 8311-030
 RESULTS REPORT TO L. Waterland TELEPHONE _____
 ADDRESS _____
Vermont

	Bottom	Cyclone	Bottom	Cyclone						
SAMPLE ID (CUSTOMER)	Ash Test 1	Ash Test 1	Ash Test 2	Ash Test 2						
SAMPLE ID (LAB)	488	476	498	504						
PARAMETER										UNITS
NO ₂ ⁻	<1	<10	<1	<10						mg/L
NO ₃ ⁻	<1	<10	<1	<10						mg/L
PO ₄ ⁻³	<1	<10	<1	<10						
F ⁻	0.25	0.46	0.10	1.8						
Cl ⁻	2.6	300	1.3	180						
SO ₄ ⁻²	300	19,000	220	12,000						
SO ₄ ⁻² and SO ₃ ⁻²	320	24,000	240	17,000						

ANALYST C. McMillen
 REVIEWER [Signature]

5.6 TOTAL CHROMATOGRAPHABLE ORGANICS (TCO), GRAVIMETRIC ORGANICS (GRAV), GAS CHROMATOGRAPHY/MASS SPECTROMETRY (GC/MS), AND INFRARED SPECTRA (IR) OF TOTAL SAMPLE EXTRACTS

Acurex/ES

January 16, 1984

Acurex ID#: 8310-003

8311-030

Client PO#: 307736.62

Attention: Larry Waterland

Sample: Vermont, Rock of Ages, 2 SASS Trains;
Received 7/12/83

The above samples were analyzed by Level 1 protocol. The XAD and OMC extracts were combined per your instruction. Organic extracts were also analyzed for the semivolatile priority pollutants by gas chromatography/mass spectrometry employing a J&W SE-54 30 meter capillary column. The column was held at 30°C for 2 minutes, then ramped at 10°C per minute to 270°C. In addition to the priority pollutants, other organics including benzo(c)phenanthrene, dibenzo(c,g)carbazole, 7,12-dimethylbenzo(a)anthracene, 3-methylcholanthrene, and perylene were sought employing the computerized library search and manual interpretation. The assignment and quantitation of these organics is tentative since analytical standards of these compounds were not available for analysis. Benzo(c)phenanthrene, dibenzo(c,g)carbazole, 7,12-dimethylbenzo(a)anthracene, 3-methylcholanthrene and perylene were not detected in any of the samples at levels above 400 µg per 10 mL of extract.

Submitted by: Greg Nicoll
Greg Nicoll
Operations ManagerViorica Lopez-Avila
Viorica Lopez-Avila, Ph.D.
Technical Director

GN/VLA/ats

DATA REPORTING FORM

CUSTOMER CMEA DATE January 16, 1984
CUSTOMER CONTRACT NO. 307736.62 ACUREX CONTRACT NO. 8310-003
RESULTS REPORT TO L. Waterland TELEPHONE _____
ADDRESS _____
Vermont

5-86

SAMPLE ID (CUSTOMER)	XAD I	XAD II	XAD B1k	Front I	Front II	Bottom Ash I	Cyclone Ash I	Bottom Ash II	Cyclone Ash II	
SAMPLE ID (LAB)	8	23	14	6	20	28	29	32	33	
PARAMETER										UNITS
GRAV	24	27	<4	<8	<9	<80*	1100*	220*	500*	mg/train
TCO	2.0	3.5; 2.8**	<0.2	--	--	--	--	--	--	mg/train
PAH - Naphthalene	0.06	0.35; 0.44**	<0.01	--	--	--	--	--	--	mg/train
- Phenol	<0.01	0.45; 0.54**	<0.01	--	--	--	--	--	--	mg/train
- Phenanthrene	<0.01	0.07; 0.08**	<0.01	--	--	--	--	--	--	mg/train
- Fluoranthene	<0.01	0.05; 0.06**	<0.01	--	--	--	--	--	--	mg/train
- Bis(2-ethylhexyl) phthalate ***	0.12	0.14; 0.07**	<0.01	--	--	--	--	--	--	mg/train
- Diethyl phthalate ***	<0.01	0.15; 0.15**	<0.01	--	--	--	--	--	--	mg/train

* mg/Kg
** Duplicate injection

*** Normally found in laboratory blanks
at this level

ANALYST U. Spannagel, C. Beeman, S. Kraska

REVIEWER

[Signature]

IR REPORT

SAMPLE: 8310-03-6 Front Half Rinse

[illegible]

SAMPLE: 8310-03-8 XAD Test I

SAMPLE: 8310-03-8 XAD Test I

5-88

IR REPORT

SAMPLE: 8310-03-14 XAD B1k

[illegible]

SAMPLE:

Bottom Ash I

5-90

SAMPLE: 8310-03-29 Cyclone Ash I

5-91

SAMPLE: 8310-03-20 Front Half Rinse Test II

8310-03-20

Front Half Rinse Test II

[illegible]

5-93

IR REPORT

SAMPLE:

8310-03-32

Bottom Ash II

[illegible]

SAMPLE: 8310-03-33 Cyclone Ash II

SAMPLE: 8310-03-33 Cyclone Ash II

Aliphatic

GC/MS Detection Limits

<u>ACID COMPOUND</u>		<u>ng</u>	<u>BASE/NEUTRAL COMPOUNDS</u>		<u>ng</u>
21A	2,4,6-trichlorophenol	5	41B	4-bromophenyl phenyl ether	1
22A	p-chloro-m-cresol	5	42B	bis(2-chloroisopropyl)ether	1
24A	2-chlorophenol	5	43B	bis(2-chloroethoxy)methane	1
31A	2,4-dichlorophenol	5	52B	hexachlorobutadiene	1
34A	2,4-dimethylphenol	5	53B	hexachlorocyclopentadiene	1
57A	2-nitrophenol	5	54B	isophorone	1
58A	4-nitrophenol	20	55B	naphthalene	1
59A	2,4-dinitrophenol	20	56B	nitrobenzene	1
60A	4,6-dinitro-o-cresol	20	61B	N-nitrosodimethylamine	NA
64A	pentachlorophenol	5	62B	N-nitrosodiphenylamine	1
65A	phenol	1	63B	N-nitrosodi-n-propylamine	5
<u>BASE/NEUTRAL COMPOUNDS</u>			66B	bis(2-ethylhexyl)phthalate	1
1B	acenaphthene	1	67B	butylbenzyl phthalate	1
5B	benzidine	20	68B	di-n-butyl phthalate	1
8B	1,2,4-trichlorobenzene	1	69B	di-n-octyl phthalate	1
9B	hexachlorobenzene	1	70B	diethyl phthalate	1
12B	hexachloroethane	1	71B	dimethyl phthalate	1
18B	bis(2-chloroethyl)ether	1	72B	benzo(a)anthracene	1
20B	2-chloronaphthalene	1	73B	benzo(a)pyrene	1
25B	1,2-dichlorobenzene	1	74B	3,4-benzofluoranthene	1
26B	1,3-dichlorobenzene	1	75B	benzo(k)fluoranthene	1
27B	1,4-dichlorobenzene	1	76B	chrysene	1
28B	3,3'-dichlorobenzidine	5	77B	acenaphthylene	1
35B	2,4-dinitrotoluene	1	78B	anthracene	1
36B	2,6-dinitrotoluene	1	79B	benzo(ghi)perylene	5
37B	1,2-diphenylhydrazine (as azobenzene)	1	80B	fluorene	1
39B	fluoranthene	1	81B	phenanthrene	1
40B	4-chlorophenyl phenyl ether	1	82B	dibenzo(a,h)anthracene	5
			83B	indeno(1,2,3-cd)pyrene	5
			84B	pyrene	1

5.7 LIQUID CHROMATOGRAPHY (LC) SEPARATION AND IR SPECTRA OF LC FRACTIONS

Acurex/ES (CMEA)
MS 2-2260

March 12, 1984
Acurex ID#: 8402-020
Client PO#: 307736.62


Attention: Larry Waterland

Sample: Cyclone Ash, Rock of Ages; Received 2/10/84


The above samples were subjected to liquid chromatography followed by gravimetric measurement and infrared spectrophotometry according to Level 1 protocol.

Results are enclosed.

Submitted by:


John S. Labash
Chemist

Approved by:


Greg Nicoll
Manager, Inorganic Chemistry

JSL/GN/ats

Enclosures

SAMPLE: Rock of Ages Cyclone Ash Test 1 #819476 8402-020-1

	TCO mg	GRAV mg	TCO + GRAV Total mg	Concentration mg/ Kg
Total Sample ¹		55		1100
Taken for LC ²		22		440
Recovered ³		28		560

Fraction	TCO in mg				GRAV in mg				TCO + GRAV Total mg	Concentration mg/Kg
	Found in Fraction	Blank	Cor- rected	Total ⁴	Found in Fraction	Blank	Cor- rected	Total ⁴		
1					5.0	<0.5	5.0	12		240
2					0.8	<0.4	0.8	2		40
3					2.2	<0.4	2.2	6		120
4					1.8	<0.4	1.8	4		80
5					2.2	<0.4	2.2	6		120
6					11.6	<0.4	11.6	29		580
7					4.6	0.6	4.0	10		200
Sum					28.2	0.6	27.6	69		1400

1. Quantity in entire sample, determined before LC
2. Portion of whole sample used for LC, actual mg
3. Quantity recovered from LC column, actual mg
4. Total mg computed back to total sample

IR REPORT

SAMPLE: 2-20-1 LCF 1 Cyclone Ash Test 1

[illegible]

SAMPLE: 2-20-1 LCF 2

SAMPLE: 2-20-1 LCF 2

5-102

SAMPLE: 2-20-1 LCF 3

SAMPLE: 2-20-1 LCF 3

5-103

IR REPORT
SAMPLE: 2-20-1 LCF 4

SAMPLE: 2-20-1 LCF 4

[illegible]

SAMPLE 2-20-1 LCF 5

5-105

SAMPLE: 2-20-1 LCF 6

5-106

SAMPLE: 2-20-1 LCF 7

5-107

SAMPLE: Rock of Ages Cyclone Ash Test 2 #819504 8402-020-2

	TCO mg	GRAV mg	TCO + GRAV Total mg	Concentration mg/Kg
Total Sample ¹		25		500
Taken for LC ²		22		440
Recovered ³		27		540

Fraction	TCO in mg				GRAV in mg				TCO + GRAV Total mg	Concentration mg/Kg
	Found in Fraction	Blank	Cor- rected	Total ⁴	Found in Fraction	Blank	Cor- rected	Total ⁴		
1					5.0	<0.5	5.0	5.6		110
2					1.8	<0.4	1.8	2.0		40
3					3.4	<0.4	3.4	3.8		76
4					2.4	<0.4	2.4	2.7		54
5					2.6	<0.4	2.6	2.9		58
6					8.4	<0.4	8.4	9.3		190
7					3.6	0.6	3.0	3.3		66
Sum					27.2	0.6	26.6	29.6		590

1. Quantity in entire sample, determined before LC

2. Portion of whole sample used for LC, actual mg

3. Quantity recovered from LC column, actual mg

4. Total mg computed back to total sample

IR REPORT

SAMPLE: 2-20-2 LCF 1 Cyclone Ash Test 2

[illegible]

IR REPORT

SAMPLE: 2-20-2 LCF 2

[illegible]

SAMPLE:

2-20-2 LCF 3

5-111

SAMPLE: 2-20-2 LCF 4

5-112

IA REPORT

SAMPLE:

2-20-2

LCE 5

[illegible]

SAMPLE: 2-20-2 LCF 6

SAMPLE: 2-20-2 LCF 6

5-114

Acurex/ES (CMEA)
MS 2-2260

March 13, 1984
Acurex ID#: 8401-029
Client PO#: 307736.62


Attention: Larry Waterland

Sample: Honor Rancho Inlet XAD, Rock of Ages XADs;
Received 1/20/84


The above samples were subjected to liquid chromatography followed by TCO, gravimetric measurement, and infrared spectrophotometry according to Level 1 protocol.

Results are enclosed.

Prepared by:


John S. Labash
Chemist

Approved by:


Greg Nicoll
Manager, Inorganic Chemistry

JSL/GN/ats

SAMPLE: 819459 Rock of Ages Test 1 XAD-2

	TCO mg	GRAV mg	TCO + GRAV Total mg	Concentration mg/dscm
Total Sample ¹	2.0	24	26	
Taken for LC ²	1.1	14	15	
Recovered ³	0.6	7.9	8.5	

Fraction	TCO in mg				GRAV in mg				TCO + GRAV Total mg	Concentration mg/dscm
	Found in Fraction	Blank	Cor- rected	Total ⁴	Found in Fraction	Blank	Cor- rected	Total ⁴		
1	0.6	<0.2	0.6	1.1	1.5	<0.5	1.5	2.6	3.7	
2	<0.1	<0.1	<0.1	<0.2	<0.4	<0.4	<0.4	<0.7	<0.9	
3	<0.1	<0.1	<0.1	<0.2	<0.4	<0.4	<0.4	<0.7	<0.9	
4	<0.1	0.2	<0.1	<0.2	<0.4	<0.4	<0.4	<0.7	<0.9	
5	<0.1	<0.1	<0.1	<0.2	0.8	<0.4	0.8	1.4	1.4	
6	<0.1	<0.1	<0.1	<0.2	2.6	<0.4	2.6	4.6	4.6	
7	<0.1	<0.1	<0.1	<0.2	3.6	0.6	3.0	5.3	5.3	
Sum	0.6	<0.9	0.6	1.1	8.5	0.6	7.9	13.9	15	

1. Quantity in entire sample, determined before LC
2. Portion of whole sample used for LC, actual mg
3. Quantity recovered from LC column, actual mg
4. Total mg computed back to total sample

SAMPLE:

1-29-2 LCF 1

5-118

SAMPLE: _____

1-29-2 LCF 2

5-119

SAMPLE:

1-29-2 LCF 3

5-120

SAMPLE: 1-29-2 LCF 4

SAMPLE: 1-29-2 LCF 4

5-121

IR REPORT

SAMPLE: 1-29-2 LCF 5

[illegible]

SAMPLE:

1-29-2 LCF 6

* Tentative assignment

SAMPLE:

LCF 7

[illegible]

SAMPLE: 819465 Rock of Ages Test 2 XAD-2

	TCO mg	GRAV mg	TCO + GRAV Total mg	Concentration mg/dscm
Total Sample ¹	3.2	27	30	
Taken for LC ²	1.6	13	15	
Recovered ³	<0.8	13.6	14	

Fraction	TCO in mg				GRAV in mg				TCO + GRAV Total mg	Concentration mg/dscm
	Found in Fraction	Blank	Cor- rected	Total ⁴	Found in Fraction	Blank	Cor- rected	Total ⁴		
1	<0.2	<0.2	<0.2	<0.4	3.2	<0.5	3.2	6.5	6.5	
2	<0.1	<0.1	<0.1	<0.2	<0.4	<0.4	<0.4	<0.8	<1	
3	<0.1*	<0.1	<0.1	<0.2	1.2	<0.4	1.2	2.4	2.4	
4	<0.1	0.2	<0.1	<0.2	1.0	<0.4	1.0	2.0	2.0	
5	<0.1	<0.1	<0.1	<0.2	0.6	<0.4	0.6	1.2	1.2	
6	<0.1	<0.1	<0.1	<0.2	3.8	<0.4	3.8	7.8	7.8	
7	<0.1	<0.1	<0.1	<0.2	4.4	0.6	3.8	7.8	7.8	
Sum	<0.8	<0.9	<0.8	<2	14.2	0.6	13.6	27.7	27.7	

1. Quantity in entire sample, determined before LC
2. Portion of whole sample used for LC, actual mg
3. Quantity recovered from LC column, actual mg
4. Total mg computed back to total sample

*Duplicate injection gave <0.1

SAMPLE: 1-29-3 LCF 1

SAMPLE: 1-29-3 LCF 1

5-126

SAMPLE:

1-29-3 LCF 2

5-127

SAMPLE: 1-29-3 LCF 3

SAMPLE: 1-29-3 LCF 3

No peaks

SAMPLE: 1-29-3 LCF 4

SAMPLE: 1-29-3 LCF 4

5-129

SAMPLE: 1-29-3 LCF 5

5-130

IR REPORT

SAMPLE: 1-29-3 LCF 6

[illegible]

SAMPLE: 1-29-3 LCF 7

5-132

SAMPLE:

1-29-BLK LCF-1

[illegible]

IR REPORT

SAMPLE: 1-29-BLK LCF 2

[illegible]

IA REPORT

SAMPLE: 1-29-BLK LCF 3

[illegible]

IA REPORT

SAMPLE: 1-29-BLK LCF 4

[illegible]

IR REPORT

SAMPLE: 1-29-BLK LCF 5

[illegible]

IR REPORT

SAMPLE: 1-29-BLK LCF 6

[illegible]

IR REPORT

SAMPLE: 1-29-BLK LCF 7

[illegible]

5.8 GC/MS ANALYSES OF VOST TRAPS

Acurex/E.S.

Attention: Larry Waterland

November 1, 1983

Acurex ID#: 8307-010

Customer PO#: 307736.62

Page 1 of 2


Subject: Analysis of Two VOST Sample Sets
by GC/MS.

The above referenced samples were analyzed according to the latest revisions of the EPA VOST Protocol for Volatile Priority Pollutants and Xylenes. An attempt was also made to identify ethylene oxide, propylene oxide, 2-nitropropane and allyl chloride, but due to the lack of analytical standards for these compounds, it proved impossible.


Results are listed in Table 1.

Please call if you have any questions.

Prepared by:


William G. Hellier
Staff Chemist

Approved by:


Viorica Lopez-Avila, Ph.D.
Technical Director

WGH/VLA/ats

Table 1. Volatile Organics Results

Trap ID Lab ID	Concentration (ng/trap)				
	Tenax/C 819501 <i>Sample</i> -1	Tenax 819501 <i>Sample</i> -2 ^a	Tenax/C 819502 <i>Blank</i> -3	Tenax 819502 <i>Blank</i> -4	Tenax/C 819503 <i>Blank</i> -5 ^a
<u>Compound</u>					
Chloromethane	12	10	ND	ND	ND
Bromomethane	ND	ND	ND	ND	ND
Vinyl chloride	ND	ND	ND	ND	ND
Chloroethane	ND	ND	ND	ND	ND
Dichloromethane	65	>1,100	1,600	115	102
1,1-Dichloroethylene	98	ND	90	80	ND
1,1-Dichloroethane	ND	ND	ND	ND	ND
Trans-1,2-dichloroethylene	ND	ND	ND	ND	ND
Chloroform	22	67	ND	ND	8
1,2-Dichloroethane	ND	ND	37	ND	ND
1,1,1-Trichloroethane	ND	ND	ND	ND	ND
- Carbon tetrachloride	ND	ND	ND	ND	ND
Dichlorobromomethane	ND	ND	ND	ND	ND
1,2-Dichloropropane	ND	ND	ND	ND	ND
1,3-Dichloropropene(trans)	ND	ND	ND	ND	ND
Trichloroethylene	3	483	5	ND	17
Chlorodibromomethane	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	ND	ND	72	ND	21
1,3-Dichloropropene(cis)	ND	ND	ND	ND	ND
Benzene	7	ND	69	ND	26
2-Chloroethyl vinyl ether	ND	ND	ND	ND	ND
Bromoform	ND	ND	213	ND	ND
Tetrachloroethylene	ND	51	ND	ND	ND
1,1,2,2-Tetrachloroethane	ND	ND	173	ND	ND
Toluene	140	146	5	ND	36
Chlorobenzene	ND	152	15	ND	7
Ethylbenzene	ND	14	10	ND	7
Xylenes	ND	ND	ND	ND	ND
Dichlorodifluoromethane	ND	ND	ND	ND	ND
Trichlorofluoromethane	28	ND	ND	335	ND
<u>Percent Surrogate Recovery</u>					
Toluene-d ₈	95	57	88	50	88

5.9 N₂O ANALYSES BY GC/ECD

Acurex/E.S.

September 2, 1983

Acurex ID#: 8308-012

Client PO#: 307736.62

Page 1 of 1

Attention: Larry Waterland

Subject: Analysis of 2 Gas Bombs for Nitrous Oxide by GC/ECD

The above referenced samples were analyzed by GC/ECD according to previously reported method.

Results are listed in the table below:

<u>Sample ID</u>	<u>N₂O (ppm)</u>
812714	27
812715	58

If you have any questions, please call.

Submitted by: William G. Hellier
William G. Hellier
Staff Chemist

Approved by: Viorica Lopez-Avila
Viorica Lopez-Avila, Ph.D.
Technical Director

WGH/VLA/ats

5.10 BIOASSAY RESULTS

In the following, samples with the prefix "RA" are for these tests; samples with prefixes "HR", or "DM" are for other tests performed.



BIONETICS

5516 Nicholson Lane, Kensington, Maryland 20895 301 881-5600 • Telex 89-8369

April 18, 1984

Dr. Larry Waterland
Acurex Corporation
485 Clyde Avenue
Mountain View, California 94042

RE: Acurex Subcontract No. RB59178A
Release No. 6

Dear Larry:

Enclosed are three bound, and one unbound, copies of the final reports for the five XAD resin extract samples and six ash samples submitted for testing and evaluation in IERL-EPA Level 1 Ames/Salmonella mutagenesis and CHO cytotoxicity bioassays. All studies were conducted and evaluated under IERL-EPA Level 1 guidelines.

Bioassay of the samples took slightly longer than normal because a phased testing approach was used with the XAD-2 resin extract samples. This phased approach involved initial CHO cytotoxicity testing, then preliminary range-finding Ames tests with only one strain, followed by one or more definitive Ames assays. By using this approach, we were able to adequately test and evaluate all samples.

The summary of the bioassay data, the criteria used to evaluate the results, the critical data upon which the evaluations were based, and a graphic display of the relative ranking of the samples are presented in the attached tables and figures.

If you have any questions or comments concerning these reports or future testing, please feel free to contact me at (301) 881-5600, extension 536.

Sincerely,

LITTON BIONETICS, INC.

Robert R. Young
Environmental Assessment Section
Department of Molecular Toxicology

RRY/mg

Enclosures: Ames and CHO 7330-7346 Reports.

cc: Contracts, LBI No. 20993, 20988

TABLE 1
BIOASSAY SUMMARY TABLE

Technical Directive or Project No. LBI Project No. 20988 and 20993.

Contract No. EPA No. 68-02-3188; ACUREX Subcontract No. RB 59178A Release No. 6.

Sample Identification	Health Effects Tests					Ecological Effects Tests								Notes
	AMES salmonella	RAM Cytotoxicity	CHO Cytotoxicity	Rodent Toxicity	Fish	Aquatic				Terrestrial				
						Fresh Water		Marine		Plant Stress Ethylene	Root Elongation	Insect Toxicity		
						Invertebrate	Algal	Fish	Invertebrate				Algal	
HR XAD-2 EXTRACT, INLET (819369)	H		M/H											
HR XAD-2 EXTRACT, OUTLET (819370)	M		M											
RA XAD-2 EXTRACT, TEST 1 (819459)	H		M											
RA XAD-2 EXTRACT, TEST 2 (819465)	M		H/M											
DM XAD-2 EXTRACT (900206)	M		M											
RA BOTTOM ASH, TEST 1 (819488)	ND		ND											
RA BOTTOM ASH, TEST 2 (819498)	ND		ND											
RA CYCLONE ASH, TEST 1 (819476)	M/H		ND											
RA CYCLONE ASH, TEST 2 (819504)	L/M		ND											
DM FILTER + 1 μm PART. (900204)	ND		L											
DM 10 μm + 3 μm PART. (900218)	ND		L											

ND = No Detectable Toxicity
 L = Low Toxicity
 M = Moderate Toxicity
 H = High Toxicity

TABLE 2

DEFINITION OF TOXICITY CATEGORIES FOR HEALTH EFFECTS ASSAYS

Assay ^a	Activity Measured ^b	Sample Type ^c	MAD ^d	Units	Range of Concentration or Dosage			
					High	Moderate	Low	Not Detectable (ND)
Ames	MEC (mutagenesis)	S	5	mg/plate	<0.05	0.05-0.5	0.5-5	ND at >5
		AL,NAL	200	μl/plate	<2	2-20	20-200	ND at >200
		E	5000	L/plate	<50	50-500	500-5000	ND at >5000
RAM	EC ₅₀ (lethality)	S	1	mg/ml	<0.01	0.01-0.1	0.1-1	ND at >1
		AL	600	μl/ml	<6	6-60	60-600	ND at >600
		NAL	20	μl/ml	<0.2	0.2-2	2-20	ND at >20
		E	1000	L/ml	<10	10-100	100-1000	ND at >1000
CHO	EC ₅₀ (lethality)	S	1	mg/ml	<0.01	0.01-0.1	0.1-1	ND at >1
		AL	600	μl/ml	<6	6-60	60-600	ND at >600
		NAL	20	μl/ml	<0.2	0.2-2	2-20	ND at >20
		E	1000	L/ml	<10	10-100	100-1000	ND at >1000
WAT	LD ₅₀ (lethality and toxic signs)	S	5	gm/kg	<0.05	0.05-0.5	0.5-5	ND at >5
		AL,NAL	5	ml/kg	<0.05	0.05-0.5	0.5-5	ND at >5

^aStandard test abbreviations are as follows:

Ames: Ames Salmonella/microsome mutagenesis assay
 RAM: Rabbit alveolar macrophage cytotoxicity assay
 CHO: Rodent cell clonal toxicity assay
 WAT: Acute in vivo test in rodents (whole animal test)

^bStandard abbreviations for measured endpoints are as follows:

MEC: Minimum effective concentration
 EC₅₀: Calculated concentration expected to produce effect in 50 percent of population
 LD₅₀: Calculated dose expected to kill 50 percent of population

^cS = Solid, AL = Aqueous liquid, NAL = Nonaqueous liquid, E = Extract and/or concentrate of unknown organic content (use equivalent volume of SASS train gas)

^dMAD = Maximum applicable dose

TABLE 3

HEALTH EFFECTS CRITICAL DATA SUMMARY FORM^a

Contract No. EPA No. 68-02-3188 Technical Directive or Project No. LBI No. 20988 and 20993 Site Sampled HR, RA and DM
 Acurex Subcontract No. RB 59178A
 Release No. 6

Sample Identification	Ames Mutagenicity [MEC] ^b	CHO Clonal Toxicity [EC ₅₀] ^c	RAM Cytotoxicity [EC ₅₀] ^c				Rodent Toxicity	
			Viability	Viability Index	ATP	ATP/Per 10 ⁶ Cells	LD ₅₀ ^d	Toxic Signs ^e
HR XAD-2 EXTRACT, INLET 819369	25 ^f	11.5 ^f						
HR XAD-2 EXTRACT, OUTLET 819370	100	18.4						
RA XAD-2 EXTRACT, TEST 1 819459	20	35.2						
RA XAD-2 EXTRACT, TEST 2 819465	137.5	9.35						
DM XAD-2 EXTRACT 900206	200	16.0						
RA BOTTOM ASH, TEST 1 819488	>10000	>1000 (4000)						
RA BOTTOM ASH, TEST 2 819498	>10000	1400						
RA CYCLONE ASH, TEST 1 819476	50	>1000 (5000)						
RA CYCLONE ASH, TEST 2 819504	500	>1000 (1200)						
DM FILTER + 1 μ m PART. 900204	>10000	140						
DM 10 μ m + 3 μ m PART. 900218	>10000	450						

5-153

^aThe assays, observed parameters and evaluation criteria are presented in IERL-RTP Procedures Manual; Level 1 Environmental Assessment Biological Tests, [EPA Contract No. 68-02-2681, Litton Bionetics, Inc., Kensington, Md.]

^bMEC: Minimum Effective Concentration - Lowest concentration for any tester strain giving a mutagenic response.

^cEC₅₀: Effective concentration that reduces the observed parameter to 50 percent of the appropriate negative control.

^dLD₅₀: The dose lethal to 50 percent of treated animals.

^eToxic signs are identified in a numbered list in the Level 1 manual. Only the number is reported here.

^fConcentrations are μ g organics per plate for Ames assay and per ml of culture medium for the CHO assay. Values in parenthesis are extrapolated values.




Figure 1. Ranking of test material toxicity using EC_{50} in EPA level 1 CHO clonal toxicity assay.




Figure 2. Ranking of test material mutagenicity using minimum effective concentration in EPA level 1 Ames mutagenesis assay.

TECHNICAL REPORT DATA <i>(Please read Instructions on the reverse before completing)</i>		
1. REPORT NO. EPA-600/7-86-011b	2.	3. RECIPIENT'S ACCESSION NO.
4. TITLE AND SUBTITLE Environmental Assessment of a Commercial Boiler Fired with a Coal/Waste Plastic Mixture; Volume II. Data Supplement	5. REPORT DATE April 1986	6. PERFORMING ORGANIZATION CODE
7. AUTHOR(S) R. DeRosier, H.I. Lips, and L.R. Waterland	8. PERFORMING ORGANIZATION REPORT NO.	
9. PERFORMING ORGANIZATION NAME AND ADDRESS Acurex Corporation Energy and Environmental Division P.O. Box 7044 Mountain View, California 94039	10. PROGRAM ELEMENT NO.	11. CONTRACT/GRANT NO. 68-02-3188
12. SPONSORING AGENCY NAME AND ADDRESS EPA, Office of Research and Development Air and Energy Engineering Research Laboratory Research Triangle Park, NC 27711	13. TYPE OF REPORT AND PERIOD COVERED Final; 7/83 - 7/84	14. SPONSORING AGENCY CODE EPA/600/13
15. SUPPLEMENTARY NOTES AEERL project officer is Joseph A. McSorley, Mail Drop 65, 919/541-2920. Volume I contains the technical results.		
16. ABSTRACT The report gives results of comprehensive emissions testing and laboratory analyses of a stoker-fired commercial boiler firing a coal/waste plastic mixture. In one test, the unit fired its typical coal fuel; in the other, shredded waste polyethylene terephthalate (PET) beverage bottles were added to the coal to about 16% by weight in the mixed fuel. NOx, total unburned hydrocarbon, and solid particulate were relatively unchanged for the two tests, as was the emitted particle size distribution. SOx emissions decreased with the coal/PET fuel in keeping with its lowered sulfur content; average CO emissions were also decreased. Flue gas emissions of most trace elements were comparable for both tests, as were the trace element compositions of corresponding ash streams. However, lead emissions were significantly increased for the coal/PET fuel, reflecting an increased lead content of the mixed fuel. The cyclone hopper ash for the coal/PET test had consistently lower leachable trace element and anion content than for the coal fuel test. Total flue gas organic emissions were comparable for both tests, in the 1 mg/dscm range; although levels of several semivolatile priority pollutants were higher for the mixed fuel.		
17. KEY WORDS AND DOCUMENT ANALYSIS		
a. DESCRIPTORS	b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group
Pollution Assessments Combustion Coal Plastics Polyethylene Terephthalate	Pollution Control Stationary Sources Environmental Assessment Coal/Waste Fuel	13B 14B 21B 21D 111
18. DISTRIBUTION STATEMENT Release to Public	19. SECURITY CLASS (This Report) Unclassified 20. SECURITY CLASS (This page) Unclassified	21. NO. OF PAGES 203 22. PRICE