

R E S E A R C H   T R I A N G L E   I N S T

RTI/2418/29

STATUS REPORT #5  
STABILITY OF ORGANIC AUDIT MATERIALS  
AND RESULTS OF SOURCE TEST ANALYSIS AUDITS

R. K. M. Jayanty  
W. F. Gutknecht  
C. E. Decker

EPA Project Officers: Joseph E. Knoll  
Darryl J. von Lehmden

EPA Contract No.: 68-02-3431

Prepared for

U.S. Environmental Protection Agency  
Environmental Monitoring Systems Laboratory  
Quality Assurance Division  
Research Triangle Park, North Carolina 27711

June 1983

R E S E A R C H   T R I A N G L E   P A R K ,   N O R T H   C A R O

## TABLE OF CONTENTS

<u>SECTION NO.</u>		<u>PAGE</u>
1.0	INTRODUCTION . . . . .	1
1.1	Objectives. . . . .	1
1.2	Audit Materials Contained in the Repository . . .	1
2.0	EXPERIMENTAL PROCEDURES. . . . .	6
2.1	Instrumentation . . . . .	6
2.2	Calibration . . . . .	6
3.0	PERFORMANCE AUDITS . . . . .	9
4.0	STABILITY STUDIES. . . . .	22
5.0	SUMMARY AND CONCLUSIONS. . . . .	24
	REFERENCES . . . . .	25
	ATTACHMENT 1 - STABILITY DATA AS OF JUNE 1983. . . . .	26
	ATTACHMENT 2 - SAMPLE CALCULATIONS OF PERCENT CHANGE/MONTH . .	75

## SECTION 1.0

### INTRODUCTION

#### 1.1 OBJECTIVES

The need for reliable standards for source emission measurement of hydrocarbons, halocarbons and sulfur compounds is well established. The Research Triangle Institute (RTI) under contract to the U.S. Environmental Protection Agency (USEPA) has responded to this need through development of an extensive repository of gaseous compounds. The main objectives of this ongoing project are (1) to provide gas mixtures to EPA, state/local agencies, or their contractors as performance audits to assess the relative accuracy of source emission measurements in certain organic chemical manufacturing industries, (2) to corroborate the vendor's certified analysis of the gas mixtures by in-house analysis, (3) to determine the stability of the gas mixtures with time by in-house analysis, and (4) to explore the feasibility of new audit materials as requested by EPA.

This report describes the present status of this project. Included in the report are (1) a description of the experimental procedures used for initial cylinder analyses and collection of stability data, (2) a description of the audit procedure, (3) presently available audit results, and (4) presently available stability data. Full details of the study with additional statistical analyses for ten (10) halocarbons and eight (8) organics are presented in a journal publication (1,2). Statistical analysis for the remaining compounds will be presented in the final report.

#### 1.2 AUDIT MATERIALS CONTAINED IN THE REPOSITORY

The RTI repository currently contains 42 different compounds for use in conducting performance audits during source testing. The compounds were selected based on the anticipated needs of the personnel of the Emissions Measurements Branch, Office of Air Quality Planning and Standards, USEPA. Table 1 lists the compounds, the concentration

ranges, the number of cylinders of each compound, and the cylinder construction material. In Table 1, the audit materials fall into two concentration ranges. The low concentration range between 5 and 20 parts per million (ppm) simulates possible emission standard levels. The high concentration range between 50 and 700 ppm simulates expected source emission levels. The balance gas for all gas mixtures is nitrogen. In the case of some of the audit materials, a second compound, which serves as an internal standard, was added to the gas mixture.

TABLE 1. AUDIT MATERIALS CURRENTLY HELD IN THE REPOSITORY

Compound	Low Concentration Range			High Concentration Range		
	No. of Cylinders	Concentration Range (ppm)	Cylinder Construction*	No. of Cylinders	Concentration Range (ppm)	Cylinder Construction*
Benzene	14	8 - 13	S	17	60 - 400	AI, S
Ethylene	4	5 - 20	AI	4	300 - 700	AI
				6	3000 - 20,000	AI
Propylene	4	5 - 20	AI	4	300 - 700	AI
Methane/Ethane	-	-----	-	4	1000 - 6000(M), 200 - 700(E)	AI
Propane	4	5 - 20	AI	4	300 - 700	AI
Toluene	2	5 - 20	S	2	300 - 700	S
Hydrogen Sulfide	4	5 - 20	AI	2	300 - 700	AI
Meta-Xylene	2	5 - 20	S	2	300 - 700	LS
Methyl Acetate	2	5 - 20	S	2	300 - 700	S
Chloroform	2	5 - 20	S	2	300 - 700	S
Carbonyl Sulfide	2	5 - 20	S	2	100 - 300	S
Methyl Mercaptan	4	3 - 10	AI	-	-----	-
Hexane	2	20 - 80	AI	2	1000 - 3000	LS
1,2-Dichloroethane	4	5 - 20	AI	4	100 - 600	AI
Cyclohexane	-	-----	-	1	80 - 200	S
Methyl Ethyl Ketone	1	30 - 80	S	-	-----	-
Methanol	1	30 - 80	AI	-	-----	-
1,2-Dichloropropane	2	5 - 20	AI	2	300 - 700	LS
Trichloroethylene	2	5 - 20	AI	2	100 - 600	AI

\*Cylinder constructions: AI = Aluminum, S = Steel, LS = Low-Pressure Steel

TABLE 1. AUDIT MATERIALS CURRENTLY HELD IN THE REPOSITORY (Continued)

Compound	Low Concentration Range			High Concentration Range		
	No. of Cylinders	Concentration Range (ppm)	Cylinder* Construction	No. of Cylinders	Concentration Range (ppm)	Cylinder* Construction
1,1-Dichloroethylene	2	5 - 20	AI	2	100 - 600	AI
1,2-Dibromoethylene	2	5 - 20	AI	2	100 - 600	AI
Perchloroethylene	2	5 - 20	S	2	300 - 700	LS
Vinyl Chloride	9	5 - 30	S	-	-----	--
1,3-Butadiene	1	5 - 30	S	-	-----	--
Acrylonitrile	3	5 - 20	LS, AI	3	300 - 700	LS, AI
**Aniline	1	5 - 20	AI	-	-----	--
Methyl Isobutyl Ketone	1	5 - 20	AI	1	75	AI
**Para-dichlorobenzene	2	5 - 20	S	-	-----	--
**Ethylamine	2	5 - 20	AI	-	-----	--
**Formaldehyde	-	--	-	-	-----	--
Methylene Chloride	1	5 - 20	AI	-	-----	--
Carbon Tetrachloride	1	5 - 20	AI	-	-----	--
Freon 113	1	5 - 20	AI	-	-----	--
Methyl Chloroform	1	5 - 20	AI	-	-----	--
Ethylene Oxide	1	5 - 20	AI	-	-----	--
Propylene Oxide	1	5 - 20	AI	1	75 - 200	AI
Allyl Chloride	1	5 - 20	S	1	75 - 200	S

TABLE 1. AUDIT MATERIALS CURRENTLY HELD IN THE REPOSITORY (Continued)

Compound	Low Concentration Range			High Concentration Range		
	No. of Cylinders	Concentration Range (ppm)	Cylinder* Construction	No. of Cylinders	Concentration Range (ppm)	Cylinder* Construction
Acrolein	1	5 - 20	AI	-	-----	--
Chlorobenzene	1	5 - 20	AI	-	-----	--
Carbon Disulfide	-	---	AI	1	75 - 200	AI
**Cyclohexanone	1	5 - 20	AI	-	-----	--
***EPA Method 25 Gas	3	100 - 200	AI	3	750 - 2000	AI

\*Cylinder construction: AI = Aluminum, S = Steel, LS = Low Pressure Steel

\*\*Cylinders are no longer available in the repository since the compounds are found to be unstable in the cylinders.

\*\*\*The gas mixture contains an aliphatic, an aromatic and carbon dioxide in nitrogen. Concentrations shown are reported in ppmC.

## SECTION 2.0

### EXPERIMENTAL PROCEDURES

Analysis of the cylinder gases is required to corroborate the concentrations reported by the company which prepared the gas mixtures and also to measure concentration changes with time, that is, estimate stability of the standards.

#### 2.1 INSTRUMENTATION

Analyses are performed with (1) a Perkin-Elmer Model 3920B Gas Chromatograph with flame ionization and flame photometric detectors, and (2) a Tracor Model 560 Gas Chromatograph with a flame photometric detector. The Tracor instrument has been used principally for measurement of the sulfur-containing species. The gaseous samples are injected onto the columns by means of gas sampling valves constructed of Hastalloy C (high nickel content and low adsorptive properties). These valves are equipped with interchangeable sample loops to allow the injection of variable but known volumes of gas. To further facilitate the injection of varying sample sizes, a sample injection system (Figure 1) is employed. The operation of the system is based upon measurement of pressure differentials. Further details on the system are published in the open literature (3).

The gas chromatographic parameters used in the measurement of individual compounds and problems that have arisen are listed in Attachment 1.

#### 2.2 CALIBRATION

Calibration of the gas chromatographs has involved measurement of known concentrations of gases in air or nitrogen. The source or method of preparation of calibration standards varies depending on the gas involved.

National Bureau of Standards, Standard Reference Materials (NBS-SRM's) of methane and propane are used for the calibration of the GC for the measurement of methane and propane audit materials. These




Figure 1. Sample injection system.

same gases are used to calibrate the chromatographic system for measurement of ethylene and propylene, assuming the FID response per carbon is constant from compound to compound.

A second method for the quantitation of gaseous compounds involves the use of permeation tubes. Thus, the calibration gases for vinyl chloride and ethylene oxide have been generated using permeation tubes. The tube is placed in a temperature-controlled chamber and zero air is passed over the tube at a known flow rate. The resultant gaseous mixture is further diluted if necessary with additional zero air in a glass dilution bulb. The final mixture is collected in a gas sampling bulb or a Tedlar® bag and analyzed by GC-FID. The permeation rates of the tubes are determined periodically by weight loss.

A third method for developing a standard is the "glass bulb" technique. A known volume of the compound, either gas or liquid, is injected into an evacuated glass bulb of known volume. The bulb is then returned to atmospheric pressure with a balance gas of choice. If a pure liquid is injected, total vaporization is assumed and the concentration is calculated by using the ideal gas law. Additional dilutions are also made, if necessary, by utilizing additional bulbs or by repeatedly pressurizing with a balance gas to a known pressure and then partially evacuating to a known pressure.

With each of these approaches, multipoint calibration curves are prepared each time a sample is analyzed. Certain quality control procedures are followed, for example, equilibrating the permeation system and the glass bulbs with the sample gas before taking an aliquot for GC measurement. Also, an NBS standard cylinder of methane is used to verify the constancy of the detector response. Blank measurements are taken during the process of cylinder analysis and generally, blank measurements have shown no signal above the baseline.

## SECTION 3.0 PERFORMANCE AUDITS

RTI supplies repository cylinders for audits upon request from the EPA, state or local agencies or contractors. A contractor must be performing source emission tests at the request of EPA or a state or local agency in order to qualify for the performance audit. When a request is received, the contents of the cylinders are analyzed, the tank pressures are measured and the cylinders are shipped by overland carrier. Tank regulators are also provided when requested. A letter is included with the cylinders which provides general instructions for performance of the audit. The audit concentrations and cylinder pressures are provided to the requesting agency audit coordinator.

To date, 106 individual audits have been initiated, and 102 are complete. The audit results collected to date are presented in Table 2. Generally, the results of the audits show close agreement ( $\pm$  10%) with the actual cylinder concentrations measured prior to shipment.

TABLE 2. SUMMARY OF PERFORMANCE AUDIT RESULTS

Audit No.	Client	Industry	Audit material	RTI audit conc. (ppm)	Client audit % bias (Avg.)	Status of audit
1	A	Ethylene oxide production	Ethylene in N <sub>2</sub> Ethylene in N <sub>2</sub>	3,239 21,226	-22.5 -20.0	E
2	A	Ethylene oxide production	Methane/ethane in N <sub>2</sub> Methane/ethane in N <sub>2</sub>	1,710Me/220Et 8,130Me/597Et	+9/-20 +9/-1.00	E
3	A	Ethylene oxide production	Methane/ethane in N <sub>2</sub> Methane/ethane in N <sub>2</sub>	1,021Me/315Et 6,207Me/773Et	+21.5/-4.50 +23.5/-4.50	E
4	A	Acetone production	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	79.0 374.0	-19.0 -11.0	E
5	A	Maleic anhydride production	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	138 300	-9.40 +4.70	E
6	A	Ethylene oxide production	Ethylene in N <sub>2</sub> Ethylene in N <sub>2</sub>	5,442 18,918	-27.0 -33.0	E
7	B	Maleic anhydride production	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	80.0 355	+2.30 +27.5	E
8	C	Maleic anhydride production	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	101 387	+12.9 +14.5	E
9	D	Ethyl benzene styrene manufacturer	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	71.0 229	-2.80 -3.90	E
10	E	Gasoline bulk terminal	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	62.0 80.0	+3.80 +3.40	E
11	F	Gasoline transfer terminal	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	142 294	-3.50 +3.20	E
12	F	Gasoline transfer terminal	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	268 343	-11.8 -1.00	E

TABLE 2. SUMMARY OF PERFORMANCE AUDIT RESULTS (Continued)

Audit No.	Client	Industry	Audit material	RTI Audit conc. (ppm)	Client Audit % bias (Avg.)	Status of audit
13	F	Gasoline transfer terminal	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	129 318	+4.70 +8.70	E
14	F	Gasoline transfer terminal	Benzene in N <sub>2</sub>	10.7	+2.60	E
15	C	Nitrobenzene manufacturing	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	9.73 269	-4.60 -2.60	E
16	F	Gasoline bulk terminal	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	8.20 140	-2.30 -1.80	E
17a	F	Gasoline bulk terminal	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	9.50 127	+10.4 -2.80	E
17b	F	Gasoline bulk terminal	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	9.50 127	+12.5 -6.30	E
18	G	Coke oven	Hydrogen sulfide in N <sub>2</sub> Hydrogen sulfide in N <sub>2</sub>	7.05 9.73	-24.8 -22.9	E
19	F	Gasoline bulk terminal	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	12.0 218	-0.80 +7.30	E
20	F	Gasoline bulk terminal	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	7.65 396	+16.3 +1.50	E
21	F	Linear alkylbenzene manufacturing	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	98 294 331	+5.70 +6.80 +4.50	E
22	F	Gasoline bulk terminal	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	9.85 81.0	-4.10 -6.80	E
23	F	Gasoline bulk terminal	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	10.15 61.0	+4.60 -9.50	E

TABLE 2. SUMMARY OF PERFORMANCE AUDIT RESULTS (Continued)

Audit No.	Client	Industry	Audit material	RTI audit conc. (ppm)	Client audit % bias (Avg.)	Status of audit
24	H	Industrial surface coating process	Toluene in N <sub>2</sub> Propylene in N <sub>2</sub> Propane in N <sub>2</sub> Methane/ethane in N <sub>2</sub>	14.8 474 20.3 1,640Me/195et	-1.90 +0.20 -2.30 -13.5(as methane)	E
25	C	Acrylic acid and ester Production	Propane in N <sub>2</sub> Propane in N <sub>2</sub>	10.1 710	+8.60 +5.60	E
26	C	Acrylic acid and ester Production	Propane in N <sub>2</sub> Propane in N <sub>2</sub>	5.1 607	+17.6 -3.60	E
27	E	Maleic anhydride	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	10.2 218	NA NA	F
28A	A	Carbon adsorber	Toluene in N <sub>2</sub> Toluene in N <sub>2</sub>	8.55 405	-6.40 -1.00	E
28B	A	Carbon adsorber	Toluene in N <sub>2</sub> Toluene in N <sub>2</sub>	8.55 405	+4.10 NA	E
28C	A	Carbon adsorber	Toluene in N <sub>2</sub> Toluene in N <sub>2</sub>	8.55 405	-8.80 NA	E
29	EPA, QAD	Instrument check-out	Ethylene in N <sub>2</sub> Ethylene in N <sub>2</sub> Ethylene in N <sub>2</sub> Ethylene in N <sub>2</sub> Ethylene in N <sub>2</sub>	4.75 19.6 312 3021 20456	+4.00 +3.10 -0.80 +5.30 -8.60	E

TABLE 2. SUMMARY OF PERFORMANCE AUDIT RESULTS (Continued)

Audit No.	Client	Industry	Audit material	RTI Audit conc. (ppm)	Client Audit % bias (Avg.)	Status of audit
30	EPA, QAD	Instrument check-out	Benzene in N <sub>2</sub>	8.20	+0.30	E
			Benzene in N <sub>2</sub>	78.0	-0.90	
			Benzene in N <sub>2</sub>	133	-4.00	
			Benzene in N <sub>2</sub>	348	-0.90	
31	EPA, QAD	Instrument check-out	Toluene in N <sub>2</sub>	405	+3.20	E
			Toluene in N <sub>2</sub>	579	+1.00	
32	EPA, QAD	Instrument check-out	Methyl acetate in N <sub>2</sub>	6.80	-2.60	E
			Methyl acetate in N <sub>2</sub>	17.2	+1.70	
			Methyl acetate in N <sub>2</sub>	326	-1.50	
			Methyl acetate in N <sub>2</sub>	455	-1.30	
33	EPA, QAD	Instrument check-out	Propylene in N <sub>2</sub>	4.90	-22.4	E
			Propylene in N <sub>2</sub>	19.7	-7.80	
			Propylene in N <sub>2</sub>	300	+1.00	
			Propylene in N <sub>2</sub>	685	-1.80	
34	EPA, QAD	Instrument check-out	Propane in N <sub>2</sub>	14.6	-0.70	E
			Propane in N <sub>2</sub>	303	+7.60	
			Propane in N <sub>2</sub>	439	+6.20	
35a	I	Vegetable oil plant	Hexane in N <sub>2</sub>	82.2	+8.10	E
			Hexane in N <sub>2</sub>	1982	+3.00	
35b	I	Vegetable oil plant	Hexane in N <sub>2</sub>	82.2	-1.20	E
			Hexane in N <sub>2</sub>	1982	-1.30	
36	A	Carbon adsorber	Toluene in N <sub>2</sub>	8.20	-2.40	E

TABLE 2. SUMMARY OF PERFORMANCE AUDIT RESULTS (Continued)

Audit No.	Client	Industry	Audit material	RTI audit conc. (ppm)	Client audit % bias (Avg.)	Status of audit
37	B	Coke oven	Benzene in N <sub>2</sub>	12.1	+0.80	E
			Benzene in N <sub>2</sub>	105	+2.90	
38	D	Ethylbenzene/styrene	Benzene in N <sub>2</sub>	9.90	+5.70	E
			Benzene in N <sub>2</sub>	77.9	+3.60	
			Benzene in N <sub>2</sub>	345	+1.50	
39	B	Coke oven Byproduct	Benzene in N <sub>2</sub>	8.20	-2.60	E
			Benzene in N <sub>2</sub>	85.4	-8.70	
40	D	Coke oven Byproduct	Benzene in N <sub>2</sub>	10.9	+20.0	
			Benzene in N <sub>2</sub>	147	+6.80	
41	H	Paint spray	Benzene in N <sub>2</sub>	10.8	NA	F
			m-Xylene in N <sub>2</sub>	16.4	NA	
42	H	Tire manufacturing	Cyclohexane in N <sub>2</sub>	93.4	-11.1	D
43	B	Coke oven	Benzene in N <sub>2</sub>	7.54	+0.10	D
			Benzene in N <sub>2</sub>	225	+0.40	
44	D	Ethylbenzene/styrene	Benzene in N <sub>2</sub>	8.20	-3.40	D
			Benzene in N <sub>2</sub>	74.5	-0.20	
			Propane in N <sub>2</sub>	10.6	-3.00	
45	F	Industrial surface coating	Propane in Air	316	-3.20	E
			Propane in Air	450	-2.00	
46	EPA, QAD	Tire manufacturing	Propane in Air	15	NA	F
			Propane in Air	316	NA	

TABLE 2. SUMMARY OF PERFORMANCE AUDIT RESULTS (Continued)

Audit No.	Client	Industry	Audit material	RTI audit conc. (ppm)	Client audit % bias (Avg.)*	Status of audit**
47	EPA, QAD	Tire manufacturing	Propane in air Propane in air	20.8 453	-18.4 +13.4	E
48	D	Dimethyl terephthalate production	Meta-Xylene in air	487	-2.10	E
49	EPA, QAD	Instrument check-out	Toluene in N <sub>2</sub> Methanol in N <sub>2</sub>	61.5 55.2	NA NA	F
50	EPA, QAD	Tire oven manufacturing	Propane in air Propane in air Propane in air	4.9 613 718	-48.8 +16.9 +16.8	E
51	EPA, QAD	Instrument check-out	Propane in air Propane in air	20.8 316	+20.0 -9.20	E
52	D	Styrene manufacturing	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub> 1,3-Butadiene in N <sub>2</sub>	106 358 20.9	-4.90 -3.70 +23.8	E
53	I	Veg. oil manufacturing	Cyclohexane in N <sub>2</sub>	99.0	-3.50	E
54	M	Research	Chloroform in N <sub>2</sub> Chloroform in N <sub>2</sub>	16.51 531	NA NA	F
55	J		Ethylene in N <sub>2</sub>	300	+1.40	E

TABLE 2. SUMMARY OF PERFORMANCE AUDIT RESULTS (Continued)

Audit No.	Client	Industry	Audit material	RTI audit conc. (ppm)	Client audit % bias (Avg.)*	Status of audit**
56	K	Reactivity of vent activated charcoal	Chloroform in N <sub>2</sub>	8.11	NA	F
57	EPA, QAD	Instrument check-out	Hydrogen sulfide in N <sub>2</sub>	16.2	NA	F
58	C	Coil coating	Propane in N <sub>2</sub> Propane in N <sub>2</sub>	5.20 472	NA -8.40	E
59	L		Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	9.45 341	NA NA	F
60	M		Audit not initiated	--	--	--
61	EPA (State of Conn.)		Benzene in N <sub>2</sub>	132.9	NA	F
62	O		Meta-xylene in N <sub>2</sub> Hexane in N <sub>2</sub>	760 1986	NA NA	F
63	M		Methyl mercaptan in N <sub>2</sub>	4.44	NA	F
64	P		Benzene in N <sub>2</sub> Methyl ethyl ketone in N <sub>2</sub>	13.4 44.5	NA NA	F
65	E	Coke oven Byproduct Recovery	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	7.93 132	-2.90 +1.39	E

TABLE 2. SUMMARY OF PERFORMANCE AUDIT RESULTS (Continued)

Audit No.	Client	Industry	Audit material	RTI audit conc. (ppm)	Client audit % bias (Avg.)*	Status of audit**
66	D	Rubber manufacturing	Benzene in N <sub>2</sub>	12.0	+14.2	E
			Benzene in N <sub>2</sub>	10.2	0	
			Benzene in N <sub>2</sub>	100.4	+6.40	
			Benzene in N <sub>2</sub>	335	+6.00	
			Hexane in N <sub>2</sub>	79.8	+1.80	
			Hexane in N <sub>2</sub>	3076	-7.50	
			Propane in N <sub>2</sub>	9.97	-3.20	
			Propane in N <sub>2</sub>	314	-10.8	
67	E	Coke oven Byproduct Recovery	Benzene in N <sub>2</sub>	8.29	-2.20	E
			Benzene in N <sub>2</sub>	75.7	-2.50	
68	EPA, Region II		Vinyl chloride in N <sub>2</sub>	5.74	NA	F
			Vinyl chloride in N <sub>2</sub>	28.3	NA	
69	EPA, QAD	Instrument Check-out	Propylene in N <sub>2</sub>	328	-7.00	E
			Propylene in N <sub>2</sub>	725	-8.30	
70	EPA, Region I		Vinyl chloride in N <sub>2</sub>	7.5	NA	F
71	E	Degreasing vent	Trichloroethylene in N <sub>2</sub>	14.9	-0.40	E
			Trichloroethylene in N <sub>2</sub>	566	-8.70	
72	EPA, QAD	Instrument check-out	Hexane in N <sub>2</sub>	3076	NA	F
73	EPA, QAD	Combustion efficiency test	Hydrogen sulfide in N <sub>2</sub>	16.2	-7.50	E
			Methyl mercaptan in N <sub>2</sub>	8.22	-8.90	

TABLE 2. SUMMARY OF PERFORMANCE AUDIT RESULTS (Continued)

Audit No.	Client	Industry	Audit material	RTI audit conc. (ppm)	Client audit % bias (Avg.)*	Status of audit**
74	E	Vinyl chloride manufacturing	1,2-Dichloroethane in N <sub>2</sub> 1,2-Dichloroethane in N <sub>2</sub>	9.30 462	+6.00 +3.70	E
75	N	Coil coating	Propane in air Propane in air	10.01 309	NA NA	F
76	F	Coil coating	Propane in air Propane in air	10.01 309	NA NA	F
77	D	Maleic anhydride	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	9.46 66.9	-6.60 -11.7	E
78	EPA, Region VII	Instrument checkout	Benzene in N <sub>2</sub> Hexane in N <sub>2</sub>	120 30.2	NA NA	F
79	D	Maleic anhydride	Benzene in N <sub>2</sub> Benzene in N <sub>2</sub>	9.46 127.60	-4.60 +12.5	E
80	F	Plywood/veneer drying	Propylene in N <sub>2</sub> Propylene in N <sub>2</sub> Toluene in N <sub>2</sub>	14.8 328 430	-4.70 +4.40 -0.80	E
81	P	Plywood/veneer drying	Propylene in N <sub>2</sub> Propylene in N <sub>2</sub> Toluene in N <sub>2</sub>	20.3 479 487	+18.2 -22.5 +32.5	E
82	J	Polypropylene manufacturing	Propylene in N <sub>2</sub> Propane in N <sub>2</sub> Propane in N <sub>2</sub>	9.63 19.70 296	-0.35 +0.84 +0.45	E
83	I	Coke oven	Hydrogen sulfide in N <sub>2</sub> Hydrogen sulfide in N <sub>2</sub> Carbonyl sulfide	428 647 101	+4.90 -16.5 +1.98	E

TABLE 2. SUMMARY OF PERFORMANCE AUDIT RESULTS (Continued)

Audit No.	Client	Industry	Audit material	RTI audit conc. (ppm)	Client audit % bias (Avg.)*	Status of audit**
84	J	Compliance testing	Benzene in N <sub>2</sub> Hexane in N <sub>2</sub> Toluene in N <sub>2</sub> Methyl mercaptan in N <sub>2</sub>	7.45 72.6 15.0 5.40	+3.70	E
85	I	Steel manufacturing	Hydrogen sulfide in N <sub>2</sub> Carbonyl sulfide in N <sub>2</sub>	647 9.08		E
86	I	Oil shale	Hydrogen sulfide in N <sub>2</sub> Carbonyl sulfide in N <sub>2</sub> Methyl mercaptan in N <sub>2</sub>	437 117 8.42		E
87	Q	Malic Anhydride Production	Benzene in N <sub>2</sub> Hexane in N <sub>2</sub>	55.7 323.7	+528.4 +20.5	E
88	R	Refining	Hydrogen sulfide in N <sub>2</sub> Hydrogen sulfide in N <sub>2</sub>	17.5 437	21.1 22.0	E
89	Air Quality Bureau, New Mexico	Refining	Hydrogen sulfide in N <sub>2</sub>	647	NA	F
90	S	Oil shale	Carbonyl sulfide in N <sub>2</sub> Methyl mercaptan in N <sub>2</sub> Hydrogen sulfide in N <sub>2</sub>	117.4 8.42 437	-29.1 -14.8 -3.65	E
91	F	Compliance testing & demonstration	Trichlorethylene in N <sub>2</sub> Propane in N <sub>2</sub> Propane in N <sub>2</sub> Propane in N <sub>2</sub>	94.6 10.0 309 73.8	NA NA -54.0 8.7	E

TABLE 2. SUMMARY OF PERFORMANCE AUDIT RESULTS (Continued)

Audit No.	Client	Industry	Audit material	RTI audit conc. (ppm)	Client audit % bias (Avg.)*	Status of audit**
92	EPA, Region I	Research Method Development	Toluene in N <sub>2</sub>	347	NA	F
93	D	Method Validation	Hydrogen sulfide in N <sub>2</sub>	8.32	NA	F
94	USEPA, Region I	Research-Method Development	Vinylchloride in N <sub>2</sub> 1,1-dichloroethylene in N <sub>2</sub> Trichloroethylene in N <sub>2</sub> Perchloroethylene in N <sub>2</sub>	8.39 14.2 13.46 7.94	-20.2 +10.6 +55.6 +48.1	E
95	E	Acrylonitrile Production	Acrylonitrile in N <sub>2</sub> Acrylonitrile in N <sub>2</sub>	413 10.8	NA 6.94	E
96	USEPA, Region I	Resource Recovery Garbage Burning Emissions	Propane in N <sub>2</sub> Propane in N <sub>2</sub>	10.0 296	-35.0 -17.2	E
97	Tewksbury State Hospital, MA	Research-Method Development	Vinyl chloride 1,1-dichloroethylene Trichloroethylene Tetrachloroethylene	8.39 14.2 13.5 7.94	+57 -9.9 -4.4 +48.6	E
98	T	Plywood Veneer	CO <sub>2</sub> , propane, toluene CO <sub>2</sub> , propane, toluene	102 1944		A
99	U	Hazardous Materials Incineration	Trichloroethylene in N <sub>2</sub> Perchloroethylene in N <sub>2</sub> Chloroform in N <sub>2</sub>	8.91 7.94 16.5	NA NA NA	F

TABLE 2. SUMMARY OF PERFORMANCE AUDIT RESULTS (Continued)

Audit No.	Client	Industry	Audit material	RTI audit conc. (ppm)	Client audit % bias (Avg.)*	Status of audit**
100	USEPA, Region I	Research Method Development	Chlorobenzene Benzene Hexane M-xylene	9.20 127.8 30.2 6.82 (cold bulb) 2.68 (warm bulb)	NA NA NA NA	F
101	U	Hazardous Materials Incineration	Trichloroethylene in N <sub>2</sub> Perchloroethylene in N <sub>2</sub>	13.46 14.54	NA NA	F
102	Allegheny County	Source Testing	Toluene MEK Acrylonitrile MIBK (n-pentane tracer)	8.51 38.69 11.60 9.49		A
103	I	Hazardous Waste Incineration	Vinylidene chloride in N <sub>2</sub>	14.20		A
104	I	Hazardous Waste Incineration	Vinylidene chloride in	9.00		A
105	USEPA, Region VI	Plastics	Vinylchloride	8.41		A
106	USEPA, Region VI	Vinyl Chloride Manufacturing	Vinylchloride	8.44		A

NA = Not analyzed

\*Client % Bias = 100 X Client-Measured Concentration - RTI-Measured Concentration  
RTI-Measured Concentration

\*\*Status Codes:

- A = Cylinder shipped; audit results not yet received;
- B = Audit results received;
- C = Audit report submitted to EPA;
- D = Audit results received, audit report submitted to EPA, cylinder not yet returned by client;
- E = Audit complete;
- F = Audit completed without analysis of audit materials by client.

1977 - Audits 1-8	1981 - Audits 76-82
1978 - Audits 9-28	1982 - Audits 83-86
1979 - Audits 29-49	1983 - Audits 87-106
1980 - Audits 50-75	

## SECTION 4.0

### STABILITY STUDIES

An ideal calibration standard or audit material should be stable over its total time of usage. Any change or instability should be less than the measurement error tolerated during its use. The stabilities of the compounds in the repository are being estimated through periodic analysis of the cylinder contents. Improved estimates of stabilities could be determined by increasing considerably the frequency of the analyses, however, this increase is beyond the scope and financial limits of this project. The primary objective of this project is to conduct performance audits during source testing to assess the relative accuracy of the analytical results.

In this project, the gas mixtures in the repository are initially analyzed upon receipt from the specialty gas vendor to corroborate the vendor's analysis. If the RTI analysis differs from the vendor's value by more than 10 percent, the cylinder is given to a third party for analysis. The gas mixtures are again analyzed at 1 month, at 2 months, and at one year following the initial analysis. These subsequent analyses are made to determine the stability of the gas mixtures. In some cases, analyses are not performed on the dates specified above; however, every attempt is made to acquire the data on this schedule. Cylinder concentrations are also determined prior to each performance audit, providing additional data for use in stability studies.

The estimates of stability have been calculated in terms of percent change per month. These rates of change are calculated from a linear regression analysis of the concentration/time data. Stability estimates have been calculated only for cylinder contents analyzed three or more times. Two standard deviations of percentage change per month have been calculated only for cylinder contents analyzed four or more times. Attachment 1 shows the concentrations and time periods on which the calculations are based and the percent change per month for each cylinder. Sample calculations for a 100 ppm benzene cylinder are given in Attachment 2 (See Page 76).

As the number of analyses per cylinder increases, additional statistical analyses will be performed. These additional statistical analyses will include testing models other than the linear regression model. Such models are needed especially where the change is rapid at first but later becomes slow or nonexistent. The results will be presented in a final report. Statistical analysis for ten (10) halocarbons and eight (8) organics were recently published in the open literature (1,2).

Absolute accuracies of the cylinder analyses have not been determined due to lack of NBS-SRM's as standards for most gas mixtures. Recently NBS has issued SRM's for both benzene and for tetrachlorethylene and is in the process of preparing SRM's containing up to eight different organic components. The available NBS-SRM's will be used in the future to estimate the absolute accuracy. Absolute accuracy could also be estimated by performing the analyses using several different analytical methods or by having a relatively large number of laboratories perform analyses on the same cylinders; both of these approaches are beyond the financial limits of this project. An examination of the data in Attachment 1 shows values for individual cylinder analyses usually have varied by less than 10 percent for 4-8 analyses over 2-3 years. This variation indicates either a real change in cylinder contents (i.e., instability) and/or the precision of the measurement process. The possible sources of experimental error that could result in apparent changes in concentrations include (1) the variability of the analytical technique used for analysis, (2) stability of and/or accuracy of calibration standards, and (3) the ability to reproduce standards for which NBS-SRM's do not exist. Each of the above sources of variability impacts to some extent on the resulting data presented in Attachment 1.

In some cases, the cylinder contents were lost after only a few analyses. The possible reasons include leakage during storage or shipping, misuse, multiple use in audits or initial low pressure in the cylinder.

## SECTION 5.0

### SUMMARY AND CONCLUSIONS

Cylinder gases of hydrocarbons, halocarbons, and sulfur containing organic species have been used successfully as audit materials to assess the relative accuracy of gas chromatographic systems used to measure source emissions. Absolute accuracy has not been determined because of lack of standard reference materials for most gas mixtures; instead interlaboratory bias has been reported for the performance audits conducted during source testing. The interlaboratory bias determined has been generally within 10 percent for both low and high concentration gases (Table 2).

Of the 42 gaseous compounds studied or currently under study, 37 have demonstrated sufficient stability in cylinders to be used further as audit materials. Four compounds (ethylamine, paradichlorobenzene, cyclohexanone, and aniline) are not recommended as audit materials for various reasons as discussed in Attachment 1. One gaseous compound (formaldehyde) was ordered but the specialty gas manufacturer indicated that cylinder gases of this compound could not be prepared. As stated previously, the percent change per month values reported in Attachment 1 are only estimates of stability. Detailed statistical analyses which would separate statistical deviations from true concentration changes with time are in progress and will be presented in a final report.

## REFERENCES

1. R. K. M. Jayanty, C. Parker, C. E. Decker, W. F. Gutknecht, J. E. Knoll and D. J. VonLehmden, "Quality Assurance for Emissions Analysis Systems," Environmental Science and Technology, 17 (6), 257-263A (1983).
2. G. B. Howe, R. K. M. Jayanty, V. J. Rao, W. F. Gutknecht, C. E. Decker and D. J. VonLehmden, "Evaluation of Selected Gaseous Halocarbons for Use in Source Test Performance Audits," Accepted for publication in J. of Air Pollution Control Association, (in print).
3. S. K. Gangwal and D. E. Wagoner, "Response Correlation of Low Molecular Weight Sulfur Compounds Using a Novel Flame Photometric Detector," J. Chrom. Sci., 17, 196-201 (1979).

ATTACHMENT 1

Stability Data  
as of  
June 1983

- 1.0 BENZENE STABILITY STUDY
- 2.0 ETHYLENE STABILITY STUDY
- 3.0 PROPYLENE STABILITY STUDY
- 4.0 METHANE/ETHANE STABILITY STUDY
- 5.0 PROPANE STABILITY STUDY
- 6.0 TOLUENE STABILITY STUDY
- 7.0 HYDROGEN SULFIDE STABILITY STUDY
- 8.0 META-XYLENE STABILITY STUDY
- 9.0 METHYL ACETATE STABILITY STUDY
- 10.0 CHLOROFORM STABILITY STUDY
- 11.0 CARBONYL SULFIDE STABILITY STUDY
- 12.0 METHYL MERCAPTAN STABILITY STUDY
- 13.0 HEXANE STABILITY STUDY
- 14.0 1,2-DICHLOROETHANE STABILITY STUDY
- 15.0 CYCLOHEXANE STABILITY STUDY
- 16.0 METHYL ETHYL KETONE STABILITY STUDY
- 17.0 METHANOL STABILITY STUDY
- 18.0 1,2-DICHLOROPROPANE STABILITY STUDY
- 19.0 TRICHLOROETHYLENE STABILITY STUDY
- 20.0 1,1-DICHLOROETHYLENE STABILITY STUDY
- 21.0 1,2-DIBROMOETHYLENE STABILITY STUDY
- 22.0 PERCHLOROETHYLENE STABILITY STUDY

23.0 VINYL CHLORIDE STABILITY STUDY  
24.0 1,3-BUTADIENE STABILITY STUDY  
25.0 ACRYLONITRILE STABILITY STUDY  
26.0 ANILINE STABILITY STUDY  
27.0 METHYL ISOBUTYL KETONE STABILITY STUDY  
28.0 CYCLOHEXANONE STABILITY STUDY  
29.0 PARADICHLOROBENZENE STABILITY STUDY  
30.0 ETHYLAMINE STABILITY STUDY  
31.0 FORMALDEHYDE STABILITY STUDY  
32.0 METHYLENE CHLORIDE STABILITY STUDY  
33.0 CARBON TETRACHLORIDE STABILITY STUDY  
34.0 FREON 113 STABILITY STUDY  
35.0 METHYL CHLOROFORM STABILITY STUDY  
36.0 ETHYLENE OXIDE STABILITY STUDY  
37.0 PROPYLENE OXIDE STABILITY STUDY  
38.0 ALLYL CHLORIDE STABILITY STUDY  
39.0 ACROLEIN STABILITY STUDY  
40.0 CHLOROBENZENE STABILITY STUDY  
41.0 CARBON DISULFIDE STABILITY STUDY  
42.0 METHOD 25 GAS MIXTURE

**1.0 BENZENE STABILITY STUDY**

Cylinder No. Cylinder Construction*	1A AI	1B AI	1C AI	1D AI	1E S	1F S	1G S	
Manufacturer Concentration	ppm	65.4	324	200	117	61.0	71.0	80.0
	Date ppm	7/27/77 (79.0)	7/27/77 (374)	7/27/77 (241)	7/27/77 (138)	2/10/78 (62.0)	2/10/78 (71.0)	2/10/78 (80.0)
	Day ppm	136 (74.0)	136 (337)	247 (216)	29 (144)	78 (62.0)	232 (73.0)	78 (81.0)
RTI Concentration	Day ppm	156 (78.0)	156 (350)	252 (215)	157 (134)	216 (61.0)	385 (75.0)	216 (81.0)
	Day ppm	167 (80.0)	167 (355)	381 (218)	252 (129)	385 (65.0)	586 (74.5)	385 (84.0)
	Day ppm	630 (77.9)	402 (331)		290 (127)	722 (66.9)	882 (75.7)	504 (85.4)
	Day ppm	**	433 (343)		414 (127)	1337 (55.7)	1292 (65.7)	1292 (74.0)
	Day ppm		969 (358)		1247 (132)	1858 (58.7)		
	Day ppm		1274 (348)					
		1491 (324)						
		2056 (305)						
% Change/month	-0.01	-0.16	-0.87	-0.12	-0.13	-0.14	-0.17	
Two Std. Dev. of % Change/month	0.42	0.12	0.66	0.27	0.19	0.29	0.25	

\* AI = Aluminum; S = Steel; LS = Low-Pressure Steel.

\*\* Cylinder empty

ANALYTICAL CONDITIONS: Flame ionization detector, 10% OV-101 on Chromosorb W-P column at 60°.

CALIBRATION: Reagent-grade "Benzene" liquid is used as a standard. Glass-bulb dilution technique is used for making the series of standards for calibration.

## 1.0 BENZENE STABILITY STUDY (Continued)

Cylinder No.	1H	1I	1J	1K	1L	1M	1N	
Cylinder Construction***	S	S	S	S	S	S	S	
Manufacturer Concentration	ppm	100	139	232	265	296	326	344
	Date ppm	2/8/78 (101)	2/9/78 (139)	2/9/78 (229)	2/9/78 (264)	2/9/78 (295)	2/9/78 (319)	2/9/78 (332)
	Day ppm	65 (102)	49 (139)	233 (237)	49 (261)	49 (292)	49 (316)	49 (327)
RTI Concentration	Day ppm	206 (98.0)	50 (142)	386 (243)	50 (268)	51 (294)	51 (318)	54 (342)
	Day ppm	237 (101)	96 (139)	557 (225)	69 (254)	93 (298)	96 (323)	69 (335)
	Day ppm	434 (105)	127 (140)		84 (269)	205 (294)	433 (345)	809 (342)
	Day ppm	773 (106)	205 (138)			237 (302)	830 (335)	**
	Day ppm	831 (100)	505 (147)			809 (295)	1294 (320)	
	Day ppm	1294 (92.0)	1293 (128)			1294 (290)		
		1338 (128)						
% Change/month	-0.12	-0.16	-0.02	-0.04	-0.03	0.06	0.10	
Two Std. Dev. of % Change/month	0.21	0.12	0.62	2.51	0.06	0.17	0.16	

\*\*\* Al = Aluminum; S = Steel; LS = Low Pressure Steel.

\*\* Empty

1.0 BENZENE STABILITY STUDY (Continued)

Cylinder No. Cylinder Construction***	10 S	1P S	1Q S	IR S	IS S	IT S	IU S	
Manufacturer Concentration	ppm	389	8.04	9.85	9.89	9.93	10.0	10.9
	Date ppm	2/9/78 (387)	4/21/78 (8.37)	4/21/78 (9.99)	4/21/78 (10.0)	4/21/78 (10.0)	4/21/78 (10.7)	4/21/78 (11.5)
	Day ppm	64 (369)	4 (8.33)	5 (9.88)	4 (10.1)	4 (10.1)	25 (10.2)	4 (10.7)
RTI Concentration	Day ppm	205 (396)	25 (8.20)	25 (10.1)	13 (9.73)	26 (9.80)	146 (9.20)	25 (10.8)
	Day ppm	809 (396)	26 (8.34)	332 (9.71)	332 (9.77)	56 (9.50)	362 (9.90)	332 (10.7)
	Day ppm	1294 (389)	56 (8.19)		1018 (9.46)	146 (8.90)	1222 (9.56)	434 (10.9)
	Day ppm		134 (7.81)		1270 (9.64)	628 (9.57)	**	759 (10.2)
	Day ppm		434 (8.21)			738 (9.45)	1222 (9.69)	
	Day ppm		766 (7.93)			**		
			1222 (7.68)					
% Change/month	0.06	-0.16	-0.25	-0.10	-0.13	-0.15	-0.29	
Two Std. Dev. of % Change/month	0.16	0.10	0.26	0.08	0.33	0.35	0.15	

\*\*  
Cylinder empty.

\*\*\* Al = Aluminum; S = Steel; LS = Low Pressure Steel.

**1.0 BENZENE STABILITY STUDY (Continued)**

Cylinder No. Cylinder Construction***	I V S	I W S	I X S	I Y S	I Z S	I A A S	I A B A I
Manufacturer Concentration	ppm	12.2	8.09	11.0	11.2	8.09	9.14
	Date ppm	4/25/78 (12.7)	5/19/78 (8.10)	5/4/78 (11.2)	5/4/78 (10.9)	5/4/78 (8.20)	5/4/78 (9.10)
	Day ppm	1 (12.5)	105 (7.70)	132 (10.2)	132 (9.90)	132 (7.04)	132 (7.80)
RTI Concentration	Day ppm	21 (12.3)	287 (8.10)	**	302 (10.7)	302 (7.70)	302 (8.50)
	Day ppm	109 (12.0)	488 (8.20)		393 (10.8)	473 (7.54)	1005 (8.17)
	Day ppm	358 (12.1)	784 (8.30)				1209 (8.42)
	Day ppm	755 (12.0)	1194 (7.45)				
			1218 (11.7)				
% Change/month		-0.14	-0.09	-2.04	0.11	-0.27	-0.08
Two Std. Dev. of % Change/month		0.09	0.25	---	1.04	1.21	0.35
							0.11

\*\* Cylinder empty.

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

**2.0 ETHYLENE STABILITY STUDY**

Cylinder No.	2A	2B	2C	2D	2E	2F	2G
Cylinder Construction***	AI	AI	AI	AI	AI	AI	AI
Manufacturer Concentration	ppm	2920	3000	4960	4970	19900	19900
	Date	2/23/78	2/23/78	2/23/78	2/23/78	2/24/78	2/24/78
	ppm	(3066)	(3127)	(5214)	(5202)	(20438)	(20622)
RTI Concentration	Day	49	49	48	48	48	29
	ppm	(3115)	(3177)	(5341)	(5284)	(20780)	(20822)
	Day	198	198	201	201	200	106
	ppm	(2883)	(2942)	(4662)	(4913)	(20150)	(20320)
	Day	809	809	809	809	808	741
	ppm	(3203)	(3272)	(5383)	(5338)	(18906)	(18960)
	Day						1180
	ppm						(5.12)
% Change/month		0.18	0.19	0.14	0.10	-0.31	-0.32
						+0.14	
Two Std. Dev.		0.44	0.44	0.72	0.39	0.10	0.07
% of Change/month							0.22

\*\*\*  
AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame ionization detector, Durapak n-octane on Porasil C column at 30 degrees Celsius.

CALIBRATION: NBS-SRM Propane is used for standard calibration.

**2.0 ETHYLENE STABILITY STUDY (Continued)**

Cylinder No.	2H	2I	2J	2K	2L	2M	2N	
Cylinder Construction***	AI	AI	AI	AI	AI	AI	AI	
Manufacturer Concentration	ppm	10.0	15.0	19.9	300	448	603	701
	Date ppm	4/27/78 (9.7)	4/28/78 (14.4)	4/28/78 (19.2)	4/28/78 (306)	4/28/78 (468)	4/28/78 (629)	4/28/78 (740)
RTI Concentration	Day ppm	29 (9.6)	28 (14.4)	28 (19.3)	33 (319)	33 (493)	34 (646)	34 (749)
	Day ppm	106 (9.9)	104 (14.9)	104 (20.3)	105 (312)	104 (473)	104 (636)	104 (737)
	Day ppm	740 (8.4)	739 (18.0)	739 (27.5)	728 (300)	740 (457)	740 (606)	740 (703)
	Day ppm	1180 (10.0)	1179 (14.4)	1179 (18.9)				
% Change/month		-0.07	+0.18	+0.29	-0.17	-0.19	-0.20	-0.23
Two Std. Dev. of % Change/month		0.44	0.66	1.14	0.22	0.27	0.14	0.08

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

### 3.0 PROPYLENE STABILITY STUDY

Cylinder No. Cylinder Construction***	3A Al	3B Al	3C Al	3D Al	3E Al	3F Al	3G Al	3H Al	
Manufacturer Concentration	ppm	4.94	9.91	14.8	20.0	298	446	585	683
	Date ppm	4/27/78 (4.86)	4/27/78 (9.83)	4/27/78 (14.6)	4/27/78 (19.8)	4/27/78 (296)	4/27/78 (442)	4/27/78 (577)	4/27/78 (672)
	Day ppm	26 (4.94)	26 (9.85)	26 (14.5)	27 (19.0)	27 (286)	27 (428)	27 (560)	27 (655)
RTI Concentration	Day ppm	27 (4.78)	104 (10.3)	104 (14.8)	104 (20.0)	104 (317)	105 (474)	104 (629)	105 (729)
	Day ppm	104 (4.98)	749 (9.76)	749 (14.8)	749 (20.3)	750 (324)	750 (479)	750 (620)	750 (721)
	Day ppm	749 (4.93)	1250 (9.63)			820 (328)			820 (725)
% Change/month		0.05	-0.08	0.06	0.16	0.38	0.33	0.27	0.25
Two Std. Dev. of % Change/month		0.17	0.12	0.09	0.25	0.29	0.47	0.56	0.32

\*\*\*  
Al = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame Ionization detector, Durepak n-octane on Porasil C column at 30 degrees Celsius

CALIBRATION: NBS-SRM Propane is used for standard calibration.

**4.0 METHANE/ETHANE STABILITY STUDY**

Cylinder No.	4A		4B		4C		4D	
Cylinder Construction***	AI	AI	AI	AI	AI	AI	AI	AI
Audit Material****	M	E	M	E	M	E	M	E
Manufacturer Concentration	ppm	6000	714	8130	597	1000	295	1670
RTI Concentration	Date ppm	7/21/78 (6207)	7/21/78 (773)	7/21/78 (8130)	7/21/78 (654)	7/21/77 (1021)	7/21/77 (315)	7/21/77 (1710)
	Day ppm	264 (5982)	163 (715)	35 (7551)	35 (663)	264 (983)	163 (292)	35 (1563)
	Day ppm	662 (6584)	264 (684)	264 (7824)	163 (606)	1027 (1289)	264 (283)	264 (1640)
	Day ppm		662 (703)	662 (8592)	264 (577)		1027 (284)	1027 (1953)
	Day ppm				662 (598)			1027 (206)
% Change/month		0.32	-0.34	0.43	-0.43	0.90	-0.20	0.59
Two Std. Dev. of % Change/month	---		0.61	0.53	0.57	---	0.36	0.41

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

\*\*\*\* M = Methane; E = Ethane.

ANALYTICAL CONDITIONS: Flame Ionization detector, Durapak n-octane on Porasil C column at 30 degrees Celsius.

CALIBRATION: NBS-SRM methane is used for standard calibration.

5.0 PROPANE STABILITY STUDY

Cylinder No.	5A	5B	5C	5D	5E	5F	5G	5H
Cylinder Construction***	AI	AI	AI	AI	AI	AI	AI	AI
Manufacturer Concentration	ppm	5.01	10.0	14.6	20.0	303	439	604
								708
	Date ppm	4/25/78 (4.90)	4/25/78 (9.70)	4/25/78 (14.3)	4/25/78 (19.5)	4/26/78 (304)	4/26/78 (441)	4/26/78 (615)
	Day ppm	24 (4.90)	24 (9.80)	25 (14.5)	25 (19.8)	24 (301)	24 (436)	27 (615)
RTI Concentration	Day ppm	108 (5.10)	108 (10.1)	108 (14.9)	108 (20.3)	107 (305)	107 (440)	107 (607)
	Day ppm	605 (4.89)	513 (10.6)	582 (15.0)	582 (20.8)	530 (316)	530 (450)	604 (613)
	Day ppm	729 (5.20)	752 (10.0)	736 (14.7)	736 (20.1)	581 (316)	581 (453)	735 (628)
	Day ppm		914 (10.0)		1252 (19.7)	735 (313)	728 (472)	
	Day ppm					752 (314)		
	Day ppm					913 (309)		
						1251 (296)		
% Change/month	0.11	0.09	0.10	0.01	0.01	0.25	0.08	0.3
Two Std. Dev. of % Change/month	0.26	0.22	0.16	0.14	0.12	0.12	0.10	0.13

\*\*\* AI = Aluminum; S = Steel, LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame Ionization detector, Durapak n-octane on Porasil C column at 30 degrees Celsius.

CALIBRATION: NBS-SRM Propane is used for standard calibration.

5.0 PROPANE STABILITY STUDY (Continued)

Cylinder No.	5I	5J	5K	5L	
Cylinder Construction***	AI	AI	AI	AI	
Manufacturer Concentration	ppm	1000	2000	10,000	20,000
RTI Concentration	Date ppm	3/3/83 1270	3/3/83 2100	3/3/83 11,760	3/3/83 20,073
% Change/month	---	---	---	---	
Two Std. Dev. of % Change/month	---	---	---	---	

\*\*\* AI = Aluminum; S = Steel, LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame Ionization detector, Durapak n-octane on Porasil C column at 30 degrees Celsius.

CALIBRATION: NBS-SRM Propane is used for standard calibration.

### 6.0 TOLUENE STABILITY STUDY

Cylinder No.	6A	6B	6C	6D	6E	
Cylinder Construction***	LS	LS	S	S	S	
Manufacturer Concentration	ppm	408	606	16.2	9.11	
					9.00	
	Date ppm	12/6/78 (405)	12/6/78 (585)	10/3/78 (17.3)	10/3/78 (9.62)	3/29/83 (8.5)
RTI Concentration	Day ppm	3 (405)	3 (579)	48 (14.9)	64 (8.50)	
	Day ppm	86 (394)	86 (577)	365 (15.0)	66 (8.60)	
	Day ppm	100 (393)	358 (615)	1046 (8.91)	160 (8.20)	
	Day ppm	**	982 (491)		**	
	Day ppm		985 (487)	1373 (14.8)		
% Change/month		-0.29	-0.50	-0.54	-2.67	----
Two Std. Dev. of % Change/month		0.06	0.06	0.92	1.97	----

\*\* Cylinder empty.

\*\*\* AI = Aluminum, S = Steel, LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame Ionization detector, 10% OV-101 Chromosorb WHP column at 60 degrees Celsius.

CALIBRATION: Reagent grade "Toluene" liquid is used as a standard. "Glass bulb" technique is utilized for generation of series of standards for calibration.

ANALYTICAL PROBLEMS: All analyses of Cylinder No. 6B before Day 982 and of Cylinder No. 6C before Day 1046 used glass calibration bulbs at room temperature rather than bulbs which were heated to above toluene's boiling point. As a result, toluene may have condensed on the walls of the room-temperature bulbs. This may explain why the earlier concentrations are greater than those of the most recent analyses. However, actual degradation may have occurred in these cylinders.

**7.0 HYDROGEN SULFIDE STABILITY STUDY**

Cylinder No.	7A	7B	7C	7D	7E	7F	7G
Cylinder Construction***	AI	AI	AI	AI	AI	AI	AI
Manufacturer Concentration	ppm	399	9.15	16.7	649	6.95	6.45
RTI Concentration	Date ppm	10/1/78 (371)	7/7/78 (9.73)	10/1/78 (16.1)	10/1/78 (641)	10/1/78 (7.05)	10/1/78 (4.94)
	Day ppm	38 (424)	87 (6.72)	38 (16.5)	38 (655)	87 (5.75)	38 (5.14)
	Day ppm	111 (414)	124 (7.11)	111 (15.7)	111 (690)	124 (5.62)	111 (4.81)
	Day ppm	1030 (437)	197 (6.36)	580 (16.2)	1030 (647)	197 (5.23)	580 (4.35)
	Day ppm		696 (6.23)	1030 (17.5)	**	696 (5.14)	1030 (3.71)
	Day ppm		1116 (8.32)			1116 (5.38)	
% Change/month		+0.28	-0.05	+0.22	-0.05	-0.43	-0.75
Two Std. Dev. of % Change/month		0.47	1.24	0.20	0.28	0.67	0.16

\* Cylinder empty.

\*\*\* AI = Aluminum, S = Steel, LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame ionization detector, 10% OV-101 Chromosorb WHP column at 60 degrees Celsius.

CALIBRATION: Reagent grade pure "Hydrogen sulfide" gas is used as a standard. Dilutions are made in a Teflon bag for generation of series of standards for calibration.

ANALYTICAL PROBLEMS: Only a Teflon® column and Teflon® lines should be used. The air-to-hydrogen ratio is critical to the sensitivity of the FPD.

**8.0 M-XYLENE STABILITY STUDY**

Cylinder No. Cylinder Construction***	8A LS	8B LS	8C S	8D S	
Manufacturer Concentration	ppm	405	613	17.3	
RTI Concentration	Date ppm	10/5/78 (480)	10/5/78 (720)	10/5/78 (16.6)	10/5/78 (6.20)
	Day ppm	63 (445)	63 (676)	63 (17.2)	63 (6.81)
	Day ppm	158 (425)	158 (656)	166 (20.8)	166 (6.82)
	Day ppm	412 (487)	606 (760)*	302 (16.4)	948 (4.36)*
	Day ppm	606 (507)*	1040 (534)	948 (14.1)*	1036 (5.66)
	Day ppm	1040 (364)		1036 (19.0)	1596 (2.68)
% Change/month		0.35**	-1.65**	+0.24	-0.95
Two Std. Dev. of % Change/month		0.74	0.77	0.84	0.52

\* Questionable value. Not included in the calculation of % change/month.

\*\* Calculated only through Day 412 because of change in analytical procedures as described under analytical problems.

\*\*\* Al = Aluminum; S = Steel; LS = Low Pressure Steel.

CALIBRATION: Reagent grade "M-Xylene" liquid is used. "Glass bulb" technique is used for generation of series of standards for calibration.

ANALYTICAL CONDITIONS: Flame ionization detector, 10% OV-101 on Chromosorb WHP column at 60, 120 or 140 degrees Celsius.

ANALYTICAL PROBLEMS: All analyses before Day 948 used glass calibration bulbs at room temperature rather than bulbs which were heated to above meta-xylene's boiling point. As a result, meta-xylene may have condensed on the walls of the room-temperature bulbs. This may explain why the RTI concentration for cylinder Nos. 8A and 8B before day 1040 are greater than those for the analysis on Day 1040.

**9.0 METHYL ACETATE STABILITY STUDY**

Cylinder No.	9A	9B	9C	9D	
Cylinder Construction***	S	S	S	S	
Manufacturer Concentration	326	455	6.84	17.2	
RTI Concentration	Date ppm	10/13/78 (271)	10/13/78 (428)	10/13/78 (5.29)	10/13/78 (12.9)
	Day ppm	230 (340)	230 (437)	230 (4.86)	230 (12.5)
	Day ppm	286 (324)	286 (442)	286 (5.02)	286 (11.8)
	Day ppm	629 (348)	629 (479)	630 (5.88)	630 (12.5)
% Change/month	1.15	0.60	0.68	-0.13	
Two Std. Dev. of % Change/month	1.08	0.21	1.13	0.56	

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame ionization detector, 10% OV-275 on Chromosorb WHP column at 50 degrees Celsius.

CALIBRATION: Reagent grade "Methyl acetate" liquid is used as a standard. "Glass bulb" technique is utilized for generation of series of standards for calibration.

**10.0 CHLOROFORM STABILITY STUDY**

Cylinder No. Cylinder Construction***	10A S	10B S	10C S	10D S	
Manufacturer Concentration	ppm	520	348	8.70	16.9
	Date ppm	10/17/78 (529)	10/17/78 (345)	10/17/78 (8.08)	10/17/78 (17.6)
RTI Concentration	Day ppm	161 (515)	161 (351)	161 (7.39)	161 (16.5)
	Day ppm	256 (514)	256 (340)	256 (7.50)	256 (16.2)
	Day ppm	553 (531)	975 (325)	553 (8.11)	553 (16.5)
.					
% Change/month		0.06	-0.20	0.14	-0.29
Two Std. Dev. of % Change/month		0.31	0.12	0.88	0.51

\*\*\* Al = Aluminum; S = Steel; LS = Low Pressure.

**ANALYTICAL CONDITIONS:** Flame ionization detector, 10% OV-101 on Chromosorb WHP column at 50 or 100 degrees Celsius.

**CALIBRATION:** Reagent grade "Chloroform" liquid is used as a standard. "Glass bulb" technique is utilized for generation of series of standards for calibration .

11.0 CARBONYL SULFIDE STABILITY STUDY

Cylinder No.		11A	11B	11C	11D	11E	11F
Cylinder Construction***	S	S	S	S	AL	AL	
Manufacturer Concentration	ppm	251	100	9.96	7.03	9.54	101
	Date ppm	11/3/78 (276)	11/3/78 (109)	11/3/78 (9.10)	11/3/78 (6.81)	9/18/81 (12.9)	9/18/81 (111)
RTI Concentration	Day ppm	78 (281)	78 (111)	78 (8.66)	78 (6.48)		
	Day ppm	185 (275)	185 (95)	185 (8.23)	185 (6.41)		
	*	*	*	*	*		
% Change/month		-0.09	-2.13	-1.55	-0.92	**	**
Two Std. Dev. of % Change/month		---	---	---	---	---	---

\* Cylinder empty.

\*\* Calculations for % change/month are only done when three or more analyses are available.

\*\*\* Al = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame photometric detector, Carbopak B column at 50 degrees Celsius or Chromosil 330 column at 60 degrees Celsius.

CALIBRATION: Reagent grade pure "Carbonyl Sulfide" gas is used as a standard. Dilutions are made in Teflon® bag for generation of series of standards for calibration.

ANALYTICAL PROBLEMS: Only a Teflon column and Teflon lines should be used. The air-to-hydrogen ratio is critical to the sensitivity of the FPD.

**12.0 METHYL MERCAPTAN STABILITY STUDY**

Cylinder No.	I2A	I2B	I2C	I2D	
Cylinder Construction***	AI	AI	AI	AI	
Manufacturer Concentration	ppm	8.03	10.0	3.55	4.22
	Date ppm	1/24/79 (5.66)	1/24/79 (7.94)	1/24/79 (3.65)	1/24/79 (4.23)
RTI Concentration	Day ppm	104 (5.60)	104 (8.10)	104 (3.50)	104 (4.76)
	Day ppm	139 (5.65)	139 (7.90)	139 (3.56)	139 (4.54)
		985 (5.40)	985 (8.42)	985 (3.64)	*
% Change/month		-0.14	0.18	0.05	2.04
Two Std. Dev. of % Change/month		0.04	0.10	0.17	---

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

\* Empty

**ANALYTICAL CONDITIONS:** Flame photometric detector, CarboPak B column at 50 degrees Celsius or Chromosil 330 column at 60 degrees Celsius.

**CALIBRATION:** Reagent grade pure "Methyl mercaptan" gas is used a standard. Dilutions are made in a Teflon® bag for generation of series of standards for calibration.

**ANALYTICAL PROBLEMS:** Only a Teflon column and Teflon lines should be used. The air-to-hydrogen ratio is a critical variable.

13.0 HEXANE STABILITY STUDY

Cylinder No. Cylinder Construction***	13A LS	13B LS	13C AI	13D AI	13E AI
Manufacturer Concentration	ppm	1975	2973	30.6	79.2
RTI Concentration	Date ppm	2/6/79 (2170)	2/6/79 (3070)	2/6/79 (30.8)	2/6/79 (82.2)
	Day ppm	6 (1982)	6 (2855)	296 (30.1)	296 (81.0)
	Day ppm	337 (2069)	338 (2946)	337 (30.6)	337 (81.3)
	Day ppm	469 (1986)	469 (3076)	469 (32.0)	469 (79.8)
	Day ppm			523 (30.0)	835 (80.2)
	Day ppm			835 (30.2)	12.47 (82.7)
% Change/month		-0.22	0.16	-0.05	-0.01
Two Std. Dev. of % Change/month		0.69	0.60	0.26	0.09

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame Ionization detector, 10% OV-101 on Chromosorb WHP column at 60 or 100 degrees Celsius.

CALIBRATION: Reagent grade "Hexane" liquid is used as a standard. "Glass bulb" technique is utilized for making series of standards for calibration.

**14.0 1,2 DICHLOROETHANE (ETHYLENE DICHLORIDE) STABILITY STUDY**

Cylinder No.	14A	14B	14C	14D	14E	14F	14G	14H
Cylinder Construction***	AI	AI	AI	AI	AI	AI	AI	AI
Manufacturer Concentration	ppm	14.4	9.64	100	526	6.92	12.5	97.9
RTI Concentration	Date ppm	1/19/79 (14.1)	1/19/79 (9.20)	1/19/79 (96.2)	1/19/79 (498)	4/5/79 (10.0)	4/5/79 (15.2)	4/5/79 (102)
	Day ppm	58 (15.2)	58 (10.8)	58 (103)	58 (534)	30 (9.42)	30 (14.7)	30 (105)
	Day ppm	155 (14.9)	155 (10.0)	155 (98.2)	155 (524)	69 (9.30)	69 (14.3)	69 (99.0)
	Day ppm	811 (14.2)	811 (9.56)	501 (87.3)	501 (592)	586 (9.14)	811 (14.5)	425 (87.3)
	Day ppm	835 (13.5)	835 (9.19)	920 (102)	920 (502)	811 (9.70)	835 (13.8)	844 (101)
	Day ppm					835 (9.16)		844 (453)
% Change/month	-0.22	-0.23	-0.01	+0.04	-0.09	-0.16	-0.18	-0.10
Two Std. Dev. of % Change/month	0.28	0.50	0.58	0.64	0.25	0.21	0.62	0.16

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame ionization detector, 10% OV-101 on Chromosorb WHP column at 100 degrees Celsius.

CALIBRATION: Reagent grade "1,2 Dichloroethane" liquid is used as a standard. "Glass bulb" technique is utilized for making series of standards for calibration.

## 15.0 CYCLOHEXANE STABILITY STUDY

Cylinder No.	15A
Cylinder Construction***	Al
Manufacturer	ppm
Concentration	99.1
RTI	Date
Concentration	ppm
	3/19/79
	(106)
	Day
	ppm
	147
	(93.4)
	Day
	ppm
	394
	(99.0)
	926
	(102)
% Change/month	0.02
Two Std. Dev.	0.55
of % Change/month	

\*\*\*

AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame Ionization detector, 10% OV-101 on Chromosorb WHP column at 100 degrees Celsius.

CALIBRATION: Reagent grade "Cyclohexane" liquid is used as a standard. "Glass bulb" technique is used for making series of standards for calibration.

## 16.0 METHYL ETHYL KETONE STABILITY STUDY

---

Cylinder No.  
Cylinder Construction\*\*\*

---

16A  
S

---

Manufacturer      ppm      43.7  
Concentration

---

RTI              Day      5/23/79  
Concentration      ppm      (42.3)

RTI              Day      28  
Concentration      ppm      (40.0)

Day              Day      58  
ppm              ppm      (39.9)

Day              Day      380  
ppm              ppm      (44.5)

Day              Day      653  
ppm              ppm      (38.7)

---

% Change/month      -0.08

---

Two Std. Dev.  
of % Change/month      0.67

---

\*\*\*  
AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame ionization detector, Chromosorb 101 column at 180 degrees Celsius.

CALIBRATION: Reagent grade "Methyl ethyl ketone" liquid is used as a standard. "Glass bulb" technique is utilized for making series of standards for calibration.

## 17.0 METHANOL STABILITY STUDY

Cylinder No.	17A
Cylinder Construction***	AI
Manufacturer	ppm
Concentration	50.0
RTI	Date
Concentration	ppm
	5/17/79
	(58.8)
	Day
	ppm
	21
	(52.3)
	Day
	ppm
	51
	(51.1)
	Day
	ppm
	196
	(55.2)
% Change/month	-1.03
Two Std. Dev.	3.01
of % Change/month	

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame Ionization detector, Chromosorb 101 column at 50 degrees Celsius or 0.2% Carbowax 1500 plus 0.1% SP-2100 on Carbowax C at 60 degrees Celsius.

CALIBRATION: Reagent grade "Methanol" is used as a standard. "Glass bulb" dilution technique is utilized for making series of standards for calibration.

18.0 1,2-DICHLOROPROPANE (PROPYLENE DICHLORIDE) STABILITY STUDY

Cylinder No.		18A	18B	18C	18D
Cylinder Construction***		AI	AI	AI	AI
Manufacturer Concentration	ppm	7.07	14.6	476	664
	Date	7/10/79	7/10/79	7/10/79	7/10/79
	ppm	(6.06)	(15.6)	(496)	(685)
RTI Concentration	Day	28	28	28	28
	ppm	(5.52)	(16.4)	(455)	(621)
	Day	48	48	48	48
	ppm	(5.94)	(15.0)	(480)	(675)
	Day	497	749	372	372
	ppm	(6.03)	(16.3)	(497)	(685)
	Day	749			
	ppm	(5.59)			
% Change/month		-0.09	+0.16	+0.33	+0.30
Two Std. Dev. of % Change/month		0.43	0.43	0.89	1.05

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame ionization detector, 10% OV-101 on Chromosorb WHP column at 100 degrees Celsius.

CALIBRATION: Reagent grade "1,2-Dichloropropane" liquid is used as a standard. "Glass bulb" dilution technique is utilized for making series of standards for calibration.

**19.0 TRICHLOROETHYLENE STABILITY STUDY**

Cylinder No.	19A	19B	19C	19D	
Cylinder Construction***	AI	AI	AI	AI	
Manufacturer Concentration	ppm	9.23	14.7	100	505
	Date ppm	5/24/79 (9.58)	5/24/79 (14.3)	5/24/79 (102)	5/24/79 (506)
RTI Concentration	Day ppm	77 (10.2)	77 (15.1)	77 (103)	77 (503)
	Day ppm	92 (9.78)	92 (14.9)	92 (100)	92 (499)
	Day ppm	683 (9.03)	683 (13.6)	810 (105)	810 (522)
		820 (8.91)	820 (13.5)	820 (94.6)	820 (490)
% Change/month		-0.37	-0.33	-0.08	0.02
Two Std. Dev. of % Change/month		0.23	0.21	0.31	0.19

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

**ANALYTICAL CONDITIONS:** Flame Ionization detector, 10% OV-101 on Chromosorb WHP column at 100 degrees Celsius.

**CALIBRATION:** Reagent grade "Trichloroethylene" liquid is used as a standard. "Glass bulb" technique is used for making series of standards for calibration.

20.0 1,1-DICHLOROETHYLENE (VINYLDENE CHLORIDE) STABILITY STUDY

Cylinder No.		20A	20B	20C	20D
Cylinder Construction***		AI	AI	AI	AI
Manufacturer Concentration	ppm	9.58	14.8	96.8	490
	Date	6/1/79	6/1/79	6/1/79	6/1/79
	ppm	(10.3)	(15.6)	(101)	(524)
RTI Concentration	Day	35	35	35	35
	ppm	(9.90)	(15.1)	(99)	(510)
	Day	62	62	62	62
	ppm	(10.1)	(15.5)	(102)	(505)
	Day	404	404	817	404
	ppm	(11.5)	(17.1)	(94)	(498)
		818	818		
		(9.0)	(14.2)		
% Change/month		-0.25	-0.17	+0.40	-0.26
Two Std. Dev. of % Change/month		0.81	0.63	0.14	0.31

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame ionization detector, 10% OV-101 on Chromosorb WHP column at 100 degrees Celsius or 10% SP-2100 on Supelcoport column at 100 degrees Celsius.

CALIBRATION: Reagent grade "1,1-Dichloroethylene" pure liquid is used as a standard. "Glass bulb" dilution technique is utilized for making series of standards for calibration.

21.0 1,2-DIBROMOETHYLENE (ETHYLENE DIBROMIDE) STABILITY STUDY

Cylinder No. Cylinder Construction***	21A LS	21B LS	21C LS	21D LS	
Manufacturer Concentration	ppm	10.0	14.9	99.9	301
	Date ppm	6/18/79 (7.90)	6/18/79 (12.2)	6/1/79 (110)	6/18/79 (265)
RTI Concentration	Day ppm	61 (7.80)	61 (12.0)	61 (107)	61 (266)
	Day ppm	89 (7.40)	89 (11.6)	89 (105)	89 (257)
	Day ppm	722 (7.72)	772 (8.02)	787 (99.2)	643 (309)
% Change/month		-1.90*	-1.53*	-1.52*	-0.83*
Two Std. Dev. of % Change/month		0.35	0.10	0.17	0.29

\* % change/month is calculated for only the first three analyses and are approximate because of change in calculation procedure as described below in the analytical problems.

\*\*\* Al = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame ionization detector, 10% OV-101 on Chromosorb WHP column at 100 degrees Celsius.

CALIBRATION: Reagent grade "1,2-Dibromoethylene" pure liquid is used as a standard. "Glass bulb" dilution techniques is utilized for making series of standards for calibration.

ANALYTICAL PROBLEMS: The gas mixtures and the calibration standards contain substantial amounts of both the cis and the trans isomers of 1,2-Dibromoethylene. The first three sets of analyses are questionable because only one isomer was measured during the calibrations and cylinder analyses.

**22.0 PERCHLOROETHYLENE STABILITY STUDY**

Cylinder No.		22A	22B	22C	22D
Cylinder Construction***		S	S	LS	LS
Manufacturer	ppm	7.98	13.0	487	629
Concentration					
RTI	Date	7/6/79 (8.40)	7/6/79 (15.0)	7/6/79 (419)	7/6/79 (624)
Concentration	Day	35	35	35	35
	ppm	(7.97)	(14.9)	(453)	(642)
	Day	52	52	52	52
	ppm	(7.92)	(14.7)	(440)	(619)
	Day	376	376	677	677
	ppm	(7.94)	(14.5)	(361)	(542)
			713 (387)	713 (571)	
% Change/month		-0.22	-0.23	-0.63	-0.51
Two Std. Dev.		0.61	0.17	0.37	0.22
of % Change/month					

\*\*\* Al = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame Ionization detector, 10% OV-101 on Chromosorb WHP column at 50 or 100 degrees Celsius.

CALIBRATION: Reagent grade "Perchloroethylene" liquid is used as a standard. "Glass bulb" dilution technique is utilized for making series of standards for calibration.

## 23.0 VINYL CHLORIDE STABILITY STUDY

Cylinder No. Cylinder Construction***	23A S	23B S	23C S	23D S	23E S	23F S	23G S	23H S	23I S	
Manufacturer Concentration	ppm	5.94	8.00	8.03	8.52	20.0	20.1	30.0	30.3	7.98
RTI Concentration	Date ppm	10/1/79 (5.87)	10/1/79 (7.71)	10/1/79 (7.82)	10/1/79 (7.85)	10/1/79 (19.7)	10/1/79 (20.1)	10/1/79 (29.6)	10/1/79 (29.8)	10/1/79 (7.31)
		18 (5.74)	18 (7.50)	18 (7.45)	18 (7.61)	18 (19.1)	18 (19.3)	18 (28.3)	18 (28.7)	18 (7.12)
		700 (6.60)		700 (8.44)	700 (8.41)	700 (20.7)	700 (20.9)	700 (20.4)	700 (29.4)	700 (8.39)
% Change/month		0.59	**	0.45	0.38	0.29	0.25	0.21	0.01	0.71

\*\* Calculations for % change/month are only done when three or more analyses are available.

\*\*\* Al = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame Ionization detector, 0.4% Carbowax 1500 on Carbopak C at 50 degrees Celsius.

CALIBRATION: Vinyl chloride permeation tube purchased from Metronics is used for calibration. Permeation tube is maintained at 30°C.

24.0 1,3 BUTADIENE STABILITY STUDY

---

Cylinder No.	24A
Cylinder Construction***	S

---

Manufacturer	ppm	22.6
Concentration		

---

RTI Concentration	Date ppm	3/21/80 (20.9)
	Date ppm	95 (23.1)
	Day ppm	480 (24.0)

---

% Change/month	+0.73
----------------	-------

---

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame Ionization detector, 0.1% SP-1000 on Carbopek C column at 90 degrees Celsius or 10% OV-101 on Chromosorb WHP column at 60 degrees Celsius.

CALIBRATION: Reagent grade "1,3 Butadiene" liquid is used as a standard. "Glass bulb" dilution technique is utilized for making series of standards for calibration.

## 25.0 ACRYLONITRILE STABILITY STUDY

Cylinder No.	25A	25B	25C	25D	25E	25F
Cylinder Construction***	LS	LS	LS	LS	AL	AL
Manufacturer Concentration	ppm	20.1	348	11.7	638	-
Date	7/24/79 ppm	185 (14.6)	185 (411)	185 (6.38)	185 (678)	11/8/82 (413) 11/18/82 (10.8)
RTI Concentration	Day ppm	(12.7)	(416)	(3.35)	(699)	134 (410) 139 (15.7)
	Day ppm	349 (13.2)	349 (441)	349 (2.87)	349 (703)	
	Day ppm	841 (9.96)	841 (397)	841 (4.05)	841 (667)	
% Change/month		-1.07	-0.14	-1.12	-0.10	----
Two Std. Dev. of % Change/month		0.46	0.47	3.49	0.26	----

\*\*\* Al = Aluminum; S = Steel; LS= Low Pressure Steel

ANALYTICAL CONDITIONS: Flame ionization detector, 4% Carbowax 20M on Carbopak B at 50 or 150 degrees Celsius.

CALIBRATION: Acrylonitrile permeation tube is used for GC-FID calibration. Permeation tube is maintained at  $30^{\circ} \pm 0.1^{\circ}\text{C}$ .

ANALYTICAL PROBLEMS: The large changes noted at the low concentration levels are, at least in part, a result of difficulty in making precise measurements at these levels.

## 26.0 ANILINE STABILITY STUDY

Cylinder No.	26A	26B
Cylinder Construction***	AI	AI
Manufacturer ppm	11.3	18.4

RTI Analysis See Analytical Problems

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel

ANALYTICAL CONDITIONS: Flame ionization detector, 10% OV-101 on Chromosorb WHP column at 250 degrees Celsius.

CALIBRATION: Reagent grade "Aniline" pure liquid is used as a standard. "Glass bulb" dilution technique is utilized for making series of standards for calibration.

ANALYTICAL PROBLEMS: Because aniline has an extremely high boiling point (186°C), special handling would be required to measure this compound. A completely heated system for sampling in the vapor phase and for preparing standards would be required. Temperature-dependent condensation in the cylinder and the regulator causes the amount of aniline which is delivered by the cylinder to vary. As a result, aniline is not considered to be practical as an audit material.

**27.0 METHYL ISOBUTYL KETONE STABILITY STUDY**

<b>Cylinder No.</b>		<b>27A</b>	<b>27C</b>
<b>Cylinder Construction***</b>		Al	Al
<b>Manufacturer</b>	<b>ppm</b>	<b>9.51</b>	<b>72.9</b>
<b>Concentration</b>			
	<b>Date</b>	<b>12/18/80</b>	<b>7/8/81</b>
	<b>ppm</b>	<b>(10.2)</b>	<b>(75.4)</b>
<b>RTI</b>	<b>Day</b>	<b>27</b>	<b>See Analytical</b>
<b>Concentration</b>	<b>ppm</b>	<b>(10.6)</b>	<b>Problems</b>
	<b>Day</b>	<b>83</b>	
	<b>ppm</b>	<b>(9.53)</b>	
	<b>Day</b>	<b>202</b>	
	<b>ppm</b>	<b>(9.49)</b>	
<b>% Change/month</b>		<b>-1.40</b>	<b>**</b>
<b>Two Std. Dev.</b>		<b>1.58</b>	
<b>of % Change/month</b>			

\*\* Calculations for % change/month are only done when three or more analyses are available.

\*\*\* Al = Aluminum; S = Steel; LS = Low Pressure Steel

**ANALYTICAL CONDITIONS:** Flame ionization detector, 0.1% SP-1000 on CarboPak C column at 180° degrees Celsius.

**CALIBRATION:** Reagent grade "Methyl Isobutyl ketone" liquid is used as a standard. "Glass bulb" technique is utilized for making series of standards for calibration.

**ANALYTICAL PROBLEMS:** Methyl Isobutyl ketone at high concentrations is not practical as an audit material because pressurization of the cylinder above approximately 200 psi results in condensation of the analyte.

28.0 CYCLOHEXANONE STABILITY STUDY

Cylinder No.		28A	28B
Cylinder Construction***		AI	AI
Manufacturer Concentration	ppm	10.1	19.0
RTI Analysis	Date ppm	12/11/80 (8.19)	12/11/80 (25.5)
	Day ppm	85 (3.26)	85 (17.1)
% Change/month		**	**

\*\* Calculations for % change/month are only done when three or more analyses are available.

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel

ANALYTICAL CONDITIONS: Flame Ionization detector, 10% SP-1000 on Supelcoport column at 200 degrees Celsius.

CALIBRATION: Reagent grade "Cyclohexanone" liquid is used as a standard. "Glass bulb" technique is used for making series of standards for calibration.

ANALYTICAL PROBLEMS: The analysis of cyclohexanone gas is dependent on the temperatures of the cylinder and the regulator and on the length of the sampling line between the regulator and the gas chromatograph. The concentration in the cylinder decreases with time. Therefore, cyclohexanone is not practical as an audit material.

## 29.0 PARADICHLOROBENZENE STABILITY STUDY

Cylinder No.	29A	29B
Cylinder Construction***	S	S
Manufacturer	ppm	15.6
Concentration		38.1
RTI Analysis	See Analytical Problems	

\*\*\*  
AI = Aluminum; S = Steel; LS = Low Pressure Steel

ANALYTICAL CONDITIONS: Flame ionization detector, 10% SP-1000 on Supelcoport column at 200 degrees Celsius.

CALIBRATION: Reagent grade "Paradichlorobenzene" is used as a standard. "Glass bulb" technique is used for making series of standards for calibration.

ANALYTICAL PROBLEMS: The stability study for this compound was terminated because of analytical difficulties and because the cylinder pressure was less than 200 psig. Paradichlorobenzene is a solid at room temperature with a melting point of 54°C. Condensation in the cylinder, regulator and sampling lines was extreme. Paradichlorobenzene is not practical as an audit material.

### 30.0 ETHYLAMINE STABILITY STUDY

Cylinder No.		30A	30B
Cylinder Construction***		S	S
Manufacturer	ppm	10	20
Concentration			
RTI Analysis		See Analytical Problems	

\*\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel

ANALYTICAL CONDITIONS: Flame Ionization detector, 10% OV-101 Chromosorb WHP column at 250 degrees Celsius.

CALIBRATION: Reagent grade "Ethylamine" liquid is used as a standard. "Glass bulb" technique is utilized for making series of standards for calibration.

ANALYTICAL PROBLEMS: Because of vapor pressure considerations, the cylinders could not be fully pressurized. The pressure in the cylinder is less than 200 psi. A completely heated system for sampling in the vapor phase and for preparing standards would be required. Temperature-dependent condensation in the cylinder and the regulator causes the amount of ethylamine which is delivered by the cylinder to vary. As a result of these problems, ethylamine is not considered to be practical as an audit material.

31.0 FORMALDEHYDE STABILITY STUDY

---

RTI Requested Concentration	ppm	10	20
-----------------------------------	-----	----	----

---

The speciality gas supplier indicated that they could not make gas mixtures containing formaldehyde.

**32.0 METHYLENE CHLORIDE STABILITY STUDY**

Cylinder No.	32A	
Cylinder Construction*	AI	
Manufacturer Concentration	ppm	10.2
RTI Concentration	Date ppm	3/5/82 (10.8)
	Day ppm	31 (10.8)
	Day ppm	70 (10.6)
	Day ppm	96 (11.2)
	Day ppm	124 (11.4)
	Day ppm	160 (10.9)
	Day ppm	277 (10.2)
	Day ppm	278 (10.2)
	Day ppm	278 (9.8)
	Day ppm	381 (9.7)
% Change/month	-0.94	
Two Std. Dev. of % Change/Month	0.53	

\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame Ionization detector, 20 ft. x 1/8" SS column packed with 10% SP-1000 on 80/100 Supelcoport. 30 cm<sup>3</sup>/minute He carrier gas. Column temp. = 100°C. Detector temp. = 175°C.

CALIBRATION: Reagent grade "Methylene chloride" liquid is used as a standard. "Glass bulb" technique is utilized for making series of standards for calibration.

33.0 CARBON TETRACHLORIDE STABILITY STUDY

Cylinder No.		33A
Cylinder Construction*		AL
Manufacturer Concentration	ppm	11.3
RTI Concentration	Date ppm	3/4/82 (12.7)
	Day ppm	74 (11.7)
	Day ppm	74 (10.2)
	Day ppm	98 (11.1)
	Day ppm	124 (10.6)
	Day ppm	161 (10.2)
	Day ppm	279 (9.3)
	Day ppm	279 (9.4)
	Day ppm	382 (10.5)
% Change/Month		-1.57
Two Std. Dev. of % Change/Month		1.21

\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame ionization detector, 20 ft. x 1/8" SS column packed with 10% SP-1000 on 80/1000 Supelcoport. 30 cm<sup>3</sup>/minute He carrier gas. Column temp. = 100°C. Detector temp. = 175°C.

CALIBRATION: Reagent grade "Carbon tetrachloride" liquid is used as a standard. "Glass bulb" dilution technique is utilized for making series of standards for calibration.

34.0 FREON 113 STABILITY STUDY

Cylinder No.		34A
Cylinder Construction*		AI
Manufacturer	ppm	10.4
Concentration		
RTI Concentration	Date ppm	3/3/82 (10.8)
	Day ppm	34 (10.1)
	Day ppm	70 (10.0)
	Day ppm	70 (9.6)
	Day ppm	98 (10.0)
	Day ppm	125 (10.0)
	Day ppm	162 (10.3)
	Day ppm	384 (9.8)
% Change/month		-0.37
Two Std. Dev. of % Change/Month		0.66

\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame Ionization detector, 20 ft. x 1/8" SS column packed with 10% SP-1000 on 80/100 Supelcoport. 30 cm<sup>3</sup>/minute He carrier gas. Column temp. = 100°C. Detector temp. ~ 175°C.

CALIBRATION: Reagent grade "Freon 113" liquid is used as a standard. "Glass bulb" dilution technique is utilized for making series of standards for calibration.

35.0 METHYL CHLOROFORM STABILITY STUDY

Cylinder No.		35A
Cylinder Construction*		Al
Manufacturer	ppm	10.2
Concentration		
RTI Concentration	Date ppm	3/2/82 (10.3)
	Day ppm	70 (11.8)
	Day ppm	99 (10.7)
	Day ppm	136 (10.6)
	Day ppm	161 (10.0)
	Day ppm	381 (10.4)
% Change/Month		-0.35
Two Std. Dev. of % Change/Month		1.28

\* Al = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame ionization detector, 20 ft. x 1/8" SS column packed with 10% SP-1000 on 80/100 Supelcoport.  
<sup>3</sup> 30 cm/min He carrier gas. Column temp. = 100°C.  
 Detector temp. = 175°C.

CALIBRATION: Reagent grade "Methyl chloroform" is used as a standard. "Glass bulb" dilution technique is utilized for making series of standards for calibration.

### 36.0 ETHYLENE OXIDE STABILITY STUDY

Cylinder No.	36A	
Cylinder Construction*	AI	
Manufacturer Concentration	ppm	10.0
RTI Concentration	Date ppm	3/12/82 (11.2)
	Day ppm	73 (9.60)
	Day ppm	88 (9.80)
	Day ppm	157 (9.8)
	Day ppm	122 (9.6)
% Change/month		-2.54
Two Std. Dev. of % Change/Month		2.24

\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame Ionization detector, 6 ft. x 1/8" SS column packed with 80/100 mesh Porepak QS. 30 cm<sup>3</sup>/minute Helium carrier gas. Column temp. = 150°C. Detector temp. = 175°C.

CALIBRATION: Ethylene oxide permeation tube purchased from Metronics is used for GC-FID calibration. Permeation tube is maintained at 30°C.

ANALYTICAL PROBLEMS: There appeared to be some loss of ethylene oxide when a brass regulator was used on the cylinder.

**37.0 PROPYLENE OXIDE STABILITY STUDY**

Cylinder No.		37A	37B
Cylinder Construction*		Al	Al
Manufacturer	ppm	9.48	96.0
Concentration			
RTI	Date	8/4/82	8/4/82
Concentration	ppm	(12.3)	(89.5)
	Date	55	55
	ppm	(11.8)	(86.9)
	Date	76	76
	ppm	(10.6)	(83.6)
	Date		121
	ppm		(90.8)
% Change/Month		----	0.09
Two Std. Dev.		----	
of % Change/Month			3.06

\* Al = Aluminum; S = Steel; LS = Low Pressure Steel.

**ANALYTICAL CONDITIONS:** Flame Ionization detector, 6 ft. X 1/8" SS column packed with 80/100 mesh Porapak QS. 30 cm<sup>3</sup>/min Helium carrier gas. Column temp. = 150°C. Detector temp. = 175°C.

**CALIBRATION:** Reagent grade "propylene oxide" is used as a standard. "Glass bulb" dilution technique is utilized for making series of standards for calibration.

**38.0 ALLYL CHLORIDE STABILITY STUDY**

Cylinder No.		38A	38B
Cylinder Construction*		S	S
Manufacturer	ppm	10.2	99.5
Concentration			
RTI	Date	8/13/82**	8/13/82**
Concentration	ppm	(11.6)	(124)
Day	75	74	
ppm	(5.25)	(87.2)	
Day	110	110	
ppm	(5.08)	(87.7)	
Day	167	167	
ppm	(5.36)	(83.4)	
% Change/Month		+0.92	-1.45
Two Std. Dev. of			
% Change/Month		3.10	1.58

\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

\*\* Initial analysis was discarded.

ANALYTICAL CONDITIONS: Flame Ionization detector, 20 ft. X 1/8" SS column packed with 10 % SP-1000 Supelcoport. 30 cm<sup>3</sup>/minute Helium carrier gas. Column temp. = 100°C. Detector temp. = 175°C,

CALIBRATION: Reagent grade "Allyl chloride" is used as a standard. "Glass bulb" dilution technique is utilized for making series of standards for calibration.

**39.0 ACROLEIN STABILITY STUDY**

<b>Cylinder No.</b>		<b>39A</b>	<b>39B</b>
<b>Cylinder Construction*</b>		<b>AI</b>	<b>AI</b>
<b>Requested Concentration</b>	<b>ppm</b>	<b>10.2</b>	<b>107</b>
<b>RTI Concentration</b>	<b>Date ppm</b>	<b>8/18/82 (10.6)</b>	<b>8/18/82 (90.4)</b>
	<b>Day ppm</b>	<b>28 (11.0)</b>	<b>28 (103)</b>
	<b>Day ppm</b>	<b>69 (9.74)</b>	<b>69 (106)</b>
<b>% Change/Month</b>		<b>-3.80</b>	<b>6.94</b>
<b>Two Std. Dev. of % Change/Month</b>		<b>6.82</b>	<b>6.70</b>

\*

AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame ionization detector, 20 ft. X 1/8" SS column packed with 10 % SP-1000 on 80/100 Supelcoport. 30 cm<sup>3</sup>/min Helium carrier gas. Column temp = 100°C. Detector temp. = 175°C.

CALIBRATION: Reagent grade "acrolein" is used as a standard. "Glass bulb" dilution technique is utilized for making series of standards for calibration.

40.0 CHLOROBENZENE STABILITY STUDY

Cylinder No.		40A
Cylinder Construction*		AI
Manufacturer	ppm	9.66
Concentration		
RTI	Date	8/6/82
Concentration	ppm	(9.03)
	Day	39
	ppm	(9.15)
	Day	75
	ppm	(9.20)
% Change/Month		0.76
Two Std. Dev. of		
% Change/Month		0.32

\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame ionization detection, 20' X 1/8" stainless steel column packed with 10% SP-1000 on 80/100 mesh Supelcoport. 30 cc/min Helium carrier gas. Column temp. = 150°C. Detector temp = 175°C.

CALIBRATION: Reagent grade chlorobenzene was used as a standard. "Glass bulb" dilution technique is utilized for making a series of standards.

#### 41.0 CARBON DISULFIDE STABILITY STUDY

Cylinder No.	41A	
Cylinder Construction*	AI	
Manufacturer	ppm	108
Concentration		
RTI	Date	7/14/82
Concentration	ppm	(100)
	Day	34
	ppm	(114)
	Day	72
	ppm	(116)
% Change/Month	6.42	
Two Std. Dev. of		
% Change/Month	6.06	

\* AI = Aluminum; S = Steel; LS = Low Pressure Steel.

ANALYTICAL CONDITIONS: Flame photometric detector, 4.6" X 1/4" Teflon® column packed with Carbpak BHT 100. 90 cc/min Helium carrier gas. Column temp. = 75°C. Detector temp. = 175°C.

CALIBRATION: Reagent grade carbon disulfide is injected into a Teflon® bag being filled with N<sub>2</sub> at 5 L/min. through a mass flow controller. The injection fitting is heated slightly to ensure volatilization.

ANALYTICAL PROBLEMS: There is significant peak "tailing" unless a very high flow rate is used. "Tailing" is also caused by "bleed" from the sample loop. Sample valve should be in the inject position for exactly 5 seconds and then switched back to the sampling position to attenuate tailing.

All sample lines and regulators must be conditioned extensively.

**42.0 EPA METHOD 25 GAS MIXTURE\***

Cylinder No.	42A	42B	42C	42D	42E	42F	
Cylinder Construction**	AI	AI	AI	AI	AI	AI	
Manufacturer Concentration	ppm	100	100	200	750	1000	2000
RTI Concentration	Date ppmC	3/16/83 102	3/16/83 107	3/16/83 205	3/16/83 775	3/16/83 1043	3/16/83 1944

\* Gas Mixture contains an aliphatic, an aromatic and carbon dioxide in nitrogen.

\*\* AI = Aluminum; S = Steel; LS = Low Pressure Steel

**ATTACHMENT 2**

**SAMPLE CALCULATIONS OF % CHANGE/MONTH**

ATTACHMENT 2

Sample Calculations of % Change/Month

Example: (Data shown for benzene cylinder.)

Data:

<u>Date of Analysis</u>	<u>Concentration, ppm</u>
2/8/78	101
4/13/78	102
9/1/78	98
10/2/78	101
4/17/79	105

1) Linear Regression, X and Y Data Points, Slope

X values correspond to the dates of analyses, with the first date being day 1 (2/8/78). The second X value is equal to the number of calendar days (i.e., 65) between the first analysis date and the second analysis date (4/13/78) and so on. The Y values are the concentrations (ppm) that were determined on the respective analysis dates.

<u>X</u>	<u>Y</u>
1	101
65	102
206	98
237	101
434	105

Perform the regression analysis and determine the slope of the line utilizing commercially-available hand calculators or by the following formula:

$$m = \frac{\sum (x_i - \bar{x})(y_i - \bar{y})}{\sum (x_i - \bar{x})^2} = 0.0071$$

Standard deviation of slope =

$$\left[ \frac{\sum (y_i - \bar{y})^2 - \frac{[\sum (x_i - \bar{x})(y_i - \bar{y})]^2}{\sum (x_i - \bar{x})^2}}{(N-2) \sum (x_i - \bar{x})^2} \right]^{1/2} = 0.0076$$

$m$  = slope of regression line

$x_i$  = x-coordinate of an individual value

$y_i$  = y-coordinate of an individual value

$\bar{x}$  = average of all  $x_i$

$\bar{y}$  - average of all  $y_i$

$N$  = number of analyses

## 2) Percent change/month

$$\% \text{ change/month} = \frac{m \text{ (slope)}}{b} \times 100 \times 30 \text{ days}$$

where

$$b = y \text{ intercept} = \frac{1}{n} (Y - bX) = 100.06$$

Therefore,

$$\% \text{ change/month} = \frac{0.0071}{100.06} \times 100 \times 30 = 0.21$$

## 3) Standard deviation of percent change/month

$$\text{Standard deviation in units} = \frac{\text{Standard deviation of slope}}{\text{Intercept}} \times 100 \times 30 = 0.2270$$

$$95\% \text{ Confidence interval} = 0.21 \pm 2 \times 0.2270 = (-0.255, 0.664)$$

for % change/month