



## *SITE Technology Capsule*

# **Filter Flow Technology, Inc., Colloid Polishing Filter Method**

### **Abstract**

The Filter Flow Technology, Inc. (FFT), Colloid Polishing Filter Method (CPFM) was demonstrated at the U.S. Department of Energy's (DOE) Rocky Flats Plant (RFP) as part of the U.S. Environmental Protection Agency's (EPA) Superfund Innovative Technology Evaluation (SITE) program. The CPFM system is designed to remove ionic, colloidal, and complexed radionuclides and heavy metals from water. Pollutants are removed from water predominantly via sorption or chemical complexing. The purpose of the demonstration was to evaluate the ability of the CPFM system to remove low levels of uranium and gross alpha contamination from RFP groundwater.

During the demonstration, average uranium and gross alpha concentrations in influent water were 98 micrograms per liter (ug/L) and 91 picoCuries per liter (pCi/L), respectively. Analytical results showed that radionuclide levels decreased by about 75% following treatment with the CPFM system. At maximum removal efficiency, the CPFM system was capable of achieving Colorado Water Quality Control Commission (CWQCC) standards for water to be discharged from RFP.

As part of the SITE program, the CPFM technology was also evaluated based on nine criteria used for decision making in the Superfund feasibility study process. The results of this evaluation indicate that the CPFM system can provide short- and long-term protection of human health and the environment by removing radionuclide contamination from water and concentrating it in spent filter packs.

### **Introduction**

In 1980, the U.S. Congress passed the Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA), also known as Superfund. CERCLA committed resources to protecting human health and the environment from uncontrolled hazardous waste sites. CERCLA was amended by the Superfund Amendments and Reauthorization Act (SARA) in 1986 – amendments that emphasized the achievement of long-term effectiveness and permanence of remedies at Superfund sites. SARA mandated permanent solutions and alternative treatment technologies or resource recovery technologies to clean up hazardous waste sites to the maximum extent possible.

State and federal agencies, as well as private parties, are now exploring a growing number of innovative technologies for treating hazardous wastes. Because the sites on the National Priorities List comprise a broad spectrum of physical, chemical, and environmental conditions requiring varying types of remediation, EPA has focused on policy, technical, and informational issues related to exploring and applying new remediation technologies applicable to multiple Superfund sites. One such initiative is EPA's SITE program. It was established to accelerate development, demonstration, and use of innovative technologies for site cleanups. EPA SITE Technology Capsules summarize the latest information available on selected innovative treatment and site remediation technologies and related issues. These capsules are designed to help EPA remedial project managers, EPA on-scene coordinators, contractors, and other site cleanup man-



agers understand the types of data needed to effectively evaluate a technology's applicability for cleaning up Superfund sites.

Results from an evaluation of the CPFM system, based on the nine criteria used for decision making in the Superfund feasibility study process, are presented in Table 1. This table shows that the CPFM system provides both long-term and short-term protection of the environment, reduces contaminant mobility and volume, and presents few risks to the community or the environment.

This Capsule provides information on the FFT CPFM system, a technology developed to remove low levels of radionuclides and heavy metal pollutants from groundwater, wastewater, and soil washing wastewater. The CPFM system was evaluated under EPA's SITE program in September 1993 at RFP in Golden, Colorado where groundwater is contaminated with radionuclides. Information in this Capsule emphasizes specific site characteristics and results of the SITE field demonstration at RFP. This Capsule presents the following information:

- Technology description
- Technology applicability
- Technology limitations
- Process residuals
- Site requirements
- Performance data
- Technology status
- Sources of further information

## Technology Description

The FFT CPFM system uses a proprietary compound (Filter Flow 1000) that consists of inorganic, oxide-based granules. Filter Flow 1000 is formulated to remove radionuclides and heavy metals from water through a combination of sorption, chemical complexing, and filtration. FFT states that sorption on the Filter Flow 1000 accounts for the majority of the removal action.

Filter Flow 1000 is contained in specialty designed colloid filter packs within a colloid filter press unit. The colloid filter press unit is approximately 7 ft high and 3 ft sq. The four filter plates of the colloid filter press unit support three colloid filter packs. The filter plates are 26 in. sq, 2 in. thick and constructed of very strong plastic. One colloid filter pack is located between each set of plates within the colloid filter press unit. Each filter pack is constructed of a durable, fibrous, polymer material that contains a premeasured amount of the complexing agent Filter Flow 1000. Once the filter packs have been placed between the filter plates, hydraulic pressure is applied to the plates. Pressure seal O-rings contained in the plates form a water tight seal between the plates, holding water within the unit. The plates are also designed to evenly disperse water across the filter media.

Figure 1 is a process flow diagram of the CPFM system used for the SITE technology demonstration at RFP. The following main components comprise the CPFM system: an influent mixing tank, a miniclarifier with a small sludge filter press, a bag filter, colloid filter press units, and an effluent pH adjustment tank.

The CPFM process involves the following basic steps: (1) contaminated water is pumped to an influent mixing tank for chemical preconditioning (pH adjustment or sodium sulfide addition), if necessary, to induce formation of colloidal forms of pollutants. (2) suspended solids are then removed by an incline plate miniclarifier, (3) overflow water from the miniclarifier is pumped through a microfiltration bag filter where particles greater than 10 microns in diameter are removed, (4) water passing through the bag filter is pumped to the colloid filter press units where heavy metals and radionuclides are removed by the sorption, chemical complexing, and filtration effects of Filter Flow 1000, (5) treated water exiting the colloid filters is pH adjusted prior to discharge. Following treatment, sludge in the miniclarifier is dewatered in the small sludge filter press using compressed air. The filter packs are also dewatered using compressed air to form a cake containing 60 to 70% solids. These two solid wastes are combined for disposal.

During the demonstration at RFP, the CPFM system treated contaminated groundwater collected by an interceptor trench system constructed downgradient of the RFP solar evaporation ponds. Contaminated water from the interceptor trench is pumped to three open-top, 500,000 gal storage tanks (the interim measure/interim remedial action (IM/IRA) tanks), one of which stored influent for the CPFM system. Influent pH adjustment was not required because the influent was within the optimum pH range (8 to 9) for the CPFM system. The pH of the effluent water was monitored in the final pH adjustment tank and treated with hydrochloric acid to reduce the pH to its original level before discharge to a second IM/IRA tank.

## Technology Applicability

The CPFM technology is designed to remove non-tritium radionuclides and heavy metals from water to parts per million (ppm) or parts per billion (ppb) levels. The CPFM technology can be used as a stand alone unit to treat low-total suspended solids (TSS) water or in a treatment train, downstream from other technologies such as soil washing, or conventional wastewater treatment using flocculation and solids removal. According to the developer, potential applications also include remediation of contaminated liquid wastes from industrial operations, oil-drilling production water contaminated with naturally occurring radioactive materials (NORM), uranium mine groundwater, and transuranic and low-level radioactive wastes from nuclear-related facilities with contaminated water. FFT states that the CPFM system is designed to treat a wide range of inorganic metallic pollutants in water including colloidal, complexed, and ionic forms. In general, low levels of radionuclides and heavy metals are the most suitable for treatment by the CPFM system.


Under the SITE program, in addition to the full-scale demonstration at RFP, the CPFM system has been tested at a bench-scale level. The study used RFP interceptor trench water that contained uranium-238 at approximately 35 pCi/L. and was spiked with up to 30 pCi/L of plutonium-239, americium-241, and radium-226. The results from this study indicated removal efficiencies of greater than 99% for uranium, plutonium, and americium with no chemical pretreatment. Removal efficiency for

Table 1. Criteria Evaluation for the CPFM Technology

Criteria								
Overall Protection of Human Health and the Environment	Compliance with Federal ARARs	Long-Term Effectiveness and Permanence	Reduction of Toxicity, Mobility, or Volume Through Treatment	Short-Term Effectiveness	Implementability	Cost*	Community Acceptance	State Acceptance
Provides both short- and long-term protection by eliminating exposure to contaminants in groundwater.	Requires compliance with RCRA treatment, storage, and land disposal regulations (of a hazardous waste).	Effectively removes and stabilizes contamination.	Significantly reduces toxicity, mobility, and volume of contaminants through treatment.	Presents few short-term risks to workers and community.	Involves few administrative difficulties.	\$15 per 1000 gal to \$0.50 per 1000 gal	Minimal short-term risks presented to the community make this technology favorable to the public.	If remediation is conducted as part of RCRA corrective actions, state regulatory agencies may require permits.
Prevents off-site migration through sorption on filter packs.	Wastewater discharges require compliance with clean Water Act regulations.	Involves well-demonstrated technique for removal of contaminants.		Some personal protective equipment required to be worn by operators.	Involves few utility requirements including water, electricity, and compressed air.			
		Involves some residuals treatment (filter cake, wastewater) or disposal (PPE).		The system can relatively rapidly reduce large volumes of contaminated water to clean water and filter cake.	Once on site, the treatment system can be operational within 1 week			

Notes:

\* Actual cost of a remediation technology is highly specific and dependent upon the original and target cleanup level, contaminant concentrations, groundwater characteristics, and volume of water. Cost data presented in this table are for treating groundwater at 100 gpm for 1 year.



**Legend**



Note: Colloid Filter Units can be Operated in Series or Parallel Modes. (Only Series Shown Here)

Figure 1. CPFM Treatment System.

gross alpha was 86%. These test runs showed only 43% removal efficiency for radium.

**Technology Limitations**

In general, the CPFM technology is designed to remove trace to moderate levels (less than 1,000 ppm) of non-tritium radionuclides and heavy metal pollutants present in water. The CPFM technology will not remove tritium because of its chemical characteristics. Tritium in water is incorporated in water molecules and is therefore not retained by Filter Flow 1000. Only tritium associated with TSS will be removed by the bag filter upstream of the colloid filter units. Although future testing of this technology may show differently, preliminary results and theoretical investigations do not indicate potential tritium removal.

Because high organic compound concentrations may interfere with the chemical and physical reactions occurring between Filter Flow 1000 and charged radionuclide and heavy metal pollutants, water with high organic compound concentrations is not treated as effectively by the CPFM technology.

**Process Residuals**

The CPFM process generates two waste streams: treated effluent and filter cake. Demonstration analytical results for composite samples shown in Table 2 indicate that effluent from runs 1 and 4 were near CWQCC discharge standards for uranium and gross alpha.

The filter cake generated during the demonstration was tested for hazardous waste and radiation characteristics and is being stored at RFP pending disposal at an EPA- and DOE-approved facility. The EPA paint filter liq-

uids test, performed at the time of waste packaging, indicated that the wastes do not contain free liquids. The toxicity characteristic leaching procedure was also performed on the filter cake solids. Table 3 shows that composited filter cake solids from the demonstration did not contain leachable radionuclides, or leachable metals at levels above EPA standards (40 CFR Part 268). In addition, Table 4 indicates that uranium and gross alpha activities were very low for filter cake solids from each run.

Drummed personal protective equipment (PPE) was screened for radioactivity and disposed of in accordance with state and federal requirements. Wash water from decontamination was collected and placed in a 1,000 gal storage tank prior to acceptance by a wastewater disposal facility at RFP.

**Site Requirements**

All process equipment is mounted and operated on the bed of a trailer. Access roads are needed for equipment transport. A paved or well graded gravel area of approximately 450 sq ft is also needed to accommodate the CPFM unit, support equipment, and facilities. In addition, berms are needed for spill containment. Once on-site, the unit can be operational within a week if all the necessary facilities, utilities, equipment, and supplies are available.

Utility requirements for the CPFM system are water, electricity, compressed air, and a telephone. Clean process water is required for system operation and decontamination of equipment and personnel. Fire hydrant water was provided by the site operator for the demonstration. The CPFM system used for the demonstration

Table 2. Analytical Results from the CPFM SITE Demonstration

Parameter	Run Number	Influent		Intermediate		Effluent		CWQCC* Standards
		Composite/Duplicate	Grab/Duplicate	Composite/Duplicate	Grab/Duplicate	Composite/Duplicate	Grab/Duplicate	
Uranium ( $\mu\text{g/L}$ )	1	102/104	102	60/60	62	9.5/9.6	3.4	7
Gross Alpha (pCi/L)		98/99	94	40	77	13	9.4	7
Uranium ( $\mu\text{g/L}$ )	2	89/94	102	92	98/94	38/38	43	7
Gross Alpha (pCi/L)		88/62	110	84	68/110	53/47	24	7
Uranium ( $\mu\text{g/L}$ )	3	102	96/96	94	94/92	23/25	7.9/8.3	7
Gross Alpha (pCi/L)		110	100/110	36	110/57	27	0/25	7
Uranium ( $\mu\text{g/L}$ )	4	98	104	64	55	5.1	19	7
Gross Alpha (pCi/L)		65	100	71	50	3.7	11	7

\* Colorado Water Quality Control Commission

Table 3. Analytical Results for TCLP Extract Solutions

Parameter	Run 5 Pack 1	Run 5 Pack 2	Regulatory Level (mg/L)
Uranium ( $\mu\text{g/L}$ )	1.0U	1.0U	—
Gross Alpha (pCi/L)	82U	290U	—
Arsenic ( $\mu\text{g/L}$ )	380U	380U	6.0
Barium ( $\mu\text{g/L}$ )	2,640	4,780	100.0
Cadmium (g/L)	50U	50U	1.0
Chromium (g/L)	40U	40U	5.0
Lead ( $\mu\text{g/L}$ )	290U	290U	5.0
Mercury ( $\mu\text{g/L}$ )	10U	10U	0.2
Selenium ( $\mu\text{g/L}$ )	10U	10U	7.0
Silver ( $\mu\text{g/L}$ )	40U	40U	5.0

U = undetected at this value

Table 4. Analytical Result for Filter Pack Solids

Parameter	Run 1	Run 2	Run 3	Run 4 Pack 1	Run 5 Pack 2	Run 5
Uranium ( $\mu\text{g/g}$ )	2.1	2.1	3.4	2.6	4.7	5.7
Gross Alpha (pCi/g)	13U	12	15	8.1	11	12U

U = undetected at this value

requires 120-volt, 30-amperes electrical service and a minimum of 100 psi compressed air supply for the process equipment and field laboratory equipment. For the demonstration, gas powered generators and an air compressor were used. Telephone service is required mainly for ordering equipment, scheduling deliveries, and communicating emergencies. A cellular telephone was used during the demonstration.

Additional equipment and supplies included a 1,000-gal water storage tank for decontamination rinse water, equipment for filter cake disposal, including 55-gal drums and a forklift with operator, sampling equipment and containers, and health- and safety-related gear.

After treatment is completed, the treatment system can be demobilized within 1 week. This activity includes equipment decontamination and utilities disconnection. Demobilization following the demonstration took approximately 1 week.

### Performance Data

The CPFM technology was developed to treat water contaminated with radionuclides and heavy metals. Water from the RFP IM/IRA storage tanks was selected as a source of contaminated water for the demonstration because the principal contaminants in groundwater at RFP were expected to be uranium, radium, plutonium, and

americium. Following the bench scale testing, the contamination in RFP water was determined to be dominantly uranium and gross alpha. Therefore, these contaminants were considered the critical parameters and radium, plutonium, and americium were considered secondary parameters.

The CPFM technology was evaluated to determine appropriateness for use in removing radionuclides from RFP water. The objectives for the project were to:

- Assess the technology's ability to remove uranium and gross alpha contaminants to levels below CWQCC standards
- Document the operating conditions, and identify operational needs, such as utility and labor requirements, for the treatment system
- Estimate costs associated with the operation of the CPFM system
- Assess the technology's ability to remove other radionuclides (plutonium, americium, and radium)
- Evaluate the disposal options for prefiltered solids (miniclarifier and bag filter solids) and spent filter packs from the colloid filter unit

The demonstration was comprised of three tests. The first test consisted of three replicate runs of 4 hr each, at operating parameters established by the developer. Three runs were conducted during this test in order to collect enough data to statistically evaluate the CPFM system's ability to meet CWQCC standards. For these runs, the colloid filter presses held three filter packs each and water was routed through the packs in series. During these three runs, process parameters including flow rate (5 gal/min), and amount of filter bed material (30 kilograms of Filter Flow 1000) were held constant. For the second test, sodium sulfide was added to the influent water in the pretreatment tank to change the oxidation state of radionuclides in water. This test consisted of one run; using the same operating configuration and conditions as the first test. The purpose of this test was to determine whether pretreatment could be used to improve CPFM performance that may be required to attain CWQCC standards. The third test was a 15-hr run. This test used only a single pack in each colloid filter press. This run was designed to determine the time of breakthrough and the amount of contamination each filter pack is capable of treating. This information was then used in evaluating the operational costs of the CPFM system.

During the demonstration, samples were collected of the untreated water (influent), pretreated water after passing through the miniclarifier and bag filter (intermediate), and treated water that had passed through the filter packs (effluent). Filter cake was also analyzed. Samples were analyzed to determine the technology's effectiveness and evaluate disposal options for filter cake,

Analytical results for uranium and gross alpha from runs 1 through 4 are presented in Table 2. Runs 1 through 4 were designed to collect sufficient data to do a statistical evaluation of CPFM system capabilities. Therefore, composite, grab, and replicate samples were collected and analyzed.

Assessment of data quality for the critical parameters uranium and gross alpha included evaluation of

laboratory method blanks, matrix spike and matrix spike duplicate recoveries, and analytical/field duplicates. No laboratory contamination was indicated by method blank data. Uranium matrix spike recoveries were all within the acceptable range of 80 to 120%. However, 3 out of 20 matrix spike recoveries for gross alpha were outside of these control limits. Duplicate uranium analyses were all well within  $\pm 20\%$ . Samples and duplicates yield an  $r^2$  value from linear regression of 0.99, indicating that uranium analyses had good precision. However, 12 out of 20 duplicate gross alpha analyses exceeded  $\pm 20\%$ . Samples and duplicates yield an  $r^2$  value from linear regression of 0.15, indicating poor precision of gross alpha data. Therefore, only uranium analyses are considered reliable for assessing the performance of the CPFM system and gross alpha data should be interpreted with caution.

Figures 2 and 3 show graphically the removal of radionuclides in runs 1 through 4. Figures 4 and 5 show gross alpha and uranium concentrations, respectively, for sampling during the breakthrough assessment of run 5. Where possible, only composite data were used to construct these figures (where replicate composites exist, an average value was used). Composite gross alpha and uranium concentrations for influent for runs 1 through 3, varied from 62 to 110 pCi/L for gross alpha and 89 to 104  $\mu\text{g/L}$  for uranium. Analytical results for composite samples of intermediate waters from these three runs show a range of 36 to 84 pCi/L for gross alpha and a range of 60 to 94  $\mu\text{g/L}$  for uranium. Analytical results for composite effluent water from runs 1 through 3 show gross alpha values that range from a low of 13 pCi/L for run 1 to a high of 53 pCi/L for run 2. Similarly analytical results for uranium ranged from a low of 9.5  $\mu\text{g/L}$  for run 1 to a high of 38  $\mu\text{g/L}$  for run 2.

Removal efficiencies for runs 1 through 4 were calculated using composite data and are shown in Table 5. (Where replicate composites exist, an average value was used.) Overall removal efficiencies for uranium during runs 1 through 3 ranged from a low of 58.4% to a high of 90.6%. Overall removal efficiencies for gross alpha for runs 1 through 3 ranged between 33.3% and 86.8%. Overall removal efficiencies for uranium and gross alpha for run 4 were slightly better than the best of the initial 3 runs (run 1) with 94.8% and 94.3% removal, respectively. It should be noted that only in run 4 were the CWQCC standards for composite sampling met. Though removal is largely attributable to the colloid filter pack, significant removal of uranium occurred in runs 1 and 4 prior to the colloid filter unit. Significant pre-colloid filter removal of gross alpha is also indicated for runs 1 and 3.

Analytical results for plutonium and americium showed that these elements were at or near method detection limits. Therefore, the ability of the CPFM system to remove them from RFP groundwater could not be properly evaluated. Results for radium analyses indicated that the CPFM system did not remove radium from RFP groundwater.

The results from run 5, the breakthrough run, are presented graphically in Figures 4 and 5. These results indicate that using a single colloid filter unit, breakthrough occurred prior to the first sampling time at 120 min or that the single pack was not capable of removing significant contamination. This result was not expected based on the information initially provided by FFT. On average, only a slight reduction in the influent uranium and gross alpha




Figure 2. Gross alpha concentrations for runs 1 through 4.




Figure 3. Uranium concentrations for runs 1 through 4.




Figure 4. Gross alpha concentrations for run 5 effluent. Solid squares correspond to concentrations and removal efficiencies.




Figure 5. Uranium concentrations for run 5 effluent. Solid squares correspond to concentrations and removal efficiencies.

Table 5. Removal Efficiency Results for Runs 1 through 4 for the CPFM SITE Demonstration

Parameter	Run Number	Influent	Intermediate	Effluent	CWQCC Standards	Mini-Clarifier and Bag Filter Removal Efficiency	Colloid Filter Unit Removal Efficiency	Overall Removal Efficiency
Uranium ( $\mu\text{g/L}$ )	1	103	60	9.6	7	41.7	84.0	90.6
Gross Alpha (pCi/L)		98.5	40	13	7	59.4	67.5	86.8
Uranium ( $\mu\text{g/L}$ )	2	91.5	92	38	7	-0.5	58.6	58.4
Gross Alpha (pCi/L)		75	84	50	7	-12.0	40.5	33.3
Uranium ( $\mu\text{g/L}$ )	3	102	94	24	7	7.8	74.5	76.5
Gross Alpha (pCi/L)		110	36	27	7	72.5	25.0	75.5
Uranium ( $\mu\text{g/L}$ )	4	96	64	5.1	7	34.7	92	94.8
Gross Alpha (pCi/L)		65	71	3.7	7	-9.2	94.8	94.3

\* Overall removal efficiency =  $\frac{[\text{Influent}] - [\text{Effluent}]}{[\text{Influent}]} \times 100$

\*\* Colloid Filter Unit removal efficiency =  $\frac{[\text{Intermediate}] - [\text{Effluent}]}{[\text{Intermediate}]} \times 100$

Where: [ ] equals the concentration of the individual parameters

concentrations was observed in run 5. It should be noted that data for this run are erratic, thus indicating that performance of the system during discrete time intervals may be unpredictable. Single pack removal efficiencies are considerably less than the series of six packs used in runs 1 through 4. Reduction in removal efficiencies may be due to a variety of factors such as channeling through a single pack, or insufficient residence time within the pack. However, this demonstration was not designed to evaluate such factors.

Operating conditions documented during the demonstration indicated that water treatment with a series of colloid filter packs was successful in removing uranium and gross alpha contamination from RFP waters. The demonstration results also indicate that pretreatment of influent water with sodium sulfide improves CPFM system removal efficiencies.

Disposal options for the used filter pack are determined by its radionuclide and leachable metal content. Table 4 shows that concentrations of uranium in the filter cake ranged from 2.1 to 5.7  $\mu\text{g/g}$  and gross alpha concentrations ranged from not detectable to 15 pCi/g. In addition, Table 3 shows TCLP test results indicating that the filter cake does not contain extractable metals above regulatory limits.

Based on an economic analysis using a 1-year treatment scenario at 100 gal/min for 24 hr/day, 7 days/wk, the treatment cost is approximately \$15/1000 gal. This cost is reduced to \$0.50/1000 gal using a 5-yr treatment scenario. Costs can be expected to vary depending on contamination type, level, and volume of water treated.

## Technology Status

Other sites are considering the CPFM system. Pilot-scale testing is underway at the Oak Ridge National Laboratory through a joint venture with Martin Marietta and Dwight and Church. The pilot test will determine the CPFM process effectiveness in treating mixed waste. In another

pilot-scale test, funded by the Westinghouse Science and Technology Group, the process is being applied in a treatment train to mixed wastewater that has been pretreated to destroy organic compounds and remove suspended solids. The CPFM system is also being used to treat metal finishing wastes. FFT is also building a CPFM system in Peru that will treat mine wastewater discharge that contains copper, zinc, lead, and arsenic. In all, a total of 15 commercial projects are planned or underway.

## Sources of Further Information

### EPA Contact:

U.S. EPA Project Manager:  
Annette Gatchett  
U.S. Environmental Protection Agency  
Risk Reduction Engineering Laboratory  
26 West Martin Luther King Drive  
Cincinnati, OH 45268  
Telephone No.: 513/569-7697  
Fax No.: 513/569-7620

### Technology Developer:

Tod Johnson, Ph.D.  
Filter Flow Technology, Inc.  
122 Texas Avenue  
League City, TX 77573  
Telephone No.: 713/554-5405  
Fax No.: 713/554-5208

### DOE Contact:

Beth Bralnard-Jordan  
Community Relations  
DOE Rocky Flats Office  
Rocky Flats Plant  
P.O. Box 928  
Golden, CO 80402-0928  
Telephone No.: 303/966-5993

United States  
Environmental Protection Agency  
Center for Environmental Research Information  
Cincinnati, OH 45268

Official Business  
Penalty for Private Use  
\$300 E

EPA/540/R-94/501a

BULK RATE  
POSTAGE & FEES PAID  
EPA  
PERMIT No. G-35