



Field Inspection Notebook for Monitoring Total Reduced Sulfur (TRS) from Kraft Pulp Mills

Field Inspection Notebook for Monitoring Total Reduced Sulfur (TRS) from Kraft Pulp Mills

Prepared by
William T. Winberry, Jr.

Engineering-Science
501 Willard Street
Durham, North Carolina 27701

Contract No. 68-02-3960
Work Assignment No. 53

EPA Project Manager: John Busik
EPA Work Assignment Manager: Sonya M. Stelmack

U.S. ENVIRONMENTAL PROTECTION AGENCY
Stationary Source Compliance Division
Office of Air Quality Planning and Standards
Washington, D C 20460

December 1984

DISCLAIMER

This report was furnished to the Environmental Protection Agency by Engineering-Science, 501 Willard Street, Durham, N. C., 27701 in fulfillment of Contract No. 68-02-3960, Work Assignment No. 53. The opinions, findings, and conclusions expressed are those of the author and not necessarily those of the U. S. Environmental Protection Agency. Mention of company or product names is not to be considered as an endorsement by the Environmental Protection Agency.

TABLE
OF
CONTENTS

<u>Subject</u>	<u>Page Number</u>
Introduction.....	1
Field Inspection Notebook Objective.....	2
Inspection Procedures.....	5
Level I.....	7
Level II.....	11
Level III.....	29
Monitor Specific Inspection Procedures.....	33
Sampling Technology Inc.....	35
Barton Titrator.....	43
Bendix TRS CEM System.....	51
Level IV.....	61
Reference Method 16 Observation Checklist.....	63
Reference Method 16A Observation Checklist.....	83
Abbreviated Inspection Procedures.....	97
Appendix.....	109

FIELD INSPECTION NOTEBOOK
TOTAL REDUCED SULFUR
CONTINUOUS EMISSION MONITORING SYSTEM

INTRODUCTION

This notebook is intended to assist the field inspector in the inspection of total reduced sulfur (TRS) continuous emission monitoring systems (CEMs). Contained in the notebook are checklists and data entry tables covering preparation for the inspection, preliminary review of records, preliminary on-site meeting with source personnel, and general guidelines for inspection of any type TRS CEM system. Specific audit procedures for three of the most common models of TRS CEMs:

- Sampling Technology Inc. Model 100 TRS CEM System (pg. 35);
- Barton Titrator TRS System (pg. 43); and
- Bendix Gas Chromatograph TRS System (pg. 51)

are provided as sectional inserts. In auditing these monitors the inspector should follow the specific procedure rather than the general guidelines given in the body of the field notebook.

Conscientious use of this notebook will aid the inspector in conducting a thorough audit of the TRS CEM system and provide a comprehensive original record of all phases of the inspection.

FIELD INSPECTION NOTEBOOK OBJECTIVE

This notebook is designed to provide a complete unit checklist for inspection of an TRS CEM system. The inspection procedures follow the control agency inspection program, dealing with the "phase" and "level" approach.

The "phase" process consists of administrative activities involved with initial CEM system application, performance testing and final approval. This enables the state agency to approve the monitoring system through established certification procedures. The type of activities at each phase are:

Phase I - Control agency initial approval of CEM application as required through source permit;

Phase II - Control agency observation of performance specification testing (PST) of the installed CEM system; and

Phase III - Control agency review of the PST report, with final approval or disapproval.

The "level" approach begins after completion of the "phase" evaluation. The levels of CEM system inspection extend from agency source records review (lowest level) to stack test compliance determination (highest level). The inspection determines or confirms compliance and identifies causes of excess emissions. The types of activities at each level are:

Level I - Control agency records review including excess emission reports, previous inspection reports, source "working" file and permits;

Level II - On-site inspection involving review of monitor record-keeping (maintenance, monitor and control equipment logs), monitor fault indicator, monitor internal zero/span check, strip chart review and electronic checks;

Level III - Evaluation of installed CEMS through external audit evaluation involving neutral density filters for opacity monitors and gas cylinders/permeation tubes for gas monitors;

Level IV - Comparative evaluation of installed CEMS through performance testing utilizing Federal Reference Methods or portable CEMS.

The "phase" and "level" audit procedure has been designed so that each activity indicates whether or not the CEM system has achieved the necessary level of compliance before starting the next phase.

The main objective, of this notebook is to cover in detail the inspection procedure covering the "level" section of a control agency CEM system inspection program. During the inspection the inspector may need to add comments, explanations or other notes to the notebook. To aid in referencing these comments, a column under the heading of Check or Comment has been provided along the right margin of all pages containing inspection data. These blank lines may be used to indicate action items or to enter code numbers referencing entries elsewhere in the notebook.

Once a thorough evaluation of the TRS CEM system has been accomplished, control agency personnel may want to perform the next inspection on a less comprehensive basis. To assist the control agency personnel, an abbreviated inspection procedure checklist has been developed. The abbreviated checklist is applicable to all TRS CEM systems. It does not address monitor specific inspection points, but does evaluate the TRS monitor on a system audit basis. The checklist is divided into three major areas:

- o Control agency records review;
- o Control agency records update; and
- o Source TRS CEM system review.

The control agency records review consists of a review of permits and/or any current enforcement actions to determine the purpose of the CEM. In addition, a review of the PST report and current EER is conducted to verify conformance with the appropriate performance specification and reporting requirements for EERs.

The control agency records update is conducted by telephone to verify that the records in agency files correctly describe the current CEM status.

Finally, the source TRS CEM system review evaluates a source's record-keeping, data reduction procedures, monitor evaluation through zero/span checks and overall system review.

INSPECTION PROCEDURES

Concurrent with the "level" approach philosophy, the CEM inspection begins with a "thorough" working knowledge of the facility by reviewing the "permanent" and "working" file of the source in the agency office. Next, the inspection proceeds to the facility where other information is gathered to support the records review activity. While on the premises, the inspector reviews all records which would provide information associated with the monitoring system. Then, a review of the monitoring system is in order.

For a TRS extractive system, heat tracing, insulation, weather protection, transport lines, and connection material should be inspected. The field inspector should evaluate monitor location for ease of maintenance, representative sampling, and environmental factors such as vibration and temperature. The calibration gas interface with the sample system should be inspected and their relative proximity noted. The inspector should verify that during calibration the pressure of the calibrator gas at the interface is approximately equal to its pressure during sampling.

The inspector should observe CEM calibration procedures to confirm calibration reference values and provide a spontaneous quality assurance check. Documentation of calibration gas values by Protocol 1 traceability or triplicate reference method analysis should be available in plant records and verified during the field inspection.

Finally, the CEM control unit and signal recording device should be inspected. The inspector should review previous 24-hour emissions and zero/span check. He should initiate a zero/span check and compare to recorded values.

To assist the inspector, the front part of the notebook covers Levels I, II, III, and IV inspection procedures. These are generic in nature, adaptable to any TRS CEM system. The latter part of the notebook covers specific TRS CEM inspection procedures.

FIELD INSPECTION NOTEBOOK
TOTAL REDUCED SULFUR
CONTINUOUS EMISSION MONITORING SYSTEM

1.0 LEVEL I CHECKLIST

1.1 SOURCE IDENTIFICATION

Company Name _____

Mailing Address _____

Location of Facility _____

(Include County or Parish)

Personnel

	<u>Name</u>	<u>Title</u>	<u>Phone</u>
o Facility Manager	_____	_____	_____
o Environmental Manager	_____	_____	_____
o Facility Contact	_____	_____	_____
o Confidentiality State- ment Required	_____	_____	_____

1.2 PREPARATION FOR INSPECTION

1.2.1 Source Notification

- o Has the appropriate representative of the source been notified of the time and date of auditor's intended visit? Yes___ No___

By phone _____

By letter _____

Name of Representative _____

Date contacted _____

Record of notification filed _____

1.2.2 Review of Source's Permit to Operate

- o Permit information pertinent to the CEM audit is contained in the following checklist.

CEM requirement due to: Permit _____
NSPS _____
SIP _____
Enforcement Action _____

Date CEM installation completed _____

Date CEM started up _____

Gases monitored TRS _____ Opacity _____ O₂ _____

Allowable emission rates TRS _____

Opacity _____

1.2.3 CEM Equipment Summary

	<u>Pollutant</u>	<u>Manufacturer</u>	<u>Model/Type</u>	<u>Process</u>
Monitor/Analyzer	_____	_____	_____	_____
Data Recorder	_____	_____	_____	_____
Data Processor	_____	_____	_____	_____

1.2.4 Review of Performance Specification Test Report

- o A CEM Performance Specification Test (PST) report should be on file. Information to be reviewed is contained in the following checklist.

Dates of Operational Test Period (OTP) (<30 days after performance test) _____

Date PST report submitted (<60 days after OTP) _____

Date of process startup (<180 days prior to OTP) _____

Date of initial full-load operation (<60 days prior to OTP)

Emission rate conversion formula(s) _____

o PST Summary Results

	TRS	O ₂	Opacity
Relative Accuracy		NA	NA
Response Time			
24 Hr. Span Drift			
24 Hr. Zero Drift			

1.2.5 Review of Excess Emissions Reports

- o The following checklist summarizes pertinent information to be obtained from excess emissions reports.

Months covered by reports _____

Did each excess emission report document:

Date, time, and duration of excess emissions? Yes___ No___

Magnitude of excess emissions? Yes___ No___

Reason for excess emissions? Yes___ No___

Corrective action taken to reduce emissions? Yes___ No___

Conversions factor/formula? Yes___ No___

Method for determining conversion or correction factors
used in calculating emission rate.

Process downtime_____ None _____

Monitor downtime_____ None _____

If significant monitor downtime occurred, briefly discuss corrective
action taken to return monitor to operation.

What percent availability did the CEM system achieve? _____

$$\% \text{ availability} = \frac{\text{Hours of monitor operation}}{\text{Hours of process operation}}$$

o Select one excess emission event and record:

Date _____

Time _____

Magnitude _____

Reason _____

Corrective Action _____

This information is intended for use during Level II evaluation.

2.0 LEVEL II CHECKLIST

2.1 PRE-INSPECTION MEETING

Before the CEM inspection, the inspector should arrange to meet with source representatives directly responsible for CEM operation and maintenance, compliance, records and reports. The purpose of the opening conference is to inform facility official(s) of the purpose of the inspection, the authority under which it will be conducted, and the procedures to be followed, and answer any questions they may have. The opening conference also offers the inspector the opportunity to completely discuss agency policy and inspection procedures, and to provide relevant information and other assistance. The inspector's effective execution of the opening conference often sets the tone of the remainder of the inspection.

During the opening conference, the discussion should cover the following items:

	<u>COVERED</u>
o Inspection objectives	_____
o Inspection agenda	_____
o Facility Information verification	_____
o Review of records	_____
o Maintenance	_____
o CEM Operation Logbook	_____
o Strip Charts	_____
o Data Log	_____
o Control Equipment Records	_____
o Excess Emission Reports	_____
o Source Permit	_____
o Safety Requirements	_____
o Scheduling of Source Personnel Interviews	_____
o Inspection Techniques to Be Used	_____
o Scheduling of Copying Needed Documentation	_____
o Any Questions	_____

In particular, the inspector should develop his or her understanding of the operation/maintenance of the audited system to ascertain whether the TRS CEM system has been operated according to permit condition since the last inspection. The inspector should be able to support any conclusions by:

- o Examination of CEM maintenance records;
- o CEM span and zero calibration checks over previous quarter;
- o Reviewing the CEM program;
- o Records comparison, i.e., correlation of excess emission reports, strip chart records, operations and maintenance records, and computer printouts (if available); and
- o Reviewing files to identify missing documents (if any).

The following checklists are provided to assist the inspector in conducting the preliminary meeting.

2.1.1 Personnel In Attendance

[illegible]

2.1.2 Review of CEM Maintenance Records.

- o Describe significant CEM maintenance since last audit.

Description	Type*	Date/time Performed

*Routine, Preventive, Emergency, etc.

- o Recurring Maintenance Problems (Last 12 Months)

2.1.3 Review of Calibration Frequency

	Zero	Span	Calibration Error*	Relative Accuracy*
Estimate of Calibration Frequency	_____	_____	_____	_____

*Optional

- o Describe Unusual or Persistent Monitor Calibration problems

2.1.4 General Review of CEM Program

- o Is an alarm connected to CEM control panel or annunciator panel in process control room to signal excess emissions? Yes___ No___
- o How often is CEM strip chart or computer output checked by an operator?

- o What procedures are implemented during an excess emission incident to reduce emissions?_____

- o Do records contain process data needed for conversion of CEM output to units of the standard (i.e., moisture, velocity, oxygen correction)? Yes___ No___
- o Are process data measurements conducted? Yes___ No___
- o Do records contain current information on calibration reference materials (gases, permeation tubes, cells, filters)? Yes___ No___
- o Are entries into Maintenance and Operations Logs made on monitor:
 - Malfunction? Yes___ No___
 - Calibrations? Yes___ No___
 - Maintenance? Yes___ No___
 - QA Checks? Yes___ No___
- o Are charts/printouts for the past two years filed and readily retrievable? Yes___ No___

2.1.5 Internal Consistency of Records and Reports

It should be possible to relate the emission excursions reported in the Excess Emissions Report with the recorded CEM data showing the occurrence of excess emissions. Such excursions should also be documented in the CEM Log, which should include a report of the incident and the corrective action taken by the source. In those cases where a mechanical problem is cited as the cause of the excess emissions, maintenance records should show corrective action taken by the source. The inspector should try to determine the time between the measured excess emissions incident and the initiation of corrective action.

- o Report of Excess Emissions (Enter data from Level I Review)

Date	Time		Pollutant	%O ₂	Magnitude (ppm)
	From	To			
_____	_____	_____	_____	_____	_____

- o Description of Excess Emissions from CEM or operating Log on above date.

- o Identification of Excess Emissions Incident in Chart Record

Above Date	Time	Last Zero Check	Last Span Check	Average (ppm)	Calculated
					equivalent (ppm) (O ₂ corrected)
_____	_____	_____	_____	_____	_____

- o Subsequent Corrective Action Described in Maintenance Log (if applicable), and date and time initiated

- o Are dates and times of above records consistent in recording this excess emission event? Yes ___ No ___

- o If No, explain _____

2.2 TRS CEM FIELD INSPECTION

The general inspection procedures presented on the following pages cover extractive TRS CEM systems. These procedures should be followed when a monitor-specific procedure is unavailable.

Check
or
Comment

2.2.1 TRS CEM Operational Environment

- o Is the process monitored by the TRS CEM operating within normal limits as compared to the source performance test? Yes___ No___
(If process is not operating within normal limits, Inspector should delay any part of audit which requires normal process conditions.)
- o Process Capacity _____
- o Process Rate _____
- o Stack Gases TRS _____ Opacity _____
Monitored:
(Avg. Conc.) O₂ _____
- o Stack Gas Temperature _____ °F
- o Pollution Control Device _____
- o Is the analyzer unit subject to excessive heat?
Yes___ No___
- o Is the analyzer unit subject to excessive vibration? Yes___ No___
[Note: Excessive heat/vibrations are meaningful only if system (1) fails to satisfy the operations specified by vendor or (2) fail to meet PST 5.]
- o Frequency of sampling: _____ per hour _____

2.2.2 Measurements and Data Handling

The following checklists are intended to assist the inspector in an analysis of the source's data handling and data reduction practices.

At some facilities data reduction is done by a computer programmed to convert stack gas concentrations directly and continuously to the units of the applicable emission standard. At other facilities manual calculations of emissions in units of the standard are only done for periods of excess emissions.

	Check or Comment
2.2.2.1 <u>Data Handling</u>	
o How is data reduction handled? Manually _____	_____
Electronically_____	_____
o How many data points are used to calculate each average? _____	_____
o Are these data points taken at equally spaced time intervals? _____ Yes ____ No ____	_____
o If yes, what is that time interval? _____	_____
o If data reduction is manual, how often is it done? _____	_____

o Who performs manual data reduction? _____	_____

o Are the data adjusted to account for zero drift measurements? _____ Yes ____ No ____	_____
o Are the data corrected to account for calibration (span) drift measurements? _____ Yes ____ No ____	_____
o Does the source arbitrarily edit the data before reduction? _____ Yes ____ No ____	_____
o If yes, what criteria is used to edit? _____	_____

2.2.2.2 <u>Electronic Data Reduction:</u>	
o Who wrote the program for calculating averages? _____	_____

o Is the source's data processing system time shared or dedicated? _____	_____
o Was it installed with the monitoring system or added at a later date? _____	_____

	Check or Comment
o Who installed the data processing system? _____ _____	_____
o At what interval does the data logger acquire CEM measurements? _____ _____	_____
o Does the system include a data recorder as well as a chart? _____ Yes ____ No ____	_____
o If yes, indicate which kind. Magnetic tape _____ Paper tape _____ Paper print-out _____	_____
o If both automated data processing and chart recording are done, does the CEM value from the automated data processor agree with the value recorded on the chart? Yes ____ No ____	_____
o If no, explain. _____ _____ _____	_____
o Indicate which functions the automated data processing system performs.	_____
Data recording _____	
Data storage _____	
Averaging Period _____	
Hourly summary _____	
Daily summary _____	
Other summary (explain) _____ _____	
Identification of excess emissions _____	
Display instantaneous value _____	
Alarm _____	

Check
or
Comment

Records process equipment malfunction codes _____

Records pollution control equipment malfunction codes _____

Records excess emission codes _____

2.2.2.3 Internal Zero/Span Check

- o Write date and time on chart or data processor at start of inspection _____

- o Record current emissions

	TRS (ppm)	O ₂ (%)	Opacity (%)
Current Emissions	_____	_____	_____

- o Request internal zero and upscale calibration, enter results below, and compare results to typical previous values.

Monitor Response	_____	_____	_____
Zero	_____	_____	_____
Span	_____	_____	_____
Calibration Value			
Zero	_____	_____	_____
Span	_____	_____	_____

- o Review previous day's recording for typical emissions, repeated zero/span checks, etc. _____

	Yes	No
Emissions normal	_____	_____
Calibration normal	_____	_____
Exceedances above the standard	_____	_____
Calibrations noted on data processor and reviewed	_____	_____
Operator aware of emission limits	_____	_____

Check
or
Comment

2.2.3 Inspection of Monitor Control Unit

Although instrumentation differs among the various types and models of TRS CEM's, many will incorporate some or all of these control indicators or switches. The inspector should locate those in use and enter their position/status below.

	TRS	O ₂	Opacity	
<input type="checkbox"/> Reference	_____	_____	_____	_____
<input type="checkbox"/> Calibration	_____	_____	_____	_____
<input type="checkbox"/> Alarm	_____	_____	_____	_____
<input type="checkbox"/> Temperature	_____	_____	_____	_____
<input type="checkbox"/> Sample gas	_____	_____	_____	_____
<input type="checkbox"/> Stack gas	_____	_____	_____	_____
<input type="checkbox"/> Heater	_____	_____	_____	_____
<input type="checkbox"/> Backpurge	_____	_____	_____	_____
<input type="checkbox"/> Request Calibration	_____	_____	_____	_____
<input type="checkbox"/> Operating Range	_____	_____	_____	_____
<input type="checkbox"/> Recorder Readout	_____	_____	_____	_____
<input type="checkbox"/> Operate	_____	_____	_____	_____
<input type="checkbox"/> Sample Flow Rate	_____	_____	_____	_____

2.2.4 Calibration Gas System

- ☐ If system uses compressed gases to routinely calibrate system, note following gas cylinder information:

Gas Cylinder 1

Pollutant _____

Concentration _____

Certification Date _____

Cylinder Number _____

Cylinder Pressure (psi) _____ primary (>150psi)

_____ secondary (> 15psi)

Gas Cylinder 2

Pollutant _____

Concentration _____

Certification Date _____

Cylinder Number _____

Cylinder Pressure (psi) _____ primary (>150psi)
_____ secondary (> 15psi)

Gas Cylinder 3

Pollutant _____

Concentration _____

Certification Date _____

Cylinder Number _____

Cylinder Pressure (psi) _____ primary (>150psi)
_____ secondary (> 15psi)

Gas Cylinder 4

Pollutant _____

Concentration _____

Certification Date _____

Cylinder Number _____

Cylinder Pressure (psi) _____ primary (>150psi)
_____ secondary (> 15psi)

Check
or
Comment

2.2.5 Sample Transport System

- o Type of tubing _____
- o Internal diameter of tubing _____ inches
- o Enter the distance from sample point to analyzer _____ feet
- o Is transport line heat traced? ____ Yes ____ No ____
- o If yes, how is temperature monitored? _____

- o Enter the temperature of the transport line: _____

2.2.6 Sample Conditioning/Extractive Systems

For extractive systems the following checklists describe the sampling point, transport system, and sample conditioning system.

2.2.6.1 Sampling Point -

- o Location: Stack _____
Duct Horizontal _____
Duct Vertical _____
- o Is it downstream of pollution control device? Yes ____ No ____
- o Type pollution control device(s) _____
- o Estimate distance from nearest flow disturbance and record below.
Downstream: _____ feet
Upstream: _____ feet
- o Sketch the cross-section of the duct/stack at the sampling point and show the location of the sampling probe of CEM. Indicate dimensions. _____

Sketch of Duct/Stack and Sampling Probe Location

Check
or
Comment

- o On the following blank page sketch the components of the Extractive CEM, including the probe, filter, calibration gas interface, pump, moisture removal system, SO₂ scrubber system (where applicable), and analyzer.

2.2.6.2 Sample Probe -

- o Type Material: _____
- o Singular or multi-point sampling? _____
- o If multi-point sampling, enter number of sampling points _____
- o Distance of each point from the wall: _____

Point No. 1 2 3 4 5 6 7

Inches
from wall ____ ____ ____ ____ ____ ____ ____

- o If single point, enter distance from wall: ____ inches

Sketch of the Components of the Extractive CEM, Including the Probe, Filter, Calibration Gas Interface, Pump, Moisture Removal System, SO₂ Scrubber System (where applicable), Analyzer, and Calibration System.

	Check or Comment
2.2.6.3 <u>Filter</u> -	
o Type: Internal _____ External _____	_____
o Condition: _____	_____
o Is there a back purge on the sampling system to clean the probe? _____ Yes ___ No ___	_____
o If yes, how often is it activated? _____	_____
o Is the purge air dried prior to use? Yes ___ No ___	_____
o Frequency of Replacement: _____	_____
o Typical pressure drop across filter (if monitored): _____	_____
o Current pressure drop across filter (if monitored): _____	_____
2.2.6.4 <u>Moisture Removal (if applicable)</u> : -	
o Type of moisture removal equipment? _____	_____
Refrigerated or tube type condenser _____	
Permeation dryer _____	
o Location: _____	_____
o Sample Gas Temperature at Outlet During Audit: _____	_____
2.2.6.5 <u>Sample Pump</u> -	
o Type: _____	_____
o Location: _____	_____
o Flow Rate: _____	_____
2.2.6.6 <u>Heater/Oven (if applicable)</u> -	
o Location: _____	_____

o Temperature of Gas at Outlet During Audit (if monitored) _____	_____

Check
or
Comment

2.2.6.7 SO₂ Scrubber System -

- o Location: _____

- o Type: _____

- o Frequency of change _____

2.3 CLOSING CONFERENCE

The closing conference enables the inspector to "close-out" the inspection with plant personnel. At this time, questions can also be answered relating to results of the inspection. In general, the following elements should be covered in the closing conference:

- o Review of Inspection Data _____
- o Inspection Discussion _____
- o Confidential Information _____
- o Deficiencies in monitoring program _____
- o Recommendations _____

3.0 LEVEL III CHECKLIST

3.1 INTRODUCTION

The Level III inspection, for the State inspector, is the most costly and labor intensive. Level III inspection becomes necessary only when the Level II inspection indicates deficiencies in the CEM system. The Level III inspection involves a complete evaluation of the monitoring system through a dynamic calibration procedure. Multiple concentration gases are injected, as close to the probe tip as possible, and the monitor response is compared to the certified gas values. From this evaluation, a calibration error is determined. If the error falls outside calibration drift performance specification values, then the monitoring system is "out-of-control." This would necessitate some form of corrective action.

3.2 CYLINDER GAS AUDIT

Check
or
Comment

- 3.2.1 Attach the proper gas line from the certified gas cylinder to as close to the probe tip as possible. Properly adjust the flow rate to manufacturers' specifications.

3.2.2 List Certified Gases

Gas Mixtures:

Pollutant

TRS O₂ Other

Gas A _____ppm/%

Cylinder No. _____

Certification Date _____

Pressure (psi) Initial Final

Gas B _____ppm/%

Cylinder No. _____

Certification Date _____

Pressure (psi) Initial Final

Gas C _____ppm/%

Cylinder No. _____

Certification Date _____

Pressure (psi)
 Initial Final

Check
or
Comment

3.2.3 Inject each gas into the monitoring system, as close to the probe tip as practical. Record monitor response on Level III Field Data Sheet. _____

3.2.4. Calculate % Difference for each calibration gas by the following equation: _____

$$\% \text{ Difference} = \left[\frac{(\text{Avg. Monitor Response}) - (\text{Audit value})}{(\text{Audit Value})} \right] \times 100$$

LEVEL III
FIELD DATA SHEET
PERCENT DIFFERENCE DETERMINATION

Person Conducting Audit _____ Affiliation _____ Date _____		Analyzer Manufacturer _____ Model/Serial No. _____ Location _____			
<u>Audit Gas Concentration</u> Low-Range _____ Mid-Range _____ High-Range _____		<u>Pollutant</u> _____ _____ _____		<u>Certification Date</u> _____ _____ _____	
		<u>Expiration Date</u> _____ _____ _____			
Run Number	Audit Gas Concentration	Instrument Response	Arithmetic Difference		
			Low	Mid	High
1-Low				-	-
2-Mid			-		-
3-High			-	-	
4-Low				-	-
5-Mid			-		-
6-High			-	-	
7-Low				-	-
8-Mid			-		-
9-High			-	-	
10-Low				-	-
11-Mid			-		-
12-High			-	-	
13-Low				-	-
14-Mid			-		-
15-High			-	-	-
		Arithmetic Mean			

3.3 MONITOR-SPECIFIC INSPECTION PROCEDURES

If calibration gases are not available, the inspector can evaluate the installed TRS CEM system through monitor-specific inspection procedures. This involves observing various operating parameters as indicated by valves, meters, pressure gauges or switches. Observed values are then referenced to the "baseline" values established during monitor certification.

To assist the inspector, monitor-specific inspection procedures have been developed for three commercially available TRS monitoring systems. They are:

- o Sampling Technology Inc. TRS CEM Model 100;
- o Barton Titration TRS CEM System; and
- o Bendix Gas Chromatograph TRS CEM System.

To insure that all information is obtained in an orderly fashion, the procedures are presented in the order they are normally encountered in the field, i.e., analyzer/computer system; calibration system, transfer system and probe/conditioning system.


3.3.1 SAMPLING TECHNOLOGY INC. TRS CEM SYSTEM INSPECTION PROCEDURES

3.3.1.1 Analyzer Evaluation

Pulse Fluorescence Analyzer

Check Comment

- o Observe reading of SO₂ as displayed in window (reading is % of monitor range). Compare to CRT display and computer printout. (Review diagram for inspection points)



- o Observe that "on" light is illuminated.
- o Check positions of zero/span pots (potentiometer) and compare to maintenance logs.

O₂ Analyzer

- o Observe meter display and compare to CRT and computer printout.
- o Note position of "Range" switch.

Range

- o Note "sample flow" as indicated by rotameter. (Should be between 400-500 cc/min).

cc/min

	<u>Check</u>	<u>Comment</u>
<u>Computer</u>		
o Observe that power light (yellow) on key board is flashing.	_____	_____
o Observe that power light (red) on screen display is on.	_____	_____
o Observe that printer "power on light" is illuminated.	_____	_____
o Observe that screen "format" is updated every 4-6 seconds.	_____	_____
o Observe last computer readouts of TRS and O ₂ and compare to instantaneous values as displayed on monitor meters.		

TRS	O ₂
_____	_____
_____	_____
meter	meter

- | | | |
|---|-------|-------|
| o Observe previous 12 hour report (see sample). | _____ | _____ |
|---|-------|-------|

TRS 12 HOUR REPORT - 12:00:48 JULY 11 1984

12 HOUR [TRS/O₂ CORRECTED] AVERAGE VALUE (PPM)

RCVY BLR TRS	TRS	O ₂
00:00 TO 01:00	.3	5.2
01:00 TO 02:00	.3	5.0
02:00 TO 03:00	.3	5.0
03:00 TO 04:00	.3	4.8
04:00 TO 05:00	.3	4.7
05:00 TO 06:00	.2	5.2
06:00 TO 07:00	.2	5.2
07:00 TO 08:00	.3	5.7
08:00 TO 09:00	0.0	0.0
09:00 TO 10:00	0.0	0.0
10:00 TO 11:00	2.3	6.9
11:00 TO 12:00	.1	14.8
UNCORRECTED TRS AVERAGE	.5	
O ₂ CORRECTED TRS AVERAGE	.4	
O ₂ AVERAGE	6.2	

where:

- C_{corr} = the average concentration corrected for oxygen;
 C_{meas} = the average concentration uncorrected for oxygen for previous 12-hours;
 X = the volumetric oxygen concentration in percentage to be corrected to (8 percent for recovery furnaces and 10 percent for lime kilns, incinerators, or other devices); and
 Y = the measured 12-hour average volumetric oxygen concentration.

Check Comment

- o Review previous 24-hour printouts observing stack gas concentration variation and consistency.
- o Review previous 24 hour calibration drift report and compare to plant standard. (See printout below).

- o Initiate an internal "zero/span" check or monitor system. Compare to gas cylinder valves.

TRS

O₂

Gas cylinder
valves

Gas cylinder
valves

Monitor response

Monitor response

% Off

% Off

- o Request "Limits Factors" and compare to plant limits.

- o O₂ STD _____
- o TRS _____
- o O₂ cal gas valve _____

Check Comment

Dilution Air Conditioning System

- o Open cabinet door. _____
- o Insure pump is running with 30 lbs pressure. _____
- o Air pressure regulator should indicate 60 lbs pressure. _____
- o Listen to insure regenerative dryer working properly. _____

Calibration Gas Cylinder

- o Check certification of gas cylinders valves and compare to maintenance logs and computer printout. _____
- o Check cylinder numbers and compare to certification sheets. _____
- o Observe primary/secondary pressure gauge and note setting. (Normal settings should be 300 psi primary and 40 psi secondary). _____

Gas Cylinder #1

Concentration _____
 Certificate date _____
 Gauge settings _____

Primary _____
 Secondary _____

Gas Cylinder #2

Concentration _____
 Certificate date _____
 Gauge settings _____

Primary _____
 Secondary _____


Recorder

- o Observe emissions over previous day. _____
- o Inspect previous zero/span readings and compare to gas cylinder valves. _____


	Check	Comment
<u>3.3.1.2 SO₂ Scrubber System (located behind monitor racks)</u>		
o Check moisture level in reservoir.	_____	_____
o Observe that scrubber is regenerating in a timely fashion (15 minutes).	_____	_____
o Review maintenance logs for possible drift problems associated with scrubber system.	_____	_____
<u>Positive Drift</u> - Release of SO ₂ from packing.	_____	_____
<u>Negative Drift</u> - Retention of SO ₂ during daily zero/span check.	_____	_____
o Review maintenance logs for periodic changing scrubber sieves (30 day intervals).	_____	_____
<u>Thermal Oxidizer</u>		
o Check temperature display on front of panel. Should be between 1500-1600°F. (825-875°C).	_____	_____
o Observe that power light is on.	_____	_____
o Review maintenance logs for periodic adjustments of thermal oxidizer temperature.	_____	_____
<u>Analyzer Rack</u>		
o Check for power on.	_____	_____
o Check all pressure regulators and relate setting to initial monitor certification setting in maintenance logs.	_____	_____
o Check sample by-pass rotameter (should be 1-2 lpm. However, this number depends upon length of sample line. Initial valve should be recorded in log book during certification testing).	_____	_____
<u>Switch Central Panel</u>		
o Check to see all switches are in "auto" position.	_____	_____
o Observe if any red lights are lit indicating operating mode.	_____	_____

3.3.1.3 Probe/Conditioning System

The inspection of the probe/conditioning system involves both a review of the maintenance logs and a physical inspection of the unit itself. (Refer to the following diagram for inspection points).



	Check	Comment
o Observe overall condition of system.	_____	_____
Vibration Problems	_____	_____
Temperature Problems	_____	_____
Other _____	_____	_____
o Open cabinet and observe internal housekeeping.	_____	_____
Loose wires	_____	_____
Condenser dirty	_____	_____
Other _____	_____	_____
o Cal gas introduced at probe.	_____	_____
o Observe "back-purge" if applicable. Check drain for air/water.	_____	_____
o Observe automatic calibration cycle. (during automatic calibration cycle, the cal gas is under positive pressure to probe). If a leak in the system occurs, then the O ₂ valve will never reach zero.	_____	_____
o Check "Fault Indicators" on probe controller box. Note. (Refer to following diagram for fault indicator location).	_____	_____
<u>Indication</u> <u>On/Off</u>	_____	_____
Power	_____	
Enclosure Temperature	_____	
Vaporizer Temperature	_____	
Probe Restriction	_____	
Air Pressure	_____	




Check Comment

- | | | |
|--|-------|-------|
| o Check water level in liquid resevoir, (should not be greater than one-fourth of bowl). | _____ | _____ |
| o Check steam panel regulator (should be between 20-30 psi). | _____ | _____ |
| o Check maintenance records for periodic maintenance on system. | _____ | _____ |
| o Inertial filter changes _____ | | |
| Lime Kiln (2-4 weeks) | _____ | _____ |
| Recovery Boiler (monthly) | _____ | _____ |
| o Eductor removed/cleaned periodically | _____ | _____ |

3.3.2 ITT BARTON TITRATION TRS CEM SYSTEM INSPECTION PROCEDURES

3.3.2.1 Sampling Module (Refer to following figure for inspection points).




Check Comment

- o Observe pressure of condensate resevoir regulator.

15 psi


- o Observe LED is lit on panel of heat trace line controller.
- o Observe "reading" of heat-trace line controller as displayed by meter.
(Temperature indication should be 10-20°F higher than the dew point of the sample gas).

Titration Module (Refer to following figure for inspection points).



	Check	Comment
o Insure the SO ₂ scrubber solution is at the 500 ml mark.	_____	_____
o Insure the titration cell reservoir is between stamped lines on cell.	_____	_____
o Observe following setting of regulators.	_____	_____
o Vortex tube supply _____		
80-120 psi		
o Aspirator Pressure _____		
35-50 psi		
o Purge pressure regulator _____		
5-10 psi		
o Check high volume pump operation by observing flow at pump vent point.	_____	_____
o Verify heater operation by observing orange glow of the element through the observation point.	_____	_____
o Observe flowmeter setting and compare to calibration sheet to insure sample flow of 250 cc/mm.	_____	_____

Control Module (Refer to following figure for inspection points).



	Check	Comment
o Observe range switches. Note range monitor is on.	_____	_____
<u>Range</u>		
o Note settings from zero/span/blank. Compare to historical data.	_____	_____
Zero	<u>present</u>	<u>previous</u>
Span	<u>present</u>	<u>previous</u>
Blank ADJ	<u>present</u>	<u>previous</u>
o Observe mode switches. Note which mode switch is illuminated.	_____	_____
<u>Mode</u>		

The mode switches (TRS, BLK, CELL CAL and AUTO) determine the characteristics of the sample reaching the detector cell. The mode switch functions are listed in the following Table.

SWITCH	SAMPLE CHARACTERISTIC
PWR OFF	Instrument power ON/OFF.
TRS	Sample gas passes through SO ₂ scrubber, remainder oxidized to SO ₂ .
BLK	Ambient air passes through the charcoal filter.
CAL	Calibration gas injected at probe.
CELL CAL	Calibration gas injected just before cell.
AUTO	Automatically cycles instrument through modes.

o Press RAW DATA switch and REC CHK switch simultaneously. The recorder should go to min-scale. (Failure to do so indicates the existence of a program in either the recorder or the control power supply).	_____	_____
---	-------	-------

RAW DATA Function

o Measure the raw data value in the BLANK mode.	_____	_____
<u>RAW DATA</u>		
o Is it within value range?	_____	_____
_____ No _____ Yes		

Check Comment

- o Measure the raw data values in either the TRS or CAL mode.

TRS/CAL
value

- o Subtract the lowest from the highest value.
- o Observe range switch setting.
- o From the following Table, obtain SO₂ conversion factor.

Conversion Factor Data

<u>RANGE SWITCH</u>	<u>SO₂ CONVERSION FACTOR</u>	<u>UNITY GAIN FULL SCALE</u>	<u>FULLSCALE RANGE</u>	<u>RAW DATA BLANK READING</u>
1	0.035	3.5	1.0-5.0	20 \pm 8
2	.82	8.2	5-15	12 \pm 4
3	.26	26.	15-50	6 \pm 3
4	.75	75.	50-150	3 \pm 1.5
5	2.5	250.	150-500	2 \pm .5
6	7.1	710.	500-1000	1.5 \pm .8
7	23.	2300.	1000-3000	0.7 \pm .4

- o Calculate concentration by multiplying difference between sample and blank values by the SO₂ conversion factor.

$$\begin{aligned} \text{ppm} &= (\text{Sample Raw Data} - \text{Blank Raw Data}) \times \text{Conversion Factor} \\ &= (\quad - \quad) \times (\quad) \\ &= \end{aligned}$$

Value determined should be within \pm 15%.

- o Press CELL CAL mode switch.
- o Note monitor response and compare to gas cylinder value.

Monitor Response

Gas Cylinder Value


- o Calculate % calibration error by the following equation.

$$\frac{(\text{Monitor Response}) - (\text{Gas Cylinder Response})}{(\text{Gas Cylinder Response})} \times 100$$

- o Calculated value should be \pm 15%.

3.3.2.2 Probe/Conditioning System

The inspection of the probe/conditioning system involves both a review of the maintenance logs and a physical inspection of the unit itself. (Refer to following diagram for inspection points).



Check Comment

- o Observe overall condition of system.

Vibrational Problems _____

Temperature Problems _____

Other _____

- o Open cabinet and observe internal housekeeping.

Check Comment

Loose wires _____
 Condenser trap dirty _____
 Other _____

- o Observe condensate reservoir, if possible
 Observe emptying of condensate trap during
 "blank" mode of operation.

- o During calibration mode, insure that
 calibration gas injection solenoid valve
 opens.

- o Is condensate trap frozen?


- o Observe that system back purges
 periodically.

- o Note whether sample line is heat traced.

3.3.3 BENDIX TRS CEM SYSTEM INSPECTION PROCEDURES

3.3.3.1 Analyzer/Calibration Assemblies

The inspection of the above assemblies involves observing gauges/flowmeters and comparing their indicated values to their "baseline" values. The observed values may change from week to week; but, reference should be made back to the "baseline" value. The following figure illustrates the assemblies we will be inspecting.



Calibration Gas Cylinder

- o Check certification of gas cylinders values and compare to maintenance logs and computer printout. _____
- o Check cylinder numbers and compare to certification sheets. _____
- o Observe primary/secondary pressure gauge and note setting. (Normal settings should be ~ 300 psi primary and ~ 40 psi secondary). _____
- o Note following information on each gas cylinder. _____

Gas Cylinder #1

Pollutant _____
 Concentration _____
 Certificate date _____
 Gauge settings _____

Primary _____
 Secondary _____

Gas Cylinder #2

Pollutant _____
 Concentration _____
 Certificate date _____
 Gauge settings _____

Primary _____
 Secondary _____

Gas Cylinder #3

Pollutant _____
 Concentration _____
 Certificate date _____
 Gauge settings _____

Primary _____
 Secondary _____

Gas Cylinder #4

Pollutant _____
 Concentration _____
 Certificate date _____
 Gauge settings _____

Primary _____
 Secondary _____


Gas Cylinder #5

Pollutant _____
 Concentration _____
 Certificate date _____
 Gauge settings _____

Primary _____
 Secondary _____

Support Assembly


Observe the following gauges/meters as part of the Support Assembly. All observations should be referenced to "baseline" values. (Refer to diagram for inspection points).



	Baseline Value	Observed Value
Sweep Air Flowmeter (A)	_____	_____
Sweep Air Pressure Gauge (B)	_____	_____
Plant Air Pressure Gauge (C)	_____	_____

Calibration Assembly


Observe the following gauges/meters as part of the Calibration Assembly. All observations should be referenced to "baseline" values. (Refer to diagram for inspection points).



	Baseline Value	Observed Value
Zero Air Pressure Gauge	_____	_____
Nitrogen Pressure Gauge	_____	_____
Calibration Gas Pressure Gauge	_____	_____
Oxygen Pressure Gauge	_____	_____
Dilution Pressure Gauge	_____	_____
Other	_____	_____

Sample Transport Assembly

Observe the following gauges/meters as part of the Sample Transport Assembly. All observations should be referenced to "baseline" values. (Refer to diagram for inspection points).



(Dual Gas Stream System Illustrated)

	Baseline Value	Observed Value
Oxygen Sample Flowmeter (D)	_____	_____
Gas Chromatograph Sample flowmeter (E)	_____	_____

Analyzer Controls and Indicators

Observe the following gauges/meters as part of the Analyzer Controls and Indicator Assembly. All observations should be referenced to "baseline" values.

	<u>Baseline Value</u>	<u>Observed Value</u>
Detector Purge Gauge	_____	_____
Plant Air Supply Gauge	_____	_____
Heater Air Pressure Gauge	_____	_____
S/P Valve Switch On	_____	_____
Hydrogen Supply Gauge	_____	_____
Column #1 Pressure Gauge	_____	_____
Column #2 Pressure Gauge	_____	_____
Analyzer Oven Temperature Gauge	_____	_____
Calibration Pump Gauge	_____	_____
Other	_____	_____
Other	_____	_____

Gas Chromatograph System

Type: _____ Detection Technique: _____

Column 1. _____

2. _____

3. _____

Column Temperature ($\pm 1^{\circ}\text{C}$) 1. _____

2. _____

3. _____

Sample Column Size: _____

Detection Temperature: _____

Attenuation: _____

Data Processor/Recorder

Check Comment

o Observe emissions over previous day. _____

o Consistent values? _____

o Exceedances? _____

o Problems? _____

o Inspect previous zero/span calibration readings and compare to gas cylinder values. _____


Check Comment

- o Initiate an internal "zero/span" check of the monitor system.
Compare to gas cylinder values.

Cylinder Values	Monitor Response	% Calibration Error
H ₂ S _____	_____	_____
CH ₃ SH _____	_____	_____
(CH ₃) ₂ S _____	_____	_____
(CH ₃) ₂ S ₂ _____	_____	_____

(Are the calculated calibration errors < 20%?)

(A typical chromatograph of a zero/span check is illustrated below).



During the calibration, observe software report as recorded by the Data Printer. A "typical" printout follows:

	TRS COR (PPM)	TRS MEAS (PPM)	H2S (PPM)	CH3SH (PPM)	DMS (PPM)	DMS (PPM)	O2 (%)	OPACITY (%)
STACK #1								
CALCULATED (PLANT 2)	200.	199.	100.	33.00	33.00	34.00	10.1	13.6
STACK #2								
LINE RTLM (PLANT 2)	199.	189.	100.	32.00	33.00	34.00	10.1	21.2

GC CALIBRATION REPORT

DATE 1/21/79 00106104

INUT 0001 STACK #1

COMP	RT	OLD RF	NEW RF	(RF)ZVAR	CC	% DRIFT
H2S	150	1.65	1.64	.6%	27	.5%
CH3SH	220	3.87	3.85	.5%	27	.3%
DMS	290	5.68	5.68	0%	27	.05%
DMS	410	7.12	7.13	.01%	27	.1%

o Observe if any hardware/software alarms have been observed over the previous 24 hours.

Typical hardware alarms include the following:

- o Low Zero Gas
- o Low TRS Span Gas
- o Low O₂ Span Gas
- o Low Plant Air
- o Low Sweep Air
- o Probe Restriction

Chromatograph related hardware alarms are:

- o Low Carrier Gas
- o Low hydrogen
- o Oven Hi
- o Oven Lo
- o Low Purge Air
- o Flameout

Optional system alarms are:

- o Low Sample Flow
- o Low Sample Pump Vacuum

	Check	Comment
3.3.3.2 <u>Probe/Conditioning Assembly</u>		
o Observe overall condition of system.	_____	_____
Vibration Problems	_____	_____
Temperature Problems	_____	_____
Other _____	_____	_____
o Open cabinet and observe internal housekeeping.	_____	_____
Loose wires _____	_____	_____
Condenser dirty _____	_____	_____
Other _____	_____	_____
o Cal gas introduced at probe?	_____	_____
o Observe "back-purge" if applicable. Check drain for air/water.	_____	_____
o Observe automatic calibration cycle, (during automatic calibration cycle, the cal gas is under positive pressure to probe. If a leak exists, then the O ₂ valve will never reach zero during cal gas introduction.	_____	_____
o Listen for air flow to heat exchanger.	_____	_____
o Observe reading of Dew Point meter, if applicable.	_____	_____
o Go to opposite side of port and observe probe.	_____	_____

4.0 LEVEL IV CHECKLIST

4.1 Introduction

A Level IV evaluation involves a recertification of the installed CEM system utilizing Performance Specification Test 5 and 3. The role of the inspector during this level is to observe that proper sampling and computation of emissions from the source during testing occurs. At this time, additional "baselining" of the control equipment and continuous emission monitoring system can be performed.

To assist the inspector, observation checklists have been developed for both Federal Reference Method 16 and 16A. The inspector should use these checklists when performing a Level IV evaluation.

.

Federal Reference Method 16
Observation Checklist

Federal Reference Method 16
Observation Checklist

1.0 BACKGROUND INFORMATION

- 1.1 Source Name: _____
- 1.2 Location: _____
- 1.3 Affected Facility: _____
- 1.4 Test Dates: _____
- 1.5 Test Team: _____
- Leader: _____
- Members: _____
- 1.6 Plant Contact: _____
- 1.7 Corporate Contact: _____
- Phone # _____
- Title _____

2.0 PROCESS DATA

- 2.1 Process Tested: _____
- 2.2 Process Description: _____
- _____
- 2.3 Process Operating Data: _____
- _____

3.0 TEST EQUIPMENT

- 3.1 Sketch system used for sampling and analysis (including calibration system).

Initial

3.2 - TEST EQUIPMENT DESCRIPTION

3.2.1 Probe/SO₂ Scrubber System

3.2.1 Probe

Length: _____ ID: _____

Material of Construction: _____

Filter Device: Out-of-stack _____

In-Stack _____

Material _____

Heated? _____

3.2.1.2 SO₂ Scrubber

Impinger Technique: _____

Solution: _____

pH of Solution: _____

3.2.2 Sample Lines/Pump

3.2.2.1 Lines:

I.D.: _____ O.D.: _____

Material of Construction: _____

Heated? _____

3.2.2.2 Pump

Type: _____

Material of Construction: _____

Heated: _____

3.2.3 - Dilution System

Technique: _____

Dilution Ratio: 1. _____ 2. _____ 3. _____

Dilution Gas: _____

Heated? _____

3.2.4 - Gas Chromatograph System

Type: _____ Detection Technique: _____

Column 1. _____

2. _____

Column Temperature (+ 1°C) 1. _____

2. _____

3. _____

Sample Column Size: _____

Detection Temperature: _____

Attenuation: _____

Gas Flow:

H₂ Flow: _____

Air Flow: _____

N₂ Flow: _____

Accuracy Range: _____

Detect 0.5 ppm for H₂S, MeSH, DMS and DMDS? _____

3.2.5 - Calibration System

3.2.5.1 - Permeation Technique

Pollutant	Certification Number	Permeation Rate	Certification Temperature	Traceability Technique
<u>H₂S</u>	_____	_____	_____	_____
<u>MeSH</u>	_____	_____	_____	_____
<u>DMS</u>	_____	_____	_____	_____
<u>DMDS</u>	_____	_____	_____	_____
Analysis Date	Vendor			
_____	_____			
_____	_____			
_____	_____			

H₂S = Hydrogen Sulfide; MeSH = Methyl Mercaptan; DMS = Dimethyl Sulfide;
 DMDS = Dimethyl Disulfide

Initial _____

Remarks: _____

Constant Temperature Bath ($\pm 1^\circ\text{C}$) of Permeation Tube Certification Sheet _____

Flowmeter Calibrated? _____

Date _____

Calibration Curve _____

Flow of Calibration System greater than demand of Analytical System? _____

Bubble Meter used to monitor flow? _____

Temperature indicator calibrated? _____

Carrier gas prepurified? _____

Discuss _____

Diluent Gas - 50ppb S compounds? _____

10ppm each of H_2O and HC: _____

Heated prior to mixing? _____

3.2.5.2 - Cylinder Gases

Pollutant (in Air)	Concentration	Traceability to NBS Per- meation tube	Analysis Date	Expiration Date
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

Remarks _____

Initial

Greater than 200 psi in gas cylinders?_____

Vent valve utilized?_____

3.2.6 - Integrator or Recorder

Type:_____

Averaging Time:_____

Attenuation:_____

Last calibration:_____

4.0 - SAMPLE PORT LOCATION

Stack/Duct Conditions (leaks, particle build-up, corrosion):

Number of stack diameters upstream from flow disturbance:_____

Number of stack diameters downstream from flow disturbance:_____

Velocity Traverses Performed:_____

Number of points_____

Location_____

Avg. Δp _____

Pitot tube calibration factor_____

Date Calibrated_____

Avg. Velocity_____

Stack Temperature Sensor:

Type:_____ Range:_____

Location in Stack:_____

Date Calibrated:_____ Calibration Papers Rec'd_____

Remarks:_____

Initial

Location of CEM in reference to Sample Port Location:_____

5.0 PRE-TEST ACTIVITIES

System set-up properly?_____

System leak check (optional)_____

2 inches Hg Vacuum for 1 minute_____

Pass_____ Failed _____

All components operating properly_____

Discussion:_____

Pre-Test Recovery Determined (optional)_____

Discussion:_____

5.1 Interference Determination

Chromatograph submitted of calibration gases with/without
10% CO₂?_____

Agreement within 5%_____

Chromatograph submitted showing separation of SO₂ from other
peaks?_____

or

SO₂ Scrubber System used to remove SO₂ prior to GC analysis

Initial _____

Chromatograph submitted showing resolution of Sulfur Dioxide (SO₂), Hydrogen Sulfide (H₂S), Methyl Mercaptan (MeSH), Dimethyl Sulfide (DMS) and Dimethyl Disulfide (DMDS): _____

Discussion: _____

5.2 Calibration of GC/FPD and Dilution System

5.2.1 GC/FPD Calibration through SO₂ Scrubber Dilution System prior to calibration? _____

Permeation tubes in bath 24 hours? _____

Calibration Curve developed from three injections of three known concentrations of H₂S, MeSH, DMS, and DMDS? _____

Calibration Curve developed in range data is being collected? _____

Precisions of injections for each known TRS within $\pm 5\%$ of mean value? _____

Temperature of bath $\pm 0.1^\circ\text{C}$ of certification tube temperature _____

Calibration Curve Generated? _____

5.2.2 Dilution System

Injection of H₂S in front of Dilution System? _____

Three injections? _____

Precision of three injections $\pm 5\%$ of mean value? _____

Dilution factor calibrated for each stage? _____

Stage 1 Factor _____

Stage 2 Factor _____

6.0 STACK TEST

Port closed around probe? _____

Initial

Sample traversed at three points in source (16.7, 50.0 and 83.3%)
of stack diameter?_____

Sampling System conditioned 15 minutes prior to test?_____

Sample run consists of a min. of 16 individual injections performed
over a period of not less than 3 hours or more than 6 hours?_____

Discussion:_____

Orsat collected during sample run?_____

Orsat collection technique and location_____

GAS CHROMATOGRAPH INFORMATION

	Run 1	Run 2	Run 3
Date	_____	_____	_____
Time Began	_____	_____	_____
Time End	_____	_____	_____
No. of Injections or Analysis (min 16)	_____	_____	_____
Ave H ₂ S conc, ppm	_____	_____	_____
Ave MeSH Conc, ppm	_____	_____	_____
Ave DMS conc, ppm	_____	_____	_____
Ave DMDS Conc, ppm	_____	_____	_____
Ave TRS Conc, ppm as SO ₂	_____	_____	_____
Concentration of trace gas	_____	_____	_____
Ave O ₂ Conc, %	_____	_____	_____

Initial

7.0 - POST TEST PROCEDURES

7.1 - Sample Line Loss - Correction Factor Known concentration of H₂S injected as close to probe tip as possible? _____Concentration of H₂S generated at level of standard (+ 20%)? _____H₂S Generated By:

Permeation System _____

Cylinder Gas Dilution _____

% Recovery

20% _____ (Sample run not to be used)

20% _____ (Sample run corrected)

Recovery Correction Factor _____

7.2 - Recalibration of GC/FPD and Dilution System

7.2.1 - GC/FPD

Known concentration of H₂S injected into GC/FPD? _____

Compared to original calibration curve? _____

Calibration Drift + 10%? _____

Highest sample values chosen if calibration drift 10% _____

Discussion: _____

Initial

7.2.2 - Dilution System

Known concentration of H₂S injected into front of Dilution System? _____

Compared to original calibration curve? _____

Calibration Drift ± 10%? _____

7.3 - LEAK CHECK

Sampling system leak checked? _____

Technique? _____

8.0 - CALCULATIONS

Individual concentrations of H₂S, DMS, DMDS and MESH Recorded?
(Oxygen Corrected)

	Run 1 (avg. ppm)	Run 2 (avg. ppm)	Run 3 (avg. ppm)
H ₂ S	_____	_____	_____
MeSH	_____	_____	_____
DMS	_____	_____	_____
DMDS	_____	_____	_____
Total	_____	_____	_____

Initial

9.0 - RELATIVE ACCURACY

9.1 Calculation

	TRS (ppm)		
	Run 1	Run 2	Run 3
Reference Method	_____	_____	_____
TRS Conc. (%O ₂ corrected)	_____	_____	_____
CEM TRS Conc. (%O ₂ Corrected)	_____	_____	_____
Difference	_____	_____	_____
Avg. Differences	_____	_____	_____

$$9.2 \% \text{ Relative Accuracy} = \frac{1x1 + C.I.95\%}{[RMavg]} \times 100$$

$$= \text{_____} (\text{ } 20\%)$$

10.0 - SUMMARY

Are final results expressed in units which satisfy permit or Agency requirements? _____

Does tester have documentation to support emission calculations (only required on smelt dissolving tank vents)? _____

Initial

Brief Summary of Test:_____

11.0 - AUTHORIZATION

11.1 - Regulatory Observer

Observer Signature_____

Title_____

Organization_____

Address_____

Telephone # () _____

11.2 - Company Observer

Company Observer Signature_____

Title_____

Telephone # _____

TOTAL REDUCED SULFUR
FIELD CALIBRATION DATA SHEET
FEDERAL REFERENCE METHOD 16

Company _____ Date _____

Address _____ Analyst _____

_____ Sampling Location _____

Company Contact _____

I. Permeation Tube Information

Information	Pollutant			
	H ₂ S	CH ₃ SH	(CH ₃) ₂ S	(CH ₃) ₂ S ₂
Tube I. D. #:				
Permeation Rate (PR)				

II. Calibration Curve

Point #1

Time _____
Flow (Q) _____
Known Concentration
(ppm) _____
H₂S: _____
CH₃SH: _____
(CH₃)₂S: _____
(CH₃)₂S₂: _____

Avg.

	Area			
1				
2				
3				
Avg.				

Point #2

Time _____
Flow (Q) _____
Known Concentration
(ppm) _____
H₂S: _____
CH₃SH: _____
(CH₃)₂S: _____
(CH₃)₂S₂: _____

Avg.

	Area			
1				
2				
3				
Avg.				

Point #3

Time _____
 Flow (Q) _____
 Known Concentration
 (ppm) _____
 H₂S: _____
 CH₃SH: _____
 (CH₃)₂S: _____
 (CH₃)₂S₂: _____

	Pollutant Area			
	H ₂ S	CH ₃ SH	(CH ₃) ₂ S	(CH ₃) ₂ S ₂
1				
2				
3				
Avg.				

III. Equation

$$c = \frac{(PR) \left(\frac{24.46 \mu\ell/\mu\text{-mole}}{(M) \mu\text{g}/\mu\text{-mole}} \right) \left(\frac{T^{\circ}K}{298^{\circ}K} \right) \left(\frac{760 \text{ mm Hg}}{P \text{ mm Hg}} \right)}{Q \ell/\text{min}}$$


Where: *c* = concentration, $\mu\ell/\ell$ or ppm by volume
T = temperature of the system, $^{\circ}K$
P = pressure of the system, mm Hg
PR = permeation rate, $\mu\text{g}/\text{min}$
Q = total flow rate, liters/min
M = molecular weight of the permeating gas, $\mu\text{g}/\mu\text{-mole}$
 24.46 = molar volume (\bar{V}) of any gas at 25°C & 760 mm Hg, $\mu\ell/\mu\text{-mole}$

c = _____

IV. Remarks: _____

V. Graph Calibration Curve

Using the graph paper below, graph either the peak area, peak height or available integrator information for each of the individual sulfur standards vs. concentration. Draw the best fit line through the plotted points and determine source sample concentration from the established calibration curve.



Federal Reference Method 16A
Observation Checklist

Federal Reference Method 16
Observation Checklist

1.0 BACKGROUND INFORMATION

1.1 Source Name:_____

1.2 Location: _____

1.3 Affected Facility:_____

1.4 Test Dates:_____

1.5 Test Team:_____

Leader:_____

Members:_____

1.6 Plant Contact:_____

1.7 Corporate Contact:_____

Phone # _____

Title _____

2.0 PROCESS DATA

2.1 Process Tested:_____

2.2 Process Description:_____

2.3 Process Operating Data:_____

3.0 TEST EQUIPMENT

3.1 Sketch system used for sampling and analysis (including calibration system).

Initial

4.0 SAMPLE PORT LOCATION

4.1 Stack/Duct Conditions (leaks, particle build-up, corrosion):

4.2 Number of stack diameters upstream from flow disturbance:_____

4.3 Number of stack diameters downstream from flow disturbance:_____

4.4 Velocity Traverses Performed:_____

Number of points_____

Location_____

Avg. Δp _____

Pitot tube calibration factor_____

Date Calibrated_____

Avg. Velocity_____

4.5 Stack Temperature Sensor:

Type:_____ Range:_____

Location in Stack:_____

Date Calibrated:_____ Calibration Papers Rec'd_____

4.6 Remarks:_____

_____4.7 Location of CEM in reference to sample port location_____

5.0 SAMPLE TRAIN PREPARATION

5.1 - Probe

Material of Construction_____

Heated?_____ Temperature_____

5.2 - SO₂ Scrubber System

Type_____

Citrate Acid Buffer Added?_____

Initial

pH of Solution _____

Location of Probe? _____

5.3 - Oxidizing Furnace

Type _____

Material of Construction _____

Tube Dimensions _____

Temperature _____

5.4 - SO₂ Impinger Train

Type _____

Hydrogen Peroxide added to Impingers ? _____

Quantity _____

Glass Wool plug used? _____

5.5 - Dry Gas Meter

Type _____

Volume _____

Correction Factor _____

Date Calibrated _____

Calibration Papers Revised? _____

Temperature Measured? _____

6.0 PRE-TEST ACTIVITIES

6.1 - Pre-test leak check (optional)

6.1.1 Complete sampling train checked: _____

6.1.2 Vacuum of 10 inches mercury? _____

Initial

6.1.3 Leak rate 40 cc/min? _____

6.1.4 Pump leak checked? _____

6.2 - System Performance Check

6.2.1 Sketch sampling train and gas dilution system.

6.2.2 List gases available, concentration, traceability, analysis date, expiration date and gas cylinder pressure (include information in both calibration gas and diluent gas).

Initial

<u>Pollutant</u>	<u>Concentration</u>	<u>Traceability</u>	<u>Analysis Date</u>	<u>Expiration Date</u>	<u>Cylinder Pressure</u>
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

6.2.2.1 Diluent gases contain 50 ppb total sulphur compound and
10ppm

6.2.2.2 Total HC? _____

6.2.2.3 Calibration gases verified by Reference Method 11, GC/FPD
or zinc acetate technique _____

6.2.2.4 Rotometers used in dilution system calibrated? _____

6.2.2.5 Dry gas meter used in Dilution System calibrated? _____

6.2.2.6 Flows measures by bubble meter? _____

6.2.2.7 Concentrations generated? _____

6.2.3 System Performance Check Form

6.2.3.1 Two thirty minute samples taken? _____

Date _____

Run I.D. _____

Time Began _____

Time Ended _____

Dry Gas Meter Volume _____

Initial

Volume of Solution (mm l)	_____	_____	_____	_____
Volume of Solution Titrated (mm l)	_____	_____	_____	_____
Volume of Titrant (mm l)	_____	_____	_____	_____
Normality of Titrant	_____	_____	_____	_____
Conc. H ₂ S Determined	_____	_____	_____	_____
Conc. H ₂ S Generated	_____	_____	_____	_____
% Recovery	_____	_____	_____	_____

6.2.3.2 Within $\pm 15\%$ of generated H₂S _____6.2.3.3 Two 30-minute samples within $\pm 5\%$ of their mean value? _____

6.2.3.4 Notes/Remarks: _____

Initial7.0 SAMPLING

7.1 - General

7.1.1 Leak check performed after system performance check?_____

7.1.2 Sample extraction involving either: (1) three one hour samples at 20 liters/min?_____

(2) One three hour sample of 120 liters intermittently or continuous_____

7.1.3 Sampling involves traversing stack?_____

7.1.4 Oxidizing furnace maintained at 850°C?_____

7.1.5 Citrate buffer solution adequate?_____

[Note: The citrate buffer solution volume may change during sampling due to condensed water from sample stream and gas flow rate.]

7.2 - Field Data Required?

Date _____

Run I.D. _____

Time Began _____

Time Ended _____

Avg. Rotameter reading _____

Avg. Dry Gas Temperature _____

Dry Gas Meter volume (ft.) _____

7.2.1 Sampling rate performed 2.0 liters/minutes (± 10%)?_____

7.2.2 Post-Test leak check performed?_____

Initial

7.2.3 Impingers containing hydrogen peroxide recovered? _____

- sample recovery bottle labeled? _____

- fluid level indicated on side of bottle? _____

7.2.4 Probe/Sample line to SO₂ scrubbers rinsed after each run?

8.0 - SAMPLE RECOVERY TEST

8.1 - General

8.1.1 Was a leak test performed prior to the sample recovery test? _____

8.1.2 Were SO₂ impingers re-charged with hydrogen peroxide?

List gases available, concentration, traceability, analysis date, expiration date, date and gas cylinder pressure (include information in both calibration gas and diluent gas):

<u>Pollutant</u>	<u>Concentration</u>	<u>Traceability</u>	<u>Analysis Date</u>	<u>Expiration Date</u>	<u>Cylinder Pressure</u>
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

8.1.3 Diluent gases contain \leq 50 ppb total sulfur compound?

8.1.4 Calibration gases verified by Reference Method 11, GC/FPD or Zinc Acetate technique? _____

8.1.5 Rotameters in dilution system calibrated? _____

_____8.1.6 Dry gas meter in dilution system calibrated? _____

_____8.1.7 Flows measured by bubble meter? _____

8.2 Sample Recovery Test Field Data

Date	_____	_____	_____	_____
Run I.D.	_____	_____	_____	_____
Time Began	_____	_____	_____	_____
Time Ended	_____	_____	_____	_____
Dry Gas Meter Volume(ft ³)	_____	_____	_____	_____

9.0 - ANALYSIS

9.1 Source Sample

Run Number	_____	_____	_____	_____
Dry Gas Meter Volume (ft ³)	_____	_____	_____	_____
Volume of Solution (ml)	_____	_____	_____	_____
Volume of Solution Titrated (ml)	_____	_____	_____	_____
Volume of Sample Titrant (ml)	_____	_____	_____	_____
Normality of Titrant	_____	_____	_____	_____
Volume of Blank Titrant	_____	_____	_____	_____

9.2 Sample Train Recovery

Run Number	_____	_____	_____	_____
Dry Gas Meter Volume (ft ³)	_____	_____	_____	_____
Volume of Solution (ml)	_____	_____	_____	_____
Volume of Solution Titrated (ml)	_____	_____	_____	_____
Volume of Sample Titrant (ml)	_____	_____	_____	_____
Normality of Blank Titrant	_____	_____	_____	_____
Volume of Blank Titrant	_____	_____	_____	_____

10.0 CALCULATIONS

- 10.1 Calculate the volume of gas sampled corrected to standard conditions, for each sample run utilizing the following equation (for Sample and Sample Train Recovery):

$$V_{m(std)} = 17.64 (Y) \left(\frac{V_m P_{bar}}{T_m} \right)$$

Where: $V_{m(std)}$ = volume of gas sample through the dry gas meter at standard conditions, dscf

V_m = volume of gas sampled through the dry gas meter, (cu.ft.)

T_m = average dry gas meter temperature, ($^{\circ}\text{R}$)($^{\circ}\text{F} + 460$)

17.64 = conversion factor $\left(\frac{^{\circ}\text{R}}{\text{in. Hg}} \right)$

$$= \frac{528^{\circ}\text{R}}{29.92 \text{ in. Hg}}$$

Y = dry gas meter calibration factor, dimensionless. For our source test, we will assume a dry gas meter calibration factor of $Y = 1$.

P_{bar} = barometric pressure, in. Hg

$$V_{m(std)} = (17.64)(1) \left[\frac{(\underline{\hspace{1cm}})(\underline{\hspace{1cm}})}{(\underline{\hspace{1cm}})} \right]$$

$$= \underline{\hspace{2cm}} \text{ dscf.}$$

- 10.2 Calculate concentration (ppm) of both source sample and Sample Train Recovery utilizing the following equation:

$$c_{SO_2} = K_2 \frac{N(V_t - V_{tb}) \left(\frac{V_{soln}}{V_a} \right)}{V_{m(std)}}$$

Where: c_{SO_2} = emission rate of sulfur dioxide, ppm
 V_t = volume of titrant required for sample (mL), $Ba(ClO_4)_2$
 V_{tb} = volume of titrant required for blank (mL), $Ba(ClO_4)_2$
 N = normality of $Ba(ClO_4)_2$ (meq/mL)
 V_{soln} = total volume of sample (mL)
 $V_{m(std)}$ = volume of sample corrected to standard conditions (dscf)
 V_a = volume of aliquot titrated (mL)
 K_2 = 424.30

$$c_{SO_2} = \left[\begin{array}{c} 424.30 \end{array} \right] \left[\frac{(\text{---})(\text{---} - \text{---}) \left(\frac{\text{---}}{\text{---}} \right)}{(\text{---})} \right]$$

= _____

Initial

10.0 - SUMMARY

Are final results expressed in units which satisfy permit on
agency requirements? _____

Does Tester have documentation to support emission calibrations
(only required on smelt dissolving tank vents)? _____

Brief Summary of Test _____

11.0 - AUTHORIZATION

11.1 Regulatory Observer
Observer Signature _____

Title _____

Organization _____

Address _____

11.2 Company Observer _____
Company Observer Signature _____

Title _____

Telephone # _____

FIELD INSPECTION NOTEBOOK
TOTAL REDUCED SULFUR
CONTINUOUS EMISSION MONITORING SYSTEM
ABBREVIATED INSPECTION PROCEDURES

FIELD INSPECTION NOTEBOOK
TOTALS REDUCED SULFUR
CONTINUOUS EMISSION MONITORING SYSTEM
ABBREVIATED INSPECTION PROCEDURES

Once a thorough evaluation of the TRS CEM system has been accomplished, control agency personnel may want to perform the next inspection on a less comprehensive basis. To assist the control agency personnel, an abbreviated inspection procedure checklist has been developed. The abbreviated checklist is applicable to all TRS CEM systems. It does not address monitor specific inspection points, but does evaluate the TRS monitor on a system audit basis. The checklist is divided into three major areas:

- o Control agency records review;
- o Control agency records update; and
- o Source TRS CEM system review.

The control agency records review consists of a review of permits and/or any current enforcement actions to determine the purpose of the CEM. In addition, a review of the PST report and current EER is conducted to verify conformance with the appropriate performance specification and reporting requirements for EERs.

The control agency records update is conducted by telephone to verify that the records in agency files correctly describe the current CEM status.

Finally, the source TRS CEM system review evaluates a source's record-keeping, data reduction procedures, monitor evaluation through zero/span checks and overall system review.

ABBREVIATED INSPECTION PROCEDURES
TOTAL REDUCED SULFUR CONTINUOUS EMISSION MONITORING SYSTEM
CONTROL AGENCY RECORD REVIEW

SOURCE NAME _____
SOURCE ADDRESS _____
SOURCE CONTACT _____
SOURCE TELEPHONE NO. _____
DATE _____

ACTION

REQUIRED*

1 - PERMIT REVIEW

_____ Is CEM required by permit? Yes____ No____
_____ CEM requirement due to: NSPS _____
_____ SIP _____
_____ Enforcement Action _____

_____ Is CEM installed? Yes____ No____
_____ CEM Installation/startup date _____ / _____
_____ Allowable emission rate _____
_____ Date of source performance test _____

2 - CEM PERFORMANCE SPECIFICATION TEST (PST) REPORT REVIEW

_____ Dates of PST (<30 days after performance test) _____
_____ Date PST report submitted (<60 days after OTP¹) _____
_____ Date of process startup (<180 days prior to OTP) _____
_____ Date of initial full-load operation (<60 days prior to OTP) _____
_____ Emission Rate Conversion formula _____

CEM SUMMARY

	OPACITY	TRS	O ₂
Analyzer			
Manufacturer			
Model			
Serial			
Recorder			
Manufacturer			
Model			
Serial			
Type ²			

PST REPORT REVIEW

	OPACITY	TRS	O ₂
Relative Accuracy			
Calibration Error			
Response Time			
24 Hr. Span Drift			
24 Hr. Zero Drift			

1 OTP= Operational Test Period

2 Magnetic Tape, Strip Chart, Data Logger, Other (describe).

CALIBRATION REFERENCE MATERIAL REVIEW

	OPACITY	TRS	O ₂
Full Span Value			
Upscale Value			
Mid Span Value			
Calibration Value			
Gas Value Verification			
RM Triplicate Analysis/Date			
NBS Traceable (Protocol 1)			
Other			
Gas Cell Value Verification			
Manufacturer/Date			
Comparison to Gas/Date			
Agency Verification			
Other			

ACTION REQUIRED

_____ Was stratification evaluated? _____ Discuss _____

_____ Describe monitor locations (diluent and pollutant) _____

3 - EXCESS EMISSION REPORT REVIEW

Months reported _____

Did each excess emission report document:

Date, time, and duration of excess emissions	Yes _____	No _____
Magnitude of excess emissions	Yes _____	No _____
Reason for excess emissions	Yes _____	No _____
Corrective action taken to reduce emissions	Yes _____	No _____
Conversions factor/formula	Yes _____	No _____

Method for determining conversion or correction factors used in calculating emission rate.

Moisture content _____

Gas velocity _____

Temperature _____

Diluent gas concentration (O₂) _____

Corrective action taken to reduce emissions Yes _____ No _____

Briefly discuss corrective action _____

Process downtime	Yes _____	No _____
Monitor downtime	Yes _____	No _____
Corrective action taken to return monitor to operation	Yes _____	No _____

Briefly discuss corrective action _____

What percent availability did the CEM system achieve? _____

(2190 - # hrs. downtime) / 2190 = % availability

CONTROL AGENCY RECORDS UPDATE

FIELD REVIEW _____
TELEPHONE REVIEW _____
DATE _____

ACTION REQUIRED

1 - SYSTEM OPERATION & MAINTENANCE

_____ Is monitoring system currently operational? Yes _____ No _____
_____ Is system calibration checked daily? _____ Automatic Yes _____ No _____
_____ Manual Yes _____ No _____
_____ Are recommended maintenance schedules/procedures provided
by the CEM manufacturer and followed? Yes _____ No _____
_____ What group or person is responsible for CEM maintenance? _____
_____ Is manufacturer's recommended spare parts list in plant inventory; or on
order? Yes _____ No _____
_____ Are CEM system malfunctions documented to identify recurring failures
of components or subsystems? Yes _____ No _____

2 - RECORDKEEPING AND DATA REDUCTION TECHNIQUES

What are the engineering units of the data recorded by the CEM system?
What data reduction procedure is used in calculating emission rates?

Over what time intervals are data averaged? _____
Are chart speed, span value, date and time documented? Yes _____ No _____
Where is this data filed? On site _____
Home office _____
Other _____

Is the following information filed for the previous
two years:

_____ All system calibrations Yes _____ No _____
_____ All maintenance performed on the CEM system Yes _____ No _____
_____ All CEM system outages Yes _____ No _____
_____ Span gas certified Yes _____ No _____
_____ Triplicate reference method analysis of span gas Yes _____ No _____
_____ PST reports Yes _____ No _____
_____ Modifications to the CEM system Yes _____ No _____
_____ Excess Emission Reports Yes _____ No _____
_____ Performance Test Reports Yes _____ No _____

_____ Does span gas value (gas cell or neutral density filter)
correspond to appropriate subpart requirements? Yes _____ No _____
_____ Are zero and span calibration checks performed daily? Yes _____ No _____
_____ Are drift values within performance specification
requirements? Yes _____ No _____

SOURCE TRS CEM SYSTEM REVIEW

DATE _____ SOURCE CONTACT _____

- 1 - Review records and update inspection procedures.
Note all items to which unsatisfactory responses were received. Discuss each with source representative via telephone and note status below.

- 2 - Request copies of unreduced CEM system output including diluent gas and process parameter measurements necessary for conversion to emission rate which correspond to:
 - o an excess emission,
 - o a CEM system malfunction or outage, and
 - o an interval of time during which no excess emission or CEM system malfunction occurred as determined by the EER review.
- 3 - Request a copy of CEM maintenance log corresponding to a CEM system malfunction and/or outage reported in EER.
- 4 - Request copies of zero and span calibration (generally shown on strip chart) check.
After receiving the requested information reduce CEM data to units of emission standard and compare to corresponding emission rates submitted on EER. Refer to appropriate subpart of 40 CFR 60, 40 CFR 51 Appendix P, operating permit or enforcement action for proper data reduction procedure and conversion factor. Review CEM output during reported process downtime, CEM calibration and monitor malfunction.

ACTION REQUIRED

_____	Are EER and agency calculated excess emission rates the same?	Yes _____	No _____
_____	Do agency calculations of data not reported as excess emissions indicate compliance?	Yes _____	No _____
_____	Was CEM malfunction or outage caused by component or subsystem failure?	Yes _____	No _____
_____	Was CEM outage scheduled for preventive maintenance?	Yes _____	No _____
_____	Do source maintenance and operating records indicate monitor status and corrective action during outage?	Yes _____	No _____
_____	Which if any of the following caused the outage:		
	- Calibration gas supply,		
	- Optical surface condition,		
	- Conditioning system,		
	- Air purge system,		
	- Optical alignment,		
	- Light source.		
	- Other (describe) _____		

ACTION
REQUIRED

5 - TRS CEM SYSTEM INSTALLATION INSPECTION

_____	Is CEM sampling point in a nonstratified location (for gas monitors)?	Yes _____	No _____
_____	If so, how was non-stratification verified? _____		
_____	If stratification exists, does sampling method and location of diluent gas sampling interface provide measurement of representative sample?	Yes _____	No _____
_____	Is R.M. sampling point as close as possible to CEM sampling point?	Yes _____	No _____
_____	Describe access to sampling point. _____		
_____	_____		
_____	Are CEM sampling and analyzing components free of excessive vibration and extreme ambient temperatures?	Yes _____	No _____
_____	Describe location of calibration gas bottles (if used). _____		
_____	_____		
_____	Are transport and conditioning systems designed and installed properly to deliver sample which meets analyzer requirements (temperature, wet, dry etc)? Refer to manufacturer's operation/maintenance manual	Yes _____	No _____
_____	Is calibration gas introduced at or near the sample interface at the proper pressure?	Yes _____	No _____
_____	Are control panel and recorder located in a controlled environment?	Yes _____	No _____
_____	Is purge air supply clean and dry?	Yes _____	No _____
_____	Transport line details - Conditioning System		
_____	<u>CEM SYSTEM OPERATION OBSERVATION</u>		
_____	Does calibration check indicate satisfactory drift?	Yes _____	No _____
_____	Is automatic zero compensation employed?	Yes _____	No _____
_____	If so, is zero compensation greater than 4% (opacity only) or does reference indicator (if used) show TRS CEM system zero signal to be within specified tolerance of zero reference signal?	Yes _____	No _____
_____	If calibration gases are used, are they introduced to the TRS CEM system at the sampling interface?	Yes _____	No _____
_____	Are calibration references (gas cell, gas cylinder, neutral density filter) of the appropriate value?	Yes _____	No _____

ACTION
REQUIRED

_____ Is recorder span set at value required by the appropriate subpart of 40 CFR 60, or by SIP? Yes _____ No _____
_____ Is pollutant concentration easily determined from recording device? Yes _____ No _____
_____ Is a zero offset employed? Yes _____ No _____
_____ If not, how is negative zero drift quantified? _____
_____ Are any fault indications displayed on control panel? Yes _____ No _____
_____ If so, discuss. _____

3 - CEM PROGRAM EVALUATION

_____ Is an alarm connected to TRS CEM control panel to signal excess emissions? Yes _____ No _____
_____ How often is CEM output checked by an operator? _____
_____ What procedures are implemented during an excess emission incident to reduce emissions? _____
_____ Are process data measurements conducted according to the methods described in applicable NSPS/SIP regulation or permit? Yes _____ No _____
_____ Are changes in calibration reference materials (gas, cell, filter) documented? Yes _____ No _____
_____ How and how often is emission data reviewed for validity by the source? _____
_____ Are entries into Maintenance and Operations Logs made in relation to monitor:
_____ Malfunctions Yes _____ No _____
_____ Calibrations Yes _____ No _____
_____ Maintenance Yes _____ No _____
_____ QA Checks Yes _____ No _____

Conversion Factors

International Metric System: Le Systeme International d'Unites (SI Units)

Base Units of the International Metric System (SI)		
Quantity	Name of the Unit	Symbol
Length	meter	m
Mass	kilogram	kg
Time	second	s
Temperature	Kelvin	K
Amount of substance	mole	mol

Recommended decimal multiples and submultiples and the corresponding prefixes and names.

Factor	Prefix	Symbol	Meaning
10^{12}	tera	T	One trillion times
10^9	giga	G	One billion times
10^6	mega	M	One million times
10^3	kilo	k	One thousand times
10^2	hecto	h	One hundred times
10	deca	da	Ten times
10^{-1}	deci	d	One tenth of
10^{-2}	centi	c	One hundredth of
10^{-3}	milli	m	One thousandth of
10^{-6}	micro	μ	One millionth of
10^{-9}	nano	n	One billionth of
10^{-12}	pico	p	One trillionth of
10^{-15}	femto	f	One quadrillionth of
10^{-18}	atto	a	One quintillionth of

Conversion from ppm to g/m³ at STP

$$T_{std} = 273.15^{\circ}\text{K}$$

$$P_{std} = 1 \text{ atm}$$

$$\frac{\text{g}}{\text{dscm}} = \frac{\text{ppm} \times \text{M.W.} \left(\frac{\text{g}}{\text{g-mole}} \right)}{22.414 \frac{\text{liters}}{\text{g-mole}} \times 10^{-3} \frac{\text{m}^3}{10^3 \text{L}} \left(\frac{293.15^{\circ}\text{K}}{273.15^{\circ}\text{K}} \right)} \times \frac{1}{1 \times 10^6 \text{ ppm}}$$

Atomic Weights and Numbers

Name	Symbol	Atomic Number	Atomic Weight
Arsenic	As	33	74.9216
Barium	Ba	56	137.34
Cadmium	Cd	48	112.40
Carbon	C	6	12.01115
Chlorine	Cl	17	35.453
Hydrogen	H	1	1.00797
Iodine	I	53	126.9044
Lead	Pb	82	207.19
Nitrogen	N	7	14.0067
Oxygen	O	8	15.9994
Phosphorous	P	15	30.9738
Potassium	K	19	39.102
Sodium	Na	11	22.9898
Sulfur	S	16	32.064

Volume

From \ To	cm ³	liter	m ³	in ³	ft ³
cm ³	1	0.001	1×10^{-6}	0.06102	3.53×10^{-5}
liter	1000	1	0.001	61.02	0.03532
m ³	1×10^{-6}	1000	1	6.10×10^{-4}	35.31
in ³	16.39	0.01639	1.64×10^{-4}	1	5.79×10^{-4}
ft ³	2.83×10^{-4}	28.32	0.02832	1728	1

Temperature

$^{\circ}\text{C} = 5/9(^{\circ}\text{F} - 32)$	$^{\circ}\text{F} = 9/5^{\circ}\text{C} + 32$	$^{\circ}\text{K} = ^{\circ}\text{C} + 273.2$	$^{\circ}\text{R} = ^{\circ}\text{F} + 459.7$
---	---	---	---

Conversion factors—ppm vs. $\mu\text{g}/\text{m}^3$.

Desired unit Given unit	Parts per million by volume					
	O ₂	NO ₂	SO ₂	H ₂ S	CO	HC as methane
$\mu\text{g}/\text{m}^3$	5.10×10^{-4}	5.32×10^{-4}	3.83×10^{-4}	7.19×10^{-4}	—	—
mg/m ³	—	—	—	—	0.875	1.53

Desired unit Given unit	$\mu\text{g}/\text{m}^3$				mg/m ³	
	O ₂	NO ₂	SO ₂	H ₂ S	CO	HC
ppm	1960	1880	2610	1390	1.14	0.654

To convert a value from a given unit to a desired unit, multiply the given value by the factor opposite the given units and beneath the desired unit.

TECHNICAL REPORT DATA
(Please read Instructions on the reverse before completing)

1. REPORT NO. 340/1-85-013b		2.	3. RECIPIENT'S ACCESSION NO.	
4. TITLE AND SUBTITLE Field Inspection Notebook for Monitoring Total Reduced Sulfur (TRS) from Kraft Pulp Mills			5. REPORT DATE December 1984	
			6. PERFORMING ORGANIZATION CODE	
7. AUTHOR(S) William T. "Jerry" Winberry, Jr.			8. PERFORMING ORGANIZATION REPORT NO.	
9. PERFORMING ORGANIZATION NAME AND ADDRESS Engineering-Science 501 Willard Street Durham, NC 27701			10. PROGRAM ELEMENT NO.	
			11. CONTRACT/GRANT NO. 68-02-3960	
12. SPONSORING AGENCY NAME AND ADDRESS Stationary Source Compliance Division Technical Service Branch Waterside Mall, 401 M Street, S.W. Washington, DC 20460			13. TYPE OF REPORT AND PERIOD COVERED	
			14. SPONSORING AGENCY CODE	
15. SUPPLEMENTARY NOTES <u>Supplements Technical Assistance Document for Monitoring Total Reduced Sulfur (TRS)</u> <u>from Kraft Pulp Mills; EPA Task Manager-Sonya Stelmack, (202) 382-2851</u>				
16. ABSTRACT <p>Field performance audit procedures were developed for three of the most common total reduced sulfur (TRS) continuous emission monitoring systems (CEMS). These procedures were designed to assist state/federal field inspectors in the evaluation of TRS-CEMS. Contained in the notebook are checklists and data entry tables covering preparation for the inspection, preliminary review of records, preliminary on-site meeting with source personnel, and general guidelines for inspection of any type TRS-CEMS. Specific audit procedures for three of the most common models of TRS CEMS</p> <ul style="list-style-type: none"> - Sampling Technology Inc. Model 100 TRS CEM System; - Barton Titrator TRS System; and - Bendix Gas Chromatograph TRS System <p>are provided as sectional inserts. In auditing these monitors the inspector should follow the specific procedure rather than the general guidelines given in the body of the field notebook.</p> <p>Conscientious use of this notebook will aid the inspector in conducting a thorough audit of the TRS CEMS and provide a comprehensive original record of all phases of the inspection.</p>				
17. KEY WORDS AND DOCUMENT ANALYSIS				
a. DESCRIPTORS		b. IDENTIFIERS/OPEN ENDED TERMS		c. COSATI Field/Group
Air Pollution Monitoring Kraft Pulp Mills Continuous Emission Monitoring		Opacity Monitoring Systems Audit Procedures TRS Continuous Emission Monitors		
18. DISTRIBUTION STATEMENT Release to Public		19. SECURITY CLASS (This Report) Unclassified		21. NO. OF PAGES 120
		20. SECURITY CLASS (This page) Unclassified		22. PRICE