



## Project Summary

# Environmental Assessment of an Enhanced Oil Recovery Steam Generator Equipped with an EPA Heavy Oil Low-NO<sub>x</sub> Burner

C. Castaldini, L. R. Waterland, and R. De Rosier

The report discusses emission results obtained from sampling the flue gas from a 16-MW (55 million Btu/hr) enhanced oil recovery steam generator equipped with an EPA heavy oil low-NO<sub>x</sub> burner firing high-nitrogen (about 1 percent) Kern County crude oil. The tests consisted of a comprehensive flue gas monitoring program to characterize emissions from the steamer with the burner operation set to achieve NO<sub>x</sub> levels below 85 ppm (at 3 percent O<sub>2</sub>) with low CO and smoke emissions. In addition, an extended 30-day flue gas monitoring program was conducted to measure low-NO<sub>x</sub> burner performance under typical unattended steamer operation. Emission measurements for the comprehensive tests included:

- Continuous monitoring of flue gas emissions.
- Source assessment sampling system (SASS) testing with subsequent laboratory analysis of samples to give total flue gas organics in two boiling point ranges, specific quantitation of the semivolatile organic priority pollutant species, and flue gas concentrations of 73 trace elements.
- Volatile organic sampling train (VOST) testing with subsequent laboratory analysis to give volatile organic priority pollutant species emissions.
- EPA methods 5 and 8 sampling for particulate and SO<sub>x</sub> emissions.
- Controlled condensation system (CCS) sampling, also for SO<sub>x</sub> emissions.

- Emitted particle size distribution measurements using Andersen impactors.
- N<sub>2</sub>O emission sampling.

During the comprehensive tests, NO<sub>x</sub> emissions averaged 70 ppm at 3 percent O<sub>2</sub> with CO levels generally below 30 ppm. SO<sub>2</sub> emissions measured with a continuous monitor ranged between 500 and 750 ppm at 3 percent O<sub>2</sub>. Measurements of SO<sub>2</sub> by EPA Method 8 (and subsequently by controlled condensation) indicated generally good agreement with the continuous emission analyzer. The average of two particulate emission measurements was 27 ng/J (96 mg/dscm). The average condensable particulate emission level was 14 ng/J (50 mg/dscm). Two particle size distribution measurements were performed. Results indicate that 90 percent of the particulate matter had a mean particle diameter less than 1.4 and 11 μm, respectively, for the two tests.

Total organic emissions from the steamer were relatively low, at 300 μg/dscm (85 pg/J), and relatively evenly distributed between the semivolatile (boiling point about 100 to 300 °C) and nonvolatile (boiling point greater than about 300 °C) categories. Of the volatile organic priority pollutants, emissions of benzene, toluene, and ethylbenzene were quantitated in the 2 to 60 μg/dscm (0.4 to 20 ppb) range. Of the semivolatile organic priority pollutants, emissions of naphthalene and phenol at about 1 μg/dscm (0.3 ppb) were measured.

Extended 30-day continuous monitoring of flue gas emissions confirmed the bur-

ner's ability to maintain  $\text{NO}_x$  emissions below 80 ppm. The average for this duration was calculated at about 70 ppm at 3 percent  $\text{O}_2$ . CO emissions were also low, generally less than 30 ppm at 3 percent  $\text{O}_2$ , throughout the test program.

*This Project Summary was developed by EPA's Air and Energy Engineering Research Laboratory, Research Triangle Park, NC, to announce key findings of the research project that is fully documented in two separate volumes of the same title (see Project Report ordering information at back).*

## Introduction

Remaining petroleum reserves in older fields often require enhanced oil recovery (EOR) techniques for continued production. One EOR technique involves steam flooding of oil fields to lower the viscosity of heavy crude so it can be recovered. The steam for injection is most often raised by crude-oil-fired steam generators, termed steamers. In Kern County, California, the aggregate  $\text{NO}_x$  emissions from these steamers have received recent regulatory attention since that area is currently in borderline attainment of the  $\text{NO}_2$  ambient air quality standard.

Over the past several years, EPA has sponsored the development of a low- $\text{NO}_x$

burner capable of achieving  $\text{NO}_x$  levels below 85 ppm with low CO and smoke generation while burning high nitrogen fuel oils such as the Kern County crude. These programs have led to the recent full-scale demonstration of a burner prototype in an operating steamer. This steamer, equipped with a full-scale 16-MW (55 million Btu/hr) burner prototype, was tested under the Combustion Modification Environmental Assessment (CMEA) program. Results of these tests are presented in this report.

## Summary and Conclusions

### Source Description

The tests were performed on a crude-oil-fired steamer retrofitted with the low- $\text{NO}_x$  burner illustrated in Figure 1. The burner consists of a large,  $13 \text{ m}^3$  (460  $\text{ft}^3$ ), refractory-lined chamber. Steam-atomized oil and combustion air are well mixed in this chamber at a stoichiometric ratio of about 0.6 to 0.65. Primary air to the chamber is preheated by a regenerative chamber design in which the air passes through an inner shell before being injected into the chamber. Secondary combustion air is injected both radially and axially in the interface connecting the burner to the steamer. This staged combustion low- $\text{NO}_x$  burner enhances the

decay of total fixed nitrogen species ( $\text{NH}_3$  and HCN primarily), formed early in the mixing zone from fuel nitrogen, to  $\text{N}_2$  prior to injection of secondary combustion air. The large refractory-lined combustor volume provides both the long residence time (about 0.6 sec) and the high temperature (about  $1,400^\circ\text{C}$ ) required for the decay of the fixed nitrogen species.

## Test Program and Burner Operation

The test program called for a comprehensive evaluation of steamer flue gas emissions with the burner operation set to achieve  $\text{NO}_x$  levels below 85 ppm with low CO and smoke emissions. In addition, the test program called for a continuous 30-day emission monitoring program to monitor the longer-term  $\text{NO}_x$  control capability of the burner under typical steamer operation.

Table 1 summarizes the steamer/burner operating conditions during the comprehensive tests on February 1, 1984. The burner fired Kern County crude with a nitrogen and sulfur content of 1.04 and 1.06 percent, respectively. Measurement of primary and secondary airflows indicated a first-stage combustor stoichiometry in the range of 0.61 to 0.65, with an estimated




Figure 1. EPA low- $\text{NO}_x$  burner

bulk gas residence time of 0.65 sec. Steamer operation was uninterrupted during this test.

### Emission Measurements and Results—Comprehensive Tests

The sampling and analysis procedures used in this test conformed to an extended EPA Level 1 protocol. Emission measurements included:

- Continuous monitoring for O<sub>2</sub>, CO<sub>2</sub>, CO, NO<sub>x</sub>, and SO<sub>2</sub>.
- SASS sampling for trace element and semi- and non-volatile organic emissions.
- VOST for volatile organic emissions.
- EPA Method 5 sampling for solid and condensable particulate emissions.
- EPA Method 8 sampling for SO<sub>x</sub> emissions in conjunction with Method 5.
- Particle size distribution measurements using Andersen impactors.
- CCS for SO<sub>x</sub> emissions.
- Grab sampling for laboratory gas chromatographic analysis of N<sub>2</sub>O.

All sampling took place at the stack, downstream of the steamer economizer. The analysis protocol for the SASS train samples included:

- Analyzing methylene chloride extracts of particulate and XAD-2 resin for total organic content in two boiling point ranges: semivolatile organics with boiling points between 100 and

300 °C (nominally C<sub>7</sub> to C<sub>16</sub> organics) by total chromatographable organic (TCO) analysis and nonvolatile organics with boiling points greater than 300 °C (nominally C<sub>16+</sub> organics) by gravimetry.

- Obtaining infrared (IR) spectra of the gravimetric residues of the extract samples.
- Analyzing the organic sorbent module extract samples for the semivolatile organic priority pollutants, including several polynuclear aromatic hydrocarbon (PAH) species, by gas chromatography/mass spectrometry (GC/MS) according to EPA Method 625.
- Analyzing particulate, XAD-2 resin, and impinger solutions for 73 trace elements using primarily spark source mass spectrometry (SSMS) and atomic absorption spectroscopy.

VOST train samples were analyzed by thermal desorption, purge and trap GC/MS for the volatile organic priority pollutant compounds as outlined in the EPA VOST protocol.

Table 2 summarizes the emissions measured during the comprehensive tests. Emissions of NO<sub>x</sub>, CO, and SO<sub>2</sub> were relatively constant throughout these tests. NO<sub>x</sub> emissions averaged about 70 ppm dry corrected to 3 percent O<sub>2</sub>, well below the burner target of 85 ppm. CO emissions averaged 24 ppm. SO<sub>2</sub> emissions, as determined by both the continuous monitor

and the average of two Method 8 determinations, are shown in the table: the two agree within 10 percent. Average SO<sub>3</sub> emissions by Method 8 were about 9 ppm (3 percent O<sub>2</sub>), corresponding to about 1.4 percent of total SO<sub>x</sub> (SO<sub>2</sub> + SO<sub>3</sub>) emissions: this is a significantly lower fraction than is typical for oil-fired sources. Subsequent measurements using CCS gave SO<sub>2</sub> emissions of 600 ppm (average of two measurements) with SO<sub>3</sub> emissions of 49 ppm: in these subsequent test, SO<sub>3</sub> accounted for about 7.5 percent of the total SO<sub>x</sub> emitted, more typical for oil-fired sources.

Table 2 shows that particulate emissions were 146 mg/dscm (average of two measurements) with about 35 percent of the particulate being condensable. Total organic emissions from the steamer were quite low, at 300 µg/dscm. These were roughly equally split among the semi- and non-volatile boiling point ranges.

Of the volatile organic priority pollutants, benzene and alkyl substituted benzenes were detected at concentrations below about 20 ppb. No other volatile organic priority pollutants were detected. Of the semivolatile organic priority pollutants, naphthalene and phenol were detected at concentrations of 0.3 and 0.2 ppb, respectively. The dimethyl phthalate noted in Table 2 is most likely a contaminant.

Trace element analyses of SASS samples indicate that sodium, chlorine (condensed chlorides), copper, iron, nickel, and zinc are emitted at the highest levels with emissions exceeding 100 µg/dscm. The most likely source of the sodium and chlorine is the residual brine in the crude oil fuel. Sodium levels in the fuel were quite high, about 120 µg/g. Figure 2 illustrates the particle size distributions resulting from two separate Andersen impactor measurements. The data indicate that 90 percent of the total particulate mass had a mean particle diameter of less than 1.4 µm for run 1 and 11 µm for run 2.

### Emission Measurements and Results—30-Day Monitoring

The sampling and analysis protocol for this portion of the test program consisted of continuous monitoring of flue gas for O<sub>2</sub>, CO<sub>2</sub>, CO, NO<sub>x</sub>, and SO<sub>2</sub> with certification of NO<sub>x</sub> analyzer readings using EPA Method 7. Flue gas was monitored from January 21 to February 24, 1984. Figures 3 through 5 illustrate the emission data collected. Apart from two periods when the steamer was shut down, one for inspection and another due to electrical

Table 1. Steamer/Burner Operation

	Range	Average <sup>a</sup>
Fuel flow, l/min (bbl/day)	23.4 to 24.1 (212 to 218)	23.8 (215)
Heat input, MW (10 <sup>6</sup> Btu/hr)	16.4 to 16.8 (55.8 to 57.4)	16.6 (56.6)
Fuel temperature, °C (°F)	129 to 132 (264 to 269)	130 (267)
Feedwater flow, l/min (10 <sup>3</sup> bbl/day)	380 to 400 (3.4 to 3.6)	390 (3.5)
Steam pressure, MPa (psig)	7.03 to 9.10 (1,020 to 1,320)	8.41 (1,220)
Steam temperature, °C (°F)	279 to >300 (525 to >570)	—
Stack temperature, °C (°F)	232 to 254 (450 to 490)	242 (468)
Burner primary airflow, m <sup>3</sup> /s (scfm)	2.71 to 2.87 (5,740 to 6,080)	2.80 (5,940)
Secondary airflow, m <sup>3</sup> /s (scfm)	2.38 to 2.95 (5,040 to 6,260)	2.65 (5,630)
First stage stoichiometry	0.61 to 0.65	0.64
First stage residence time, <sup>b</sup> sec	—	0.65
Fuel/Oil analysis, percent weight		
Carbon	—	86.2
Hydrogen	—	11.3
Sulfur <sup>c</sup>	1.00 to 1.10	1.06
Nitrogen <sup>c</sup>	1.00 to 1.09	1.04
Ash	—	0.03
Moisture	—	0.57
Oxygen	—	0.4
Gross heating value, MJ/kg (Btu/lb)	—	42.78 (18,430)
Specific gravity (API) at 16°C (60°F)	—	12.6

<sup>a</sup>Spans the entire 1-day period of comprehensive testing.

<sup>b</sup>Assumes a combustor temperature of 1,430°C (2,600°F).

<sup>c</sup>Analyses of sulfur and nitrogen were performed in triplicate.

**Table 2.** Summary of Flue Gas Emissions

Component	Flue gas concentration <sup>a</sup>		
	ppm <sup>b</sup>	mg/dscm	ng/J <sup>c</sup>
<i>Criteria pollutant and other gas-phase species:</i>			
NO <sub>x</sub> (as NO <sub>2</sub> )	69	140	39
CO	24	29	8.1
SO <sub>2</sub>			
– Continuous monitor	556	1,560	435
– Method 8 <sup>d</sup>	606	1,640	456
SO <sub>3</sub>			
– Method 8 <sup>d</sup>	8.7	29	8.1
Particulate			
– Solid <sup>d</sup>	–	96	27
– Condensible <sup>d</sup>	–	50	14
Total particulate <sup>d</sup>	–	146	41
N <sub>2</sub> O	7	12	3.5
<i>Total organics:</i>			
Semivolatile organics (C <sub>7</sub> to C <sub>16</sub> ) by TCO	–	0.17	0.050
Nonvolatile organics (C <sub>16+</sub> ) by gravimetry	–	0.13	0.035
Total C <sub>7+</sub>	–	0.30	0.085
<i>Volatile organic priority pollutants:</i>			
Benzene	0.018	0.060	0.017
Toluene	0.00083	0.0032	0.0009
Ethylbenzene	0.00039	0.0017	0.0005
<i>Semivolatile organic priority pollutants:</i>			
Naphthalene	0.0003	0.0014	0.0004
Phenol	0.0002	0.0007	0.0002
Dimethyl phthalate	0.0004	0.0036	0.0010

<sup>a</sup>Average flue gas O<sub>2</sub> and CO<sub>2</sub> were 2.7 and 13.1 percent, respectively.

<sup>b</sup>Corrected to 3 percent O<sub>2</sub>.

<sup>c</sup>Heat input basis.

<sup>d</sup>Average of two separate measurements.

problems, operation throughout this test period was relatively steady. O<sub>2</sub> levels, shown in Figure 3, were maintained at about 3 percent. Only at the start and end of the 30-day test period did the O<sub>2</sub> increase to over 4 percent. It is not known if this increase was caused by a change in primary or secondary combustion air-flow. NO<sub>x</sub> emission levels, shown in Figure 4, were below 80 ppm corrected to 3 percent O<sub>2</sub> throughout. Average NO<sub>x</sub> for the entire test period was about 70 ppm. CO emissions were generally below 30 ppm. However, there were no CO readings after day 23. SO<sub>2</sub> emissions ranged between 500 and 750 ppm corrected to 3 percent O<sub>2</sub>. The notable increase in SO<sub>2</sub> during the last days of testing may have been caused by an increase in sulfur content of the crude.

### Quality Assurance

Results of several quality assurance (QA) activities performed in conjunction with this test program are discussed in the

report. Conclusions are that the quality of data obtained is of an acceptable level in terms of the stated project QA objectives.

### Summary

Emissions from a crude-oil-fired steamer equipped with the EPA low-NO<sub>x</sub> burner were tested. Field testing of the steamer over a 30-day monitoring period supports the capability of the burner to maintain NO<sub>x</sub> levels below 80 ppm with CO emissions below 30 ppm. Particulate emissions were in the range typical of other EOR steamers. Total organic emissions were relatively low. Low concentrations of several aromatics (benzene, toluene, ethylbenzene, phenol, and naphthalene) were quantitated.




Figure 2. Particle size distribution.




Figure 3. Flue gas O<sub>2</sub> and CO<sub>2</sub> for the extended test period




Figure 4. Flue gas NO<sub>x</sub> and CO for the extended test period




Figure 5. Flue gas SO<sub>2</sub> for the extended test period.

C. Castaldini, L. Waterland, and R. De Rosier are with Acurex Corp., Mountain View, CA 94039.

Joseph A. McSorley is the EPA Project Officer (see below).

The complete report consists of two volumes, entitled "Environmental Assessment of an Enhanced Oil Recovery Steam Generator Equipped with an EPA Heavy Oil Low-NO<sub>x</sub> Burner,"

"Volume I. Technical Results," (Order No. PB 86-191 475/AS; Cost: \$16.95)

"Volume II. Data Supplement," (Order No. PB 86-191 483/AS; Cost: \$16.95)

The above reports will be available only from: (cost subject to change)

National Technical Information Service

5285 Port Royal Road

Springfield, VA 22161

Telephone: 703-487-4650

The EPA Project Officer can be contacted at:

Air and Energy Engineering Research Laboratory

U.S. Environmental Protection Agency

Research Triangle Park, NC 27711


United States  
Environmental Protection  
Agency

Center for Environmental Research  
Information  
Cincinnati OH 45268

---

Official Business  
Penalty for Private Use \$300

EPA/600/S7-86/013



0000329 PS

U S ENVIR PROTECTION AGENCY  
REGION 5 LIBRARY  
230 S DEARBORN STREET  
CHICAGO IL 60604

3