



Project Summary

Environmental Assessment of a Waste-to-Energy Process: GSA/Pentagon Co-Fired Boiler Tests

Mark A. Golembiewski, K. P. Ananth, T. Sutikno, and Harry M. Freeman

A series of emission tests at the Virginia Heating and Refrigeration Plant (VHRP) in Arlington, Virginia, were conducted by Midwest Research Institute. This plant provides steam heat or refrigerated air to the Pentagon building. The study was designed to obtain emission data while one of the steam boilers was co-fired with different blends of coal and densified refuse-derived fuel (d-RDF).

The No. 4 boiler at VHRP was utilized for this test program. The steam output of this underfeed-retort stoker boiler is rated at 70,000 lb/hr, although usual maximum load is about 50,000 lb/hr. Coal is normally the sole fuel. For this d-RDF burn program, sampling was conducted during three fuel firing modes: coal only, 20% d-RDF + 80% coal, and 60% d-RDF + 40% coal. The tests were intended to be run at a single boiler load for comparative purposes, but steam output could not be held constant during much of the sampling period.

Samples of the coal, d-RDF, and coal/d-RDF fuel mixtures were collected hourly and analyzed by the National Center for Resource Recovery (NCRR) for moisture, ash, heating value and chemical composition.

Several daily samples of bottom ash were also collected by NCRR. These were analyzed for loss-on-ignition and chemical composition.

Midwest Research Institute was responsible for sampling and analysis of the stack effluent. Tests were conducted for particulate concentration, gaseous criteria pollutants (SO_2 , NO_x , CO, and total hydrocarbons), and chlorides. Particulate samples were also analyzed for lead content.

This publication is a summary of the complete project report, which can be purchased from the National Technical Information Service.

Introduction

Under the sponsorship of the U.S. Environmental Protection Agency's Fuel Technology Branch in Cincinnati, Midwest Research Institute (MRI) is presently conducting multi-media environmental assessment of various waste-to-energy conversion systems. This paper will discuss the results of a series of emission tests at the Virginia Heating and Refrigeration Plant (VHRP) in Arlington, Virginia.

VHRP is operated by the General Services Administration (GSA) for the purpose of satisfying the steam heat

and chilled water needs of the Pentagon and the Henderson Hall office building. The heating plant consists of five coal-fired boilers, one of which (No. 4) was utilized for the testing described in this report.

The National Center for Resource Recovery (NCRR) in Washington, D.C., is concerned with developing the use of refuse-derived fuel (RDF) as an alternative energy source. Discussions were held with representatives of GSA concerning possible use of densified RDF as a supplemental fuel for their coal-fired boilers. The outcome of these discussions was an agreement to test

fire a coal-RDF fuel mixture at VHRP and evaluate the subsequent effects on boiler operation and air emissions. The U.S. Environmental Protection Agency (EPA), with MRI as contractor, provided air sampling and analysis capabilities.

The test burn and air sampling activities were conducted during the week of March 19-23, 1979, and results of those emission tests are described herein. Subsequent sections of this report present a description of the boiler test facility, an overview of the sampling and analytical methodologies employed, and a discussion of the test results.

Test Facility

The No. 4 boiler at VHRP was manufactured by the Riler Stoker Company and installed in 1941. It is an underfeed retort stoker boiler with a rated steam capacity of 70,000 lb/hr. Normal maximum operating load for the boiler, however, is about 50,000 lb/hr. A schematic of the boiler with its auxiliary equipment is shown in Figure 1.

Coal is supplied to the plant from outdoor storage pile or directly from cars via an underground belt conveyor. The coal is transferred from the conveyor to a bucket conveyor which feeds a coal bunker located above the boiler. The coal is then transferred from the bunker through a coal chute to the stoker ram. The stoker ram is driven by a stoker drive and a turbine drive. The stoker ram feeds the boiler. The boiler is equipped with a mechanical collector, induced draft fan, D/A (Deaerator) Tank, Steam Drum, Mud Drum, Ash Hopper, and a Forced Draft Fan. The boiler feedwater pump feeds the boiler. The boiler is connected to a Surge Tank, Condensate Tank, City Water, Zeolite Softener Tank, Vacuum Ash Puller, and an Ash Unloader. The ash is transported via a Pneumatic Ash Line to a Coal Belt Conveyor.




Figure 1. Schematic diagram of the test boiler.

oilier. During the test burn program, the RDF pellets were fed to the same bucket conveyor, using a second belt conveyor. The specified volume ratio of pellets to coal was maintained in each bucket through the use of throttling plates at the conveyor transfer points. The coal/d-RDF mixtures were also transferred to the same overhead bunker that is normally used for coal feeding.

Further information on the process conditions and equipment specifications is given in the complete project report.

Sampling and Analytical Methodology

The emissions sampling program for the GSA/NCRR d-RDF test burn was designed to characterize boiler exhaust as emissions when firing coal and when firing two blends of coal and d-RDF. The sampling matrix is illustrated in Figure 2. In addition to the stack testing conducted by MRI, samples of the input fuels as well as bottom ash were collected by NCRR during the test program. The analytical matrices for these samples are also shown in Figure 2. A summary of the test chronology is presented in the table below.

Brief discussions of the sampling and analytical procedures are presented next. Full descriptions of the methods used are contained in the complete report.

Coal and d-RDF Fuels—Hourly grab samples of the fuels (of about one cubic ft) were taken from the weigh station area above the ram feed chutes. Each sample was then progressively subdivided to about a 5 kg size using a riffler apparatus and stored in a plastic bag. The fuel analysis basically followed standard procedures of American Society for Testing and Materials (ASTM).




Figure 2. Sampling and analysis matrix.

Bottom Ash—Grab samples of the boiler bottom ash were collected twice daily and composited. Analysis was done in accordance with the standard procedures of ASTM and U.S. Bureau of Mines, and consisted of loss-on-ignition, carbon/hydrogen/nitrogen, and lead determinations.

Stack Emissions—Samples of the boiler exhaust gases were collected over a 4-day period and later analyzed in the MRI laboratories. The sampling analysis methods used for each of the gas parameters measured are discussed next.

Particulate Concentration—Three EPA Method 5 runs were conducted during each of the three fuel firing

modes. In addition, two extra runs were taken during a second baseline coal mode, for a total of five runs when the boiler was supplied with 100% coal. The probe wash, filter catch, and impinger contents of each sample were analyzed for net particulate weight. Filter samples were also analyzed for lead content using atomic absorption spectrometry (AAS).

Oxygen and Carbon Dioxide—O₂ and CO₂ contents of the stack gas were measured using Fyrite detectors. Replicate readings were taken during each Method 5 run to determine the molecular weight of the air stream and the percentage of excess air used by the boiler.

Criteria Gaseous Pollutants—Continuous gas analyzers were used to measure the concentrations of O₂, CO, NO_x, SO₂, and total hydrocarbons in the stack effluent on a realtime basis. The sample was drawn through a heated Teflon sample line to a field trailer which housed the monitoring equipment. There, the sample stream was dried and filtered before it was proportioned to each of the analyzers. Instrument responses were registered on strip chart recorders and transcribed

Table 1. Pentagon Boiler Test Schedule

Run No.	Date	Fuel Fired	Test Period
1, 2, 3	3/20	100% coal	10:15-18:57
4, 5, 6	3/21	20% d-RDF/80% coal	08:10-17:05
7, 8, 9	3/22	60% d-RDF/40% coal	08:10-17:02
10, 11	3/23	100% coal	08:07-12:49

to data log sheets at 15-minute intervals.

Chlorides—A midjet impinger train containing a dilute sodium hydroxide solution was used to collect stack gas samples for chloride analysis. One chloride sample was taken for each Method 5 particulate run (i.e., three per fuel firing mode). Each sample was collected over a half-hour period.

Presentation and Discussion of Results

Results of the sampling and analysis efforts are discussed as follows:

Boiler Operation

Although the full load rating of the No. 4 boiler is 70,000 lb of steam per hour, unseasonably mild weather conditions (and thus reduced steam demand) precluded running the unit near full load conditions. As a result, GSA plant personnel established an operating level of 30,000 lb/hr as one that could be reasonably maintained for the test program.

Fuel usage and heat input data from the test program are summarized in the complete project report. These data, which have been selected to correspond with the particulate sampling runs, show a wide variation in boiler operation, even among the three runs at each fuel firing conditions. Heat input rates during the 11 sampling runs ranged from 23.5 to 82.1 x 10⁶ kJ/hr (22.3 to 77.8 x 10⁶ Btu/hr). The variation in boiler operation was primarily due to fluctuating steam demand, the influence of the adjoining on-line boilers when loads changed, and improper functioning of some control instruments.

Coal and RDF Fuels

The chemical composition of each fuel was analyzed. Analysis results are reported in detail in the complete project report. Basically, the results are

report. Basically, the results showed that the blend with the higher proportion of d-RDF had a greater moisture content, a lower ash content, and a lower heating value. The higher heating value of d-RDF was about 7800 Btu/lb dry.

Bottom Ash

The bottom ash sample of both coal only and the 20% d-RDF blend showed a

very high proportion of combustible material (over 30%), which would indicate incomplete combustion of the fuels during these two firing modes. The average percentages of hydrogen and nitrogen in the bottom ashes of the fuels were about 0.10% and 0.08%, respectively. The lead content in each bottom ash sample was below the detectability of the instruments (0.6 ppm).

Stack Emissions

Particulate emissions were reduced from 22 to 38% when d-RDF was blended with the original coal fuel. Filterable particulate emissions were lowest when using the 20% d-RDF blend and rose again when the proportion of d-RDF was raised to 60%. This finding may not be conclusive, however, since the boiler load was held steady during the 20% d-RDF firing but not during the 60% mode. Further tests, conducted over longer periods of time, and at consistent boiler conditions, are needed to substantiate the observed trend.

The amount of particulate lead emitted when burning the d-RDF with coal is substantially higher than that from combustion of coal alone and may be a cause for environmental concern. Approximately 200% more lead was

emitted during firing of the 20% d-RDF blend (an average of 1,000 µg/n versus 330 µg/m³ during coal combustion), and 580% more (2,260 µg/m³) when the 60% d-RDF fuel was used.

Concentrations of sulfur dioxide, nitrogen oxides, and carbon monoxide all decreased slightly when the RDF was used with coal. Because of the very low sulfur content of d-RDF, SO₂ emissions were reduced progressively as the proportion of d-RDF with coal was increased. NO_x and CO levels, however, are highly dependent on boiler combustion conditions which may or may not have been the direct result of burning coal RDF.

Chloride emissions showed no definite trend which could be used to correlate chloride emissions with RDF modes, though slightly higher concentrations of HCl were observed in two of the samples collected during combustion of the 60% d-RDF blend.

In summary, co-firing of d-RDF with coal at the Virginia Heating and Refrigeration Plant appears to be a viable option from an environmental standpoint. However, the role of lead emissions must be considered when making a final evaluation of the overall potential of d-RDF substitution.

Mark A. Golembiewski, K. P. Ananth, and T. Sutikno are with Midwest Research Institute, Kansas City, MO 64110.

Harry M. Freeman is the EPA Project Officer (see below).

The complete report, entitled "Environmental Assessment of a Waste-to-Energy Process: GSA/Pentagon Co-Fired Boiler Tests," (Order No. PB 81-109100; Cost: \$6.50, subject to change) will be available from:

*National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161
Telephone: 703-487-4650*

*The EPA Project Officer can be contacted at:
Industrial Environmental Research Laboratory
U.S. Environmental Protection Agency
Cincinnati, OH 45268*

United States
Environmental Protection
Agency

Center for Environmental Research
Information
Cincinnati OH 45268

Postage and
Fees Paid
Environmental
Protection
Agency
EPA 335



Official Business
Penalty for Private Use \$300

IERL0167053
US EPA REGION V
LIBRARY
230 S DEARBORN ST
CHICAGO IL 60604