



Project Summary

EPA Utility FGD Survey January - March 1981

M. Smith, M. Melia, N. Gregory, and K. Scalf

This report, generated by a computerized data base system, presents a survey of operational and planned domestic utility flue gas desulfurization (FGD) systems, operational domestic particle scrubbers, and Japanese coal-fired utility boiler FGD installations. It summarizes information contributed by the utility industry, system and equipment suppliers, system designers, research organizations, and regulatory agencies. It presents data on system design, fuel characteristics, operating history, and actual performance. Unit by unit dependability parameters are included. Problems and solutions associated with the boilers, scrubbers, and FGD systems are discussed.

The domestic FGD systems are tabulated alphabetically by development status (operational, under construction, or in the planning stages), utility company, system supplier, process, waste disposal practice, and regulatory class. FGD system economic data, definitions, and a glossary of terms are appended to the report. Current data for domestic FGD systems show 87 systems in operation, 35 systems under construction, and 104 planned systems. Projected 1990 FGD controlled capacity in the U.S. is 108,612 MW.

This Project Summary was developed by EPA's Industrial Environmental Research Laboratory, Research Triangle Park, NC, to announce key findings of the research project that is fully documented in a separate report

of the same title (see Project Report ordering information at back).

Introduction

This report is prepared quarterly (every 3 months) by PEDCo Environmental, Inc., under contract to the Industrial Environmental Research Laboratory/Research Triangle Park and the Stationary Source Enforcement Division of the U.S. Environmental Protection Agency. It is generated by a computerized data base system, the structure of which is illustrated in Figure 1 (see pages 6 and 7).

Table 1 summarizes the status of FGD systems in the United States at the end of March 1981. Table 2 lists the units that have changed status during the first quarter 1981, and Table 3 shows the performance of operating units during this period.

Current projections indicate that the total power generating capacity of the U.S. electric utility industry will be approximately 833 GW by the end of 1990.¹ (This value reflects the annual loss resulting from the retirement of older units, which is considered to be 0.4% of the average generating capacity at the end of each year.²) Approximately 370 GW or 44% of the 1990 total will come from coal-fired units. The distribution of power generation sources, both present (December 1979) and future (December 1990) is shown in Table 4.¹

Based on the known commitments to FGD by utilities as presented in Table 1, the percentage of electrical generating

capacity controlled by FGD for both the present (March 1981) and the future (December 1990) is shown in Table 5.

In light of the revised New Source Performance Standards, actual FGD control is expected to be greater than what is reflected by the figures above. For example, about 40 to 50 systems

representing approximately 20,000 to 25,000 MW of generating capacity presently fall into the uncommitted category. These are systems that cannot be included in the committed group at this time because information regarding their status is not ready for public release.

In an effort to show general F usage and projected usage trends, Table 6 gives a current (March 1981) and projected (December 1990) breakdown of throwaway product systems versus salable product systems as a percent of the total known commitments to FGD of the end of the first quarter 1981.

Table 1. Number and Total Capacity of FGD Systems

Status	No. of units	Total controlled capacity, MW*	Equivalent scrubbed capacity, MW†
Operational	87	32,717	29,538
Under construction	35	14,835	14,481
Planned:			
Contract awarded	27	13,796	13,796
Letter of intent	11	8,235	8,235
Requesting/evaluating bids	18	10,191	10,075
Considering only FGD systems	48	28,838	28,850
Total	226	108,612	104,975

*The summation of the gross unit capacities (MW) brought into compliance with FGD systems regardless of the percent of the flue gas scrubbed by the FGD systems.

†The summation of the effective scrubbed flue gas in equivalent MW based on the percent of flue gas scrubbed by the FGD systems.

Table 2. Summary of Changes—January - March 1981

FGD status report December 31, 1980	Operational		Under construction		Contract awarded		Letter of intent		Requesting/eval. bids		Considering FGD		Total	
	No.	MW ^a	No.	MW ^a	No.	MW ^a	No.	MW ^a	No.	MW ^a	No.	MW ^a	No.	MW ^a
Arizona Public Service Cholla 4	+1	126	-1	126										
Basin Electric Power Coop Antelope Valley 2					+1	440			-1	440				
Cincinnati Gas & Electric East Bend 2	+1	650	-1	650										
Colorado Ute Electric Assn. Craig 3			+1	447	-1	447								
Iowa Electric Light & Power Guthrie Co.									+1	720	-1	720		
Jacksonville Electric Authority														
St. Johns River Power Park 1									+1	600	-1	600		
St. Johns River Power Park 2									+1	600	-1	600		
Kentucky Utilities Hancock 1									+1	650	-1	650		
Hancock 2									+1	650	-1	650		
Tennessee Valley Authority Widows Creek 7	+1	575	-1	575										
Utah Power & Light Hunter 3			+1	400	-1	400								
Hunter 4			+1	400	-1	400								
Washington Water Power Creston Coal 2											+1	570	+1	570
Creston Coal 3											+1	570	+1	570
Creston Coal 4											+1	570	+1	570
West Penn Power Mitchell 33			+1	300	-1	300								
Total	87	29,538	35	14,481	27	13,796	11	8,235	18	10,075	48	28,850	226	104,975

^aEquivalent scrubbed capacity.

^bThis value was modified slightly due to a MW correction.

Highlights: January - March 1981

The following paragraphs highlight FGD system developments during the first quarter of 1981.

Arizona Public Service announced that initial FGD operations at Cholla commenced in March 1981. The 3 MW (gross) boiler fires pulverized coal with an average sulfur content of 0.5%. Flue gas flows through an ESP to a double-loop, spray-packed tower (Forsberg-Cottrell design) which uses limestone slurry and treats 36% of the flue gas. The system operated 1 week and was shut down for a bearing inspection.

Basin Electric Power Coop announced that a contract was awarded to

Table 3. Performance of Operational Units—January - March 1981

Plant	FGD system capacity, MW ^a	Flue gas % scrubbed	FGD capacity on line during period MW ^b	No information for this period, MW ^a	Shut down throughout period, MW ^a	January 1981 Dependability % ^{c*}				February 1981 Dependability % ^{c*}				March 1981 Dependability % ^{c*}			
						AVL	OPR	REL	UTL	AVL	OPR	REL	UTL	AVL	OPR	REL	UTL
<i>Alabama Electric</i>																	
Tombigbee 2	179	70		179													
Tombigbee 3	179	70		179													
<i>Arizona Electric Power</i>																	
Apache 2	98	50	98			100	63	100	63	100	11	100	11	100	54	100	44
Apache 3	98	50	98			100	53	100	46	100	27	100	27	79	24	53	24
<i>Arizona Public Service</i>																	
Cholla 1	119	100		119													
Cholla 2	264	100		264													
Cholla 4	126	33	126														
Four Corners 1	175	100		175													
Four Corners 2	175	100		175													
Four Corners 3	229	100		229													
<i>Basin Electric Power Coop</i>																	
Laramie River 1	570	100	570			100	95	100	92	100	95	100	85	100	99	100	97
<i>Big Rivers Electric</i>																	
Green 1	242	100	242														
Green 2	242	100	242														
<i>Central Illinois Light</i>																	
Duck Creek 1	416	100	416			93	92	96	92	91	92	99	90	87	84	88	80
<i>Central Illinois Public Service</i>																	
Newton 1	617	100	617			99	90	100	90	100	95	100	95	90	67	100	62
<i>Cincinnati Gas & Electric</i>																	
East Bend 2	650	100	650														
<i>Colorado Ute Electric Association</i>																	
Craig 1	410	90	410			40	48	48	38	9	8	9	7	12	12	12	12
Craig 2	410	90	410			79	78	78	78	66	66	66	66	52	53	54	52
<i>Columbus & Southern</i>																	
<i>Ohio Electric</i>																	
Conesville 5	411	100	411			91	86	85	77	94	92	92	86	4	20	26	1
Conesville 6	411	100	411			98	92	92	92	92	85	85	78	75	97	99	59
<i>Commonwealth Edison</i>																	
Powerton 51	450	100			450				0				0				0
<i>Cooperative Power Association</i>																	
Coal Creek 1	327	60	327			100	44		44	83	53		43	47	61		29
Coal Creek 2	327	60	327			100	57		57	100	57		56	55	55		31
<i>Delmarva Power & Light</i>																	
Delaware City 1	60	100	60			90	90	90	90	86	84	84	76	96	96	96	95
Delaware City 2	60	100	60			93	93	93	93	96	96	96	96	58	89	89	58
Delaware City 3	60	100	60			64	64	64	64	88	88	88	88	81	83	83	83
<i>Duquesne Light</i>																	
Elrama 1-4	510	100	510			100	75	77	75	97	82	82	82				
Phillips 1-6	408	100	408			70	69	95	69	95	69	73	69				
<i>Gulf Power</i>																	
Scholz 1	20	N/A ^d	20														
<i>Indianapolis Power & Light</i>																	
Petersburg 3	532	100		532													
<i>Kansas City Power & Light</i>																	
Hawthorn 3	90	100	90			100	100	100	74	85	100	67	30	52	100	100	52
Hawthorn 4	90	100	90			100	100	100	67	5	100	5	5	86	100	100	62
La Cygne 1	820	100	820			87	100	83	68	99	100	99	66	97	96	97	81
<i>Kansas Power & Light</i>																	
Jeffrey 1	540	75	540														
Jeffrey 2	490	70	490														
Lawrence 4	125	100	125														
Lawrence 5	420	100	420														
<i>Kentucky Utilities</i>																	
Green River 1-3	64	100			64	100			0	100			0	100			0
<i>Louisville Gas & Electric</i>																	
Cane Run 4	188	100	188			81	81	81	81	0	0		0	100	100	100	39
Cane Run 5	200	100	200			100	100	100	89	82	77	77	59	100	46	46	43
Cane Run 6	299	100	299			86	83	83	80	100	100	100	72	100	34	34	28

Table 3. (continued)

Plant	FGD system capacity, MW ^a	Flue gas % scrubbed	FGD capacity on line during period, MW ^{a,b}	No information for this period, MW ^a	Shut down throughout period, MW ^a	January 1981 Dependability % ^{c,*}				February 1981 Dependability % ^{c,*}				March 1981 Dependability % ^{c,*}			
						AVL	OPR	REL	UTL	AVL	OPR	REL	UTL	AVL	OPR	REL	UTL
Mill Creek 1	358	100	358			51	46	46	42	52	52	52	52	39	36	36	
Mill Creek 3	442	100	442			0	0		0	0	0		0	1	1	1	
Paddy's Run 6	72	100			72	100			0	100			0	100			
<i>Minnesota Power & Light</i>																	
Clay Boswell 4	475	85	475			100	95	100	95	100	82	100	81	100	92	100	
<i>Minnkota Power & Light</i>																	
Milton R. Young 2	185	42	185			84	94	100	84	95	100	100	95	88	95	100	
<i>Monongahela Power</i>																	
Pleasants 1	618	100	618														
Pleasants 2	618	100	618														
<i>Montana Power</i>																	
Colstrip 1	360	100	360			96				97							
Colstrip 2	360	100	360			98				97							
<i>Nevada Power</i>																	
Reid Gardner 1	125	100	125			85	85	85	85	43	54	54	43	76	73	73	
Reid Gardner 2	125	100	125			97	96	97	84	93	90	89	75	100	98	98	
Reid Gardner 3	125	100	125			99	99	99	99	100	100	100	100	89	67	67	
<i>Northern Indiana</i>																	
<i>Public Service</i>																	
Dean H. Mitchell 11	115	99			115	100	0		0	100	0		0	100	0		
<i>Northern States Power</i>																	
Riverside 6,7	110	N/A ^d	110														
Sherburne 1	740	91	740			100	100	100	100	100	100	100	95	100	100	100	
Sherburne 2	740	91	740			100	100	100	100	100	100	100	99	100	100	100	
<i>Pacific Power & Light</i>																	
Jim Bridger 4	550	100		550													
<i>Pennsylvania Power</i>																	
Bruce Mansfield 1	917	100	917														
Bruce Mansfield 2	917	100	917														
Bruce Mansfield 3	917	100	917														
<i>Public Service Co. of New Mexico</i>																	
San Juan 1	361	100	361			100	99	100	97	98	92	96	84	100	66	82	
San Juan 2	350	100	350			97	76	98	76	96	31	99	25	94	82	94	
San Juan 3	534	100	534			100	90	98	55	81	80	80	75	98	97	98	
<i>Salt River Project</i>																	
Coronado 1	280	80	280														
Coronado 2	280	80	280														
<i>South Carolina Public Service Authority</i>																	
Winyah 2	140	50	140			99	99	99	99	97	97	97	97	100	100	100	
Winyah 3	280	100	280			66	80	80	66	86	88	88	82	85	100	100	
<i>South Mississippi Electric</i>																	
R.D. Morrow, Sr. 1	124	62	124			100			0	100	92	100	12	86	80	80	
R.D. Morrow, Sr. 2	124	62	124			89	98	98	87	100	100	100	86	86	87	87	
<i>Southern Illinois Power Coop</i>																	
Marion 4	173	100	173			59	50	53	49	67	67	67	67	65	72	75	
<i>Southern Indiana Gas & Electric</i>																	
A.B. Brown 1	265	100	265			99	99	99	99	99	99	99	99	94	86	88	
<i>Springfield City Utilities</i>																	
Southwest 1	194	100	194			58	54	71	54	46	43	46	43				
<i>Springfield Water, Light, & Power</i>																	
Dallman 3	205	100	205			100	58	58	58	50	48	95	40	50	46	46	
<i>St Joe Zinc</i>																	
G F. Weaton 1	60	N/A ^d			60	0	0		0	0	0		0	0	0		
<i>Tennessee Valley Authority</i>																	
Shawnee 10A	10	N/A ^d	10														
Shawnee 10B	10	N/A ^d	10														
Widows Creek 7	575	100	575														
Widows Creek 8	550	100			550												
<i>Texas Power & Light</i>																	
Sandow 4	382	70	382														
<i>Texas Utilities</i>																	
Martin Lake 1	595	75	595														
Martin Lake 2	595	75	595														

Table 3. Concluded

Plant	FGD system capacity, MW ^a	Flue gas % scrubbed	FGD capacity on line during period MW ^{a,b}	No information for this period, MW ^a	Shut down throughout period, MW ^a	January 1981 Dependability % ^{c,*}				February 1981 Dependability % ^{c,*}				March 1981 Dependability % ^{c,*}				
						AVL	OPR	REL	UTL	AVL	OPR	REL	UTL	AVL	OPR	REL	UTL	
Martin Lake 3	595	75	595															
Monticello 3	800	100	800															
Ohio Power & Light																		
Unit 1	360	90	360			100			93	100			95	100			31	
Unit 2	360	90	360			100			89	100			96	100			99	
Unit 1	366	86	366			100			96	100			100	100			94	
Total	29,538		25,825		2,402													

^aivalent scrubbed capacity

^b category includes the flue gas capacity being handled by the FGD system at least part of the time during the report period

^c percent figures listed are average values for all system scrubbing trains during the period.

^d gas % scrubbed for prototype and demonstration units is not applicable unless the system is designed to bring a unit into compliance with SO₂ emission standard.

^e availability, operability, reliability, and utilization as defined in Appendix C of the full report

manufacturing/Niro Atomizer for a lime/spray drying FGD system to be installed at Antelope Valley 2. The 440 V (gross) unit will fire lignite with an average sulfur content of 0.68%. Operations are scheduled to commence in October 1985.

The limestone FGD system operated at Laramie River 1 of Basin Electric Power achieved 100% availability for the first quarter of 1981. The system operated for the 3 month period with no major problems reported.

The dual-alkali scrubbing system installed at Newton 1 of Central Illinois Public Service achieved availabilities of 98%, 100%, and 90% during January, February, and March, respectively. No major FGD-related problems were reported during the three months.

The initial operation of the FGD system at West Bend 2 of Cincinnati Gas and Electric commenced in March 1981. The unit fires pulverized coal with an average sulfur content of 3.0%. A hot-end ESP is followed by three lime FGD modules, supplied by Babcock and Wilcox. The stabilized sludge from this closed water loop system is disposed of in an on-site landfill. The system operated in a shakedown/debugging phase during March.

Colorado Ute Electric announced that construction of the Craig 3 FGD system began during the first quarter of 1981. The lime/spray-drying system is being supplied by Babcock and Wilcox. The 15-MW (gross) unit will fire pulverized subbituminous coal with an average sulfur content of 0.45%. A fabric filter will be used to collect the flyash and the dry calcium sulfite/sulfate particulate matter (as well as any unused reagent).

Table 4. Power Generation Sources; Present and Future

	Coal	Nuclear	Oil	Hydro	Gas	Other	GW (total)
December 1979	39%	9%	25%	13%	13%	1%	603
December 1990	44%	14%	20%	11%	10%	1%	833

Startup of the FGD system is expected in April 1983.

Columbus and Southern Ohio Electric reported that the Conesville 5 FGD system achieved availabilities of 91% and 94% for January and February, respectively. The Conesville 6 FGD system achieved availabilities of 98% and 92% for the same period, respectively. No major FGD-related problems were reported for either system during the 2 months. March performance data were not provided.

The 20-MW prototype dual-alkali/limestone test program being conducted by Thyssen/CEA and Arthur D. Little at the Scholz station of Gulf Power was completed on March 28. The program was conducted to determine the feasibility of using limestone rather than lime as the source of calcium for regeneration reactions. The system reportedly achieved SO₂ removal efficiencies of 96% and 97% during February and March, respectively.

There are no current plans to continue operation of the prototype.

The Elrama FGD system of Duquesne Light achieved availabilities of 100% for January and 97% for February. With the exception of some absorber module lining repairs during February, no major operational problems were encountered during the 2 months. Information for March was not provided.

Iowa Electric Light and Power announced that a letter of intent was signed with Combustion Engineering for the installation of a wet limestone scrubbing system on Guthrie County 1. The unit is rated at 720 MW (gross) and will fire pulverized subbituminous coal with an average sulfur content of 0.4%. An ESP will provide primary particulate matter control. Operations are scheduled to commence in October 1984.

Jacksonville Electric Authority announced that bids are being requested for wet limestone FGD systems to be installed at Units 1 and 2 at the St.

Table 5. FGD Controlled Generating Capacity; Present and Future

	Coal-fired generating capacity controlled by FGD, %	Total generating capacity controlled by FGD, %
March 1981*	13.9	5.4
December 1990	29.6	13.0

*The number of committed FGD systems is as of March 1981; however, the figure used for the total generating capacity and coal-fired generating capacity is based on the available December 1979 figures.




Figure 1. Computerized data base structure diagram.

Unit Performance
Date
Boiler Hours
Boiler Avail
Capacity Factor

Removal Performance
SO₃ REM -%
Part REM -%

Literal Information
Comments/
Abstract

FGD System Performance
Service Hrs
Avail -%
Oper -%
Rel -%
Util -%

Problems Solutions Comments

Process Control and Instrumentation
Proc Stream
Parameters
-Chemical
-Physical

Chemicals
Function
Name
Consumption

Problem/Solution Description

Problem Area

ect

Water Balance
Losses
Additions
Source
Addition Points

Other

re
ity
ition

sal
'Final
e
ion
capacity

Johns River Power Park. Each 500-MW (gross) unit will fire pulverized coal with an average sulfur content of 2.5%. Initial operations are scheduled for 1985 and 1987, respectively.

Kentucky Utilities announced that bids are being requested for limestone FGD systems at Hancock 1 and 2. The 708-MW (gross) units will be located in Hawesville, Kentucky, and will fire Western Kentucky coal with an average sulfur content of 3.5%. ESP's will be used to control particulate matter emissions. Operations are scheduled to commence in 1988 and 1994, respectively.

The FGD system at Clay Boswell 4 of Minnesota Power and Light achieved 100% availabilities during January, February, and March. No major problems were reported for the lime/alkaline flyash FGD system during the 3 months.

Montana Power reported that the Colstrip 1 FGD system achieved availabilities of 96% and 97% for January and February, respectively. The Colstrip 2 FGD system achieved availabilities of 98 and 97% for the same 2 months, respectively. No major FGD related problems were reported for either system. March performance data were not provided.

The limestone/alkaline flyash FGD systems installed at Sherburne 1 and 2 of Northern States Power achieved 100% availabilities for the first quarter of 1981. No major operational problems were reported for the 3 months.

San Juan 1 of the Public Service of New Mexico achieved availabilities of 100%, 98%, and 100% during January, February, and March, respectively. San Juan 2 achieved availabilities of 97%, and 94% during the same period, respectively. No major FGD-related problems were reported during the three months.

The limestone FGD system installed at Winyah 2 of South Carolina Public Service achieved availabilities of 99%, 97%, and 100% during the months of January, February, and March, respectively. An expansion joint problem in the quencher discharge pump was the only major problem reported during the 3 months.

The FGD system installed at A.B. Brown 1 of Southern Indiana Gas and Electric achieved availabilities of 99%, 99%, and 94% during January, February, and March, respectively. Some minor pump and vacuum filter problems were reported during the 3 months; however,

Table 6. Summary of FGD Systems by Process

		Percent of total MW	
		March 1981	December 1990
Throwaway product process			
<i>Wet systems</i>			
<i>Lime</i>		39.6	20.2
<i>Limestone</i>		47.4	36.2
<i>Dual alkali</i>		4.1	1.9
<i>Sodium carbonate</i>		3.1	3.0
<i>NA^a</i>		—	6.3
<i>°Dry systems</i>			
<i>Lime</i>		0.4	2.9
<i>Sodium carbonate</i>		—	0.4
Salable product process			
<i>Process</i>	<i>Byproduct</i>		
<i>Aqueous carbonate/ spray drying</i>	<i>Elemental sulfur</i>	—	0.1
<i>Citrate</i>	<i>Elemental sulfur</i>	0.2	0.1
<i>Lime</i>	<i>Gypsum</i>	—	0.1
<i>Limestone</i>	<i>Gypsum</i>	—	0.2
<i>Lime/limestone</i>	<i>Gypsum</i>	—	0.5
<i>Magnesium oxide</i>	<i>Sulfuric acid</i>	—	0.7
<i>Wellman Lord</i>	<i>Sulfuric acid</i>	2.4	1.2
<i>Wellman Lord</i>	<i>Elemental sulfur</i>	2.8	0.7
<i>Process undecided</i>		—	25.5
<i>Total</i>		100.0	100.0

^a Not available (these systems are committed to a throwaway product process; however, the actual process is unknown at this time).

overall system unavailable time was minimal.

Tennessee Valley Authority announced that initial FGD operations at Widows Creek 7 commenced in March 1981. The 575-MW (gross) unit fires pulverized coal with an average sulfur content of 3.7%. The limestone spray tower absorber FGD system is preceded by an ESP and four variable-throat venturiers for primary particulate matter control. The system operated in a shake-down/debugging mode throughout March.

Utah Power and Light announced that construction of the FGD systems at Hunter 3 and 4 began in March 1981. The 400-MW (gross) units are being constructed in Castledale, Utah, and will fire pulverized bituminous coal with an average sulfur content of 0.55%. GE Environmental Services, Inc. (formerly Chemico) is supplying the limestone FGD systems which are expected to begin initial operations in 1983 and 1985, respectively.

Washington Water Power announced plans to construct Creston Coal 2, 3, and 4 in Creston, Washington. Each 570-MW (gross) unit will use a limestone FGD system for SO₂ control. Construction at this site is scheduled to commence in 1983, with initial operation of the units currently scheduled for 1987.

West Pennsylvania Power announced that construction of the Mitchell 33 FGD system began in March 1981. This 300-MW (gross) unit is being constructed in Courtney, Pennsylvania, and will fire coal with an average sulfur content of 2.8%. The lime scrubbing process is being supplied by GE Environmental Services, Inc., and is designed for a 95% SO₂ removal efficiency. The system is expected to commence operation in August 1982.

References

1. U.S. Department of Energy. Energy Information Administration. Office of Coal and Electric Power Statistics. Electric Power Statistics Division.

Inventory of Power Plants in the United States, December 1979.
Report No. DOE/EIA-0095 (79).

2. Rittenhouse, R.C. *New Generating Capacity: When, Where, and by Whom.* Power Engineering 82(4):57. April 1978.

M. Smith, M. Melia, N. Gregory, and K. Scalf are with PEDCo Environmental, Inc., Cincinnati, OH 45246.

Norman Kaplan is the EPA Project Officer (see below).

The complete report, entitled "EPA Utility FGD Survey, January-March 1981," (Order No. PB 81-225 773; Cost: \$23.00, subject to change) will be available only from:

*National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161
Telephone: 703-487-4650*

The EPA Project Officer can be contacted at:

*Industrial Environmental Research Laboratory
U.S. Environmental Protection Agency
Research Triangle Park, NC 27711*



Business
Private Use, \$300

MS. LOU W. TILLEY
ENVIRONMENTAL PROTECTION AGENCY
R/O V
270 S. DEARBORN ST.
CHICAGO, ILLINOIS
60604