



## Project Summary

# Analysis of Long-Term NO Emission Data from Pulverized Coal-Fired Utility Boilers

S. S. Cherry

Long-term NO emission monitoring data from nine pulverized-coal-fired utility boilers were analyzed. These data were in the form of hourly averaged NO, O<sub>2</sub> (or CO<sub>2</sub>), and load: NO and O<sub>2</sub>/CO<sub>2</sub> were measured with certified continuous emission analyzers. The analyses were compared to the emissions limitations in both the 1971 and 1978 New Source Performance Standards (NSPS).

The comparison with the 1978 NSPS showed that seven of the nine boilers would have produced no periods of excess NO emissions on a 30-day rolling average basis. In addition, the same seven boilers would have complied with the 1978 NSPS NO<sub>x</sub> performance test requirements.

Recommendations are made to more fully analyze the operation of two of these boilers to determine if their mode of operation could be adopted by other boilers. These boilers use permanently installed CO monitors to allow operation at the lowest practical excess air to achieve either low NO emissions or better fuel efficiency.

*This Project Summary was developed by EPA's Industrial Environmental Research Laboratory, Research Triangle Park, NC, to announce key findings of the research project that is fully documented in a separate report of the same title (see Project Report ordering information at back).*

### Introduction and Summary

Long-term NO emission data from nine pulverized-coal-fired utility boilers were analyzed to determine the degree to

which compliance was achieved with both the 1971 and 1978 New Source Performance Standards (NSPS). These standards are summarized in Table 1. Pertinent boiler characteristics are summarized in Table 2.

Table 1. Summary of 1971 and 1978 Coal NO<sub>x</sub> NSPS

Coal Type	NO <sub>x</sub> lb/10 <sup>6</sup>	
	ng/J	Btu
<b>1971<sup>a</sup></b>		
Subbituminous	300	0.70
Bituminous	300	0.70
Lignite (Dakotas or Montana)	340	0.80
Other Lignites	260	0.60
<b>1978<sup>b</sup></b>		
Subbituminous	210	0.50
Bituminous	260	0.60
Lignite (Dakotas or Montana)	340	0.80
Other Lignites	260	0.60

<sup>a</sup>3-hr averaging period (rolling or block).  
<sup>b</sup>30-day rolling average.

The NO and O<sub>2</sub> (or CO<sub>2</sub>) data were measured by certified analyzers.\* The utilities also supplied hourly averaged unit load, monitor certification reports, and periodic coal analyses as part of the data packages.

A KVB computer program was specially modified for this study to perform the following computations:

\*All analyzers were measuring NO only, not NO<sub>x</sub>. EPA allows the use of NO-only analyzers to satisfy the requirement to measure "oxides of nitrogen."

**Table 2. Boiler Pertinent Information**

Utility	Station	Coal Unit	Type <sup>a</sup>	Boiler Mfg <sup>b</sup>	Gross MWe	NO <sub>x</sub> Controls <sup>c</sup>	Site Visit
Oklahoma Gas & Electric	Muskogee	4	Sub.	CE	550	Tang. + OFA	Yes
		5	Sub.	CE	550	Tang. + OFA	Yes
Omaha Public Power District	Nebraska City	1	Sub.	FW	575	Interstage air	No
Iowa Power & Light	Council Bluffs	3	Sub.	B&W	720	DRB	Yes
Pennsylvania Electric	Homer City	3	Bit.	B&W	680	DRB	Yes
Louisville Gas & Electric	Mill Creek	3	Bit.	B&W	425	DRB	No <sup>d</sup>
Proprietary	---	A	Sub.	CE	350	Tang. + OFA	Yes
		B	Sub.	CE	350	Tang. + OFA	Yes
Public Service New Mexico	San Juan	1	Sub.	FW	360	OFA + DRB	Yes

<sup>a</sup> Sub. = Subbituminous Bit. = Bituminous

<sup>b</sup> CE = Combustion Engineering FW = Foster Wheeler B&W = Babcock & Wilcox

<sup>c</sup> Tang. = Tilting tangential OFA = Overfire air DRB = Dual register burner

<sup>d</sup> Detailed information obtained by letter.

- Daily means and standard deviations of NO, O<sub>2</sub> (or CO<sub>2</sub>), and load.
- Means and standard deviations of NO and O<sub>2</sub>/CO<sub>2</sub> as functions of unit load.
- Load probability.
- NO probability.
- Number of periods of excess NO emissions with respect to the 1971 NSPS on both a 3-hour rolling average and 3-hour block average basis.
- Number of periods of excess NO emissions with respect to the 1978 NSPS on a 30-day rolling average basis.

Sites were visited (see Table 2) to discuss details of monitor and boiler operation. As a result of these visits, revised computer analyses were performed for certain boilers when it was determined that some of the monitor data was of questionable validity.

The results of this study are summarized in Table 3. Note that seven of the nine boilers would have complied with the 1978 NSPS performance test and that the same boilers would not have produced any periods of excess emissions on a 30-day rolling average basis. (The "Maximum" column is the

number of 30-day rolling averages obtained from the data, each of which is a potential period of excess emissions.)

### Discussion

Long-term NO emissions data from nine pulverized-coal-fired utility boilers were analyzed and compared with the

**Table 3. Analysis Summary**

Boiler	Coal Type <sup>a</sup>	1978 NSPS Performance		1971 NSPS NO <sub>x</sub> Exceedances		1978 NSPS NO <sub>x</sub> Exceedances	
		Per- ng/J	Number of Valid Days	Rolling	Block	Actual	Maximum
Muskogee 4	Sub.	208	94	17	6	0	65
Revised		207	78	17	6	0	49
Muskogee 5	Sub.	179	82	16	6	0	53
Revised		<sup>b</sup>	21	5	2	--	--
Nebraska City 1	Sub.	228 <sup>c</sup>	31	30	12	2	2
Council Bluffs 3	Sub.	141	96	0	0	0	67
Revised		138	63	0	0	0	34
Homer City 3	Bit.	274 <sup>c</sup>	61	161	60	32	32
Mill Creek 3	Bit.	210	54	0	0	0	25
Unit A	Sub.	189	75	75	31	0	46
Unit B	Sub.	158	78	2	2	0	49
San Juan 1	Sub.	175	57	0	0	0	28

<sup>a</sup> Sub. = Subbituminous Bit. = Bituminous

<sup>b</sup> Insufficient data to calculate 30-day rolling average.

<sup>c</sup> Would not have complied with 1978 NSPS performance test.

1978 NSPS. Note that none of these boilers are subject to the 1978 NSPS but were included in the study because they were equipped with certified continuous emission monitors (CEM).

Each utility submitted a data package consisting of: hourly averages of NO, O<sub>2</sub> (or CO<sub>2</sub>)\*; CEM certification reports; and periodic coal analyses. These packages were reviewed for completeness and legibility. Discrepancies were resolved with the utility by telephone.

The hourly averages were entered on computer input sheets for analysis by a specially modified computer program. Plots were prepared of NO and O<sub>2</sub> (or CO<sub>2</sub>) as a function of unit load prior to the site visits in order to identify any unusual results.

Seven of the nine boilers analyzed were visited during this assignment. Details on an eighth boiler were obtained by letter. The purpose of these visits was to hold detailed discussions with the appropriate station personnel. Topics discussed included:

- Boiler Design--
  - Boiler description, number of burners and burner arrangement, and heat release rate.
  - Operation of dual register burners and/or overfire air system.

\*The 1971 NSPS allows the use of either O<sub>2</sub> or CO<sub>2</sub> as a dilution correction. CO<sub>2</sub> was used on only one boiler.

2. Boiler Operation--
  - a. O<sub>2</sub> versus load.
  - b. Heat rate.
  - c. Steam temperature problems.
  - d. Slagging/fouling characteristics.
  - e. Unit availability/load limitations.
  - f. Ash carbon characteristics.
  - g. Tube wastage.
  - h. NO excess emissions.
3. CEM System--
  - a. Make and model.
  - b. Sampling location.
  - c. Data reduction procedure.
  - d. Recertification.
  - e. Calibration procedure, frequency, out-of-calibration flag, and corrective action.
  - f. Quality assurance program.
4. Coal Supply--
  - a. Source.
  - b. Nominal characteristics and variability.




Figure 2. Mill Creek Unit 3 - load probability.

If the site visit identified some of the data as being of questionable validity, a revised computer analysis was performed, deleting these data.

The analysis is illustrated by the results computed for Mill Creek Unit 3. Figure 1 shows the boiler characteristics (NO and O<sub>2</sub>) developed as a function of load. These characteristics were computed by sorting the data into 10 load "cells" and averaging the associated values of NO and O<sub>2</sub>. Note the relatively flat NO emission factor across the load range. Apparently, the decrease in O<sub>2</sub> with load is sufficient to nearly offset the higher heat release rate. Figure 2 is the load

probability distribution, representable only in terms of its median value of 270 gross MWe (63.5 percent of rating). Figure 3 indicates that the hourly averaged NO is normally distributed with a mean of 215 ng/J and a standard deviation of 27 ng/J.

Muskogee Units 4 and 5 are nominally identical, yet their NO characteristics are significantly different (Figure 4). Note that the maximum NO emission factor occurs at less than full load, and that Unit 5 indicates a significant NO decrease with loads above 200 gross MWe. The difference in O<sub>2</sub> characteristics (Figure 5)

was deemed to be insufficient to completely resolve the difference in NO.

The NO emissions from Council Bluffs 3 and San Juan 1 were low, compared to the other boilers analyzed. Visits to these two units indicated that they were being operated with the minimum air flow practical, and that both units were equipped with CO monitors as operating adjuncts. Reasons for this mode of operation were:

Council Bluffs 3--

- Induced draft fan limitation at high load
- Fuel economy

San Juan 1--

- More stringent State of New Mexico NO<sub>x</sub> limitation

In addition, neither unit was experiencing any unusual conditions due to low air operation; e.g., slagging, fouling, unburned carbon.

### Conclusions and Recommendations

The major conclusion of this study was that seven of the nine boilers analyzed would have complied with the 1978 NSPS performance test requirements and would have produced no periods of excess NO emissions on a 30-day rolling average basis. The main exception




Figure 1. Mill Creek Unit 3 - boiler characteristics.




Figure 3. Mill Creek Unit 3 - NO probability.




Figure 4. Muskogee Units 4 and 5 - comparison of NO characteristic.




Figure 5. Muskogee Units 4 and 5 - comparison of O<sub>2</sub> characteristic.

(Homer City 3) is operated in a base-loaded manner; therefore, it is not possible to "average in" potentially lower NO emissions at reduced load.

It was also established that Council Bluffs 3 and San Juan 1 are low NO emission sources across their respective load ranges. This is attributed to their being operated with the lowest practical excess air with the assistance of a CO monitor.

It is recommended that the operation of these two units be documented in detail and then discussed with the respective boiler manufacturers to determine if this mode of operation could be adopted by other boilers.

It is also noted that base-loaded units behave differently with respect to 30-day NO<sub>x</sub> rolling averages since they do not have the operational flexibility to "average in" periods of potentially lower NO emissions at lower loads to meet the 1978 NO<sub>x</sub> standard.

---

**S. S. Cherry is with KVB, Inc., Irvine, CA 92714.**

**Robert E. Hall is the EPA Project Officer (see below).**

**The complete report consists of two volumes, entitled "Analysis of Long-Term NO Emission Data from Pulverized Coal-Fired Utility Boilers,"**

**"Volume I. Technical Analysis," (Order No. PB 83-175 000; Cost: \$19.00, subject to change)**

**"Volume II. Appendices," (Order No. PB 83-175 018; Cost: \$32.50, subject to change) will be available only from:**

**National Technical Information Service**

**5285 Port Royal Road**

**Springfield, VA 22161**

**Telephone: 703-487-4650**

**The EPA Project Officer can be contacted at:**

**Industrial Environmental Research Laboratory**

**U.S. Environmental Protection Agency**

**Research Triangle Park, NC 27711**

United States  
Environmental Protection  
Agency

Center for Environmental Research  
Information  
Cincinnati OH 45268

Postage and  
Fees Paid  
Environmental  
Protection  
Agency  
EPA 335



Official Business  
Penalty for Private Use \$300

PS 0000329  
U S ENVIR PROTECTION AGENCY  
REGION 5 LIBRARY  
230 S DEARBURN STREET  
CHICAGO IL 60604