

Research and Development



Package Water Treatment Plants

Volume 2. A Cost Evaluation



RESEARCH REPORTING SERIES

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into nine series. These nine broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and a maximum interface in related fields. The nine series are:

1. Environmental Health Effects Research
2. Environmental Protection Technology
3. Ecological Research
4. Environmental Monitoring
5. Socioeconomic Environmental Studies
6. Scientific and Technical Assessment Reports (STAR)
7. Interagency Energy-Environment Research and Development
8. "Special" Reports
9. Miscellaneous Reports

This report has been assigned to the ENVIRONMENTAL PROTECTION TECHNOLOGY series. This series describes research performed to develop and demonstrate instrumentation, equipment, and methodology to repair or prevent environmental degradation from point and non-point sources of pollution. This work provides the new or improved technology required for the control and treatment of pollution sources to meet environmental quality standards.

EPA-600/2-80-008b
July 1980

PACKAGE WATER TREATMENT PLANTS

Volume 2. A Cost Evaluation

by

Richard G. Stevie
Robert M. Clark

Drinking Water Research Division
Municipal Environmental Research Laboratory
Cincinnati, Ohio 45268

Contract No. GS-05S-10458

Project Officer

Robert M. Clark
Drinking Water Research Division
Municipal Environmental Research Laboratory
Cincinnati, Ohio 45268

MUNICIPAL ENVIRONMENTAL RESEARCH LABORATORY
OFFICE OF RESEARCH AND DEVELOPMENT
U.S. ENVIRONMENTAL PROTECTION AGENCY
CINCINNATI, OHIO 45268

DISCLAIMER

This report has been reviewed by the Municipal Environmental Research Laboratory, U.S. Environmental Protection Agency, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the U.S. Environmental Protection Agency, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

FOREWORD

The Environmental Protection Agency was created because of increasing public and government concern about the dangers of pollution to the health and welfare of the American people. Noxious air, foul water, and spoiled land are tragic testimonies to the deterioration of our natural environment. The complexity of that environment and interplay among its components require a concentrated and integrated attack on the problem.

Research and development is that first step in problem solution, and it involves defining the problem, measuring its impact, and searching for solutions. The Municipal Environmental Research Laboratory develops new and improved technology and systems (1) to prevent, treat, and manage wastewater, solid and hazardous waste, and pollutant discharges from municipal and community sources, (2) to preserve and treat public drinking water supplies, and (3) to minimize the adverse economic, social, health, and aesthetic effects of pollution. This publication is a product of that research and is a most vital communications link between the researcher and the user community.

One of the major problems facing the U. S. Environmental Protection Agency in meeting the requirements of the Safe Drinking Water Act is helping small and rural water systems in achieving compliance. This report presents results from a study on the cost and performance characteristics of self-contained package water treatment plants. These data should be useful in assisting small and rural systems in providing high quality drinking water.

Francis T. Mayo,
Director
Municipal Environmental Research
Laboratory

ABSTRACT

Many small and rural water systems have both cost and quality problems. Their unit costs tend to be higher because of the small number of connections they service. As shown by the Community Water Supply Survey of 1969, many small systems have trouble meeting minimal drinking water standards. These problems are likely to be compounded in the future as drinking water standards are raised. The cost of building a conventional water treatment plant to provide higher quality water for a small community may be prohibitive. A possible alternative to a conventional water treatment plant is a package water treatment plant. These plants are self-contained units that can be installed for minimum cost.

Results from a study of 36 package plants in Kentucky, West Virginia, and Tennessee show that treatment plants can provide water that meets the turbidity requirement of the National Interim Primary Drinking Water Standards. However, as with all treatment plants, proper operation is required. These plants, contrary to some manufacturers' claims, are not totally automatic but require supervision. Nevertheless, when properly maintained and operated, they can provide water that meets the Safe Drinking Water Act's MCLs at a cost less than that associated with conventional treatment.

The results of this study indicate two aspects. Scale economies exist in package treatment plants under 1 mgd. The average flow rate for the municipal systems in this study was found to be slightly less than 0.2 mgd, implying that the average plant will be able to achieve the scale economies that potentially exist with this technology.

Therefore, based on this study, it is felt that package plants can be used in a cost effective manner to meet the turbidity requirements of the Safe Drinking Water Act, and still not impose an enormous burden on the utility's budget.

This report (Volume 2) present the results of a cost evaluation study for package water treatment plants. Volume 1 discusses the performance of package plants with minimal cost evaluation.

This report was submitted in fulfillment of Contract GS-05S-10458. This report covers the period June 1977 to June 1979, and work was completed as of June 1979.

CONTENTS

	Page
FOREWORD	iii
ABSTRACT	iv
FIGURES	vi
TABLES	vii
METRIC CONVERSION TABLE	ix
ACKNOWLEDGEMENTS	x
INTRODUCTION	1
PACKAGE PLANT DATA ANALYSIS	2
Package Plants	2
Cost and Quality Data	2
DESCRIPTIVE ANALYSIS OF THE DATA	6
Utility Data Analysis	6
Package Treatment Plant Data	6
EMPIRICAL METHODOLOGY	29
Discussion of Methodology	29
Production Functions	29
Chemical Cost Relationships	31
EMPIRICAL RESULTS	32
Predictive Relationships	32
Quasi-Production Functions	38
Combined Chemical Costs	40
Conclusions	40

	Page
COST COMPARISON AND CONCLUSIONS	41
Comparative Cost Analysis	41
Conclusions	44
REFERENCES	45
APPENDIX A - Quality Data from Municipal and Recreational Plants .	46
APPENDIX B - Data Collection Guide for Package Plants	50
APPENDIX C - Cost Data from Municipal and Recreational Plants . . .	59

FIGURES

<u>Number</u>		<u>Page</u>
1	Operating and Capital Costs for Municipal Utilities (Total and Percent of Total)	8
2	Operating and Capital Costs for Recreational Utilities (Total and Percent of Total)	9
3	Operating and Capital Costs for Combined Data Set (Total and Percent of Total)	10
4	Operating Cost Functions for Municipal Utilities (Total and Percent of Total)	11
5	Operating Cost Functions for Recreational Utilities (Total and Percent of Total)	12
6	Operating Cost Functions for Combined Data Set (Total and Percent of Total)	13
7	Capital Cost Functions for Municipal Utilities (Total and Percent of Total)	14
8	Capital Cost Functions for Recreational Utilities (Total and Percent of Total)	15
9	Capital Cost Functions for Combined Data Set (Total and Percent of Total)	16
10	Principal Operating Cost Components for Municipal Utilities (Total and Percent of Total)	17

<u>Number</u>		<u>Page</u>
11	Principal Operating Cost Components for Combined Utilities (Total and Percent of Total)	18
12	Principal Operating Cost Components for Combined Data Set (Total and Percent of Total)	19
13	Municipal Package Plants Operating and Capital Cost (Total and Percent of Total)	20
14	Recreational Package Plants Operating and Capital Cost (Total and Percent of Total)	21
15	Combined Package Plants Operating and Capital Cost (Total and Percent of Total)	22
16	Municipal Package Plant Construction Cost Components (Total and Percent of Total)	23
17	Recreational Package Plant Construction Cost Components (Total and Percent of Total)	24
18	Combined Package Plant Construction Cost Components (Total and Percent of Total)	25
19	Municipal Package Plants Operating Cost Elements (Total and Percent of Total)	26
20	Recreational Package Treatment Plants Operating Cost Elements (Total and Percent of Total)	27
21	Combined Package Plant Operating Cost Elements (Total and Percent of Total)	28
22	Total Unit Construction Costs for System and Package Plants (Municipal Utilities	36
23	Total Unit O&M Cost for System and Package Plant (70% of capacity)	37
24	Total Construction Cost Versus Plant Capacity	42
25	Annual Cost Versus Revenue Producing Water	43

TABLES

Number		Page
1	Types of Plants Studied	3
2	Locations of Plants Studied	4
3	Utility O&M Costs by Major Cost Components ($C = aQ^b$) . . .	33
4	Total Cost Equations (O&M and Capital) by Major Cost Components ($C = aQ^b$)	34
5	Construction Costs for Package Plants and Total System ($C = aQ^b$)	35
6	Substitution Elasticities Among Q, L, C, and E	39
7	Comparative Cost Analysis for 1 MGD Plant	44

METRIC CONVERSION TABLE

English Units

1 foot
1 mile
1 sq mi
1 mil gal
1 \$/mil gal

Metric Equivalents

0.305 meters
1.61 kilometers
2.59 sq kilometers
3.79 thou cu meters
0.26 \$/thou cu meters

ACKNOWLEDGEMENTS

The authors wish to acknowledge the assistance of the following individuals: Dr. Gary Logsdon, Messrs. Walter Feige, Daniel Guttman, Jeffrey Adams, and Michael Laugle of the Drinking Water Research Division, Municipal Environmental Research Laboratory, USEPA, and Mr. Carl Schneider of PEDCO, Incorporated, Cincinnati, Ohio.

The authors would like to extend a special acknowledgement to Mr. Larry Gray and Mr. Steve Cordle for their encouragement and support throughout all phases of this study.

INTRODUCTION

Many studies have attempted to evaluate the costs associated with conventional water treatment plant design and operation.^{1,2,3} Evidence from these studies indicates that significant economies of scale exist in construction as well as in day-to-day operation. The large expenditures required to construct and maintain such a treatment system can place an immense burden on small water utilities. Package water treatment plants have been suggested as an alternative to conventional technologies, but little is known about their costs and performance. This report evaluates the cost-effectiveness of operating package treatment plants. It is hoped that the information provided in this report will aid water utility managers.

The following section contains a description of the data collected during the study and a discussion of cost allocation procedures utilized. In additional sections: a descriptive analysis of the data is provided; empirical methodology is presented, which involves identifying the relationships to be estimated; factors affecting the cost of water supply are identified; empirical results are presented and interpreted; and, a comparative analysis of conventional and package treatment plant technologies is made.

PACKAGE PLANT DATA ANALYSIS

PACKAGE PLANTS

Package water treatment plants are prefabricated treatment systems requiring minimal on-site construction. Necessary installation procedures involve assembly of prefabricated parts, a hook-up to an existing pipe network, and the construction of a building to house the plant. Table 1 lists the types of plants visited, and Table 2 specifies their location.

The package plants studied were categorized as being either municipal or recreational in nature. Municipal plants generally serve a stable population and are operated year-round, while recreational plants serve a transient population and tend to be operated sporadically.

COST AND QUALITY DATA

Data were collected in two major areas: quality and cost. Quality data reflect the capability of package plants to purify source water in order to meet drinking water standards. Cost data can be used to evaluate the cost effectiveness of this type of treatment technology.

Quality information gathered for both raw and finished water included alkalinity, hardness, pH, temperature, turbidity, coliforms, and inorganic chemicals. Information on other selected quality variables was also collected, such as the type of water source (ground, spring, free-flowing surface, or impounded surface), level of nitrate, fluoride, free chlorine residual, and trihalomethanes; and the input concentration of certain chemicals: alum, polyelectrolyte, soda ash, and lime. Based on quality data, the ability to meet the drinking water standards can be determined. Appendix A, Tables A-1 and A-2, list the quality data for both municipal and recreational plants.

Cost and operational information was collected on numerous aspects of individual package plants as well as for the utility as a whole. Data forms used in the study are contained in Appendix B. Utility costs were separated into four major components: acquisition, treatment, distribution, and support services. The first three represent functional areas related to the physical operation of the plant. Acquisition includes all operating and capital (depreciation plus interest) costs incurred in collecting water for delivery to the treatment plant. Treatment costs include operating and capital costs associated with the purification of source water by the package plant, and distribution expenditures involve

Table 1. TYPES OF PLANTS STUDIED

<u>Sites</u>	<u>Manufacturer</u>	<u>Model</u>	<u>Capacity</u>
5	Neptune Microfloc	WB-27	20 gpm
1	Permutit		48 gpm
6	Neptune Microfloc	SB-82	60 gpm
1	Intermountain Systems	60TS/PF-IF	60 gpm
3	Neptune Microfloc	WB-133	100 gpm
7	Neptune Microfloc	AQ-40	200 gpm
1	Hungerford & Terry	L-28	200 gpm
1	Permutit		200 gpm
5	Neptune Microfloc	AQ-70	350 gpm
3	Neptune Microfloc	AQ-112	560 gpm
2	Neptune Microfloc	AQ-180	900 gpm
1	Neptune Microfloc	Concrete	1000 gpm

Table 2. LOCATIONS OF PLANTS STUDIED

I. MUNICIPAL PLANTS

Alderson, W. Va.
Anawalt, W. Va.
Bonde Croft Utility District, Sparta, Tenn.
Carrollton Utilities, Carrollton, Ky.
Coal River PSD, Racine, W. Va.
Franklin, W. Va.
Greenup, Ky.
Hambrick PSD, Hendricks, W. Va.
Marrowbone Plant, Regina, Ky.
Mountain Top PSD, Mount Storm, W. Va.
Mowbray Utility Dist., Soddy Daisy, Tenn.
Nettie-Levisay PSD, Nettie, W. Va.
Preston County PSD, Reedsville, W. Va.
Richwood, W. Va.
Russell Springs, Ky.
Stanton, Ky.
Thomas, W. Va.
Union, W. Va.
Winfield, W. Va.

II. RECREATIONAL PLANTS

Apple Valley Resort, Jamestown, Ky. (private)
Big Bone State Park, Union, Ky. (state)
Canaan Valley State Park, Davis, W. Va. (state)
Carr Fork Lake, Irishman Creek Rec. Area, Sassafras, Ky. (USCE)*
Dewey Lake, Prestonburg, Ky. (USCE)
East Lynn Lake, East Fork Rec. Area, East Lynn, W. Va. (USCE)
East Lynn Lake, Utility Bldg., East Lynn, W. Va. (USCE)
Fishtrap Lake, Shelbiana, Ky. (SCE)
Green River Reservoir, Holmes Bend Rec. Area, Campbellsville, Ky. (USCE)
J. Percy Priest Reservoir, Cook Rec. Area, Nashville, Tenn. (USCE)
J. Percy Priest Reservoir, Fate Sanders Rec. Area, Nashville, Tenn. (USCE)
J. Percy Priest Reservoir, Poole Knobs Rec. Area, Nashville, Tenn. (USCE)
J. Percy Priest Reservoir, Seven Points Rec. Area, Nashville, Tenn. (USCE)
Natural Bridge State Park, Slade, Ky. (state)
Norris Dam State Park, Norris, Tenn. (state)
Smith County Rest Area (Interstate 40, Tenn. (state)
Snowshoe Ski Resort, Slaty Fork, W. Va. (private)

* USCE stands for U. S. Army Corps of Engineers.

all costs incurred in delivery of the finished or treated drinking water to the consumer. The fourth component, support services, is related to the overall utility management function. Support service costs include activities, such as billing, supervision, accounting, and general items, not directly related to any of the other three components. In addition, subelement operating costs (chemical, payroll, and power) were collected for each component. These are isolated for analysis as to their individual impact on operating expenditures as well as their productive input into the operation of a utility. In general, the data collected in this study had to be allocated to each component, since the original cost records do not conform to this categorization. In many cases, this allocation was based upon a proportion suggested by the utility manager.

Package water treatment plant costs were also collected according to the four major categories. As with the total utility costs each category was subdivided into chemical, payroll, and power costs. Capital costs were categorized according to installation, building, and the package plant itself and also aggregated into total cost. Installation capital expense includes the depreciation and interest spent to make the plant operational; building capital expense involves the annualized construction cost of a building to house the package plant; and package plant capital is the annualized purchase price of the plant. Many of the utilities did not depreciate their facilities, therefore, a depreciation schedule was constructed, based on a 20-yr life and a 5 percent interest rate. An interest rate of 5 percent was used to reflect historical costs not current or incremental costs. Appendix C tables C-1 and C-2 contains all information generated (-2 indicates missing data).

Not all of the utilities were established in the same year, and not every utility had current expenditures available. Therefore, capital and operating costs were adjusted to a common base, using regional consumer price indices, for 1977. The inflation factors for each utility are listed in Table C-3. Cost figures in tables C-1 and C-2 have already been adjusted for inflation.

DESCRIPTIVE ANALYSIS OF DATA

In this section a descriptive analysis of the collected data is performed at two levels. An aggregate analysis of data at the utility level has been made as well as a more detailed analysis of the package plants themselves.

UTILITY DATA ANALYSIS

Figures 1, 2, and 3 show the relationship between O&M (operation and maintenance costs), depreciation, and interest expenses for municipal, recreational (which do not operate year-round), and the combined utilities. It is obvious that for these small utilities, having an average flow rate of .115 MGD (.195 MGD for municipal plants and 0.35 MGD for recreational plants when operating), capital cost is a very important factor.

Figures 4 to 6 show the allocation of operating cost to acquisition, treatment, transmission, and distribution based on the latest year of information. In general, acquisition costs are lowest, while treatment costs are highest. These costs result from the chemical, power, and labor costs associated with operating the treatment plant.

Figures 7 to 9 show the allocation of capital. Distribution capital expenditures are highest in municipal utilities, but treatment capital is highest in recreational utilities. Municipal utilities tend to have elaborate distribution systems with a larger number of service connections than do recreational systems. Figures 10 to 12 present average yearly expenditures for labor, chemicals and power. Labor cost is the predominant factor, ranging from 67% to 71% of the total cost of chemicals, power, and labor.

PACKAGE TREATMENT PLANT DATA

The following analysis is directed toward the treatment function specifically. Figures 13 to 15 show the average operating and maintenance cost, depreciation, and interest for the treatment function. Capital dominates treatment costs. As might be expected, total treatment is more expensive for municipal than for recreational plants.

As shown in figures 16 to 18, the treatment capital costs have been subdivided into the average construction costs for the plant itself, the building to house the plant, and the installation cost. Housing is the greatest portion of capital cost, amounting to over 40% of the treatment plant construction cost. The purchase price of the prefabricated plant

is significant, but the building to house the plant remains the most important cost item, and is also the factor which can be best controlled by the utility manager. If a utility were to construct the building itself, some costs might be cut from total treatment expenditures.

Figures 19 to 21 show the treatment, labor, chemical and power cost elements. Labor cost dominates, representing 50% to 65% of the total chemical, power, and payroll expense. Treatment labor expense comprises almost 50% of the total utility payroll. The degree of labor time apportioned to the treatment function can affect the level of quality. This is analyzed more closely in the empirical work to follow. In general, from the quality analysis, it was evident that with more time devoted to the operation of the treatment plant a higher quality of water was produced.




Figure 1. Operating and Capital Costs for Municipal Utilities




Figure 2. Operating and Capital Costs for Recreational Utilities




Figure 3. Operating and Capital Costs for Combined Data Set




Figure 4. Operating Cost Functions for Municipal Utilities




Figure 5. Operating Cost Functions for Recreational Utilities




Figure 6. Operating Cost Functions for Combined Data Set




Figure 7. Capital Cost Functions for Municipal Utilities




Figure 8. Capital Cost Functions for Recreational Utilities




Figure 9. Capital Cost Functions for Combined Data Set




Figure 10. Principle Operating Cost Components for Municipal Utilities




Figure 11. Principle Operating Cost Components for Recreational Utilities




Figure 12. Principle Operating Cost Components for Combined Data Set




Figure 13. Municipal Package Plants Operating and Capital Cost




Figure 14. Recreational Package Plants Operating and Capital Cost




Figure 15. Combined Package Plants Operating and Capital Cost




Figure 16. Municipal Package Plant Construction Cost Components




Figure 17. Recreational Package Plant Construction Cost Components




Figure 18— Combined Package Plant Construction Cost Components




Figure 19. Municipal Package Plants Operating Cost Elements




Figure 20. Recreational Package Treatment Plants Operating Cost Elements




Figure 21. Combined Package Plant Operating Cost Elements

EMPIRICAL METHODOLOGY

Many approaches have been used to examine the cost structure of an industry or firm. Two are discussed by Johnston⁴ in his book on statistical estimation of cost functions. According to Johnston, cost curves can be analyzed on the basis of accounting records or through the use of key explanatory variables. Cost curve estimation based on accounting records reflects the production relationships involved. The use of explanatory variables attempts to provide information on the relation between cost and selected factors which theoretically affect cost. This study utilizes both approaches. Accounting data were collected from municipal and recreational water utilities which use package water treatment plants, but most empirical relationships developed in this report are for predictive as well as explanatory purposes.

DISCUSSION OF METHODOLOGY

Major predictive relationships were developed to estimate costs based upon design capacity or flow in the form of a power function, as follows:

$$C = A Q^b \quad (1)$$

where Q = design capacity or flow, million gallons/year;

C = total cost, \$/year;

b = cost elasticity; and

A = constant.

Separate equations were estimated for the municipal, recreational, and combined data sets. The combined data set does not necessarily reflect the actual proportion of municipal to recreational facilities in the population. But some indication of the general relationships in the total population can be determined from this data set. Results from the individual data sets are more applicable for some predictive purposes.

PRODUCTION FUNCTIONS

Production function relationships cannot be explicitly estimated, because the usage of each input factor was not collected except for the chemical input ratios. Therefore, the general trade-off among inputs cannot be determined, but some indication of the substitutability among the

inputs can be determined by examination of the costs. The following production function was hypothesized:

$$Q = f(L, P, Q, K) \quad (2)$$

where L = labor units, man-hours;

P = power units, kwh;

K = design capacity, MG/yr;

Q = revenue-producing water, MG/yr.

As a variant on equation 2, total cost can be expressed as:

$$TC = g(Q) = g^1(L, P, C, K) \quad (3)$$

A linear form of equation 3 is as follows:

$$TC = A + wL + mP + nC + rK \quad (4)$$

where TC = total cost in \$/yr;

w = wage rate in \$/hr;

m = unit power cost in \$/kwh;

n = unit chemical cost in \$/lb;

r = capital or capacity cost in \$/unit of capacity;

A = constant.

Equation 4 represents the sum of each cost input. Multiplying both sides of equation 4 by $Q/Q = 1$ yields:

$$TC = \frac{wL}{Q} Q + \frac{mP}{Q} Q + \frac{nC}{Q} Q + \frac{rK}{Q} Q \quad (5)$$

Each of these ratios represents the unit costs of labor, power, chemicals, and capacity, and each contains the input ratios implicitly even though they cannot be evaluated separately. In addition, each term in equation 5 refers to the share of total expenditures incurred by that input. Because of the separable nature of the equations, estimates may be made on the individual segments and combined to create equation 5.

A multiplicative variant of equation 3 may also be formed as follows:

$$TC = B(L^1)^\alpha (P^1)^\beta (C^1)^\gamma (K^1)^\delta Q^\eta \quad (6)$$

where

$$L^1 = \frac{wL}{Q}$$

$$P^1 = \frac{mP}{Q}$$

$$C^1 = \frac{nC}{Q}$$

$$K^1 = \frac{rK}{Q}$$

$$B = \text{constant}$$

$\alpha, \beta, \gamma, \delta, \eta$, = cost elasticities

Equation 6 combines all of the relevant inputs into one equation for ease of estimation. Empirical analysis of equation 6 will yield information on the existence of scale economies and substitutability of inputs.

Chemical Cost Relationships

The relationship between finished water quality and chemical costs is of particular interest. Using the approaches discussed earlier, it is possible to formulate a chemical cost equation as follows:

$$CH = \eta (A, PL, S, LM, Q) \quad (7)$$

where CH = total chemical cost, \$/year;

A = alum, mg/L;

PL = polyelectrolyte, mg/L;

S = soda ash, mg/L;

LM = lime, mg/L; and

Q = revenue-producing water, million liters/yr.

Equation 7 expresses chemical cost as a function of its input.

A more appropriate method for evaluating raw water quality would be to examine the relation of chemical costs and total treatment cost to selected dummy variables.

For example:

$$CH = f(Q, X\phi) \quad (8)$$

where $X\phi = \begin{cases} 0 & \text{for unprotected raw water source} \\ 1 & \text{for protected raw water source} \end{cases}$

An unprotected source is defined as free-flowing or impounded surface water while a protected source is ground or spring water.

EMPIRICAL RESULTS

This section provides the empirical estimates of the relationships discussed previously. Results, categorized into three segments, are reported for each data set: municipal, recreational, and combined. The first segment presents the results for predictive relationships, while the second segment provides empirical results for the production equations.

PREDICTIVE RELATIONSHIPS

Individual cost equations for each component of the entire water utility -- acquisition, treatment, distribution, and support services -- were estimated as a function of revenue/producing water. The O&M equations are presented for each data set in Table 3. For treatment and total O&M, recreational utilities have lower cost elasticities than do municipal plants. This should be expected, since recreational plants operate at a lower average flow and for only part of the year. Thus, greater operating economies may be gained by recreational plants through expanding output than can be gained by municipal plants, which have already achieved economies of scale. In general, the results indicate that operating economies exist in all components as well as total O&M for utilities that use package treatment plants.

Table 4 contains results for the total costs including capital for each major component as well as for total system cost. Municipal cost elasticities again exceed the recreational cost elasticity estimates, as might be expected. Results in these tables also indicate that significant economies prevail for total operating cost, depreciation and interest, and total annual cost as a function of revenue-producing water. These results imply that as output rises, economies of scale in capital and operation drive unit costs down.

Table 5 provides the empirical results from construction cost equations for each data set. Total construction cost is regressed against treated water. These construction costs are for the total utility and the complete package treatment plant (includes equipment, building, and installation cost). As can be seen from the table, significant scale economies also exist in construction. Figures 22 and 23 depict unit construction costs and O&M costs with respect to plant size for package treatment plants and for a total utility. These data are from the municipal data set.

Table 3. UTILITY O&M COSTS BY MAJOR COST COMPONENTS ($C = aQ^b$)*

	Municipal Utilities			Recreational Utilities			Combined Data Set		
	a	b	R ²	a	b*	R ²	a	b	R ²
Acquisition	79.277	.716 (.155)	.620	NS	NS	--	209.863	.399 (.103)	.350
Treatment	297.526	.886 (.182)	.627	2326.181	.218 (.078)	.374	2044.530	.394 (.054)	.646
Distribution	232.204	.930 (.182)	.668	NS	NS	--	425.354	.724 (.116)	.583
Support Services	129.195	.914 (.488)	.212	NS	NS	--	329.308	.614 (.134)	.430
Total O&M	895.620	.862 (.209)	.567	4073.134	.222 (.092)	.307	3661.697	.475 (.059)	.696

* C = Cost in \$/yr; Q = revenue-producing water in mil gal/yr; a, b = constants (values in parentheses are standard errors).

Table 4. TOTAL COST EQUATIONS (O&M AND CAPITAL) BY MAJOR COMPONENT ($C = aQ^b$)*

	Municipal Utilities			Recreational Utilities			Combined Data Set		
	a	b	R ²	a	b	R ²	a	b	R ²
Acquisition	432.272	.588* (.315)	.208	NS	NS	--	1460.734	.213 (.102)	.143
Treatment	3492.074	.549 (.159)	.499	10030.984	.132 (.070)	.264	9556.807	.278 (.043)	.639
Distribution	2863.769	.713 (.344)	.264	NS	NS	--	4817.522	.537 (.094)	.575
Support Services	468.746	.608 (.374)	.249	NS	NS	--	342.561	.627 (.132)	.520
Total O&M	895.620	.862 (.209)	.567	4073.134	.222 (.092)	.307	3661.697	.475 (.059)	.696
Total Capital	36761.633	.151 (.098)	.122	12761.614	.241 (.114)	.240	16006.113	.329 (.064)	.443
Total Cost	7775.787	.645 (.196)	.454	19054.451	.118 (.101)	.089	17753.803	.408 (.057)	.653

* C = Cost in dollars/yr; Q = revenue-producing water in mil gal/yr; a,b = constants. All values in parentheses are standard errors.

Table 5. CONSTRUCTION COSTS FOR PACKAGE PLANTS
AND TOTAL SYSTEM ($C = aQ^b$)

Data Set	Total	a	b	R^2
<u>Municipal</u>				
	Total	35018.788	.610 (.256)	.251
	Treatment	12890.141	.616 (.150)	.498
<u>Recreational</u>				
	Total	17835.462	.684 (.165)	.552
	Treatment	8470.095	.730 (.194)	.520
<u>Combined</u>				
	Total	14289.31	.773 (.090)	.692
	Treatment	10739.717	.653 (.064)	.762

C = total cost; Q = mil gal water treated/yr; a,b = constants.

(Values in parentheses are standard errors.)




Figure 22. Total Unit Construction Costs for System and Package Plants (Municipal Utilities)




Figure 23. Total Unit O&M Cost for System and Package Plant (70% of capacity)

QUASI-PRODUCTION FUNCTIONS

Equation 9 provides a variation of equation 6 discussed in the previous section. Since no productivity or production function relationships can be generated due to the sparsity of data, an attempt was made to examine the cost tradeoffs inherent in utilities using package treatment plants. This analysis is conducted only for total treatment operating costs. The estimated operating and maintenance cost equation is:

$$\text{TOC} = 3.561 Q^{.980} L^{.612} C^{.160} E^{.179} \quad (R^2 = .994) \quad (9)$$

(.038) (.038) (.025) (.049)

where:

TOC = total annual treatment operating cost in \$/yr;

Q = revenue-producing water, million gallons/yr;

L = payroll expense per million gallons;

C = chemical expense per million gallons; and

E = power expense per million gallons.

From this equation, it is obvious the payroll costs are a significant factor in operating the package plant. To further examine the degree of this impact, a set of relationships can be derived based on equation 9.

The total differential of equation 9 yields:

$$\begin{aligned} d\text{TOC} = & 3.490 Q^{-.020} L^{.612} C^{.160} E^{.179} dQ \\ & + 2.179 Q^{.980} L^{-.388} C^{.160} E^{.179} dL \\ & + .570 Q^{.980} L^{.612} C^{-.840} E^{.179} dC \\ & + .637 Q^{.980} L^{.612} C^{.160} E^{-.821} dE \end{aligned} \quad (10)$$

Setting $d\text{TOC}$, dQ , and $dE = 0$ yields:

$$\begin{aligned} 0 = & 2.179 Q^{.980} L^{-.388} C^{.160} E^{.179} dL \\ & + .570 Q^{.980} L^{.612} C^{-.840} E^{.179} dC \end{aligned} \quad (11)$$

Solving for $\frac{dL}{dC}$ gives:

$$\frac{dL}{dC} = - \frac{.570 Q^{.980} L^{.612} C^{-.840} E^{.179}}{2.179 Q^{.980} L^{-.388} C^{.160} E^{.179}} = -0.262 \frac{L}{C} \quad (12)$$

Multiplying by $\frac{C}{L}$ to get a cost elasticity yields:

$$\frac{dL}{dC} \frac{C}{L} = \xi_{LC} = -.262 \quad (13)$$

Equation 13 implies that a 1% increase in chemical costs must be accompanied by a .262% decrease in payroll costs in order to keep costs constant. Other trade-off elasticities generated from equation 9 are provided in Table 6. These relationships do not reflect the trade-offs from large changes in the variables, but rather the variations in the neighborhood of a point.

Table 6. SUBSTITUTION ELASTICITIES AMONG Q, L, C, AND E

X	Y	ξ_{YX}			
		Q	L	C	E
Q		--	-1.602	-6.123	-5.479
L		-.624	--	-3.817	-3.421
C		-.163	-.262	--	-.895
E		-.183	-.292	-1.118	--

The most important factor influencing operating cost outside of Q is payroll cost. If payroll costs increase by 1%, chemical cost must decrease 3.817% or energy cost must decrease 3.421%. Thus, the level of labor activity devoted to operating and maintenance of the package plant is very important.

Chemical cost equations were developed for the combined data set as follows:

Combined Chemical Costs

$$CH = 55.037 Q^{.661} AL^{.349} \quad (R^2 = .860) \quad (14)$$

(.054) (.071)

where CH = total chemical cost, \$/year;

Q = revenue-producing water, million gallons/year; and

AL = alum, mg/L.

Other relationships were developed between chemical cost or total treatment operating cost and selected dummy variables on source type, turbidity standards, and drinking water standards.

Relationships were developed for chemical and total treatment O&M costs, versus water source, meeting the turbidity standards and meeting the other drinking water standards. These significant equations are as follows:

Combined Cost

$$CH = 105.109 Q^{.660} 1.458^X \quad (R^2 = .754) \quad (15)$$

(.075)

$$CH = 125.336 Q^{.589} 1.486^T \quad (R^2 = .756) \quad (16)$$

(.042)

$$TOM = 1939.140 Q^{.402} 1.203^S \quad (R^2 = .781) \quad (17)$$

(.042)

where TOM = total treatment O&M, \$/year;

X = $\begin{cases} 1 & \text{if unprotected raw water source} \\ 0 & \text{if protected raw water source} \end{cases}$

T = $\begin{cases} 1 & \text{if turbidity standard met} \\ 0 & \text{if turbidity standard not met} \end{cases}$

S = $\begin{cases} 1 & \text{if drinking water standards met} \\ 0 & \text{if drinking water standards not met.} \end{cases}$

A protected source is defined as ground water or spring water while an unprotected source is a surface source or impoundment. These results indicate that if a standard is met or if the source is unprotected, more treatment expense is incurred at each level of output.

COST COMPARISON AND CONCLUSIONS

This report presents results from a study of 36 selected water utilities that use package treatment plants. The study was conducted in order to evaluate the cost-effectiveness of package treatment plants in treating drinking water. The following section provides a comparative analysis to the cost of conventional treatment and the general conclusions are contained in the final section.

COMPARATIVE COST ANALYSIS

Package water treatment plants can produce water for small communities that will meet the requirements of the Interim Regulations. However, the cost of this new technology must be compared to that for conventional treatment. Data on the cost of conventional treatment plants are not generally available for plants of the size less than one mgd, prohibiting extrapolation of cost estimates for conventional treatment into that range. It is equally difficult to estimate costs for plants greater than one mgd. Therefore, both systems were compared at the one mgd level.

Reference to figures 22 and 23 in the previous section shows the relevant unit operating and construction costs for municipal treatment plants and total utility cost. These figures indicate that economies of scale and operation are achievable for package plants built and operated in a range less than or equal to one mgd. Therefore, for the average municipal plant size, slightly greater than .5 mgd in this data set, significant scale economies can be attained.

Figure 24 shows total construction cost of a package plant and the entire treatment system versus plant capacity in mgd. Figure 25 shows the annualized cost of treatment and total utility cost versus revenue producing water in mil gal/yr.

The construction cost for 1 mgd plant with settling has been estimated⁷ at \$1,124,000 (see Table 7). Total construction cost for 1 mgd package plant (includes plant, building, and installation), using the equation for municipal treatment plant from Figure 24, is \$488,236. Therefore, based on construction cost alone, a package plant is significantly less expensive than conventional treatment.

Total operation and maintenance cost for both technologies can also be estimated. Using a previously developed equation for treatment O&M from a study of small utilities,⁸ annual operating cost is estimated at \$62,571.42 for conventional treatment. The equations from Table 3 estimate annual operating costs for package plants as \$40,408.55.





Figure 24. Total Construction Cost Versus Plant Capacity



**Figure 25. Annual Cost Versus Revenue
Producing Water**

Table 7. COMPARATIVE COST ANALYSIS FOR 1 MGD PLANT⁷

Cost Estimate	Conventional	Package
Construction cost	\$1,124,000.00	\$488,236.00
Annual treatment, operation, and maintenance cost	\$ 62,571.42	\$ 40,408.55

Therefore, package plants not only can produce water for small communities that will meet the turbidity requirements of the National regulations, but also reduce the cost impact on small systems unable to achieve scale economies with conventional treatment.

CONCLUSIONS

Compliance with the requirements of the Safe Drinking Water Act may seriously impact the budgets of small communities. But it is the intent of the Act to provide adequate water quality to the small as well as the large utilities. As a result, this analysis was conducted to examine the viability of using package treatment plants to meet the drinking water standards.

The results of this study indicate two aspects. Scale economies exist in package treatment plants under 1 mgd. The average flow rate for the municipal systems in this study was found to be slightly less than 0.2 mgd, implying that the average plant will be able to achieve the scale economies that potentially exist with this technology.

As shown in Table 7, construction and operating costs are lower for the package treatment technology than for conventional treatment processes of the 1 mgd level. Utilities can lower their construction cost by performing some of the installation and building work themselves. This opportunity gives the manager a great deal of flexibility in controlling construction costs.

Therefore, based on this study, it is felt that package plants can be used in a cost effective manner to meet the turbidity requirements of the Safe Drinking Water Act, and still not impose an enormous burden on the utility's budget.

REFERENCES

1. Koenig, L., "Cost of Water Treatment by Coagulation, Sedimentation, and Rapid Sand Filtration," Journal of the American Water Works Association, 59 (March 1967), p. 290-336.
2. Orlob, G. T., and Lindorf, M. R., "Cost of Water Treatment in California," Journal of the American Water Works Association, 50 (January 1958), p. 45-55.
3. Clark, R. M., Gillean, J. I., and Adams, J. K., The Cost of Water Supply and Water Utility Management, Vol. I, EPA-600/5-77-015a, November 1977.
4. Johnston, J., Statistical Cost Analysis, (New York: McGraw-Hill, 1960).
5. Kmenta, Jan (Macmillan Co., New York, N. Y., 1971), Elements of Econometrics, p. 539-550.
6. Cooper, J. P., Econometric Software Package (University of Chicago, Chicago, 1973).
7. Manual of Treatment Techniques for Meeting the Interim Primary Drinking Water Regulations, U. S. Environmental Protection Agency, Office of Research and Development, Municipal Environmental Research Laboratory, Water Supply Research Div., EPA-600/8-77-005, Cincinnati, Ohio, May 1977, p. 41, Fig. 38.
8. Unpublished report on small utilities, Environmental Protection Agency, Municipal Environmental Research Laboratory, Water Supply Research Division, Table 17.

APPENDIX A
QUALITY DATA

Table A-1. MUNICIPAL PLANTS

Plant No.	Type of Plant	Capacity gpd	Plant Output gpd	Water Source	Alkalinity, mg/l		Hardness, mg/l		pH		Temperature, °F		NO ₃ (as N), mg/l Finished
					Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	
1	AQ 40	288,000	97,000	Im	36	70	60	62	7.1	7.8	73	73	< 0.01
2	(2)WB 133	288,000	98,500	Gr	180	180	180	184	7.3	7.3	55	55	0.18
3	AQ 40	288,000	75,000	Gr	257	261	390	400	7.1	7.2	56	57	3.30
4	AQ 70	504,000	147,350	Ff	55	59	78	88	7.9	7.6	70	71	0.40
5	AQ 40	288,000	105,500	Im	100	113	64	62	7.8	7.9	59	59	0.13
6	Concrete	1,440,000	860,000	Ff	4	12	12	10	6.6	7.2	58	60	0.22
7	AQ 180	1,296,000	364,000	Gr	358	159	448	124	7.0	8.5	57	61	4.1
8	AQ 112	806,400	233,000	Ff					7.8	8.2	69	69	0.04
9	AQ 70	504,000	229,000	Ff	34	40	75	126	7.0	8.6	66	66	0.49
10	H-T	288,000	114,000	Sp	16	15	236	230	7.1	6.5	56	60	0.13
11	AQ 40	288,000	84,300	Im	11	39	18	20	6.5	8.1	52	54	0.09
12	AQ 70	504,000	80,000	Sp	86	82	98	94	7.4	7.4	50	52	0.20
13	WB 133	144,000	70,000	Im	1	6	28	30	5.5	6.6	53	54	0.72
14	AQ 40	288,000	70,000	Sp	0	7	10	30	4.7	7.9	57	60	0.02
15	AQ 112	806,000	43,200	Im	6	16	8	22	6.9	7.5	59	59	0.01
16	AQ 180	1,296,000	450,000	Ff	42	36	106	102	7.3	7.3	59	59	0.60

Water Sources: Gr - Ground water
 Sp - Spring
 Ff - Free-flowing surface water
 Im - Impounded surface water

Table A-1. MUNICIPAL PLANTS (Cont.)

Plant No.	Fluoride, mg/l Finished	Turbidity, NTU		Average Chemical Doses, mg/l				Coliforms/100 ml		Free Chlorine residual, mg/l	Trihalomethanes $\mu\text{g/l}$
		Raw	Finished	Alum	Polyelectrolyte	Soda Ash	Other	Raw	Finished		
1	0.10	6.4	0.9	31	0.02	37		TNTC	0	2.5	355.0
2	0.18	20.	0.7	13	0.1			38	23,7	< 0.1	< 1.0
3	(0.17 raw) 1.15	7.0	0.5		0.03		ferric sulfate 8 mg/l fluoride 0.5 mg/l lime 18 mg/l lime 18 mg/l	780	0	1.0	< 1.0
4	0.07	5.2	0.5	20	0.3			TNTC	0	1.5	35.1
5	0.13	1.8	1.6			13		TNTC	0	1.5	57.5
6	(0.05 raw) 0.80	0.6	0.8	9	0.04	17	fluoride 0.6 mg/l	TNTC	0	1.0	68.0
7	(0.14 raw) 1.66	0.04	0.03	22			sodium hydroxide 13 mg/l fluoride 0.6 mg/l lime 339 mg/l	4	0	0.6	< 1.0
8	0.12	7.0	0.2	43	0.5	66		TNTC	0,3	2.5	24.0
9	0.20	520.	1.4	52			lime 23 mg/l		0	1.7	112.0
10	0.12	5.0	0.7				KMnO ₄ 0.2 mg/l	TNTC	0	3.0	5.1
11	0.02	6.6	0.7	57		52				0.6	46.3
12	(0.05 raw) 1.11	1.1	0.4	11		5	fluoride 1.6 mg/l	TNTC	0,1	0.4	14.8
13	0.07	3.4	0.4	7		9				1.0	41.0
14	0.02	0.8	0.3	37			lime 22 mg/l	TNTC	0	2.5	34.0
15	0.01	5.9	0.7	20	0.4	12	lime 9 mg/l	TNTC	0	1.5	59.0
16	0.07	29.	6.0	14			lime 4 mg/l		0	1.7	10.8

Table A-2. RECREATIONAL PLANTS

Plant No.	Type of Plant	Capacity gpd	Plant Output gpd	Water Source	Alkalinity, mg/l		Hardness, mg/l		pH		Temperature, °F		NO ₃ (as N), mg/l
					Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	
1	WB 27	28,800	1,000	Im	16	31	30	30	6.4	7.3	74	73	0.01
2	ISI	86,400	5,200	Im	19	25	30	32	7.0	7.4	72	72	0.06
3	WB 27	28,800	2,700	Im	65	72	215	219	7.1	7.3	68	72	0.38
4	WB 82	86,400	3,250	Im	98	102	114	106	7.9	7.7	75	81	0.07
5	WB 82	86,400	4,700	Im	90	97	115	120	8.0	8.3	81	84	< 0.01
6	WB 27	28,800	1,150	Im	108	110	118	118	7.4	7.6	79	79	0.04
7	Per. 48	69,120	6,000	Im	92	96	114	116	8.2	7.9	82	82	
8	Per. 200	288,000	50,000	Ff	12	88	24	26	6.2	8.4	48	52	0.03
9	WB 82	86,400	1,250	Im	50	46	62	72	7.9	7.2	55	61	0.17
10	WB 82	86,400	6,300	Im	40	52	63	65	7.3	7.4	64	64	0.31
11	AQ 40	288,000	12,000	Im	80	75	110	112	7.2	7.0	58	58	0.21
12	WB 27	28,800	13,000	Ff	73	80	100	94	6.9	7.5	59	59	0.26
13	WB 27	28,800	3,000	Im	38	57	159	180	6.9	7.1	64	63	0.27
14	WB 82	86,400	3,600	Im	56	58	98	115	7.6	7.6	59	61	0.20
15	WB 133	144,000	33,400	Im	36	57	43	48	7.8	8.3	57	59	< 0.01

Water sources: Im - impounded surface water
Ff - free-flowing surface water

Table A-2. RECREATIONAL PLANTS (Cont.)

Plant No.	Fluoride, mg/ℓ Finished	Turbidity, NTU		Average Chemical Doses, mg/ℓ				Coliforms/100 ml		Free Chlorine residual, mg/ℓ	Trihalomethanes μg/ℓ
		Raw	Finished	Alum	Polyelectrolyte	Soda Ash	Other	Raw	Finished		
1	0.01	7.4	0.3	62	0.9	108		TNTC	0	0.4	95.0
2	0.02	6.0	0.4	30	0.7	31		TNTC	0	2.5 ~ 3.0	26.0
3	0.07	38.	0.4	48				166	0	1.0	4.7
4	0.12	2.6	2.1	10	1.2			4	0	1.0	98.0
5	0.11	28.	2.0	2	0.3			0	0	0.7	55.0
6	0.12	4.8	2.7	3	0.5			1	0	0.1 ~ 0.4	45.0
7	0.13	22.	2.5	2	0.5			0	0	2.0	70.3
8	0.01	2.8	0.5	83		88		TNTC	0	1.5	185.0
9	0.02	11.	1.0	680	0.9			0	0	0.2	23.6
10	0.06	5.0	2.5	10	2.8	9		25	0	1.8	45.0
11	0.03	2.5	0.5	33				TNTC	0	1.5	42.8
12	0.12	1.4	0.7	15				TNTC	0	2.0	64.0
13	0.20	> 100.	1.4	8	2.0			0	0	> 3.0	376.0
14	0.14	31.	12.	19	0.4			0	0	6.1	< 1.0
15	0.03	1.7	0.7	8		16		32	0	3.9	132.0

APPENDIX B - INTERVIEW GUIDE FOR PACKAGE PLANTS

I. GENERAL

- A. Date: Mo. _____ Day _____ Year _____
- B. City or Owner _____
- C. Ownership Type: Municipal () Investor ()
- D. Utility Name _____
- E. Address _____

- F. Contact: Name of Plant Manager,
 Operator, or Interviewee: _____
- G. Population Served: Wholesaling _____
 Retailing _____
- | | | |
|--------------------|----------------|---------------|
| H. Purchased Water | <u>Percent</u> | <u>Amount</u> |
| Raw | _____ | _____ |
| Treated | _____ | _____ |
- I. Source of water: Percent
- | | |
|-------------------|-------|
| Ground: | _____ |
| Surface impounded | _____ |
| freeflowing | _____ |
- J. Number of Meters: _____
- | | |
|------------------------------|-------|
| Number of Accounts | _____ |
| Number of Flat-rate Accounts | _____ |
- K. Total Treated Water _____
- L. Total Billed Consumption _____
- M. Average price charged per unit of water _____

Year

Number of Meters

Number of Accounts

Number of Flat-rate Accounts

Total Treated Water

Total Billed Consumption

Average Price Charged

II. WATER QUALITY

	<u>Raw</u>	<u>Finished</u>
A. Bacterial count (total coliform, per 100 ml)	_____	_____
B. Chlorine residual	_____	_____
C. Alkalinity	_____	_____
D. Hardness	_____	_____
E. pH	_____	_____
F. Temperature	_____	_____
H. Total THM	_____	_____
1. Chloroform	_____	_____
2. Dibromochloromethane	_____	_____
3. Bromoform	_____	_____
4. Bromodichloromethane	_____	_____

I. Drinking Water Regulation Constituents

1. Arsenic	_____	_____
2. Barium	_____	_____
3. Cadmium	_____	_____
4. Chromium	_____	_____
5. Lead	_____	_____
6. Mercury	_____	_____
7. Nitrate	_____	_____
8. Selenium	_____	_____
9. Silver	_____	_____
10. Fluoride	_____	_____
11. Endrin	_____	_____
12. Lindane	_____	_____
13. Methoxychlor	_____	_____
14. Toxaphene	_____	_____
15. 2,4-D	_____	_____
16. 2,4,5-TP	_____	_____
17. Turbidity	_____	_____

III. SUPPLEMENTAL QUALITY INFORMATION FROM STATE RECORDS, MANUFACTURERS' RECORDS, OR OTHER SOURCES:

IV. CHEMICALS USED*

	Point of Application	lbs/year	Concentration
A. Chlorine	_____	_____	_____
B. Fluoride	_____	_____	_____
C. Carbon	_____	_____	_____
D. Lime	_____	_____	_____
E. Ammonia	_____	_____	_____
F. Alum	_____	_____	_____
G. Copper Sulfate	_____	_____	_____
H. Soda Ash	_____	_____	_____
I. Polymer	_____	_____	_____
J. Iron Chloride	_____	_____	_____
K. Iron Sulfate	_____	_____	_____
L. Others	_____	_____	_____

* If the only available data are for time periods shorter than one year, record the flow rate along with the lbs per time period.

V. PLANT AND SYSTEM DESIGN

A. Flow Diagram of Treatment Plant

B. Flow Diagram of Major Pipe Network and Position of Pump Stations and Treatment Plant.

VI. TREATMENT PLANT STRUCTURE

A. Treatment Process (General)

	Design Detention Time	Notes
1. Activated	_____	_____
2. Aeration	_____	_____
3. Chlorination	_____	_____
4. Coagulation	_____	_____
5. Dechlorination	_____	_____
6. Filtration	_____	_____
7. Fluoridation	_____	_____
8. Fluoride Removal	_____	_____
9. Sedimentation	_____	_____
10. Softening	_____	_____
11. Stabilization	_____	_____
12. Others	_____	_____

B. Filter Media Yes () No ()

If yes, what type? _____

1. Layer	Material	Eff. size	Uniformity Coefficient	Thickness (inches)
Top	_____	_____	_____	_____
Intermediate (if used)	_____	_____	_____	_____
Intermediate (if used)	_____	_____	_____	_____
Bottom	_____	_____	_____	_____

2. Support Medium:

- a. graded gravel _____ d. Leopold block _____
 b. porous plate _____ e. Other _____
 c. wheeler bottom _____

3. Chemical addition immediately prior or at filter? Yes () No ()

If no, where? _____

4. Brand names of chemicals:

- a. _____, _____ mg/l
 b. _____, _____ mg/l
 c. _____, _____ mg/l

5. How mixed? _____

6. Backwash practices:

Duration, minutes	Rate: gpm/ft ² or inches rise/min	When used in backwash cycle
Backwash		
Surface Wash		
Air Assisted Wash		

Air flow, standard cubic feet/minute _____

C. Treatment Manufacturer's name and Address:

D. Package Plant Model Number _____

E. Expected Lifetime _____

F. Date of Plant Installation _____

G. Flow Rate at Time of Sampling _____

VII. Cost Information for Year

- A. Plant capacity _____
- B. Total O&M cost (all cost components) _____
- C. Total depreciation expense (all cost components) _____
- D. Total interest expense (all cost components) _____
- E. Total overhead cost (includes billing, collecting,
meter reading and administrative operations) _____
- F. Total payroll expense _____
- G. Total man-hours _____
- H. Total energy expense _____
- I. Total KWH _____
- J. Treatment
 - 1. Total chemical cost _____
 - 2. Total labor cost _____
 - 3. Number of man-hours per year _____
 - a. percent of time spent on treatment
maintenance. _____
 - b. percent of time spent on treatment
operation. _____
 - 4. Total energy cost _____
 - 5. Total KWH _____
 - 6. Laboratory expense _____
 - 7. Treatment plant purchase cost _____
 - 8. Plant housing cost _____
 - 9. Plant installation cost _____
 - 10. Reservoir and/or storage cost _____
 - 11. Other O&M cost _____
 - 12. Other capital cost _____

K. Acquisition

- | | |
|-----------------------|-------|
| 1. Plant investment | _____ |
| 2. Labor expense | _____ |
| 3. Man-hours | _____ |
| 4. Energy cost | _____ |
| 5. KWH | _____ |
| 6. Other O&M cost | _____ |
| 7. Other capital cost | _____ |

APPENDIX C
COST DATA FOR PACKAGE PLANTS

Table C-1. MUNICIPAL PLANTS

I.D.	Design	Treatment Operation Rate	Acquisition O&M	Treatment O&M	Chemical O&M	Distribution O&M	Support Services O&M	Total O&M	Power	Acquisition KI
1	288000	97400.	456.	6752.	1970.	4981.	2069.	14258.	2113.	173040.
2		98500.	1250.	4184.	1200.	4420.	1053.	10907.	4282.	- 2.
3		75000.	1063.	4364.	607.	4076.	1028.	10531.	5314.	23359.
4		47350.	1241.	10905.	1000.	10278.	5039.	27463.	6204.	17124.
5			2183.	11614.	505.	12766.	6301.	32864.	9406.	112895.
6			4447.	33323.	6076.	31335.	11550.	80655.	18474.	93001.
			2158.	29947.	8732.	24173.	33193.	89471.	7994.	10500.
			3750.	23716.	7940.	19500.	9202.	56168.	18228.	15000.
			2000.	23795.	3666.	28829.	14181.	68805.	8286.	81865.
			1133.	9060.	300.	9100.	3473.	22766.	5666.	10000.
			822.	6877.	2832.	4292.	9072.	21063.	4109.	0.
			411.	6265.	2174.	3690.	5024.	15420.	2639.	57192.
				1015.	-2.	1555.	58.	3406.	3348.	0.
				8068.	1648.	6601.	11450.	26723.	3021.	38410.
				6586.	767.	6100.	7376.	20998.	4681.	21221.
				22220.	3636.	-2.	-2.	-2.	-2.	12200.
				-2.	-2.	-2.	-2.	-2.	-2.	25332.
				-2.	-2.	-2.	-2.	-2.	-2.	50000.
				-2.	-2.	-2.	-2.	-2.	-2.	4209.
				3043.2	2870.2	11446.4	8004.6	33433.2	6917.7	41408.2

Table C-1. MUNICIPAL PLANTS (Cont.)

I.D.	Total Treatment KI	Plant Equipment KI	Treatment Building KI	Treatment Installation KI	Distribution Storage KI	Overhead KI	Interest	Total KI	Payroll O&M	Treatment Labor \$
1	272593.	106593.	93737.	72264.	295295.	0.	25994.	740928.	10175.	4070.
2	196645.	122652.	25384.	48609.	16520.	0.	5003.	213165.	5425.	1920.
3	165031.	54180.	69795.	41056.	12317.	0.	7502.	200707.	4610.	1844.
4	199347.	88565.	64263.	46520.	438589.	11340.	23379.	666400.	19180.	7672.
5	225785.	58700.	111391.	55694.	2264095.	0.	26106.	2602775.	21000.	8400.
6	923415.	161203.	479911.	282301.	1610674.	123131.	69697.	2750222.	56105.	22442.
7	244841.	219533.	9047.	16261.	1551985.	-2.	11820.	1807326.	49640.	19856.
8	413850.	135000.	137250.	141600.	2110706.	-2.	33936.	2539556.	30000.	12000.
9	571440.	183201.	257428.	130811.	-2.	-2.	87619.	653304.	43080.	17709.
10	322025.	55000.	168127.	98898.	950970.	29670.	28859.	1312665.	16800.	6720.
11	339325.	60893.	185622.	92810.	327816.	0.	3522.	667141.	6415.	2566.
12	342662.	69440.	182688.	90131.	549053.	0.	18967.	948503.	7020.	2808.
13	97710.	43970.	24428.	29313.	445292.	-2.	10050.	543002.	-2.	-2.
14	133600.	53440.	53440.	26720.	542830.	-2.	18075.	714840.	1664.	5332.
15	457995.	124749.	234219.	99027.	986653.	0.	27172.	1265869.	10335.	4134.
16	430996.	93071.	135830.	202094.	153560.	-2.	23584.	596756.	18584.	18584.
17	363934.	69663.	196181.	98090.	710734.	0.	15700.	404966.	-2.	-2.
18	595965.	85000.	340643.	170322.	228712.	-2.	36500.	874677.	-2.	-2.
19	318067.	196881.	87890.	33196.	45716.	1564.	18400.	367992.	-2.	-2.
Ave.	348169.8	104301.7	150382.8	93458.8	724528.7	13808.7	25888.7	1045831.4	20002.2	9070.5

Table C-1. MUNICIPAL PLANTS (Cont.)

I.D.	Treatment Energy	Lab Expense	Total Depreciation	CPI O&M	CPI Deprec. & KI
1	712.00	-2.00	37046.40	1.00	1.36
2	1064.00	0.00	10658.00	1.00	1.00
3	1913.00	-2.00	10034.91	1.00	1.29
4	2233.00	-2.00	33320.00	1.00	1.36
5	2709.00	670.00	130138.99	1.00	1.81
6	4805.00	-2.00	137511.23	1.00	1.11
7	1359.00	-2.00	61379.85	1.00	1.05
8	3776.00	-2.00	126978.00	1.00	1.50
9	2420.00	6215.00	32665.42	1.00	1.01
10	2040.00	-2.00	65633.00	1.00	1.00
11	1479.00	-2.00	33356.72	1.00	1.36
12	1283.00	-2.00	47425.28	1.00	2.24
13	1015.00	-2.00	27150.00	1.00	1.50
14	1088.00	-2.00	17114.16	1.00	1.67
15	1685.00	-2.00	63293.44	1.00	1.12
16	-2.00	-2.00	29837.54	1.01	1.22
17	-2.00	-2.00	20248.00	1.00	1.00
18	-2.00	-2.00	43734.00	1.00	1.00
19	-2.00	-2.00	18400.00	1.00	1.00
Ave.	1972.1	2295.0	49785.5		

Table C-2. RECREATIONAL PLANTS

I.D.	Design	Treatment Operation Rate	Acquisition O&M	Treatment O&M	Chemical O&M	Distribution O&M	Support Services O&M	Total O&M	Power	Acquisition KI
1	28800.	1000.	80.	2025.	143.	1906.	1127.	5138.	400.	2040.
2	86400.	5200.	147.	3464.	186.	71.	260.	3942.	352.	2040.
3	28800.	2700.	132.	4569.	321.	52.	200.	4953.	244.	13362.
4	86400.	3250.	182.	2486.	68.	1617.	833.	5118.	404.	10500.
5	86400.	4700.	182.	2588.	170.	1617.	833.	5220.	404.	13100.
6	28800.	1150.	182.	2469.	52.	1617.	833.	5102.	404.	16700.
7	69120.	6000.	182.	2632.	214.	1617.	732.	5163.	404.	12200.
8	288000.	50000.	1095.	4317.	1315.	4754.	4090.	14256.	3176.	-2.
9	86400.	1250.	392.	1443.	350.	187.	220.	2242.	932.	97071.
10	86400.	6300.	1800.	2389.	379.	300.	100.	4589.	1800.	59393.
11	288000.	12000.	480.	3722.	170.	3696.	1392.	9290.	2400.	10500.
12	28800.	13000.	396.	5603.	1050.	832.	39.	6870.	1980.	5240.
13	28800.	3000.	146.	924.	122.	307.	255.	1632.	731.	80199.
14	86400.	3600.	353.	1811.	75.	35.	104.	2303.	882.	14443.
15	144000.	144000.	10.	4539.	890.	880.	485.	5914.	1795.	6477.
16	504000.	302400.	-2.	-2.	-2.	-2.	-2.	-2.	-2.	213754.
17	86400.	-2.	-2.	-2.	-2.	-2.	-2.	-2.	-2.	3750.
Ave.	120112.9	34971.9	383.9	2998.8	366.9	1299.2	766.9	5448.7	1087.3	35048.1

Table C-2. RECREATIONAL PLANTS (Cont.)

I.D.	Total Treatment KI	Plant Equipment KI	Treatment Building KI	Treatment Installation KI	Distribution Storage KI	Overhead KI	Interest	Total KI	Payroll O&M	Treatment Labor \$
1	56100.	17850.	20400.	17850.	2040.	0.	2111.	60180.	4095.	1738.
2	74800.	34000.	6800.	34000.	-2.	0.	2696.	76840.	3151.	3151.
3	47237.	17063.	12873.	17301.	40898.	0.	3697.	101497.	4136.	4120.
4	136500.	20370.	77420.	38710.	79800.	0.	10617.	226800.	4545.	2273.
5	72050.	20174.	34584.	17292.	55020.	0.	5105.	140170.	4545.	2273.
6	66800.	25050.	41750.	0.	58450.	0.	3963.	141950.	4444.	2273.
7	79300.	19520.	42700.	17080.	75640.	0.	6605.	167140.	3829.	2273.
8	-2.	-2.	-2.	-2.	-2.	-2.	-2.	-2.	6135.	2454.
9	106405.	53992.	38062.	14351.	236617.	0.	16029.	440093.	758.	758.
10	90525.	38823.	37581.	14121.	41111.	0.	8942.	191029.	2410.	1410.
11	454230.	50820.	268940.	134470.	-2.	0.	21754.	464730.	6720.	2688.
12	22139.	8450.	5240.	8450.	29344.	0.	1940.	56723.	3840.	3840.
13	115289.	59920.	40249.	15120.	16100.	0.	9199.	211588.	539.	539.
14	161600.	30805.	87196.	43599.	27427.	0.	9990.	203470.	1260.	1260.
15	151225.	58670.	51467.	41089.	112885.	-2.	12668.	270617.	2779.	2779.
16	99431.	-2.	-2.	-2.	567035.	1029.	35423.	880219.	-2.	-2.
17	40866.	21000.	13244.	6622.	27892.	0.	3625.	72508.	-2.	-2.
Ave.	110906.1	31767.	51900.4	28003.7	97875.7	68.6	9647.8	231597.1	3545.7	2255.1

Table C-2. RECREATIONAL PLANTS (Cont.)

I.D.	Treatment Energy	Lab Expense	Total Depreciation	CPI O&M	CPI Deprec. & KI
1	144.00	250.00	3008.32	1.00	1.36
2	127.26	252.50	3842.00	1.01	1.36
3	128.00	100.00	5074.94	1.00	1.31
4	145.44	101.00	11340.00	1.01	1.05
5	145.44	101.00	7008.50	1.01	1.31
6	145.44	101.00	7097.50	1.01	1.67
7	145.44	101.00	8357.00	1.01	1.22
8	548.00	-2.00	-2.00	1.00	1.00
9	335.32	202.00	22004.07	1.01	1.31
10	600.00	0.00	9551.85	1.00	1.05
11	864.00	-2.00	23236.50	1.00	1.05
12	713.00	0.00	2836.15	1.00	1.31
13	263.00	0.00	10579.52	1.00	1.12
14	476.00	0.00	10173.73	1.00	1.01
15	870.00	0.00	13530.30	1.00	1.05
16	-2.00	-2.00	29911.20	1.00	1.21
17	-2.00	-2.00	3625.00	1.00	1.00
Ave.	376.7	92.9	10698.5		

TECHNICAL REPORT DATA <i>(Please read Instructions on the reverse before completing)</i>		
1. REPORT NO. EPA-600/2-80-008b	2.	3. RECIPIENT'S ACCESSION NO.
4. TITLE AND SUBTITLE PACKAGE WATER TREATMENT PLANTS Volume 2. A Cost Evaluation	5. REPORT DATE July 1980 (Issuing Date)	
	6. PERFORMING ORGANIZATION CODE	
7. AUTHOR(S) Richard G. Stevie and Robert M. Clark	8. PERFORMING ORGANIZATION REPORT NO.	
9. PERFORMING ORGANIZATION NAME AND ADDRESS Drinking Water Research Division Municipal Environmental Research Laboratory Cincinnati, Ohio 45268	10. PROGRAM ELEMENT NO. 1CC614 SOS 1	
	11. CONTRACT/GRANT NO. GS-05S-10458	
12. SPONSORING AGENCY NAME AND ADDRESS Municipal Environmental Research Laboratory--Cin., OH Office of Research and Development U.S. Environmental Protection Agency Cincinnati, Ohio 45268	13. TYPE OF REPORT AND PERIOD COVERED Final - 6/77 to 6/79	
	14. SPONSORING AGENCY CODE EPA/600/14	
15. SUPPLEMENTARY NOTES See also Volume 1 (EPA-600/2-80-008a) Project Officer: Robert M. Clark DWRD Cincinnati, Ohio 45268 (513) 684-7488		
16. ABSTRACT <p>Many small and rural systems have both cost and quality problems. Their unit costs tend to be higher because of the small number of connections they service. As shown by the Community Water Supply Survey of 1969, many small systems have trouble meeting minimal drinking water standards. These problems are likely to be compounded in the future as drinking water standards are raised. The cost of building a conventional water treatment plant to provide higher quality water for a small community may be prohibitive. A possible alternative to a conventional water treatment plant is a package water treatment plant. These plants are self-contained units that can be installed for a minimum cost.</p> <p>Results from a study of 36 package plants in Kentucky, West Virginia, and Tennessee show that treatment plants can provide water that meets the turbidity requirement of the National Interim Drinking Water Standards. However, as with all treatment plants, proper operation is required. These plants, contrary to some manufacturers' claims, are not totally automatic but require supervision. Nevertheless, when properly maintained and operated, they can provide water that meets the Safe Drinking Water Act's MCKs at a cost less than that associated with conventional treatment.</p> <p>This report (Volume 2) presents the results of a cost evaluation study for package water treatment plants. Volume 1 discusses the performance of package plants with minimal cost evaluation.</p>		
17. KEY WORDS AND DOCUMENT ANALYSIS		
a. DESCRIPTORS	b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group
Construction Costs; Cost Analysis; Cost Centers; Cost Control; Cost Effectiveness; Distribution Costs; Distribution Systems; Economic Analysis; Operating Cost; Performance Evaluation; Quality; Statistical Analysis; Regression Analysis; Utility; Water Supply; Water Treatment	Capital Costs; Chemical Costs; Conventional Treatment; Field Evaluation; Maximum Contaminant Levels; Operating and Maintenance Cost; Package Plants; Predictive Relationships; Safe Drinking Water Act; Small Systems; Treatment Systems	13B 14A
18. DISTRIBUTION STATEMENT Release to public	19. SECURITY CLASS (This Report) Unclassified	21. NO. OF PAGES 75
	20. SECURITY CLASS (This page) Unclassified	22. PRICE

EPA/600/2-80/008b

Package Water Treatment Plants