

CONCEPTUALIZED FLY-ASH AND
SULFUR DIOXIDE SCRUBBING
SYSTEM WITH BY-PRODUCT RECOVERY

THE BABCOCK & WILCOX COMPANY
POWER GENERATION DIVISION

CONCEPTUALIZED FLY-ASH AND
SULFUR DIOXIDE SCRUBBING
SYSTEM WITH BY-PRODUCT RECOVERY

by

Gary E. Carlson

and

David E. James

January 29, 1971

CONCEPTUALIZED FLY-ASH AND SULFUR DIOXIDE
SCRUBBING SYSTEM WITH BY-PRODUCT RECOVERY

General

Based on the experimental data gathered during this contract, a conceptualized air pollution system was established. The system was designed to remove 99% of the fly-ash and 97 1/2% of the sulfur dioxide contained in an assumed but typical flue gas. A venturi-type scrubber was chosen to remove the fly-ash, and a tray-type absorber was chosen for sulfur dioxide absorption. A slurry of magnesium oxide and magnesium sulfite is the active absorbent. The conceptualized system is shown schematically on Drawing No. 390407B-0. Drawings Nos. P17-96-1X0 and P17-96-2X0 show the side and plan views of scrubbing venturis and sulfur dioxide absorbers as integrated into an 800 MW boiler system. The outline and location of the major pieces of equipment are shown on Drawing No. P17-96-3X0.

The above drawings were utilized to develop the cost of the conceptualized system. Whenever possible, commercially available equipment was utilized in the design and cost estimate. When commercial equipment was not available, suitable conceptual equipment designs were developed, and the cost of the equipment established.

System Description

The system, as conceptualized here, starts at the plenum which collects the flue gas leaving the primary and secondary air heaters. The flue gas passes through the following equipment which is arranged in parallel: four venturi scrubbers, four sulfur dioxide absorbers, four induced fans, and two steam coil gas reheaters. The gas is then discharged through a stack. The entrances to the stack are considered terminal points. The cost of the stack has not been included in the estimate.

The gas entering the venturis is mixed with water which contacts and removes the entrained fly-ash. The resulting fly-ash slurry is transferred to a thickener for separation. The clarified overflow is returned to the venturis for reuse while the underflow is pumped to filters. Here, the fly-ash is washed with fresh water to minimize the amount of soluble sulfur and magnesium compounds that leave the system with the fly-ash. Pumps have been included to sluice the fly-ash to a pond. The discharge of these pumps is the terminal point of the ash system.

The particulate-free flue gas passes to the absorbers where sulfur dioxide is removed by reacting with magnesium sulfite. The resulting magnesium-sulfur compounds are dewatered by thickening and centrifuging. The liquor which is separated from the slurry in the thickener and centrifuges is returned to the absorbers. Magnesium oxide, which results from the regeneration of the magnesium-sulfur compounds, is added to the absorbers to replace the magnesium which reacts with sulfur dioxide and is removed to the thickener as a sulfide. The solid materials leaving the centrifuge are dried and then decomposed to yield magnesium

System Description (Continued)

oxide and a gas stream containing 17.7% sulfur dioxide by weight. The product gas leaving the reactor is cooled and filtered and leaves the system. This gas is suitable for making concentrated sulfuric acid. The cost of the acid plant is not included in this study.

The flow quantities at the terminals described above are listed below:

Gas at Entrance to Fly-Ash Scrubber

Temperature - 300 F

Lb/Hr	SO ₂	43,500	
Lb/Hr	CO ₂	1,386,000	
Lb/Hr	O ₂	243,000	
Lb/Hr	N ₂	4,790,000	
Lb/Hr	H ₂ O	392,000	
Lb/Hr	Ash	<u>67,200</u>	
Total		<u>6,921,700</u>	Lb/Hr

Stack Gas

Temperature - 180 F

Lb/Hr	SO ₂	1,090	
Lb/Hr	CO ₂	1,386,000	
Lb/Hr	O ₂	243,000	
Lb/Hr	N ₂	4,790,000	
Lb/Hr	H ₂ O	729,000	
Lb/Hr	Ash	<u>670</u>	
Total		<u>7,149,760</u>	Lb/Hr

Product Gas

Temperature - 400 F

Lb/Hr	SO ₂	40,200	
Lb/Hr	CO ₂	23,300	
Lb/Hr	O ₂	20,100	
Lb/Hr	N ₂	132,500	
Lb/Hr	H ₂ O	<u>11,700</u>	
Total		<u>227,800</u>	Lb/Hr

System Description (Continued)

Waste to Ash Pond

Temperature - 128 F

Solids	Lb/Hr	69,720
Water	Lb/Hr	<u>104,580</u>
Total		<u>174,300</u> Lb/Hr

Equipment Cost Estimates

For estimating purposes, the air pollution control system has been divided into three sections. These sections, the equipment associated with each, and the costs are listed below. Also shown is the cost of erecting the equipment.

Boiler Associated Equipment

- Flue Platework
- Expansion Joints and Dampers
- Venturis (4)
- Sumps (4)
- SO₂ Absorbers (4)
- Ash and Sulfite Collection Tanks (2)
- Foundations
- Structural Steel
- Brickwork, Refractories, Insulation,
and Lagging
- Controls
- Electricals
- Valves
- Pumps and Drives (28)
- Mixer
- Steam Coil Gas Reheaters (2)
- Absorber Packing
- Demisters (4)
- I.D. Fans (4)
- I.D. Fan Drives (4)
- Piping and Fittings
- Rubber Lining for Tanks
- Engineering and Drawings

Total Cost for Boiler Associated Equipment \$5,835,000

Equipment Cost Estimates (Continued)

Dewatering Equipment

Filtrate Tanks (2)
Foundations
Structural Steel
Brickwork, Refractories, Insulation,
and Lagging
Controls
Electricals
Valves
Pumps and Drives (24)
Mixer
Thickeners and Filters (7)
Rubber Lining for Tanks
Piping and Fittings
Engineering and Drawings

Total Cost for Dewatering Equipment \$1,205,000

Regeneration Equipment

Flue Platework
Expansion Joints and Dampers
Heat Exchangers (2)
Reactors (2)
Combustors (2)
Dryers (2)
Holding, Wash, and Storage Tanks (4)
Coal Bunker
Foundations
Building Steel
Structural Steel
Brickwork, Refractories, Insulation,
and Lagging
Controls
Electricals
Valves
Pumps and Drives (8)
Mixer
Fans and Blowers (12)
Fan Drives (12)
Conveyors (4)
Cyclones (5)
Centrifuges (4)
Bag Filter Houses
Pug Mills (2)
Rotary Feeders (14)
Engineering and Drawings

Total Cost for Regeneration Equipment \$3,225,000


Equipment Cost Estimates (Continued)

Total Equipment Costs	\$10,265,000
Erection Cost	\$ 3,398,500
Total Delivered and Erected Cost	\$13,663,500

Operating Requirements

The following list of operating utilities has been prepared and is based on the terminal flow quantities listed above and an 800 MW steam generator operating at a levelized load factor of 70% or 6,132 hours per year.

Electrical Power	$\frac{86.1 \times 10^6 \text{ kwhr}}{\text{yr}}$	
Fuel	$\frac{1,281,000 \text{ MkB}}{\text{yr}}$	57.9% coal 42.1% oil
Water	$\frac{303.3 \times 10^6 \text{ gal}}{\text{yr}}$	
Steam	$\frac{131,500 \text{ MkB}}{\text{yr}}$	(added fuel input)
Dolomite	$\frac{5,940,000 \text{ lb}}{\text{yr}}$	



CONTRACT NO. CPA 22-69-129


FOR
NATIONAL AIR POLLUTION CONTROL ADMINISTRATION

DWN. <i>[Signature]</i>	CHK'D
DATE <i>5/15/70</i>	APP'D

SCHEMATIC PROCESS DIAGRAM FOR MAGNESIA
SLURRY ABSORPTION OF SO₂, MAGNESIA
REGENERATION AND BY-PRODUCT RECOVERY

SCALE INCHES = 1 FOOT

390407 B-




NOTE: FOR PLAN VIEW, SEE DWG. P17-96-20X


FLY ASH SCRUBBING AND
SO₂ ABSORPTION SYSTEM

Babcock & Wilcox
POWER GENERATION DIVISION

P17-96 - 1X0



NOTE: FOR SIDE ELEVATION SEE DWG. P17-96-1X



ASME: See Section 8. General Notes: See Section 8.14 for other notes.

Babcock & Wilcox
POWER GENERATION DIVISION

PLOT PLAN AND ARRANGEMENT
FLY ASH SCRUBBING, SO₂ ABSORPTION,
DEWATERING AND REGENERATION SYSTEMS

CONTRACT NO. CPA 22-59-22
FOR NATIONAL AIR POLLUTION CONTROL ADMINISTRATION
P 17-96 - 3 X 0