

EMISSION TESTING REPORT
ETB TEST NUMBER 71-MM-03

Emissions From
Wet Process Cement Kiln
And Clinker Cooler
at

I D E A L C E M E N T C O M P A N Y
SEATTLE, WASHINGTON


Project Officer
Clyde E. Riley

ENVIRONMENTAL PROTECTION AGENCY
Office of Air Programs
Research Triangle Park, North Carolina 27711

PREFACE

The work reported herein was conducted by the Roy F. Weston Company, pursuant to a task order issued by the Environmental Protection Agency (EPA), under the terms of EPA Contract Number CPA 70-132 Task Order 1. Mr. G. E. Benson served as the Project Engineer and directed the Weston field team consisting of Messrs. H. F. Schiff, B. W. Cowan, and L. W. Johnson. Mr. Schiff and Mr. Cowan performed the pollutant analyses at the Weston laboratories. Roy F. Weston submitted to EPA a draft document from which EPA personnel prepared the final report (Test No. 71-MM-03)

Approved:
Environmental Protection Agency



Gene W. Smith
Chief, Metallurgical and Mechanical Section
Emission Testing Branch

March 29, 1972

TABLE OF CONTENTS

	<u>Page</u>
Acknowledgments	iv
List of Tables	v
List of Figures	v
Summary	vi
Introduction	1
Process Description	2
Discussion of testing and Results	6
Abstract	12
Appendix A - Schematics of Test Locations	13
Appendix B - Sampling Procedures	16
Appendix C - Field Data and Notes	19
Appendix D - Laboratory Procedures	35
Appendix E - Sample Calculations	41
Appendix F - Test Log	43

ACKNOWLEDGMENTS

The Office of Air Programs of the Environmental Protection Agency gratefully wishes to acknowledge the valuable assistance of the following members of the staff of Roy F. Weston, Inc., who made meaningful contributions to the preparation of this report:

E. F. Gilardi, Senior Project Manager	Concept Technology Division
F. L. Cross, Air Pollution Consultant	Concept Technology Division
G. E. Benson, Project Engineer	Concept Technology Division
H. F. Schiff, Assistant Project Scientist	Concept Technology Division
B. W. Cowan, Technician	Concept Technology Division
L. W. Johnson, Technician	Concept Technology Division

We also wish to acknowledge the following personnel of the Ideal Cement Company, Seattle, Washington, for their cooperation and assistance in the preparation of this report:

F. Bauer, Plant Manager	
R. Owens, Supervisor	Quality Control
R. J. Castelli, Environmental Specialist	Denver Office

The following staff members of EPA-OAP have participated in the planning and execution of this project and/or preparation of this report:

C. E. Riley, Technician	Emission Testing Branch
P. K. York, Chemical Engineer	Source Control Branch
J. Bazes, Chemical Engineer	Emission Testing Branch

LIST OF TABLES

<u>Table No.</u>	<u>Title</u>	<u>Page</u>
1	Summary of Particulate Data for Clinker Cooler	vii
2	Summary of Particulate Data for Kiln Stack	viii
3	Particulate Emissions Data for Clinker Cooler	9
4	Particulate Emissions Data for Kiln Stack	11
D-1	Results of Sample Recovery Procedure	38
D-2	Results of Emission Spectroscopy Analysis	40
F-2	Sampling Log	43

LIST OF FIGURES

<u>Figure No.</u>	<u>Title</u>	<u>Page</u>
1	Diagram of Baghouse Collector on Clinker Cooler	3
2	Diagram of Electrostatic Precipitator on Kiln	4
A-1	Schematic of Clinker Cooler Exhaust Duct	14
A-2	Schematic of Kiln Stack Cross Section	15
B-1	EPA-OAP Particulate Train	18

SUMMARY

The Office of Air Programs of the Environmental Protection Agency contracted with Roy F. Weston, Inc. to conduct OAP particulate sampling tests in the duct from the clinker cooler and in the kiln stack at the Seattle, Washington plant of the Ideal Cement Company. Three sampling runs were conducted at the clinker cooler duct and two simultaneous runs were conducted at the kiln stack.

The clinker cooler particulate emissions, which were controlled by a baghouse **dust** collector, were 42, 46, and 56 lbs/hr. The measured particulate concentrations were 0.0513, 0.0571, and 0.0698 gr/scf, respectively (particulate emission catch of front half of train).

The kiln emissions, which were controlled by an electrostatic precipitator, were 85.9 and 94.0 lbs/hr. The particulate concentrations were 0.0935 and **.1064** gr/scf (particulate emission catch of front half of train).

The isokinetic sampling ratios were between 89.9 and 105.7 percent.

A summary of the particulate emissions data is presented in the following Tables 1 and 2. The complete summary results of the test may be found in Tables 3 and 4.

TABLE 1
SUMMARY OF PARTICULATE DATA FOR CLINKER COOLER

Run number	1	2	3
Date	3-18-71	3-19-71	3-19-71
Percent Excess Air	NA	NA	NA
Percent Isokinetic	105.7	105.3	101.9
Stack Flow Rate-SCFM* dry	95,699	94,971	94,100
Stack Flow Rate-ACFM wet	108,307	105,121	104,555
Volume of Dry Gas Sampled SCF*	105.39	104.21	100.03
Feed Rate - tons/hr	103.4	102.8	104.9
<u>Particulates</u>			
<u>Probe, Cyclone, & Filter Catch</u>			
mg	351.0	386.0	453.3
gr/SCF* dry	0.0513	0.0571	0.0698
gr/CF @Stack Conditions	0.0453	0.0516	0.0628
lbs/hr	42.0	46.4	56.3
lbs/ton feed	0.406	0.452	0.536
<u>Total Catch</u>			
mg	374.3	400.6	462.7
gr/SCF* dry	0.0547	0.0592	0.0712
gr/CF @Stack Conditions	0.0483	0.0534	0.0641
lbs/hr	44.8	48.2	57.4
lbs/ton feed	0.433	0.468	0.547
% Impinger Catch	6.22	3.49	2.03

* 70°F, 29.92" Hg
 NA--Not Applicable.

TABLE 2
SUMMARY OF PARTICULATE DATA FOR KILN STACK

Run Number	1	2
Date	3-24-71	3-24-71
Percent Excess Air	67.8	67.8
Percent Isokinetic	93.5	89.9
Stack Flow Rate - SCFM [*] dry	107,179	103,085
Stack Flow Rate - ACFM wet	286,431	288,505
Volume of Dry Gas Sampled - SCF [*]	39.69	36.68
Feed Rate - tons/hr	101.7	101.7
<u>Particulates</u>		
<u>Probe, Cyclone, & Filter Catch</u>		
mg	241	253.5
gr/SCF [*] dry	0.0935	0.1064
gr/CF @Stack Conditions	0.0350	0.0380
lbs/hr	85.9	94.0
lbs/ton feed	0.844	0.924
<u>Total Catch</u>		
mg	262	281.8
gr/SCF [*] dry	0.1016	0.1183
gr/CF @Stack Conditions	0.0380	0.0422
lbs/hr	93.4	104.4
lbs/ton feed	0.918	1.027
% Impinger Catch	8.01	10.04

* 70°F, 29.92" Hg

INTRODUCTION

Under the Clean Air Act, as amended, the Environmental Protection Agency is charged with the establishment of performance standards for new installations or modifications of existing installations in stationary source categories which may contribute significantly to air pollution. A performance standard is a standard for emissions of air pollutants which reflects the best emission reduction systems that have been adequately demonstrated (taking into account economic considerations).

The development of realistic performance standards requires accurate data on pollutant emissions within the various source categories. In the cement industry, eight plants exhibiting well controlled operation have been selected for the emissions testing program. This report presents the particulate emissions data for the Seattle, Washington plant of the Ideal Cement Company.

Between March 15 and March 25, 1971, Roy F. Weston, Inc. conducted particulate source sampling at the following locations within the plant:

1. Outlet duct from the clinker cooler baghouse collector.
2. Stack from the kiln electrostatic precipitator.

The clinker cooler performs the function described by its name; i.e., cools the clinker (the main constituent of cement) which is discharged from the kiln. The kiln acts to calcine the raw materials (which are fed to the kiln in the form of a slurry) in a wet process operation.

The following sections of this report include (1) a process description, (2) a discussion of the testing procedure and results, (3) an abstract of the report, (4) analytical procedures and results, and (5) sample calculations.


PROCESS DESCRIPTION

Clay, crushed limestone and silica sand are brought to the plant by barge from British Columbia and Port Angeles, Washington. These materials are ground and blended in a rotating ball mill to a slurry.

The blended slurry is fed into the upper end of a sloping (3/8 inch per foot), slowly revolving (one revolution per minute) kiln. This gas-fired kiln is 500 ft. long, 15 1/2 ft. in diameter at the feed end and tapered to 14 ft. at the discharge end with refractory lining encased in a steel cylinder. Fuel consumption is approximately 1,240 cu. ft. of gas per barrel of cement produced. During passage through the kiln, the raw materials are heated to a temperature of about 2800°F to produce the element hydraulic calcium silicates, known in the trade as "clinker". This marble-sized clinker material is then discharged from the lower end of the kiln at temperatures exceeding 2000°F and fed immediately into air-quenching cooler units which reduce the temperature of the material to about 150°F. From these coolers, the newly-formed clinker material is conveyed to a storage silo.

A small amount of gypsum (4.45% by weight) is added to the clinker material and this mixture is fed into the finish grinding mill. The mixture leaving the grinding mill is fed to an air separator or classifier where the coarse material is returned to the mill and the finished cement (90% through 325 mesh screen) is pneumatically pumped to storage silos. Present plant production is approximately 2,500,000 barrels of cement per year.

The control equipment of interest in this report consists of two Mikro-Pulsaire baghouse collectors (parallel) on the clinker cooler and a Buell electrostatic precipitator on the kiln (see Figures 1 and 2).






FIGURE 2. DIAGRAM OF ELECTROSTATIC PRECIPITATOR ON KILN

The baghouse collectors consist primarily of a series of cylindrical filter elements enclosed in a dust-tight housing. The felted filter media is "Nomex" which is heat resistant for temperatures as high as 425⁰F and is supported on a stainless steel wire frame. Dust laden air is admitted to the housing and clean air withdrawn from inside the filter cylinders. As dust particles accumulate on the filter elements, periodic cleaning is accomplished by introduction of a momentary jet of high pressure air through a venturi mounted above each filter cylinder. A continuous flow of air through the collector is maintained, since only a fraction of the total filter area is cleaned at one time. The particulate matter falls during the cleaning cycle to the hopper below where the material is removed by a screw conveyor.

These Mikro-Pulsaire collectors are designed to operate with a pressure drop of 7 in. of water and have 864 filter bags per unit that are 4 1/2 in. in diameter x 8 ft. long. Each collector has six compartments and is 16 ft. tall x 36 ft. long x 13 ft. wide with a 60⁰ hopper below. Each collector is designed for a performance of 99.99+ percent efficiency with a gas volume of 62,500 ACF at 350⁰F. The collection surface area is 8,040 square feet, which gives an air to surface ratio of 7.79 CFM/ft². The approximate installed cost of both baghouses was \$425,000 in 1966. Annual bag usage is about 50 bags (\$12.00 each) and labor and maintenance is approximately \$600.00.

The electrostatic precipitator is of the horizontal flow type and consists of two sections with three treatment stages in each **section**. This unit is designed for a performance of 99.83 percent efficiency with an inlet loading of 12 gr/ACF at 700⁰F and an outlet loading of 0.02 gr/ACF and a gas volume

to the **precipitator** of 400,000 ACFM containing 30-40 percent water. The collection surface area is 151,200 square feet which gives an air-to-surface ratio of 2.64 CFM/ft². The linear gas velocity is 5.28 feet per second and the residence time is 8.5 seconds. The particle drift velocity is 0.281 feet per second. There are 35 gas passages per section and each passage is 9 inches wide, 24 feet high, and 45 feet long. The precipitator contains a total of 3,990 emitting electrodes constructed of stainless steel. The approximate cost of installation in 1966 was \$2,325,000.00 and the annual operating cost is about \$10,400.00.

DISCUSSION OF TESTING AND RESULTS

Schematic drawings of the sampling locations are shown in Appendix A. The clinker cooler duct was not an ideal sampling location, however, it was the only available location. A temperature-controlled damper was located approximately four feet in front of the sampling ducts. Immediately preceding the damper was the fan. Three sampling runs of 144 minutes duration were conducted in the duct from the clinker cooler baghouse.

Sampling was conducted at a total of 36 points--12 points at each of three sampling ports. No sampling problems occurred. The isokinetic sampling rates were 105.7, 105.3 and 101.9 percent for the three runs.

Sampling was conducted in the kiln stack 150 feet above grade. Two simultaneous particulate runs were conducted. Sampling was done at 12 points--three points at each of four ports located 90° apart. The sampling trains were operated at ports 180° apart.

Tests at the kiln stack were begun on March 16 but discontinued due to sampling equipment difficulties. OAP type unitized trains were obtained and

sampling at the kiln stack was begun again on March 23. Heavy rainfall made sampling difficult. The sampling platform and equipment were electrified and several members of the sampling crew received shocks. The electrical shocks and the rain forced abortion of the sampling after five minutes of the tests. With the concurrence of the OAP observer, the tests were continued on March 24 at the point where they had been discontinued.

Two simultaneous one-hour duration runs were completed between 11:30 a.m. and 5:30 p.m. The sampling was extremely difficult to complete. The sampling ports were below the stack platform top railing, and two ports were further blocked by vertical members of the stack platform railing. The port locations made necessary the use of two different lengths of probe to sample the three points at each port. Operating two trains simultaneously caused further problems due to coordination. Anything that delayed the sampling with one train also delayed the other. The stack platform width was approximately 30 inches around the stack. The sampling equipment and the four sampling platforms erected at ports cluttered the platform and made movement around the stack difficult. Winds with velocities of 40 and 50 mph made it difficult to retain heat in the sampling boxes.

When changing probes and moving the sampling boxes inside and outside the railing and from port to port, the box temperatures decreased quickly. Fifteen to twenty minutes were necessary to reheat the boxes after the sampling at almost every point. After completion of the two simultaneous particulate sampling runs, no further sampling was conducted at the kiln stack. For details of the sampling procedure see Appendix B. Data sheets and notes recorded in the field are presented in Appendix C.

The kiln stack emissions which were controlled by an electrostatic precipitator were 93.4 and 104.4 lbs/hr. The particulate concentrations were 0.1016 and 0.1183 gr/scf. The isokinetic sampling rates were 93.5 and 89.9 percent.

A complete summary of all particulate testing data is presented in Tables 3 and 4. According to the Federal Register, "Standards of Performance for New Stationary Sources", (December 23, 1971), the standards for particulate emissions, in terms of lbs. per ton of feed to the kiln, for cement plants are based upon measurement of the weight of particulate matter collected in the probe, cyclone and filter section. At the time of testing the Ideal, Seattle Plant (March 1971), these standards had not been officially established. Thus, emissions data were obtained measuring (a) the weight of particulates collected by the probe, cyclone and filter alone and (b) measuring the total weight of particulates collected (to include the impinger catch). These are reported for both schemes in Tables 3 and 4. A sample calculation is presented in Appendix E in which the data for run No. 1 of the clinker cooler are utilized.

Particulate samples were recovered from the sampling train and analyzed for the elements Sb, As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, Sr, V, and Zn. Details of the sample recovery procedure as well as the results of the subsequent analyses are presented in Appendix D.

Nitrogen oxides and carbon monoxide grab sampling was to be conducted simultaneously with the particulate sampling. During trial runs of NO_x sampling, a stream of water was pulled into the sample flask with the stack gas stream. This and other equipment difficulties, together with a test crew member's illness, made NO_x and CO sampling impossible.

TABLE 3
PARTICULATE EMISSIONS DATA FOR CLINKER COOLER

<u>Run No.</u>		<u>1</u>	<u>2</u>	<u>3</u>
<u>Test Date</u>		3-18-71	3-19-71	3-19-71
D_n	Sampling nozzle diameter, in.	0.189	0.189	0.189
T_t	Net time of test, min.	144	144	144
P_b	Barometric pressure, in. Hg absolute	30.23	29.88	29.92
P_m	Average Orifice pressure drop, in. H_2O	1.30	1.29	1.27
V_m	Volume of dry gas sampled, ft^3 at meter conditions	103.81	104.06	101.92
T_m	Average gas meter temperature, °F	68.7	69.8	81.2
V_{mstd}	Volume of dry gas sampled at standard conditions*, SCF	105.39	104.21	100.03
V_w	Total H_2O collected in impingers and silica gel, ml	12	10	8
V_{wgas}	Volume of water vapor collected at standard conditions*, SCF	0.57	0.47	0.38
% M	% Moisture in the stack gas by volume	0.54	0.45	0.38
M_d	Mole fraction of dry gas	0.99	0.99	0.99
% CO_2		0.03	0.03	0.03
% O_2		20.95	20.95	20.95
% CO		<1	<1	<1
% N_2		78.0	78.0	78.0
% EA	Excess Air Percent	-	-	-
MW_d	Molecular weight of stack gas, dry basis	29.0	29.0	29.0
MW	Molecular weight of stack gas, wet basis	28.9	28.9	28.9
C_p	Pitot tube coefficient	0.85	0.85	0.85
ΔP_s	Average velocity head of stack gas, in. H_2O	1.23	1.19	1.17
T_s	Average stack temperature, °F	141	121	124
N_p	Net sampling points	36	36	36
P_{st}	Static pressure of stack gas in. Hg	0.05	0.05	0.05
P_s	Stack gas pressure in. Hg absolute	30.28	29.93	29.97
V_s	Stack gas velocity at stack conditions fpm	4012	3894	3873
A_s	Stack area, in. ²	3888	3888	3888
Q_s	Dry stack gas volumetric flow rate at standard conditions* SCFM	95,699	94,971	94,100
Q_a	Stack gas volumetric flow rate at stack conditions, ACFM	103,307	105,121	104,555
% I	Percent isokinetic	105.7	105.3	101.9

* 70°F, 29.92 in. Hg

TABLE 3 (Concluded)
PARTICULATE EMISSIONS DATA FOR CLINKER COOLER

<u>Run No.</u>		<u>1</u>	<u>2</u>	<u>3</u>
T _c	Unit Feed Rate- Tons/hr	103.4	102.8	104.9
m _f	Particulate - probe, cyclone and filter, mg	351.0	386.6	453.3
m _t	Particulate - total, mg	374.3	400.6	462.7
I _c	% impinger catch	6.22	3.49	2.03
C _{an}	Particulate - probe, cyclone, and filter, gr/SCF*	0.0513	0.0571	0.0698
C _{ao}	Particulate - total, gr/SCF*	0.0547	0.0592	0.0712
C _{at}	Particulate - probe, cyclone, and filter, gr/cf at stack conditions	0.0453	0.0516	0.0628
C _{au}	Particulate - total, gr/cf at stack conditions	0.0483	0.0534	0.0641
C _{aw}	Particulate - probe, cyclone, and filter, lb/hr.	42.0	46.4	56.3
C _{ax}	Particulate - total, lb/hr.	44.8	48.2	57.4
P _{tf}	Particulate - probe, cyclone, and filter, lb/ton feed	0.406	0.0452	0.536
P _{tt}	Particulate - total, lb/ton feed	0.433	0.468	0.547

*70°F, 29.92 in. Hg, dry basis

TABLE 4
PARTICULATE EMISSIONS DATA FOR KILN STACK

Run No.		<u>1</u>	<u>2</u>
Test Date		3-24-71	3-24-71
D _n	Sampling nozzle diameter, in.	0.5	0.5
T _t	Net time of test, min.	60	60
P _b	Barometric pressure, in. Hg absolute	29.79	29.79
P _m	Average Orifice pressure drop, in. H ₂ O	1.23	1.72
V _m	Volume of dry gas sampled, ft ³ at meter conditions	38.80	35.39
T _m	Average gas meter temperature, °F	57.0	50.9
V _m std	Volume of dry gas sampled at standard conditions*, SCF	39.69	36.68
V _w	Total H ₂ O collected in impingers and silica gel, ml	347	356
V _w gas	Volume of water vapor collected at standard conditions*, SCF	16.45	16.87
% M	% Moisture in the stack gas by volume	29.3	31.5
M _d	Mole fraction of dry gas	0.71	0.68
% CO ₂		17.0	17.0
% O ₂		8.0	8.0
% CO		< 1	< 1
% N ₂		75.0	75.0
% EA	Excess Air Percent	67.8	67.8
MW _d	Molecular weight of stack gas, dry basis	31.04	31.04
MW	Molecular weight of stack gas, wet basis	27.22	27.00
C _p	Pitot tube coefficient	0.85	0.85
ΔP _s	Average velocity head of stack gas, in. H ₂ O	0.081	0.082
T _s	Average stack temperature, °F	542	545
N _p	Net sampling points	12	12
P _{st}	Static pressure of stack gas in. Hg	0.02	0.02
P _s	Stack gas pressure in. Hg absolute	29.81	29.81
V _s	Stack gas velocity at stack conditions fpm	1382	1392
A _s	Stack area, in. ²	29,850	29,850
Q _s	Dry stack gas volumetric flow rate at standard conditions, SCFM	107,179	103,085
Q _a	Actual stack gas volumetric flow rate at stack conditions, ACFM	286,431	288,505
% I	Percent isokinetic	93.5	89.9

* 70°F, 29.92 in. Hg

TABLE 4 (Concluded)
PARTICULATE EMISSIONS DATA FOR KILN STACK

<u>Run No.</u>		<u>1</u>	<u>2</u>
T _c	Unit Feed Rate- Tons/hr	101.7	101.7
m _f	Particulate - probe, cyclone and filter, mg	241	253.5
m _t	Particulate - total, mg	262	281.8
I _c	% impinger catch	8.01	10.04
C _{an}	Particulate - probe, cyclone, and filter, gr/SCF*	0.0935	0.1064
C _{ao}	Particulate - total, gr/SCF*	0.1016	0.1183
C _{at}	Particulate - probe, cyclone, and filter, gr/cf at stack conditions	0.0350	0.0380
C _{au}	Particulate - total, gr/cf at stack conditions	0.0380	0.0422
C _{aw}	Particulate - probe, cyclone, and filter, lb/hr.	85.9	94.0
C _{ax}	Particulate - total, lb/hr.	93.4	104.4
P _{tf}	Particulate - probe, cyclone, and filter, lb/ton feed	0.844	0.924
P _{tt}	Particulate - total, lb/ton feed	0.918	1.027


*70°F, 29.92 in. Hg, dry basis

ABSTRACT


This source sampling report is one of nine studies concerning particulate and gaseous emissions from selected cement plants at various locations. The objectives of this study were to evaluate air pollution control equipment performance and efficiencies and to determine emission constituents typical of the cement industry. Schematics of test locations, field and processed data, and descriptions of sampling and laboratory analytical procedures have been included as part of the evaluation.

APPENDIX A
SCHEMATICS OF TEST LOCATIONS

FIGURE A-1
IDEAL CEMENT COMPANY
SEATTLE, WASHINGTON
SCHEMATIC OF CLINKER COOLER EXHAUST DUCT




TOP VIEW



SIDE VIEW

FIGURE A-2
IDEAL CEMENT COMPANY
SEATTLE, WASHINGTON
SCHEMATIC OF KILN STACK CROSS-SECTION



APPENDIX B

SAMPLING PROCEDURES

The particulate sampling train used by Roy F. Weston, Inc. is shown in Figure B-1. A glass or nonreactive metal probe with button hook nozzles (whose size depended on the velocity of the gases) headed the train. The equipment following the probe consisted of a glass cyclone and flask (for certain runs a glass cyclone by-pass was used), a pre-weighed glass fiber filter, and four Greenberg-Smith impingers. The impingers were placed in an ice bath, while the preceding glass pieces were contained in a hot box maintained at a temperature of 240°F. The first impinger was modified by breaking off the glass tip, the second was unmodified, and the third and fourth were modified. The first two impingers each contained 100 ml of distilled water, the third was empty, and the fourth contained a pre-weighed quantity of silica gel. A leakless vacuum pump, a dry gas meter, and a calibrated orifice measured with an inclined manometer completed the train.

During sampling, gas stream velocities were measured by insertion of a calibrated type "S" pitot tube into the stack beside the particulate sampling probe. A type "K" thermocouple and a direct reading pyrometer measured gas temperatures within the gas flow itself. Temperature measurements were made at the heated cyclone, after the silica gel impinger, and at the inlet and outlet of the dry gas meter. Immediately after positioning on each traverse point, readings were made and sampling were adjusted.


Each sampling location was divided into equal cross-sectional area. The centroid of each area was chosen as a sampling point. The number of sampling points was determined by the configuration of the sampling location (e.g. circular, square, or rectangular) and its distance from bends, constrictions,

fans, etc. In general, the closer a sampling location was to a bend, constriction, fan, etc., the greater was the number of sampling points used.

After the completion of sampling, the cleanup of the train proceeded as follows: The filter was placed in a Petri dish. The probe, cyclone, flask, and the front half of the filter holder were washed with acetone into a sample bottle. The volume of the first three impingers was measured, and these impingers, the back half of the filter holder, and all connectors were washed first with distilled water and then with acetone. The silica gel was weighed to the nearest tenth of a gram.

FIGURE B.1



EPA-OAP PARTICULATE TRAIN



APPENDIX C
FIELD DATA AND NOTES

Clinker Cooler

Seattle
Clinker Cooler
Dust Collector



3 ports
12 sampling areas/port
4 MIN/area
total time/port - 48 MIN
test time - 144 MIN

Probe distance	
1. 3"	8. 45"
2. 9"	9. 51"
3. 15"	10. 57"
4. 21"	11. 63"
5. 27"	12. 69"
6. 33"	13. 75"
7. 39"	

PRELIMINARY FIELD DATA

Stack Geometry

Plant Ideal Cement Seattle

Test No. _____

Location Clinker Cooler

Date 3-16-71

A. Dist. from inside of far wall to outside of near wall, in., = 74"

B. Wall thickness, in., = 2"

Inside diameter of stack = A-B 72"

Stack Area = 3,888.

Comments: 72" x 54"

Sketch of stack cross-section showing sampling holes

Calculations:

Point	Dist. from outside of sample port, in.
1	3" + 2" = 5"
2	9" = 11"
3	15" = 17"
4	21" = 23"
5	27" = 29"
6	33" = 35"
7	39" = 41"
8	45" = 47"
9	51" = 53"
10	57" = 59"
11	63" = 65"
12	69" = 71"

Calculator C E Riley

NCAP-28 (12/67)

Clinker Cooler Dust Collector Dust
Ideal Cement, Seattle, Washington

Sampling Data

Date 3-18-71

Run	DAY	P _{at}	T _{aw}	V _{sc}	T _{zi}	P _{at}	V _{zb}
1	.189	30.23	144	103.809	68.7	1.30	105.39
2	.189	29.88	144	104.055	70.0	1.27	104.16
3	.189	29.92	144	101.920	81.3	1.26	100.02

Moisture

Run	V _{ce}	V _{cf}	V _{cg}	M _{ch}	M _{ca}
1	12	.564	.54	.990	28.89
2	10	.474	.54	.990	28.89
3	8	.379	.38	.996	28.96

Velocity and Calculation Data

Run	S _{dd}	P _{di}	T _{df}	S _{dc}	V _{dh}	V _{db}	I _{AX}
1	3,888	30.28	141	27.24	4006	95,556	105.8
2	3,888	29.93	121	26.29	3889	94,850	105.4
3	3,888	29.97	124	26.17	3864	94,450	101.6

Static press. .05 in. Hg.

Plant Ideal Cement - Date 3-16-71

Sampling location Clinker Cooler

STACK DATA FOR NOMOGRAPH:

1. Meter ΔH 1.60 in H₂O
2. Avg. meter temp (ambient + 20°) 70 °F
3. Moisture (volume) 0.3
4. Avg. static press. @ .75 in. H₂O, 0.73 = .05 in. Hg.
5. Bar. press sampling point 30.23 in. Hg + .25 (static press in. Hg) = _____ in. Hg.
6. Bar press of meter 30.23 in. Hg.
7. P_s/P_m = 5. _____ in. Hg
6. _____ in. Hg = 1.0
8. Avg. stack temperature 110 °F.
9. Avg. stack velocity (ΔP) 1.12 in H₂O.

(1.5)


C factor (1) .9 (2) _____

prof tip, .189
.184

TIME (24 hr. clock)	SAMPLE POINT	STACK TEMP. °F or °C	MANOM. READING IN. H ₂ O	VELOCITY HEAD IN. H ₂ O	VELOCITY ft./sec.
top	1		1.3		
	2		1.4		
	3		1.2		
	4		1.1		
	5		1.1		
	6		1.2		
	7	105	1.2		
	8		1.1		
	9		1.3		
	10		1.5		
	11		1.7		
	12		1.5		
middle	1		1.3		
	2		1.3		
	3		1.1		
	4		0.95		
	5		0.82		
	6		0.73		
	7		0.75		
	8		0.89		
	9		1.3		
	10		1.3		
	11		0.98		
	12		1.2		
bottom	1		0.98		
	2		0.86		
	3		0.73		
	4		0.95		
	5		1.2		
	6	1000	1.2		
	7		1.3		
	8		1.2		
	9		0.85		
	10		0.83		
	11		0.92		
	12		1.00		

Antistatic

Static P = 0.95



POINT	4 DISTANCE FROM WALL	DISTANCE FROM WALL INCHES
1		
2		
3		
4		
5		
6		
7		
8		

Area Square ft. _____
Effluent Flow Rate, CFM _____
Effluent Flow Rate, SCFM _____
Operator _____

.73
1.7
1.12

(1.12)

PARTICULATE FIELD DATA

Fun No. 1
Location Clinton Co. road
Date 5-18-71
Operator GER/HJS
Sample Box No. _____
Meter Box No. _____
Factor A 1.60
Factor B 0.9

VERY IMPORTANT - FILL IN ALL BLANKS

Read and record at the start of each test point.

PATHOLOGICAL INCUBATORS-
read and record every 5 minutes.

Ambient Temp of 50

Bar. Press. "Hg 30.23

Assumed Moisture % 3

Heater Box Setting, °F 250

Probe Tip Dia., In. 0.005Probe Length 9-12

Pre-Heater Setting _____

Page 1 of 1

Diagram of a rectangular block with points A, B, and C. A horizontal force of 12 N is applied to the right at the top. A vertical force of 4 N is applied downwards at the left side. The block is labeled "4 MIN / sample".

[illegible]

Automatic danger ~~contaminated~~ floor through duct from ~~the~~ ^{the} ~~bag~~ ^{bag}
house area! ^{velocity} cont. moving changing at each point
Mushroom seed 12 mm

Comments	Clock	Dry Gas Meter, CF	Pilot in. H ₂ O ΔP	Orifice ΔH in H ₂ O		Dry Gas Temp. °F		Pump Vacuum In. Hg Gauge	Box Temp. °F	Impinger Temp °F	Stack Press in. Hg	Stack Temp °F	Amb Temp °F
				Drifted	Actual	Inlet	Outlet						
Check crack No 1 Test	B-4 0012	133.00	0.78	0.73	0.73	75	58	1.0	178			410	58
	B-5 0016	135.25	0.65	0.64	0.64	74	58	1.0	178			410	47
	B-6 0020	137.40	0.50	0.69	0.69	72	58	1.0	170			415	41
	B-7 0024	139.56	0.75	0.73	0.73	74	58	2.0	170			415	26
	B-8 0028	141.80	0.15	0.85	0.85	74	58	0.2	200			435	29
	B-9 0032	144.00	1.00	1.33	1.33	77	58	4.0	205			435	23
	B-10 0036	146.20	1.00	1.78	1.78	80	58	6.0	210			435	17
	B-11 0040	150.30	2.00	2.30	2.30	80	58	12.0	210			440	11
	B-12 0044	152.40	2.00	2.30	2.30	94	59	12.0	210			440	5
	B-13 0048	154.50	1.90	2.03	2.03	87	58	8.0	200			440	71
	B-14 0052	156.60	1.80	1.80	1.80	82	58	5.2	200			440	66
	B-15 0056	158.70	1.60	1.60	1.60	80	58	6.0	210			440	59
No 2 Test	B-4 0012	165.0	1.00	1.00	1.00	80	58	5.3	210			440	53
	B-5 0016	170.00	1.10	1.01	1.01	82	58	8.0	210			440	47
	B-6 0020	173.95	1.05	0.99	0.99	86	58	3.0	210			440	41
	B-7 0024	176.00	1.40	1.45	1.45	82	58	5.0	215			440	35
	B-8 0028	179.34	1.00	1.21	1.21	87	60	2.0	215			440	29
	B-9 0032	182.30	1.00	1.00	1.00	88	60	4.0	215			440	23
	B-10 0036	184.40	0.90	0.89	0.89	80	60	2.5	215			440	17
	B-11 0040	187.40	0.90	0.90	0.90	80	60	2.5	215			440	11
	B-12 0044	189.90	0.90	0.90	0.90	80	60	2.5	215			440	5
	B-13 0048	192.00											
	B-14 0052	194.10											
	B-15 0056	196.20											
				1.30		79.1	58.4					141	
						68.7							

DIST.

Transferred to + Velocity constantly changing due to auto dumper

CLIENT NPCA I chad commit
 WO. # 300-18 SC-400

NAPCA TRAIN DATA
 Bur P. # 29.88

Sheet #1
 LOCATION Shunko, Gula
 DATE 3/19/71
 TEST # 2
 PERSONNEL APS (LCS) Bury

TIME	POSITION	VELOCITY HEAD PILOT	GAS MOTOR			GRIFED MOTOR MIN/MIN	STACK TEMP	NOTES TEMP	OIL TEMP
			READING	TAMP IN	TAMP OUT				
0914									
0	C1	1.50 +	142.5/10	58	54	1.53	145	140	1.53
4	2	0.95 +	143.5/10	66	56	0.96	145	150	0.96
7	1	1.25 +	144.1/10	69	56	1.18	145	160	1.18
12	4	1.12 +	200.92	72	53	1.22	155	170	1.22
16	5	1.15 +	202.90	76	53	1.22	155	180	1.22
20	6	1.00 +	206.90	80	53	1.30	155	190	1.30
24	7	1.10 +	206.90	86	56	1.33	155	195	1.33
28	8	1.10 +	212.59	88	56	1.12	155	190	1.12
32	9	1.25 +	212.59	92	56	1.25	155	200	1.25
36	10	0.95 +	218.44	94	53	0.94	155	200	0.94
40	11	0.95 +	224.05	82	52	0.97	115	205	0.97
44	12	0.95 +	224.05	80	56	0.95	115	205	0.95
48	Stop	—	226.14	80	56	—	—	—	—
52	11	1.20 +	232.14	64	54	1.20	115	215	1.20
56	12	1.00 +	232.14	70	54	1.05	110	220	1.05
60	1	0.95 +	231.66	74	54	0.92	115	220	0.92
64	2	0.45 +	234.15	74	54	1.00	110	220	1.00
68	3	0.35 +	236.75	74	54	0.97	110	220	0.97
72	4	0.25 +	237.17	75	54	0.97	110	220	0.97
76	5	0.10 +	241.51	74	54	0.95	110	225	0.95
80	6	0.25 +	244.01	78	54	1.00	110	225	1.00
84	7	0.10 +	246.43	83	55	1.32	110	225	1.32
88	8	0.10 +	249.90	85	55	1.15	110	225	1.15
92	9	0.10 +	252.76	83	56	1.18	110	225	1.18
96	10	0.10 +	256.45	90	56	1.12	110	225	1.12
100	Stop	—	258.59	90	56	—	—	—	—
104	11	1.20 +	258.59	64	52	1.22	110	225	1.22
108	12	1.20 +	258.59	61	50	1.05	110	225	1.05
112	1	1.50 +	262.90	92	50	1.05	110	240	1.05
116	2	1.50 +	262.90	96	50	1.32	110	240	1.32
120	3	1.50 +	271.26	96	50	1.35	110	240	1.35

VACUUM

50
46
60
60
70
70
70
80
60
48
45
45

SAMPLE NOZZLE SIZE 1/8"

IMPROVED SOLUTION VOLUMES

STOP START

PRESSURE 1144 lb/in²

TIME IN

AVERAGES

22. mousteri 10 gme

CLIENT Apco Island Cement NAPCA TRAIN DATA
 WO. # 300-18 Seattle

Sheet #2
 LOCATION Clinker cooler
 DATE 3/11/71
 TEST # 2
 PERSONNEL 1883 LWS/Buc

TIME	POSITION	VELOCITY HEAD P. ft	GAS METER			GRIFICE HEAD desired	STACK TUMPS	NOTES TUMPS	Griffin Head Actual	Velocity
			READING	TUMPS IN	TUMPS OUT					
1000	A 6 ft	1.55	274.67	100	60	1.69	120	240	169	9.5
1004	"	1.55	277.95	100	60	1.73	125	240	173	9.5
1008	"	1.55	280.79	96	60	1.73	130	240	173	9.5
1012	"	1.55	283.62	97	60	1.50	135	240	150	9.5
1016	"	1.55	286.45	99	60	1.60	135	240	160	9.5
1020	"	1.55	289.28	102	61	1.60	140	240	160	9.5
1024	"	1.55	292.11	106	62	1.60	140	240	160	9.5
1028	"	1.55	294.95	106	62	1.60	140	240	160	9.5
144			104.655	83.1	56.6		121		1.27	
					70.					

FILTER #4
 SILICA GEL #
 SAMPLE MOISTURE SIZE
 INAPPROPRIATE SOLUTION VOLUMES
 STOP
 START

CLIENT Apco Island Cement NAPCA TRAIN DATA
 WO. # 300-18 Seattle

Sheet #1
 LOCATION Clinker cooler
 DATE 3/11/71
 TEST # 3
 PERSONNEL 1883 LWS/Buc

Transferred to city
 4/23/71

Reading at bagging point - velocity constantly at each point

TIME	POSITION	VELOCITY HEAD P. ft	GAS METER			GRIFICE HEAD desired	STACK TUMPS	NOTES TUMPS	Griffin Head Actual	Velocity
			READING	TUMPS IN	TUMPS OUT					
1422	A	2.0	296.16	70	62	2.34	125	255	1.68	8.5
4	1	1.55	300.16	80	62	1.73	125	255	1.73	8.5
8	1	1.55	303.43	90	63	1.65	115	260	1.65	8.5
12	4	1.30	306.72	96	64	1.42	120	265	1.42	8.5
16	5	1.50	309.99	99	64	1.62	130	275	1.62	8.5
20	6	1.55	313.26	104	64	1.62	125	270	1.62	8.5
24	7	1.50	316.53	108	65	1.62	125	270	1.62	8.5
28	7	1.40	319.80	108	65	1.48	125	270	1.48	8.5
32	7	1.40	323.07	109	65	1.47	125	270	1.47	8.5
36	7	1.50	326.34	110	66	1.61	120	270	1.61	8.5
40	11	1.60	329.61	112	67	1.89	120	270	1.89	8.5
44	12	1.50	332.88	116	68	1.61	125	270	1.61	8.5
48	12	—	335.45	116	68	—	—	—	—	8.5
52	12	1.40	338.72	116	68	1.49	125	270	1.49	8.5
56	12	1.10	342.00	116	68	1.10	120	270	1.10	8.5
60	12	1.10	345.27	116	68	1.03	110	270	1.03	8.5
64	12	0.75	348.54	116	68	0.69	120	270	0.69	8.5
68	12	0.75	351.81	116	68	0.73	120	270	0.73	8.5
72	12	0.75	355.08	116	68	0.73	130	270	0.73	8.5
76	12	0.75	358.35	116	68	0.73	130	270	0.73	8.5
80	12	0.75	361.62	116	68	0.73	130	270	0.73	8.5
84	12	0.75	364.89	116	68	0.73	130	270	0.73	8.5
88	12	0.75	368.16	116	68	0.73	130	270	0.73	8.5
92	12	0.75	371.43	116	68	0.73	130	270	0.73	8.5
96	12	0.75	374.70	116	68	0.73	130	270	0.73	8.5
100	12	0.75	377.97	116	68	0.73	130	270	0.73	8.5
104	12	0.75	381.24	116	68	0.73	130	270	0.73	8.5
108	12	0.75	384.51	116	68	0.73	130	270	0.73	8.5
112	12	0.75	387.78	116	68	0.73	130	270	0.73	8.5
116	12	0.75	391.05	116	68	0.73	130	270	0.73	8.5
120	12	0.75	394.32	116	68	0.73	130	270	0.73	8.5
124	12	0.75	397.59	116	68	0.73	130	270	0.73	8.5
128	12	0.75	400.86	116	68	0.73	130	270	0.73	8.5
132	12	0.75	404.13	116	68	0.73	130	270	0.73	8.5
136	12	0.75	407.40	116	68	0.73	130	270	0.73	8.5
140	12	0.75	410.67	116	68	0.73	130	270	0.73	8.5
144	12	0.75	413.94	116	68	0.73	130	270	0.73	8.5
148	12	0.75	417.21	116	68	0.73	130	270	0.73	8.5
152	12	0.75	420.48	116	68	0.73	130	270	0.73	8.5
156	12	0.75	423.75	116	68	0.73	130	270	0.73	8.5
160	12	0.75	427.02	116	68	0.73	130	270	0.73	8.5
164	12	0.75	430.29	116	68	0.73	130	270	0.73	8.5
168	12	0.75	433.56	116	68	0.73	130	270	0.73	8.5
172	12	0.75	436.83	116	68	0.73	130	270	0.73	8.5
176	12	0.75	440.10	116	68	0.73	130	270	0.73	8.5
180	12	0.75	443.37	116	68	0.73	130	270	0.73	8.5
184	12	0.75	446.64	116	68	0.73	130	270	0.73	8.5
188	12	0.75	449.91	116	68	0.73	130	270	0.73	8.5
192	12	0.75	453.18	116	68	0.73	130	270	0.73	8.5
196	12	0.75	456.45	116	68	0.73	130	270	0.73	8.5
200	12	0.75	459.72	116	68	0.73	130	270	0.73	8.5
204	12	0.75	462.99	116	68	0.73	130	270	0.73	8.5
208	12	0.75	466.26	116	68	0.73	130	270	0.73	8.5
212	12	0.75	469.53	116	68	0.73	130	270	0.73	8.5
216	12	0.75	472.80	116	68	0.73	130	270	0.73	8.5
220	12	0.75	476.07	116	68	0.73	130	270	0.73	8.5
224	12	0.75	479.34	116	68	0.73	130	270	0.73	8.5
228	12	0.75	482.61	116	68	0.73	130	270	0.73	8.5
232	12	0.75	485.88	116	68	0.73	130	270	0.73	8.5
236	12	0.75	489.15	116	68	0.73	130	270	0.73	8.5
240	12	0.75	492.42	116	68	0.73	130	270	0.73	8.5
244	12	0.75	495.69	116	68	0.73	130	270	0.73	8.5
248	12	0.75	498.96	116	68	0.73	130	270	0.73	8.5
252	12	0.75	502.23	116	68	0.73	130	270	0.73	8.5
256	12	0.75	505.50	116	68	0.73	130	270	0.73	8.5
260	12	0.75	508.77	116	68	0.73	130	270	0.73	8.5
264	12	0.75	512.04	116	68	0.73	130	270	0.73	8.5
268	12	0.75	515.31	116	68	0.73	130	270	0.73	8.5
272	12	0.75	518.58	116	68	0.73	130	270	0.73	8.5
276	12	0.75	521.85	116	68	0.73	130	270	0.73	8.5
280	12	0.75	525.12	116	68	0.73	130	270	0.73	8.5
284	12	0.75	528.39	116	68	0.73	130	270	0.73	8.5
288	12	0.75	531.66	116	68	0.73	130	270	0.73	8.5
292	12	0.75	534.93	116	68	0.73	130	270	0.73	8.5
296	12	0.75	538.20	116	68	0.73	130	270	0.73	8.5
300	12	0.75	541.47	116	68	0.73	130	270	0.73	8.5
304	12	0.75	544.74	116	68	0.73	130	270	0.73	8.5
308	12	0.75	548.01	116	68	0.73	130	270	0.73	8.5
312	12	0.75	551.28	116	68	0.73	130	270	0.73	8.5
316	12	0.75	554.55	116	68	0.73	130	270	0.73	8.5
320	12	0.75	557.82	116	68	0.73	130	270	0.73	8.5
324	12	0.75	561.09	116	68	0.73	130	270	0.73	8.5
328	12	0.75	564.36	116	68	0.73	130	270	0.73	8.5
332	12	0.75	567.63	116	68	0.73	130	270	0.73	8.5
336	12	0.75	570.90	116	68	0.73	130	270	0.73	8.5
340	12	0.75	574.17	116	68	0.73	130	270	0.73	8.5
344	12	0.75	577.44	116	68	0.73	130	270	0.73	8.5
348	12	0.75	580.71	116	68	0.73	130	270	0.73	8.5
352	12	0.75	583.98	116	68	0.73	130	270	0.73	8.5
356	12	0.75	587.25	116	68	0.73	130	270	0.73	8.5
360	12	0.75	590.52	116	68	0.73	130	270	0.73	8.5
364	12	0.75	593.79	116	68	0.73	130	270	0.73	8.5
368	12	0.75	597.06	116	68	0.73	130	270	0.73	8.5
372	12	0.75	600.33	116	68	0.73	130	270	0.73	8.5
376	12	0.75	603.60	116	68	0.73	130	270	0.73	8.5
380	12	0.75	606.87	116	68	0.73	130	270	0.73	8.5
384	12	0.75	610.14	116	68	0.73	130	270	0.73	8.5
388	12	0.75	613.41	116	68	0.73	130	270	0.73	8.5
392	12	0.75	616.68	116	68	0.73	130	270	0.73	8.5
396	12	0.75	619.95	116	68	0.73	130	270	0.73	8.5
400	12	0.75	623.22	116	68	0.73	130	270	0.73	8.5
404	12	0.75	626.49	116	68	0.73	130	270	0.73	8.5
408	12	0.75	629.76	116	68	0.73	130	270	0.73	8.5
412	12	0.75	633.03	116	68	0.73	130	270	0.73	8.5
416	12	0.75	636.30	116	68	0.73	130	270	0.73	8.5
420	12	0.75	639.57	116	68	0.73	130	270	0.73	8.5
424	12	0.75	642.84	116	68	0.73	130	270	0.73	8.5
428	12	0.75	646.11	116	68	0.73	130	270	0.73	8.5
432	12	0.75	649.38	116	68	0.73	130	270	0.73	8.5
436	12	0.75	652.65	116	68	0.73	130	270	0.73	8.5
440	12	0.75	655.92	116	68	0.73	130	270	0.73	8.5
444	12	0.75	659.19	116	68	0.73	130	270	0.73	8.5
448	12	0.75	662.46	116	68	0.73	130	270	0.73	8.5
452	12	0.75	665.73	116	68	0.73	130	270	0.73	8.5
456	12	0.75	669.00	116	68	0.73	130	270	0.73	8.5
460	12	0.75	672.27	116	68	0.73	130	270	0.73	8.5
464	12	0.75	675.54	116	68	0.73	130	270	0.73	8.5
468	12	0.75	678.81	116	68	0.73	130	270	0.73	8.5
472	12	0.75	682.08	116	68	0.73	130	270	0.73	8.5
476	12	0.75	685.35	116	68	0.73	130	270	0.73	8.5
480	12	0.75	688.62	116	68	0.73	130	270	0.73	8.5
484	12	0.75	691.89	116	68	0.73	130	270	0.73	8.5
488	12	0.75	695.16	116	68	0.73	130	270	0.73	8.5
492	12	0.75	698.43	116	68	0.73	130	270	0.73	8.5
496	12	0.75	701.70	116	68	0.73	130	270	0.73	8.5
500	12	0.75	704.97	116	68	0.73	130	270	0.73	8.5
504	12	0.75	708.24	116	68	0.73	130	270	0.73	8.5
508	12	0.75	711.51	116	68	0.73	130	270	0.73	8.5</

Clinker Cooler Dust Collector Duct
Ideal Cement, Seattle, Washington

<u>Sampling Data</u>						<u>Date 3-18 - 3-19</u>	
Run	DAY	P _{ae}	T _{aw}	V _{ce}	T _{ai}	P _{af}	V _{ab}
1	.189	30.23	144	103.809	68.7	1.30	105.39
2	.189	29.88	144	104.055	70.0	1.27	104.16
3	.189	29.92	144	101.920	81.3	1.26	100.02

Moisture

Run	V _{ce}	V _{cf}	V _{cg}	M _{ch}	M _{ca}
1	12	.569	.54	.990	28.89
2	10	.474	.54	.990	28.89
3	8	.379	.38	.996	28.96

Velocity and Calculation Data

Run	S _{dd}	P _{di}	T _{df}	S _{de}	V _{dh}	V _{db}	I _{ax}
1	3,888	30.28	141	27.24	4006	95,556	105.8
2	3,888	29.93	121	26.29	3889	94,850	105.4
3	3,888	29.97	124	26.17	3864	94,450	101.6

Static pres. 0.5 in. Hg.

PRELIMINARY FIELD DATA

Stack Geometry

Plant Aldeal Cement Smelt
 Test No. _____
 Location Kiln Stack
 Date _____

A. Dist. from inside of far wall to outside of near wall, in., = 20.8

B. Wall thickness, in., = 13"

Inside diameter of stack = A-B 19.5"

Stack Area = _____

Comments: $A = .785(d^2)$

Sketch of stack cross-section showing sampling holes

Calculations:

Point	% Dia. for circular stack	Dist. from outside of sample port, in.
1	4.4	8.6 + 13 = 21.6
2	14.7	28.7 = 41.8
3	29.5	57.5 = 77.0
4	70.5	137.5 = 157.0
5	85.3	166.3 = 179.3
6	95.6	186.4 = 199.3

Calculator _____

NIA-28 (12/67)

Plant Aldeal Cement Date 3-24-71

Sampling location Kiln Stack Train No. 2

STACK DATA FOR NOMOGRAPH:

1. Meter ΔH 1.78 in H_2O

2. Avg. meter tempt (ambient + 20° 30 50 °F

3. Moisture (volume) 30 %

4. Avg. static press. + _____ in. $H_2O \times 0.73 = +$ 10.2 in. Hg.

5. Bar. press sampling point 29.70 in. Hg + 29.72 (static press in. Hg) = _____ in. Hg.

6. Bar press of meter 29.70 in. Hg.

7. $P_s/P_m = \frac{5. \text{ in. Hg}}{5. \text{ in. Hg}} = \underline{1.0}$

8. Avg. stack temperature 500 °F.

9. Avg. stack velocity (ΔP) .071 in H_2O .

C factor (1) .58 (2) _____

Plant Aldeal Cement Date 3-24-71

Sampling location Kiln Stack Train No. 1

STACK DATA FOR NOMOGRAPH:

1. Meter ΔH 1.24 in H_2O

2. Avg. meter tempt (ambient + 20° 30 50 °F

3. Moisture (volume) 30 %

4. Avg. static press. + _____ in. $H_2O \times 0.73 = +$ 10.2 in. Hg.

5. Bar. press sampling point 29.70 in. Hg + 29.72 (static press in. Hg) = 29.72 in. Hg.

6. Bar press of meter 29.70 in. Hg.

7. $P_s/P_m = \frac{5. \text{ in. Hg}}{5. \text{ in. Hg}} = \underline{1.0}$

8. Avg. stack temperature 500 °F.

9. Avg. stack velocity (ΔP) .071 in H_2O .

C factor (1) .42 (2) _____

Kiln Slack, Seattle, Ideal Cement Train No. 1

Sampling Data

Run	DAV	Paz	Taw	Vac	Tai	Pzf	Vzb
1	0.50	29.79	60	38.802	57	1.23	39.694
2	.50						
3	.50						

Moisture

Run	Vce	Vcf	Vcg	Mch	Mbj	Mca
1	347	16.45	29.3	.71	31.04	27.26
2						
3						

Velocity and Calculation Data

Run	Sdd	Pdi	Tdf	Sde	Vdh	Vdb	IAX
1	29,850	29.81	542	9.03	1378	106,869	93.8
2							
3							

Static press. - .02 in Hg.
 Note - Train No. 1, Run 1 was operating at the same time as
 Train No. 2, Run 1; each being 180° ports away.
 3-24-71 11:30 reading CO₂ - 17% O₂ - 8%

Kiln Slack, Ideal Cement, Seattle Train No. 2

Sampling Data

Run	DAV	Paz	Taw	Vac	Tai	Pzf	Vzb
1	.50	29.79	60	35.394	51	1.72	36.677
2	.50						
3	.50						

Moisture

Run	Vce	Vcf	Vcg	Mch	Mbj	Mca
1	356	16.87	31.5	.69	31.04	27.00
2						
3						

Velocity and Calculation Data

Run	Sdd	Pdi	Tdf	Sde	Vdh	Vdb	IAX
1	29,850	29.81	545	9.05	1388	104,300	88.8
2							
3							

Static press. - .02 in Hg.
 Note - Train No. 1, Run 1 was operating at the same time as
 Train No. 2, Run 1; each being 180° ports away.
 3-24-71 11:30 reading CO₂ - 17% O₂ - 8%

Run No. 1-6 (18)
 Location Field
 Date 3-17-71
 Operator mm
 Sample Box No. _____
 Meter Box No. _____
 Meter A H 1.60
 C Factor 5.2

VERY IMPORTANT - FILL IN ALL BLANKS
 Read and record at the start of each test point.
 PATHOLOGICAL INCUBATORS - read and record every 5 minutes.

Ambient Temp °F 45
 Bar. Press. "Hg 30.26
 Assumed Humidity % 30
 Heater Box Setting, °F 250
 Probe Tip Dia., in. 5.00
 Probe Length 8 1/4
 Probe Heater Setting 70
 Avg. A P 1.07 Avg. H 1.32

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O AP	Orifice ΔH in. H ₂ O	Dry Gas Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp °F	Impinger Temp °F	Screen Temp in. H ₂ O	Stem Temp °F
N-1		500.886		1.82	60	4	110			51.5
3		506.2		1.81	61	3	120			
1		502.765								
3										
1		7.87								
3										
1										
3										
1										
3										

Handwritten note: No. 1
 Filter weight 0.1931g
 (or filter used)

Plant Idaho, Seattle
 Run No. one
 Location Field
 Date 3/13/71 and 3/24/71
 Operator _____
 Sample Box No. _____
 Meter Box No. 1.24
 Factor _____

VERY IMPORTANT - FILL IN ALL BLANKS
 Read and record at the start of each test point.
 PATHOLOGICAL INCUBATORS - read and record every 5 minutes.
 Ambient Temp °F 50
 Bar. Press. "Hg 29.79
 Assumed Humidity % 30
 Heater Box Setting, °F _____
 Probe Tip Dia., in. 0.50
 Probe Length _____
 Probe Heater Setting _____

Ambient Temp °F 50
 Bar. Press. "Hg 29.79
 Assumed Humidity % 30
 Heater Box Setting, °F _____
 Probe Tip Dia., in. 0.50
 Probe Length _____
 Probe Heater Setting _____

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O AP	Orifice ΔH in. H ₂ O	Dry Gas Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp °F	Impinger Temp °F	Screen Temp in. H ₂ O	Stem Temp °F
N-1	0	511.208	0.8	1.20	58	10	120			41.6
N-2	5	514.603	0.9	1.33	58	9	120			41.7
N-3	10	518.00	0.6	0.90	58	7	120			41.7
N-4	15	521.40	0.6	0.90	58	7	120			41.7
N-5	20	524.80	0.6	0.90	58	7	120			41.7
N-6	25	528.20	0.6	0.90	58	7	120			41.7
N-7	30	531.60	0.6	0.90	58	7	120			41.7
N-8	35	535.00	0.6	0.90	58	7	120			41.7
N-9	40	538.40	0.6	0.90	58	7	120			41.7
N-10	45	541.80	0.6	0.90	58	7	120			41.7
N-11	50	545.20	0.6	0.90	58	7	120			41.7
N-12	55	548.60	0.6	0.90	58	7	120			41.7
N-13	60	552.00	0.6	0.90	58	7	120			41.7
N-14	65	555.40	0.6	0.90	58	7	120			41.7
N-15	70	558.80	0.6	0.90	58	7	120			41.7
N-16	75	562.20	0.6	0.90	58	7	120			41.7
N-17	80	565.60	0.6	0.90	58	7	120			41.7
N-18	85	569.00	0.6	0.90	58	7	120			41.7
N-19	90	572.40	0.6	0.90	58	7	120			41.7
N-20	95	575.80	0.6	0.90	58	7	120			41.7
N-21	100	579.20	0.6	0.90	58	7	120			41.7
N-22	105	582.60	0.6	0.90	58	7	120			41.7
N-23	110	586.00	0.6	0.90	58	7	120			41.7
N-24	115	589.40	0.6	0.90	58	7	120			41.7
N-25	120	592.80	0.6	0.90	58	7	120			41.7
N-26	125	596.20	0.6	0.90	58	7	120			41.7
N-27	130	599.60	0.6	0.90	58	7	120			41.7
N-28	135	603.00	0.6	0.90	58	7	120			41.7
N-29	140	606.40	0.6	0.90	58	7	120			41.7
N-30	145	609.80	0.6	0.90	58	7	120			41.7
N-31	150	613.20	0.6	0.90	58	7	120			41.7
N-32	155	616.60	0.6	0.90	58	7	120			41.7
N-33	160	620.00	0.6	0.90	58	7	120			41.7
N-34	165	623.40	0.6	0.90	58	7	120			41.7
N-35	170	626.80	0.6	0.90	58	7	120			41.7
N-36	175	630.20	0.6	0.90	58	7	120			41.7
N-37	180	633.60	0.6	0.90	58	7	120			41.7
N-38	185	637.00	0.6	0.90	58	7	120			41.7
N-39	190	640.40	0.6	0.90	58	7	120			41.7
N-40	195	643.80	0.6	0.90	58	7	120			41.7
N-41	200	647.20	0.6	0.90	58	7	120			41.7
N-42	205	650.60	0.6	0.90	58	7	120			41.7
N-43	210	654.00	0.6	0.90	58	7	120			41.7
N-44	215	657.40	0.6	0.90	58	7	120			41.7
N-45	220	660.80	0.6	0.90	58	7	120			41.7
N-46	225	664.20	0.6	0.90	58	7	120			41.7
N-47	230	667.60	0.6	0.90	58	7	120			41.7
N-48	235	671.00	0.6	0.90	58	7	120			41.7
N-49	240	674.40	0.6	0.90	58	7	120			41.7
N-50	245	677.80	0.6	0.90	58	7	120			41.7
N-51	250	681.20	0.6	0.90	58	7	120			41.7
N-52	255	684.60	0.6	0.90	58	7	120			41.7
N-53	260	688.00	0.6	0.90	58	7	120			41.7
N-54	265	691.40	0.6	0.90	58	7	120			41.7
N-55	270	694.80	0.6	0.90	58	7	120			41.7
N-56	275	698.20	0.6	0.90	58	7	120			41.7
N-57	280	701.60	0.6	0.90	58	7	120			41.7
N-58	285	705.00	0.6	0.90	58	7	120			41.7
N-59	290	708.40	0.6	0.90	58	7	120			41.7
N-60	295	711.80	0.6	0.90	58	7	120			41.7
N-61	300	715.20	0.6	0.90	58	7	120			41.7
N-62	305	718.60	0.6	0.90	58	7	120			41.7
N-63	310	722.00	0.6	0.90	58	7	120			41.7
N-64	315	725.40	0.6	0.90	58	7	120			41.7
N-65	320	728.80	0.6	0.90	58	7	120			41.7
N-66	325	732.20	0.6	0.90	58	7	120			41.7
N-67	330	735.60	0.6	0.90	58	7	120			41.7
N-68	335	739.00	0.6	0.90	58	7	120			41.7
N-69	340	742.40	0.6	0.90	58	7	120			41.7
N-70	345	745.80	0.6	0.90	58	7	120			41.7
N-71	350	749.20	0.6	0.90	58	7	120			41.7
N-72	355	752.60	0.6	0.90	58	7	120			41.7
N-73	360	756.00	0.6	0.90	58	7	120			41.7
N-74	365	759.40	0.6	0.90	58	7	120			41.7
N-75	370	762.80	0.6	0.90	58	7	120			41.7
N-76	375	766.20	0.6	0.90	58	7	120			41.7
N-77	380	769.60	0.6	0.90	58	7	120			41.7
N-78	385	773.00	0.6	0.90	58	7	120			41.7
N-79	390	776.40	0.6	0.90	58	7	120			41.7
N-80	395	779.80	0.6	0.90	58	7	120			41.7
N-81	400	783.20	0.6	0.90	58	7	120			41.7
N-82	405	786.60	0.6	0.90	58	7	120			41.7
N-83	410	790.00	0.6	0.90	58	7	120			41.7
N-84	415	793.40	0.6	0.90	58	7	120			41.7
N-85	420	796.80	0.6	0.90	58	7	120			41.7
N-86	425	800.20	0.6	0.90	58	7	120			41.7
N-87	430	803.60	0.6	0.90	58	7	120			41.7
N-88	435	807.00	0.6	0.90	58	7	120			41.7
N-89	440	810.40	0.6	0.90	58	7	120			41.7
N-90	445	813.80	0.6	0.90	58	7	120			41.7
N-91	450	817.20	0.6	0.90	58	7	120			41.7
N-92	455	820.60	0.6	0.90	58	7	120			41.7
N-93	460	824.00	0.6	0.90	58	7	120			41.7
N-94	465	827.40	0.6	0.90	58	7	120			41.7
N-95	470	830.80	0.6	0.90	58	7	120			41.7
N-96	475	834.20	0.6	0.90	58	7	120			41.7
N-97	480	837.60	0.6	0.90	58	7	120			41.7
N-98	485	841.00	0.6	0.90	58	7	120			41.7
N-99	490	844.40	0.6	0.90	58	7	120			41.7
N-100	495	847.80	0.6	0.90	58	7	120			41.7

Dist. from Outside of Sample Port, in.

Plant Idaho, Seattle
 Run No. one
 Location Field
 Date 3/13/71 and 3/24/71
 Operator _____
 Sample Box No. _____
 Meter Box No. 1.70
 Factor _____

VERY IMPORTANT - FILL IN ALL BLANKS
 Read and record at the start of each test point.
 PATHOLOGICAL INCUBATORS - read and record every 5 minutes.
 Ambient Temp °F 50
 Bar. Press. "Hg 29.79
 Assumed Humidity % 30
 Heater Box Setting, °F _____
 Probe Tip Dia., in. 0.50
 Probe Length _____
 Probe Heater Setting _____

Ambient Temp °F 50
 Bar. Press. "Hg 29.79
 Assumed Humidity % 30
 Heater Box Setting, °F _____
 Probe Tip Dia., in. 0.50
 Probe Length _____
 Probe Heater Setting _____

Point	Clock Time	Dry Gas Meter, CF	Pitot in. H ₂ O AP	Orifice ΔH in. H ₂ O	Dry Gas Temp. °F	Pump Vacuum in. Hg Gauge	Box Temp °F	Impinger Temp °F	Screen Temp in. H ₂ O	Stem Temp °F
N-1	0	276.164	0.8	1.20	58	10	120			41.6
N-2	5	279.5	0.9	1.33	58	9	120			41.7
N-3	10	282.8	0.6	0.90	58	7	120			41.7
N-4	15	286.2	0.6	0.90	58	7	120			41.7
N-5	20	289.6	0.6	0.90	58	7	120			41.7
N-6	25	293.0	0.6	0.90	58	7	120			41.7
N-7	30	296.4	0.6	0.90	58	7	120			41.7
N-8	35	299.8	0.6	0.90	58	7	120			41.7
N-9	40	303.2	0.6	0.90	58	7	120			41.7
N-10	45	306.6	0.6	0.90	58	7	120			41.7
N-11	50	310.0	0.6	0.90	58	7	120			41.7
N-12	55	313.4	0.6	0.90	58	7	120			41.7
N-13	60	316.8	0.6	0.90	58	7	120			41.7
N-14	65	320.2	0.6	0.90	58	7	120			41.7
N-15	70	323.6	0.6	0.90	58	7	120			41.7
N-16	75	327.0	0.6	0.90	58	7	120			41.7
N-17	80	330.4	0.6	0.90	58	7	120			41.7
N-18	85	333.8	0.6	0.90	58	7	120			41.7
N-19	90	337.2	0.6	0.90	58	7	120			41.7
N-20	95	340.6	0.6	0.90	58	7	120			41.7
N-21	100	344.0	0.6	0.90	58	7	120			41.7
N-22	105	347.4	0.6	0.90	58	7	120			41.7
N-23	110	350.8	0.6	0.90	58	7	120			41.7
N-24	115	354.2	0.6	0.90	58	7	120			41.7
N-25	120	357.6	0.6	0.90	58	7	120			41.7
N-26	125	361.0	0.6	0.90	58	7	120			41.7
N-27	130	364.4	0.6	0.90	58	7	120			41.7
N-28	135	367.8	0.6	0.90	58	7	120			41.7
N-29	140	371.2	0.6	0.90	58	7	120			41.7
N-30	145	374.6	0.6	0.90	58	7	120			41.7
N-31	150	378.0	0.6	0.90	58	7	120			41.7
N-32	155	381.4	0.6	0.90	58	7	120			41.7
N-33	160	384.8	0.6	0.90	58	7	120			41.7
N-34	165	388.2	0.6	0.90	58	7	120			41.7
N-35	170	391.6	0.6	0.90	58	7	120			41.7
N-36	175	395.0	0.6	0.90	58	7	120			41.7
N-37	180	398.4	0.6	0.90	58	7	120			41.7
N-38	185	401.8	0.6	0.90	58	7	120			41.7
N-39	190	405.2	0.6	0.90	58	7	120			41.7
N-40	195	408.6	0.6	0.90	58	7	120			41.7
N-41	200	412.0	0.6	0.90	58	7	120			41.7
N-42	205	415.4	0.6	0.90	58	7	120			41.7
N-43	210	418.8	0.6	0.90	58	7	120			41.7
N-44	215	422.2	0.6	0.90	58	7	120			41.7
N-45	220	425.6	0.6	0.90	58	7	120			41.7
N-46	225	429.0	0.6	0.90	58	7	120			41.7
N-47	230	432.4	0.6	0.90	58	7	120			41.7
N-48	235	435.8	0.6	0.90	58	7	120			41.7
N-49	240	439.2	0.6	0.90	58	7	120			41.7
N-50	245	442.6	0.6	0.90	58	7	120			41.7
N-51	250	446.0	0.6	0.90	58	7	120			41.7
N-52	255	449.4	0.6	0.90	58	7	120			41.7
N-53	260	452.8	0.6	0.90	58	7	120			41.7
N-54	265	456.2	0.6	0.90	58	7	120			41.7
N-55	270	459.6	0.6	0.90	58	7	120			41.7
N-56	275	463.0	0.6	0.90	58	7	120			41.7
N-57	280	466.4	0.6	0.90	58	7	120			41.7
N-58	285	469.8	0.6	0.90	58	7	120			41.7
N-59	290	473.2	0.6	0.90	58	7	120			41.7
N-60	295	476.6	0.6	0.90	58	7	120			41.7
N-61	300	480.0	0.6	0.90	58	7	120			41.7
N-62	305	483.4	0.6	0.90	58	7	120			41.7
N-63	310	486.8	0.6	0.90	58	7	120			41.7
N-64	315	490.2	0.6	0.90	58	7	120			41.7
N-65	320	493.6	0.6	0.90	58	7	120			41.7
N-66	325	497.0	0.6	0.90	58	7	120			41.7
N-67	330	500.4	0.6	0.90	58	7	120			41.7
N-68	335	503.8	0.6	0.90	58	7	120			41.7
N-69	340	507.2	0.6	0.90	58	7	120			41.7
N-70	345	510.6	0.6	0.90	58	7	120			41.7
N-71	350	514.0	0.6	0.90	58	7	120			41.7
N-72	355	517.4	0.6	0.90	58	7	120			41.7
N-73	360	520.8	0.6	0.90	58	7	120			41.7
N-74	365	524.2	0.6	0.90	58	7	120			41.7
N-75	370	527.6	0.6	0.90	58	7	120			41.7
N-76	375	531.0	0.6	0.90	58	7	120			41.7
N-77	380	534.4	0.6	0.90	58	7	120			41.7
N-78	385	537.8	0.6	0.90	58	7	120			41.7
N-79	390	541.2	0.6	0.90	58	7	120			41.7
N-80	395	544.6	0.6	0.90	58	7	120			41.7
N-81	400	548.0	0.6	0.90	58	7	120			41.7
N-82	405	551.4	0.6	0.90	58	7	120			41.7
N-83	410	554.8	0.6	0.90	58	7	120			41.7
N-84	415	558.2	0.6	0.90	58	7	120			41.7
N-85	420	561.6	0.6	0.90	58	7	120			41.7
N-86	425	565.0	0.6	0.90	58	7	120			41.7
N-87	430	568.4	0.6	0.90	58	7	120			41.7
N-88	435	571.8	0.6	0.90	58	7	120			41.7
N-89	440	575.2	0.6	0.90	58	7	120			41.7
N-90	445	578.6	0.6	0.90	58	7	120			41.7
N-91	450	582.0	0.6	0.90	58	7	120			41.7
N-92	455	585.4	0.6	0.90	58	7	120			41.7
N-93	460	588.8	0.6	0.90	58	7	120			41.7
N-94	465	592.2	0.6	0.90	58	7	120			41.7
N-95	470	595.6	0.6	0.90	58	7	120			41.7
N-96	475	599.0	0.6	0.90	58	7	120			41.7
N-97	480	602.4	0.6	0.90	58	7	120			41.7
N-98	485	605.8	0.6	0.90	58	7	120			41.7
N-99	490	609.2	0.6	0.90	58	7	120			41.7
N-100	495	612.6	0.6	0.90	58	7	120			41.7

analyzed by Howard
crist

Kiln Slag - , Seattle, Ideal Cement Train No. 1

Sampling Data

Run	DAY	P ₂₃	T _{2W}	V _{AC}	T ₂₁	P _{2f}	V _{2b}
1	0.50	29.79	60	38.802	57	1.23	39.694
2	.50°						
3	0.50						

Moisture

Run	V _{ce}	V _{cf}	V _{cg}	M _{ch}	M _{bj}	M _{ca}
1	347	16.45	29.3	.71	31.04	27.26
2						
3						

Velocity and Calculation Data

Run	S _{dd}	P _{di}	T _{df}	S _{de}	V _{dh}	V _{db}	I _{AX}
1	29,850	29.81	542	9.03	1378	106,869	93.8
2							
3			46°				
			1002				

Static press. - .02 in. Hg.

Note - Train No. 1, Run 1 was operating at the same time as
Train No. 2, Run 1, each being 180° ports away!

3-24-71 11:30 reading CO₂ - 17% O₂ - 8%

analyzed by RFW

Kilm. Slack, Ideal Cement, Seattle Train No. 2

Sampling Data

Run	DAV	P ₂₂	T _{2W}	VAC	TAI	P _{2F}	VAB
1	.50	29.79	60	35.394	51	1.72	36.677
2	.50						
3	.50						

Moisture

Run	Vce	Vcf	Vcg	Mch	Mbj	Mca
1	356	16.87	31.5	.69	31.04	27.00
2						
3						

Velocity and Calculation Data

Run	Sdd	Pdi	Tdf	Sde	Vdh	Vdb	IAX
1	29,850	29.81	545	9.05	1388	104,300.	88.8
2							
3							

Static press. - .02 in Hg.

Note- Train No. 1, Run 1 was operating at the same time as Train No. 2, Run 1; each being 180° ports away!

3-24-71 11:30 reading CO₂ - 17% O₂ - 8%

FTS-206-583-0111

PRESURVEY - PROCESS INDUSTRY & POWER PLANTS

NAME OF COMPANY Ideal Cement DATE OF PRESURVEY 2-18-71
 ADDRESS 5400 West Marginal Way CITY Seattle STATE Washington
 NAME OF CONTACT ~~John~~ Bauer TITLE Plant Mgr PHONE 937-8025

PROVIDE FLOW DIAGRAM OF EACH PROCESS TO BE SAMPLED, INCLUDING FEED COMPOSITIONS AND RATES, OPERATING TEMPERATURES AND PRESSURES, PRODUCT RATES, AND PROPOSED SAMPLING SITES:

Process - wet
 Kiln fuel - natural gas
 Single kiln - yes

Kiln data at stack port	temperature	Moisture	CFM
	400°F	30-40	400,000
Clinker cooler	200-300 180°	3- 5 2-3	150,000
mill operation	2500	3-5	30,000 50,000

COMMENTS:
 Plant Capacity - 7200 bbl/day ; 2.6 MM BB2/year

PROVIDE DIAGRAM OF EACH SAMPLING SITE. INCLUDE THE FOLLOWING INFORMATION:


DIMENSIONS TO NEAREST OBSTRUCTION IN ALL DIRECTIONS FROM SAMPLING PORT.

COMPLETE DESCRIPTION OF ALL PORTS INCLUDING ALL DIMENSIONS. DESCRIPTION OF ANY UNUSUAL FEATURES ABOUT ENVIRONMENT; HEIGHT, ODORS, TOXIC CONDITIONS, TEMPERATURE, DUST, ETC.



*Inside plant environment - excellent
Outside environment - stack etc. lots of rain!*

No ports exist except on kiln stack (see drawing).

Kelvin mast



Port - 4 (8" x 8" x 90°)



150

$$\begin{array}{r} 146 \\ 3.5 \\ \hline 149.5 \end{array}$$

OPERATING HOURS OF PLANT PERSONNEL 24 hrs./day 7 days/week

OPERATING SCHEDULE FOR EACH PROCESS TO BE SAMPLED same

ARE PROCESSES BATCH OR CONTINUOUS? Continuous

LIST FEED RATES AND COMPOSITION FOR EACH PROCESS

LIST ANY CONTROL EQUIPMENT, INCLUDING SIZE Kiln ESP unit (3 stages);
Clinker cooler baghouse; mill finish mill baghouses

LIST EXPECTED CONSTITUENTS OF STACK GAS FOR EACH SAMPLING SITE NOx, particulates

Kiln STACK DATA: HEIGHT 250 . WIDTH 19'-13' DIAMETER 1.0/19'-13'

 O.D. AMOUNT OF INSULATION WALL THICKNESS 24" C

MATERIAL OF CONSTRUCTION concrete GAS TEMPERATURE @ 400°F

PRESSURE 4-6 in. H₂O WET BULB TEMPERATURE ?

AVERAGE PITOT TUBE READING

DISTANCE TO NEAREST UPSTREAM RESTRICTION 100' TYPE OF RESTRICTION top

DISTANCE TO NEAREST DOWNSTREAM RESTRICTION 110' TYPE OF RESTRICTION entrance duct

ARE PORTS EXISTING? ☒ YES, SIZE 8" x 8"

☐ NO. WHO WILL PROVIDE THEM?

SCAFFOLDING OR OTHER MEANS OF SUPPORT PRESENT?

☒ YES

☒ NO, WHO WILL PROVIDE IT? plant

SOURCE OF ELECTRICITY AVAILABLE? ☒ YES, MAXIMUM AMPERAGE PER CIRCUIT 20

☐ NO

DISTANCE 150-200 WHO WILL PROVIDE EXTENSION CORDS? contractor & plant

LOCATION OF FUSE BOX _____

PARKING FACILITIES AVAILABLE FOR TRAILER OR VAN? yes

SIGNATURE REQUIRED ON PASSES? no WAIVERS? _____

NEARBY RESTAURANTS AND MOTELS lunch - Andy's (@ 2 miles) Vending machines
Motels - Holiday Inn No. 1 Seattle: 206 762 0300
Cheaper - Mar - Lynn WE 7-9920

LIST ANY SPECIAL SAFETY EQUIPMENT OR RULES Hard hats

SURVEY BY C.E. Riley

COMMENTS:

Plants is in excellent condition. Plant personnel
seem very interested in our testing and want to cooperate
to the fullest extent.
Note - No ice available on plant site!

APPENDIX D
LABORATORY PROCEDURES

The following is a detailed outline of the laboratory procedure used in determining the weights of particulates and water collected in the various segments of the EPA-OAP sampling train.

All glassware used for evaporation and residue determinations in the following steps was prepared for use by the following procedure. The beakers were first soaked in 40% nitric acid for several hours. They were then washed and rinsed with distilled water followed by oven-drying. After drying, the beakers were desiccated to constant weight and kept in a desiccator until used. Beakers were weighed to ± 0.1 mg.

A. Filter

1.) Preparation

The filters are oven-dried @ 105°C for a minimum of four hours, and then desiccated to constant weight. Filters are weighed to ± 0.1 mg. After weighing, the filters are placed in plastic petri dishes until used.

2.) Particulate weight determination

Filter and any loose particulate matter are transferred to a tared glass weighing dish, and desiccated to constant weight. The weight gain is then recorded.

B. Acetone washings prior to filter

1.) The acetone washings are received in glass bottles and their volume is measured. They are then transferred to the tared beakers prepared as described above.

- 2.) The acetone washings are allowed to evaporate to dryness at ambient temperature and pressure. The beakers are covered with ribbed cover glasses to facilitate evaporation without allowing dust or other foreign matter into the beakers. When dry, the beakers are desiccated to constant weight. Beakers are weighed to nearest 0.1 mg.
- 3.) A blank of the acetone (measured amount) is evaporated also as described above. Any residue resulting from this blank is used to correct for the amount of acetone used in the washings. The net weight is the required particulate residue.

C. Impinger water plus water rinsings

- 1.) The volume of impinger water has been measured in the field and recorded. Final volumes of these samples are measured in the laboratory in order to determine the volume of washings used and to correct for this water using a blank (by the same procedure used in part B-3 above).
- 2.) At this point an organic extraction of the impinger water is in order. However, this step was omitted since no organic material was considered present.

D. Acetone washings - back

- 1.) The volume of acetone washings is first measured and then the liquid is transferred to tared beakers (prepared as above) and allowed to evaporate to dryness at ambient temperature and pressure. Upon drying, the beakers are desiccated to constant weight. A blank of the acetone used is also evaporated any corrections due

to the acetone are made if necessary. Beakers are weighed to nearest 0.1 mg.

E. Silica gel

1.) Preparation

The silica gel is placed in a wide mouth plastic bottle and capped. The bottle plus silica gel is then weighed to the nearest 0.1 gm.

2.) After sampling, the bottle plus used silica gel is weighed to the nearest 0.1 gm and the weight of water collected is determined.

Results of the sample recovery procedure are presented in Table D-1 wherein total particulate weights are reported for each run. These values were obtained by adding the weights of the probe, cyclone, filter and impinger catches.

An emission spectroscopy analysis was conducted on the particulate samples collected from each stack to determine the concentrations ($\mu\text{g/g}$) of the following elements: Sb, As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, Sr, V, and Zn. The results of these tests are presented in Table D - 2. In general, of the components tested for, iron was present in the highest proportion (reaching concentrations as high as 3.3%), followed by zinc, strontium and lead.

TABLE D - 1
RESULTS OF SAMPLE RECOVERY PROCEDURE

Description of Sample		Clinker Cooler			Kiln Stack		
		Run 1	Run 2	Run 3	Run 1*	Run 2	
1. Filter	RFW #	1419	1423	1427	----	1430	
	Filter #	F56	F65	F67	----	----	
	Net wt. gm.	0.0077	0.0297	0.0197	0.159	0.1643	
2. Probe, Flask Cyclone Front half Filter holder	RFW #	1417	1422	1426	----	1429	
	Acetone Beaker #	117	122	119	----	110	
	Wash	Net wt. gm	0.3433	.3569	0.4336	0.082	0.0892
Total		351.0	386.0	453.3	241	253.5	
3. Impinger H ₂ O + H ₂ O wash Imp, conn. back 1/2 filter holder	RFW #	1416	1420	1424	----	Note: Impinger water lost in transit. Value assumed to be that for Run# 1	
	Beaker #						
	Net wt. (blank) gms.	<u>0.0153</u>	<u>0.0047</u>	<u>0.0031</u>	0.021		0.021
4. Impingers, Connectors back 1/2 filter holder	RFW #	1418	1421	1425	----	1428	
	Acetone Beaker #	124	104	105	----	111	
	wash	Net wt. gm.	0.0080	0.0093	0.0063	----	0.0073
Blanks H ₂ O	RFW #	1414	1415		----		
	Beaker #	121	120		----		
	Net wt. gm.	0.0024	0.0025	----	0.0023	----	
	Sample Volume ml.	420	435		500		
Total Particulates, mg (obtained by adding weights 1, 2, 3 and 4)		374.3	400.6	462.7	262	281.8	

* See TABLE D - 1 (Continued)

TABLE D - 1 (Continued)
ENVIRONMENTAL PROTECTION AGENCY

Reply to
Attn of: ETB, DAT

Date: April 20, 1971

Run #1

Subject: Particulate Analysis of Samples Collected at Ideal Cement, Seattle, Washington.

To: Gene Riley

Sample	Particulate, Mg	Location
Impinger water	21	Kiln stack
Probe, cyclone, flask & filter holder	82	
Filter	<u>159</u>	
Total	262	
Water blank (Seattle)	2.3 Mg/500 ml	
Water blank (Tijeris)	2.1 Mg/500 ml	

The sample results reflect correction for the blank. The above sample was one of a pair of samples collected simultaneously by Roy Weston Company. They are analyzing the companion sample for comparison with the above results.

Howard Crist

Howard L. Crist
Chemist
Emission Testing Branch
Division of Applied Technology

TABLE D - 2

RESULTS OF EMISSION SPECTROSCOPY ANALYSIS

Sample type	Particulate	Particulate
Sample location and run No.	Clinker Cooler Run # 1	Kiln Run # 1
Sample weight, mg	374.3	262.0
Volume of gas sampled, scf	105.39	39.69

Concentration, $\mu\text{g/g}$

Sb	100	< 110
As	< 192	< 276
Be	2	2
Cd	40	170
Cr	850	100
Cu	500	200
Fe	33,000	15,000
Pb	300	4,000
Mn	400	200
Ni	500	200
Sr	2,000	< 276
V	< 4	60
Zn	4,000	8,000

APPENDIX E

SAMPLE CALCULATIONS

Example: Run No. 1 on Clinker Cooker (for data, see Table 3, page)

1. Volume of dry gas sampled at standard conditions: 70°F, 29.92 in. Hg, SCF

$$V_{m\text{std}} = \frac{17.7 \times V_m (P_b + \frac{P_m}{13.6})}{(T_m + 460)} = \frac{17.7 \times 103.81 (30.23 + 1.30)}{(68.7 + 460)} \times \frac{13.6}{13.6} = 105.39 \text{ SCF}$$

2. Volume of water vapor at 70°F and 29.92 in. Hg, SCF

$$V_{w\text{gas}} = 0.0474 \times V_w = 0.0474 \times 12 = 0.57 \text{ SCF}$$

3. Percent moisture in stack gas

$$\% M = \frac{100 \times V_{w\text{gas}}}{V_{m\text{std}} + V_{w\text{gas}}} = \frac{100 \times 0.57}{105.39 + 0.57} = 0.54$$

4. Mole fraction of dry gas

$$M_d = \frac{100 - \%M}{100} = \frac{100 - 0.54}{100} = 0.99$$

5. Average molecular weight of dry stack gas

$$MW_d = (\%CO_2 \times \frac{44}{100}) + (\%O_2 \times \frac{32}{100}) + [(\%CO + \%N_2) \times \frac{28}{100}] =$$

$$(0.03 \times \frac{44}{100}) + (20.95 \times \frac{32}{100}) + (78 \times \frac{28}{100}) = 29.0$$

6. Molecular weight of stack gas

$$MW = MW_d \times M_d + 18 (1 - M_d) = 29.0 \times 0.99 + 18 (1 - .99) = 28.9$$

7. Stack gas velocity at stack conditions, fpm

$$V_s = 4,360 \times \sqrt{\frac{P_s}{P_s \times (T_s + 460)}} \left[\frac{1}{P_s \times MW} \right]^{1/2} =$$

$$4,360 \times 27.2 \left[\frac{1}{30.28 \times 28.9} \right]^{1/2} = 4012 \text{ fpm}$$

SAMPLE CALCULATIONS, RUN NO. 1, CLINKER COOLER(Continued)

8. Stack gas volumetric flow rate at standard conditions*, SCFM

$$Q_s = \frac{0.123 \times V_s \times A_s \times M_d \times P_s}{(T_s + 460)} = \frac{0.123 \times 4012 \times 3888 \times 0.99 \times 30.28}{(141 + 460)} = 95,699 \text{ SCFM}$$

9. Stack gas volumetric flow rate at stack conditions, ACFM

$$Q_a = \frac{.05645 \times Q_s \times (T_s + 460)}{P_s \times M_d} = \frac{.05645 \times 95,699 \times (141 + 460)}{30.28 \times 0.99} = 108,307 \text{ ACFM}$$

10. Percent isokinetic

$$\%I = \frac{1,032 \times (T_s + 460) \times V_{m_{std}}}{V_s \times T_t \times P_s \times M_d \times (D_n)^2} = \frac{1,032 \times (141 + 460) \times 105.39}{4012 \times 144 \times 30.28 \times 0.99 \times (0.189)^2} = 105.7\%$$

11. Particulate: probe, cyclone and filter, gr/SCF* Dry Basis

$$C_{an} = 0.0154 \times \frac{m_f}{V_{m_{std}}} = 0.0154 \times \frac{351.0}{105.39} = 0.0513 \text{ gr/SCF}$$

12. Particulate total, gr/SCF* Dry Basis

$$C_{ao} = 0.0154 \times \frac{m_t}{V_{m_{std}}} = 0.0154 \times \frac{374.3}{105.39} = 0.0547 \text{ gr/SCF}$$

13. Particulate: probe, cyclone and filter, gr/CF at stack conditions

$$C_{at} = \frac{17.7 \times C_{an} \times P_s \times M_d}{(T_s + 460)} = \frac{17.7 \times 0.0513 \times 30.28 \times 0.99}{(141 + 460)} = 0.0453 \text{ gr/CF}$$

14. Particulate: total, gr/CF at stack conditions

$$C_{au} = \frac{17.7 \times C_{ao} \times P_s \times M_d}{(T_s + 460)} = \frac{17.7 \times 0.0547 \times 30.28 \times 0.99}{(141 + 460)} = 0.0483 \text{ gr/CF}$$

15. Particulate: probe, cyclone, and filter, lb/hr

$$C_{aw} = 0.00857 \times C_{an} \times Q_s = 0.00857 \times 0.0513 \times 95,699 = 42.0 \text{ lb/hr}$$

16. Particulate: total, lb/hr

$$C_{ax} = 0.00857 \times C_{ao} \times Q_s = 0.00857 \times 0.0547 \times 95,699 = 44.8 \text{ lb/hr}$$

17. Particulate: probe, cyclone, and filter, lb/ton feed

$$P_{tf} = \frac{C_{aw}}{T_c} = \frac{42.0}{103.4} = 0.406 \text{ lb/ton feed}$$

18. Particulate: total, lb/ton

$$P_{tt} = \frac{C_{ax}}{T_c} = \frac{44.8}{103.4} = 0.433 \text{ lb/ton feed}$$

APPENDIX F

TEST LOG

Table F - 1 presents the actual time during which sampling was conducted.

Table F - 1

Sampling Log

(Clinker Cooler)

<u>Run</u>	<u>Date</u>	<u>Sampling Port</u>	<u>Began</u>	<u>Ended</u>	<u>Elapsed Time (min)</u>
1	3-18-71	A	13:20	14:08	48
		B	14:19	15:07	48
		C	15:16	16:04	48
2	3-19-72	C	09:14	10:02	48
		B	10:10	10:58	48
		A	11:14	12:02	48
3	3-19-71	A	14:22	15:10	48
		B	15:16	16:04	48
		C	16:13	17:01	48

(Kiln Stack)

1	3-23-71	E	10:25	10:30	5
1(cont.)	3-24-71	E	10:50	11:00	10
		N	12:30	12:40	10
		N	12:50	12:55	5
		W	14:00	14:05	5
		W	14:15	14:25	10
		S	16:00	16:10	10
		S	16:20	16:25	5

TABLE F - 1 (Continued)

<u>Run</u>	<u>Date</u>	<u>Sampling Port</u>	<u>Began</u>	<u>Ended</u>	<u>Elapsed Time (min)</u>
2	3-23-71	W	10:25	10:30	5
2(cont.)	3-24-71	W	10:50	11:00	10
		S	12:30	12:40	10
		S	12:50	12:55	5
		E	14:00	14:05	5
		E	14:15	14:25	10
		N	16:00	16:10	10
		N	16:20	16:25	5