

ENFORCEMENT WORKSHOP ON PLANT INSPECTION AND EVALUATION PROCEDURES

VOLUME II INSPECTION PROCEDURES AND PERFORMANCE EVALUATION



**U.S. ENVIRONMENTAL PROTECTION AGENCY
OFFICE OF ENFORCEMENT
OFFICE OF GENERAL ENFORCEMENT
WASHINGTON, D.C. 20460**

ENFORCEMENT WORKSHOP ON
PLANT INSPECTION AND EVALUATION

COUNTERFLOW INSPECTION PROCEDURES
FOR PERFORMANCE BASELINE ASSESSMENT
AND ROUTINE EVALUATION

by

John R. Richards
PEDCo Environmental, Inc.
505 South Duke Street
Durham, North Carolina 27701

Contract No. 68-01-4147
PN 3570-2-I

for

U.S. ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF STATIONARY SOURCE ENFORCEMENT
OFFICE OF ENFORCEMENT
WASHINGTON, D.C. 20460

February 1980

CONTENTS

	<u>Page</u>
1. Counterflow Inspection Procedures for Performance Baseline Assessment and Routine Evaluation	1
1.1 Baseline Assessment	2
2. Counterflow Inspection Concepts	4
3. Pre-inspection Steps for Regulatory Agency Inspectors	6
3.1 File Review	6
3.2 Inspection Announcement	7
3.3 Inspection Equipment	7
3.4 Plant Surroundings	8
3.5 Plant Entry	9
3.6 Pre-inspection Interview	9
4. Counterflow Inspection for Routine Performance Evaluation	11
4.1 Step 1: Observe the Stack Effluent	11
4.2 Step 2: Check the Continuous Monitors	19
4.3 Step 3: Measure the Fan Parameters	20
4.4 Step 4: Analyze Control Device Performance	26
4.4.1 Fabric filters	41
4.4.2 Wet scrubbers	42
4.4.3 Electrostatic precipitators	43
4.5 Step 5: Check the Ventilation System	45
4.6 Step 6: Evaluate Process Operating Conditions	45
5. Post-inspection Steps for Regulatory Agency Personnel	50
5.1 Plant Interview	50
5.2 File Update and Report Preparation	50
6. Safety Considerations	51
Appendix A: (See Working File Handout)	
Appendix B: Sample Inspection Data Sheets	56

SECTION 1

COUNTERFLOW INSPECTION PROCEDURES FOR PERFORMANCE BASELINE ASSESSMENT AND ROUTINE EVALUATION

The Counterflow Inspection Procedure has been developed by PEDCo Environmental to aid both the source operators and regulatory agency inspectors to routinely evaluate air pollution control equipment performance. The fundamental principal of the Counterflow Techniques is simply that performance diagnosis is done by comparison of observed operating conditions with a site-specific baseline operating condition. It is recognized that field measurements are sometimes subject to error or impossible; therefore, diagnosis is based on sets of trends rather than just one parameter. Even when some of the basic data is missing, it is still possible to reach meaningful and accurate conclusions.

The purpose of the Counterflow Technique is to rapidly identify significant changes in performance and the possible reasons for the changes. It does not, necessarily, provide definite evidence of noncompliance nor does it, necessarily provide a specific list of repairs required.

Persons utilizing the Counterflow Inspection Technique should have a technical background--preferably engineering experience. As with any work involving equipment, care should be exercised. Section 6 provides some minimum guidelines and should be read and reread regularly. Formal safety training is highly recommended for this activity and any field work involving air pollution control equipment.

No single technique can satisfy all source characteristics and inspection circumstances. Inspectors and source operators should modify these procedures whenever necessary.

1.1 BASELINE ASSESSMENT

Baseline determinations are preferably done soon after the unit is installed and the shakedown period has been successfully completed. For existing units, an adequate baseline can be developed during a properly conducted stack test. The purpose of the baseline assessment is to provide a site-specific comparison of equipment performance.

The inspection procedures (and forms) presented in this report should be used for both the baseline assessment and the routine evaluation. There are several additional items, however, that should be accomplished, namely:

1. Request a set of general arrangement drawings of the control equipment, ventilation system layout, and waste handling system;
2. Evaluate the stack test location and procedures to ensure the emissions data will be accurate and complete;
3. Carefully describe all internal conditions (if such inspections can be conducted safely). Photographs are extremely valuable and should be taken if it is safe to do so and if plant personnel permits;
4. The sounds of operating components, such as rappers and solenoids, should be noted so that the inspector will be able distinguish developing problems;
5. Obtain a complete set of process operating conditions, fan characteristics, and raw material characteristics; and
6. Obtain Method 9 opacity readings.

Using the opacity observation and the stack test results, the inspector should evaluate how close the source is operating to the applicable regulations. If the margin is small, the variability is normal; performance may be enough to result in frequent violations. If the source is initially well-below the standard, major changes in operation or severe deterioration of control equipment is needed to result

in noncompliance. The inspector must always be cognizant of the compliance margin. The Counterflow Inspection Procedures are used to evaluate the significance of the changes since the baseline assessment.

SECTION 2

COUNTERFLOW INSPECTION CONCEPTS

Proceeding counter to the gas flow (backward through the system) should minimize inspection time and reporting requirements and maximize the amount of useful information obtained. More specifically, the information on effluents and control equipment gained early in the inspection is not only the easiest to obtain, it can be used later either to narrow the scope of the inspection or to terminate the inspection without completing the most time-consuming part of the evaluation--namely, the process equipment.

As shown in the list below, the steps start at the stack, proceed backward through the system, and end with the process equipment. For regulatory agency personnel, there are some additional preinspection and post-inspection steps required.

Counterflow Inspection Procedure

- Observe the stack effluent
- Check the continuous monitor(s)
- Measure the fan parameters and evaluate physical condition
- Analyze the control equipment performance and physical conditions
- Check the ventilation system performance and physical condition
- Evaluate process operating conditions
- Check raw materials and/or fuels

Pre-inspection Steps (regulatory agency personnel only)

- Review the source files
- Schedule the inspection
- Check the inspection equipment
- Observe the plant surroundings

Request entry to the plant
Interview plant official(s)

Post-inspection Steps (regulatory agency personnel
only)

Interview plant official(s)
Update source files
Prepare report

SECTION 3

PRE-INSPECTION

3.1 FILE REVIEW

A logical starting point for Agency inspectors is to review the files concerning the specific plant. The following items should be checked. Copies of items 1 and 2 should be obtained for the project files.

1. Pending compliance schedules,
2. Construction and/or operating permits pertaining to source processes,
3. Past conditions of noncompliance,
4. Frequency of malfunctions reports, and
5. History of abnormal operations.

The inspector should also obtain a copy of appropriate plant layout drawings for use in preparing the audit inspection report. If possible, the files should be reviewed before entry to the plant so that important characteristics will be more easily remembered.

The inspector should prepare a concise file containing basic plant information, process descriptions, flowsheets, and acceptable operating conditions (Appendix A). It should contain the following to facilitate inspections and/or preparations:

1. A chronology of control actions, inspections, and complaints concerning each major source in the plant;

2. A flowsheet identifying sources, control devices, monitors, and other information of interest;
3. The most recent permits for each major source, and
4. Previous inspection checklists.

Volume IV presents a recommended flow charting technique. In plants with complex control systems, it may be beneficial to review the technical literature and/or the complete agency file.

Based on reviews of agency and personnel files, the inspector should select a time when processes will probably be operating at representative conditions. The scheduling of time to visit plants with batch operations or other irregular operating schedules (e.g., seasonal) is especially important.

3.2 INSPECTION ANNOUNCEMENT

Written instructions from the Agency supervisory personnel should be obtained concerning the advance announcement of inspections. If it is desirable to announce the inspection in advance, leads of 1 day to 1 week are generally adequate to ensure that the necessary plant personnel will be available. The person contacted should have the authority to release data and samples and to arrange for access to specific processes.

3.3 INSPECTION EQUIPMENT

Necessary tools and safety gear should be carried in a portable case from source to source:

Carry at all Times

Hardhat
Safety glasses or goggles
Gloves
Coveralls
Safety shoes (steel tipped)
Ear protectors

Tape measure
Flashlight
Manometer or differential pressure gauges
Stopwatch
pH paper
Brass rods
Duct tape
Pry bar
Pocket guide of industrial hazards

Other equipment can be left in a central location until needed.

Carry When Needed

Pipe wrench
Respirator with appropriate cartridge
Velometer
Pump and filter system
Bucket
Combustion gas analyzer
Thermometers or thermocouples
Multimeter
Sample bottles
Strobe
Inductance ammeter
Tachometer
Oxygen and combustibles meter
Self-contained breathing equipment
Pipe wrench
Rope

Particularly important is the safety equipment--including the hard hat, the safety glasses, and the ear protectors. Remember, it is the inspector's responsibility to have safety equipment before entering the plant. Access to certain industrial facilities can be rightfully restricted or refused by plant representatives if designated equipment is not worn.

3.4 PLANT SURROUNDINGS

Observations of areas surrounding the plant may reveal a variety of signs of operational practices and pollutant emissions which can aid in the preentry evaluation, including:

1. Obvious vegetation damage near the plant,
2. Odors downwind of the plant,

3. Deposits on cars parked closeby,
4. Other signs of "dusting" downwind of the plant,
5. Fugitive emissions near plant boundaries,
6. Conditions around the product and/or waste storage piles, and
7. Conditions near lagoons and sludge ponds.

Some of the signs may mean that fugitive emission sources should be added to the inspection agenda. If odors are a problem, the weather conditions should be noted for later inclusion in the inspection report. Once inside the plant, olfactory fatigue may (under certain circumstances) reduce the inspector's ability to detect odors.

3.5 PLANT ENTRY

Upon arrival at the plant offices, the inspector should contact a responsible official to gain access to specific areas. If requested, the inspector should display an employee identification card which includes a photograph, and a physical description including, but not necessarily limited to, height, color of eyes, and color of hair. Visitor release forms generally can be signed as long as they in no way restrict the scope of the inspection.

If entry is refused for part or all of a facility within the scope of the inspection, obtain 1) reason(s) for refusal of entry, 2) plant official's name and title, and 3) time and date entry was requested. Notify supervisory personnel by telephone immediately. Under no circumstances should field inspectors attempt to summarize the potential legal consequences of refusal of entry.

3.6 PRE-INSPECTION INTERVIEW

The inspector should plan the initial interview with the plant manager or other responsible officials prior to the in-plant inspection. Some of the points for discussion are:

1. The purpose of the inspection,
2. The type of measurements to be made,
3. The samples (if any) to be acquired,
4. The systems to be evaluated,
5. Changes in plant management that need to be noted in the main file,
6. Process flowsheets needed to confirm that operational conditions in the file still pertain, and
7. Operating records required by Standards of Performance for New Sources (NSPS) and/or for determinations of operating conditions specified in permits.

Applicable regulatory requirements should be reviewed carefully, and their specific applications to the source in question should be discussed with appropriate engineering and/or legal staff.

Other issues the inspector should be prepared to discuss include:

1. Authority for the inspection,
2. Agency organization,
3. Scope, timing, and organization of the inspection (preferred inspection agenda), and
4. Treatment of confidential data.

The inspector should ask plant officials about the operational status of all processes and pollution control equipment within the scope of the inspection and about the types and frequencies of any malfunctions. If equipment is not at or near normal conditions, the reasons for deviation should be noted, and the times when units can be expected to achieve representative operations should be recorded for use in scheduling follow-up inspections, if necessary.

SECTION 4

COUNTERFLOW INSPECTION

The inspector starts the inspection at the gas exhaust point (or endpoint) of the process and proceeds through the process flow to the point where raw materials are input. Each step shown on the flowsheet of Figure 1 should be based on data from previous steps to derive increasingly precise analyses. Examples of data received at each step are listed in column 2 of Table 1; the evaluations in column 3 gradually focus on air pollution control effectiveness as the inspection continues, due to the expanding data base in column 4. By the time the in-plant inspection has ended, a series of ten or fifteen distinct observations should provide a consistent and logical assessment of performance conditions.

4.1 STEP 1: OBSERVE THE STACK EFFLUENT

The opacity readings^a of emission points should be observed using Method 9 procedures. PEDCo recognizes that an agency can, in many cases, develop a legally and technically sound case solely on the basis of visible emission observations. In some cases, however, it is possible that the value of opacity information will be primarily for diagnosing changes in system performance. The following paragraphs describe how the Counterflow Technique includes this diagnostic requirement.

^aOnly staff with currently valid Visible Emission Certificates should make these observations. It should be recognized that an agency may choose to initiate enforcement actions directly on the basis of these observations.

STEP 6
INSPECT
PROCESS

STEP 5
INFLUENT GAS
HANDLING SYSTEM

STEP 1
OBSERVE STACK




Figure 1. Steps in Counterflow Inspection Technique for coal-fired utility boilers controlled by a "cold side" electrostatic precipitator.

TABLE 1. COUNTERFLOW TECHNIQUE, UTILIZATION OF DATA

Step	Data obtained	Preliminary evaluation	Support data and steps obtained
1. Stack effluent	Change in opacity reading Presence of detached plume Presence and timing of puffs Colors of emissions	None	None
2. Continuous monitors	Change in opacity reading SO ₂ and NO _x concentrations Temperature of gas stream Intermittent emission spikes Representativeness of inspection period (review of records)	Have emissions increased to the point of possible noncompliance? Has size distribution of particles changed? Are there intermittent emission problems?	Opacity - step 1 Opacity - step 1 Color - step 1 Puffs - step 1
3. Induced draft fan	Fan static pressure Fan R.P.M. Fan motor current Gas temperature Fan wheel vibration Fan housing condition Fan damper position	Has system pressure drop changed? Has control system been bypassed? Is effluent diluted? Has gas flow rate changed? Is demister operating satisfactorily? Has operation changed fan R.P.M.?	None
Inspection stop point		Is further inspection necessary?	Opacity - step 1 Opacity - step 2 Gas temp - step 2 or 3 Fan static pressure - step 3 Fan motor current - step 3 Fan R.P.M. - step 3
4. Air pollution control device external inspection	Static pressure drop Cleaning system operation Hopper condition Liquid flow rate Liquid temperature Liquid pH Electrical parameters Rapper operation Solids/liquids discharge rate	Has gas flow rate increased or decreased substantially? Has mass loading increased? Has particle size distribution changed? Are operating and maintenance practices adequate?	Opacity - steps 1 and 2 Gas temperature - step 2 or 3 System pressure drop - step 3 Fan motor current - step 3 Opacity - steps 1 and 2 System pressure drop - step 3 Opacity - steps 1 and 2 Color of plume - step 1

(continued)

TABLE 1. (continued)

Step	Data obtained	Preliminary evaluation	Support data and steps obtained
Inspection stop point		Is further inspection necessary?	Results of previous analyses, plus comparison of control device actual and baseline parameters (diagnostic score)
5. Ventilation system ductwork (effluent delivery)	Hood capture velocities Static pressures along ductwork Gas temperatures Condition of cleanout traps Integrity of ductwork	Have gas flow rates changed? Are gas streams being diluted? Are all sources being operated?	Fan current - step 3 Fan static pressure - step 3 Control equipment static pressure drop - step 4 Gas temp - steps 2 and 3
6. Process equipment	Production data Process monitors Raw material information and samples	Has production rate increased? Have operating conditions changed? Have raw material characteristics changed? Has particle size distribution of effluent changed? Can an internal inspection of control equipment be conducted safely?	Gas flow rate - step 5 Static pressure data - steps 4 and 5 Solids discharge rates - step 4 Opacity - steps 1 and 2 Fan motor current - step 3 Fan static pressures - step 3 Opacity - steps 1 and 2
Inspection stop point		Is an internal inspection of air pollution control devices necessary and feasible?	Process operating conditions - step 2 Control device conditions - step 4
7. Air pollution control device (external inspection)	Clean side deposits Alignment of electrodes - ESP Insulator conditions Fabric condition Gas distribution plate/vane conditions Air inleakage through welds and holes Hopper conditions		Confirm preliminary evaluations - steps 1 through 6

In most cases, there is a relationship between the opacity observed during the inspection and the mass emissions penetrating the control device. Regardless of the mathematical form of this relationship, as the opacity increases, the mass emissions generally increase. In Figure 2a, Case 1 represents the most sensitive relationship--a small increase in opacity indicates a large increase in mass emissions; however, errors inherent in a small opacity increase can make any conclusions meaningless in this case. Case 2 presents "contrary" problems--above a certain upper opacity level, there is no change in mass emission rates; thus, at this level, opacity has no diagnostic value. The ideal case is the linear relationship of Case 3; fortuitously, this is generally the prevailing relationship in most industries.

Despite the best efforts of regulatory development personnel, the mass emission regulations and opacity regulations may not always agree. Linear relationships illustrate these possible disagreements in Figure 2b. Case 4 represents the intended situation; that is, any violation of an opacity regulation also involves a violation of the mass emission regulation. In Case 5 there is a substantial opacity violation without a violation of the mass standard. In other cases (represented by line segment 6), a violation of mass emission standards might not be suspected due to decreased sensitivity to opacity. The point is: in certain cases the absolute magnitude of the observed opacity is most useful when the opacity-mass relationship is known.

In the diagnostic phase of the Counterflow approach, the procedure uses (whenever possible) a change in opacity (observed versus historical) rather than an absolute magnitude of observed opacity. Regardless of the opacity-mass relationship, (or the mathematical form) a change in opacity does indicate a change in mass emissions. This information supported by a set of facts herein provides the conclusions sought in a plant inspection using the counterflow procedure.




Figure 2a. Opacity-mass relationships.




Figure 2b. Opacity and mass emission violations.

The color of the effluent is another plume characteristic which should be observed. For fossil fuel combustion sources, the color is an indirect indication of operating conditions. The following list (Table 2) was compiled by EPA's Control Programs Development Divisions:

TABLE 2. PLUME CHARACTERISTICS AND COMBUSTION PARAMETERS

Plume color	Possible operating parameters to investigate
White	Excess combustion air; loss of burner flame in oil-fired furnace
Gray	Inadequate air supply or distribution
Black	Lack of air; clogged or dirty burners or insufficient atomizing pressure, improper oil preheat; improper size of coal
Reddish brown	Excess furnace temperatures or excess air; burner configuration
Bluish white	High sulfur content in fuel

For other types of sources, the color may not be as variable or may not have a distinct meaning with respect to the process or the control equipment. Nevertheless, a change in the color indicates a change in the system. For example:

1. Increased quantities of bluish particulates generally indicate increased generation of very small particles (0.1 to 2 microns) which are difficult to collect in most control devices.
2. A detached plume indicates fairly conclusively that particulates are forming as the vapors are released to the cold ambient air; detached plumes often cause serious corrosion problems, since any cold surface in the system is susceptible to acid-mist condensation.
3. The frequency and duration of "puffs" from the stack are often caused by rapping reentrainment problems in electrostatic precipitators (ESP's) or by fabric leaking/cleaning problems in baghouses. Cyclic process conditions can also lead to puffs.

4.2 STEP 2: CHECK THE CONTINUOUS MONITORS

After observation of the stack effluent, the next logical step is to check the continuous monitors downstream from the control equipment.

1. The operation of the purge air blowers should be confirmed and the alignment of the source and retro-reflection should be checked.
2. The actual path length should be compared with the value used in the instrument calibration.
3. In almost all cases, the zero and full-scale settings can be checked and confirmed without taking the instrument offline.
4. The status of the window inductor light should be checked.
5. Also, the appearance of the instrument recording trace and the changes in recorded values may indicate reliability or unreliability of continuous monitor data.

Process operating personnel should be able to supply data on the technique and the frequency of calibrations.

The continuous opacity monitor (commonly called a transmissometer) indicates intermittent emission spikes caused by rapping reentrainment (ESP's); pulse flexing of bag seams (fabric filters); and other problems. A brief scan of the last 24 hours of chart paper may help to identify these problems and to describe system performance.

The transmissometer data should be used to confirm and clarify the opacity observations in step 1. Instrument problems should be suspected when there are substantial differences between the opacity recorded in step 1 and that indicated on the monitor. If the instrument response time and the recorder chart speed have been set properly, it will be possible to check for trends in the opacity levels.

1. A cyclic pattern suggests variation in process operating conditions; and

2. A continually deteriorating pattern suggests a developing control device problem which is likely to demand the attentions of the operator and the inspector; the deterioration can also suggest a gradual drift of the instrument or accumulation of dirt on the optical surfaces.

Failure to properly operate and/or maintain an opacity monitor can constitute a violation of regulations.

In step 2, the inspector should have:

1. Confirmed the visible emissions status with respect to opacity regulations,
2. Confirmed the installation and operating status with respect to continuous monitor regulations, and
3. Developed a preliminary idea of the process and the control device operating conditions.

As yet, there would not be enough information to evaluate mass emissions in cases where a reliable opacity-mass emission correlation has not been identified.

4.3 STEP 3: MEASURE THE FAN OPERATING PARAMETERS

Three operating parameters of the induced draft fan are useful in interpreting control system operations:

1. Increase in total static pressure across the fan,
2. Electrical current drawn by the fan motor, and
3. Revolutions per minute (R.P.M.'s) of the fan wheel.

Evaluated together these parameters indicate the gas flow rate and the total system pressure drop. These changes are important in diagnosing control system operating conditions.

If the fan parameters are not monitored at the plant, the inspector should use an inductance ammeter, a manometer (or magnehelic gauge), and a tachometer (or a strobe in cases where the tachometer cannot be used). The inspector should request that static pressure taps be made in the ductwork leading to and from the induced draft fan. The inspector should not drill or cut these holes unless the plant manager approves. Once

taps are available, the static pressures at the fan inlet and outlet should be measured using the set of magnehelic gauges.

The fan data can be used to estimate the gas flow at the time of the inspection. After correction of all readings to standard conditions, refer to the appropriate set of characteristic curves to determine SCFM. Please remember that this is only an estimate and is subject to errors due to variability in fan performance, site-specific gas flow factors, and physical condition of the wheel. The remainder of this section concerns means to utilize fan data to diagnose changes since the previous Counterflow Inspection. (Note: in most cases the baseline data will not be available since fan parameters are not measured in conventional inspections).

The type of fan used by most industrial sources with particulate-laden effluents is the radial blade centrifugal fan. Its operating parameters are illustrated in Figure 3; this curve applies to a New York Blower Company size 332 general induced draft fan with an LS wheel operating at 1460 R.P.M.'s at standard conditions. As indicated, the static pressure losses in the control equipment and ductwork (curve A) increase proportionally with the square of the flow rate. The fan, however, develops less static pressure at higher flow rates, and thus it has a strong negative slope (curve B). The intersection of the system line and the fan pressure drop curves define the operating point of the system. At this point, the gas flow rate is 8,400 SCFM, and the brake horsepower (curve C) is approximately 24.5. Figure 3 should be used as baseline data in considering:

1. The potential effects of gas temperature,
2. The changes in system static pressure drop, and
3. The changes in fan speed.

Changes in the rotation speed of the fan wheel is possible in many belt-driven units as shown by the curves in Figure 4. In Case 1, an R.P.M. increase leads to a greater gas flow rate and




Figure 3. Operating characteristics of radial blade centrifugal fan
(New York blower size 332 with LS wheel @ 1460




Figure 4. Fan characteristic curves, effect of R.P.M. change.

higher static pressure. Increasing the R.P.M. is the course of action at plants where process gas flow is insufficient; however, this can dangerously increase tip speed, and it can adversely affect fabric filters or ESP's. The opposite situation is illustrated in Case 2. An R.P.M. decrease (perhaps to save energy cost) can decrease the flow substantially; this can reduce the collection efficiency of cyclones and wet scrubbers since these depend on impaction for particle collection and since impaction efficiency is directly dependent on gas velocity. Increases in the fan wheel R.P.M. can occur because of intentional actions of the operator. (Belt shippage can reduce R.P.M. without operator's knowledge).

Other changes in fan operation can occur with or without the operator's knowledge. For example, the fan motor current decreases when the static pressure drop increases; Case 3 in Figure 5 represents total system pressure drop increases. Accompanying this Case 3 change should be an increase in the fan motor current as indicated in Figure 5. As indicated in Table 3, this change can be due to a variety of process and control device operating factors. Pressure drop decreases can be caused by (partial list):

1. Decreased effluent gas flow rate, and/or
2. Operating conditions such as control device short-circuiting (open access doors, gaps in ductwork, open by-pass dampers), and
3. Decreased scrubber liquor flow.

The cause of the change can be further analyzed by considering the measured gas temperature at the fan inlet. A low temperature suggests either an open access hatch or a serious leak in the ductwork.

System diagnoses are based on changes in the three fan operating parameters. All three (total static pressure, motor current, and wheel R.P.M.) must be measured since all three are analyzed as a set. (The Counterflow Procedure does not require




Figure 5. Fan characteristic curves--effect of system pressure drop change.

knowledge of fan characteristic curves.) With these, the inspector should be able to determine if abnormal conditions exist and which of the four cases is applicable.

In addition to analyzing the operation of the fan, the inspector should observe the physical condition of the fan. If it is possible to physically inspect the fan (be sure it is locked off), note the presence of:

1. Blade abrasion,
2. Deposit buildups, and
3. Corrosion of the wheel and fan housing.

The first two problems indicate excess emissions of large particles (10 μ) and demister malfunction. The third problem could be due to both the overloading of the demister and excess emissions of corrosive gases. The induced draft fan operating parameters indicate a number of important changes in control device operating conditions (Table 3). The measured parameters were corrected for the gas temperature at the fan inlet by using the factors in Table 4.

At the end of step 3, the inspector should decide whether or not further on-site efforts are necessary to determine compliance with mass emission standards. If the fan operating parameters (static pressure, motor current, and R.P.M.'s) are $\pm 10\%$ and if the gas temperature at the fan inlet is $\pm 20^{\circ}\text{F}$, it is unlikely that mass emissions have changed significantly. In some cases, the field inspection can be terminated with step 3. Generally, it is necessary to inspect the control equipment (step 4) to confirm the evaluations of steps 1, 2, and 3.

4.4 STEP 4: ANALYZE CONTROL DEVICE PERFORMANCE

Based on the previous three steps in the Counterflow Procedure, the inspector should have a preliminary estimate of the following:

1. Present gas flow rate through the control system and changes since last Counterflow Inspection,

TABLE 3. INTERPRETATION OF FAN OPERATING CONDITIONS
(RADIAL BLADE TYPE ONLY)

Case	Fan parameters			Possible causes
	Calculated ΔP_{sp} at 70°F	Calculated Amps at 70°F	Fan wheel R.P.M.	
1	Decreased	Decreased	Decreased	Operator decreased R.P.M.
2	Increased	Increased	Increased	Operator increased R.P.M.
3	Increased	Decreased	Unchanged	a) Filter blinding b) Filter cleaning problem c) Hopper overflow d) Scrubber bed pluggage e) Decreased gas flow f) Damper partially closed
4	Decreased	Increased	Unchanged	a) Baghouse leaks b) Shortcircuiting c) Decrease in liquor flow d) Increase in gas flow e) Damper partially open

TABLE 4. FAN DATA, TEMPERATURE CORRECTION^a

Temp °F	Factor	Temp °F	Factor
20	0.91	320	1.47
40	0.94	340	1.51
60	0.98	360	1.55
80	1.92	380	1.59
100	1.06	400	1.62
120	1.09	420	1.66
140	1.13	440	1.70
160	1.17	460	1.74
180	1.21	480	1.77
200	1.25	500	1.81
220	1.28	520	1.85
240	1.32	540	1.89
260	1.36	560	1.92
280	1.40	580	1.96
300	1.43	600	2.00

^aAdapted from "Basic Energy/Environment Analysis", NAPA information series 67, by C. Heath, August 1978.

2. Present total system static pressure drop and changes since last Counterflow Inspection,
3. Changes in particulate emission levels since last stack test or Counterflow Inspection,
4. Present temperature of the effluent, and
5. Presence of cyclic or intermittent emissions.

Results of these five observations should provoke specific questions to guide the inspection of the control system.

When inspecting the control device and its auxiliary equipment, the inspector should proceed in a logical sequence to obtain the information needed for evaluating the performance. Detailed checklists (Appendix B) have been prepared for wet scrubbers, fabric filters, and ESP's. The general approach to all three is to use checklists as the inspector proceeds from the control room (if applicable) to the control device. These checklists are arranged to facilitate the inspection. The checklists include preliminary diagnostic sections (Tables 5-7) which are arranged according to commonly encountered problems.

For example, the ESP diagnostic sheet includes, but is not limited to:

1. Particle resistivity changes,
2. Insulator failures,
3. Broken discharge wires, and
4. Nonuniform gas distributions.

Under the each problem category is a list of readily observed symptoms and the relative importance of each as indicated by a rating factor. If the sum of the factors under any category is >10, there is a reasonable probability that a problem does exist; if so, further inspection and/or testing is needed and should be recommended in the inspection report.

In most plants, it will be impractical to observe every item listed in Figures 6-8 or to observe every symptom listed

TABLE 5. FABRIC FILTERS COUNTERFLOW INSPECTION DIAGNOSTIC SECTION

Possible Operating Problems	Average Baseline (Specify Value)	Observed (Specify Value)	Location ^a	Abnormal (Check)	Rating (1-10)	Recommended Action
A. Bag Tears or Pinholes						
1. Filter house pressure drop low (<80% avg.)	_____	_____	E	_____	3	If sum (Σ) of ratings is > 10, perform internal inspection. Check for deposits on filter house clean side. Check inaccessible bags. Use fluorescent dye technique. Check integrity of fabric by attempting to extend rips.
2. Opacity high	_____	_____	E	_____	5	
3. Bag age high (typical avg.)	_____	_____	E	_____	5	
4. Some bags inaccessible	N/A	N/A	I	_____	2	
5. Design A/C high (>120% avg.)	_____	_____	E	_____	4	
6. Actual A/C high (>120% avg.)	_____	_____	E	_____	4	
7. Wear plate eroded	N/A	N/A	I	_____	3	
8. Frequent high excursions	_____	_____	E or I	_____	4	
					Σ = _____	
B. Bag Blinding						
1. Filter house pressure drop high (>150% avg.)	_____	_____	E	_____	7	If sum (Σ) of ratings is >10, perform internal inspection. Check dirty side of bags for coatings (this may be difficult to identify in some cases). Check records for steady rise in filter house pressure drop. Reschedule inspection in near future.
2. Opacity low	_____	_____	E	_____	2	
3. Cleaning frequency high (cycles/day)	_____	_____	E	_____	5	
4. Gas temp low (<200°F avg.)	_____	_____	E	_____	4	
5. Moisture in gas stream	N/A	N/A	E	_____	4	
6. Particulate sticky	N/A	N/A	E	_____	4	
7. Air in-leakage (hoppers/access doors)	N/A	N/A	I	_____	2	
8. Unit not insulated	N/A	N/A	E	_____	2	
					Σ = _____	
C. Bag Bleeding						
1. Opacity high	_____	_____	E	_____	5	If sum (Σ) of ratings is >10, attempt to confirm uses of fluorescent dye and black light.
2. Pressure drop gradually increasing	_____	_____	E	_____	2	
3. Cleaning frequency high	_____	_____	E	_____	5	
					Σ = _____	

(Continued)

^aLocation: E is external, and I is internal.

TABLE 5 (Continued)

Possible Operating Problems	Average Baseline (Specify Value)	Observed (Specify Value)	Location*	Abnormal (Check)	Rating (1-10)	Recommended Action
D. <u>Cleaning System</u>						
1. Filter house pressure drop high	_____	_____	E	_____	5	If sum (Σ) of ratings is >10 , perform internal inspection and check deposits on dirty side of bags. Check bag tension. Reschedule inspection in near future.
2. Pulse-jet air header pressure low	_____	_____	E	_____	5	
3. Solenoids inoperative	N/A	N/A	E or I	_____	10	
4. Reverse air fan inoperative	N/A	N/A	E or I	_____	10	
5. Shaker motor inoperative	N/A	N/A	E or I	_____	10	
6. Bag length long	_____	_____	E	_____	2	
7. Equipment inaccessible	N/A	N/A	I	_____	2	
8. High intensity cleaning required	_____	_____	E	_____	2	
					$\Sigma =$ _____	
E. <u>Hopper</u>						
1. Filter house pressure drop high	_____	_____	E	_____	5	If sum (Σ) of ratings is >10 , perform internal inspection of hoppers.
2. Solids-removal run intermittent	N/A	N/A	E	_____	3	
3. Indicator level existent and/or inoperative	N/A	N/A	E	_____	2	
4. Heaters nonexistent and/or inoperative	N/A	N/A	E	_____	2	
5. Vibrators nonexistent and/or inoperative	N/A	N/A	E	_____	2	
6. Hopper valves corroded	N/A	N/A	I	_____	3	
7. Hopper slope $<60^\circ$	N/A	N/A	E	_____	2	
8. Hoppers not insulated	N/A	N/A	E	_____	2	
9. Winter	N/A	N/A	E	_____	2	
10. Hammer markings on hopper walls	N/A	N/A	E	_____	2	
11. Conveyor inoperative	N/A	N/A	E	_____	10	
					$\Sigma =$ _____	

*Location: E is external, and I is internal.

TABLE 6. SCRUBBERS COUNTERFLOW INSPECTION DIAGNOSTIC SECTION

Possible Operating Problems	Average Baseline (Specify Value)	Observed (Specify Value)	Location*	Abnormal (Check)	Rating (1-10)	Recommended Action
A. <u>No Liquor Flow</u>						
1. Pumps are inoperative	N/A	Yes, No	E	_____	10	If sum (Σ) of ratings ≥ 10 , request immediate correction action, and/or stack test.
2. Inlet and outlet gas temps same	N/A	N/A	E	_____	10	
3. Opacity high	_____	_____	E	_____	5	
4. Scrubber pressure drop low	_____	_____	E	_____	5	
5. Nozzles plugged	N/A	Yes, No	I	_____	7	
				$\Sigma =$ _____		
B. <u>Low Liquor Flow</u>						
1. Nozzle operating pressure (<80% avg.)	_____	_____	E	_____	3	If sum (Σ) of ratings is ≥ 10 , attempt to measure exit water flow rate to confirm conclusions. Request stack test.
2. Gas temp high (10% above avg.)	_____	_____	E	_____	3	
3. Opacity high	_____	_____	E	_____	5	
4. Recirculation liquor pH low (<5)	_____	_____	E	_____	3	
5. Flow rate monitor value low (<80% avg.)	_____	_____	E	_____	7	
6. Scrubber pressure drop low (<80% avg.)	_____	_____	E	_____	3	
7. Exit water temp high (>20% above avg.)	_____	_____	E	_____	3	
				$\Sigma =$ _____		
C. <u>Gas Flow Rate High</u>						
1. Opacity high	_____	_____	E	_____	5	If sum (Σ) of ratings is ≥ 10 , check process equipment and production rate.
2. Outlet gas stream temp high (>20°F above avg.)	_____	_____	E	_____	5	
3. Exit water temp high (>20°F above avg.)	_____	_____	E	_____	5	
				$\Sigma =$ _____		

*Location: E is external, and I is internal.

(Continued)

TABLE 6 (Continued)

Possible Operating Problems	Average Baseline (Specify Value)	Observed (Specify Value)	Location*	Abnormal (Check)	Rating (1-10)	Recommended Action
D. Gas Flow Rate High						
1. Opacity high	_____	_____	E	_____	5	If sum (Σ) of ratings is >10 , check process equipment and production rate. Request stack test if problem is serious.
2. Temp of outlet gas low ($>20^{\circ}\text{F}$ below avg.)	_____	_____	E	_____	5	
3. Temp of exit liquor low ($>20^{\circ}\text{F}$ below avg.)	_____	_____	E	_____	5	
4. Scrubber pressure drop low ($<80\%$ avg.)	_____	_____	E	_____	5	
					$\Sigma =$	
E. Bed Plugging						
1. Scrubber pressure drop high ($>40\%$ above avg.)	_____	_____	E	_____	5	If sum (Σ) of ratings is >10 , check for bypassing of effluent around scrubber. Request immediate corrective action.
2. Liquor turbidity high	N/A	N/A	E	_____	5	
3. Liquor pH high (>8)	_____	_____	E	_____	5	
					$\Sigma =$	
F. Nozzle Erosion						
1. Nozzle operating pressure drop low ($<80\%$ avg.)	_____	_____	E	_____	5	If sum (Σ) of ratings is >10 , recommend nozzle replacement.
2. Opacity high	_____	_____	E	_____	3	
3. Liquor turbidity high	N/A	N/A	E	_____	3	
4. Corrosive liquor	N/A	N/A	E	_____	3	
5. Nozzles unchanged in 6 months	N/A	N/A	E	_____	3	
6. Nozzles operable	N/A	N/A	I	_____	10	
					$\Sigma =$	

*Location: E is external, and I is internal.

(Continued)

TABLE 6 (Continued)

Possible Operating Problems	Average Baseline (Specify Value)	Observed (Specify Value)	Location*	Abnormal (Check)	Rating (1-10)	Recommended Action
G. <u>Demister</u>						
1. No water flow to demister	_____	_____	I	_____	5	If sum (Σ) of ratings is >10, check for changes in production rate. Reschedule inspection in near future in anticipation of fan unbalance problem.
2. Gas velocity high (>10 ft. per second)	_____	_____	E	_____	10	
3. Fan vibrating	_____	_____	E	_____	5	
					$\Sigma =$ _____	
H. <u>Venturi Throat Adjustment</u>						
1. Scrubber pressure drop low (<80% avg.)	_____	_____	E	_____	4	If sum (Σ) of ratings is >10, request corrective action immediately or request stack test.
2. Visible evidence of changes	N/A	N/A	E	_____	4	
3. Opacity high	_____	_____	E	_____	4	
					$\Sigma =$ _____	
I. <u>Impingement Plate or Tray Collapse</u>						
1. Pressure drop low (<80% avg.)	_____	_____	E	_____	4	If sum (Σ) of ratings is >10, attempt internal inspection.
2. Opacity high	_____	_____	E	_____	4	
3. Build-up of liquor in sump	N/A	N/A	I	_____	4	
					$\Sigma =$ _____	
J. <u>In-leakage of Air</u>						
1. Temp of gas stream low	_____	_____	E	_____	5	If sum (Σ) of ratings is >10, attempt internal inspection.
2. Obvious shell corrosion	N/A	N/A	I	_____	5	
					$\Sigma =$ _____	

*Location: E is external, and I is internal.

TABLE 7. ELECTROSTATIC PRECIPITATORS COUNTERFLOW INSPECTION DIAGNOSTIC SECTION

Possible Operating Problems	Average Baseline (Specify Value)	Observed (Specify Value)	Location*	Abnormal (Check)	Rating (1-10)	Recommended Action
I. ELECTRICAL						
A. Particle Resistivity						
1. Peak voltage low (down 5-10 kv)	_____	_____	E	_____	5	If sum (Σ) of ratings is ≥ 10 , request in-situ resistivity test and check sulfur content of fuel, moisture content of gas, and temperature of gas.
2. Rapping intensity increased	_____	_____	E	_____	5	
3. Temp changed (+50°F)	_____	_____	E	_____	3	
4. Spark rate increased (+50 sparks/min)	_____	_____	E	_____	5	
5. Opacity high	_____	_____	E	_____	6	
6. Coal sulfur content low (<1.0%)	_____	_____	E	_____	6	
					$\Sigma =$ _____	
B. Transformer-Rectifier Set Problems						
1. No secondary current	N/A	N/A	E	_____	10	If sum (Σ) of ratings is ≥ 10 , request repair.
2. No penthouse purge	N/A	N/A	E	_____	2	
3. Voltage zero, current high	N/A	N/A	E	_____	10	
4. Opacity high	_____	_____	E	_____	6	
					$\Sigma =$ _____	
C. Insulator Failure						
1. Peak voltage low	_____	_____	E	_____	5	If sum (Σ) of ratings is ≥ 10 , request repair.
2. Penthouse purge (not used)	N/A	N/A	E	_____	5	
3. Penthouse temp high (+20°F)	_____	_____	E	_____	3	
4. Opacity high	_____	_____	E	_____	6	
5. Cracks visible	N/A	N/A	I	_____	10	
					$\Sigma =$ _____	

(Continued)

*Location: E is external, and I is internal.

TABLE 7 (Continued)

Possible Operating Problems	Average Baseline (Specify Value)	Observed (Specify Value)	Location*	Abnormal (Check)	Rating (1-10)	Recommended Action
D. Broken Discharge Wires						
1. Deposits on wires	N/A	N/A	I	_____	5	If sum (Σ) of ratings is ≥ 10 , request repair.
2. Violent meter fluctuating	N/A	N/A	E	_____	10	
3. Hopper level indicator not used	N/A	N/A	E	_____	2	
4. Spark rate high (± 50 sparks/min)	_____	_____	E	_____	5	
5. Opacity high	_____	_____	E	_____	3	
6. Broken discharge wires	N/A	N/A	I	_____	10	
					$\Sigma =$ _____	
II. GAS FLOW						
A. Excessive Velocity						
1. Flow rate high	_____	_____	E	_____	5	If sum (Σ) of ratings is ≥ 10 , check production and/or generator rate.
2. Voltages high, currents low	_____	_____	E	_____	5	
3. Opacity high	_____	_____	E	_____	5	
					$\Sigma =$ _____	
B. Nonuniform Distribution						
1. Flow rate increased	_____	_____	E	_____	2	If sum (Σ) of ratings is ≥ 10 , request velocity traverse.
2. Secondary currents nonparallel	N/A	N/A	E	_____	5	
3. Hopper levels differences on parallel branches	_____	_____	I	_____	5	
4. Rappers on distribution plates not used	N/A	N/A	E or I	_____	3	
					$\Sigma =$ _____	

*Location: E is external, and I is internal.

(Continued)

TABLE 7 (Continued)

Possible Operating Problems	Average Baseline (Specify Value)	Observed (Specify Value)	Location*	Abnormal (Check)	Rating (1-10)	Recommended Action
III. MECHANICAL						
A. Rapper Problems						
1. Puffs visible	N/A	N/A	E	_____	5	If sum (Σ) of ratings is >10, request internal inspection by plant personnel. Request inten sity measurement, if appropriat
2. Peak voltage changed, secondary current constant	_____	_____	E	_____	5	
3. Spark rate changed	_____	_____	E	_____	3	
4. Low sulfur coal used	_____	_____	E	_____	3	
5. Dust sticky	N/A	N/A	E	_____	3	
					Σ = _____	
B. Hopper Solids Removals						
1. Broken discharge wires	N/A	N/A	I	_____	5	If sum (Σ) of ratings is >10, request internal inspection and/or changes in operational practices.
2. Mass loading probably increased	N/A	N/A	E	_____	5	
3. Nonuniform gas distri- bution	N/A	N/A	E	_____	3	
4. Hoppers not emptied continuously	N/A	N/A	E	_____	5	
5. Level indicators not used	N/A	N/A	E	_____	3	
6. Heaters not used	N/A	N/A	E	_____	2	
7. Vibrators not used	N/A	N/A	E	_____	2	
8. Hoppers not insulated	N/A	N/A	E	_____	2	
9. Corrosion around out- let valves	N/A	N/A	I	_____	3	
10. Hopper slope <60°	N/A	N/A	E	_____	3	
11. Hoppers full or bridged	N/A	N/A	I	_____	10	
					Σ = _____	

*Location: E is external, and I is internal.

(Continued)

TABLE 7 (Continued)

Possible Operating Problems	Average Baseline (Specify Value)	Observed (Specify Value)	Location*	Abnormal (Check)	Rating (1-10)	Recommended Action
III. MECHANICAL (continued)						
C. <u>Collection Plate Warp and Malalignment</u>						
1. Change in air load	<u>N/A</u>	<u>N/A</u>	E	<u> </u>	5	If sum (Σ) of ratings is ≥ 10 , request alignment check.
2. Repeated hopper over- flow	<u>N/A</u>	<u>N/A</u>	E or I	<u> </u>	3	
3. Air in-leakage	<u>N/A</u>	<u>N/A</u>	E	<u> </u>	3	
4. Malalignment visible	<u>N/A</u>	<u>N/A</u>	I	<u> </u>	10	
					$\Sigma =$ <u>10</u>	
IV. EFFLUENT CHARACTERISTICS						
A. <u>Mass Loading Increases</u>						
1. Opacity high	<u> </u>	<u> </u>	E	<u> </u>	6	If sum (Σ) of ratings is ≥ 10 , check production and/or genera- tor rate.
2. Inlet section, secon- dary currents low	<u> </u>	<u> </u>	E	<u> </u>	5	
3. Hopper unloading fra- quency increases	<u> </u>	<u> </u>	E	<u> </u>	2	
					$\Sigma =$ <u>13</u>	

*Location: E is external, and I is internal.




Figure 6. Fabric filter inspection flowsheet.




Figure 7. Scrubber inspection flowsheet.




Figure 8. Electrostatic precipitator inspection flowsheet.

in Tables 5-7. This is why the diagnostic sheets are designed to reflect combinations of observations. In the extreme situation where there are essentially no equipment monitors and where access to components is restricted, the difficulty and limitations involved in performance evaluation should be noted in the inspection report.

During each stage of the control device evaluation, the inspector should compare the observed operating conditions with the baseline values obtained from compliance stack tests or from manufacturer's specifications. Deviations from site-specific baseline values are the best indicators of abnormal performances.

The following discussions of control devices do not extend to standard design methodology and operating procedures. It is assumed that the field inspector is familiar with most control devices and has performed in-plant inspections in the past.

4.4.1 Fabric Filters

Five major categories of fabric filter operating problems are listed in the left column of Table 5. Only one of these-- Bag Tears/Pinholes--causes immediate excess emissions. The others strain the fabric to the point that extensive repair and/or replacement is eventually necessary.

There are two basic approaches to the inspection of fabric filters. With the most common one, the unit is not shutdown during the inspection. The field inspector should decide if the observed performance symptoms call for a follow-up internal inspection and if a stack test should be recommended. With the second approach, the system can be shutdown (or compartments isolated one-by-one) long enough to perform the internal inspection. If the opacity observed in step 1 and/or step 2 is high and if the internals are accessible, we highly recommend proceeding along the right-hand path of Figure 6. Internal checks are the only truly reliable means for identifying fabric filter problems. Only if access to the unit is impossible

do we suggest the use of the indirect approach illustrated on the left of Figure 6; in this case, the inspector evaluates whether a return trip (when the unit is down) is justified.

Some of the symptoms on the diagnostic checklists are design factors. Fabric filter design is very significant with respect to long-term performance. Design deficiencies at any source should be checked routinely during each inspection.

4.4.2 Wet Scrubbers

To evaluate the performance of a wet scrubber, the PEDCo inspector should first confirm that the recirculation pump is operating. If there is no water/liquid circulating through the system, the inspector should recommend a follow-up inspection when the scrubber will be operational. If there is circulation, the inspector should proceed along the flow of water through the system (water flow is generally counter to gas flow).

Next, the inspector should confirm that the pumps are on, and if so, should read the flow meter (if any). In the line going to the spray nozzles, low pressure indicates erosion of the nozzles and likely increases in the water spray droplet size. If the line pressure does not change when the flow is temporarily shut off (the inspector must not adjust valves), the nozzles are plugged. Static pressure drop across each stage should be recorded, if possible, to help in problem diagnosis.

To complete the check of the water system, the inspector should measure the temperature and the pH of the sump liquor. It is advisable to take a liquor sample; however, the expense should not be incurred unless there are reasons to suspect operational and/or corrosion problems (chain-of-custody procedures must be followed). During the inspection, the integrities of the scrubber shell and the component parts should be routinely checked.

4.4.3 Electrostatic Precipitators

There are four problems which can affect the performance of an ESP:

1. Electrical,
2. Gas flow,
3. Mechanical, and
4. Effluent.

In each problem category, there are three to five symptoms which occur with reasonable frequency, but the observed symptoms do not often indicate a particular problem. Due to the complexity caused by the interfacing of these problems, it is important that the inspector use a combination of symptoms in identifying operational difficulties.

The checklist (Table 7) and the flowsheet (Figure 8) are logical approaches to the evaluation of an ESP. Unlike the comparable charts for fabric filters and wet scrubbers, those for an ESP include a preliminary flowcharting step for use if a diagram is not available, so that the electrical data can be simplified and understood.

The inspector should begin in the main control room (or the substation) where much of the electrical data can be obtained. Performance evaluation should include, but not necessarily be limited to:

1. Power density calculations,
2. Evaluation of parallel field secondary currents,
3. Evaluation of inlet field secondary currents,
4. Spark rate,
5. Hopper heater/vibrator operational status,
6. Penthouse purge fan operational status,
7. Hopper unloading frequency,
8. Rapper operational status, and
9. Rapper frequency in various locations.

We recommend that internal ESP inspections be done only when the inspector is accompanied by a company representative. Furthermore, the inspector should always wear a respirator, hard-hat, and gloves; should fully understand the lockout procedures used at the plant, and should strictly adhere to safety procedures due to the many potential hazards. A precipitator is essentially a giant capacitor.

Inside the unit, it is possible to identify many operating problems which are hard to diagnose otherwise. Particular attention should be given to:

1. Dust accumulation on turning vanes and distribution plates which can indicate and/or cause poor gas distribution and low particulate control efficiency;
2. Obvious corrosion which suggests in-leakage of air or operating below the acid dewpoint;
3. A full hopper which causes misalignment of the collection plates, which in turn can reduce collection efficiency;
4. Removal of a large number of discharge wires in a bus section which can indicate alignment problems and/or design deficiencies; and
5. Inadequate rapping of collection plates, and/or discharge wire.

Broken discharge wires can generally be located by checking for bottle weights hanging below the normal level.

At the end of step 4, the inspector decides whether or not the ventilation system and the process, itself, need to be inspected. If the operation and maintenance of the control system appear to be adequate and if there are no indications of changes in effluent characteristics (e.g., increased gas flow rates, smaller particle size distribution, higher temperature), the inspection should be terminated. Otherwise, the ventilation system (if applicable) and the process operations should be visited.

4.5 STEP 5: CHECK THE VENTILATION SYSTEM

To inspect the ventilation system, the inspector checks the capture velocities of hoods to the extent possible using the velometer. Factors which could cause inadequate capture efficiency include the following problems (partial list):

1. Inadequate hood design and location,
2. Thermal drafts,
3. Cross-drafts in the vicinity of the hood, and
4. Leaking of air into hoods and/or ducts within the system.

If the ductwork is accessible, the static pressures at various points should be inspected; furthermore, the physical conditions of ducts should be observed to locate leaks. Improper hood locations can account for drops in pollutant mass loading or for changes in particle size distributions. Releases of emissions to roof monitors or as fugitive material should be checked, especially for movable hoods.

4.6 STEP 6: EVALUATE PROCESS OPERATING CONDITIONS

The purpose of the process inspection is to answer questions and to confirm conclusions reached in earlier steps. However, if the source is subject to special state/local regulations or to New Source Performance Standards or to National Emission Standards for Hazardous Air Pollutants, compliance with recordkeeping and monitoring requirements should be checked first, using a DSSE-published series of documents which includes checklists and associated information.

The inspector can seek answers to questions which were derived from steps 1 through 5. The inspector addresses problems which could be individually or collectively responsible for nonoptimal performance, including, but not limited to:

1. Has the production rate increased (higher mass loading and/or gas flow rate)?

2. Have the raw materials and/or fuels changed to the extent that effluent characteristics are different?
3. Has the process equipment deteriorated to the extent that emissions are affected?
4. Have changes in operating conditions resulted in more difficult collection problems (particle size decreases)?

The process inspector should begin at the control centers where process monitors are located to look for signs of changes in operating conditions and to observe current operating/maintenance practices. At these centers, process operating data are available; a process flowsheet is generally posted on the control panel; plant operators are generally nearby; and the subdued noise level is conducive to technical discussions.

While in the control room, the inspector should seek out the process monitors and/or records most pertinent to the compliance questions. Example "inspection points" for six source types are in Table 2; several generalizations can be drawn from this table.

1. In most cases, the inspector can confirm increased production rate by using data available in the control room;
2. The inspector can confirm raw material changes by inspecting records kept either in the control room or in the administrative offices;
3. The inspector cannot easily confirm process operational changes;
4. For batch operations, it is necessary to observe the equipment since little useful information is available in the control room; and
5. For other processes, it is possible to identify changes in operating conditions, but the significance of the changes is hard to determine.

Follow-up questions remaining after the inspection of records and monitors in the control room can be quite time consuming due to the cyclic processes and to distances between inspection

points at large plants. The follow-up can be guided by the items listed in Table 8, but the inspector is encouraged to develop more extensive lists for specific plants. The presence of fugitive emissions should be noted.

TABLE 8. EXAMPLE INSPECTION POINTS, COUNTERFLOW INSPECTION PROCEDURES

Type of Industry/Source	Inspection in the Office and/or Control Room	Inspection of Specific Equipment
<u>1. Confirm the Rates of Production and/or Generation</u>		
Sulfuric acid	Check acid production records, and observe acid flow rate indicator.	N/A
Asphalt	N/A	Observe number of batches shipped per hour of plant operation.
Utility or industrial boiler	Check megawatt generation and steam production rates.	N/A
Cement	Check raw material feed rate records.	N/A
Refinery	Check throughput records on catalytic cracker.	N/A
<u>2. Confirm Raw Material Changes</u>		
Asphalt	N/A	Perform lab tests to determine coal gradation and surface moisture percentage.
Utility or industrial boiler	Check daily records of analyses: % ash, %S, Btu content, ash fusion temp.	Take sample for later analyses.
Sulfuric acid	Check records of feed content; high levels contribute acid mist.	N/A
Refinery	Check production inventory records.	N/A

TABLE 8 (Continued)

Type of Industry/Source	Inspection in the Office and/or Control Room	Inspection of Specific Equipment
3. <u>Confirm Process Operational Changes</u>		
Sulfuric acid	Check catalyst bed temp and air flow rate to catalyst bed if SO ₂ monitor values are high. Check acid concentration temp and flow to absorbers.	N/A
Secondary brass and bronze	Check records for percentage of zinc in alloy and for pouring temp.	Check for grease and oil on scrap and for operational practices such as maintenance integrity of slag load. Check hood caption velocity in furnace area. Determine if zinc is added before furnace temp is maximum.
Utility or industrial boiler	Check air preheater exit temperatures.	N/A
4. <u>Confirm Process Equipment Deterioration</u>		
Sulfuric acid	Observe SO ₂ concentration monitors; check for inactive or poisoned catalyst if SO ₂ is high.	Check pressure drop across mist eliminator. If low, check for shortcircuiting; if high, check for plugging.
Secondary brass and bronze	N/A	Check hoods and ductwork for physical damage and caption velocity.
Utility or industrial boiler	Check excess air level by means of O ₂ readings.	Check to see if stoker boiler draft above fuel beds has >0.10" negative pressure.
Refinery	N/A	Observe flow rate.

SECTION 5

POST-INSPECTION

5.1 PLANT INTERVIEW

Having evaluated the exhaust system, monitoring equipment, control systems, and possibly the process itself, the inspector should meet with a responsible plant official to:

1. Ask follow-up questions as necessary,
2. Review inspection notes so that there is general agreement on the technical facts, and
3. Discuss need for followup inspection or additional records.

5.2 FILE UPDATE AND REPORT PREPARATION

All appropriate file entries should be changed as necessary. The conclusions of the inspector, based on observations and calculations, should be clearly stated in a concise paragraph in the inspection report which should also include two sheets--the control device diagnostic checklist and a coverpage (Table 9)--with the following information:

- Any change in responsible plant personnel,
- Requested permit changes or reported process modifications,
- Results of Counterflow evaluation,
- Action requested,
- Inspector's signature, and
- Date of inspection.

A copy of both sheets should be kept in the inspector's source file and in the agency's central file.

SECTION 6

SAFETY CONSIDERATIONS

The field inspector should take any precautions necessary to absolutely ensure that the inspection is conducted safely. All applicable OSHA regulations should be satisfied. If there is any question whether all or part of the inspection can be done safely, that part should be delayed until the issue is adequately resolved.

There are several principles which should be obeyed during a field inspection, namely:

1. Prior to the inspection, the files should be reviewed to assess possible hazards. Consult references, such as the Pocket Guide of Industrial Hazards and Occupational Diseases, a Guide to Their Recognition;
2. The inspection should bring all necessary safety equipment (in good working order);
3. Safety equipment should be worn whenever necessary regardless of the practices of plant personnel;
4. The inspector should proceed with the inspection at a controlled pace so there is time to fully assess possible hazards and so foolish accidents do not occur;
5. Inspectors should not work alone. If plant personnel are not available or willing to accompany the inspector, then the inspector should wait until additional help is available from the agency or the company;
6. Prior to any confined space entry, the inspector should read Appendix C, and follow the recommendations completely;

7. Physical examinations should be completed annually;
8. Accidents should be reported to supervisory personnel immediately, regardless of the suspected severity of the injury;
9. Lock-out procedures should be followed completely;
10. Entry to electrostatic precipitators should not be done until grounding hooks have been used in all areas to be inspected;
11. Hoppers full of material should never be opened or entered by the inspector; and
12. Fans vibrating severely should be avoided and plant personnel should be notified immediately.

A field inspector cannot afford to under-estimate potential hazards. The inspector is inherently exposed on a regular basis to a wide variety of hazards and does not have the opportunity to acquaint himself or herself with the details of each plant. For these reasons, it is particularly important that the inspector adhere to the basic principles outlined above. It should also be realized that these are simply a starting point and other precautions will be needed in most circumstances.

TABLE 9. CONTROL DEVICE DIAGNOSTIC CHECKLIST AND COVERPAGE

INSPECTION REPORT

REPORT NUMBER _____

PLANT NAME _____

PLANT I.D. _____

SPECIAL ACTION RECOMMENDED (Yes) (No) _____

I. GENERAL INFORMATION

A. Sources Inspected _____ Production Status _____

B. Reasons for Inspection (Check Appropriate Items)

Routine Inspection _____	Compliance Progress _____
Complaint Investigation _____	Permit Review/Renewal _____
Stack Testing Observed _____	Tax Certification _____
Special Studies _____	Emergency Episode _____
Other _____	Equipment Malfunction _____

C. Plant Representative Contacted (Name and Title) _____

D. Inspection Procedures and Conditions

Prior Notice (Check One) Yes _____ No _____

Time/Date _____ Duration On-Site _____

Type Inspection (Check One) Counterflow _____ Follow-Up _____

Other _____

Weather _____ Wind Direction _____

II. PRE-INSPECTION INTERVIEW

A. Production Status: Normal _____ Abnormal _____

B. Control Equipment: Normal _____ Abnormal _____

C. Permit/Compliance Schedule Changes Needed: Yes _____ No _____

D. Comments _____

(continued)

TABLE 9. (continued)

Report Number		
III. INSPECTION RESULTS		
A. General Conclusions		
All Sources in Compliance with:		
Mass Emission Regulations:	Yes _____ No _____ N/A _____	
Visible Emission Regulations:	Yes _____ No _____ N/A _____	
Fuel Quality Regulations:	Yes _____ No _____ N/A _____	
Continuous Monitoring Regulations:	Yes _____ No _____ N/A _____	
Sampling/Testing Requirements:	Yes _____ No _____ N/A _____	
Recordkeeping Requirements:	Yes _____ No _____ N/A _____	
Permit Stipulations:	Yes _____ No _____ N/A _____	
Special Orders:	Yes _____ No _____ N/A _____	
O&M Practices:	Good _____ Average _____ Poor _____	
Housekeeping:	Good _____ Average _____ Poor _____	
B. Specific Conclusions		
Compliance Questionable Due To:		
Changes in Raw Materials and/or Fuels _____		
Production Rates Increases _____		
Operational Changes in Process _____		
Deterioration of Process Equipment _____		
Operational Problems in Control Equipment (Check Appropriate Items Below)		
Electrostatic Precipitators	Fabric Filters	Wet Scrubbers
Resistivity _____	Tears/Pinholes _____	Low Liquor Flow _____
TR Sets _____	Blinding _____	Gas Flow Rate Low _____
Insulators _____	Bleeding _____	Bed Plugging _____
Discharge Wires _____	Cleaning System _____	Nozzle Erosion _____
High Velocity _____	Hopper Overflow _____	Demisters _____
Gas Distribution _____	Corrosion _____	Throat Adjustment _____
Rappers _____		Tray Collapse _____
Solids Handling _____		Corrosion _____
Plate Warpage _____		
Mass Overload _____		
Other _____		
C. Samples Taken (Describe) _____		

D. Comments/Recommended Action _____		

Inspector _____ Date _____		
Reviewer _____ Date _____		

APPENDIX A
(See Working File Handout)

APPENDIX B
(Sample Inspection Data Sheets)



PEDCO ENVIRONMENTAL
INSPECTION DATA SHEET

A. INSPECTION INFORMATION

1. IDENTIFICATION

Company _____
Plant Name _____
Plant I.D. Number _____
Address _____

Control Device/System Number _____
Process Served _____

2. PROCEDURES AND CONDITIONS

Prior Notice: Yes _____ No _____
Time(s) On-Site _____

Type Inspection _____

Inspectors _____

Plant Representatives _____

Information Claimed Confidential: Yes _____ No _____

B. Visible Emissions
Observations

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. STACK CHARACTERISTICS

Location _____

Height _____

Temperature _____

Exit Dimensions _____

Orientation _____

Other Information _____

2. STACK EFFLUENT

Detached Plume: No _____ Yes _____ Distance _____

Color _____

Puffing: Yes _____ No _____

Opacity

<u>Time</u>	<u>Average Opacity</u>	<u>Observation Point</u>	<u>Sheet No.</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

3. FUGITIVE EMISSIONS

Control Device: Yes _____ No _____

Solids Removal System: Yes _____ No _____

Process: Yes _____ No _____

Continuous _____ Intermittent _____

Adjacent Deposits: Yes _____ No _____

C. Fan Data

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. FAN MOTOR

Manufacturer _____

Model No. _____ Type _____

Rated Horsepower _____

Volts _____ Maximum Amps _____

Maximum R.P.M. _____ Service factor _____

Operating Current: Panel _____ Other _____

2. DRIVE

Direct _____ Belt _____ Other _____

Sheath Reduction _____

Audible Belt Slippage: Yes _____ No _____

3. FAN

Manufacturer _____

Model No. _____ Type _____

Fan Vibration _____

Gas Temperature at inlet, °F _____

Fan R.P.M. _____

Fan Static Pressures: Inlet _____ Outlet _____

Differential Static Pressures: Measured _____ Panel _____

Fan Housing Condition _____

Dampers _____

Fan Exit _____

**D. Electrostatic Precipitator
Data**

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. DESCRIPTIVE INFORMATION

Type _____

Manufacturer _____

Model Number _____

Plant Inventory Number _____

Date Installed _____

Number of Chambers _____

Number of Fields in Series _____

Specific Collection Area ($\text{Ft}^2/1000 \text{ Ft}^3$) _____

Design Superficial Viscosity (Ft/Sec) _____


Pulse Energization (Yes/No) _____

2. LOCATION

Building/Area _____

Elevation _____

3. LAYOUT (SKETCH FIELD LAYOUT AND NUMBER FIELDS, SHOW FANS)



E. Electrostatic Precipitator External Inspection

Inspection No. _____

Equipment No. _____

Confidential: Yes No

Page No. _____ of _____

1. HOPPER LAYOUT (SKETCH TOP VIEW AND NUMBER; SHOW SOLIDS HANDLING SYSTEM)

A full-page view of a blank sheet of white graph paper. The grid consists of thin black horizontal and vertical lines forming small squares. There are approximately 20 columns and 20 rows visible on the page.

- ## 2. HOPPER DESCRIPTION

Vibrators: Yes _____ No _____

Heaters: Yes No

Insulation: Yes No

Level Indicators: Yes _____ No _____ Type _____

Physical Condition (Characterize)

Transport Equipment: Screws Pneumatic Other

Transport Equipment Operating: Yes ☐ No ☐

Characterize Discharge

E. Electrostatic Precipitator
External Inspection

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____


3. HOPPER VALVES

Type: Screw _____ Other _____

Speed/Cycle Times _____

Blade Type _____

4. RAPPER LAYOUT (SKETCH TOP VIEW, SHOW DISCHARGE WIRE UNITS AS D,
COLLECTION PLATE UNITS AS C AND DISTRIBUTION PLATE UNITS AS X).



E. Electrostatic Precipitator
External Inspection

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

5. RAPPER PERFORMANCE (Continued)

COLLECTION PLATE RAPPERS

No.	Time Interval (Minutes)	Duration (Seconds)	Comments
C ₁			
C ₂			
C ₃			
C ₄			
C ₅			
C ₆			
C ₇			
C ₈			
C ₉			
C ₁₀			
C ₁₁			
C ₁₂			
C ₁₃			
C ₁₄			
C ₁₅			
C ₁₆			
C ₁₇			
C ₁₈			
C ₁₉			
C ₂₀			

E. Electrostatic Precipitator
External Inspection

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

5. RAPPER PERFORMANCE

DISCHARGE WIRE RAPPERS

No.	Time Interval (Minutes)	Duration (Seconds)	Comments
D ₁			
D ₂			
D ₃			
D ₄			
D ₅			
D ₆			
D ₇			
D ₈			
D ₉			
D ₁₀			
D ₁₁			
D ₁₂			
D ₁₃			
D ₁₄			
D ₁₅			
D ₁₆			
D ₁₇			
D ₁₈			
D ₁₉			
D ₂₀			

E. Electrostatic Precipitator
External Inspection

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

5. RAPPER PERFORMANCE (Continued)

DISTRIBUTION PLATE RAPPERS

No.	Time Interval (Minutes)	Duration (Seconds)	Comments
X ₁			
X ₂			
X ₃			
X ₄			
X ₅			
X ₆			

6. RAPPER DESCRIPTION

DISCHARGE WIRES

Type _____

Number _____

Manufacturer _____

Air Pressure _____

COLLECTION PLATES

Type _____

Number _____

Manufacturer _____

Air Pressure _____

DISTRIBUTION PLATES

Type _____

Number _____

Manufacturer _____

Air Pressure _____

E. Electrostatic Precipitator
External Inspection

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

9. TRANSFORMER - RECTIFIER SET CONDITIONS

No.	Primary current (amperes)	Primary voltage (volts)	Secondary current (milliamps)	Secondary voltage (kilovolts)	Spark rate #/min	Control mode M-manual A-automatic
T-R-1a						
T-R-1b						
T-R-2a						
T-R-2b						
T-R-3a						
T-R-3b						
T-R-4a						
T-R-4b						
T-R-5a						
T-R-5b						
T-R-6a						
T-R-6b						
T-R-7a						
T-R-7b						
T-R-8a						
T-R-8b						
T-R-9a						
T-R-9b						
T-R-10a						
T-R-10b						

E. Electrostatic Precipitator
External Inspection

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

10. OPERATING INFORMATION

Gas Inlet Temperature, °F _____

Hopper Heater Operational Indicator Lights (Identify units not on) _____

Penthouse Heater/Blower Operational Indicator Lights (Identify units not on) _____

Comments _____

11. OPACITY MONITORS

Opacity - Minimum, % _____

Average, % _____

Maximum, % _____

Spikes (Characterize Frequency, Duration, Intensity) _____

Calibration Spikes (Characterize Levels, Frequency) _____

Comments _____

F. Electrostatic Precipitator Internal Inspection

Inspection No. _____

Equipment No. _____

Confidential: Yes_____ No_____

Page No. _____ of _____

1. PURPOSE

Reason(s) Necessary _____

SAFETY EVALUATION

Lockout Procedure Followed:

Plant Employee Performing Lockout

Grounding Straps Available: Yes No

Time Period De-energized (Hours) _____

Purge Completed: Yes _____ No _____

O_2 , % _____

Combustibles, %

Noise _____

Other _____

Inspection Not Conducted Due to Potential Hazards (Characterize)

2. AREAS INSPECTED (SKETCH TOP VIEW AND INDICATE ENTRY POINTS)

[illegible]

**F. Electrostatic Precipitator
Internal Inspection**

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page _____ of _____

3. HATCH CONDITIONS

Gaskets _____

Corrosion _____

4. PENTHOUSE CONDITIONS

Purge Air _____

Heater(s) _____

Insulators _____

Alignment of Collection Plates _____

Comments _____

**F. Electrostatic Precipitator
Internal Inspection**

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

**5. ELECTRODE CONDITIONS
DISCHARGE WIRES**

Type _____

Diameter _____

Material _____

Spacing and Length _____

Conditions _____

COLLECTION PLATES

Type _____

Material _____

Spacing and Length _____

Conditions _____

Alignment _____

**F. Electrostatic Precipitator
Internal Inspection**

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

6. INTERNAL SUPPORTS

Describe _____

Conditions _____

7. GAS DISTRIBUTION EQUIPMENT

Type _____

Condition _____

8. HOPPERS

Baffle Condition _____

Hopper Condition _____

G. Continuous Monitor Evaluation

Inspection No. _____

Equipment No. _____

Confidential: Yes No

Page No. _____ of _____

1. DESCRIPTIVE DATA

Manufacturer _____

Model

Type _____

Date Installed _____

Single or Multiple Breeching (Describe Sources)

NSPS Applicable: Yes _____ No _____

2. TRANSMISSOMETER

LAYOUT (SHOW LOCATION RELATIVE TO FLOW RESTRICTIONS)

A full-page view of a blank sheet of white graph paper. The grid consists of thin black horizontal and vertical lines forming small squares. There are approximately 20 columns and 20 rows visible. A faint, light gray rectangular border is present around the perimeter of the page.

G. Continuous Monitor Evaluation

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

2. TRANSMISSOMETER (Continued)

Approximate Path Length, (Feet) _____

Mounting (Characterize) _____

Vibration (Characterize) _____

Housing (Characterize) _____

Purge Air (Condition of Blowers and Hoses) _____

Filters (Characterize Type and Describe Condition) _____

Alignment (Window Check) _____

3. CONSOLES

Breeching/Stack Correlation _____

Zero/Span _____

Comments _____

**H. Electrostatic Precipitator
Evaluation**

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. FILES/ADMINISTRATIVE

Specification Sheets Available: Yes _____ No _____

Prints Available (Characterize) _____

Supervisor of Unit _____

O and M Personnel (Describe Staff and Organization) _____

2. RECORDKEEPING

Type Records _____

Operating Records (List Parameters) _____

Diagnostic Records (Characterize) _____

3. PROCEDURES

Spare Parts Inventory (Characterize) _____

O&M Plan (Characterize) _____

Troubleshooting (Characterize) _____

I. Samples

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. Solids

Sample No. _____

Location Obtained _____

Date/Time Obtained _____

Results _____

2. Other Samples

Sample No. _____

Location Obtained _____

Date/Time Obtained _____

Permeability _____

Tensile Strength _____

Count _____

Weight/Yard² _____

3. Other _____

**J. Electrostatic Precipitator
Evaluation**

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. POWER INPUT

Collection Plate Area/Field

Inlet _____

Other _____

Discharge Wire Length/Field

Inlet _____

Other _____

Field	Secondary Currents (Milliamps)	Power Input (Watts)	Current Densities	
			(Milliamps/Ft)	Watts/Ft ²
1.	_____	_____	_____	_____
2.	_____	_____	_____	_____
3.	_____	_____	_____	_____
4.	_____	_____	_____	_____
5.	_____	_____	_____	_____
6.	_____	_____	_____	_____
7.	_____	_____	_____	_____
8.	_____	_____	_____	_____
9.	_____	_____	_____	_____
10.	_____	_____	_____	_____
11.	_____	_____	_____	_____
12.	_____	_____	_____	_____
13.	_____	_____	_____	_____
14.	_____	_____	_____	_____
15.	_____	_____	_____	_____

K. Process

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. PROCESS TYPE

Characterize Source _____

Operating Schedule _____

2. OPERATION

Product Type During Inspection _____

Production Data During Inspection _____

Raw Materials During Inspection _____

Fuels During Inspection _____

L.Summary

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page _____ of _____

1. POWER INPUT _____

2. MECHANICAL _____

3. SOLIDS REMOVAL _____

4. EFFLUENT QUANTITY/CHARACTERISTICS _____

5. OTHER _____

6. SHEETS

A. _____ B. _____ C. _____

D. _____ E. _____ F. _____

G. _____ H. _____ I. _____

J. _____ K. _____

Preparer: Name _____ Signature _____

Date _____

Reviewer: Name _____ Signature _____

Date _____

Copy Received: Initials _____ Date _____



PEDCo ENVIRONMENTAL
INSPECTION DATA SHEET

A. INSPECTION INFORMATION

1. IDENTIFICATION

Company _____

Plant Name _____

Plant I.D. Number _____

Address _____

Control Device/System Number _____

Process Served _____

2. PROCEDURES AND CONDITIONS

Prior Notice: Yes _____ No _____

Time(s) On-Site _____

Type Inspection _____

Inspectors _____

Plant Representatives _____

Information Claimed Confidential: Yes _____ No _____

B. Visible Emissions
Observations

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. STACK CHARACTERISTICS

Location _____

Height _____

Temperature _____

Exit Dimensions _____

Orientation _____

Other Information _____

2. STACK EFFLUENT

Detached Plume: No _____ Yes _____ Distance _____

Color _____

Puffing: Yes _____ No _____

Opacity

<u>Time</u>	<u>Average Opacity</u>	<u>Observation Point</u>	<u>Sheet No.</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

3. FUGITIVE EMISSIONS

Control Device: Yes _____ No _____

Solids Removal System: Yes _____ No _____

Process: Yes _____ No _____

Continuous _____ Intermittent _____

Adjacent Deposits: Yes _____ No _____

C. Fan Data

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. FAN MOTOR

Manufacturer _____

Model No. _____ Type _____

Rated Horsepower _____

Volts _____ Maximum Amps _____

Maximum R.P.M. _____ Service factor _____

Operating Current: Panel _____ Other _____

2. DRIVE

Direct _____ Belt _____ Other _____

Sheath Reduction _____

Audible Belt Slippage: Yes _____ No _____

3. FAN

Manufacturer _____

Model No. _____ Type _____

Fan Vibration _____

Gas Temperature at inlet, °F _____

Fan R.P.M. _____

Fan Static Pressures: Inlet _____ Outlet _____

Differential Static Pressures: Measured _____ Panel _____

Fan Housing Condition _____

Dampers _____

Fan Exit _____

D. Fabric Filter Data

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. DESCRIPTIVE INFORMATION

Fabric Filter Type _____

Manufacturer _____

Model No. _____

Plant Inventory No. _____

Date Installed _____

2. LOCATION

Building/Area _____

Inside _____ Outside _____

3. LAYOUT (SKETCH FABRIC FILTER, FAN, INLET, SOLIDS REMOVAL, ETC.).

This image shows a full page of blank graph paper. The grid consists of small, equal-sized squares formed by thin black lines. There are approximately 20 columns and 20 rows of squares across the page. The margins are consistent on all sides, leaving a narrow border around the grid area. The paper is otherwise completely empty, with no text or markings other than the grid lines.

**E. Fabric Filter External
Inspection**

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. SOLIDS REMOVAL

Valve Type: Rotary _____ Flapper _____ Other _____

Valve Speed/Frequency _____

Transport Equipment: Screws _____ Other _____

Transport Equipment Operating: Yes _____ No _____

Transport Equipment Discharging Solids: Yes _____ No _____

Characterize Discharge _____

Hopper Vibrators: Yes _____ No _____

Hopper Insulation: Yes _____ No _____

Hopper Level Indicators _____

Hopper Condition _____

Disposal Method _____

2. SHELL CONDITIONS

Insulated: Yes _____ No _____

Possible Weld/Seam Gaps, Characterize _____

**E. Fabric Filter External
Inspection**

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

3. OPERATING CONDITIONS

Static Pressure on Clean Side, _____ in. H₂O

Static Pressure on Dirty Side, _____ in. H₂O

On-site Monitor, Differential Static Pressure _____ in. H₂O

Tap Conditions _____

Gas Inlet Temperature _____ °F

4. CLEANING SYSTEMS

Type _____

Frequency _____

Air Pressure, _____ PSIG

Drier: Yes _____ No _____

Evidence of Water and/or Oil Problems _____

Solenoids Inoperative _____

5. PRECLEANERS

Type _____

Static Pressures: Inlet _____ Outlet _____ in. H₂O

Gas Inlet Temperature _____ °F

**F. Fabric Filter Internal
Inspection**

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. PURPOSE

Reason(s) Necessary

Inventory Check _____

Comprehensive Inspection _____

Other _____

Safety Evaluation (Describe if applicable)

Respirator Necessary _____

Temperature _____ °F

O₂ _____ %

Combustibles _____ %

Electrical Grounding _____

Mechanical Hazards _____

Noise _____

Other _____

Inspection Conducted: Yes _____ No _____

Inspection Not Performed Due to Safety _____

2. BAG LAYOUT (ATTACH DRAWING)

No. of bags _____

Length _____ ft

Diameter _____ in.

Material (Characterize) _____

Attachment(s) _____

**F Fabric Filter Internal
Inspection**

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

3. HATCH CONDITIONS

Gaskets _____

Corrosion _____

Bolts/Ears _____

Ease of Access _____

4. LEAK JETS

Location _____

Number _____

5. BAG CONDITIONS

**F. Fabric Filter Internal
Inspection**

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

6. HOPPERS AND BLAST PLATES

7. CLEANING APPARATUS

G Samples

Inspection No. _____

Equipment No. _____

Confidential: Yes ____ No ____

Page No. _____ of _____

1. SOLIDS DEPOSITS

Sample No. _____

Location Obtained _____

Date/Time Obtained _____

Results _____

2. FABRIC SAMPLES

Sample No. _____

Location Obtained _____

Date/Time Obtained _____

Permeability _____

Tensile Strength _____

Count _____

Weight/Yard² _____

3. OTHER

H Ventilation System

Inspection No. _____

Equipment No. _____

Confidential: Yes No

Page No. _____ of _____

1. DUCTS (SHOW STATIC PRESSURES ON LAYOUT.)

[illegible]

2. HOOD

Configuration

Average Capture Velocity _____ ft/min

Thermal Drafts (Characterize) _____

Cross Currents (Characterize)

Estimated Effectiveness	%
100%	100%
90%	90%
80%	80%
70%	70%
60%	60%
50%	50%
40%	40%
30%	30%
20%	20%
10%	10%
0%	0%

I Process

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. PROCESS TYPE

Characterize Source _____

Operating Schedule _____

2. OPERATION

Product Type During Inspection _____

Production Rate During Inspection _____

Raw Materials During Inspection _____

Fuels During Inspection _____

J Fabric Filter Evaluation

Inspection No. _____
 Equipment No. _____
 Confidential: Yes _____ No _____
 Page No. _____ of _____

Possible Operating Problems	Average Baseline (Specify Value)	Observed (Specify Value)	Location*	Abnormal (Check)	Rating (1-10)	Recommended Action
D. <u>Cleaning System</u>						
1. Filter house pressure drop high	_____	_____	E	_____	5	If sum (Σ) of ratings is >10, perform internal inspection and check deposits on dirty side of bags. Check bag tension. Reschedule inspection in near future.
2. Pulse-jet air header pressure low	_____	_____	E	_____	5	
3. Solenoids inoperative	N/A	N/A	E or I	_____	10	
4. Reverse air fan inoperative	N/A	N/A	E or I	_____	10	
5. Shaker motor inoperative	N/A	N/A	E or I	_____	10	
6. Bag length long	_____	_____	E	_____	2	
7. Equipment inaccessible	N/A	N/A	I	_____	2	
8. High intensity cleaning required	_____	_____	E	_____	2	
					$\Sigma =$	
E. <u>Hopper</u>						
1. Filter house pressure drop high	_____	_____	E	_____	5	If sum (Σ) of ratings is >10, perform internal inspection of hoppers.
2. Solids-removal run intermittent	N/A	N/A	E	_____	3	
3. Indicator level existent and/or inoperative	N/A	N/A	E	_____	2	
4. Heaters nonexistent and/or inoperative	N/A	N/A	E	_____	2	
5. Vibrators nonexistent and/or inoperative	N/A	N/A	E	_____	2	
6. Hopper valves corroded	N/A	N/A	I	_____	3	
7. Hopper slope <60°	N/A	N/A	E	_____	2	
8. Hoppers not insulated	N/A	N/A	E	_____	2	
9. Winter	N/A	N/A	E	_____	2	
10. Hammer markings on hopper walls	N/A	N/A	E	_____	2	
11. Conveyor inoperative	N/A	N/A	E	_____	10	
					$\Sigma =$	

*Location: E is external, and I is internal.

J Fabric Filter Evaluation

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

Possible Operating Problems	Average Baseline (Specify Value)	Observed (Specify Value)	Location*	Abnormal (Check)	Rating (1-10)	Recommended Action
A. Bag Tears or Pinholes						
1. Filter house pressure drop low (<80% avg.)	_____	_____	E	_____	3	If sum (Σ) of ratings is ≥ 10 , perform internal inspection. Check for deposits on filter house clean side. Check inaccessible bags. Use fluorescent dye technique. Check integrity of fabric by attempting to extend rips.
2. Opacity high	_____	_____	E	_____	5	
3. Bag age high (typical avg.)	_____	_____	E	_____	5	
4. Some bags inaccessible	N/A	N/A	I	_____	2	
5. Design A/C high (>120% avg.)	_____	_____	E	_____	4	
6. Actual A/C high (>120% avg.)	_____	_____	E	_____	4	
7. Wear plate eroded	N/A	N/A	I	_____	3	
8. Frequent high excursions	_____	_____	E or I	_____	4	
					$\Sigma =$ _____	
B. Bag Blinding						
1. Filter house pressure drop high (>150% avg.)	_____	_____	E	_____	7	If sum (Σ) of ratings is ≥ 10 , perform internal inspection. Check dirty side of bags for coatings (this may be difficult to identify in some cases). Check records for steady rise in filter house pressure drop. Reschedule inspection in near future.
2. Opacity low	_____	_____	E	_____	2	
3. Cleaning frequency high (cycles/day)	_____	_____	E	_____	5	
4. Gas temp low (<20°F avg.)	_____	_____	E	_____	4	
5. Moisture in gas stream	N/A	N/A	E	_____	4	
6. Particulate sticky	N/A	N/A	E	_____	4	
7. Air in-leakage (hoppers/access doors)	N/A	N/A	I	_____	2	
8. Unit not insulated	N/A	N/A	E	_____	2	
					$\Sigma =$ _____	
C. Bag Bleeding						
1. Opacity high	_____	_____	E	_____	5	If sum (Σ) of ratings is ≥ 10 , attempt to confirm uses of fluorescent dye and black light.
2. Pressure drop gradually increasing	_____	_____	E	_____	2	
3. Cleaning frequency high	_____	_____	E	_____	5	
					$\Sigma =$ _____	

*Location: E is external, and I is internal.

K Summary

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

1. CONTROL SYSTEM PERFORMANCE

System Air Flow Based on Fan Data _____ ACFM

System Air Flow Based on Pitot Traverse _____

System Air Flow Based on Process _____

Actual Air to Cloth Ratio _____

Design Air to Cloth Ratio _____

Fabric Compatibility with Environment _____

2. ADDITIONAL COMMENTS

3. SHEETS INCLUDED

A. _____ B. _____ C. _____ D. _____ E. _____ F. _____

G. _____ H. _____ I. _____ J. _____ K. _____

Preparer: Name _____ Signature _____

Date _____

Reviewer: Name _____ Signature _____

Date _____

Copies Received _____ Initials _____ Date _____

Fabric Filter Supplemental
Information

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____

Fabric Filter Supplemental
Information

Inspection No. _____

Equipment No. _____

Confidential: Yes _____ No _____

Page No. _____ of _____



PEDCO ENVIRONMENTAL
WET SCRUBBER INSPECTION DATA SHEET

LOCATION _____ DATA SHEET NO. _____
DESIGNATION _____ DATE _____
CLIENT _____ INSPECTOR(S) _____
PN _____ INSPECTION NO. _____
CLAIMED
CONFIDENTIAL Yes _____ No _____

A. DESCRIPTIVE INFORMATION

Wet Scrubber Type _____
Manufacturer _____
Model Number _____
Date Installed _____
Process/Source Controlled _____
Particulate Characteristics _____

B. COMPONENT INFORMATION (Describe if applicable)

1. Gas Pretreatment:

Presaturator _____
Cyclones _____
Settling Chamber _____
Other _____

2. Demister:

Cyclone _____
Chevron _____
Fibrous Mat _____
Other _____

3. Pumps:

Number _____
Recirculation _____
Pump Manufacturer _____
Recirculation _____
Pump Rated Horsepower _____
Recirculation Pump Type _____

Inspection No. _____

Data Sheet No. _____

Preparer _____

Confidential: Yes__ No__

B. COMPONENT INFORMATION (continued)

4. Fan/Motor (Specify)

Fan Manufacturer _____

Blade Type: Radial ____ Backward ____ Forward ____

Drive: Direct ____ Belt ____

Damper Position _____

Motor Manufacturer _____

Model No. _____

Rated Horsepower _____

Location: Forced Draft ____ Induced Draft ____

5. Instrumentation (Check if Applicable)

Differential
Pressures:

Throat _____

Separator _____

Demister _____

Temperatures:

Gas Outlet _____

Gas Inlet _____

Liquor Inlet _____

Liquor Outlet _____

pH:

Recirculation _____

Exit Liquor _____

Fan Motor Current _____

Other _____

Nozzle Pressure _____

Flow Rates:

Recirculation _____

Makeup _____

Purge _____

Motor Current:

Fan _____

Pump _____

Inspection No. _____

Data Sheet No. _____

Preparer _____

Confidential: Yes__ No__

B. COMPONENT INFORMATION (continued)

6. Materials of Construction (Specify type and gauge) . .

Presaturator _____

Throat _____

Scrubber Shell _____

Trays/Bed Supports _____


Demister _____

Fan Housing _____


Inspection No. _____
Data Sheet No. _____
Preparer _____
Confidential: Yes__ No__

C. DIAGRAM

1. Sketch wet scrubber system. (Show all major components and processes controlled.)



2. Sketch wet scrubber layout (each square 1' x 1')



Inspection No. _____

Data Sheet No. _____

Preparer _____

Confidential: Yes__ No__

F. SAMPLE ANALYSIS

Scrubber Liquor Effluent

Sample No. _____

Location Obtained _____

Date/Time Obtained _____

Results:

Suspended Solids _____ ppm

Dissolved Solids _____ ppm

pH _____

Chloride _____ ppm

Scrubber Recirculation

Sample No. _____

Location Obtained _____

Date/Time Obtained _____

Results:

Suspended Solids _____ ppm

Dissolved Solids _____ ppm

pH _____

Chloride _____ ppm

Other

Inspection No. _____

Data Sheet No. _____

Preparer _____

Confidential: Yes__ No__

G. CONTROL SYSTEM PERFORMANCE

Gaseous Flow _____ ACFM
(implied from fan operation)

Gaseous Flow _____ ACFM
(calculated from pitot traverse)

Gaseous Flow _____ ACFM
(implied from process operation)

Liquor Flow _____ gpm

L/G Ratio _____

Bypass (% of total gas flow) _____ %

Throat Velocity _____ FPS

Superficial Velocity (design) _____ FPM
(effective) _____ FPM

Visible Emissions (residual) _____ %

H. ADDITIONAL COMMENTS

Sheets Included: A _____ B _____ C _____
D _____ E _____ F _____
G _____ H _____

Inspector's Signature _____

Date Prepared _____

Reviewer's Signature _____

Date Reviewed _____

Date Filed _____



PEDCO ENVIRONMENTAL
MECHANICAL COLLECTOR INSPECTION DATA SHEET

LOCATION _____ DATA SHEET NO. _____
DESIGNATION _____ INSPECTION NO. _____
CLIENT _____ INSPECTOR(S) _____
PN _____ DATE _____
CLAIMED
CONFIDENTIAL Yes _____ No _____

A. DESCRIPTIVE INFORMATION

Mechanical Collector Type

Cyclone _____ Settling Chamber _____
Cyclone Bank _____ Double Vortex Cyclone _____
Multiclone _____ Other (describe) _____

Manufacturer _____
Model Number _____
Date Installed _____
Process/Source Controlled _____
Particulate Characteristics _____

B. COMPONENT INFORMATION

1. Cyclone

Diameter of Body _____ ft.
Cone Angle _____ degrees
Material of Construction _____
Gauge of Metal _____
Number of Cyclones _____

2. Hoppers

Number _____
Slope _____
Insulation: Yes _____ No _____
Heating: Yes _____ No _____
Vibrators: Yes _____ No _____

Confidential: Yes___ No___

Inspection No. _____

Data Sheet No. _____

Preparer _____

Confidential: Yes__ No__

D. EXTERNAL INSPECTION

Fan Inlet Static Pressure _____ in. of H₂O

Fan Outlet Static Pressure _____ in. of H₂O

Fan Motor Current _____ amperes

Fan Rotational Speed _____ rpm

Fan Damper Position _____

Gas Temperature at Fan Inlet _____ °F

Fan Vibration (low, moderate, severe) _____

Static Pressure at Collector Outlet _____ in. of H₂O

Static Pressure at Collector Inlet _____ in. of H₂O

On-site Differential Pressure Gauge Reading _____ in. of H₂O

Gas Temperature at Collector Inlet _____ °F

Rotary Valve Rotational Speed _____ rpm

Flapper Gate Frequency _____ (#/hr)

Hopper Conditions (Check if applicable)

Cold _____

Dented _____

Warped _____

Corroded _____

Inspection No. _____
Data Sheet No. _____
Preparer _____
Confidential: Yes__ No__

E. INTERNAL INSPECTION

Hoppers (plugged or corroded) _____

Hopper Baffles Nonexistent (Characterize potential abra-
sion) _____

Inlet Vanes Plugged/Eroded (Characterize severity) _____

Cones Plugged (location, number) _____

Flow Disturbances (Characterize severity) _____

Outlet Tube Erosion (Characterize potential bypassing)

Corrosion (Characterize) _____

Scaling (Characterize) _____

Inspection No. _____

Data Sheet No. _____

Preparer _____

Confidential: Yes__ No__

F. CONTROL SYSTEM PERFORMANCE

Air Flow Rate (implied from fan operation) _____ ACFM

Air Flow Rate (calculated from pitot tube) _____ ACFM

Air Flow Rate (implied from process operation) _____ ACFM

Inlet Velocity _____ FPS

Opacity _____ %

G. ADDITIONAL COMMENTS

Sheets Included: A__ B__ C__ D__
E__ F__ G__

Inspector's Signature _____

Date Prepared _____

Reviewer's Signature _____

Date Reviewed _____

Date Filed _____

SOURCE NAME			SOURCE ID NUMBER				OBSERVATION DATE								
ADDRESS			OBSERVER'S NAME (PRINT)												
			ORGANIZATION												
STATE	ZIP	PHONE	CERTIFIED BY				DATE								
<div><div><div>70°70°</div><div>SUN SHADOW LINE</div></div></div>															
PROCESS			OPERATING MODE			START TIME				STOP TIME					
						0153045				0153045					
CONTROL EQUIPMENT			OPERATING MODE			1					31				
						2					32				
DESCRIBE EMISSION POINT						3					33				
						4					34				
EMISSION POINT HEIGHT ABOVE GROUND LEVEL			EMISSION POINT HEIGHT RELATIVE TO OBSERVER			5					35				
						6					36				
DISTANCE TO EMISSION POINT			DIRECTION TO EMISSION POINT			7					37				
						8					38				
						9					39				
DESCRIBE EMISSIONS						10					40				
						11					41				
						12					42				
COLOR OF EMISSIONS			CONTINUOUS <input type="checkbox"/> FUGITIVE <input type="checkbox"/>			13					43				
			INTERMITTENT <input type="checkbox"/>			14					44				
						15					45				
WATER VAPOR PRESENT			IF YES, IS PLUME			16					46				
NO <input type="checkbox"/> YES <input type="checkbox"/>			ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>			17					47				
						18					48				
AT WHAT POINT WAS OPACITY DETERMINED						19					49				
						20					50				
						21					51				
DESCRIBE BACKGROUND						22					52				
						23					53				
COLOR OF BACKGROUND			SKY CONDITIONS			24					54				
						25					55				
WIND SPEED			WIND DIRECTION			26					56				
						27					57				
AMBIENT TEMPERATURE			RELATIVE HUMIDITY			28					58				
						29					59				
						30					60				
REMARKS						AVERAGE OPACITY				NUMBER OF READINGS ABOVE					
										% WERE					
						RANGE OF OPACITY									
						READINGS				FROM TO					
SOURCE LAYOUT SKETCH						DRAW NORTH ARROW									
						<div><div>X</div><div>EMISSION PT.</div></div>									
OBSERVER'S SIGNATURE			DATE			I HAVE RECEIVED A COPY OF THESE OPACITY OBSERVATIONS.									
						SIGNATURE									
VERIFIED BY						TITLE									
						DATE									