


Air



# **Costs of Sulfur Dioxide, Particulate Matter, and Nitrogen Oxide Controls on Fossil Fuel Fired Industrial Boilers**



# **Costs of Sulfur Dioxide, Particulate Matter, and Nitrogen Oxide Controls on Fossil Fuel Fired Industrial Boilers**

**Prepared by:**

**Michael L. Bowen  
Mark S. Jennings  
Radian Corporation  
3024 Pickett Road  
Durham, North Carolina 27705**

**EPA Project Officer: Larry G. Jones  
Emission Standards and Engineering Division  
Contract No.: 68-02-3058**

**U.S. ENVIRONMENTAL PROTECTION AGENCY  
Office of Air, Noise, and Radiation  
Office of Air Quality Planning and Standards  
Research Triangle Park, North Carolina 27711**

The report has been reviewed by the Emission Standards and Engineering Division of the Office of Air Quality Planning and Standards, EPA, and approved for publication. Mention of trade names or commercial products is not intended to constitute endorsement or recommendation for use. Copies of this report are available through the Library Services Office (MD-35), U.S. Environmental Protection Agency, Research Triangle Park, N.C. 27711, or from National Technical Information Services, 5285 Port Royal Road, Springfield, Virginia 22161.

## TABLE OF CONTENTS

<u>Chapter</u>		<u>Page</u>
1.0	INTRODUCTION . . . . .	1-1
2.0	METHODOLOGY FOR CALCULATING SO <sub>2</sub> AND PM MODEL BOILER COSTS. . . . .	2-1
	2.1 METHODOLOGY FOR ANALYZING THE PM AND SO <sub>2</sub> COST IMPACTS ON INDUSTRIAL BOILERS . . . . .	2-1
	2.2 COST CALCULATION APPROACH . . . . .	2-4
	2.2.1 CAPITAL COSTS. . . . .	2-9
	2.2.2 OPERATION AND MAINTENANCE (O&M) COSTS. . . . .	2-13
	2.2.3 ANNUALIZED COSTS . . . . .	2-13
	2.3 BOILER AND FUEL COSTS . . . . .	2-17
	2.4 PARTICULATE MATTER (PM) CONTROL COSTS . . . . .	2-19
	2.5 SO <sub>2</sub> CONTROL COSTS . . . . .	2-26
	2.6 COMPLIANCE, REPORTING, AND MALFUNCTION COSTS. . . . .	2-26
	2.7 REFERENCES. . . . .	2-31
3.0	COSTS OF PM AND SO <sub>2</sub> CONTROL FOR COAL-FIRED BOILERS . . . . .	3-1
	3.1 CAPITAL COSTS OF PM AND SO <sub>2</sub> CONTROL APPLIED TO COAL FIRED BOILERS. . . . .	3-2
	3.2 O&M AND TOTAL ANNUALIZED COSTS OF PM AND SO <sub>2</sub> CONTROL APPLIED TO COAL-FIRED BOILERS . . . . .	3-10
4.0	COSTS OF PM AND SO <sub>2</sub> CONTROL FOR RESIDUAL OIL-FIRED BOILERS. . . . .	4-1
	4.1 CAPITAL COSTS OF PM AND SO <sub>2</sub> CONTROLS APPLIED TO RESIDUAL OIL-FIRED BOILERS. . . . .	4-1
	4.2 O&M AND TOTAL ANNUALIZED COSTS OF PM AND SO <sub>2</sub> CONTROL FOR OIL-FIRED BOILERS . . . . .	4-4
5.0	NO <sub>X</sub> CONTROL COSTS. . . . .	5-1
	5.1 SELECTION OF NO <sub>X</sub> CONTROL CASES. . . . .	5-1
	5.2 COST CALCULATION APPROACH . . . . .	5-1
	5.3 ANALYSIS OF COST IMPACTS. . . . .	5-6
	5.4 REFERENCES. . . . .	5-12
6.0	COSTS OF LOW SULFUR COAL AND LOW SULFUR OIL. . . . .	6-1
	6.1 LOW SULFUR COAL . . . . .	6-1
	6.2 LOW SULFUR FUEL OIL . . . . .	6-4
	6.3 REFERENCES. . . . .	6-9

## TABLE OF CONTENTS (Continued)

APPENDIX A - COST ALGORITHMS . . . . .	A-1
APPENDIX B - LISTING OF FORTRAN COST ANALYSIS PROGRAM. . . . .	B-1
APPENDIX C - MODEL BOILER COST TABLES. . . . .	C-1
APPENDIX D - COST ESCALATION METHODS . . . . .	D-1

## LIST OF TABLES

<u>Table</u>		<u>Page</u>
2-1	STANDARD BOILERS SELECTED FOR EVALUATION OF SO <sub>2</sub> AND PM CONTROLS. . . . .	2-3
2-2	HIGH SULFUR COAL-FIRED MODEL BOILERS FOR SO <sub>2</sub> AND PM CONTROLS. . . . .	2-5
2-3	LOW SULFUR COAL-FIRED MODEL BOILERS FOR SO <sub>2</sub> AND PM CONTROLS. . . . .	2-6
2-4	RESIDUAL OIL-FIRED MODEL BOILERS FOR SO <sub>2</sub> AND PM CONTROLS. . . . .	2-7
2-5	ABBREVIATIONS USED FOR MODEL BOILERS . . . . .	2-8
2-6	SUMMARY OF COSTING ALGORITHMS. . . . .	2-10
2-7	CAPITAL COST COMPONENTS. . . . .	2-11
2-8	WORKING CAPITAL CALCULATIONS FOR BOILERS AND CONTROL DEVICES. . . . .	2-12
2-9	OPERATING AND MAINTENANCE COST COMPONENTS. . . . .	2-14
2-10	CAPACITY UTILIZATION AND LABOR FACTORS USED FOR MODEL BOILER COST CALCULATIONS . . . . .	2-15
2-11	UNIT COSTS USED IN CALCULATIONS. . . . .	2-16
2-12	ANNUALIZED COST COMPONENTS . . . . .	2-18
2-13	DIRECT O&M COST MULTIPLIERS TO ACCOUNT FOR ECONOMIES ASSOCIATED WITH MULTIPLE BOILER INSTALLATIONS. . . . .	2-20
2-14	SPECIFICATIONS FOR COAL-FIRED STANDARD BOILERS . . . . .	2-21
2-15	SPECIFICATIONS FOR RESIDUAL OIL-FIRED STANDARD BOILERS . . . . .	2-22
2-16	FUEL ANALYSIS AND PRICES . . . . .	2-23
2-17	GENERAL DESIGN SPECIFICATIONS FOR PM CONTROL SYSTEMS . . . . .	2-24
2-18	GENERAL DESIGN SPECIFICATIONS FOR SO <sub>2</sub> CONTROL SYSTEMS. . . . .	2-27

LIST OF TABLES (Continued)

<u>Table</u>		<u>Page</u>
2-19	ANNUAL REPORTING, COMPLIANCE, AND MALFUNCTION COSTS . . . . .	2-29
3-1	CAPITAL COSTS FOR HSC-FIRED MODEL BOILERS. . . . .	3-3
3-2	CAPITAL COSTS FOR LSC-FIRED MODEL BOILERS. . . . .	3-4
3-3	ANNUAL O&M COSTS FOR HSC-FIRED MODEL BOILERS . . . . .	3-11
3-4	ANNUAL O&M COSTS FOR LSC-FIRED MODEL BOILERS . . . . .	3-12
3-5	TOTAL ANNUALIZED COSTS FOR HSC-FIRED MODEL BOILERS . . . . .	3-13
3-6	TOTAL ANNUALIZED COSTS FOR LSC-FIRED MODEL BOILERS . . . . .	3-14
4-1	CAPITAL COSTS FOR RESIDUAL OIL-FIRED MODEL BOILERS . . . . .	4-2
4-2	ANNUAL O&M COSTS FOR RESIDUAL OIL-FIRED MODEL BOILERS. . .	4-5
4-3	TOTAL ANNUALIZED COSTS FOR RESIDUAL OIL-FIRED MODEL BOILERS. . . . .	4-6
5-1	NO <sub>X</sub> CONTROL CASES AND EMISSION LEVELS. . . . .	5-2
5-2	NO <sub>X</sub> COMBUSTION MODIFICATION EQUIPMENT REQUIREMENTS OR MODIFICATIONS. . . . .	5-5
5-3	FUEL COSTS USED FOR NO <sub>X</sub> CONTROL ANALYSIS . . . . .	5-7
5-4	FUEL F-FACTORS AND BOILER EXCESS AIR LEVELS USED IN NO <sub>X</sub> CONTROL COST CALCULATIONS. . . . .	5-8
5-5	NO <sub>X</sub> CONTROL COSTS. . . . .	5-9
6-1	INCREMENTAL INCREASES IN RESIDUAL OIL PRICES FOR VARIOUS SULFUR CONTENTS. . . . .	6-7

## LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
3-1	NORMALIZED CAPITAL COSTS FOR HSC-FIRED MODEL BOILERS . . .	3-5
3-2	NORMALIZED CAPITAL COSTS FOR LSC-FIRED MODEL BOILERS . . .	3-6
3-3	PERCENT INCREASES IN CAPITAL COST OVER UNCONTROLLED FOR HSC-FIRED MODEL BOILERS. .	3-7
3-4	PERCENT INCREASES IN CAPITAL COST OVER UNCONTROLLED FOR LSC-FIRED MODEL BOILERS. .	3-8
3-5	NORMALIZED ANNUALIZED COSTS FOR HSC-FIRED MODEL BOILERS. .	3-15
3-6	NORMALIZED ANNUALIZED COSTS FOR LSC-FIRED MODEL BOILERS. .	3-16
3-7	PERCENT INCREASES IN ANNUALIZED COST OVER UNCONTROLLED FOR HSC-FIRED MODEL BOILERS. .	3-18
3-8	PERCENT INCREASES IN ANNUALIZED COST OVER UNCONTROLLED FOR LSC-FIRED MODEL BOILERS. .	3-19
4-1	NORMALIZED CAPITAL COSTS FOR RESIDUAL OIL-FIRED MODEL BOILERS. .	4-3
4-2	NORMALIZED ANNUALIZED COSTS FOR RESIDUAL OIL-FIRED MODEL BOILERS. .	4-7
6-1	DELIVERED PRICE OF COAL TO MIDWEST LOCATION (CHICAGO). . .	6-2
6-2	NORMALIZED ANNUALIZED COST OF FGD SYSTEM APPLIED TO HSC COAL-FIRED BOILERS .	6-3
6-3	DELIVERED PRICE OF COAL TO A SOUTHWEST LOCATION (HOUSTON). .	6-5
6-4	DELIVERED PRICE OF COAL TO A NORTHEAST LOCATION (BOSTON) .	6-6

## 1.0 INTRODUCTION

This report presents a cost analysis of particulate matter (PM), sulfur dioxide ( $\text{SO}_2$ ), and nitrogen oxide ( $\text{NO}_x$ ) controls on coal-, oil-, and gas-fired industrial boilers. For each boiler and control device the capital costs, operating and maintenance costs, and annualized costs are estimated.  $\text{SO}_2$  and PM control costs are analyzed in Chapters 2-4 while  $\text{NO}_x$  control costs are analyzed in Chapter 5.

Chapter 2 discusses the methodologies and cost bases for estimating the boiler, PM control and  $\text{SO}_2$  control costs. Chapters 3 and 4 then present the costs for coal- and residual oil-fired boilers, respectively. In Chapter 5, the costs of various  $\text{NO}_x$  controls (combustion modifications) are discussed. This chapter also outlines the cost methodologies used in addition to presenting the costs. The last chapter, Chapter 6, discusses the costs of firing low sulfur coal and low sulfur oil.

Four appendices are also included for reference. Appendix A is a listing of the cost algorithms used to estimate the boiler, PM control,  $\text{SO}_2$  control, and  $\text{NO}_x$  control costs. Appendix B presents the FORTRAN computer program that utilizes these algorithms to develop the boiler and control device costs. Appendix C provides a detailed cost breakdown for all the cost cases studied. Finally, Appendix D presents two methods available to convert the costs calculated using the cost algorithms presented in this report (mid-1978 dollars) to a cost basis of a later year.

## 2.0 METHODOLOGY FOR CALCULATING SO<sub>2</sub> AND PM MODEL BOILER COSTS

This chapter presents the methodologies and cost bases used for calculating the costs of various SO<sub>2</sub> and PM controls that are applied to different types and sizes of industrial boilers. The emphasis of this analysis is to quantify the individual boiler cost impacts associated with the application of these emission controls. Both uncontrolled and controlled boiler costs are examined. By comparing the two, the incremental cost impact associated with the controls is assessed.

Section 2.1 describes the methodology used in this report to analyze the PM and SO<sub>2</sub> cost impacts on industrial boilers. Section 2.2 discusses the basic approach used in calculating the boiler and control device costs. The specific equipment specifications used to calculate the boiler and control device costs are presented in Section 2.3. Lastly, Section 2.4 presents annual costs due to reporting, compliance, and control device malfunction. These costs are treated separately from the boiler and control device costs presented in Chapters 3 and 4. All costs presented in this report are in mid-1978 dollars.

### 2.1 METHODOLOGY FOR ANALYZING THE PM AND SO<sub>2</sub> COST IMPACTS ON INDUSTRIAL BOILERS

In this report, the cost impacts on various types and sizes of industrial boilers from applying various PM and SO<sub>2</sub> controls are assessed through an analysis of "model boilers." Model boilers form the basis of the PM and SO<sub>2</sub> control costs analysis. They are developed by applying different combinations of PM and SO<sub>2</sub> controls to a group of standard boilers that represent the population of new industrial boilers expected to be built. Standard boilers are defined as boilers without emission controls. In general, the model boilers are selected to cover a range of boiler sizes, fossil fuel types, and control methods. A brief description of the bases used for selection of the standard boilers, the PM controls, and the SO<sub>2</sub> controls follows.

A summary of the standard boilers selected for evaluation in this report is presented in Table 2-1. Factors considered in the selection were fossil fuel types, boiler distribution by capacity, heat transfer configurations and fuel firing methods. The principal industrial boiler fossil fuels are coal, residual oil, distillate oil, and natural gas. Because distillate oil- and natural gas-fired boilers have low uncontrolled PM and SO<sub>2</sub> emissions they were not considered in this analysis. Since coal properties such as sulfur and ash content can vary considerably, separate standard boilers were selected for both low sulfur coal (LSC) and high sulfur coal (HSC) applications.

The industrial boiler population is segmented into four size categories ranging in capacity from 30 to  $400 \times 10^6$  Btu/hr. All four size categories are represented in the coal-fired boiler analysis (30, 75, 150, and  $400 \times 10^6$  Btu/hr). All of the coal-fired boilers in this analysis are field-erected units except for the  $30 \times 10^6$  Btu/hr unit which is a package boiler. In addition, they all have the same heat transfer configuration in that they are watertube units. The residual oil-fired population is smaller and is represented by two package boilers, 30 and  $150 \times 10^6$  Btu/hr. The  $30 \times 10^6$  Btu/hr boiler is a firetube boiler while the  $150 \times 10^6$  Btu/hr boiler is a watertube unit. Construction of oil-fired boilers larger than  $150 \times 10^6$  Btu/hr capacity is expected to be very limited.

Both residual oil-fired standard boilers utilize similar multi-fuel capable oil/gas burner designs. However, the coal-fired boilers vary in firing mechanism. Underfeed stokers typically occupy the lower end of the capacity range, and pulverized coal the upper end, with other stoker types occupying the intermediate range between the two. For the standard boilers, an underfeed stoker has been selected for the  $30$  and  $75 \times 10^6$  Btu/hr boilers, a spreader stoker has been selected for the  $150 \times 10^6$  Btu/hr boiler, and a pulverized coal unit has been selected for the  $400 \times 10^6$  Btu/hr boiler. The specifications for these boilers and the fuels will be presented in Section 2.3.

The controls selected for the PM and SO<sub>2</sub> cost analysis include single mechanical collectors, side stream separators, venturi scrubbers,

TABLE 2-1. STANDARD BOILERS SELECTED FOR EVALUATION OF SO<sub>2</sub> AND PM CONTROLS

Boiler Code	Fuel	Heat Input Thermal $10^6$ Btu/hr	Boiler Configuration
RES-30	Residual Oil	30	Package, Firetube
RES-150		150	Package, Watertube
HSC-30	High-Sulfur Coal	30	Package, Watertube, Underfeed Stoker
HSC-75		75	Field-Erected, Watertube, Underfeed Stoker
HSC-150		150	Field-Erected, Watertube, Spreader Stoker
HSC-400		400	Field-Erected, Watertube, Pulverized Feed
LSC-30	Low-Sulfur Coal	30	Package, Watertube, Underfeed Stoker
LSC-75		75	Field-Erected, Watertube, Underfeed Stoker
LSC-150		150	Field-Erected, Watertube, Spreader Stoker
LSC-400		400	Field-Erected, Watertube, Pulverized Feed

electrostatic precipitators, fabric filters, dual alkali scrubbers, dry scrubbers (spray dryers) and sodium throwaway scrubbers. These controls were selected because they are the most likely candidates to control  $\text{SO}_2$  and PM emissions on new industrial boilers.

$\text{SO}_2$  control devices can be equipped to remove both  $\text{SO}_2$  and PM. Dual alkali scrubbing systems can be designed to remove both PM and  $\text{SO}_2$  or  $\text{SO}_2$  only depending on whether additional PM control equipment is included prior to the scrubber. In addition, sodium throwaway scrubbers can remove both  $\text{SO}_2$  and PM or  $\text{SO}_2$  alone. However, since a fabric filter is a integral part of dry scrubbing systems, all of these systems are designed for combined  $\text{SO}_2$  and PM control. Details of the control device specifications will be presented in Section 2.3.

Dual alkali scrubbers and sodium throwaway scrubbers are analyzed at both 50 and 90 percent  $\text{SO}_2$  removal. Dry scrubbers are analyzed only at 50 percent  $\text{SO}_2$  removal on low sulfur coal-fired boilers.

As stated earlier, a controlled standard boiler is termed a model boiler. The standard boilers used in this cost analysis were presented in Table 2-1. The model boilers formed from the combination of the standard boilers and the PM and  $\text{SO}_2$  controls are presented in Tables 2-2, 2-3, and 2-4. Abbreviations used in these tables are defined in Table 2-5. Tables 2-2 through 2-4 also present the PM and  $\text{SO}_2$  emission levels that these controls can achieve for each model boiler case. These emission levels or percent reductions are based on available emission test data.<sup>1</sup>

## 2.2 COST CALCULATION APPROACH

The costs of each model boiler can be broken down into three major cost categories:

- Capital Costs (total capital investment required to construct and make operational a boiler and control system),
- Operation and Maintenance (O&M) costs (total annual cost necessary to operate and maintain a boiler and control system), and
- Annualized Costs (total O&M costs plus capital related charges).

TABLE 2-2. HIGH SULFUR COAL-FIRED MODEL BOILERS FOR SO<sub>2</sub> and PM CONTROLS

Model Boiler	Controlled Emissions (lb/10 <sup>6</sup> Btu)		Removal Efficiencies (Percent)	
	SO <sub>2</sub>	PM	SO <sub>2</sub>	PM
HSC-30-Unc, Unc	5.70	0.657	0	0
HSC-30-Unc, SM	5.70	0.40	0	39.1
HSC-30-Unc, SSS	5.70	0.20	0	69.6
HSC-30-Unc, VS	5.70	0.10	0	84.8
HSC-30-Unc, ESP	5.70	0.05	0	92.4
HSC-30-DA(50), DA/PM	2.85	0.10	50	84.8
HSC-30-DA(50), ESP	2.85	0.05	50	92.4
HSC-30-DA(90), DA/PM	0.57	0.10	90	84.8
HSC-30-DA(90), ESP	0.57	0.05	90	92.4
HSC-75-Unc, Unc	5.70	0.657	0	0
HSC-75-Unc, SM	5.70	0.40	0	39.1
HSC-75-Unc, SSS	5.70	0.20	0	69.6
HSC-75-Unc, VS	5.70	0.10	0	84.8
HSC-75-Unc, ESP	5.70	0.05	0	92.4
HSC-75-DA(50), DA/PM	2.85	0.10	50	84.8
HSC-75-DA(50), ESP	2.85	0.05	50	92.4
HSC-75-DA(90), DA/PM	0.57	0.10	90	84.8
HSC-75-DA(90), ESP	0.57	0.05	90	92.4
HSC-150-Unc, Unc	5.70	2.54	0	0
HSC-150-Unc, SM	5.70	0.60	0	76.4
HSC-150-Unc, SSS	5.70	0.20	0	92.1
HSC-150-Unc, VS	5.70	0.10	0	96.1
HSC-150-Unc, ESP	5.70	0.05	0	98.0
HSC-150-DA(50), DA/PM	2.85	0.10	50	96.1
HSC-150-DA(50), ESP	2.85	0.05	50	98.0
HSC-150-DA(90), DA/PM	0.57	0.10	90	96.1
HSC-150-DA(90), ESP	0.57	0.05	90	98.0
HSC-400-Unc, Unc	5.70	3.81	0	0
HSC-400-Unc, SM	5.70	1.00	0	73.8
HSC-400-Unc, SSS	5.70	0.20	0	94.8
HSC-400-Unc, VS	5.70	0.10	0	97.4
HSC-400-Unc, ESP	5.70	0.05	0	98.7
HSC-400-DA(50), DA/PM	2.85	0.10	50	97.4
HSC-400-DA(50), ESP	2.85	0.05	50	98.7
HSC-400-DA(90), DA/PM	0.57	0.10	90	97.4
HSC-400-DA(90), ESP	0.57	0.05	90	98.7

TABLE 2-3. LOW SULFUR COAL-FIRED MODEL BOILERS FOR SO<sub>2</sub> and PM CONTROLS

Model Boiler	Controlled Emissions (1b/10 <sup>6</sup> Btu)		Removal Efficiencies (Percent)	
	SO <sub>2</sub>	PM	SO <sub>2</sub>	PM
LSC-30-Unc, Unc	1.19	0.807	0	0
LSC-30-Unc, SM	1.19	0.40	0	50.0
LSC-30-Unc, SSS	1.19	0.20	0	75.2
LSC-30-Unc, VS	1.19	0.10	0	87.6
LSC-30-Unc, FF	1.19	0.05	0	93.8
LSC-30-DS(50), DS/PM	0.595	0.10	50	87.6
LSC-30-DA(50), DA/PM	0.595	0.10	50	87.6
LSC-30-DA(50), FF	0.595	0.05	50	93.8
LSC-30-DA(90), DA/PM	0.119	0.10	90	87.6
LSC-30-DA(90), FF	0.119	0.05	90	93.8
LSC-75-Unc, Unc	1.19	0.807	0	0
LSC-75-Unc, SM	1.19	0.40	0	50.0
LSC-75-Unc, SSS	1.19	0.20	0	75.2
LSC-75-Unc, VS	1.19	0.10	0	87.6
LSC-75-Unc, FF	1.19	0.05	0	93.8
LSC-75-DS(50), DS/PM	0.595	0.10	50	87.6
LSC-75-DA(50), DA/PM	0.595	0.10	50	87.6
LSC-75-DA(50), FF	0.595	0.05	50	93.8
LSC-75-DA(90), DA/PM	0.119	0.10	90	87.6
LSC-75-DA(90), FF	0.119	0.05	90	93.8
LSC-150-Unc, Unc	1.19	3.13	0	0
LSC-150-Unc, SM	1.19	0.6	0	80.8
LSC-150-Unc, SSS	1.19	0.20	0	93.6
LSC-150-Unc, VS	1.19	0.10	0	96.8
LSC-150-Unc, FF	1.19	0.05	0	98.4
LSC-150-DS(50), DS/PM	0.595	0.10	50	96.8
LSC-150-DA(50), DA/PM	0.595	0.10	50	96.8
LSC-150-DA(50), FF	0.595	0.05	50	98.4
LSC-150-DA(90), DA/PM	0.119	0.10	90	96.8
LSC-150-DA(90), FF	0.119	0.05	90	98.4
LSC-400-Unc, Unc	1.19	2.39	0	0
LSC-400-Unc, SM	1.19	1.0	0	58.2
LSC-400-Unc, SSS	1.19	0.20	0	91.6
LSC-400-Unc, VS	1.19	0.10	0	95.8
LSC-400-Unc, FF	1.19	0.05	0	97.9
LSC-400-DS(50), DS/PM	0.595	0.10	50	95.8
LSC-400-DA(50), DA/PM	0.595	0.10	50	95.8
LSC-400-DA(50), FF	0.595	0.05	50	97.9
LSC-400-DA(90), DA/PM	0.119	0.10	90	95.8
LSC-400-DA(90), FF	0.119	0.05	90	97.9

TABLE 2-4. RESIDUAL OIL-FIRED MODEL BOILERS FOR SO<sub>2</sub> AND PM CONTROLS

Model Boiler	Controlled Emissions (1b/10 <sup>6</sup> Btu)		Removal Efficiencies (Percent)	
	SO <sub>2</sub>	PM	SO <sub>2</sub>	PM
RES-30-Unc, Unc	3.21	0.23	0	0
RES-30-Unc, ESP	3.21	0.05	0	78.3
RES-30-NATH(50), NATH/PM	1.61	0.10	50	56.5
RES-30-NATH(50), ESP	1.61	0.05	50	78.3
RES-30-NATH(90), NATH/PM	0.321	0.10	90	56.5
RES-30-NATH(90), ESP	0.321	0.05	90	78.3
RES-30-DA(90), DA/PM	0.321	0.10	90	56.5
RES-30-DA(90), ESP	0.321	0.05	90	78.3
RES-150-Unc, Unc	3.21	0.23	0	0
RES-150-Unc, ESP	3.21	0.05	0	78.3
RES-150-DA(50), DA/PM	1.61	0.10	50	56.5
RES-150-DA(50), ESP	1.61	0.05	50	78.3
RES-150-DA(90), DA/PM	0.321	0.10	90	56.5
RES-150-DA(90), ESP	0.321	0.05	90	78.3

TABLE 2-5. ABBREVIATIONS USED FOR MODEL BOILERS

---

---

Boilers

HSC - High sulfur coal-fired

LSC - Low sulfur coal-fired

RES - Residual oil-fired

PM Control Systems

Unc - Uncontrolled

SM - Single mechanical collector (multitube cyclone)

SSS - Sidestream separator

ESP - Electrostatic precipitator

FF - Fabric filter

DA/PM - Particulate removal via dual alkali scrubber

DS/PM - Particulate removal via dry scrubber

NATH/PM - Particulate removal via sodium throwaway scrubber

SO<sub>2</sub> Control Systems

Unc - Uncontrolled

DA (50) - Dual alkali scrubber (50 percent removal)

DA (90) - Dual alkali scrubber (90 percent removal)

DS (50) - Dry scrubber (spray dryer) (50 percent removal)

NATH (50) - Sodium throwaway scrubber (50 percent removal)

NATH (90) - Sodium throwaway scrubber (90 percent removal)

---

Each of these cost categories can be further subdivided into individual cost components. Sections 2.2.1, 2.2.2, and 2.2.3 present the individual cost components and the methods used to develop the capital, O&M, and annualized costs, respectively for each of the model boilers.

The majority of the capital and O&M cost components for the boilers, SO<sub>2</sub> controls and PM controls are estimated by the use of cost algorithms. Each algorithm presents a particular boiler or control device cost component as an algebraic function of key system specifications. Table 2-6 summarizes the costing algorithms available. The routine codes shown in the first column of Table 2-6 identify the algorithms in the FORTRAN computer program that is used to develop the costs presented in this report. A complete listing of the algorithms is presented in Appendix A while a complete listing of the FORTRAN computer program is presented in Appendix B.

### 2.2.1 Capital Costs

Table 2-7 presents the individual capital cost components and the general methodology used for calculating total capital costs. Direct capital costs consist of the basic and auxiliary equipment costs in addition to the labor and material required to install the equipment. Indirect costs are those costs not attributable to specific equipment items. Other capital cost components are contingencies, the cost of land and working capital.

Contingencies are included in capital costs to compensate for unpredicted events and other unforeseen expenses. Costs for land are included in boiler capital costs but not in control system costs. All boilers except pulverized coal boilers are assumed to have land costs of \$2,000. Pulverized coal boilers are assumed to have land costs of \$4,000.

The computation of working capital in this analysis also differs slightly for boilers and control equipment. In calculating the cost for working capital the equations shown in Table 2-8 are used. These equations are based on three months of direct annual non-fuel operating costs and one month of fuel costs.

Most cost algorithms compute the key individual capital cost components (equipment costs, installation costs and indirect costs). However, some of the algorithms used in this analysis deviate from this methodology. For

TABLE 2-6. SUMMARY OF PM AND SO<sub>2</sub> COSTING ALGORITHMS

Poutine Code <sup>a</sup>	Algorithm Type	Boiler Size Applicability (10 <sup>6</sup> Btu/hr)
UNDP	Boiler, underfeed stoker, watertube, package	<u>&lt;75</u>
SPRD	Boiler, spreader stoker, watertube, field-erected	60 - 200
PL/P	Boiler, pulverized coal, watertube, field-erected	<u>&gt;200</u>
PES1	Boiler, residual oil, firetube, package	<u>&lt;30</u>
PNG1	Boiler, residual/natural gas, watertube, package	30 - 200
PNG2	Boiler, residual/natural gas, watertube, field-erected	200 - 700
DNG1	Boiler, distillate/natural gas, firetube, package	<u>&lt;30</u>
DNG2	Boiler, distillate/natural gas, watertube, package	30 - 200
VS	Venturi scrubber applied to coal-fired boiler	30 - 700
ESPC	Electrostatic precipitator applied to coal-fired boiler	<u>&lt;700</u>
ESPO	Electrostatic precipitator applied to residual oil-fired boiler	<u>&lt;700</u>
FF	Fabric filter applied to coal-fired boiler	30 - 700
SM	Single mechanical collector (multi-cyclone) applied to coal-fired boiler	30 - 700
DM	Dual mechanical collector (multi-cyclones) applied to coal-fired boiler	30 - 700
SSS	Side stream separator applied to coal-fired boiler	30 - 700
DA	Dual alkali FGD system without PM removal	All sizes
DAC	Dual alkali FGD system with PM removal	All sizes
NATH	Sodium throwaway FGD system	All sizes
DS	Lime spray drying (dry scrubbing) FGD system	All sizes

<sup>a</sup>Poutine code refers to code used to identify algorithm in FORTRAN computer program (see Appendix B).

TABLE 2-7. CAPITAL COST COMPONENTS<sup>a</sup>

(1) Direct Costs

$$\begin{aligned} & \text{Equipment} \\ + & \underline{\text{Installation}} \\ = & \text{Total Direct Costs} \end{aligned}$$

(2) Indirect Costs

Engineering - 10% of direct costs for boilers and PM controls<sup>2</sup>

For FGD systems on boilers  $< 200 \times 10^6$  Btu/hr, FGD engineering costs are 10% of FGD direct costs for an FGD system that is applied to a  $200 \times 10^6$  Btu/hr boiler.

For FGD systems on boilers  $> 200 \times 10^6$  Btu/hr, FGD engineering costs are 10% of specific FGD system's direct costs.<sup>13</sup>

$$\begin{aligned} + & \text{Construction and Field Expenses} & (10\% \text{ of direct costs})^2 \\ + & \text{Construction Fees} & (10\% \text{ of direct costs})^2 \\ + & \text{Start Up Costs} & (2\% \text{ of direct costs})^2 \\ + & \text{Performance Costs} & (1\% \text{ of direct costs})^{13} \end{aligned}$$

$$= \text{Total Indirect Costs}$$

(3) Contingencies<sup>2</sup> = 20% of (Total Indirect + Total Direct Costs)

(4) Total Turnkey Cost = Total Indirect Cost + Total Direct Cost + Contingencies

(5) Working Capital<sup>2</sup> = 25% of Total Direct Operating Costs<sup>b</sup>

(6) Land<sup>c</sup>

(7) Total Capital Cost = Total Turnkey + Working Capital + Land

<sup>a</sup>Boiler and each control system costed separately; factors apply to cost of boiler or control system considered; i.e., the engineering cost for the PM control system is 10% of the direct cost of the PM control system.

<sup>b</sup>This equation is used for control device working capital calculations. For boilers, fuel supplies are included so a different equation is used (see Table 2-8).

<sup>c</sup>Land costs are assumed to apply to boilers only (see Section 2.2.1).

TABLE 2-8. WORKING CAPITAL CALCULATIONS FOR BOILERS AND CONTROL DEVICES

---

---

Working Capital (WC)

Boilers - Assume three months of direct annual non-fuel operating costs and one month of fuel costs

$$WC^4 = 0.25 \text{ (Direct annual non-fuel operating costs)} + 0.083 \text{ (Fuel costs)}$$

Control Equipment - Assume three months of direct annual operating costs

$$WC^2 = 0.25 \text{ (Direct annual operating costs)}$$

---

example, FGD algorithms compute total direct costs without prior computation of equipment and installation costs. Also, in certain cases, indirect capital costs, as shown in Table 2-7, are computed as a percentage of the direct costs.

### 2.2.2 Operation and Maintenance (O&M) Costs

Table 2-9 lists the individual O&M cost components and the general methodologies used in calculating total O&M costs. Direct O&M costs include operating and maintenance labor, fuel, utilities, spare parts, supplies, waste disposal and chemicals. Indirect operating costs include payroll and plant overhead and are calculated based on a percentage of some key O&M cost components (direct labor, supervisory labor, maintenance labor and spare parts).

Direct O&M costs for the boilers and control devices are calculated by using the algorithms presented in Appendix A. The key factors in these algorithms are the capacity utilization, utility unit costs (steam electricity, water), and unit costs for raw materials, waste disposal, and labor.

Capacity utilization is defined as the actual annual fuel consumption as a percentage of the potential annual fuel consumption at maximum firing rate. To account for reduced labor costs for boilers operating at reduced capacity utilization, labor factors that are based on capacity utilization are used. Table 2-10 presents the capacity utilizations and labor factor functions used for the boiler and control device O&M cost calculations.

Table 2-11 presents the unit costs used in calculating several of the other key annual O&M cost components for the boilers and control equipment. Some additional factors affecting O&M costs are boiler type, boiler size, fuel type, fuel composition, flue gas flowrate, and control efficiency (see Appendix A).

### 2.2.3 Annualized Costs

Total annualized costs are the sum of the annual O&M costs and the annualized capital charges. The annualized capital charges include the payoff of the capital investment (capital recovery), interest on working capital, general and administrative costs, taxes, and insurance.

TABLE 2-9. OPERATING AND MAINTENANCE COST COMPONENTS<sup>a</sup>

---

(1) Direct Operating Costs

- Direct Labor
- + Supervision
- + Maintenance Labor, Replacement Parts and Supplies
- + Electricity
- + Water
- + Steam
- + Waste Disposal
  - Solids (Fly ash and bottom ash)
  - Sludge
  - Liquid
- + Chemicals
- Total Non-Fuel O&M
- + Fuel
- = Total Direct Operating Costs

---

(2) Indirect Operating Costs (Overhead)<sup>b</sup>

- Payroll (30% Direct Labor)
- + Plant (26% of Direct Labor + Supervision + Maintenance Costs + Spare Parts)

(3) Total Annual Operating and Maintenance Costs = Total Direct +  
    Total Indirect Costs

---

<sup>a</sup>Boilers and each control systems are costed separately; factors apply to boiler or control system being considered, (i.e., payroll overhead for FGD system is 30% direct labor requirement of FGD system).

<sup>b</sup>Factors recommended in Reference 3.

TABLE 2-10. CAPACITY UTILIZATION AND LABOR FACTORS USED FOR MODEL BOILER COST CALCULATIONS

<u>Boiler Type</u>	<u>Capacity Utilization (CF)</u>	<u>Labor Factor (LF)</u>
Coal-fired (Underfeed, spreader stoker, pulverized feed)	0.60	0.75
Residual oil-fired	0.55	0.62
<u>Labor Factor Equations<sup>4</sup></u>		
<u>CF</u>	<u>LF</u>	
>0.7		
0.5 - 0.7	$0.5 + \frac{1}{2.5} (CF - 0.5)$	
<0.5	$\frac{0.5}{CF}$	

TABLE 2-11. UNIT COSTS USED IN CALCULATIONS<sup>a,b</sup>

---

Utilities

Electricity	\$0.0258/kwh
Water	\$0.04/m <sup>3</sup> (\$0.15/10 <sup>3</sup> gal)
Steam	\$3.01/GJ (\$3.5/10 <sup>3</sup> lb)

Raw Material

Na <sub>2</sub> CO <sub>3</sub>	\$0.099/kg (\$90/ton)
Lime	\$0.039/kg (\$35/ton)
Limestone	\$0.009/kg (\$8/ton)

Labor

Direct Labor	\$12.02/man-hour
Supervision	\$15.63/man-hour
Maintenance Labor	\$14.63/man-hour

Waste Disposal

Solids (Ash, Spray Dried Solids)	\$0.166/kg (\$15/ton)
Sludge	\$0.0166/kg (\$15/ton)
Liquid	\$0.47/m <sup>3</sup> (\$1.80/10 <sup>3</sup> gal)

---

<sup>a</sup>All costs in 1978 \$.

<sup>b</sup>Reference 2.

Table 2-12 presents the methods used in this report to calculate the individual annualized capital charges components. The capital recovery cost is determined by multiplying the capital recovery factor, which is based on the real interest rate and the equipment life, by the total turnkey costs (see Table 2-7). For this analysis a 10 percent real interest rate and a 15 year equipment are assumed for the boilers and control equipment. This translates into a capital recovery factor of 13.15 percent. The real interest rate of 10 percent was selected as a typical constant dollar rate of return on investment to provide a basis for calculation of capital recovery charges. Since all costs presented in this report are constant mid-1978 dollars, this interest rate is the "real" interest rate above and beyond inflation (see Appendix D for cost conversions due to inflation).

Table 2-12 also presents the methods to calculate the other annualized capital charges components. Interest on working capital is based on a 10 percent interest rate. The remaining components (general and administrative costs, taxes, and insurance) are estimated as 4 percent of total turnkey costs.

### 2.3 BOILER AND FUEL COSTS

This section presents the specific cost assumptions and methodologies that were used to calculate the industrial boiler costs presented in Chapters 3 and 4. The general costing assumptions and methodologies were presented in Section 2.2. The capital and annual O&M cost algorithms for coal-, oil-, and gas-fired industrial boilers are presented in Appendix A (Tables A-4 through A-11). Specific equipment lists and assumptions used to generate the algorithms are detailed in References 5 and 6.

All boiler costs are based on a new boiler constructed at a new plant in the Midwest and do not include any retrofit costs. It is assumed that new plants will operate multiple boilers rather than one boiler. Annual O&M costs such as labor, utilities, chemicals, spare parts and ash disposal will be reduced per boiler because of the economies of scale. To account for the O&M cost reductions associated with multiple boiler installations,

TABLE 2-12. ANNUALIZED COST COMPONENTS

- 
- (1) Total Annualized Cost = Annual Operating Costs + Capital Charges
  - (2) Capital Charges = Capital recovery + interest on working capital + miscellaneous (G&A, taxes and insurance)
  - (3) Calculation of Capital Charges Components

A. Capital Recovery = Capital Recovery Factor (CRF) x Total Turnkey Cost

$$CRF = \frac{i (1 + i)^n}{(1 + i)^n - 1}$$

i = interest rate

n = number of years of useful life of boiler or control system

<u>Item</u>	<u>n</u>	<u>i</u>	<u>CRF</u>
Boiler, control systems	15	10	0.1315

B. Interest on Working Capital = 10% of working capital

C. G&A, taxes and insurance = 4% of total turnkey cost

---

multipliers for the annual O&M costs are included in the algorithms. These multipliers are presented in Table 2-13.

The boiler specifications presented in Tables 2-14 and 2-15 provide the specifications required to calculate the boiler capital costs presented in this report. Coal-fired units with less than  $60 \times 10^6$  Btu/hr thermal input capacity and oil- and gas-fired units with less than  $200 \times 10^6$  Btu/hr capacity are specified to be package boilers while all other boilers are assumed to be field-erected units. It is also assumed that all boilers are operating under low excess air firing conditions. The flue gas flow rates presented were calculated from the algorithms presented in Appendix A (Table A-23).

The largest O&M cost for boilers is fuel. Table 2-16 presents the specifications and costs for the fuels used in this analysis. The fuel costs presented are consistent with the 1990 delivered fuel price projections (in 1978 dollars) used in the Industrial Fuel Choice Analysis Model (IFCAM). The IFCAM documentation is the source of the coal transportation costs, while the Round 8 Impact Analysis is the basis for fuel prices.<sup>7,8</sup>

#### 2.4 PARTICULATE MATTER (PM) CONTROL COSTS

The algorithms used to calculate capital and operating costs for PM control devices are presented in Appendix A (Tables A-12 through A-18). The cost algorithms for electrostatic precipitators (ESPs), reverse air fabric filters, and venturi wet scrubbers were developed by PEDCo, Inc. Detailed documentation of the cost bases for these controls can be found in PEDCo's final report.<sup>11</sup> The costs for single mechanical collectors and side stream separators were developed by Radian based primarily on vendor information. Documentation of these costs can be found in a technical note and attachments.<sup>12</sup>

Table 2-17 lists the general specifications for the PM control devices investigated. These specifications are typical for industrial boiler control devices currently in use.

TABLE 2-13. DIRECT O&M COST MULTIPLIERS TO ACCOUNT FOR ECONOMIES  
ASSOCIATED WITH MULTIPLE BOILER INSTALLATIONS<sup>4</sup>

<u>Coal-fired boilers:</u>	
	<u>Multiplier</u>
Utilities, chemicals, and ash disposal	0.848
All labor, replacement parts, and overhead	0.767
<u>Residual oil-fired boilers:</u>	
Utilities and chemicals	0.845
All labor, replacement parts, and overhead	0.799

TABLE 2-14. SPECIFICATIONS FOR COAL-FIRED STANDARD BOILERS

	HSC-30	HSC-75	HSC-150	HSC-400	LSC-30	LSC-75	LSC-150	LSC-400
Thermal input $10^6$ Btu/hr	30	75	150	400	30	75	150	400
Fuel firing method	Under feed	Under feed	Spreader stoker	Pulverized feed	Under feed	Under feed	Spreader stoker	Pulverized feed
Excess air, %	35	35	35	35	35	35	35	35
Flue gas flow rate, acfm	11000	27600	55100	142000	11300	28300	56700	146000
Capacity utilization, %	60	60	60	60	60	60	60	60
Efficiency, %	78.0	79.9	80.9	83.1	78.3	80.5	81.5	83.5
Steam production, lb/hr	22700	58200	107000	280000	22800	58800	108044	279200

TABLE 2-15. SPECIFICATIONS FOR RESIDUAL OIL-FIRED STANDARD BOILERS

	RES-30	RES-150
Thermal Input, $10^6$ Btu/hr	30	150
Excess air, %	15	15
Flue gas flow rate, acfm	9010	45000
Capacity Utilization, %	55	55
Efficiency, %	85	85
Steam production, lb/hr	25000	108000

TABLE 2-16. FUEL ANALYSIS AND PRICES<sup>a,b</sup>

Fuel Type	Heating Value Btu/lb	Sulfur Content % by weight	Moisture Content	Ash Content	1990 Delivered Fuel Cost \$/lb <sup>6</sup> Btu (1978 \$)
High sulfur coal	11,800	3.54	8.79	10.54	1.81
Low sulfur coal	9,600	0.60	20.80	5.40	2.41
Residual oil	18,500	3.00	0.08	0.10	4.85

<sup>a</sup>All analyses are based on engineering judgements by PEDCo about information provided by Babcock and Wilcox, References 9 and 10.

<sup>b</sup>All costs are projected 1990 costs in 1978 dollars. Fuel costs are based on the Industrial Fuel Choice Analysis Model (IFCAM) costs.<sup>7,8</sup>

TABLE 2-17. GENERAL DESIGN SPECIFICATIONS FOR PM CONTROL SYSTEMS

Control Device	Item	Specification
Single Mechanical Collectors (SM)	Material of construction	Carbon steel
	Pressure drop <sup>a</sup>	4 in. H <sub>2</sub> O gauge
Side Stream Separators (SSS)	Material of construction	Mechanical collector and fabric filter: carbon steel
	Pressure drop <sup>a</sup>	6 in. H <sub>2</sub> O gauge
	Amount of gas flow treated in fabric filter	20%
	Fabric filter	Multi-compartment pulse-jet with Teflon coated glass felt bags
	Bag life	2 years
Venturi Scrubbers (VS)	Components	Hold tank, recirculation system, and purge stream piping
	Pressure drop <sup>b</sup>	20 in. H <sub>2</sub> O gauge
	Sludge treatment	Scrubber sludge added to coal pile runoff treatment system

TABLE 2-17. (CONTINUED)

Control Device	Item	Specification
Electrostatic Precipitators (ESP)	Material of construction	Carbon steel (insulated)
	Specific collection areas <sup>c</sup> (plate area per <sup>b</sup> gas volume for 0.05 lb/10 <sup>b</sup> Btu control levels)	Underfeed stokers: 117.3 ft <sup>2</sup> /10 <sup>3</sup> acfm Spreader stokers: 189.3 ft <sup>2</sup> /10 <sup>3</sup> acfm Pulverized Coal: 220 ft <sup>2</sup> /10 <sup>3</sup> acfm Oil-fired: 400 ft <sup>2</sup> /10 <sup>3</sup> acfm
	Pressure drop <sup>a</sup>	1 in. H <sub>2</sub> O gauge
	Power demand	3 W/ft <sup>2</sup>
Fabric Filter (FF)	Material of construction	Carbon steel (insulated)
	Cleaning method	Reverse-air (multi-compartment)
	Air to cloth ratio	2 ft/min
	Bag material	Teflon-coated fiberglass
	Bag life	2 years
	Pressure drop <sup>a</sup>	6 in. H <sub>2</sub> O gauge

<sup>a</sup>Pressure drop refers to gas side pressure drop across entire control system.

<sup>b</sup>Pressure drop for variable throat venturi scrubber will vary with required removal efficiency.  
Maximum pressure drop of 20 in. H<sub>2</sub>O was assumed for estimating fan costs.

<sup>c</sup>Values shown are for sulfur content of 3.5% in coal feed to boiler. Boilers firing coals with lower sulfur content have somewhat higher SCA values.

## 2.5 SO<sub>2</sub> CONTROL COSTS

The cost algorithms used to calculate capital and annual operating costs for flue gas desulfurization units are also presented in Appendix A (Tables A-19 through A-22). The cost basis for the double alkali without PM removal, lime spray drying, and once through sodium systems is presented in the Individual Technology Assessment Report (ITAR).<sup>13</sup> Cost algorithms based on the ITAR were developed by Acurex Corporation.<sup>14</sup> The algorithms presented in Appendix A however, do not represent the costs in the final ITAR or the Acurex report for either the double alkali or spray drying systems. The Acurex algorithms were revised to reflect revised clarifier costs for the double alkali systems and revised fabric filter costs for the spray drying systems. These revisions are documented in a technical memo.<sup>11</sup> The sodium throwaway cost algorithms are unchanged from the Acurex report. Costs for the double alkali system designed to remove PM as well as SO<sub>2</sub> were developed by Radian and include a venturi-type scrubber and a single mechanical collector upstream of the scrubber.<sup>15</sup> The costs for the double alkali system design without PM removal is based on the use of a tray-type scrubber.

Table 2-18 presents the general specifications for the FGD systems analyzed in this report. These specifications are typical for FGD systems currently in use.

## 2.6 COMPLIANCE, REPORTING, AND MALFUNCTION COSTS

Table 2-19 presents estimates for compliance, reporting, and control device malfunction costs based on issue papers prepared by Radian.<sup>16,17,18</sup> These costs vary with boiler size and type of control system.

Annual reporting costs for units without FGD reflect "baseline" requirements specified for all new sources; start-up, shutdown, and malfunction reports. It was assumed that units with FGD would also be required to make a quarterly excess emissions report, estimated to add about \$2000 to the baseline cost of \$4800 to \$5000.

Units with FGD were assumed to require continuous monitors for inlet and outlet SO<sub>2</sub> and a diluent (CO<sub>2</sub> or O<sub>2</sub>) monitor. Continuous NO<sub>x</sub> monitoring

TABLE 2-18. GENERAL DESIGN SPECIFICATIONS FOR SO<sub>2</sub> CONTROL SYSTEMS

Control Device	Item	Specification
Double Alkali FGD (SO <sub>2</sub> removal only) (DA <sup>a</sup> )	Scrubber type	Tray tower
	Pressure drop <sup>a</sup>	8 in. H <sub>2</sub> O gauge
	L/G	10 gal/10 <sup>3</sup> acf
	Scrubber sludge	60% solids
	Sludge disposal	Trucked to off-site landfill
Sodium Throwaway FGD (either SO <sub>2</sub> removal only or combined SO <sub>2</sub> & PM removal) (NATH)	Material of construction	316 stainless steel
	Scrubber type	Variable throat venturi
	Pressure drop <sup>a</sup>	8 in. H <sub>2</sub> O gauge
	L/G	10 gal/10 <sup>3</sup> acf
	Wastewater treatment	Treated in existing facility
Double Alkali FGD (SO <sub>2</sub> and PM removal) (DA <sup>a</sup> )	Material of construction	316 stainless steel
	Scrubber type	Variable throat venturi
	System design	Includes 80% efficient single mechanical collector upstream of scrubber

TABLE 2-18. (CONTINUED)

(continued)		
Double Alkali FGD (SO <sub>2</sub> and PM removal)	Pressure drop <sup>a</sup> (over SM and scrubber)	20 in. H <sub>2</sub> O gauge
	L/G	10 gal/10 <sup>3</sup> acf
	Sludge disposal	Dry particulate collected in single mechanical combined with 60% solids scrubber sludge and trucked to off-site landfill
Dry Scrubbing (spray drying, SO <sub>2</sub> and PM removal) (DS)	Material of construction	Carbon steel spray dryer and fabric filter (insulated)
	Reagent	Lime; no solids recycle
	Fabric filter	Reverse-air (same design as previous fabric filter)
	Pressure drop <sup>a</sup>	6 in. H <sub>2</sub> O gauge
	L/G	0.3 gal/acf
	Solids disposal	Trucked to off-site landfill

<sup>a</sup>All pressure drops refer to gas side pressure drop across entire control system.

TABLE 2-19. ANNUAL REPORTING, COMPLIANCE,  
AND MALFUNCTION COSTS

---



---

REPORTING<sup>a</sup>

For units with FGD:

Baseline Annual:	\$4800
Quarterly Excess Emissions:	+ \$1920
	<u>\$6720</u>

For units without FGD:

Baseline Annual:	\$4800
------------------	--------

COMPLIANCE

For units with FGD:

(Continuous) Inlet SO <sub>2</sub>	}	\$63,000
(Continuous) Outlet SO <sub>2</sub>		
Diluent (O <sub>2</sub> /CO <sub>2</sub> )		
Opacity <sup>b</sup>	+ \$10,800	
Continuous NO <sub>x</sub> ( $\geq 250 \times 10^6$ Btu/hr only)	+ \$30,800	
NO <sub>x</sub> Method 7/O <sub>2</sub> ( $< 250 \times 10^6$ Btu/hr only)	+ \$12,000	
Total for $\geq 250 \times 10^6$ Btu/hr w/FGD =	<u>\$105,000</u>	
Total for $< 250 \times 10^6$ Btu/hr w/FGD =	<u>\$86,000</u>	

For units without FGD: ( $< 250 \times 10^6$  Btu/hr)

Method 5 (PM)	\$10,000
Opacity <sup>b</sup>	+ \$10,800
Method 7 (NO <sub>x</sub> )	+ \$ 5,000
Continuous O <sub>2</sub>	+ \$17,700
	<u>\$45,500</u>

MALFUNCTION (for units with FGD only)

Assuming 5% downtime (of FGD system) during which oil is fired.  
Oil/Coal fuel cost differential - \$3/10<sup>6</sup> Btu. (FGD operating costs do  
not reflect downtime. They are calculated on the basis of 100 percent  
FGD system availability).

---

<sup>a</sup>Baseline costs are for general provisions requirements for reporting start-up, shutdown, and malfunction.

<sup>b</sup>Pressure drop meter instead of opacity meter for boilers with combined SO<sub>2</sub>/PM scrubbing or PM wet scrubbing.

was assumed for units with thermal input capacities greater than  $250 \times 10^6$  Btu/hr. Units less than  $250 \times 10^6$  Btu/hr were assumed to combine an annual Method 5 and Method 7 tests and continuous  $\text{O}_2$  monitoring. All boilers were assumed to require an opacity monitor (or a pressure drop meter for boilers equipped with wet scrubbers for PM or combined PM/ $\text{SO}_2$  removal). Malfunction costs are based on the use of low sulfur oil for a downtime period of 5 percent of the total boiler operating hours.

Compliance, reporting, and malfunction costs are not included in the total costs presented in subsequent chapters. The costs presented in Table 2-19 are considered typical of those that might be associated with various regulatory alternatives. However, the requirements of specific regulations will determine the actual costs incurred.

## 2.7 REFERENCES

1. U. S. Environmental Protection Agency. Fossil Fuel Fired Industrial Boilers - Background Information. Volume I. Research Triangle Park, N. C. Publication No. 450/3-82-006a. March 1982. pp. 4-1 - 4-213.
2. Devitt, T., P. Spaite, and L. Gibbs. (PEDCo Environmental) Population and Characteristics of Industrial/Commercial Boilers in the U.S. (Prepared for U. S. Environmental Protection Agency.) Research Triangle Park, N. C. EPA-600/7-79-78a. Cincinnati, Ohio. August 1979. 462 p.
3. Reference 2, p. 117.
4. Letter from Medine, E. S., Energy and Environmental Analysis, Inc. to Short, R., EPA:EAB. September 14, 1981. 6 p. Comparison of IFCAM and Radian Cost Algorithms for SO<sub>2</sub> and PM Control on Coal- and Oil-Fired Industrial Boilers.
5. Reference 2, p. 118.
6. PEDCo Environmental, Inc. Cost Equations for Industrial Boilers. Final report. Prepared for U.S. Environmental Protection Agency. Research Triangle Park, N.C. EPA Contract No. 68-02-3074. January 1980. 22 p.
7. Energy and Environmental Analysis, Inc. Industrial Fuel Choice Analysis Model: Primary Model Documentation. (Prepared for U.S. Environmental Protection Agency.) Research Triangle Park, N.C. EPA Contract No. 68-02-3330. June 1980. 148 p.
8. Energy and Environmental Analysis, Inc. Impact Analysis of Alternative New Source Performance Standards II: Energy, Environmental, and Cost Impacts. (Prepared for U.S. Environmental Protection Agency.) Research Triangle Park, N.C. EPA Contract No. 68-02-3330. December 19, 1980.
9. Useful Tables for Engineers and Steam Users, Thirteenth Edition. New York, Babcock and Wilcox, 1978. p. 39.
10. Steam, Its Generation and Use, 38th Edition. New York, Babcock and Wilcox, 1975. pp. 5-1 to 5-22.
11. PEDCo Environmental, Inc. Capital and Operation Costs of Particulate Controls on Coal- and Oil-Fired Industrial Boilers. (Prepared for U.S. Environmental Protection Agency.) Research Triangle Park, N.C. EPA-450/5-80-009. August 1980. 129 p.

12. Bowen, M.L., (Radian Corporation.) Costs of Mechanical Collectors Applied to Fossil Fuel Fired Industrial Boilers. June 2, 1982. 12 p.
13. Dickerman, J.C. and K.L. Johnson, (Radian Corporation.) Technology Assessment Report for Industrial Boiler Application: Flue Gas Desulfurization. (Prepared for U. S. Environmental Protection Agency.) Research Triangle Park, N. C. EPA-600/7-79-78c. November 1979. 664 p.
14. Gardner, R., R. Chang, and L. Broz. (Acurex Corporation.) Cost, Energy and Environmental Algorithms for NO<sub>x</sub>, SO<sub>2</sub>, and PM Controls for Industrial Boilers. Final Report. (Prepared for U. S. Environmental Protection Agency.) Cincinnati, Ohio. EPA Contract No. 68-03-2567. December 1979. p. 20-52.
15. Memo from Kelly, M. E., Radian Corporation, to Industrial Boiler File. January 21, 1981. 33 p. Summary of Radian cost algorithm development for Industrial Boiler NSPS.
16. Smith, S.A., F.H. Sheffield, and W.R. Menzies. "Issue Paper: Reporting Requirements." Radian Corporation. Durham, N.C. September 1980. 40 p.
17. Dickerman, J.C. and M.E. Kelly. "Issue Paper: Compliance Monitoring Costs." Radian Corporation. Durham, N.C. September 25, 1980. 20 p.
18. Kelly, M.E. and K.L. Johnson. "Issue Paper: Control Equipment Malfunction Provisions." Radian Corporation. Durham, N.C. September 25, 1980. 43 p.

### 3.0 COSTS OF PM AND SO<sub>2</sub> CONTROL FOR COAL-FIRED BOILERS

This section presents the results of the model boiler cost analysis for various PM and SO<sub>2</sub> control technologies applied to coal-fired boilers. This analysis focuses on the capital cost, annual O&M costs, and total annualized cost of control for both HSC and LSC-fired units between  $30 \times 10^6$  Btu/hr and  $400 \times 10^6$  Btu/hr capacity.

Five technologies which control only PM are examined:

- single mechanical collector (SM),
- side stream separator (SSS),
- venturi scrubber (VS),
- electrostatic precipitator (ESP), and
- fabric filter (FF).

The ESP systems are applied to the HSC-fired units while the FF systems are used on the LSC-fired units. This analysis indicates little or no cost advantage for ESP systems compared to FF systems for HSC-fired boilers. Since the costs of FF's are relatively insensitive to fuel properties, the costs for FF's applied to LSC-fired units presented here are believed to be representative of costs for FF's applied to HSC-fired boilers.

Four SO<sub>2</sub> control technologies are also examined:

- dual alkali FGD scrubbing without provisions for PM removal (tray type scrubber),
- dual alkali FGD scrubbing with provisions for PM removal (venturi scrubber),
- lime spray drying FGD (includes a fabric filter), and
- sodium throwaway FGD scrubbing.

The first two technologies are analyzed for both HSC- and LSC-fired units at 50 percent and 90 percent SO<sub>2</sub> removal levels. The lime spray drying system is analyzed at a 50 percent removal level for LSC-fired units only. Sodium throwaway scrubbing is examined for small residual oil-fired units.

All costs in this chapter are presented as 1978 dollars. Coal-fired and residual oil-fired boilers are assumed to have a capacity utilization of 0.6 and 0.55, respectively. All boilers and control equipment are assumed to have a capital recovery factor of 13.15 percent which is based on an equipment life of 15 years and a real interest rate of 10 percent.

This chapter is divided into two sections. The first discusses capital costs while the second discusses annual O&M and total annualized costs.

### 3.1 CAPITAL COSTS OF PM AND SO<sub>2</sub> CONTROLS APPLIED TO COAL-FIRED BOILERS

Tables 3-1 and 3-2 present capital costs for the HSC- and LSC-fired model boilers defined in Chapter 2. The normalized capital costs provide a size independent measure of the capital required to build a boiler and associated pollution control system. This value estimates the capital (\$1000) required per unit of installed heat input capacity ( $10^6$  Btu/hr).

These normalized costs are graphically depicted in Figures 3-1 and 3-2. The larger boilers in the size range presented,  $150-400 \times 10^6$  Btu/hr, do not show the steady decrease in capital costs as expected. This is due to the fact that these boilers are spreader stoker and pulverized feed units and are more complex and capital intensive than the underfeed boilers used in the smaller boiler sizes ( $30$  and  $75 \times 10^6$  Btu/hr).

Also included in Tables 3-1 and 3-2 is the percent increase in capital costs over the uncontrolled model boiler. This data is graphically illustrated in Figures 3-3 and 3-4 for HSC- and LSC-fired model boilers, respectively. Of immediate note is the higher percent increases for HSC-fired units compared to LSC-fired units for the same pollution control systems. The result is due to the lower uncontrolled SO<sub>2</sub> and PM emissions inherent in the burning of LSC. The net result is a reduction in the costs of FGD and PM control systems and lower percent increases over the uncontrolled case for LSC-fired units. Also, the uncontrolled LSC-fired model boilers tend to have higher capital costs than HSC-fired units due to higher working capital requirements associated with the use of more expensive LSC fuel. (See Tables 2-7 and 2-8 for calculation of capital costs and working capital.)

TABLE 3-1. CAPITAL COSTS FOR HSC-FIRED MODEL BOILERS

Model Boiler	Capital Costs (\$1000)					% Increase Over Uncontrolled
	Uncontrolled Boiler	SO <sub>2</sub> Control	PM Control	Total	Normalized Total <sup>a</sup>	
HSC-30-Unc, Unc	1857	0	0	1857	61.9	0
HSC-30-Unc, SM	1857	0	60	1917	63.9	3.2
HSC-30-Unc, SSS	1857	0	105	1962	65.4	5.7
HSC-30-Unc, VS	1857	0	143	2000	66.7	7.7
HSC-30-Unc, ESP	1857	0	225	2082	69.4	12.1
HSC-30-DA(50), DA/PM	1857	862	w/SO <sub>2</sub>	2719	90.6	46.4
HSC-30-DA(50), ESP	1857	721	225	2803	93.4	50.9
HSC-30-DA(90), DA/PM	1857	959.	w/SO <sub>2</sub>	2816	93.9	51.6
HSC-30-DA(90), ESP	1857	829	225	2911	97.0	56.8
HSC-75-Unc, Unc	3380	0	0	3380	45.1	0
HSC-75-Unc, SM	3380	0	118	3498	46.6	3.5
HSC-75-Unc, SSS	3380	0	214	3594	47.9	6.3
HSC-75-Unc, VS	3380	0	252	3632	48.4	7.5
HSC-75-Unc, ESP	3380	0	407	3787	50.5	12.0
HSC-75-DA(50), DA/PM	3380	1183	w/SO <sub>2</sub>	4563	60.8	35.0
HSC-75-DA(50), ESP	3380	1042	407	4829	64.4	42.9
HSC-75-DA(90), DA/PM	3380	1316	w/SO <sub>2</sub>	4696	62.6	38.9
HSC-75-DA(90), ESP	3380	1202	407	4989	66.5	47.6
HSC-150-Unc, Unc	7737	0	0	7737	51.6	0
HSC-150-Unc, SM	7737	0	201	7938	52.9	2.6
HSC-150-Unc, SSS	7737	0	370	8107	54.0	4.8
HSC-150-Unc, VS	7737	0	436	8173	54.5	5.6
HSC-150-Unc, ESP	7737	0	1222	8959	59.7	15.8
HSC-150-DA(50), DA/PM	7737	1599	w/SO <sub>2</sub>	9336	62.2	20.7
HSC-150-DA(50), ESP	7737	1407	1222	10366	69.1	34.0
HSC-150-DA(90), DA/PM	7737	1764	w/SO <sub>2</sub>	9502	63.3	22.8
HSC-150-DA(90), ESP	7737	1625	1222	10584	70.6	36.8
HSC-400-Unc, Unc	18334	0	0	18334	45.8	0
HSC-400-Unc, SM	18334	0	414	18748	46.9	2.3
HSC-400-Unc, SSS	18334	0	784	19118	47.8	4.3
HSC-400-Unc, VS	18334	0	1012	19346	48.4	5.5
HSC-400-Unc, ESP	18334	0	1704	20038	50.1	9.3
HSC-400-DA(50), DA/PM	18334	2516	w/SO <sub>2</sub>	20850	52.1	13.7
HSC-400-DA(50), ESP	18334	2230	1704	22268	55.7	21.5
HSC-400-DA(90), DA/PM	18334	2764	w/SO <sub>2</sub>	21098	52.7	15.1
HSC-400-DA(90), ESP	18334	2576	1704	22614	56.5	23.3

<sup>a</sup>Normalized total is total capital cost divided by boiler capacity (\$1000/10<sup>6</sup> Btu/hr).

TABLE 3-2. CAPITAL COSTS FOR LSC-FIRED MODEL BOILERS

Model Boiler	Uncontrolled Boiler	Capital Costs (\$1000)			Normalized Total <sup>a</sup>	% Increase Over Uncontrolled
		S <sub>0</sub> <sub>2</sub> Control	PM Control	Total		
LSC-30-Unc, Unc	2244	0	0	2244	74.8	0
LSC-30-Unc, SM	2244	0	62	2306	76.9	2.8
LSC-30-Unc, SSS	2244	0	108	2352	78.4	4.8
LSC-30-Unc, VS	2244	0	145	2389	79.6	6.5
LSC-30-Unc, FF	2244	0	234	2478	82.6	10.4
LSC-30-DS(50), DS/PM	2244	622	w/SO <sub>2</sub>	2866	95.5	27.7
LSC-30-DA(50), DA/PM	2244	691	w/SO <sub>2</sub>	2935	97.8	30.8
LSC-30-DA(50), FF	2244	535	234	3013	100.4	34.3
LSC-30-DA(90), DA/PM	2244	745	w/SO <sub>2</sub>	2989	99.6	33.2
LSC-30-DA(90), FF	2244	592	234	3070	102.3	36.8
 LSC-75-Unc, Unc	4079	0	0	4079	54.4	0
LSC-75-Unc, SM	4079	0	121	4200	56.0	3.0
LSC-75-Unc, SSS	4079	0	218	4297	57.3	5.3
LSC-75-Unc, VS	4079	0	257	4336	57.8	6.3
LSC-75-Unc, FF	4079	0	613	4692	62.6	15.0
LSC-75-DS(50), DS/PM	4079	1045	w/SO <sub>2</sub>	5124	68.3	25.6
LSC-75-DA(50), DA/PM	4079	955	w/SO <sub>2</sub>	5034	67.1	23.4
LSC-75-DA(50), FF	4079	773	613	5465	72.9	34.0
LSC-75-DA(90), DA/PM	4079	1027	w/SO <sub>2</sub>	5106	68.1	25.2
LSC-75-DA(90), FF	4079	856	613	5548	74.0	36.0
 LSC-150-Unc, Unc	8334	0	0	8334	55.6	0
LSC-150-Unc, SM	8334	0	206	8540	56.9	2.5
LSC-150-Unc, SSS	8334	0	379	8713	58.1	4.5
LSC-150-Unc, VS	8334	0	446	8780	58.5	5.4
LSC-150-Unc, FF	8334	0	1059	9393	62.6	12.7
LSC-150-DS(50), DS/PM	8334	1637	w/SO <sub>2</sub>	9971	66.5	19.6
LSC-150-DA(50), DA/PM	8334	1358	w/SO <sub>2</sub>	9692	64.6	16.3
LSC-150-DA(50), FF	8334	1048	1059	10441	69.6	25.3
LSC-150-DA(90), DA/PM	8334	1432	w/SO <sub>2</sub>	9766	65.1	17.2
LSC-150-DA(90), FF	8334	1158	1059	10551	70.3	26.6
 LSC-400-Unc, Unc	18990	0	0	18990	47.5	0
LSC-400-Unc, SM	18990	0	417	19407	48.5	2.2
LSC-400-Unc, SSS	18990	0	797	19787	49.5	4.2
LSC-400-Unc, VS	18990	0	1033	20023	50.1	5.4
LSC-400-Unc, FF	18990	0	2139	21129	52.8	11.3
LSC-400-DS(50), DS/PM	18990	3333	w/SO <sub>2</sub>	22323	55.8	17.6
LSC-400-DA(50), DA/PM	18990	2110	w/SO <sub>2</sub>	21100	52.8	11.1
LSC-400-DA(50), FF	18990	1683	2139	22812	57.0	20.1
LSC-400-DA(90), DA/PM	18990	2222	w/SO <sub>2</sub>	21212	53.0	11.7
LSC-400-DA(90), FF	18990	1850	2139	22979	57.4	21.0

<sup>a</sup>Normalized total is total capital cost divided by boiler capacity (\$1000/10<sup>6</sup> Btu/hr).




Figure 3-1. Normalized capital costs for HSC-fired model boilers.




Figure 3-2. Normalized capital costs for LSC-fired model boilers.

L-E




Figure 3-3. Percent increases in capital cost over uncontrolled for HSC-fired model boilers.




Figure 3-4. Percent increases in capital cost over uncontrolled for LSC-fired model boilers.

Costs for single mechanical collectors range from about \$60,000 to \$417,000 for the boiler sizes examined, and in all cases are less than 30 percent of the cost of an ESP or FF. Although more expensive than mechanical collectors, side stream separators are less than 55 percent of the cost of an ESP or FF. Venturi scrubber costs are higher than SSS costs and are typically 65 percent of an ESP or FF cost.

Based on the range of boiler sizes examined, the ESP capital costs appear to show a diseconomy of scale. However, the relatively low costs for the 30 and  $75 \times 10^6$  Btu/hr units are more the result of two factors: (1) the inherently lower emission rate of the underfeed stoker units ( $0.657 \text{ lb}/10^6 \text{ Btu}$  for HSC) relative to the spreader stoker and pulverized units ( $2.54 - 3.81 \text{ lb}/10^6 \text{ Btu}$  for HSC) and (2) the sensitivity of ESP costs to collection efficiency. For example, the specific collection area (SCA) required to control PM emissions to  $0.05 \text{ lb}/10^6 \text{ Btu}$  is about  $117 \text{ ft}^2/10^3 \text{ acfm}$  for an underfeed stoker. But for the same control level, the SCA requirement for a spreader stoker is  $189 \text{ ft}^2/10^3 \text{ acfm}$ . This increased plate area requirement results in a more expensive ESP for the larger boilers on a normalized cost basis.

Unlike ESPs, fabric filter costs are not sensitive to collection efficiency (i.e., for a given controlled emission rate, fabric filter costs are not a function of boiler uncontrolled PM emission rate) and thus do not exhibit capital cost diseconomies of scale. Also, fabric filter costs are not sensitive to fuel sulfur content. As noted in Appendix A (Table A-13), ESP costs are expressed as a function of coal sulfur content as well as collection efficiency. Fly ash from low sulfur coals generally is more difficult to collect than the lower resistivity ash associated with many higher sulfur coals. Thus, a larger ESP collection area may be required, with the results that an ESP is typically more expensive than a fabric filter for LSC-fired boilers.

Figures 3-1 and 3-3 show the least expensive  $\text{SO}_2/\text{PM}$  control system for HSC-fired boilers to be a double alkali FGD system used to remove PM and designed for 50 percent  $\text{SO}_2$  removal. These systems result in cost increases from 14 to 46 percent of the uncontrolled boiler costs, with the percent

increasing as boiler size decreases from 400 to  $30 \times 10^6$  Btu/hr. The cost for the double alkali system designed for PM control and 90 percent  $\text{SO}_2$  removal are about 10 percent higher than those for a 50 percent removal system. The higher design  $\text{SO}_2$  removal efficiency requires larger reagent and sludge waste handling equipment, resulting in a higher capital cost.

The most expensive system for HSC-fired units is a 90 percent FGD system combined with an ESP for PM control. The cost increases over uncontrolled for this control strategy range from 23 to 57 percent of the uncontrolled boiler cost.

As seen in Figures 3-2 and 3-4 (LSC-fired model boilers), capital costs for the 50 percent  $\text{SO}_2$  removal spray drying system are higher than those for a 90 percent  $\text{SO}_2$  removal double alkali system at all but the smallest boiler size. This is attributable to the capital cost of the fabric filter that must be included with the spray drying system to collect fly ash and the product solids generated during  $\text{SO}_2$  removal in the spray dryer. The most expensive system for LSC-fired units is the double alkali FGD system used in combination with a fabric filter. The capital cost of this system ranges from 21 to 37 percent of the uncontrolled boiler costs with the percentage decreasing as boiler size increases from  $30 \times 10^6$  to  $400 \times 10^6$  Btu/hr.

### 3.2 O&M AND TOTAL ANNUALIZED COSTS OF PM AND $\text{SO}_2$ CONTROL APPLIED TO COAL-FIRED BOILERS

Annual O&M costs for HSC- and LSC-fired model boilers are presented in Tables 3-3 and 3-4, respectively. The normalized annual costs provide a size independent measure of the annual O&M cost of the boiler and pollution control system. Normalized annual costs are computed by dividing the annual cost (\$1000/yr) by the annual heat input to the boiler based on the capacity utilization ( $10^6$  Btu/yr). Since a time unit is included in both numerator and denominator, the final unit for normalized annual cost is \$/ $10^6$  Btu.

Total annualized costs, which include annual capital charges, are presented in a similar manner in Tables 3-5 and 3-6. Figures 3-5 and 3-6 provide a bar-chart representation of the normalized total annualized costs. On an annualized basis, the uncontrolled boilers show a smooth step down in

TABLE 3-3. ANNUAL O&amp;M COSTS FOR HSC-FIRED MODEL BOILERS

Model Boiler	Annual O&M Costs (\$1000/yr)					Normalized Total <sup>a</sup>	% Increase Over Uncontrolled
	Uncontrolled Boiler	SO <sub>2</sub> Control	PM Control	Total			
HSC-30-Unc, Unc	649	0	0	649	4.12	0	
HSC-30-Unc, SM	649	0	18.3	667	4.23	2.8	
HSC-30-Unc, SSS	649	0	27.0	676	4.29	4.2	
HSC-30-Unc, VS	649	0	33.3	682	4.32	5.1	
HSC-30-Unc, ESP	649	0	32.3	681	4.32	4.9	
HSC-30-DA(50), DA/PM	649	265	w/SO <sub>2</sub>	914	5.80	40.8	
HSC-30-DA(50), ESP	649	253	32.3	934	5.92	43.9	
HSC-30-DA(90), DA/PM	649	289	w/SO <sub>2</sub>	938	5.95	44.5	
HSC-30-DA(90), ESP	649	277	32.3	958	6.08	47.6	
HSC-75-Unc, Unc	1382	0	0	1382	3.51	0	
HSC-75-Unc, SM	1382	0	25.2	1407	3.57	1.8	
HSC-75-Unc, SSS	1382	0	38.6	1421	3.60	2.8	
HSC-75-Unc, VS	1382	0	55.9	1438	3.65	4.1	
HSC-75-Unc, ESP	1382	0	41.3	1423	3.61	3.0	
HSC-75-DA(50), DA/PM	1382	327	w/SO <sub>2</sub>	1709	4.34	23.7	
HSC-75-DA(50), ESP	1382	310	41.3	1733	4.40	25.4	
HSC-75-DA(90), DA/PM	1382	379	w/SO <sub>2</sub>	1761	4.47	27.4	
HSC-75-DA(90), ESP	1382	365	41.3	1788	4.54	29.4	
HSC-150-Unc, Unc	2204	0	0	2204	2.80	0	
HSC-150-Unc, SM	2204	0	47.2	2251	2.86	2.1	
HSC-150-Unc, SSS	2204	0	69.5	2274	2.88	3.2	
HSC-150-Unc, VS	2204	0	104	2308	2.93	4.7	
HSC-150-Unc, ESP	2204	0	73.7	2278	2.89	3.4	
HSC-150-DA(50), DA/PM	2204	434	w/SO <sub>2</sub>	2638	3.35	19.7	
HSC-150-DA(50), ESP	2204	394	73.7	2672	3.39	21.2	
HSC-150-DA(90), DA/PM	2204	533	w/SO <sub>2</sub>	2737	3.47	24.2	
HSC-150-DA(90), ESP	2204	496	73.7	2774	3.52	25.9	
HSC-400-Unc, Unc	5603	0	0	5603	2.67	0	
HSC-400-Unc, SM	5603	0	120	5723	2.72	2.1	
HSC-400-Unc, SSS	5603	0	177	5780	2.75	3.2	
HSC-400-Unc, VS	5603	0	262	5865	2.79	4.7	
HSC-400-Unc, ESP	5603	0	177	5780	2.75	3.2	
HSC-400-DA(50), DA/PM	5603	757	w/SO <sub>2</sub>	6360	3.03	13.5	
HSC-400-DA(50), ESP	5603	644	177	6424	3.06	14.7	
HSC-400-DA(90), DA/PM	5603	1008	w/SO <sub>2</sub>	6611	3.14	18.0	
HSC-400-DA(90), ESP	5603	899	177	6679	3.18	19.2	

<sup>a</sup>Normalized total is total O&M cost divided by annual heat input (\$/10<sup>6</sup> Btu).

TABLE 3-4. ANNUAL O&amp;M COSTS FOR LSC-FIRED MODEL BOILERS

Model Boiler	Annual O&M Costs (\$1000/yr)				Normalized Total <sup>a</sup>	% Increase Over Uncontrolled
	Uncontrolled Boiler	SO <sub>2</sub> Control	PM Control	Total		
LSC-30-Unc, Unc	758	0	0	758	4.81	0
LSC-30-Unc, SM	758	0	18.5	777	4.93	2.5
LSC-30-Unc, SSS	758	0	27.3	785	4.98	3.6
LSC-30-Unc, VS	758	0	33.5	792	5.02	4.5
LSC-30-Unc, FF	758	0	39.9	798	5.06	5.3
LSC-30-DS(50), DS/PM	758	238	w/SO <sub>2</sub>	996	6.32	31.4
LSC-30-DA(50), DA/PM	758	238	w/SO <sub>2</sub>	996	6.32	31.4
LSC-30-DA(50), FF	758	224	39.9	1022	6.48	34.8
LSC-30-DA(90), DA/PM	758	245	w/SO <sub>2</sub>	1003	6.36	32.3
LSC-30-DA(90), FF	758	232	39.9	1030	6.53	35.9
LSC-75-Unc, Unc	1642	0	0	1642	4.17	0
LSC-75-Unc, SM	1642	0	25.8	1668	4.23	1.6
LSC-75-Unc, SSS	1642	0	39.3	1681	4.26	2.4
LSC-75-Unc, VS	1642	0	56.3	1698	4.31	3.4
LSC-75-Unc, FF	1642	0	60.6	1703	4.32	3.7
LSC-75-DS(50), DS/PM	1642	264	w/SO <sub>2</sub>	1906	4.84	16.1
LSC-75-DA(50), DA/PM	1642	271	w/SO <sub>2</sub>	1913	4.85	16.5
LSC-75-DA(50), FF	1642	251	60.6	1954	4.96	19.0
LSC-75-DA(90), DA/PM	1642	284	w/SO <sub>2</sub>	1926	4.89	17.3
LSC-75-DA(90), FF	1642	266	60.6	1969	4.99	19.9
LSC-150-Unc, Unc	2671	0	0	2671	3.39	0
LSC-150-Unc, SM	2671	0	50.9	2722	3.45	1.9
LSC-150-Unc, SSS	2671	0	73.5	2745	3.48	2.8
LSC-150-Unc, VS	2671	0	107	2778	3.52	4.0
LSC-150-Unc, FF	2671	0	109	2780	3.53	4.1
LSC-150-DS(50), DS/PM	2671	317	w/SO <sub>2</sub>	2988	3.79	11.9
LSC-150-DA(50), DA/PM	2671	340	w/SO <sub>2</sub>	3011	3.82	12.7
LSC-150-DA(50), FF	2671	288	109	3068	3.89	14.9
LSC-150-DA(90), DA/PM	2671	362	w/SO <sub>2</sub>	3033	3.85	13.6
LSC-150-DA(90), FF	2671	313	109	3093	3.92	15.8
LSC-400-Unc, Unc	6856	0	0	6856	3.26	0
LSC-400-Unc, SM	6856	0	98.5	6955	3.31	1.4
LSC-400-Unc, SSS	6856	0	156	7012	3.34	2.3
LSC-400-Unc, VS	6856	0	240	7096	3.38	3.5
LSC-400-Unc, FF	6856	0	239	7095	3.37	3.5
LSC-400-DS(50), DS/PM	6856	451	w/SO <sub>2</sub>	7307	3.47	6.6
LSC-400-DA(50), DA/PM	6856	484	w/SO <sub>2</sub>	7340	3.49	7.1
LSC-400-DA(50), FF	6856	389	239	7484	3.56	9.2
LSC-400-DA(90), DA/PM	6856	538	w/SO <sub>2</sub>	7394	3.52	7.8
LSC-400-DA(90), FF	6856	446	239	7541	3.59	10.0

<sup>a</sup>Normalized total is total O&M cost divided by annual heat input (\$/10<sup>6</sup> Btu).

TABLE 3-5. TOTAL ANNUALIZED COSTS FOR HSC-FIRED MODEL BOILERS

Model Boiler	Annualized Costs (\$1000/yr)				Normalized Total <sup>a</sup>	% Increase Over Uncontrolled
	Uncontrolled Boiler	SO <sub>2</sub> Control	PM Control	Total		
HSC-30-Unc, Unc	961	0	0	961	6.09	0
HSC-30-Unc, SM	961	0	28.4	989	6.27	2.9
HSC-30-Unc, SSS	961	0	44.7	1006	6.38	4.7
HSC-30-Unc, VS	961	0	57.4	1018	6.46	5.9
HSC-30-Unc, ESP	961	0	70.5	1032	6.54	7.4
HSC-30-DA(50), DA/PM	961	410	w/SO <sub>2</sub>	1371	8.69	42.7
HSC-30-DA(50), ESP	961	373	70.5	1405	8.91	46.2
HSC-30-DA(90), DA/PM	961	450	w/SO <sub>2</sub>	1411	8.95	46.8
HSC-30-DA(90), ESP	961	416	70.5	1448	9.18	50.7
HSC-75-Unc, Unc	1948	0	0	1948	4.94	0
HSC-75-Unc, SM	1948	0	45.2	1993	5.05	2.3
HSC-75-Unc, SSS	1948	0	74.7	2023	5.13	3.8
HSC-75-Unc, VS	1948	0	98.3	2046	5.19	5.0
HSC-75-Unc, ESP	1948	0	111	2059	5.22	5.7
HSC-75-DA(50), DA/PM	1948	525	w/SO <sub>2</sub>	2473	6.27	27.0
HSC-75-DA(50), ESP	1948	485	111	2544	6.45	30.6
HSC-75-DA(90), DA/PM	1948	600	w/SO <sub>2</sub>	2548	6.46	30.8
HSC-75-DA(90), ESP	1948	566	111	2625	6.66	34.8
HSC-150-Unc, Unc	3511	0	0	3511	4.45	0
HSC-150-Unc, SM	3511	0	80.9	3592	4.56	2.3
HSC-150-Unc, SSS	3511	0	132	3643	4.62	3.8
HSC-150-Unc, VS	3511	0	177	3688	4.68	5.0
HSC-150-Unc, ESP	3511	0	282	3793	4.81	8.0
HSC-150-DA(50), DA/PM	3511	702	w/SO <sub>2</sub>	4213	5.34	20.0
HSC-150-DA(50), ESP	3511	630	282	4423	5.61	26.0
HSC-150-DA(90), DA/PM	3511	828	w/SO <sub>2</sub>	4339	5.50	23.6
HSC-150-DA(90), ESP	3511	768	282	4561	5.79	29.9
HSC-400-Unc, Unc	8699	0	0	8699	4.14	0
HSC-400-Unc, SM	8699	0	189	8888	4.23	2.2
HSC-400-Unc, SSS	8699	0	309	9008	4.28	3.6
HSC-400-Unc, VS	8699	0	432	9131	4.34	5.0
HSC-400-Unc, ESP	8699	0	466	9165	4.36	5.4
HSC-400-DA(50), DA/PM	8699	1177	w/SO <sub>2</sub>	9876	4.70	13.5
HSC-400-DA(50), ESP	8699	1016	466	10181	4.84	17.0
HSC-400-DA(90), DA/PM	8699	1466	w/SO <sub>2</sub>	10165	4.83	16.9
HSC-400-DA(90), ESP	8699	1327	466	10492	4.99	20.6

<sup>a</sup>Normalized total is total annual cost divided by annual heat input (\$/10<sup>6</sup> Btu).

TABLE 3-6. TOTAL ANNUALIZED COSTS FOR LSC-FIRED MODEL BOILERS

3-14

Model Boiler	Annualized Costs (\$1000/yr)				Normalized Total <sup>a</sup>	% Increase Over Uncontrolled
	Uncontrolled Boiler	SO <sub>2</sub> Control	PM Control	Total		
LSC-30-Unc, Unc	1136	0	0	1136	7.20	0
LSC-30-Unc, SM	1136	0	28.9	1165	7.39	2.6
LSC-30-Unc, SSS	1136	0	45.3	1181	7.49	4.0
LSC-30-Unc, VS	1136	0	57.9	1194	7.57	5.1
LSC-30-Unc, FF	1136	0	79.5	1216	7.71	7.0
LSC-30-DS(50), DS/PM	1136	342	w/SO <sub>2</sub>	1478	9.37	30.1
LSC-30-DA(50), DA/PM	1136	353	w/SO <sub>2</sub>	1489	9.44	31.1
LSC-30-DA(50), FF	1136	313	79.5	1529	9.70	34.6
LSC-30-DA(90), DA/PM	1136	370	w/SO <sub>2</sub>	1506	9.55	32.6
LSC-30-DA(90), FF	1136	330	79.5	1546	9.80	36.1
 LSC-75-Unc, Unc	2326	0	0	2326	5.90	0
LSC-75-Unc, SM	2326	0	46.2	2372	6.02	2.0
LSC-75-Unc, SSS	2326	0	76.2	2402	6.09	3.3
LSC-75-Unc, VS	2326	0	99.5	2426	6.15	4.3
LSC-75-Unc, FF	2326	0	165	2491	6.32	7.1
LSC-75-DS(50), DS/PM	2326	440	w/SO <sub>2</sub>	2766	7.02	18.9
LSC-75-DA(50), DA/PM	2326	431	w/SO <sub>2</sub>	2757	6.99	18.5
LSC-75-DA(50), FF	2326	381	165	2872	7.29	23.5
LSC-75-DA(90), DA/PM	2326	457	w/SO <sub>2</sub>	2783	7.06	19.6
LSC-75-DA(90), FF	2326	409	165	2900	7.36	24.7
 LSC-150-Unc, Unc	4078	0	0	4078	5.17	0
LSC-150-Unc, SM	4078	0	85.4	4163	5.28	2.1
LSC-150-Unc, SSS	4078	0	137	4215	5.35	3.4
LSC-150-Unc, VS	4078	0	182	4260	5.40	4.5
LSC-150-Unc, FF	4078	0	289	4367	5.54	7.1
LSC-150-DS(50), DS/PM	4078	594	w/SO <sub>2</sub>	4672	5.93	14.6
LSC-150-DA(50), DA/PM	4078	568	w/SO <sub>2</sub>	4646	5.89	13.9
LSC-150-DA(50), FF	4078	464	289	4831	6.13	18.5
LSC-150-DA(90), DA/PM	4078	603	w/SO <sub>2</sub>	4681	5.94	14.8
LSC-150-DA(90), FF	4078	507	289	4875	6.78	19.5
 LSC-400-Unc, Unc	10056	0	0	10056	4.78	0
LSC-400-Unc, SM	10056	0	169	10225	4.86	1.7
LSC-400-Unc, SSS	10056	0	290	10346	4.92	2.9
LSC-400-Unc, VS	10056	0	413	10469	4.98	4.1
LSC-400-Unc, FF	10056	0	602	10658	5.07	6.0
LSC-400-DS(50), DS/PM	10056	1016	w/SO <sub>2</sub>	11072	5.27	10.1
LSC-400-DA(50), DA/PM	10056	839	w/SO <sub>2</sub>	10895	5.18	8.3
LSC-400-DA(50), FF	10056	672	602	11330	5.39	12.7
LSC-400-DA(90), DA/PM	10056	911	w/SO <sub>2</sub>	10967	5.22	9.1
LSC-400-DA(90), FF	10056	756	602	11414	5.43	13.5

<sup>a</sup>Normalized total is total annual cost divided by annual heat input (\$/10<sup>6</sup> Btu).




Figure 3-5. Normalized annualized costs for HSC-fired model boilers.




Figure 3-6. Normalized annualized costs for LSC-fired model boilers.

normalized costs with boiler size indicating economies of scale with larger boilers.

Finally, Figures 3-7 and 3-8 provide plots of percent increases in annualized costs over uncontrolled as a function of boiler size. As was noted in capital costs, the LSC-fired model boilers show lower percent increases for all control strategies. In annual costs, the higher cost of LSC compared to HSC is strongly evident, resulting in much higher costs for the uncontrolled cases. This results in lower percent increases in costs for controlled LSC-fired model boilers for each control scheme.

Mechanical collectors and side stream separators are the least expensive control devices on an annualized cost basis as well as a capital cost basis. The ESP costs again exhibit a slight apparent diseconomy of scale due to the difference in boiler uncontrolled PM emission rates. This is primarily due to the capital cost difference being carried over in the capital charges component of annualized costs.

The application of an FGD system to an HSC-fired boiler results in at least a 13 percent increase in annualized costs over the uncontrolled boiler. Unlike the costs for PM control technologies, however, FGD costs are a fairly strong function of size below about  $250 \times 10^6$  Btu/hr. For example, an FGD system used to remove PM and designed for 50 percent SO<sub>2</sub> removal for HSC-firing results in about a 20 percent increase in steam costs for a  $150 \times 10^6$  Btu/hr unit. But the same system applied to a  $30 \times 10^6$  Btu/hr unit results in a 43 percent increase over uncontrolled. The largest percent increases due to FGD costs are observed for small boilers.

The difference in the percent increase in annualized costs over uncontrolled between 50 and 90 percent SO<sub>2</sub> removal FGD systems is about 3 to 4 percent for all HSC-fired boiler sizes. This translates into annual savings of from \$40,000/yr for a  $30 \times 10^6$  Btu/hr unit to about \$289,000/yr for a  $400 \times 10^6$  Btu/hr unit. The savings result from (1) reduced capital charges associated with the smaller reagent and sludge handling facilities for the 50 percent system, (2) reduced sludge volumes to be disposed of, and (3) reduced reagent consumption.




Figure 3-7. Percent increases in annualized cost over uncontrolled for HSC-fired model boilers.




Figure 3-8. Percent increases in annualized cost over uncontrolled for LSC-fired model boilers.

Figure 3-7 indicates that a 90 percent removal FGD system used in combination with an ESP on a HSC-fired model boiler results in annualized costs increases over uncontrolled of 21 percent for a  $400 \times 10^6$  Btu/hr unit to 51 percent for a  $30 \times 10^6$  Btu/hr unit. Percent cost increases for  $400 \times 10^6$  Btu/hr boilers controlled by FGD/ESP are approximately equivalent to increases attributed to combined  $\text{SO}_2/\text{PM}$  FGD systems at the  $150 \times 10^6$  Btu/hr capacity.

For the range of LSC-fired model boilers examined, the annualized costs of applying a double alkali FGD system to remove both PM and  $\text{SO}_2$  (90 percent  $\text{SO}_2$  removal) are roughly equal to the costs of a lime spray drying/fabric filter system designed for 50 percent  $\text{SO}_2$  removal. As discussed earlier, the spray drying system includes a fabric filter and is therefore more expensive than the double alkali scrubber on a capital costs basis. However, this difference in capital charges is somewhat balanced by the reduced waste disposal and reagent costs associated with the spray drying system.

A double alkali system (90 percent  $\text{SO}_2$  removal) used in combination with a fabric filter results in the largest percentage increase over uncontrolled for the  $\text{SO}_2/\text{PM}$  systems applied to LSC-fired boilers. Use of this control strategy results in increases over uncontrolled of from 13 percent for a  $400 \times 10^6$  Btu/hr pulverized coal boiler to 36 percent for a  $30 \times 10^6$  Btu/hr underfeed stoker.

## 4.0 COSTS OF PM AND SO<sub>2</sub> CONTROL FOR RESIDUAL OIL-FIRED BOILERS

This chapter presents the results of the model boiler cost analysis of various PM and SO<sub>2</sub> control technologies applied to residual oil-fired boilers. Capital costs are presented in the first portion of the chapter, while annual O&M and annualized costs are discussed in the second portion. Two sizes of residual oil-fired model boilers are evaluated: 30 and  $150 \times 10^6$  Btu/hr. In addition to the uncontrolled case, costs are presented for (1) the use of an ESP, (2) the use of a double alkali FGD system for PM and SO<sub>2</sub> removal (50 and 90 percent), and (3) the use of a double alkali system (50 and 90 percent SO<sub>2</sub> removal) and an ESP. For the small  $30 \times 10^6$  Btu/hr size the costs for a sodium throwaway system (50 and 90 percent SO<sub>2</sub> removal) used alone or with an ESP are also presented. Use of sodium throwaway systems is especially suited to oil-field steam generators used for thermal enhanced oil recovery. In these applications, the waste liquor can generally be reused, thus eliminating expensive treatment processes that would otherwise make the sodium throwaway system uneconomical in comparison to a double alkali system.

### 4.1 CAPITAL COSTS OF PM AND SO<sub>2</sub> CONTROLS APPLIED TO RESIDUAL OIL-FIRED BOILERS

Table 4-1 presents capital costs for the residual oil-fired model boilers defined in Chapter 2. Normalized costs, shown in the sixth column of the table, are a measure of the total capital investment (\$1,000) per unit of installed heat input capacity ( $10^6$  Btu/hr). The normalized capital costs are graphically depicted in Figure 4-1.

The most expensive control system is the double alkali FGD system used with an ESP, followed by the use of a double alkali system used to remove both SO<sub>2</sub> and PM. The capital costs of the sodium throwaway system applied to the  $30 \times 10^6$  Btu/hr unit are substantially less than for the double alkali systems since no solids handling equipment is required for the sodium throwaway system.

TABLE 4-1. CAPITAL COSTS FOR RESIDUAL OIL-FIRED MODEL BOILERS

	Capital Costs (\$1000)				Normalized Total <sup>a</sup>	% Increase Over Uncontrolled
	Uncontrolled Boiler	SO <sub>2</sub> Control	PM Control	Total		
RES-30-Unc, Unc	577	0	0	577	19.23	0
RES-30-Unc, ESP	577	0	396	973	32.43	68.6
RES-30-NATH(50), NATH/PM	577	361	w/SO <sub>2</sub>	938	31.27	62.6
RES-30-NATH(50), ESP	577	361	396 <sup>2</sup>	1334	44.47	131.2
RES-30-NATH(90), NATH/PM	577	391	w/SO <sub>2</sub>	968	32.27	67.8
RES-30-NATH(90), ESP	577	391	396 <sup>2</sup>	1364	45.47	136.4
RES-30-DA(90), DA/PM	577	832	w/SO <sub>2</sub>	1409	46.97	144.2
RES-30-DA(90), ESP	577	694	396 <sup>2</sup>	1667	55.57	188.9
RES-150-Unc, Unc	2126	0	0	2126	141.17	0
RES-150-Unc, ESP	2126	0	1055	3181	21.21	49.6
RES-150-DA(50), DA/PM	2126	1338	w/SO <sub>2</sub>	3464	23.09	62.9
RES-150-DA(50), ESP	2126	1174	1055 <sup>2</sup>	4355	29.03	104.8
RES-150-DA(90), DA/PM	2126	1475	w/SO <sub>2</sub>	3601	24.01	69.4
RES-150-DA(90), ESP	2126	1338	1055 <sup>2</sup>	4519	30.13	112.6

<sup>a</sup>\$1000/10<sup>6</sup> Btu/hr.




Figure 4-1. Normalized capital costs for residual oil-fired model boilers.

Capital cost increases over uncontrolled for the double alkali/ESP system range from 105 percent for 50 percent SO<sub>2</sub> control on a  $150 \times 10^6$  Btu/hr unit to 189 percent for 90 percent SO<sub>2</sub> control on a  $30 \times 10^6$  Btu/hr model. These large percent increases over uncontrolled are primarily due to the low capital cost of the boilers. Capital costs for an ESP are 50 percent over uncontrolled for the  $150 \times 10^6$  Btu/hr unit and 69 percent for the  $30 \times 10^6$  Btu/hr boiler.

#### 4.2 O&M AND TOTAL ANNUALIZED COSTS OF PM AND SO<sub>2</sub> CONTROL FOR OIL-FIRED BOILERS

Annual O&M costs for the residual oil-fired model boilers are presented in Table 4-2 while total annualized costs (including capital charge components) are shown in Table 4-3. The normalized annualized costs are presented graphically in Figure 4-2. This figure gives an indication of the economies of scale associated with the annualized costs of boilers and control systems.

The annualized cost impact of control over uncontrolled is less for the  $150 \times 10^6$  Btu/hr boilers than the  $30 \times 10^6$  Btu/hr boiler. This occurs because of the apparent economies of scale with the larger  $150 \times 10^6$  Btu/hr boiler and the associated control equipment. The double alkali/ESP system (the most expensive system on an annualized as well as a capital cost basis) results in a 20 and 47 percent increase over uncontrolled. The use of an ESP without SO<sub>2</sub> control results in a 5 and 10 percent increase in costs for the two boiler sizes evaluated.

TABLE 4-2. ANNUAL O&M COSTS FOR RESIDUAL OIL-FIRED MODEL BOILERS

	Annual O&M Costs (\$1000/yr)				Normalized Total <sup>a</sup>	% Increase Over Uncontrolled
	Uncontrolled Boiler	SO <sub>2</sub> Control	PM Control	Total		
RES-30-Unc, Unc	894	0	0	894	6.19	0
RES-30-Unc, ESP	894	0	28.4	922	6.38	3.1
RES-30-NATH(50), NATH/PM	894	237	w/SO <sub>2</sub>	1131	7.82	26.5
RES-30-NATH(50), ESP	894	237	28.4	1159	8.02	29.6
RES-30-NATH(90), NATH/PM	894	259	w/SO <sub>2</sub>	1153	7.98	29.0
RES-30-NATH(90), ESP	894	259	28.4	1181	8.17	32.1
RES-30-DA(90), DA/PM	894	259	w/SO <sub>2</sub>	1153	7.98	29.0
RES-30-DA(90), ESP	894	248	28.4	1170	8.09	30.9
RES-150-Unc, Unc	3863	0	0	3863	5.35	0
RES-150-Unc, ESP	3863	0	51.8	3915	5.42	1.3
RES-150-DA(50), DA/PM	3863	341	w/SO <sub>2</sub>	4204	5.82	8.8
RES-150-DA(50), ESP	3863	322	51.8	4237	5.86	9.7
RES-150-DA(90), DA/PM	3863	392	w/SO <sub>2</sub>	4255	5.89	10.1
RES-150-DA(90), ESP	3863	374	51.8	4289	5.93	11.0

<sup>a</sup>\$/10<sup>6</sup> Btu.

TABLE 4-3. TOTAL ANNUALIZED COSTS FOR RESIDUAL OIL-FIRED MODEL BOILERS

	Annualized Costs (\$1000/yr)				Normalized Total <sup>a</sup>	% Increase Over Uncontrolled
	Uncontrolled Boiler	SO <sub>2</sub> Control	PM Control	Total		
RES-30-Unc, Unc	986	0	0	986	6.82	0
RES-30-Unc, ESP	986	0	95.9	1082	7.49	9.7
RES-30-NATH(50), NATH/PM	986	296	w/ SO <sub>2</sub>	1282	8.87	30.0
RES-30-NATH(50), ESP	986	296	95 <sup>2</sup> .9	1378	9.53	39.8
RES-30-NATH(90), NATH/PM	986	322	w/ SO <sub>2</sub>	1308	9.05	32.7
RES-30-NATH(90), ESP	986	322	95 <sup>2</sup> .9	1404	9.71	42.4
RES-30-DA(90), DA/PM	986	399	w/ SO <sub>2</sub>	1385	9.58	40.5
RES-30-DA(90), ESP	986	364	95 <sup>2</sup> .9	1446	10.00	46.7
RES-150-Unc, Unc	4202	0	0	4202	5.81	0
RES-150-Unc, ESP	4202	0	232	4434	6.14	5.5
RES-150-DA(50), DA/PM	4202	566	w/ SO <sub>2</sub>	4768	6.60	13.5
RES-150-DA(50), ESP	4202	519	232 <sup>2</sup>	4953	6.85	17.9
RES-150-DA(90), DA/PM	4202	639	w/ SO <sub>2</sub>	4841	6.70	15.2
RES-150-DA(90), ESP	4202	598	232 <sup>2</sup>	5032	6.96	19.8

<sup>a</sup>\$/10<sup>6</sup> Btu.




Figure 4-2. Normalized annualized costs for residual oil-fired model boilers.

## 5.0 NO<sub>x</sub> CONTROL COSTS

Chapter five presents the methodology and bases for calculating the cost of NO<sub>x</sub> control on industrial boilers firing coal, residual oil, distillate oil, and natural gas. Four types of NO<sub>x</sub> control (combustion modifications) are analyzed; low excess air (LEA), staged combustion air (SCA), flue gas recirculation (FGR), and reduced air preheat (RAP).

Cost algorithms are used in this chapter to calculate the cost of NO<sub>x</sub> control. Section 5.1 presents the boiler cases that will be analyzed. In addition, the emission reduction achievable with these controls will be presented. Section 5.2 discusses the sources and bases of the NO<sub>x</sub> control cost algorithms. Finally, Section 5.3 presents the calculated capital, annual operating and maintenance (O&M), and annualized costs for the four types of NO<sub>x</sub> controls applied to the boiler cases presented in Section 5.1.

### 5.1 SELECTION OF NO<sub>x</sub> CONTROL CASES

Table 5-1 presents the control cases selected for the NO<sub>x</sub> control cost analysis. The boilers selected represent the range of boiler sizes expected to be built for each fuel type. Table 5-1 also presents the NO<sub>x</sub> controls that are applicable to each boiler type and the achievable NO<sub>x</sub> emission reduction.

### 5.2 COST CALCULATION APPROACH

The costs presented in this chapter are the incremental costs for NO<sub>x</sub> control and are presented in mid-1978 dollars. The costs for each NO<sub>x</sub> combustion modification are calculated and presented in terms of:

- Capital costs of the control
- Annual operating and maintenance (O&M) costs due to the application of the control
- Annualized costs (annual O&M costs plus capital related charges)

TABLE 5-1. NO<sub>x</sub> CONTROL CASES AND EMISSION LEVELS<sup>1,2,3</sup>

Control Case	Emissions lb/10 <sup>6</sup> Btu		Removal Efficiency (Percent)
	Uncontrolled <sup>b</sup>	Controlled	
<u>Coal<sup>a</sup></u>			
UNDR-30-LEA	0.40	0.32	20
UNDR-75-LEA	0.40	0.32	20
SPRD-150-LEA	0.64	0.50	22
SPRD-250-LEA	0.64	0.50	22
PLVR-150-LEA	0.90	0.76	16
PLVR-150-SCA	0.90	0.58	36
PLVR-250-LEA	0.90	0.76	16
PLVR-250-SCA	0.90	0.58	36
PLVR-400-LEA	0.90	0.76	16
PLVR-400-SCA	0.90	0.58	36
<u>0.2 Weight % Nitrogen Residual Oil</u>			
RES-30-LEA	0.29	0.26	10
RES-150-LEA	0.29	0.26	10
RES-250-LEA	0.29	0.26	10
<u>0.4 Weight % Nitrogen Residual Oil</u>			
RES-30-LEA	0.43	0.40	7
RES-30-SCA	0.43	0.24	42
RES-150-LEA	0.43	0.40	7
RES-150-SCA	0.43	0.24	42
RES-250-LEA	0.43	0.40	7
RES-250-SCA	0.43	0.24	42

TABLE 5-1. (Continued)

Control Case	Emissions lb/ $10^6$ Btu		Removal Efficiency (Percent)
	Uncontrolled <sup>b</sup>	Controlled	
<u>Distillate Oil</u>			
DIS-30-LEA	0.25	0.16	36
DIS-30-FGR	0.25	0.19	24
DIS-30-RAP <sup>c</sup>	0.25	0.19	24
DIS-150-LEA	0.25	0.16	36
DIS-150-FGR	0.25	0.19	24
DIS-150-RAP <sup>c</sup>	0.25	0.19	24
DIS-250-LEA	0.25	0.16	36
DIS-250-FGR	0.25	0.19	24
DIS-250-RAP <sup>c</sup>	0.25	0.19	24
<u>Natural Gas</u>			
NG-30-LEA	0.26	0.22	15
NG-30-FGR	0.26	0.18	31
NG-30-RAP	0.26	0.18	31
NG-150-LEA	0.26	0.22	15
NG-150-FGR	0.26	0.18	31
NG-150-RAP <sup>c</sup>	0.26	0.18	31
NG-400-LEA	0.26	0.22	15
NG-400-FGR	0.26	0.18	31
NG-400-RAP <sup>c</sup>	0.26	0.18	31

<sup>a</sup>All coal-fired boilers fire high sulfur coal.

<sup>b</sup>Uncontrolled boilers employ combustion air preheaters which preheat combustion air to 300°F.

<sup>c</sup>RAP boilers do not employ air preheaters and use ambient combustion air (77°F).

As with the boiler, PM control, and SO<sub>2</sub> control costs, the costs of NO<sub>x</sub> control are estimated by the use of cost algorithms. These algorithms present particular NO<sub>x</sub> control cost components as a function of key system specifications. Tables A-24 through A-28 of Appendix A present a listing of the algorithms for each NO<sub>x</sub> control analyzed in this chapter. The development and cost bases for these algorithms are presented in a Radian technical memorandum.<sup>4</sup> The cost calculation methodology for the NO<sub>x</sub> control costs presented in this chapter is the same as that presented in Chapter 2 for the boilers, PM controls, and SO<sub>2</sub> controls.

Table 5-2 presents the specifications and the recommended equipment needed when implementing the NO<sub>x</sub> controls. These items are the basis for the capital cost algorithms. All of the NO<sub>x</sub> controls except for RAP require additional equipment and/or boiler modifications. For residual oil-fired boilers, a slightly larger firebox is required when SCA is applied because the staging causes an extension of the boiler flame. To accommodate the longer flame a larger boiler firebox is required. The degree of staging required to meet a given emission level depends on the residual oil nitrogen content.

For RAP, the cost algorithm presented predicts only the incremental fuel cost associated with not recovering heat from the boiler flue gas. In many cases, other means of heat recovery may be available (such as economizers) to reduce or eliminate this heat loss without affecting NO<sub>x</sub> emissions.

The major annual O&M cost components are maintenance labor, maintenance materials, spare parts, fuel, and electricity. The maintenance labor, maintenance materials and spare parts cost components are combined and calculated using the spare parts cost algorithms. The fuel costs are based on a change in boiler efficiency due to the implementation of the NO<sub>x</sub> control. When LEA is used, boiler efficiency increases, therefore a fuel savings results. The other three NO<sub>x</sub> controls decrease boiler efficiency which result in higher fuel costs. The fuel cost algorithms for LEA and RAP are based on changes in excess air levels and flue gas temperatures. For

TABLE 5-2. NO<sub>X</sub> COMBUSTION MODIFICATION EQUIPMENT REQUIREMENTS OR MODIFICATIONS<sup>a</sup>

Control Device		
Low Excess Air (LEA)		Oxygen trim system - O <sub>2</sub> analyzer, air flow regulators Wind box modifications (may be required for multi-burner boilers)
Staged Combustion Air (SCA)	Pulverized coal-fired boilers	Oxygen trim system - O <sub>2</sub> analyzer, air flow regulators Airports Wind box modifications Larger forced draft fan power
	Residual oil-fired boilers	Up to 30 percent larger boiler to accommodate longer flame
Flue gas recirculation (FGR)		Larger forced draft fan and associated ductwork Modification of wind box and burners to handle additional gas flow Control system to regulate combustion oxygen and the volume of flue gas recirculated
Reduced Air Preheat (RAP)		No additional equipment or modifications required

<sup>a</sup>Continuous NO<sub>X</sub> monitors are not included in these cost algorithms.

SCA and FGR a 0.25 percent and 0.5 percent decrease in boiler efficiency, respectively, is assumed (See Appendix A).

The use of SCA and FGR also results in higher fan power requirements which increases the amount of electricity required. The cost of electricity if assumed to be \$0.026/kwh. Several key variables in the cost algorithms were assumed in this cost analysis.<sup>7</sup> Table 5-3 presents the costs of the fuels used along with the capacity utilization for the boilers to which the NO<sub>x</sub> controls are applied. The fuel prices are 1990 prices in 1978 dollars and are consistent with the fuel prices presented in Chapter 2.

For the calculation of LEA and RAP fuel costs, fuel F-factor calculations and boiler excess air levels are used in the cost algorithms to determine flue gas flow rates. Table 5-4 presents the selected values for these variables. For RAP, it was assumed that the boiler was operating under controlled excess air conditions and the change in flue gas temperature was 100°F.

In the calculation of annualized costs a capital recovery factor of 13.15 percent was used. This factor is based on a real interest rate of 10 percent and a 15 year equipment life. This is the same capital recovery component that was used in the SO<sub>2</sub> and PM control cost analyses. The other capital related charges are also the same as in the previous analyses. Taxes, G&A, and insurance are 4 percent of total turnkey costs which interest on working capital is 10 percent.

### 5.3 ANALYSIS OF COST IMPACTS

Table 5-5 presents the costs of NO<sub>x</sub> control for the control cases presented in Table 5-1. The costs are divided into capital costs, annual O&M costs, total annualized costs and normalized annualized costs. The normalized annualized costs provide a size independent measure of the annualized costs. They are calculated by dividing the total annualized costs of the control by the total annual heat input to the boiler. The final unit is \$/ $10^6$  Btu.

Low excess air (LEA) is the least expensive combustion modification because it improves boiler efficiency thus reducing boiler fuel costs. The

TABLE 5-3. FUEL COSTS AND CAPACITY FACTORS USED FOR  
 $\text{NO}_x$  CONTROL COST ESTIMATION<sup>2,3</sup>

Fuel Type	Nitrogen Content (wt. %)	Fuel Cost $\$/10^6 \text{ Btu}$	Capacity Utilization (-)
High sulfur coal	1.2	2.41	0.60
Residual oil	0.4	4.85	0.55
Distillate oil	Trace	6.06	0.55
Natural gas	8.05 <sup>a</sup>	4.85	0.55

<sup>a</sup>Unbound nitrogen, not fuel N<sub>2</sub> that can be converted to "fuel" NO<sub>x</sub> emissions.

TABLE 5-4. FUEL F-FACTORS AND BOILER EXCESS AIR LEVELS  
USED IN NO<sub>X</sub> CONTROL COST ESTIMATION

Fuel Type	F-Factor (dscf/10 <sup>6</sup> Btu)	Uncontrolled Boiler [% Excess Air (% O <sub>2</sub> )]	Controlled Boiler [% Excess Air (% O <sub>2</sub> )]
High sulfur coal	9,820	50 (6.7)	35 (5.2)
Residual and Distillate oil	9,220	38.4 (6)	9.1 (2)
Natural gas	8,740	37.4 (6)	8.5 (2)

TABLE 5-5. NO<sub>X</sub> CONTROL COSTS (MID-1978 \$)

Control Case	Capital Costs, \$	Annual O&M Costs, \$/yr	Total Annualized Costs, \$/yr	Normalized Annualized Costs, \$/10 <sup>6</sup> Btu <sup>a</sup>
<u>Coal</u>				
UNDR-30-LEA	11,600	-1,910	76	neg
UNDR-75-LEA	15,200	-5,640	-3,020	-0.008
SPRD-150-LEA	21,300	-11,900	-8,190	-0.01
SPRD-250-LEA	29,500	-20,100	-15,100	-0.01
PLVR-150-LEA	21,300	-11,900	-8,190	-0.01
PLVR-150-SCA	43,700	15,600	22,800	0.03
PLVR-250-LEA	29,500	-20,100	-15,100	-0.01
PLVR-250-SCA	60,300	23,400	33,400	0.03
PLVR-400-LEA	41,600	-32,600	-25,400	-0.01
PLVR-400-SCA	86,100	39,600	53,800	0.03
<u>0.2% Nitrogen Residual Oil</u>				
RES-30-LEA	9,150	-11,300	-9,740	-0.07
RES-150-LEA	15,300	-58,500	-55,900	-0.08
RES-250-LEA	20,400	-97,800	-94,300	-0.08
<u>0.4% Nitrogen Residual Oil</u>				
RES-30-SCA	58,600	7,040	17,000	0.12
RES-150-SCA	150,000	26,400	51,800	0.07
RES-250-SCA	227,000	42,400	80,800	0.07

TABLE 5-5. (Continued)

Control Case	Capital Costs, \$	Annual O&M Costs, \$/yr	Total Annualized Costs, \$/yr	Normalized Annualized Costs, \$/10 <sup>6</sup> Btu <sup>a</sup>
<u>Distillate Oil</u>				
DIS-30-LEA	9,150	-14,300	-12,700	-0.09
DIS-30-FGR	19,600	9,600	12,900	0.09
DIS-30-RAP	1,450	17,400	17,500	0.12
DIS-150-LEA	15,300	-73,300	-70,700	-0.10
DIS-150-FGR	36,800	43,900	49,700	0.07
DIS-150-RAP	7,230	86,800	87,500	0.12
DIS-250-LEA	20,400	-123,000	-119,000	-0.10
DIS-250-FGR	51,100	72,500	80,400	0.07
DIS-250-RAP	12,000	145,000	146,000	0.12
<u>Natural Gas</u>				
NG-30-LEA	9,200	-10,500	-8,970	-0.06
NG-30-FGR	19,500	8,700	12,000	0.08
NG-30-RAP	1,090	13,100	13,200	0.09
NG-150-LEA	15,300	-54,600	-54,000	-0.07
NG-150-FGR	36,400	39,500	45,300	0.06
NG-150-RAP	5,460	65,500	66,000	0.09
NG-250-LEA	20,800	-91,400	-87,900	-0.07
NG-250-FGR	50,500	65,200	73,000	0.06
NG-250-RAP	9,090	109,000	110,000	0.09

<sup>a</sup>Negative number indicates net savings due to application of the control.

cost of applying LEA ranges from a savings of \$119,000/year on a  $250 \times 10^6$  Btu/hr distillate oil-fired boiler to a cost of \$76/year on a  $30 \times 10^6$  Btu/hr underfired coal-fired unit.

The application of either staged combustion air (SCA), flue gas recirculation (FGR), or reduced air preheat (RAP) increases annualized costs. The application of SCA on residual oil-fired boilers is more expensive than SCA on pulverized coal-fired boilers. This higher cost occurs because staging on residual oil-fired boilers requires larger boiler fireboxes. The increase in annualized costs due to SCA on pulverized coal-fired boilers ranges from \$22,800/year on a  $150 \times 10^6$  Btu/hr boiler to \$53,800/year on a  $400 \times 10^6$  Btu/hr boiler. For residual oil-fired units the cost of applying SCA ranges from \$17,000/year on a  $30 \times 10^6$  Btu/hr unit firing 2 weight percent nitrogen oil to \$81,000/year on a  $250 \times 10^6$  Btu/hr unit firing 4 weight percent nitrogen oil.

The increase in costs due to the application of FGR on distillate oil-and natural gas-fired boilers ranges from \$12,000/year on a  $30 \times 10^6$  Btu/hr natural gas-fired boiler to \$80,400/year on a  $250 \times 10^6$  Btu/hr distillate oil-fired boiler. For RAP the increased cost for distillate oil-and natural gas-fired boilers ranges from \$13,200/year on a  $30 \times 10^6$  Btu/hr natural gas-fired boiler to \$146,000/year on a  $250 \times 10^6$  Btu/hr distillate oil-fired unit. For both of these controls, the fuel penalty and therefore control costs are higher on distillate oil-fired units because of the higher price of distillate oil (See Table 5-3).

#### 5.4 References

1. U.S. Environmental Protection Agency. Fossil Fuel Fired Industrial Boilers-Background Information. Volume 1. Research Triangle Park, N.C. Publication No. EPA-450/3-82-006a. March 1982. 869 p.
2. Memo from Lahre, T., EPA:SAS to Sedmon, C., EPA:EMB. October 1, 1981. 35 p. Review of Coal Combustion Section, Revisions to Section 1.1 of AP.42.
3. Burklin, C.E., and W.D. Kwapił. (Radian Corporation.) Regressions for NO<sub>x</sub> Emissions from Oil- and Gas-Fired Boilers. (Prepared for U.S. Environmental Protection Agency.) Research Triangle Park, N.C. May 27, 1982. 49 p.
4. Memo from Bowen, M.L., Radian Corporation, to Jones, L., EPA:SDB. July 28, 1982. 12 p. NO<sub>x</sub> Combustion Modification Cost Algorithm Development.

## 6.0 COSTS OF LOW SULFUR COAL AND LOW SULFUR OIL

This section discusses the costs of using low sulfur coal or low sulfur oil (hydrodesulfurized oil) to reduce  $\text{SO}_2$  emissions from industrial boilers. The costs are presented in constant 1978 dollars and are projected for the year 1990.

Estimation of the cost of using low sulfur fuels is complicated by site specific factors. In the case of low sulfur coal, the delivered price of the fuel is a strong function of boiler location and the availability of coal with a desired sulfur content. The delivered price of low sulfur fuel oil also depends on boiler location, as well as the available refinery hydrodesulfurization capacity to produce oil with the desired sulfur content. A complete analysis of the availability of low sulfur fuels to industrial users is beyond the scope of this report. The costs presented in this chapter are based primarily on projected fuel and transportation costs used in the Industrial Fuel Choice Analysis Model (IFCAM). Documentation of the methods of projection and assumptions used to develop these prices are contained in Chapter 10 of the Background Information Document for Industrial Boilers.<sup>1</sup>

### 6.1 LOW SULFUR COAL

Figure 6-1 shows the delivered cost of coal supplied to a boiler in the midwestern United States as a function of coal sulfur content and coal supply region. Low sulfur coal (less than 2.5 lb  $\text{SO}_2/10^6$  Btu) is typically supplied from regions other than the Midwest and transportation costs are a major component of the delivered price for these fuels. Higher sulfur coals would likely be obtained from local (Midwest) supplies.

The broad region formed by the two curves in Figure 6-1 is intended to represent an approximate range of coal prices as a function of sulfur content for the Midwest location. Using these values, one can compare the cost of using coal with a specific sulfur content to the annualized cost of FGD systems as a function of boiler size (Figure 6-2). Figure 6-2 is based on a double alkali FGD system operating at 90 percent  $\text{SO}_2$




Figure 6-1. Delivered price of coal to Midwest location (Chicago).




Figure 6-2. Normalized annualized cost of FGD system applied to HSC coal-fired boilers.

removal on a boiler firing 3.5 percent sulfur coal ( $0.6 \text{ lb SO}_2/10^6 \text{ Btu}$  controlled emissions). Unlike the use of low sulfur coal, normalized annualized costs for FGD systems ( $$/10^6 \text{ Btu}$ ) are a function of boiler size and capacity factor. Figure 6-2 shows costs for both 0.4 and 0.6 capacity factor cases.

For example, the 1990 cost of coal with emissions of about  $1.2 \text{ lb SO}_2/10^6 \text{ Btu}$  delivered to a Midwest boiler range from about  $\$2.00/10^6 \text{ Btu}$  to  $\$2.50/10^6 \text{ Btu}$  according to Figure 6-1. This can be compared to the annualized cost of a 90 percent  $\text{SO}_2$  removal FGD system on a 0.6 capacity factor unit burning 3.5 percent sulfur coal shown in Figure 6-2. The FGD system costs ranges from about  $\$0.60/10^6 \text{ Btu}$  for a  $400 \times 10^6 \text{ Btu/hr}$  unit to  $\$2.70/10^6 \text{ Btu}$  for a  $30 \times 10^6 \text{ Btu/hr}$  boiler.

As discussed earlier, the delivered price of coal is a function of boiler location. Figure 6-3 shows the delivered cost of coal to a boiler located in the Southwest (Houston). Because of the greater distances over which coal from the supply regions indicated in the figure must be transported, delivered coal prices are slightly higher than for the Midwest location.

Figure 6-4 shows the delivered price of coal to a Northeast location (Boston). Comparison of Figures 6-3 and 6-4 with Figure 6-1 shows that the variation in the delivered price of coal as a function of sulfur content is strongest in the Midwest. There are no clear trends in coal price variation with sulfur content when the coal is delivered to a Southwest or Northeast location.

It should be noted that these conclusions are based on a limited number of coals included in the IFCAM model.<sup>1</sup>

## 6.2 LOW SULFUR FUEL OIL

The cost of residual oil can be expressed as a function of sulfur content as shown in Table 6-1. The range of costs shown in this table are based on premiums associated with the desulfurization of crudes with different metal contents, a factor which impacts the desulfurization costs. Calculation of these premiums is documented in a separate paper.<sup>2</sup>




Figure 6-3. Delivered price of coal to a Southwest location (Houston).




Figure 6-4. Delivered price of coal to a Northeast location (Boston).

TABLE 6-1. INCREMENTAL INCREASES IN RESIDUAL OIL PRICES  
FOR VARIOUS SULFUR CONTENTS

Sulfur content of oil (weight %)	Incremental Cost of Desulfurization <sup>a</sup> (\$/10 <sup>6</sup> Btu)
0.8	0.68 - 0.74
0.3	0.93 - 1.03
0.1	1.03 - 1.39

<sup>a</sup>Added cost of hydrodesulfurization of 3% sulfur feedstock crude.

This paper also discusses trends in petroleum product supply and demand and compares the costs, energy, and environmental impacts of FGD and the use of low sulfur hydrodesulfurized fuel oil (HDS).

### 6.3 REFERENCES

1. Energy and Environmental Analysis. Background Information Document for Industrial Boilers, Chapter 10 (Draft). March 1981.
2. Menzies, W.R. (Radian Corporation). Issue Paper No. 5: SO<sub>2</sub> Standard for Oil. Prepared for U.S. Environmental Protection Agency, Research Triangle Park, N.C. EPA Contract No. 68-02-3074. November 3, 1980. 34 p.

## APPENDIX A

### COST ALGORITHMS

Appendix A presents the cost algorithms used to calculate the boiler, PM control,  $\text{SO}_2$  control, and  $\text{NO}_x$  control costs presented in Chapters 3, 4 and 5. Table A-1 summarizes the costing algorithms available. The algorithms are presented as routines (UNDR, VS, DAC, etc.) to identify them in the FORTRAN computer program (COST) used to calculate costs. This program is presented in Appendix B. All the algorithms are used in this analysis with the exception of the distillate/natural gas boiler routines (DNG1, DNG2) and the dual mechanical collector PM control routine (DM). These algorithms are presented for reference since they were developed in conjunction with the other routines.

Table A-2 presents the nomenclature used in the costing algorithms. Categories 1-3 are costs, while the remaining categories are boiler and pollution control system specifications and cost rates used to calculate costs. The costing algorithms presented use this nomenclature. In general, the FORTRAN program also uses this nomenclature. However, slight variations are made to facilitate computations. The major variation is the use of arrays to store cost components rather than using the individual variables in Table A-2.

Many cost calculations are common to nearly all algorithms. Rather than repeat these equations for each algorithm, Table A-3 presents these common equations. Slight variations from these calculations are found in some algorithms. In these cases, the equations presented in the individual algorithm are used rather than the equations in Table A-3.

TABLE A-1. SUMMARY OF COSTING ALGORITHMS

Routine Code <sup>a</sup>	Algorithm Type	Boiler Size Applicability (10 <sup>6</sup> Btu/hr)	Table
UNDR	Boiler, underfeed stoker, watertube, package	<u>&lt;75</u>	A-4
SPRD	Boiler, spreader stoker, watertube, field-erected	60 - 200	A-5
PLVR	Boiler, pulverized coal, watertube, field-erected	<u>&gt;200</u>	A-6
RES1	Boiler, residual oil, firetube, package	<u>&lt;30</u>	A-7
RNG1	Boiler, residual/natural gas, watertube, package	30 - 200	A-8
RNG2	Boiler, residual/natural gas, watertube, field-erected	200 - 700	A-9
DNG1	Boiler, distillate/natural gas, firetube, package	<u>&lt;30</u>	A-10
DNG2	Boiler, distillate/natural gas, watertube, package	30 - 200	A-11
VS	Venturi scrubber applied to coal-fired boiler	30 - 700	A-12
ESPC	Electrostatic precipitator applied to coal-fired boiler	<u>&lt;700</u>	A-13
ESPO	Electrostatic precipitator applied to residual oil-fired boiler	<u>&lt;700</u>	A-14
FF	Fabric filter applied to coal-fired boiler	30 - 700	A-15
SM	Single mechanical collector (multi-cyclone) applied to coal-fired boiler	30 - 700	A-16
DM	Dual mechanical collector (multi-cyclones) applied to coal-fired boiler	30 - 700	A-17
SSS	Sidestream separator applied to coal-fired boiler	30 - 700	A-18
DA	Dual alkali FGD system without PM removal	All sizes	A-19
DAC	Dual alkali FGD system with PM removal	All sizes	A-20
NATH	Sodium throwaway FGD system	All sizes	A-21
DS	Lime spray drying (dry scrubbing) FGD system	All sizes	A-22

TABLE A-1. (Continued)

Routine Code <sup>a</sup>	Algorithm Type	Boiler Size Applicability (10 <sup>6</sup> Btu/hr)	Table
LEA	Low excess air applied to all fuel types	All sizes	A-24
SCA	Staged combustion air applied to pulverized coal-fired boiler	>150	A-25
SCA	Staged combustion air applied to residual oil-fired boiler	30 - 250	A-26
FGR	Flue gas recirculation applied to distillate oil- and natural gas-fired boiler	30 - 250	A-27
RAP	Reduced air preheat applied to all fuel types	All sizes	A-28

<sup>a</sup>Routine code refers to code used to identify algorithm in FORTRAN computer program (see Appendix B).

TABLE A-2. NOMENCLATURE USED IN COST ALGORITHMS

---

1. Capital Costs (1978 dollars)

EQUP = Equipment  
INST = Installation  
TD = Total Direct  
IND = Indirect (Engineering, Field, Construction, Start-up,  
and other miscellaneous costs)  
TDI = Total Direct and Indirect  
CONT = Contingencies  
TK = Turnkey  
LAND = Land  
WC = Working Capital  
TOTL = Total Capital

2. Operation and Maintenance Costs<sup>a</sup> (1978 dollars/year)

DL = Direct Labor  
SPRV = Supervision Labor  
MANT = Maintenance Labor  
SP = Spare Parts  
ELEC = Electricity  
UC = Utilities and Chemicals  
WTR = Water  
SW = Solid Waste Disposal  
SLG = Sludge Waste Disposal  
LW = Liquid Waste Disposal  
SC = Sodium Carbonate  
LMS = Limestone  
LIME = Lime  
FUEL = Fuel  
TDOM = Total Direct Operation and Maintenance  
OH = Overhead  
TOTL = Total Operation and Maintenance

3. Annualized Costs (1978 dollars/year)

CR = Capital Recovery  
WCC = Working Capital Charges  
MISC = Miscellaneous (G & A, Taxes, Insurance)  
TCC = Total Capital Charges  
TOTL = Total Annualized Charges

---

TABLE A-2. (Continued)

4. Boiler Specifications

Q = Thermal Input ( $10^6$  Btu/hr) ( $MW$ )<sup>c</sup>  
FLW = Flue Gas Flowrate (acfm) ( $m^3/s$ )<sup>c</sup>  
CF = Capacity Factor (-)  
BCRF = Capital Recovery Factor for Boiler System

5. Fuel Specifications

FC = Fuel Cost (\$/ $10^6$  Btu) (\$/MJ)<sup>c</sup>  
H = Heating Value (Btu/lb) (KJ/kg)<sup>c</sup>  
S = Sulfur Content (percent by weight)  
A = Ash Content (percent by weight)  
N = Fuel Nitrogen Content (percent by weight)

6.  $SO_2$  Control Specifications

UNCSO2 = Uncontrolled  $SO_2$  Emissions (lb/ $10^6$  Btu) (ng/J)<sup>c</sup>  
CTRSO2 = Controlled  $SO_2$  Emissions (lb/ $10^6$  Btu) (ng/J)<sup>c</sup>  
EFFSO2 =  $SO_2$  Removal Efficiency (percent)  
CRFSO2 = Capital Recovery Factor for  $SO_2$  Control System

7. PM Control Specifications

UNCPM = Uncontrolled PM Emissions (lb/ $10^6$  Btu) (ng/J)<sup>c</sup>  
CTRPM = Controlled PM Emissions (lb/ $10^6$  Btu) (ng/J)<sup>c</sup>  
EFFPM = PM Removal Efficiency (percent)  
CRFPM = Capital Recovery Factor for PM Control System

8. Cost Rates (used in FGD algorithms)<sup>b,c</sup>

ELECR = Electricity Rate (\$/kw-hr)  
WTRR = Water Rate (\$/ $m^3$ )  
ALIMER = Lime Rate (\$/kg)  
ALSR = Limestone Rate (\$/kg)  
SASHR = Sodium Carbonate Rate (\$/kg)  
SLDGR = Sludge Disposal Rate (\$/kg)  
SWDR = Solid Waste Disposal Rate (\$/kg)  
LWDR = Liquid Waste Disposal Rate (\$/ $m^3$ )

9. Miscellaneous

S1 = Heat Specific Sulfur Removal (kg  $SO_2$ /100 MJ)  
S2 = Time Specific Sulfur Removal (kg  $SO_2$ /0.1 hr)  
LF = Labor Factor (-)<sup>d</sup>

TABLE A-2. (Continued)

---

10. NO<sub>x</sub> Control Specifications

FFAC = F-Factor (dscf/10<sup>6</sup> Btu)

UNCEA = Uncontrolled Excess Air (%)

CTREA = Controlled Excess Air (%)

PRCT = Percent Flame Extension Due to Staging

DELT = Change in the flue gas exit temperature due to the  
elimination of the air preheater or a reduction  
in its effectiveness

CRFNO<sub>x</sub> = Capital Recovery Factor for NO<sub>x</sub> Control System

---

<sup>a</sup>Cost categories are not mutually exclusive. For example, some costing routines include electricity and waste cost in the utilities category while other calculate these cost separately.

<sup>b</sup>All other algorithms assume these rates to be constants; FGD algorithms allow the rates to be varied.

<sup>c</sup>FGD algorithms use metric units.

<sup>d</sup>(-) factor presented as fraction not as percent.

TABLE A-3. CALCULATIONS COMMON TO COST ALGORITHMS

---



---

1. Capital Costs

$$\begin{aligned} \text{EQUP} + \text{INST} &= \text{TD}^{\text{a}} \\ \text{IND} &= 0.333 * \text{TD}^{\text{b}} \\ \text{TDI} &= \text{TD} + \text{IND} \\ \text{CONT} &= 0.20 * \text{TDI} \\ \text{TK} &= \text{TDI} + \text{CONT} \\ \text{LAND}^{\text{c}} &= \$4000 \text{ pulverized coal boilers} \\ &= \$2000 \text{ all other boilers} \\ \text{WC} &= 0.25 * (\text{TDOM} - \text{Fuel}) + 0.0833 (\text{Fuel})^{\text{d}} \\ \text{TOTL} &= \text{TK} + \text{LAND} + \text{WC} \end{aligned}$$

2. Operation and Maintenance Costs

$$\begin{aligned} \text{FUEL} &= \text{CF} * \text{Q} * \text{FC} * 8760 \\ \text{TDOM} &= \text{Sum of all O \& M Costs other than OH} \\ \text{OH} &= 0.30 * \text{DL} + 0.26 * (\text{DL} + \text{SPRV} + \text{MANT} + \text{SP}) \\ \text{TOTL} &= \text{TDOM} + \text{OH} \end{aligned}$$

3. Annualized Costs

$$\begin{aligned} \text{CR} &= \text{CRF} * \text{TK} \\ \text{WCC} &= 0.10 * \text{WC} \\ \text{MISC} &= 0.04 * \text{TK} \\ \text{TCC} &= \text{CR} + \text{WCC} + \text{MISC} \\ \text{TOTL} &= \text{TCC} + \text{TOTL O \& M Costs} \end{aligned}$$

4. Labor Factors

$$\begin{aligned} \text{LF} &= 1 \text{ if CF} > 0.7 \\ \text{LF} &= 0.5 + 2.5 * (\text{CF} - 0.5) \text{ if } 0.5 \leq \text{CF} \leq 0.7 \\ \text{LF} &= 0.5 \text{ if CF} < 0.5 \end{aligned}$$


---

<sup>a</sup> FGD system cost algorithms compute TD without prior computation of EQUP and INST

<sup>b</sup> Some algorithms compute IND explicitly as a function of boiler and/or control device specifications.

<sup>c</sup> Only boilers have costs assumed for land.

<sup>d</sup> For boilers, assume a 3 month supply of all working capital components except fuel, which will have a 1 month supply. For control devices, working capital is 25% of total direct operating and maintenance costs.

Table A-4 through A-11 present the boiler cost algorithms. Table A-12 through A-18 and Tables A-19 through A-22 list the PM control and SO<sub>2</sub> control cost algorithms, respectively. Table A-23 presents the algorithms used to calculate flue gas flowrates for the standard boilers and Tables A-24 through A-28 present the NO<sub>x</sub> control cost algorithms.

TABLE A-4. COST EQUATIONS FOR PACKAGE, WATERTUBE  
UNDERFEED STOKER BOILERS  
 $(\leq 75 \times 10^6 \text{ Btu/hr})^1$

Routine Code: UNDR

Capital Costs:

$$\text{EQUP} = 66,392 Q^{0.622} \left( \frac{11,800}{H} \right) + 2,257 Q^{0.819}$$

$$\text{INST} = 53,219 Q^{0.65} \left( \frac{11,800}{H} \right) + 2,882 Q^{0.796}$$

$$\text{IND} = 40,188 Q^{0.646} \left( \frac{11,800}{H} \right)^{0.926}$$

Annual Costs:<sup>a</sup>

$$\text{DL} = \text{LF} (38,020 \ln Q + 28,640)(0.767)$$

$$\text{SPRV} = \text{LF} \left( \frac{Q + 5,300,000}{99.29 - Q} \right) (0.767)$$

$$\text{MANT} = \text{LF} \left( \frac{Q + 4,955,000}{99.29 - Q} \right) (0.767)$$

$$\text{SP} = (1.705 \times 10^8 Q - 2.959 \times 10^8)^{0.5} \left( \frac{11,800}{H} \right)^{1.0028} (0.767)$$

$$\text{UC} = \frac{\text{CF}}{.6} \left( \frac{Q}{1.105 \times 10^{-5} Q + 3.69 \times 10^{-4}} \right) \left( \frac{11,800}{H} \right)^{0.9} \left( \frac{A}{10.6} \right)^{0.3} (0.848)$$

$$\text{SW} = \text{CF} (443.3) Q \left( \frac{11,800}{H} \right)^{0.9} \left( \frac{A}{10.6} \right)^{0.3} (0.848)$$

<sup>a</sup>The multipliers used, 0.767 and 0.848, are included in determining annual O&M costs. These factors reflect the economies of multiple boilers at a facility (see Chapter 2).

TABLE A-5. COST EQUATIONS FOR FIELD-ERECTED, WATERTUBE  
SPREADER-STOKER BOILERS  
( $60-200 \times 10^6$  Btu/hr)<sup>1</sup>

Routine Code: SPRD

Capital Costs:

$$EQUP = \left( \frac{Q}{7.5963 \times 10^{-8} Q + 4.7611 \times 10^{-5}} \right) \left( \frac{H}{11,800} \right)^{-0.35}$$

$$INST = \left( \frac{Q}{8.9174 \times 10^{-8} Q + 5.5891 \times 10^{-5}} \right) \left( \frac{H}{11,800} \right)^{-0.35}$$

$$IND = \left( \frac{Q}{1.2739 \times 10^{-7} Q + 7.9845 \times 10^{-5}} \right) \left( \frac{H}{11,800} \right)^{-0.35}$$

Annual Costs:<sup>a</sup>

$$DL = LF (202,825 + 5.366 Q^2) (0.767)$$

$$SPRV = LF (136,900) (0.767)$$

$$MANT = LF (107,003 + 1.873 Q^2) (0.767)$$

$$SP = 50,000 + 1,000 Q (0.767)$$

$$UC = CF (29,303 + 719.8 Q) (0.848)$$

$$SW = 0.38 CF (547,320 + 66,038 \ln \frac{A}{H}) \left( \frac{Q}{150} \right)^{0.9754} (0.848)$$

<sup>a</sup>The multipliers used, 0.767 and 0.848, are included in determining annual O&M costs. These factors reflect the economies of multiple boilers at a facility (see Chapter 2).

TABLE A-6. COST EQUATION FOR FIELD-ERECTED, WATERTUBE  
PULVERIZED COAL-FIRED BOILERS  
 $(\geq 200 \times 10^6 \text{ Btu/hr})^1$

---

Routine Code: PLVR

Capital Costs:

$$EQUP = (4,926,066 - 0.00337 H^2) \left(\frac{Q}{200}\right)^{0.712}$$

$$INST = 1,547,622.7 + 6,740.026 Q - 0.0024133 H^2$$

$$IND = 1,257,434.72 + 6,271.316 Q - 0.00185721 H^2$$

Annual Costs:<sup>a</sup>

$$DL = LF (244,455 + 1,157 Q) (0.767)$$

$$SPRV = LF (243,985 - \frac{20,636,709}{Q}) (0.767)$$

$$MANT = LF (-1,162,910 + 256,604 \ln Q) (0.767)$$

$$SP = (180,429 + 405.4 Q) (0.767)$$

$$UC = CF (189,430 + 1476.7 Q) (0.848)$$

$$SW = 0.38 CF (-641.08 + \frac{70,679,828 A}{H}) \left(\frac{Q}{200}\right)^{1.001} (0.848)$$

---

<sup>a</sup>The multipliers used, 0.767 and 0.848, are included in determining annual O&M costs. These factors reflect the economies of multiple boilers at a facility (see Chapter 2).

TABLE A-7. COST EQUATIONS FOR PACKAGE, <sub>6</sub><sup>1</sup> FIRETUBE, <sub>1</sub><sup>1</sup> RESIDUAL OIL-FIRED BOILERS ( $\leq 30 \times 10^6$  Btu/hr)

---

---

Routine Code: RES1

Capital Costs:

$$EQUP = 17,360 Q^{0.557}$$

$$INST = 4,324 Q + 56,177$$

$$IND = 2,317 Q + 29,749$$

Annual Costs: <sup>a</sup>

$$DL = LF (105,300)(0.799)$$

$$SPRV = LF \left(\frac{0-5}{10}\right) (68500) (0.799) \quad \text{if } Q < 15$$

$$LF (68,500) (0.799) \quad \text{if } Q \geq 15$$

$$MANT = LF (1,600 Q + 8,000)(0.799) \quad \text{if } Q < 15$$

$$LF (32,000)(0.799) \quad \text{if } Q \geq 15$$

$$UC = \frac{CF}{.45} (580 Q + 3,900) (0.845)$$

---

<sup>a</sup>The multipliers used, 0.799 and 0.845, are included in determining annual O&M costs. These factors reflect the economies of multiple boilers at a facility (see Chapter 2).

TABLE A-8.. COST EQUATIONS FOR PACKAGE, WATERTUBE DUAL-FIRED  
BOILERS FIRING RESIDUAL OIL/NATURAL GAS  
 $(30-200 \times 10^6 \text{ Btu/hr})^1$

Routine Code: RNG1

Capital Costs

$$EQUP = 15,925 Q^{0.775}$$

$$INST = 54,833 Q^{0.364}$$

$$IND = 16,561 Q^{0.613}$$

Annual Costs <sup>a</sup>

$$DL = LF \left( \frac{Q^2}{8.135 \times 10^{-4} Q - 1.585 \times 10^{-2}} \right) (0.799)$$

$$SPRV = LF (68,500)(0.799)$$

$$MANT = LF \left( \frac{-1,267,000}{Q} + 77,190 \right) (0.799)$$

$$SP = 7,185 Q^{0.4241} (0.799)$$

$$UC = \frac{CF}{.55} (202 Q + 24,262) (0.845)$$

<sup>a</sup>The multipliers used, 0.799 and 0.845, are included in determining annual O&M costs. These factors reflect the economies of multiple boilers at a facility (see Chapter 2).

TABLE A-9. COST EQUATIONS FOR FIELD-ERECTED, WATERTUBE  
RESIDUAL OIL/GAS-FIRED BOILERS  
 $(200 - 700 \times 10^6 \text{ Btu/hr})^1$

---

Routine Code: RNG2

Capital Costs:

$$EQUP = 1,024,258 + 8,458 Q$$

$$INST = 579,895 + 5,636 Q$$

$$IND = 515,189 + 4,524 Q$$

Annual Costs: <sup>a</sup>

$$DL = LF (173,197 + 734 Q) (0.799)$$

$$SPRV = LF (263,250 - \frac{30,940,000}{Q}) (0.799)$$

$$MANT = LF (32,029 + 320.4 Q) (0.799)$$

$$SP = (50,000 + 250 Q) (0.799)$$

$$UC = CF (43,671.7 + 479.6 Q)(0.845)$$

---

<sup>a</sup>The multipliers used, 0.799 and 0.845, are included in determining annual O&M costs. These factors reflect the economies of multiple boilers at a facility (see Chapter 2).

TABLE A-10. COST EQUATIONS FOR PACKAGE, FIRETUBE, NATURAL GAS/DISTILLATE OIL-FIRED BOILERS ( $< 30 \times 10^6$  Btu/hr)<sup>1</sup>

---

---

Routine Code: DNG1

Capital Costs

$$EQUP = 15,981 Q^{0.561}$$

$$INST = 4,261 Q + 56,041$$

$$IND = 2,256 Q + 28,649$$

Annual Costs<sup>a</sup>

$$DL = LF (105,300) (0.799)$$

$$SPRV = LF \left( \frac{Q - 5}{10} \right) (68,500) (0.799) \text{ if } Q < 15$$

$$= LF (68,500) (0.799) \text{ if } Q \geq 15$$

$$MANT = LF (1600 Q + 8000) (0.799) \text{ if } Q < 15$$

$$= LF (32,000) (0.799) \text{ if } Q \geq 15$$

$$SP = (708.7 Q + 4,424) (0.799)$$

$$UC = \frac{CF}{.45} (580 Q + 3,900) (0.845)$$

---

<sup>a</sup>The multipliers used, 0.799 and 0.845, are included in determining annual O&M costs. These factors reflect the economies of multiple boilers at a facility (see Chapter 2).

TABLE A-11. COST EQUATIONS FOR PACKAGE, WATERTUBE, DUAL-FIRED BOILERS 1  
FIRING DISTILLATE OIL/NATURAL GAS ( $30 - 200 \times 10^6$  Btu/hr)

---



---

Routine Code: DNG2

Capital Costs:

$$EQUP = 14,850 Q^{0.786}$$

$$INST = 54,620 Q^{0.361}$$

$$IND = 15,952 Q^{0.618}$$

Annual Costs:<sup>a</sup>

$$DL = LF \left( \frac{Q^2}{8.135 \times 10^{-4} Q - 1.585 \times 10^{-2}} \right) (0.799)$$

$$SPRV = LF (68,500) (0.799)$$

$$MANT = LF \left( \frac{-1,267,000}{Q} + 77,190 \right) (0.799)$$

$$SP = 7,185 Q^{0.4241} (0.799)$$

$$UC = \frac{CF}{.55} (202 Q + 24,262) (0.845)$$

---

<sup>a</sup>The multipliers used, 0.799 and 0.845, are included in determining annual O&M costs. These factors reflect the economies of multiple boilers at a facility (see Chapter 2).

TABLE A-12. COST EQUATIONS FOR VENTURI SCRUBBERS APPLIED TO  
COAL-FIRED BOILERS  
 $(30 - 700 \times 10^6 \text{ Btu/hr})^2$

---

Routine Code: VS

Capital Costs:

$$EQUP = 26,916 + 2.294 (\text{FLW})$$

$$INST = 13,904 + 1.653 (\text{FLW})$$

$$IND = 15,463 + 1.285 (\text{FLW})$$

Annual Costs:

$$DL = LF (10,150 + 106 Q) \quad \text{if } 30 \leq Q \leq 400$$

$$= LF (52,600) \quad \text{if } 400 < Q \leq 700$$

$$SPRV = 0 \quad \text{if } 30 \leq Q \leq 400$$

$$= LF (17,000) \quad \text{if } 400 < Q \leq 700$$

$$SP = 4,525 + 104.4 Q$$

$$UC = \left(\frac{CF}{0.6}\right) (304.3 Q^{0.938})$$

$$SW = \left(\frac{CF}{0.6}\right) 39.42 (\text{UNCPM} - \text{CTRPM})$$


---

TABLE A-13. COST EQUATIONS FOR ELECTROSTATIC PRECIPITATORS (ESP's)  
APPLIED TO COAL-FIRED BOILERS<sup>a</sup> ( $\leq 700 \times 10^6$  Btu/hr)<sup>a,b</sup>

---

Routine Code: ESPC

Capital Costs:

$$\begin{aligned}
 \text{EQUP} &= 0.02457 (\text{SCA}) (\text{FLW}) - 5.62 \times 10^{-10} \times [(\text{SCA}) (\text{FLW})]^2 + \\
 &\quad 0.544 (\text{FLW}) + 26353 \quad \text{if } 30 \leq Q < 100 \\
 &= 0.02457 (\text{SCA}) (\text{FLW}) - 5.62 \times 10^{-10} \times [(\text{SCA}) (\text{FLW})]^2 + \\
 &\quad (130,000 + 226 Q) \quad \text{if } 100 \leq Q < 700 \\
 &\quad \text{and } \text{TPA} \leq 28,000 \\
 &= 0.00965 (\text{SCA}) (\text{FLW}) - 2.54 \times 10^{-11} \times [(\text{SCA}) (\text{FLW})]^2 + \\
 &\quad (130,000 + 226 Q) \quad \text{if } 100 \leq Q \leq 700 \\
 &\quad \text{and } 28,000 \leq \text{TPA} \\
 \text{INST} &= 1.17 \text{ EQUP} \quad \text{if } 30 \leq Q < 100 \\
 &= 1.10 \text{ EQUP} \quad \text{if } 100 \leq Q \leq 700
 \end{aligned}$$

Annual Costs:

$$\begin{aligned}
 \text{DL} &= \text{LF} [10,150 + 106Q] \quad \text{if } 30 \leq Q < 400 \\
 &= \text{LF} (52,600) \quad \text{if } 400 < Q \leq 700 \\
 \text{SPRV} &= 0 \quad \text{if } 30 \leq Q < 400 \\
 &= \text{LF} [17,000] \quad \text{if } 400 < Q \leq 700 \\
 \text{MANT} &= \text{LF} [14,840 + 0.106 Q^2] \quad \text{if } 30 \leq Q < 400 \\
 &= \text{LF} (32,000) \quad \text{if } 400 < Q \leq 700 \\
 \text{SP} &= 5.52 \times 10^{-3} [\text{EQUP} + \text{INST} + \text{IND}] \\
 \text{UC} &= \left( \frac{\text{CF}}{0.6} \right) [0.4068 (\text{TPA}) + 2.523 Q (\text{UNCPM} - \text{CTRPM})] \\
 \text{SW} &= \left( \frac{\text{CF}}{0.6} \right) 39.42 Q [\text{UNCPM} - \text{CTRPM}]
 \end{aligned}$$

---

<sup>a</sup>SCA ( $\text{ft}^2/1000 \text{ acfm}$ ) = specific collection area =

$[324.32 S^{(-11.256 \times \text{EFFPM}^{-0.745})}] [(100-\text{EFFPM})^{-0.366S}^{-0.051}] 1.18178$

<sup>b</sup>TPA ( $\text{ft}^2$ ) = total plate area = (SCA) (FLW)/1000

TABLE A-14. COST EQUATIONS FOR ELECTROSTATIC PRECIPITATORS (ESP's)  
APPLIED TO RESIDUAL OIL-FIRED BOILERS<sup>2</sup>  
( $\leq 700 \times 10^6$  Btu/hr)<sup>a,b</sup>

---

Routine Code: ESP0

Capital Costs:

$$\begin{aligned}
 \text{EQUP} &= 0.02457 (\text{SCA}) (\text{FLW}) - 5.62 \times 10^{-10} && \text{if } 30 \leq Q < 100 \\
 &\quad \times [(\text{SCA}) (\text{FLW})]^2 + [0.544 (\text{FLW}) + 26,353] \\
 &= 0.02457 (\text{SCA}) (\text{FLW}) - 5.62 \times 10^{-10} && \text{if } 100 \leq Q \leq 700 \\
 &\quad \times [(\text{SCA}) (\text{FLW})]^2 + [0.544 (\text{FLW}) + 26,353] \text{ and TPA} < 28,000 \\
 &= 0.00965 (\text{SCA}) (\text{FLW}) - 2.54 \times 10^{-11} && \text{if } 100 \leq Q \leq 700 \\
 &\quad \times [(\text{SCA}) (\text{FLW})]^2 + [0.544 (\text{FLW}) + 26,353] \text{ and } 28,000 \leq \text{TPA} \\
 \text{INST} &= 1.17 (\text{EQUP}) && \text{if } 30 \leq Q \leq 100 \\
 &= 1.10 (\text{EQUP}) && \text{if } 100 < Q \leq 700
 \end{aligned}$$

Annual Costs:

$$\begin{aligned}
 \text{DL} &= \text{LF} [10,150 + 106 Q] && \text{if } 30 \leq Q \leq 400 \\
 &= \text{LF} (52,600) && \text{if } 400 < Q \leq 700 \\
 \text{SPRV} &= 0 && \text{if } 30 \leq Q \leq 400 \\
 &= \text{LF} (17,000) && \text{if } 400 < Q \leq 700 \\
 \text{MANT} &= \text{LF} [14,840 + 0.106 Q^2] && \text{if } 30 \leq Q \leq 400 \\
 &= \text{LF} (32,000) && \text{if } 400 < Q \leq 700 \\
 \text{SP} &= 5.52 \times 10^{-3} [\text{EQUP} + \text{INST} + \text{IND}] \\
 \text{UC} &= \left(\frac{\text{CF}}{0.6}\right) [0.4068 (\text{TPA}) + 2.523 Q (\text{UNCPM} - \text{CTRPM})] \\
 \text{SW} &= \left(\frac{\text{CF}}{0.6}\right) 39.42 Q [\text{UNCPM} - \text{CTRPM}]
 \end{aligned}$$

---

<sup>a</sup>SCA ( $\text{ft}^2/1000 \text{ acfm}$ ) = specific collection area =  $400 \text{ ft}^2/1000 \text{ acfm}$ .

<sup>b</sup>TPA ( $\text{ft}^2$ ) = total plate area = SCA \* FLW/1000.

TABLE A-15.. COST EQUATIONS FOR FABRIC FILTERS APPLIED TO  
 COAL-FIRED BOILERS  
 $(30-700 \times 10^6 \text{ Btu/hr})^2$

---

Routine Code: FF

Capital Costs:

$$EQUP = 8.340 (\text{FLW})^{0.966}$$

$$INST = -1,506,523 + 168,531 \ln (\text{FLW})$$

$$IND = 24.990 (\text{FLW})^{0.821}$$

Annual Costs:

$$DL = LF (10,150 + 106 Q) \quad \text{if } 30 \leq Q \leq 400$$

$$LF (52,600) \quad \text{if } 400 < Q \leq 700$$

$$SPRV = 0 \quad \text{if } 30 \leq Q \leq 400$$

$$= LF (17,000) \quad \text{if } 400 < Q \leq 700$$

$$MANT = LF (14,840 + 0.106 Q^2) \quad \text{if } 30 \leq Q \leq 400$$

$$= LF (32,000) \quad \text{if } 400 < Q \leq 700$$

$$SP = 0.278 (\text{FLW})^{0.997}$$

$$UC = \left(\frac{CF}{0.60}\right) 0.740 (\text{FLW})^{0.953}$$

$$SW = \left(\frac{CF}{0.60}\right) 39.42 Q (\text{UNCPM} - \text{CTRPM})$$


---

TABLE A-16. COST EQUATIONS FOR SINGLE MECHANICAL (MULTI-CYCLONE)  
COLLECTORS APPLIED TO COAL-FIRED BOILERS

$(30-700 \times 10^6 \text{ Btu/hr})^3$

---

---

Routine Code: SM

Capital Costs:

$$TD = 32.53 (FLW)^{0.7518}$$

$$IND = TD/3$$

Annual Costs:

$$DL = LF(5075 + 53 Q)$$

$$SPRV = DL(0.15)$$

$$MANT = LF(7420 + 0.053(Q^2))$$

$$SP = 0.005(EQUIP + IND)$$

$$ELEC = 0.286 (FLW) * CF$$

$$SW = (\frac{CF}{0.6}) 39.42 Q (UNCPM - CTRPM)$$

---

TABLE A-17. COST EQUATIONS FOR DUAL MECHANICAL (MULTI-CYCLONE)  
COLLECTORS APPLIED TO COAL-FIRED BOILERS  
 $(30-700 \times 10^6 \text{ Btu/hr})^3$

---

Routine Code: DM

Capital Costs:

$$TD = 24.54 (\text{FLW})^{0.813}$$

$$\text{IND} = TD/3.0$$

Annual Costs:

$$DL = LF (5075 + 53 Q)$$

$$\text{SPRV} = (DL) 0.15$$

$$\text{MANT} = LF (7420 + 0.053 Q^2)$$

$$\text{SP} = 0.005 (\text{EQUIP} + \text{IND})$$

$$\text{ELEC} = 0.3818 (\text{FLW}) * \text{CF}$$

$$\text{SW} = \left(\frac{\text{CF}}{0.6}\right) 39.42 Q (\text{UNCPM} - \text{CTRPM})$$

---

TABLE A-18. COST EQUATIONS FOR SIDE-STREAM  
SEPARATORS APPLIED TO COAL-FIRED BOILERS  
 $(30-700 \times 10^6 \text{ Btu/hr})^3$

---

---

Routine Code: SSS

Capital Costs:

$$TD = 41.3 (FLW)^{0.7869}$$

$$IND = TD/3.0$$

Annual Costs:

$$DL = LF(7105 + 74.2 Q)$$

$$SPRV = (DL) 0.15$$

$$MANT = LF (10390 + 0.074(Q^2)) + 0.0554 (FLW)^{0.997}$$

$$SP = 0.005 (EQUIP + IND)$$

$$ELEC = 0.286 (FLW) * CF + [\frac{CF}{0.6}] 0.160 (FLW)^{0.953}$$

$$SW = (\frac{CF}{0.6}) 39.42 Q (UNCPM - CTRPM)$$

---

TABLE A-19. COST EQUATIONS<sup>5</sup> FOR DUAL ALKALI  
FGD SYSTEMS WITHOUT PM REMOVAL<sup>a</sup>

---

Routine Code: DA

Capital Costs:<sup>b,c</sup>

$$TDI = 45,200 (FLW)^{0.67} + 83,118 (S2)^{0.39}$$

$$\begin{aligned} TK &= 1.48 TDI + 93,600 && \text{if } Q \leq 58.6 \\ &= 1.48 TDI + 130,000 && \text{if } Q > 58.6 \end{aligned}$$

Annual Costs:<sup>b,c</sup>

$$DL = 105,000$$

$$SPRV = 21,000$$

$$MANT = 0.08 TDI$$

$$ELEC = 8,760 CF * ELECR [2.94 FLW (0.121 S1 + 0.861)]$$

$$\begin{aligned} WTR &= 8,760 CF * WTRR [0.197 FLW + 0.30]* \\ &\quad [0.977 + 0.119 \ln S1] \end{aligned}$$

$$SW = 8,760 CF * SWDR [7.73 S2 - 3.34]$$

$$\begin{aligned} SC &= 8,760 CF * SASHR [1.13 FLW - 2.06]* \\ &\quad [0.41 - 0.70 (0.24 - S1)]^{1.74} && \text{if } S1 < 0.24 \end{aligned}$$

$$\begin{aligned} &8,760 CF * SASHR [1.13 FLW - 2.06]* \\ &\quad [0.70 (S1 - 0.24)]^{1.74} + 0.41] && \text{if } S1 \geq 0.24 \end{aligned}$$

$$LIME = 8,760 CF * ALIMER [1.61 S2 - 0.85]$$

---

<sup>a</sup> FGD algorithms use metric units as noted in Table A-2.

<sup>b</sup>  $S1 = S * EFFSO2 * 100/H$

<sup>c</sup>  $S2 = S1 * Q/3.6$

TABLE A-20. COST EQUATIONS<sup>5</sup> FOR DUAL ALKALI FGD SYSTEMS WITH PM REMOVAL<sup>a</sup>

Routine Code: DAC

Capital Costs:<sup>b,d</sup>

$$\begin{aligned} \text{TDI} = & 74370 + 9.02 \times 10^3 (\text{FLW}) - 39.5 (\text{FLW})^2 + \\ & 13,340 (\text{FLW})^{0.528} + 32.32 \times 10^3 (\text{S2})^{0.362} + \\ & 54.06 \times 10^3 [7.73 \text{ S2} - 3.34 + \text{P}]^{0.278} + \\ & 4,094 \text{ FLW}^{0.834} \end{aligned}$$

$$\begin{aligned} \text{TK} = & 1.48 \text{ TDI} + 93,600 & \text{if } Q \leq 58.6 \\ = & 1.48 \text{ TDI} + 130,000 & \text{if } Q > 58.6 \end{aligned}$$

Annual Costs:<sup>b,c,d</sup>

$$\text{DL} = 105,000$$

$$\text{SPRV} = 21,000$$

$$\text{MANT} = 0.08 \text{ TDI}$$

$$\text{ELEC} = 8,760 \text{ CF} * \text{ELECR} (6.11 \text{ FLW}) * \\ [0.121 \text{ S1} + 0.861]$$

$$\text{WTR} = 8,760 \text{ CF} * \text{WTRR} [0.197 (\text{FLW}) + 0.30] * \\ [0.977 + 0.119 \ln \text{S1}]$$

$$\text{SW} = 8,760 \text{ CF} * \text{SWDR} [7.73 \text{ S2} - 3.34 + \text{P}]$$

$$\begin{aligned} \text{SC} = & 8,760 \text{ CF} * \text{SASHR} [1.13 \text{ FLW} - 2.06] * \\ & [0.41 - 0.70 (0.24 - \text{S1})]^{1.74} & \text{if } \text{S1} < 0.24 \end{aligned}$$

$$\begin{aligned} = & 8,760 \text{ CF} * \text{SASHR} [1.13 (\text{FLW}) - 2.06] * \\ & [0.70 (\text{S1} - 0.24)]^{1.74} + 0.41 & \text{if } \text{S1} \geq 0.24 \end{aligned}$$

$$\text{LIME} = 8,760 \text{ CF} * \text{ALIMER} [1.61 \text{ S2} - 0.85]$$

<sup>a</sup>FGD algorithms use metric units as noted in Table A-2.

<sup>b</sup>P =  $3.6 \times 10^{-3}$  Q (1.2 UNCPM - 2 CTRPM)

<sup>c</sup>S1 = S\*EFFSO2 \* 100/H

<sup>d</sup>S2 = S1 \* Q/3.6

TABLE A-21. COST EQUATIONS<sup>4</sup> FOR SODIUM THROWAWAY FGD SYSTEMS<sup>a</sup>

---

---

Routine Code: NATH

Capital Costs:<sup>b</sup>

$$TDI = 44,000 (\text{FLW})^{0.62} + 20,600 (\text{S1})^{0.427}$$

$$\begin{aligned} TK &= 1.48 \text{ TDI} + 74,400 && \text{if } Q \leq 58.6 \\ &= 1.48 \text{ TDI} + 112,800 && \text{if } Q > 58.6 \end{aligned}$$

Annual Costs:<sup>b,c</sup>

$$DL = 105,000$$

$$SPRV = 21,000$$

$$MANT = 0.08 \text{ TDI}$$

$$ELEC = 8,760 \text{ CF ELECR} [4.26 (\text{FLW}) - 2.56] [0.65 + 0.31 \text{ S1}]$$

$$WTR = 8,760 \text{ CF WTRR} [0.776 (\text{FLW}) - 0.720] [0.213 + 0.684 \text{ S1}]$$

$$SW = 8,760 \text{ CF SWDR} [0.16 + 4.53 \text{ S2}]$$

$$SC = 8,760 \text{ CF SASHR} [8.03 + 3.5 \text{ S2}]$$

$$LW = 8,760 \text{ CF LWDR} (0.0860 \text{ S2})$$

---

<sup>a</sup>FGD algorithms use metric units as noted in Table A-2.

<sup>b</sup>S1 = S \* EFFSO2 \* 100/H

<sup>c</sup>S2 = S1 \* Q/3.6

TABLE A-22. COST EQUATIONS FOR LIME SPRAY DRYING  
FGD SYSTEMS WITH PM REMOVAL<sup>a</sup>

Routine Code: DS

Capital Costs:<sup>c</sup>

$$TDI = 55,600 (\text{FLW})^{0.51} + 21,600 (\text{S2})^{0.40} + 33,327 (\text{FLW})^{0.89}$$

$$\begin{aligned} TK &= 1.48 TDI + 110,400 && \text{if } Q \leq 58.6 \\ && 1.60 TDI && \text{if } Q > 58.6 \end{aligned}$$

Annual Costs:<sup>b,c</sup>

$$DL = 105,000$$

$$SPRV = 21,000$$

$$MANT = 0.08 [55,600 (\text{FLW})^{0.51} + 21,600 (\text{S2})^{0.40}] + 14,840 + 1.23 Q^2 + 578 (\text{FLW})^{0.997}$$

$$ELEC = 8,760 CF * ELECR [6.14 (\text{FLW})^{0.82}]$$

$$WTR = 8,760 CF * WTRR [0.144 (\text{FLW})]$$

$$SW = 8,760 CF * SWDR [(0.035 * EFFSO2 + 3.02) (\text{S2}) + UNCPM * EFFPM/100]$$

$$LIME = 8,760 CF * ALIMER (1.88 \ln(EFFSO2) - 5.3) \text{ S2}$$

<sup>a</sup>FGD costs use metric units as noted in Table A-2.

<sup>b</sup>S1 = S1 \* EFFSO2 \* 100/H

<sup>c</sup>S2 = S1 \* Q/3.6

TABLE A-23. FLUE GAS FLOWRATE ALGORITHMS<sup>a,b</sup>

---

---

Natural Gas

$$FLW = 8.14 \times 10^6 Q/H \quad (\text{non-LEA})$$

$$FLW = 6.81 \times 10^6 Q/H \quad (\text{LEA})$$

Distillate and/or Residual

$$FLW = 0.189 Q H^{0.77} \quad (\text{non-LEA})$$

$$FLW = 0.156 Q H^{0.77} \quad (\text{LEA})$$

Coal (Stoker)

$$FLW = \text{EXP} [8.14 \times 10^{-5} H] * 1.84 \times 10^6 Q/H \quad (\text{non-LEA})$$

$$FLW = \text{EXP} [8.14 \times 10^{-5} H] * 1.66 \times 10^6 Q/H \quad (\text{LEA})$$

Coal (Pulverized)

$$FLW = 1.62 \times 10^6 * \text{EXP} [8.03 \times 10^{-5} H] * Q/H \quad (\text{LEA})$$

---

<sup>a</sup>LEA and Non-LEA conditions are defined as follows:

NG and oil: LEA - 15% excess air  
Non-LEA - 40% excess air

Coal: LEA - 35% excess air  
Non-LEA - 50% excess air

<sup>b</sup> Reference 6.

TABLE A-24. COST EQUATIONS FOR LOW EXCESS AIR  
APPLIED TO INDUSTRIAL BOILERS

---

Routine Code: LEA

Capital Costs:

Coal: EQUIP = 46.22(Q) + 6496  
INST and IND = 21.50(Q) + 1123

Oil and Gas: EQUIP = 31.38(Q) + 5185  
INST and IND = 11.37(Q) + 1161

Annual Costs:

$$\begin{aligned} SP^b &= 0.05(TK) \\ FUEL &= -.00055(FC)(Q)(CF)(FFAC)(UNCEA - CTREA) \end{aligned}$$

---

<sup>a</sup>Algorithm assumes a flue gas temperature of 400°F and the ambient air temperature to be 77°F.

<sup>b</sup>Spare parts costs consist of the costs for spare parts, maintenance labor, and maintenance materials.

TABLE A-25. COST EQUATIONS FOR STAGED COMBUSTION AIR  
APPLIED TO PULVERIZED COAL-FIRED BOILERS  
( $>150 \times 10^6$  Btu/hr)

---

---

Routine Code: SCA

Capital Costs:

$$\begin{aligned} \text{EQUIP} &= 65 (Q) + 13000 \\ \text{INST and IND} &= 60 (Q) + 2000 \end{aligned}$$

Annual Costs:

$$\begin{aligned} \text{SP}^a &= 0.05 (\text{TK}) \\ \text{ELEC} &= 105 (Q)(\text{CF}) \\ \text{FUEL} &= 21.9 (\text{FC})(Q)(\text{CF}) \end{aligned}$$

---

<sup>a</sup>Spare parts costs consist of the costs for spare parts, maintenance labor, and maintenance materials.

TABLE A-26. COST EQUATIONS FOR STAGED COMBUSTION AIR APPLIED TO  
RESIDUAL OIL-FIRED BOILERS<sup>7</sup> (Fuel N >0.23 wt. percent)  
(30 - 250 x 10<sup>6</sup> Btu/hr)

---

Routine Code: SCA

Capital Costs:

$$TK = 1000 [(Q)(PRCT) 0.0536 + 2.56 (PRCT)]$$

where:

$$PRCT = 30; \text{ when } N > 0.6$$

$$PRCT = 81.1(N) - 18.7 \text{ when } 0.23 < N < 0.6$$

Annual Costs:

$$SP^a = 0.05 (TK)$$

$$ELEC = 102 (Q)(CF)$$

$$FUEL = 21.9 (FC)(Q)(CF)$$

---

<sup>a</sup>Spare part costs consists of the costs for spare parts, maintenance labor, and maintenance materials.

TABLE A-27. COST EQUATIONS FOR FLUE GAS RECIRCULATION  
APPLIED TO OIL- AND GAS-FIRED BOILERS  
( $<250 \times 10^6$  Btu/hr)

---

Routine Code: FGR

Capital Costs:

$$\begin{aligned} \text{EQUIP} &= 44.72(Q) + 8383 \\ \text{INST and IND} &= 35.6 (Q) + 4189 \end{aligned}$$

Annual Costs:

$$\begin{aligned} \text{SP}^a &= 0.05 (\text{TK}) \\ \text{ELEC} &= (243(Q) + 175)\text{CF} \\ \text{FUEL} &= 43.8 (\text{FC})(Q)(\text{CF}) \end{aligned}$$

---

<sup>a</sup>Spare parts costs consist of the costs for spare parts, maintenance labor, and maintenance materials.

TABLE A-28. COST EQUATIONS FOR REDUCED AIR<sub>7</sub> PREHEAT  
APPLIED TO OIL- AND GAS-FIRED BOILERS<sup>7</sup>

---

---

Routine Code: RAP

Annual Costs:<sup>a</sup>

$$\text{FUEL} = 1.726 \times 10^{-4} (Q) (\text{FC}) (\text{CF}) (\text{FFAC}) (1 + \text{UNCEA}/100) \text{ DELT}$$

---

<sup>a</sup>This algorithm predicts the incremental fuel cost associated with not recovering heat from the boiler flue gas.

## APPENDIX A

### REFERENCES

1. PEDCo Environmental, Inc. Cost Equations for Industrial Boilers. Final Report. (Prepared for U. S. Environmental Protection Agency.) Research Triangle Park, N. C. EPA Contract No. 68-02-3074. January 1980. 23 p..
2. PEDCo Environmental, Inc. Capital and Operating Costs of Particulate Controls on Coal- and Oil-Fired Industrial Boilers. (Prepared for U. S. Environmental Protection Agency.) Research Triangle Park, N. C. EPA-450/5-80-009. August 1980. 129 p.
3. Tighe, S. C., and M. S. Jennings. (Radian Corporation.) Mechanical Collectors for Particulate Control on Stoker Coal-Fired Boilers. January 13, 1981. 35 p.
4. Gardner, R., R. Chang, and L. Broz. (Acurex Corporation.) Cost, Energy and Environmental Algorithms for NO<sub>x</sub>, SO<sub>2</sub>, and PM Controls for Industrial Boilers. Final Report. (Prepared for U. S. Environmental Protection Agency.) Cincinnati, Ohio. EPA Contract No. 68-03-2567. December 1979. p. 20-52.
5. Memo from Kelly, M. E. (Radian Corporation.) to Industrial Boiler File. Summary of Radian Cost Algorithm Development for Industrial Boiler NSPS. January 21, 1981. 33 p.
6. Reference 4, p. 15-19.
7. Memo from Bowen, M.L., Radian Corporation, to Jones, L., EPA:SDB. July 28, 1982. 12 p. NO<sub>x</sub> Combustion Modification Cost Algorithm Development.

## APPENDIX B

### LISTING OF FORTRAN COST ANALYSIS PROGRAM

A FORTRAN computer program was used to develop the costs presented in this report. This appendix provides a listing of the program. A comment block at the beginning of the program provides general information concerning its use.

A basic structure consists of a main subroutine (COST) which accesses various support subroutines. Each costing algorithm presented in Appendix A (Table A-1) is implemented in a separate subroutine. COST accesses these subroutines and provides input/output functions.

Because COST is written as a subroutine rather than a main program, a small main program must be written to use COST. The listing which follows includes such a main program.

B2

```
DSNAME='XEXDUR.D0016.MSTR3.DATA'
00001000 //XEXDUR1 JOB (XEXDUR,VVP0D0016),'MLB',NSGCLASS=Q,NOTIFY=XEXDUR
00002000 //STEP1 EXEC FORTGCLG,CLASS=Q
00003000 //FORT.SYSIN DD *
00004000      REAL CAPC(10,5),OMC(19,5),ANNC(5,5),ADATE(2)
00005000      DATA BLANK,ADS,ADAC/'     ','DS ','DAC '
00006000      READ (5,1000) NN,(ADATE(I),I=1,2)
00006500 1000 FORMAT (I4,2A4)
00006750      CALL CSTCRD
00007000      DO 10 I=1,NN
00007500      DO 20 J=1,5
00008000      DO 30 K=1,10
00008500 30 CAPC(K,J)=0.0
00009000  DO 40 K=1,19
00009500 40 OMC(K,J)=0.0
00010000  DO 50 K=1,5
00010500 50 ANNC(K,J)=0.0
00011000 20 CONTINUE
00011500      READ (5,1001) AB,AS02,APM,IFFLAG
00012000 1001 FORMAT (3A4,I4)
00012500      WRITE (6,1003) I,(ADATE(J),J=1,2),AB,AS02,APM,IFFLAG
00013000 1003 FORMAT (///T2,'MODEL BOILER',I4,T45,2A4/T2,
00013500      *      'BOILER ROUTINE ',A4,T25,'S02 ROUTINE= ',A4,T50,
00014000      *      'PM ROUTINE= ',A4,T75,'FLOW FLAG= ',I4/)
00014500      CALL COST(I,AB,1,1,IFFLAG,CAPC(1,1),OMC(1,1),ANNC(1,1))
00015000      IF (AS02 .EQ. BLANK) GO TO 60
00015500      CALL S02CRD
00016000      IF ((AS02 .EQ. ADS) .OR. (AS02 .EQ. ADAC)) CALL PMCRD
00016500      CALL COST(I,AS02,1,0,IFFLAG,CAPC(1,3),OMC(1,3),ANNC(1,3))
00017000 60 CONTINUE
00017500      IF (APM .EQ. BLANK) GO TO 70
00018000      CALL PMCRD
00018500      CALL COST(I,APM,1,0,IFFLAG,CAPC(1,4),OMC(1,4),ANNC(1,4))
00019000 70 CONTINUE
00019500      CALL BPRNT
00020000      CALL FPRNT
00020500      CALL FMPRNT
00021000      CALL S2PRNT
00021500      CALL CFRNT
00022000      CALL CSTTBL(CAPC,OMC,ANNC,I)
00022250 10 CONTINUE
00022500      RETURN
00022750      END
00023000      SUBROUTINE COST (NN,ANAME,IPFLAG,IRFLAG,IFFLAG,CAPC,OMC,ANNC)
00024000 C
```

00025000 C -----  
00026000 C  
00027000 C COST - COMPUTES CAPITAL, O AND M, AND ANNUAL COSTS OF BOILER  
00028000 C AND CONTROL SYSTEM(S)  
00029000 C WRITTEN BY: M.S. JENNINGS (7/81). SUPPLEMENTARY DOCUMENTAION AVAILA  
00030000 C TO USE, EXECUTE A STATEMENT OF THE FORM  
00031000 C CALL COST (NN,ANAME,IPFLAG,IRFLAG,IFFLAG,CAPC,OMC,ANNC)  
00032000 C WHERE:  
00033000 C NN = ID NUMBER (USER SUPPLIED) PRINTED TO OUTPUT (IF DESI  
00034000 C FOR IDENTIFICATION OF ROUTINE  
00035000 C ANAME = ROUTINE TO BE USED (USER SUPPLIED). ANAME SHOULD BE  
00036000 C 'A' FORMAT (MAXIMUM OF FOUR CHARACTERS). SEE USER M  
00037000 C FOR DESCRIPTION OF VARIOUS ROUTINES AVAILABLE AND IN  
00038000 C REQUIREMENTS FOR EACH.  
00039000 C IPFLAG = PRINT FLAG (USER SUPPLIED).  
00040000 C 0 INDICATES NO PRINTING  
00041000 C 1 INDICATES ONLY INTERMEDIATE CALCULATIONS PRINTED  
00042000 C 2 INDICATES INTERMEDIATE CALCULATIONS AND INPUT DATA  
00043000 C 3 INDICATES INTERMEDIATE CALCULATIONS, INPUT DATA,  
00044000 C AND FINAL COST RESULTS PRINTED  
00045000 C IRFLAG = READ FLAG (USER SUPPLIED) SET NON-ZERO IF INPUT DATA  
00046000 C BE READ FROM INPUT DECK (SEE USERS MANUAL FOR CARD F  
00047000 C REQUIRED FOR ROUTINE SPECIFIED IN ANAME).  
00048000 C IFFLAG = FLUE GAS FLOWRATE FLAG (USER SUPPLIED) SET NONZERO I  
00049000 C ROUTINE IS TO CALCULATE FLUE GAS FLOWRATE. VALUES  
00050000 C SHOULD BE SET AS FOLLOWS:  
00051000 C 0 = FLOWRATE USER SUPPLIED  
00052000 C 1 = COAL, MASS FEED, LEA CONDITIONS  
00053000 C 2 = COAL, MASS FEED, NON-LEA  
00054000 C 3 = FULVERIZED COAL, LEA CONDITIONS  
00055000 C 4 = NATURAL GAS, LEA CONDITIONS  
00056000 C 5 = NATURAL GAS NON-LEA  
00057000 C 6 = OIL, LEA CONDITIONS  
00058000 C 7 = OIL, NON-LEA  
00059000 C CAPC = ARRAY OF CAPITAL COSTS (RETURNED). COMPONENTS OF AR  
00060000 C AS LISTED BELOW:  
00061000 C CAPC(1) = EQUIPMENT  
00062000 C CAPC(2) = INSTALLATION  
00063000 C CAPC(3) = TOTAL DIRECT  
00064000 C CAPC(4) = INDIRECT  
00065000 C CAPC(5) = TOTAL DIRECT AND INDIRECT  
00066000 C CAPC(6) = CONTINGENCIES  
00067000 C CAPC(7) = TURNKEY  
00068000 C CAPC(8) = LAND  
00069000 C CAPC(9) = WORKING CAPITAL

00070000 C CAPC(10) = TOTAL CAPITAL  
 00071000 C OMC = ARRAY OF OPERATIONAL AND MAINTENANCE COSTS (RETURNED)  
 00072000 C COMPONENTS OF ARRAY ARE AS LISTED BELOW:  
 00073000 C OMC(1) = DIRECT LABOR  
 00074000 C OMC(2) = SUPERVISION LABOR  
 00075000 C OMC(3) = MAINTENANCE LABOR  
 00076000 C OMC(4) = SPARE PARTS  
 00077000 C OMC(5) = ELECTRICITY  
 00078000 C OMC(6) = UTILITIES AND CHEMICALS  
 00079000 C OMC(7) = WATER  
 00080000 C OMC(8) = SOLID WASTE DISPOSAL  
 00081000 C OMC(9) = SLUDGE WASTE DISPOSAL  
 00082000 C OMC(10) = LIQUID WASTE DISPOSAL  
 00083000 C OMC(11) = SODIUM CARBONATE  
 00084000 C OMC(12) = LIMESTONE  
 00085000 C OMC(13) = LIME  
 00086000 C OMC(14) = AMMONIA  
 00087000 C OMC(15) = SODIUM HYDROXIDE  
 00088000 C OMC(16) = FUEL  
 00089000 C OMC(17) = TOTAL DIRECT O AND M  
 00090000 C OMC(18) = OVERHEAD  
 00091000 C OMC(19) = TOTAL O AND M  
 00092000 C ANNC = ARRAY OF ANNUALIZED COSTS (RETURNED). COMPONENTS  
 00093000 C ARE AS LISTED BELOW:  
 00094000 C ANNC(1) = CAPITAL RECOVERY  
 00095000 C ANNC(2) = WORKING CAPITAL CHARGES  
 00096000 C ANNC(3) = MISCELLANEOUS (G AND A, TAXES,  
 00097000 C AND INSURANCE)  
 00098000 C ANNC(4) = TOTAL CAPITAL CHARGES  
 00099000 C ANNC(5) = TOTAL ANNUALIZED CHARGES  
 00100000 C FIVE COMMON BLOCKS ARE USED BY COST TO COMMUNICATE BETWEEN VARIOUS  
 00101000 C SUBROUTINES. THESE ARE:  
 00102000 C COMMON /BSPEC/ Q,FLW,CF,BCRF  
 00103000 C COMMON /FUEL/ FC,H,S,A  
 00104000 C COMMON /PM/ UNCPM,CTRPM,EFFPM,CRFP  
 00105000 C COMMON /SO2/ UNCSO2,CTRSO2,EFFSO2,CRFSO2  
 00106000 C COMMON /COSTS/ DLR,SLR,AMLR,ELEC,WTR,ALIME,ALS,ALYE,SASH,SLDG,  
 00107000 C VARIABLE DEFINITIONS ARE AS FOLLOWS:  
 00108000 C Q = BOILER THERMAL INPUT (MMBTU/HR)  
 00109000 C FLW = BOILER FLUE GAS FLOWRATE (ACFM)  
 00110000 C CF = BOILER CAPACITY FACTOR (-)  
 00111000 C BCRF = BOILER CAPITAL RECOVERY FACTOR (-)  
 00112000 C FC = FUEL COST (DOLLARS/MMBTU)  
 00113000 C H = FUEL HEATING VALUE (BTU/LB)  
 00114000 C S = SULFUR CONTENT (PERCENT BY WEIGHT)

00115000 C A = ASH CONTENT (PERCENT BY WEIGHT)  
 00116000 C UNCPM = UNCONTROLLED PM EMISSIONS (LB/MMBTU)  
 00117000 C CTRPM = CONTROLLED PM EMISSIONS (LB/MMBTU)  
 00118000 C EFFPM = PM REMOVAL EFFICIENCY (PERCENT)  
 00119000 C CRFPM = CAPITAL RECOVERY FACTOR FOR PM CONTROL SYSTEM (-)  
 00120000 C UNCSO2 = UNCONTROLLED SO2 EMISSIONS (LB/MMBTU)  
 00121000 C CTRS02 = CONTROLLED SO2 EMISSIONS(LB/MMBTU)  
 00122000 C EFFSO2 = SO2 REMOVAL EFFICIENCY (PERCENT) (NOTE: IF SUBROUTINE  
                  READS DATA THIS VALUE IS CALCULATED INTERNALLY AND  
                  DOES NOT NEED TO BE PROVIDED).  
 00123000 C  
 00124000 C  
 00125000 C CRFS02 = CAPITAL RECOVERY FACTOR FOR SO2 CONTROL SYSTEM (-)  
 00126000 C DLR = DIRECT LABOR RATE (DOLLARS/MAN-HR)  
 00127000 C SLR = SUPERVISION LABOR RATE (DOLLARS/MAN-HR)  
 00128000 C AMLR = MAINTENANCE LABOR RATE (DOLLARS/MAN-HR)  
 00129000 C ELEC = ELECTRICITY RATE (DOLLARS/KW-HR)  
 00130000 C WTR = WATER RATE (DOLLARS/1000 GALS)  
 00131000 C ALIME = LIME RATE (DOLLARS/TON)  
 00132000 C ALS = LIMESTONE RATE (DOLLARS/TON)  
 00133000 C ALYE = LYE RATE (DOLLARS/1000 GALS)  
 00134000 C SASH = SODA ASH RATE (DOLLARS/TON)  
 00135000 C SLDG = SLUDGE DISPOSAL RATE (DOLLARS/TON)  
 00136000 C SWD = SOLID WASTE DISPOSAL RATE (DOLLARS/TON)  
 00137000 C ALWD = LIQUID WASTE DISPOSAL RATE (DOLLARS/1000 GALS)  
 00138000 C NOTE: SOME OF THE COSTS PRESENTED ABOVE ARE NOT USED IN THE ROUTINES  
 00139000 C EXAMPLE, THE BOILER COSTING ROUTINES ASSUME CONSTANTS FOR MANY  
 00140000 C OF THE ABOVE COST RATES AND CHANGING THE VALUES ABOVE WILL HAV  
 00141000 C EFFECT ON THE FINAL COSTS GENERATED (SEE USERS MANUAL).  
 00142000 C  
 00143000 C -----  
 00144000 C  
 00145000       REAL CAPC(10),OMC(19),ANNC(5)  
 00146000       REAL AA(19)  
 00147000       DATA AA /'UNDR','SPRD','FLVR','DNG1','DNG2','RES1','RNG1','RNG2',  
 00148000       \*        'ESPC','ESPO','FF','VS','SM','DM','SSS','DA','NATH',  
 00149000       \*        'DAC','DS'/  
 00150000 C  
 00151000 C  
 00152000 C ZERO COST ARRAYS  
 00153000       DO 10 I=1,10  
 00154000 10      CAPC(I) = -0.0  
 00155000       DO 20 I=1,19  
 00156000 20      OMC(I) = -0.0  
 00157000       DO 30 I=1,5  
 00158000 30      ANNC(I) = -0.0  
 00159000 C CHECK FOR INPUT ON INPUT DECK

```

00160000      IF (IRFLAG.NE.0) CALL READER (ANAME)
00161000 C   CHECK FOR FLUE GAS FLOWRATE CALCULATIONS
00162000      IF (IFFLAG.NE.0) CALL FLUE(IFFLAG)
00163000 C   CHECK FOR PRINTING DESIRED
00164000      IF (IPFLAG.GE.2) CALL IPRNT(ANAME)
00165000 C   CALL APPROPRIATE ROUTINE TO COMPUTE COSTS
00166000      IF (ANAME.EQ.0A(1))  CALL UNDR(CAPC,OMC,ANNC)
00167000      IF (ANAME.EQ.0A(2))  CALL SPRD(CAPC,OMC,ANNC)
00168000      IF (ANAME.EQ.0A(3))  CALL PLVR(CAPC,OMC,ANNC)
00169000      IF (ANAME.EQ.0A(4))  CALL DNG1(CAPC,OMC,ANNC)
00170000      IF (ANAME.EQ.0A(5))  CALL DNG2(CAPC,OMC,ANNC)
00171000      IF (ANAME.EQ.0A(6))  CALL RES1(CAPC,OMC,ANNC)
00172000      IF (ANAME.EQ.0A(7))  CALL RNG1(CAPC,OMC,ANNC)
00173000      IF (ANAME.EQ.0A(8))  CALL RNG2(CAPC,OMC,ANNC)
00174000      IF (ANAME.EQ.0A(9))  CALL ESPC(CAPC,OMC,ANNC,IPFLAG)
00175000      IF (ANAME.EQ.0A(10)) CALL ESPO(CAPC,OMC,ANNC,IPFLAG)
00176000      IF (ANAME.EQ.0A(11)) CALL FF(CAPC,OMC,ANNC)
00177000      IF (ANAME.EQ.0A(12)) CALL VS(CAPC,OMC,ANNC)
00178000      IF (ANAME.EQ.0A(13)) CALL SM(CAPC,OMC,ANNC)
00179000      IF (ANAME.EQ.0A(14)) CALL DM(CAPC,OMC,ANNC)
00180000      IF (ANAME.EQ.0A(15)) CALL SSS(CAPC,OMC,ANNC)
00181000      IF (ANAME.EQ.0A(16)) CALL DA(CAPC,OMC,ANNC,IPFLAG)
00182000      IF (ANAME.EQ.0A(17)) CALL NATH(CAPC,OMC,ANNC,IPFLAG)
00183000      IF (ANAME.EQ.0A(18)) CALL DAC(CAPC,OMC,ANNC,IPFLAG)
00184000      IF (ANAME.EQ.0A(19)) CALL DS(CAPC,OMC,ANNC,IPFLAG)
00185000 C
00186000 C   IF ASKED, PRINT RESULTS
00187000      IF (IPFLAG.EQ.3) CALL SPILL (NN,ANAME,CAPC,OMC,ANNC)
00188000 C
00189000 C
00190000      RETURN
00191000      END
00192000      SUBROUTINE READER (ANAME)
00193000 C   READER - READS INPUT DECK FOR NAMED ROUTINE
00194000 C   INPUT - ANAME = ALPHA VARIABLE GIVING NAME OF ROUTINE FOR WHICH
00195000 C           INPUT IS DESIRED
00196000 C   OUTPUT - COMMON BLOCKS BSPEC,SO2,PM,AND COSTS ARE FILLED AS APPROPRIA
00197000 C
00198000      REAL AA(19)
00199000      DATA AA /'UNDR','SPRD','PLVR','DNG1','DNG2','RES1','RNG1','RNG2',
00200000      *      'ESPC','ESPO','FF','VS','SM','DM','SSS','DA','NATH',
00201000      *      'DAC','DS'/
00202000 C   SEARCH FOR ROUTINE
00203000      IF (ANAME.EQ.0A(1)) GO TO 10
00204000      IF (ANAME.EQ.0A(2)) GO TO 10

```

B-7

```
00205000 IF (ANAME.EQ.AA(3)) GO TO 10
00206000 IF (ANAME.EQ.AA(4)) GO TO 10
00207000 IF (ANAME.EQ.AA(5)) GO TO 10
00208000 IF (ANAME.EQ.AA(6)) GO TO 10
00209000 IF (ANAME.EQ.AA(7)) GO TO 10
00210000 IF (ANAME.EQ.AA(8)) GO TO 10
00211000 IF (ANAME.EQ.AA(9)) GO TO 20
00212000 IF (ANAME.EQ.AA(10)) GO TO 20
00213000 IF (ANAME.EQ.AA(11)) GO TO 20
00214000 IF (ANAME.EQ.AA(12)) GO TO 20
00215000 IF (ANAME.EQ.AA(13)) GO TO 20
00216000 IF (ANAME.EQ.AA(14)) GO TO 20
00217000 IF (ANAME.EQ.AA(15)) GO TO 20
00218000 IF (ANAME.EQ.AA(16)) GO TO 30
00219000 IF (ANAME.EQ.AA(17)) GO TO 30
00220000 IF (ANAME.EQ.AA(18)) GO TO 40
00221000 IF (ANAME.EQ.AA(19)) GO TO 40
00222000 C IF ROUTINE CANT BE LOCATED, OUTPUT MESSAGE AND STOP
00223000 WRITE (6,1000) ANAME
00224000 1000 FORMAT (/T2,'ROUTINE ',A4,' NOT RECOGNIZED - PROGRAM ABORTED')
00225000 STOP
00226000 C BOILER ROUTINE TO BE CALLED
00227000 10 CALL BCRD
00228000 CALL FCRD
00229000 RETURN
00230000 C PM ROUTINE TO BE CALLED
00231000 20 CALL BCRD
00232000 CALL FCRD
00233000 CALL PMCRD
00234000 RETURN
00235000 C SO2 ROUTINE TO BE CALLED
00236000 30 CALL BCRD
00237000 CALL FCRD
00238000 CALL SO2CRD
00239000 CALL CSTCRD
00240000 RETURN
00241000 C COMBINED SO2 AND PM ROUTINE TO BE CALLED
00242000 40 CALL BCRD
00243000 CALL FCRD
00244000 CALL SO2CRD
00245000 CALL PMCRD
00246000 CALL CSTCRD
00247000 RETURN
00248000 END
00249000 SUBROUTINE BCRD
```

00250000 C BCRD - READS IN A BOILER CARD  
00251000 C  
00252000 COMMON /BSPEC/ Q,FLW,CF,BCRF  
00253000 READ (5,1000) Q,FLW,CF,BCRF  
00254000 1000 FORMAT (8F10.0)  
00255000 RETURN  
00256000 END  
00257000 SUBROUTINE FCRD  
00258000 C FCRD - READS IN A FUEL CARD  
00259000 C  
00260000 COMMON /FUEL/ FC,H,S,A  
00261000 READ (5,1000) FC,H,S,A  
00262000 1000 FORMAT (8F10.0)  
00263000 RETURN  
00264000 END  
00265000 SUBROUTINE PMCRD  
00266000 C PMCRD - READS IN A PM CARD  
00267000 C  
00268000 COMMON /PM/ UNCPM,CTRPM,EFFPM,CRFPM  
00269000 READ (5,1000) UNCPM,CTRPM,EFFPM,CRFPM  
00270000 1000 FORMAT (8F10.0)  
00271000 RETURN  
00272000 END  
00273000 SUBROUTINE SO2CRD  
00274000 C SO2CRD - READS IN A SO2 CARD  
00275000 C  
00276000 COMMON /SO2/ UNCSO2,CTRSO2,EFFSO2,CRFSO2  
00277000 READ (5,1000) UNCSO2,CTRSO2,EFFSO2,CRFSO2  
00278000 1000 FORMAT (8F10.0)  
00279000 RETURN  
00280000 END  
00281000 SUBROUTINE CSTCRD  
00282000 C CSTCRD - READS IN A COST RATE CARD  
00283000 C  
00284000 COMMON /COSTS/ DLR,SLR,AMLR,ELEC,WTR,ALIME,ALS,ALYE,SASH,SLDG,  
00285000 \* SWD,ALWD  
00286000 READ (5,1000) ELEC,WTR,ALIME,ALS,SASH,SLDG,SWD,ALWD  
00287000 1000 FORMAT (8F9.0)  
00288000 RETURN  
00289000 END  
00290000 SUBROUTINE FLUE (IFFLAG)  
00291000 C FLUE - CALCULATES FLUE GAS FLOWRATES  
00292000 C  
00293000 COMMON /BSPEC/ Q,FLW,CF,BCRF  
00294000 COMMON /FUEL/ FC,H,S,A

```

00295000      IF (IFFLAG.EQ.1) FLW=1.66E6*Q*EXP(8.141E-5*H)/H
00296000      IF (IFFLAG.EQ.2) FLW=1.836E6*Q*EXP(8.141E-5*H)/H
00297000      IF (IFFLAG.EQ.3) FLW=1.617E6*Q*EXP(8.025E-5*H)/H
00298000      IF (IFFLAG.EQ.4) FLW=6.805E6*Q/H
00299000      IF (IFFLAG.EQ.5) FLW=8.1398E6*Q/H
00300000      IF (IFFLAG.EQ.6) FLW=0.1555*Q*H**0.77
00301000      IF (IFFLAG.EQ.7) FLW=0.1887*Q*H**0.77
00302000      RETURN
00303000      END
00304000      SUBROUTINE IPRNT(ANAME)
00305000 C   IPRNT - PRINTS OUT INPUT DATA
00306000 C   INPUT -
00307000 C   ANAME = NAME OF ROUTINE TO BE USED IN COST ESTIMATION
00308000 C
00309000      REAL AA(19)
00310000      DATA AA /'UNDR','SPRD','PLVR','DNG1','DNG2','RES1','RNG1','RNG2',
00311000      *          'ESPC','ESPO','FF','VS','SM','DM','SSS','DA','NATH',
00312000      *          'DAC','DS'/
00313000 C   SEARCH FOR ROUTINE
00314000      IF (ANAME.EQ.AA(1)) GO TO 10
00315000      IF (ANAME.EQ.AA(2)) GO TO 10
00316000      IF (ANAME.EQ.AA(3)) GO TO 10
00317000      IF (ANAME.EQ.AA(4)) GO TO 10
00318000      IF (ANAME.EQ.AA(5)) GO TO 10
00319000      IF (ANAME.EQ.AA(6)) GO TO 10
00320000      IF (ANAME.EQ.AA(7)) GO TO 10
00321000      IF (ANAME.EQ.AA(8)) GO TO 10
00322000      IF (ANAME.EQ.AA(9)) GO TO 20
00323000      IF (ANAME.EQ.AA(10)) GO TO 20
00324000      IF (ANAME.EQ.AA(11)) GO TO 20
00325000      IF (ANAME.EQ.AA(12)) GO TO 20
00326000      IF (ANAME.EQ.AA(13)) GO TO 20
00327000      IF (ANAME.EQ.AA(14)) GO TO 20
00328000      IF (ANAME.EQ.AA(15)) GO TO 20
00329000      IF (ANAME.EQ.AA(16)) GO TO 30
00330000      IF (ANAME.EQ.AA(17)) GO TO 30
00331000      IF (ANAME.EQ.AA(18)) GO TO 40
00332000      IF (ANAME.EQ.AA(19)) GO TO 40
00333000 C   IF ROUTINE CANT BE LOCATED, OUTPUT MESSAGE AND STOP
00334000      WRITE (6,1000) ANAME
00335000 1000 FORMAT (/T2,'ROUTINE ',A4,' NOT RECOGNIZED - PROGRAM ABORTED')
00336000      STOP
00337000 C   BOILER ROUTINE TO BE RUN
00338000 10      CALL BPRNT
00339000      CALL FPRNT

```

00340000 RETURN  
00341000 C FM ROUTINE TO BE RUN  
00342000 20 CALL BPRNT  
00343000 CALL FPRNT  
00344000 CALL PMPRNT  
00345000 RETURN  
00346000 C S02 ROUTINE TO BE RUN  
00347000 30 CALL BPRNT  
00348000 CALL FPRNT  
00349000 CALL S2PRNT  
00350000 CALL CPRNT  
00351000 RETURN  
00352000 C COMBINED S02 AND FM ROUTINE TO BE RUN  
00353000 40 CALL BPRNT  
00354000 CALL FPRNT  
00355000 CALL S2PRNT  
00356000 CALL PMPRNT  
00357000 CALL CPRNT  
00358000 RETURN  
00359000 END  
00360000 SUBROUTINE BPRNT  
00361000 C BPRNT - PRINTS OUT BOILER SPECIFICATIONS  
00362000 C  
00363000 COMMON /BSPEC/ Q,FLW,CF,BCRF  
00364000 WRITE (6,1000) Q,FLW,CF,BCRF  
00365000 1000 FORMAT (T2,'BOILER SPECIFICATIONS'/  
00366000 \* T5,'Q=',T11,F6.1,T18,  
00367000 \* 'FLW=',T23,F6.0,T30,  
00368000 \* 'CF=',T35,F6.3,T42,  
00369000 \* 'CRF=',T47,F6.4)  
00370000 RETURN  
00371000 END  
00372000 SUBROUTINE FPRNT  
00373000 C FPRNT - PRINTS OUT FUEL SPECIFICATIONS  
00374000 C  
00375000 COMMON /FUEL/ FC,H,S,A  
00376000 WRITE (6,1000) FC,H,S,A  
00377000 1000 FORMAT (T2,'FUEL SPECIFICATIONS'/  
00378000 \* T5,'FC=',T11,F6.2,T18,  
00379000 \* 'H=',T23,F6.0,T30,  
00380000 \* 'S=',T35,F6.2,T42,  
00381000 \* 'A=',T47,F6.2)  
00382000 RETURN  
00383000 END  
00384000 SUBROUTINE PMPRNT

```

00385000 C FMPRNT - PRINTS OUT PM EMISSIONS DATA
00386000 C
00387000     COMMON /PM/ UNCPM,CTRPM,EFFPM,CRFPM
00388000     WRITE (6,1000) UNCPM,CTRPM,EFFPM,CRFPM
00389000 1000 FORMAT (T2,'PM EMISSIONS'
00390000     *      T5,'UNC=',T11,F6.3,T18,
00391000     *      'CTR=',T23,F6.3,T30,
00392000     *      'EFF=',T35,F6.2,T42,
00393000     *      'CRF=',T47,F6.4)
00394000     RETURN
00395000     END
00396000     SUBROUTINE S2PRNT
00397000 C S2PRNT - PRINTS OUT SO2 EMISSIONS DATA
00398000 C
00399000     COMMON /SO2/ UNCSO2,CTRSO2,EFFSO2,CRFSO2
00400000     WRITE (6,1000) UNCSO2,CTRSO2,EFFSO2,CRFSO2
00401000 1000 FORMAT (T2,'SO2 EMISSIONS'
00402000     *      T5,'UNC=',T11,F6.3,T18,
00403000     *      'CTR=',T23,F6.3,T30,
00404000     *      'EFF=',T35,F6.2,T42,
00405000     *      'CRF=',T47,F6.4)
00406000     RETURN
00407000     END
00408000     SUBROUTINE CPRNT
00409000 C CPRNT - PRINTS OUT COST RATE DATA
00410000 C
00411000     COMMON /COSTS/ DLR,SLR,AMLR,ELEC,WTR,ALIME,ALS,ALYE,SASH,SLDG,
00412000     *      SWD,ALWD
00413000     WRITE (6,1000) ELEC,WTR,ALIME,ALS,SASH,SLDG,SWD,ALWD
00414000 1000 FORMAT (T2,'COST RATES'
00415000     *      T5,'ELEC=',T11,F6.4,T18,
00416000     *      'WTR=',T23,F6.2,T30,
00417000     *      'LIME=',T35,F6.2,T42,
00418000     *      'ALS=',T47,F6.2,T54,
00419000     *      'SASH=',T59,F6.2,T66,
00420000     *      'SLDG=',T71,F6.2,T78,
00421000     *      'SWD=',T83,F6.2,T90,
00422000     *      'ALWD=',T95,F6.2)
00424000     RETURN
00425000     END
00426000     SUBROUTINE CSTTBL(CAPC,OMC,ANNC,N)
00427000 C CSTTBL - PRINTS OUT A BOILER COST TABLE
00428000 C INPUT -
00429000 C     CAPC = 10 X 5 ARRAY OF CAPITAL COSTS
00430000 C     OMC = 19 X 5 ARRAY OF O AND M COSTS

```

```

00431000 C      ANNC =      5 X 5 ARRAY OF TOTAL ANNUALIZED COSTS
00432000 C      NOTE:      IN THESE THREE ARRAYS, THE FIRST SUBSCRIPT DENOTES
00433000 C              THE COST COMPONENT.  THE SECOND SUBSCRIPT DENOTES
00434000 C              THE BOILER OR CONTROL SYSTEM AS FOLLOWS:
00435000 C          1 =        BOILER
00436000 C          2 =        NOX CONTROL
00437000 C          3 =        SO2 CONTROL
00438000 C          4 =        PM CONTROL
00439000 C          5 =        TOTAL (SUM OF 1 - 4)
00440000 C      N =        IDENTIFICATION NUMBER PRINTED TO OUTPUT
00441000 C
00442000 C      CSTTBL AUTOMATICALLY PERFORMS THE SUMMING OF COSTS INTO THE FIFTH
00443000 C      COLUMN OF EACH COST ARRAY
00444000 C
00445000      REAL CAPC(10,5),OMC(19,5),ANNC(5,5),ACAPC(10),ADM(19),AANN(5)
00446000      DATA ACAPC /'EQUP','INST','TD','IND','TDI','CONT','TK','LAND',
00447000      *           'WC','TOTL',//,
00448000      *           ADM /'DL','SPRV','MANT','SP','ELEC','UC','WTR','SW',
00449000      *           'SLDG','LW','SC','LMS','LIME','NH3','LYE','FUEL',
00450000      *           'TDOM','OH','TOTL',//,
00451000      *           AANN /'CR','WCC','MISC','TCC','TOTL'/
00452000      DO 100 J=1,4
00453000      DO 200 K=1,10
00454000  200  CAPC(K,5)=CAPC(K,5)+CAPC(K,J)
00455000      DO 210 K=1,19
00456000  210  OMC(K,5)=OMC(K,5)+OMC(K,J)
00457000      DO 220 K=1,5
00458000  220  ANNC(K,5)=ANNC(K,5)+ANNC(K,J)
00459000  100  CONTINUE
00460000      WRITE (6,1000) N
00461000  1000  FORMAT (/T2,'COST SUMMARY TABLE - RUN NO. ',I5/T2,80(''')/
00462000      *           T2,'ITEM',T15,
00463000      *           'BOILER',T30,'NOX CONTROL',T45,'SO2 CONTROL',T60,
00464000      *           'PM CONTROL',T75,'TOTAL'/T2,80(''')/
00465000      DO 10 I=1,10
00466000  10  WRITE (6,1001) ACAPC(I), (CAPC(I,J),J=1,5)
00467000  1001 FORMAT (T2,A4,T10,5(F12.0,3X))
00468000      WRITE (6,1002)
00469000  1002 FORMAT (' ')
00470000      DO 20 I=1,19
00471000  20  WRITE (6,1001) ADM(I),(OMC(I,J),J=1,5)
00472000      WRITE (6,1002)
00473000      DO 30 I=1,5
00474000  30  WRITE (6,1001) AANN(I),(ANNC(I,J),J=1,5)
00475000      RETURN

```

```

00476000      END
00477000      SUBROUTINE SPILL (N,ANAME,CAPC,OMC,ANNC)
00478000 C   SPILL - OUTPUTS A DETAILED COST BREAKDOWN
00479000 C   INPUT - CAPC = ARRAY OF CAPITAL COSTS
00480000 C       OMC = ARRAY OF OPERATION AND MAINTENANCE COSTS
00481000 C       ANNC = ARRAY OF ANNUALIZED COSTS
00482000 C   OUTPUT - COSTS ARE PRINTED
00483000 C
00484000      REAL CAPC(10),OMC(19),ANNC(5)
00485000      REAL ACAPC(10),AOMC(19),AANNC(5)
00486000      DATA ACAPC // 'EQUIP','INST','TD','IND','TDI','CONT','TK','LAND',
00487000      *           'WC','TOTL',//,
00488000      *           AOMC // 'DL','SPRV','MANT','SP','ELEC','UC','WTR','SW',
00489000      *           'SLDG','LW','SC','LMS','LINE','NH3','LYE','FUEL',
00490000      *           'TDOM','OH','TOTL',//,
00491000      *           AANNC // 'CR','WCC','MISC','TCC','TOTL'
00492000 C   WRITE OUT HEADER
00493000      WRITE (6,1000) ANAME,N
00494000 1000 FORMAT (/T2,'COST BREAKDOWN - ROUTINE ',A4,', - RUN NO. ',I5)
00495000 C   OUTPUT CAPITAL COSTS
00496000      WRITE (6,1001)
00497000 1001 FORMAT (T2,'CAPITAL COSTS')
00498000      DO 10 I=1,10
00499000 10 IF (CAPC(I).NE.0.0) WRITE (6,1002) ACAPC(I),CAPC(I)
00500000 1002 FORMAT (T2,A4,' = ',F12.1)
00501000 C   OUTPUT O AND M COSTS
00502000      WRITE (6,1003)
00503000 1003 FORMAT (T2,'OPERATION AND MAINTENANCE COSTS')
00504000      DO 30 I=1,19
00505000 30 IF (OMC(I).NE.0.0) WRITE (6,1002) AOMC(I),OMC(I)
00506000 C   OUTPUT ANNUALIZED COSTS
00507000      WRITE (6,1004)
00508000 1004 FORMAT (T2,'ANNUALIZED COSTS')
00509000      DO 50 I=1,5
00510000 50 IF (ANNC(I).NE.0.0) WRITE (6,1002) AANNC(I),ANNC(I)
00511000      RETURN
00512000      END
00513000      SUBROUTINE FNLCST(CAPC,OMC,ANNC,CRF,IFLAG)
00514000 C   FNLCST - PERFORMS FINAL COST CALCULATIONS FOR COMMON OPERATIONS
00515000 C
00516000      REAL CAPC(10),OMC(19),ANNC(5)
00517000      DATA OH1,OH2,WCF1,WCF2,WCF3,GA,CTG
00518000      $     /0.56,0.26,0.25,0.10,0.0833,0.04,0.2/
00519000      IF (IFLAG.EQ. 0) GO TO 20
00520000      CAPC(3)=CAPC(1)+CAPC(2)

```

```

00521000      CAPC(5)=CAPC(3)+CAPC(4)
00522000      CAPC(6)=CTG*CAPC(5)
00523000      CAPC(7)=CAPC(6)+CAPC(5)
00524000      DO 10 I=1,16
00525000  10  OMC(17)=OMC(17)+OMC(I)
00526000      OMC(18)=OH1*OMC(1)+OH2*(OMC(2) + OMC(3) + OMC(4))
00527000      OMC(19)=OMC(17) + OMC(18)
00528000      CAPC(9)=WCF1*(OMC(17)-OMC(16))+WCF3*OMC(16)
00529000      CAPC(10)=CAPC(7)+CAPC(8)+CAPC(9)
00530000  20  ANNC(1)=CRF*CAPC(7)
00531000      ANNC(2)=WCF2*CAPC(9)
00532000      ANNC(3)=GA*CAPC(7)
00533000      ANNC(4)=ANNC(1)+ANNC(2)+ANNC(3)
00534000      ANNC(5)=ANNC(4)+OMC(19)
00535000      RETURN
00536000      END
00537000      REAL FUNCTION ALF(CF)
00538000 C  ALF - FUNCTION TO CALCULATE LABOR FACTORS BASED ON CAPACITY FACTORS
00539000 C
00540000      IF(CF .GT. 0.7) ALF=1.0
00541000      IF ((CF .LE. 0.7) .AND. (CF .GE. 0.5)) ALF=0.5+2.5*(CF-0.5)
00542000      IF (CF .LT. 0.5) ALF=0.5
00543000      RETURN
00544000      END
00545000      SUBROUTINE LIMIT (Q,QLOW,QHIGH,ANAME)
00546000 C  LIMIT - CHECKS TO SEE IF THERMAL INPUT WITHIN BOUNDS OF ALGORITHM
00547000 C  INPUT - Q = THERMAL INPUT
00548000 C      QLOW = LOWER LIMIT
00549000 C      QHIGH = UPPER LIMIT
00550000 C      ANAME = ALPHA STRING OF ROUTINE CALLED
00551000 C
00552000 C  CHECK LIMITS
00553000      IF ((Q .LT. QLOW) .OR. (Q .GT. QHIGH)) WRITE (6,1000) ANAME
00554000  1000 FORMAT (/T2,'WARNING - ROUTINE ',A4,', CALLED WITH THERMAL INPUT',
00555000      *                   ' OUT OF RANGE')
00556000      RETURN
00557000      END
00558000      SUBROUTINE UNDR (CAPC,OMC,ANNC)
00559000 C  UNDR - ROUTINE FOR ESTIMATION OF UNDERFEED STOKER BOILER COSTS
00560000 C      APPLICABLE TO :
00561000 C          UNDERFEED STOKERS
00562000 C          LESS THAN 75 MMBTU/HR
00563000 C          WATERTUBE
00564000 C          FIELD-ERECTED
00565000 C

```

```

00566000 C =====
00567000      REAL CAPC(10),OMC(19),ANNC(5)
00568000      COMMON /BSPEC/ Q,FLW,CF,BCRF
00569000      COMMON /FUEL/ FC,H,S,A
00570000      CALL LIMIT(Q,15.0,75.0,'UNDR')
00571000      H1=11800/H
00572000      CAPC(1)=66392.*Q**0.622*H1+2257.*Q**0.819
00573000      CAPC(2)=53219.*Q**0.65*H1+2282.*Q**0.796
00574000      CAPC(4)=40188.*Q**0.646*H1**0.926
00574500      CAPC(8)=2000
00575000      OMC(1)=ALF(CF)*(38020* ALOG(Q)+28640)*0.767
00576000      OMC(2)=ALF(CF)*((Q+5300000.)/(99.29-Q))*0.767
00577000      OMC(3)=ALF(CF)*((Q+4955000)/(99.23-Q))*0.767
00578000      OMC(4)=(1.705E8*Q-2.959E8)**.5*H1**1.0028*0.767
00579000      OMC(6)=(CF/0.6)*(Q/(1.105E-5*Q+3.69E-4))*H1**0.9*(A/10.6)**0.3
00579500      **0.848
00580000      OMC(8)=(CF/0.6)*443.3*Q*H1**0.9*(A/10.6)**0.3*0.848
00581000      OMC(16)=CF*Q*8760*FC
00582000      CALL FNLCST(CAPC,OMC,ANNC,BCRF,1)
00583000      RETURN
00584000      END
00585000      SUBROUTINE SPRD(CAPC,OMC,ANNC)
00586000 C SPRD - ROUTINE FOR ESTIMATION OF SPREADER STOKER BOILER COSTS
00587000 C      APPLICABLE TO :
00588000 C          SPREADER STOKERS
00589000 C          WATERTUBE
00590000 C          FIELD-ERECTED
00591000 C          60-200 MMBTU/HR
00592000 C
00593000 C =====
00594000      REAL CAPC(10),OMC(19),ANNC(5)
00595000      COMMON /BSPEC/ Q,FLW,CF,BCRF
00596000      COMMON /FUEL/ FC,H,S,A
00597000      CALL LIMIT(Q,60.0,200.0,'SPRD')
00598000      H1=H/11800.
00599000      CAPC(1)=(Q/(7.5963E-8*Q+4.7611E-5))*H1**(-0.35)
00600000      CAPC(2)=(Q/(8.9174E-8*Q+5.5891E-5))*H1**(-0.35)
00601000      CAPC(4)=(Q/(1.2739E-7*Q+7.9845E-5))*H1**(-0.35)
00601500      CAPC(8)=2000
00602000      OMC(1)=ALF(CF)*(202825+5.366*Q**2)*0.767
00603000      OMC(2)=ALF(CF)*136900*0.767
00604000      OMC(3)=ALF(CF)*(107003+1.873*Q**2)*0.767
00605000      OMC(4)=(50000+1000*Q)*0.767
00606000      OMC(6)=CF*(29303.+719.8*Q)*0.848
00607000      OMC(8)=CF*(547320.+66038*ALOG(A/H))*(Q/150.0)**0.9754*0.38*0.848

```

```

00608000      OMC(16)=CF*Q*8760*FC
00609000      CALL FNLCST (CAPC,OMC,ANNC,BCRF,1)
00610000      RETURN
00611000      END
00612000      SUBROUTINE PLVR(CAPC,OMC,ANNC)
00613000 C   PLVR - ROUTINE FOR ESTIMATION OF PULVERIZED COAL-FIRED BOILER COSTS
00614000 C       APPLICABLE TO :
00615000 C           PULVERIZED COAL-FIRED
00616000 C           WATERTUBE
00617000 C           FIELD-ERECTED
00618000 C           GREATER THAN 200 MMBTU/HR
00619000 C
00620000 C =====
00621000      REAL CAPC(10),OMC(19),ANNC(5)
00622000      COMMON /BSPEC/ Q,FLW,CF,BCRF
00623000      COMMON /FUEL/ FC,H,S,A
00624000      CALL LIMIT (Q,200.0,700.0,'PLVR')
00625000      CAPC(1)=(4926066.-0.00337*H**2.0)*(Q/200.)**0.712
00626000      CAPC(2)=1547622.7+6740.026*Q-0.0024133*H**2.0
00627000      CAPC(4)=1257434.72+6271.316*Q-0.00185721*H**2.0
00627500      CAPC(8)=4000
00628000      OMC(1)=ALF(CF)*(244455+1157*Q)*0.767
00629000      OMC(2)=ALF(CF)*(243985.-20636709./Q)*0.767
00630000      OMC(3)=ALF(CF)*(-1162910.+256604.* ALOG(Q))*0.767
00631000      OMC(4)=(180429.+405.1*Q)*0.767
00632000      OMC(6)=CF*(189430.+1476.7*Q)*0.848
00633000      OMC(8)=CF*(-641.08+70679828*A/H)*(Q/200)**1.001*0.38*0.848
00634000      OMC(16)=CF*Q*8760.*FC
00635000      CALL FNLCST(CAPC,OMC,ANNC,BCRF,1)
00636000      RETURN
00637000      END
00638000      SUBROUTINE RES1(CAPC,OMC,ANNC)
00639000 C   RES1 - ROUTINE FOR ESTIMATION OF FIRETUBE RESIDUAL-FIRED BOILER COSTS
00640000 C       APPLICABLE TO :
00641000 C           RESIDUAL OIL-FIRED
00642000 C           FIRETUBE
00643000 C           PACKAGE
00644000 C           LESS THAN 30 MMBTU/HR
00645000 C
00646000 C =====
00647000      REAL CAPC(10),OMC(19),ANNC(5)
00648000      COMMON /BSPEC/ Q,FLW,CF,BCRF
00649000      COMMON /FUEL/ FC,H,S,A
00650000      CALL LIMIT(Q,0.0,30.0,'RES1')
00651000      CAPC(1)=17360*Q**0.557

```

```

00652000      CAPC(2)=4324*Q+56177
00653000      CAPC(4)=2317*Q+29749
00653500      CAPC(8)=2000
00654000      OMC(1)=ALF(CF)*105300*0.799
00655000      IF (Q.LT.15) OMC(2)=ALF(CF)*((Q-5)/10)*68500*0.799
00656000      IF (Q.GE.15) OMC(2)=ALF(CF)*68500*0.799
00657000      IF (Q.LT.15) OMC(3)=ALF(CF)*(1600*Q+8000)*0.799
00658000      IF (Q.GE.15) OMC(3)=ALF(CF)*32000*0.799
00659000      OMC(4)=(708.7*Q+4424)*0.799
00660000      OMC(6)=(CF/0.45)*(580*Q+3900)*0.845
00661000      OMC(16)=CF*Q*8760*FC
00662000      CALL FNLCST(CAPC,OMC,ANNC,BCRF,1)
00663000      RETURN
00664000      END
00665000      SUBROUTINE DNG1(CAPC,OMC,ANNC)
00666000 C  DNG1 - ROUTINE FOR ESTIMATION OF DISTILLATE/NG FIRED BOILER COSTS
00667000 C      APPLICABLE TO :
00668000 C          DUAL-FIRED (DISTILLATE AND/OR NATURAL GAS)
00669000 C          FIRETUBE
00670000 C          PACKAGE
00671000 C          LESS THAN 30 MMBTU/HR
00672000 C
00673000 C =====
00674000      REAL CAPC(10),OMC(19),ANNC(5)
00675000      COMMON /BSPEC/ Q,FLW,CF,BCRF
00676000      COMMON /FUEL/ FC,H,S,A
00677000      CALL LIMIT(Q,0.0,30.0,'DNG1')
00678000      CAPC(1)=15918*Q**0.561
00679000      CAPC(2)=4261*Q+56041
00680000      CAPC(4)=2256*Q+28649
00680500      CAPC(8)=2000
00681000      OMC(1)=ALF(CF)*105300*0.799
00682000      IF (Q.LT.15) OMC(2)=ALF(CF)*((Q-5)/10)*68500*0.799
00683000      IF (Q.GE.15) OMC(2)=ALF(CF)*68500*0.799
00684000      IF (Q.LT.15) OMC(3)=ALF(CF)*(1600*Q+8000)*0.799
00685000      IF (Q.GE.15) OMC(3)=ALF(CF)*32000*0.799
00686000      OMC(4)=(708.7*Q+4424)*0.799
00687000      OMC(6)=(CF/0.45)*(580*Q+3900)*0.845
00688000      OMC(16)=CF*Q*8760*FC
00689000      CALL FNLCST(CAPC,OMC,ANNC,BCRF,1)
00690000      RETURN
00691000      END
00692000      SUBROUTINE DNG2(CAPC,OMC,ANNC)
00693000 C  DNG2 - ROUTINE FOR ESTIMATION OF DISTILLATE/NG FIRED BOILER COSTS
00694000 C      APPLICABLE TO :

```

00695000 C DUAL-FIRED (DISTILLATE AND/OR NATURAL GAS)  
00696000 C WATERTUBE  
00697000 C PACKAGE  
00698000 C 30-200 MMBTU/HR  
00699000 C  
00700000 C ======  
00701000 REAL CAPC(10),OMC(19),ANNC(5)  
00702000 COMMON /BSPEC/ Q,FLW,CF,BCRF  
00703000 COMMON /FUEL/ FC,H,S,A  
00704000 CALL LIMIT(Q,30.0,200.0,'DNG2')  
00705000 CAPC(1)=14850\*Q\*\*0.786  
00706000 CAPC(2)=54620\*Q\*\*0.361  
00707000 CAPC(4)=15952\*Q\*\*0.618  
00707500 CAPC(8)=2000  
00708000 OMC(1)=ALF(CF)\*(Q\*\*2/(8.135E-4\*Q-1.585E-2))\*0.799  
00709000 OMC(2)=ALF(CF)\*68500\*0.799  
00710000 OMC(3)=ALF(CF)\*(-1267000/Q+77190)\*0.799  
00711000 OMC(4)=(7185\*Q\*\*0.4241)\*0.799  
00712000 OMC(6)=(CF/0.55)\*(202\*Q+24262)\*0.845  
00713000 OMC(16)=CF\*Q\*8760\*FC  
00714000 CALL FNLCST(CAPC,OMC,ANNC,BCRF,1)  
00715000 RETURN  
00716000 END  
00717000 SUBROUTINE RNG1(CAPC,OMC,ANNC)  
00718000 C RNG1 - ROUTINE FOR ESTIMATION OF RESIDUAL/NG FIRED BOILER COSTS  
00719000 C APPLICABLE TO :  
00720000 C DUAL-FIRED (RESIDUAL AND/OR NATURAL GAS)  
00721000 C WATERTUBE  
00722000 C PACKAGE  
00723000 C 30-200 MMBTU/HR  
00724000 C  
00725000 C ======  
00726000 REAL CAPC(10),OMC(19),ANNC(5)  
00727000 COMMON /BSPEC/ Q,FLW,CF,BCRF  
00728000 COMMON /FUEL/ FC,H,S,A  
00729000 CALL LIMIT(Q,30.0,200.0,'RNG1')  
00730000 CAPC(1)=15925.\*Q\*\*0.775  
00731000 CAPC(2)=54833.\*Q\*\*0.364  
00732000 CAPC(4)=16561.\*Q\*\*0.613  
00732500 CAPC(8)=2000  
00733000 OMC(1)=ALF(CF)\*(Q\*\*2/(8.135E-4\*Q-1.585E-2))\*0.799  
00734000 OMC(2)=ALF(CF)\*68500.\*0.799  
00735000 OMC(3)=ALF(CF)\*(-1267000./Q+77190.)\*0.799  
00736000 OMC(4)=(7185.\*Q\*\*0.4241)\*0.799  
00737000 OMC(6)=(CF/0.55)\*(202\*Q+24262)\*0.845

B-18

```

00738000      OMC(16)= CF*Q*8760.*FC
00739000      CALL FNLCST(CAPC,OMC,ANNC,BCRF,1)
00740000      RETURN
00741000      END
00742000      SUBROUTINE RNG2(CAPC,OMC,ANNC)
00743000 C   RNG2 - ROUTINE FOR ESTIMATION OF RESIDUAL/NG FIRED BOILER COSTS
00744000 C       APPLICABLE TO :
00745000 C           DUAL-FIRED (RESIDUAL AND/OR NATURAL GAS)
00746000 C           WATERTUBE
00747000 C           FIELD-ERECTED
00748000 C           200-700 MMBTU/HR
00749000 C
00750000 C =====
00751000      REAL CAPC(10),OMC(19),ANNC(5)
00752000      COMMON /BSPEC/ Q,FLW,CF,BCRF
00753000      COMMON /FUEL/ FC,H,S,A
00754000      CALL LIMIT(Q,200.0,700.0,'RNG2')
00755000      CAPC(1)=1024258.+8458.*Q
00756000      CAPC(2)=579895.+5636.*Q
00757000      CAPC(4)=515189.+4524.*Q
00757500      CAPC(8)=2000
00758000      OMC(1)=ALF(CF)*(173197+734*Q)*0.799
00759000      OMC(2)=ALF(CF)*(263250,-30940000./Q)*0.799
00760000      OMC(3)=ALF(CF)*(32029.+320.4*Q)*0.799
00761000      OMC(4)=(50000.+250.*Q)*0.799
00762000      OMC(6)=CF*(43671.7+479.6*Q)*0.845
00763000      OMC(16)=CF*Q*8760.*FC
00764000      CALL FNLCST(CAPC,OMC,ANNC,BCRF,1)
00765000      RETURN
00766000      END
00767000      SUBROUTINE ESPC(CAPC,OMC,ANNC,IPFLAG)
00768000 C   ESPC - ROUTINE FOR ESTIMATION OF ESP COSTS (COAL-FIRED BOILER APPLICA
00769000 C       APPLICABLE TO :
00770000 C           COAL-FIRED BOILER APPLICATIONS
00771000 C           BOILERS WITH THERMAL INPUTS LESS THAN 700 MMRTU/HR
00772000 C
00773000 C =====
00774000      REAL CAPC(10),OMC(19),ANNC(5)
00775000      COMMON /BSPEC/ Q,FLW,CF,BCRF
00776000      COMMON /FUEL/ FC,H,S,A
00777000      COMMON /PM/ UNCPM,CTRPM,EFFPM,CRFPM
00778000      CALL LIMIT (Q,30.0,700.0,'ESPC')
00779000      SCA = 324.32*(S**(-11.256*(EFFPM**(-0.745))))
00780000      *    *((100.-EFFPM)**(-0.366*(S**(-0.051))))*1.18178
00781000      TPA = SCA*FLW/1000.

```

```

00782000      IF (IPFLAG.NE.0) WRITE (6,1001) SCA,TPA
00783000  1001 FORMAT (/T2,'SPECIFIC COLLECTION AREA (SQ FT/1000 ACFM) = ',
00784000          *     F8.1/T2, 'TOTAL PLATE AREA (SQ FT) = ',F10.1)
00785000          IF (Q.GE.100.) GO TO 10
00786000          CAPC(1) = 0.02457*SCA*FLW-5.62E-10*(SCA*FLW)**2.0+0.544*FLW+2633.
00787000          CAPC(2) = CAPC(1)*1.17
00788000          GO TO 20
00789000  10      IF (TPA.LT.28000.) CAPC(1) = 0.02457*SCA*FLW-5.62E-10*(SCA*FLW)
00790000          * **2.0+130000.+226.*Q
00791000          IF (TPA.GE.28000.) CAPC(1)=0.00965*SCA*FLW-2.54E-11*(SCA*FLW)
00792000          * **2.0+130000.+226.*Q
00793000          CAPC(2) = CAPC(1)*1.10
00794000  20      CAPC(4) = 0.334*(CAPC(1)+CAPC(2))
00795000          IF (Q.GT.400.) GO TO 30
00796000          OMC(1)=ALF(CF)*(10150.+106.*Q)
00797000          OMC(3)=ALF(CF)*(14840.+0.106*Q**2.0)
00798000          GO TO 40
00799000  30      OMC(1)=ALF(CF)*52600.
00800000          OMC(2)=ALF(CF)*17000.
00801000          OMC(3)=ALF(CF)*32000.
00802000  40      OMC(4)=5.52E-3*(CAPC(1)+CAPC(2)+CAPC(4))
00803000          OMC(6)=(CF/0.6)*(0.4068*TPA+2.523*Q*(UNCPM-CTRPM))
00804000          OMC(8)=(CF/0.6)*39.42*Q*(UNCPM-CTRPM)
00805000          CALL FNLCST(CAPC,OMC,ANNC,CRFPM,1)
00806000          RETURN
00807000          END
00808000          SUBROUTINE ESPO(CAPC,OMC,ANNC,IPFLAG)
00809000 C   ESPO - ROUTINE FOR ESTIMATION OF ESP COSTS (OIL-FIRED BOILER APPLICATION)
00810000 C           APPLICABLE TO :
00811000 C               OIL-FIRED BOILER APPLICATIONS
00812000 C               BOILERS WITH THERMAL INPUTS LESS THAN 700 MMBTU/HR
00813000 C
00814000 C =====
00815000          REAL CAPC (10),OMC(19),ANNC(5)
00816000          COMMON /BSPEC/ Q,FLW,CF,BCRF
00817000          COMMON /FUEL/ FC,H,S,A
00818000          COMMON /PM/ UNCPM,CTRPM,EFFPM,CRFFPM
00819000          CALL LIMIT(Q,30.0,700.0,'ESPO')
00820000          SCA=400.
00821000          TPA=SCA*FLW/1000.
00822000          IF (IPFLAG.NE.0) WRITE (6,1001) SCA,TPA
00823000  1001 FORMAT (/T2,'SPECIFIC COLLECTOR AREA(SQ FT/1000 ACFM)=', F8.1/T2,
00824000          * 'TOTAL PLATE AREA (SQ FT)= ',F10.1)
00825000          IF (Q.GE.100) GO TO 40
00826000          CAPC(1)=0.02457*SCA*FLW-5.62E-10*(SCA*FLW)**2+(0.544*FLW+2633)

```

```

00827000      CAPC(2)=1.17*CAPC(1)
00828000      GO TO 30
00829000  40  CONTINUE
00830000      IF (TPA.LT.28000.)CAPC(1) = 0.02457*SCA*FLW-5.62E-10*(SCA*FLW)**
00831000      * 2.0+(0.544*FLW+26353.)
00832000      IF (TPA.GE.28000.) CAPC(1)=0.00965*SCA*FLW-2.54E-11*(SCA*FLW)**
00833000      * 2.0+(0.544*FLW+26353.)
00834000      CAPC(2)=1.10*CAPC(1)
00835000  30  CAPC(4)=0.334*(CAPC(1)+CAPC(2))
00836000      IF (Q.GT.400.) GO TO 10
00837000      OMC(1)= ALF(CF)*(10150.+106.*Q)
00838000      OMC(3)= ALF(CF)*(14840.+0.106*Q**2.0)
00839000      GO TO 20
00840000  10  OMC(1)= ALF(CF)*52600.
00841000      OMC(2)= ALF(CF)*17000.
00842000      OMC(3)= ALF(CF)*32000.
00843000  20  OMC(4)=5.52E-3*(CAPC(1)+CAPC(2)+CAPC(4))
00844000      OMC(6)=(CF/0.6)*(0.1068*TPA+2.523*Q*(UNCPM-CTRPM))
00845000      CALL FNLCST (CAPC,OMC,ANNC,CRFPM,1)
00846000      RETURN
00847000      END
00848000      SUBROUTINE FF(CAPC,OMC,ANNC)
00849000 C  FF - ROUTINE FOR ESTIMATION OF FABRIC FILTER COSTS
00850000 C      APPLICABLE TO :
00851000 C          COAL FIRED BOILER APPLICATIONS
00852000 C          BOILERS WITH THERMAL INPUTS FROM 30 TO 700 MMRTU/HR
00853000 C
00854000 C =====
00855000      REAL CAPC(10),OMC(19),ANNC(5)
00856000      COMMON /BSPEC/ Q,FLW,CF,BCRF
00857000      COMMON /PM/ UNCPM,CTRPM,EFFPM,CRFPM
00858000      CALL LIMIT(Q,30.0,700.0,'FF')
00859000      CAPC(1)=8.34*FLW**0.966
00860000      CAPC(2)=168531.* ALOG(FLW)-1506523.
00861000      CAPC(4)=24.99*FLW**0.821
00862000      IF (Q.GT.400) GO TO 10
00863000      OMC(1)=ALF(CF)*(10150.+106.*Q)
00864000      OMC(3)=ALF(CF)*(14840.+0.106*Q**2.0)
00865000      GO TO 20
00866000  10  OMC(1)=ALF(CF)*52600.
00867000      OMC(2)=ALF(CF)*17000.
00868000      OMC(3)=ALF(CF)*32000.
00869000  20  OMC(4)=0.278*FLW**0.997
00870000      OMC(6)=(CF/0.6)*(0.740*FLW**0.953)
00871000      OMC(8)=(CF/0.6)*(39.42*Q)*(UNCPM-CTRPM)

```

```

00872000      CALL FNLCST(CAPC,OMC,ANNC,CRFPM,1)
00873000      RETURN
00874000      END
00875000      SUBROUTINE VS(CAPC,OMC,ANNC)
00876000 C   VS - ROUTINE FOR ESTIMATION OF VENTURI SCRUBBER COSTS
00877000 C       APPLICABLE TO :
00878000 C           COAL-FIRED BOILER APPLICATIONS
00879000 C           PM REMOVAL ONLY (NO SO2 REMOVAL)
00880000 C           BOILERS WITH THERMAL INPUTS FROM 30 TO 700 MMBTU/HR
00881000 C
00882000 C =====
00883000      REAL CAPC(10),OMC(19),ANNC(5)
00884000      COMMON /BSPEC/ Q,FLW,CF,BCRF
00885000      COMMON /PM/ UNCPM,CTRPM,EFFPM,CRFPM
00886000      CALL LIMIT(Q,30.0,700.0,'VS')
00887000      CAPC(1)=26916.+2.291*FLW
00888000      CAPC(2)=13904.+1.653*FLW
00889000      CAPC(4)=15463.+1.285*FLW
00890000      IF (Q.GT.400) GO TO 10
00891000      OMC(1)=ALF(CF)*(10150.+106.*Q)
00892000      GO TO 20
00893000  10  OMC(1)=ALF(CF)*52000
00894000      OMC(2)=ALF(CF)*17000
00895000  20  OMC(3)=4525.+104.4*Q
00896000      OMC(6)=(CF/0.6)*304.3*Q**0.938
00897000      OMC(8)=(CF/0.6)*39.42*Q*(UNCPM-CTRPM)
00898000      CALL FNLCST(CAPC,OMC,ANNC,CRFPM,1)
00899000      RETURN
00900000      END
00901000      SUBROUTINE SM(CAPC,OMC,ANNC)
00902000 C   SM - ROUTINE FOR ESTIMATION OF SINGLE MECHANICAL (MULTI-CLONE)
00903000 C       COLLECTOR COSTS
00904000 C       APPLICABLE TO :
00905000 C           COAL-FIRED BOILER APPLICATIONS
00906000 C           BOILERS WITH THERMAL INPUTS FROM 30 TO 700 MMBTU/HR
00907000 C
00908000 C =====
00909000      REAL CAPC(10),OMC(19),ANNC(5)
00910000      COMMON /BSPEC/ Q,FLW,CF,BCRF
00911000      COMMON /PM/ UNCPM,CTRPM,EFFPM,CRFPM
00912000      CAPC(1)=32.53*FLW**0.7518
00913000      CAPC(4)=CAPC(1)/3.0
00914000      OMC(1)=ALF(CF)*(5075+53.0*Q)
00914500      OMC(2)=OMC(1)*0.15
00915000      OMC(3)=ALF(CF)*(7420+0.053*Q*Q)

```

```

00915500      OMC(4)=0.005*(CAPC(1)+CAPC(4))
00916000      OMC(5)=0.286*FLW*CF
00917000      OMC(8)=(CF/0.6)*39.42*Q*(UNCPM-CTRPM)
00918000      CALL FNLCST(CAPC,OMC,ANNC,CRFPM,1)
00919000      RETURN
00920000      END
00921000      SUBROUTINE DM(CAPC,OMC,ANNC)
00922000 C   DM - ROUTINE FOR ESTIMATION OF DUAL MECHANICAL (TWO MULTICLONES IN SE
00923000 C   COLLECTOR COSTS
00924000 C   APPLICABLE TO :
00925000 C           COAL-FIRED BOILERS APPLICATIONS
00926000 C           BOILERS WITH THERMAL INPUTS FROM 30 TO 700 MHBTU/HR
00927000 C
00928000 C =====
00929000      REAL CAPC(10),OMC(19),ANNC(5)
00930000      COMMON /BSPEC/ Q,FLW,CF,BCRF
00931000      COMMON /PM/ UNCPM,CTRPM,EFFPM,CRFPM
00932000      CAPC(1)=24.54*FLW**0.8130
00933000      CAPC(4)=CAPC(1)/3.0
00934000      OMC(1)=ALF(CF)*(5075+53.0*Q)
00934500      OMC(2)=OMC(1)*0.15
00935000      OMC(3)=ALF(CF)*(7420+0.053*Q*Q)
00935500      OMC(4)=0.005*(CAPC(1)+CAPC(4))
00936000      OMC(5)=0.3818*CF*FLW
00937000      OMC(8)=(CF/0.6)*39.42*Q*(UNCPM-CTRPM)
00938000      CALL FNLCST(CAPC,OMC,ANNC,CRFPM,1)
00939000      RETURN
00940000      END
00941000      SUBROUTINE SSS (CAPC,OMC,ANNC)
00942000 C   SSS - ROUTINE FOR ESTIMATION OF SIDESTREAM SEPARATOR COSTS
00943000 C   APPLICABLE TO :
00944000 C           COAL-FIRED BOILER APPLICATIONS
00945000 C           BOILERS WITH THERMAL INPUTS FROM 30 TO 700 MHBTU/HR
00946000 C
00947000 C =====
00948000      REAL CAPC(10),OMC(19),ANNC(5)
00949000      COMMON /BSPEC/ Q,FLW,CF,CRF
00950000      COMMON /PM/ UNCPM,CTRPM,EFFPM,CRFPM
00951000      CAPC(1)=41.3*FLW**0.7869
00952000      CAPC(4)=CAPC(1)/3.0
00953000      OMC(1)=ALF(CF)*(7105+74.2*Q)
00953500      OMC(2)=OMC(1)*0.15
00954000      OMC(3)=ALF(CF)*(10390+0.074*Q*Q)+0.0551*FLW**0.997
00954500      OMC(4)=0.005*(CAPC(1)+CAPC(4))
00955000      OMC(5)=0.286*FLW*CF+(CF/0.6)*0.160*FLW**0.953

```

```

00956000      OMC(8)=(CF/0.6)*39.42*Q*(UNCPM-CTRFM)
00957000      CALL FNLCST(CAPC,OMC,ANNC,CRFFM,1)
00958000      RETURN
00959000      END
00960000      SUBROUTINE DA (CAPC,OMC,ANNC,IFFLAG)
00961000 C   DA - ROUTINE FOR ESTIMATION OF DUAL ALKALI FGD COSTS
00962000 C       APPLICABLE TO :
00963000 C           COAL- AND OIL-FIRED BOILER APPLICATIONS
00964000 C           WITH PRIGR PM REMOVAL FOR COAL-FIRED APPLICATIONS
00965000 C           NO SIZE LIMITATIONS
00966000 C
00967000 C =====
00968000      REAL CAPC(10),OMC(19),ANNC(5)
00969000      COMMON /BSPEC/ Q,FLW,CF,BCRF
00970000      COMMON /FUEL/ FC,H,S,A
00971000      COMMON /SO2/ UNCS02,CTR502,EFFS02,CRFS02
00972000      COMMON /COSTS/ DLR,SLR,AMLR,ELEC,WTR,ALIME,ALS,ALYE,SASH,SLDG,
00973000      *      SWD,ALWD
00974000      H2=H*2.3257
00975000      Q2=Q*0.2930
00976000      FLW2=FLW*4.720E-4
00977000      SLDG2=SLDG*0.0011013
00978000      WTR2=WTR*0.2641
00979000      ALIME2=ALIME*0.0011013
00980000      SASH2=SASH*0.0011013
00981000      S1=S*EFFS02*100./H2
00982000      S2=S1*Q2*3.6
00983000      IF (IPFLAG.NE.0) WRITE (6,1000)S1,S2
00984000 1000 FORMAT (/T2,'S STAR (METRIC)=',F10.3/T2,'S BSTAR (METRIC)=',F10.3)
00985000      CAPC(3)=45200.*FLW2**0.61+83118*S2**0.39
00986000      IF (Q2.LE.58.6) CAPC(7)=1.48*CAPC(3)+93600
00987000      IF (Q2.GT.58.6) CAPC(7)=1.48*CAPC(3)+130000
00988000      OMC(1)=105000.
00989000      OMC(2)=21000.
00990000      OMC(3)= 0.08*CAPC(3)
00991000      OMC(5)=ELEC*(2.94*FLW2)*(0.121*S1+0.861)*8760.*CF
00992000      OMC(7)=WTR2*(0.197*FLW2+0.30)*(0.997+0.119* ALOG(S1))*8760.*CF
00993000      OMC(9)=SLDG2*(7.73*S2-3.34)*8760.*CF
00994000      IF (S1.LT.0.24) OMC(11)=SASH2*(1.13*FLW2-2.06)*(0.41-0.70*
00995000      *      (0.24-S1)**1.74)*8760.*CF
00996000      IF (S1.GE.0.24) OMC(11)=SASH2*(1.13*FLW2-2.06)*(0.70*(S1-0.24)
00997000      *      **1.74+0.41)*8760.*CF
00998000      OMC(13)=ALIME2*(1.61*S2-0.85)*8760*CF
00999000      DO 10 I=1,16
01000000 10      OMC(17)=OMC(17)+OMC(I)

```

```

01001000      OMC(18)=0.56*OMC(1)+0.26*(OMC(2)+OMC(3))
01002000      OMC(19)=OMC(17)+OMC(18)
01003000      CAPC(9)=0.25*OMC(17) .
01004000      CAPC(10)=CAPC(7)+CAPC(9)
01005000      CALL FNLCST (CAPC,OMC,ANNC,CRFS02,0)
01006000      RETURN
01007000      END
01008000      SUBROUTINE DAC (CAPC,OMC,ANNC,IPFLAG)
01009000 C   DAC - ROUTINE FOR ESTIMATION OF COMBINED DUAL ALKALI FGD WITH
01010000 C       PROVISIONS FOR PM REMOVAL
01011000 C       APPLICABLE TO :
01012000 C           COAL- AND OIL-FIRED BOILER APPLICATIONS
01013000 C           NO PRIOR PM REMOVAL REQUIRED
01014000 C           NO SIZE LIMITATIONS
01015000 C
01016000 C =====
01017000      REAL CAPC(10),OMC(19),ANNC(5)
01018000      COMMON /BSPEC/ Q,FLW,CF,BCRF
01019000      COMMON /FUEL/ FC,H,S,A
01020000      COMMON /SO2/ UNCS02,CTRS02,EFFSO2,CRFS02
01021000      COMMON /PM/ UNCPM,CTRPM,EFFPM,CRFPM
01022000      COMMON /COSTS/ DLR,SLR,AMLR,ELEC,WTR,ALIME,ALS,ALYE,SASH,SLDG,
01023000      * SWD,ALWD
01024000      H2=H*2.3257
01025000      Q2=Q*0.2930
01026000      FLW2=FLW*4.720E-4
01027000      SLDG2=SLDG*0.0011013
01028000      WTR2=WTR*0.2641
01029000      ALIME2=ALIME*0.0011013
01030000      SASH2=SASH*0.0011013
01031000      PM2U=UNCPM*430.39
01032000      PM2C=CTRPM*430.39
01033000      S1=S*EFFSO2*100.0/H2
01034000      S2=S1*Q2*3.6
01035000      P1=3.6E-3*Q2*(1.2*PM2U-2.*PM2C)
01036000      IF (IPFLAG.NE.0) WRITE (6,1000) S1,S2,P1
01037000 1000 FORMAT (/T2,'S STAR (METRIC)=',F10.3/
01038000      *      T2,'S DSTAR (METRIC)=',F10.3/
01039000      *      T2,'P DSTAR (METRIC)=',F10.3)
01040000      CAPC(3)=74370.+9.02E3*FLW2-39.5*FLW2**2+13340*FLW2**0.528+32.32E3*
01041000      *  S2**0.362+54.06E3*(7.73*S2-3.34+P1)**0.278+4094*FLW2**0.034
01042000      IF (Q2.LE.58.6) CAPC(7)=1.48*CAPC(3)+93600
01043000      IF (Q2.GT.58.6) CAPC(7)=1.48*CAPC(3)+130000
01044000      OMC(1)=105000
01045000      OMC(2)=21000

```

```

01046000      OMC(3)=0.08*CAPC(3)
01047000      OMC(5)=ELEC*6.11*FLW2*(0.121*S1+0.861)*8760*CF
01048000      OMC(7)=WTR2*(0.197*FLW2+0.30)*(0.997+0.119*ALOG(S1))*8760*CF
01049000      OMC(9)=SLDG2*(7.73*S2-3.34+F1)*8760*CF
01050000      IF (S1.LE.0.24) OMC(11)=SASH2*(1.13*FLW2-2.06)*(0.41-0.70*(0.24-
01051000      *      S1)**1.74)*8760*CF
01052000      IF (S1.GT.0.24) OMC(11)=SASH2*(1.13*FLW2-2.06)*(0.70*
01053000      *      (S1-0.24)**1.74+0.41)*8760.0*CF
01054000      OMC(13)=ALIME2*(1.61*S2-0.85)*8760*CF
01055000      DO 10 I=1,16
01056000      10 OMC(17)=OMC(17)+OMC(I)
01057000      OMC(18)=0.56*OMC(1)+0.26*(OMC(2)+OMC(3))
01058000      OMC(19)=OMC(17)+OMC(18)
01059000      CAPC(9)=0.25*OMC(17)
01060000      CAPC(10)=CAPC(7)+CAPC(9)
01061000      CALL FNLCST(CAPC,OMC,ANNC,CRFS02,0)
01062000      RETURN
01063000      END
01064000      SUBROUTINE NATH(CAPC,OMC,ANNC,IPFLAG)
01065000 C   NATH - ROUTINE FOR ESTIMATION OF SODIUM THROWAWAY FDG COSTS
01066000 C           APPLICABLE TO :
01067000 C               OIL-FIRED BOILER APPLICATIONS
01068000 C               NO SIZE LIMITATIONS
01069000 C
01070000 C =====
01071000      REAL CAPC(10),OMC(19),ANNC(5)
01072000      COMMON /BSPEC/ Q,FLW,CF,BCRF
01073000      COMMON /FUEL/ FC,H,S,A
01074000      COMMON /SO2/ UNCS02,CTRS02,EFFS02,CRFS02
01075000      COMMON /COSTS/ DLR,SLR,AMLR,ELEC,WTR,ALIME,ALS,ALYE,SASH,SLDG,
01076000      *      SWD,ALWD
01077000      H2=H*2.3257
01078000      Q2=Q*0.2930
01079000      FLW2=FLW*4.720E-4
01080000      WTR2=WTR*0.2641
01081000      SLDG2=SLDG*0.0011013
01082000      SASH2=SASH*0.0011013
01083000      ALW2=ALWD*0.2641
01084000      S1=S*EFFS02*100.0/H2
01085000      S2=S1*Q2*3.6
01086000      IF (IPFLAG.NE.0) WRITE (6,1000) S1,S2
01087000      1000 FORMAT(/T2,'S STAR (METRIC)=',F10.3/T2,' DSTAR (METRIC)=',F10.3)
01088000      CAPC(3)=44000*FLW2**0.62+20600*S2**0.427
01089000      IF (Q2.LE.58.6) CAPC(7)=CAPC(3)*1.48+74400
01090000      IF (Q2.GT.58.6) CAPC(7)=CAPC(3)*1.48+112800

```

```

01091000      OMC(1)=105000
01092000      OMC(2)=21000
01093000      OMC(3)=0.08*(CAPC(3))
01094000      OMC(5)=ELEC*(4.26*FLW2-2.56)*(0.65+0.31*S1)*8760*CF
01095000      OMC(7)=WTR2*(0.776*FLW2-.720)*(.213+.684*S1)*8760*CF
01096000      OMC(9)=SLDG2*(.16+.53*S2)*8760*CF
01097000      OMC(10)=ALW2*(0.086*S2)*8760.*CF
01098000      OMC(11)=SASH2*(8.03+3.5*S2)*8760*CF
01099000      DO 10 I=1,16
01100000 10  OMC(17)=OMC(17)+OMC(I)
01101000      OMC(18)=0.56*OMC(1)+.26*(OMC(2)+OMC(3))
01102000      OMC(19)=OMC(17)+OMC(18)
01103000      CAPC(9)=.25*OMC(17)
01104000      CAPC(10)=CAPC(7)+CAPC(9)
01105000      CALL FNLCST(CAPC,OMC,ANNC,CRFS02,0)
01106000      RETURN
01107000      END
01108000      SUBROUTINE DS(CAPC,OMC,ANNC,IPFLAG)
01109000 C   DS - ROUTINE FOR ESTIMATION OF DRY SCRUBBING FGD COSTS
01110000 C       APPLICABLE TO :
01111000 C           LOW SULFUR-COAL FIRED BOILER APPLICATIONS
01112000 C           NO PRIOR PM REMOVAL REQUIRED
01113000 C           NO SIZE LIMITATIONS
01114000 C
01115000 C =====
01116000      REAL CAPC(10),OMC(19),ANNC(5)
01117000      COMMON /BSPEC/ Q,FLW,CF,BCRF
01118000      COMMON /FUEL/ FC,H,S,A
01119000      COMMON /SO2/ UNCS02,CTRS02,EFFS02,CRFS02
01120000      COMMON /PM/ UNCPM,CTRPM,EFFPM,CRFFM
01121000      COMMON /COSTS/ DLR,SLR,AMLR,ELEC,WTR,ALIME,ALS,ALYE,SASH,SLDG,
01122000      *      SWD,ALWD
01123000      H2=H*2.3257
01124000      Q2=Q*0.2930
01125000      FLW2=FLW*4.720E-4
01126000      WTR2=WTR*0.2641
01127000      ALIME2=ALIME*0.0011013
01128000      PM2U=UNCPM*430.39
01129000      SWD2=SWD*0.0011013
01130000      PF=Q*UNCPM*0.454
01131000      S1=S*EFFS02*100.0/H2
01132000      S2=S1*Q2*3.6
01133000      IF (IPFLAG .NE. 0) WRITE (6,1000) S1,S2
01134000 1000 FORMAT (/T2,'S STAR (METRIC) = ',F10.3/
01135000      *          T2,'S DSTAR (METRIC) = ',F10.3)

```

```

01136000      CAPC(3)=55600.*FLW2**0.51+21600.*S2**0.4+33327*FLW2**0.89
01137000      IF (Q2 ,LE, 58.6) CAPC(7)=1.40*CAPC(3)+110100.
01138000      IF (Q2 ,GT, 58.6)  CAPC(7)=1.60*CAPC(3)
01139000      OMC(1)=105000.
01140000      OMC(2)=21000.
01141000      OMC(3)=0.08*(55600.*FLW2**0.51+21600.*S2**0.4) +14B40.+*
01142000      *           1.23*Q2**2.0+578.*FLW2**0.997
01143000      OMC(5)=ELEC*(6.14*FLW2**0.82)*8760.*CF
01144000      OMC(7)=WTR2*(0.144*FLW2)*8760.*CF
01145000      OMC(8)=SWD2*((0.035*EFFSO2+3.02)*S24PF *EFFPM/100.)*8760.*CF
01146000      OMC(13)=ALIME2*(1.89*ALLOG(EFFSO2)-5.3)*S2*8760.*CF
01147000      DO 10 I=1,16
01148000      10   OMC(17)=OMC(17)+OMC(I)
01149000      OMC(18)=0.56*OMC(1)+0.26*(OMC(2)+OMC(3))
01150000      OMC(19)=OMC(17)+OMC(18)
01151000      CAFC(9)=0.25*OMC(17)
01152000      CAPC(10)=CAPC(7)+CAFC(9)
01153000      CALL FNLCST(CAFC,OMC,ANNC,CRFSO2,0)
01154000      RETURN
01155000      END
01155500      /*
01156500 //GO.SYSIN DD *

```

## APPENDIX C

### MODEL BOILER COST TABLES

This appendix presents a detailed cost breakdown of the boiler, SO<sub>2</sub> control and PM control costs for all the model boilers presented in Chapters 3 and 4. The terms for which many of the abbreviations stand for are presented in the algorithm abbreviations in Table A-2. However, some variations are present. These terms and their abbreviations can be found within the FORTRAN computer program COST (Appendix B).

Each cost summary table presents three totals. The first total is the total capital costs. The second total is the total annual O&M costs and the third total is the total annualized costs.

HSC-30-Unc, Unc

MODEL BOILER	1	4-01-82			
BOILER ROUTINE UNDR	S02 ROUTINE=	PM ROUTINE=		FLOW FLAG=	1
<b>BOILER SPECIFICATIONS</b>					
Q= 30.0 FLW= 11029. CF= 0.600 CRF= 0.1315					
<b>FUEL SPECIFICATIONS</b>					
FC= 1.81 H= 11800. S= 3.54 A= 10.58					
<b>PM EMISSIONS</b>					
UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0					
<b>S02 EMISSIONS</b>					
UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0					
<b>COST RATES</b>					
ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80					
<b>COST SUMMARY TABLE - RUN NO. 1</b>					
ITEM	BOILER	NOX CONTROL	S02 CONTROL	PM CONTROL	TOTAL
EQUIP	587246.	0.	0.	0.	587246.
INST	519713.	0.	0.	0.	519713.
TD	1106959.	0.	0.	0.	1106959.
IND	361673.	0.	0.	0.	361673.
TDI	1468632.	0.	0.	0.	1468632.
CONT	293726.	0.	0.	0.	293726.
TK	1762358.	0.	0.	0.	1762358.
LAND	2000.	0.	0.	0.	2000.
WC	92986.	0.	0.	0.	92986.
TOTL	1857344.	0.	0.	0.	1857344.
DL	90863.	0.	0.	0.	90863.
SPRV	44001.	0.	0.	0.	44001.
MANT	41173.	0.	0.	0.	41173.
SP	53245.	0.	0.	0.	53245.
ELEC	0.	0.	0.	0.	0.
UC	36296.	0.	0.	0.	36296.
WTR	0.	0.	0.	0.	0.
SW	11271.	0.	0.	0.	11271.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	285401.	0.	0.	0.	285401.
TDOM	562250.	0.	0.	0.	562250.
OH	86872.	0.	0.	0.	86872.
TOTL	649122.	0.	0.	0.	649122.
CR	231750.	0.	0.	0.	231750.
WCC	9299.	0.	0.	0.	9299.
MISC	70494.	0.	0.	0.	70494.
TCC	311543.	0.	0.	0.	311543.
TOTL	960665.	0.	0.	0.	960665.

HSC-30-Unc, SM

MODEL BOILER 2  
 BOILER ROUTINE UNDR SO2 ROUTINE= 4-01-82 PM ROUTINE= SM FLOW FLAG= 1  
**BOILER SPECIFICATIONS**  
 Q= 30.0 FLW= 11029. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 1.81 H= 11800. S= 3.54 A= 10.58  
**PM EMISSIONS**  
 UNC= 0.457 CTR= 0.400 EFF= 39.10 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 2

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	587246.	0.	0.	35602.	622848.
INST	519713.	0.	0.	0.	519713.
TD	1106959.	0.	0.	35602.	1142560.
IND	361673.	0.	0.	11867.	373541.
TDI	1468632.	0.	0.	47469.	1516100.
CONT	293726.	0.	0.	9494.	303220.
TK	1762358.	0.	0.	56963.	1819320.
LAND	2000.	0.	0.	0.	2000.
WC	92986.	0.	0.	3446.	96432.
TOTL	1857344.	0.	0.	60409.	1917752.
DL	90863.	0.	0.	4999.	95862.
SPRV	44001.	0.	0.	750.	44751.
MANT	41173.	0.	0.	5601.	46773.
SP	53245.	0.	0.	237.	53482.
ELEC	0.	0.	0.	1893.	1893.
UC	36296.	0.	0.	0.	36296.
WTR	0.	0.	0.	0.	0.
SW	11271.	0.	0.	304.	11575.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	285401.	0.	0.	0.	285401.
TDOM	562250.	0.	0.	13783.	576033.
OH	86872.	0.	0.	4512.	91384.
TOTL	649122.	0.	0.	18295.	667417.
CR	231750.	0.	0.	7491.	239241.
WCC	9299.	0.	0.	345.	9643.
MISC	70494.	0.	0.	2279.	72773.
TCC	311543.	0.	0.	10114.	321657.
TOTL	960665.	0.	0.	28409.	989074.

HSC-30-Unc, SSS

MODEL BOILER 3  
 BOILER ROUTINE UNDR SO2 ROUTINE= 4-01-82 PM ROUTINE= SSS FLOW FLAG= 1  
**BOILER SPECIFICATIONS**  
 Q= 30.0 FLW= 11029. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 1.81 H= 11800. S= 3.54 A= 10.58  
**PM EMISSIONS**  
 UNC= 0.657 CTR= 0.200 EFF= 69.60 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 3

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	587246.	0.	0.	62666.	649912.
INST	519713.	0.	0.	0.	519713.
TD	1106959.	0.	0.	62666.	1169624.
IND	361673.	0.	0.	20889.	382562.
TDI	1468632.	0.	0.	83554.	1552186.
CONT	293726.	0.	0.	16711.	310437.
TK	1762358.	0.	0.	100265.	1862623.
LAND	2000.	0.	0.	0.	2000.
WC	92986.	0.	0.	5119.	98105.
TOTL	1857344.	0.	0.	105384.	1962727.
DL	90863.	0.	0.	6998.	97861.
SPRV	44001.	0.	0.	1050.	45051.
MANT	41173.	0.	0.	8437.	49609.
SP	53245.	0.	0.	418.	53663.
ELEC	0.	0.	0.	3032.	3032.
UC	36296.	0.	0.	0.	36296.
WTR	0.	0.	0.	0.	0.
SW	11271.	0.	0.	540.	11812.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	285401.	0.	0.	0.	285401.
TDOM	562250.	0.	0.	20475.	582724.
OH	86872.	0.	0.	6494.	93366.
TOTL	649122.	0.	0.	26969.	676090.
CR	231750.	0.	0.	13185.	244935.
WCC	9299.	0.	0.	512.	9810.
MISC	70494.	0.	0.	4011.	74505.
TCC	311543.	0.	0.	17707.	329250.
TOTL	960665.	0.	0.	44676.	1005341.

HSC-30-Unc, VS

MODEL BOILER	4	4-01-82			
BOILER ROUTINE UNDR	S02 ROUTINE=	PM ROUTINE= VS		FLOW FLAG=	1
<b>BOILER SPECIFICATIONS</b>					
Q= 30.0 FLW= 11029. CF= 0.600 CRF= 0.1315					
<b>FUEL SPECIFICATIONS</b>					
FC= 1.81 H= 11800. S= 3.54 A= 10.58					
<b>PM EMISSIONS</b>					
UNC= 0.657 CTR= 0.100 EFF= 84.80 CRF= 0.1315					
<b>S02 EMISSIONS</b>					
UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0					
<b>COST RATES</b>					
ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80					
<b>COST SUMMARY TABLE - RUN NO. 4</b>					
ITEM	BOILER	NOX CONTROL	S02 CONTROL	PM CONTROL	TOTAL
EQUIP	587246.	0.	0.	52217.	639463.
INST	519713.	0.	0.	32135.	551848.
TD	1106959.	0.	0.	84353.	1191311.
IND	361673.	0.	0.	29636.	391309.
TDI	1468632.	0.	0.	113988.	1582620.
CONT	293726.	0.	0.	22798.	316524.
TK	1762358.	0.	0.	136786.	1899143.
LAND	2000.	0.	0.	0.	2000.
WC	92986.	0.	0.	6427.	99413.
TOTL	1857344.	0.	0.	143212.	2000556.
DL	90863.	0.	0.	9998.	100860.
SPRV	44001.	0.	0.	0.	44001.
MANT	41173.	0.	0.	7457.	48830.
SP	53245.	0.	0.	0.	53245.
ELEC	0.	0.	0.	0.	0.
UC	36296.	0.	0.	7393.	43690.
WTR	0.	0.	0.	0.	0.
SW	11271.	0.	0.	659.	11930.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
 LYE	0.	0.	0.	0.	0.
FUEL	285401.	0.	0.	0.	285401.
TDOM	562250.	0.	0.	25707.	587956.
OH	86872.	0.	0.	7589.	94461.
TOTL	649122.	0.	0.	33296.	682418.
CR	231750.	0.	0.	17987.	249737.
WCC	9299.	0.	0.	643.	9941.
MISC	70494.	0.	0.	5471.	75966.
TCC	311543.	0.	0.	24101.	335644.
TOTL	960665.	0.	0.	57397.	1018062.

HSC-30-Unc, ESP

MODEL BOILER 5  
 BOILER ROUTINE UNDR SO2 ROUTINE= 4-01-82  
 PM ROUTINE= ESPC FLOW FLAG= 1

SPECIFIC COLLECTION AREA (SQ FT/1000 ACFM) = 117.3

TOTAL PLATE AREA (SQ FT) = 1293.3

BOILER SPECIFICATIONS

Q= 30.0 FLW= 11029. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58

PM EMISSIONS

UNC= 0.657 CTR= 0.050 EFF= 92.40 CRF= 0.1315

SO2 EMISSIONS

UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 5

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	587246.	0.	0.	63190.	650436.
INST	519713.	0.	0.	73932.	593645.
TD	1106959.	0.	0.	137122.	1244081.
IND	361673.	0.	0.	45799.	407472.
TDI	1468632.	0.	0.	182921.	1651553.
CONT	293726.	0.	0.	36584.	330311.
TK	1762358.	0.	0.	219506.	1981863.
LAND	2000.	0.	0.	0.	2000.
WC	92986.	0.	0.	5875.	98861.
TOTL	1857344.	0.	0.	225380.	2082724.
DL	90863.	0.	0.	9998.	100860.
SPRV	44001.	0.	0.	0.	44001.
MANT	41173.	0.	0.	11202.	52374.
SP	53245.	0.	0.	1010.	54255.
ELEC	0.	0.	0.	0.	0.
UC	36296.	0.	0.	572.	36868.
WTR	0.	0.	0.	0.	0.
SW	11271.	0.	0.	718.	11989.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	285401.	0.	0.	0.	285401.
TDOM	562250.	0.	0.	23499.	585748.
OH	86872.	0.	0.	8774.	95645.
TOTL	649122.	0.	0.	32272.	681394.
CR	231750.	0.	0.	28865.	260615.
WCC	9299.	0.	0.	587.	9886.
MISC	70494.	0.	0.	8780.	79275.
TCC	311543.	0.	0.	38233.	349776.
TOTL	960665.	0.	0.	70505.	1031169.

HSC-30-DA(50), DA/PM

MODEL BOILER 6  
 BOILER ROUTINE UNDR SO2 ROUTINE= DAC PM ROUTINE= FLOW FLAG= 1

S STAR (METRIC)= 0.645  
 S DSTAR (METRIC)= 20.409  
 P DSTAR (METRIC)= 8.014

BOILER SPECIFICATIONS  
 Q= 30.0 FLW= 11029. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS  
 FC= 1.81 H= 11800. S= 3.54 A= 10.58

PM EMISSIONS  
 UNC= 0.657 CTR= 0.100 EFF= 84.80 CRF= 0.1315

SO2 EMISSIONS  
 UNC= 5.700 CTR= 2.850 EFF= 50.00 CRF= 0.1315

COST RATES  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 6

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	587246.	0.	0.	0.	587246.
INST	519713.	0.	0.	0.	519713.
TD	1106959.	0.	487199.	0.	1594157.
IND	361673.	0.	0.	0.	361673.
TDI	1468632.	0.	0.	0.	1468632.
CONT	293726.	0.	0.	0.	293726.
TK	1762358.	0.	814654.	0.	2577012.
LAND	2000.	0.	0.	0.	2000.
WC	92986.	0.	47745.	0.	140731.
TOTL	1857344.	0.	862399.	0.	2719743.
DL	90863.	0.	105000.	0.	195863.
SPRV	44001.	0.	21000.	0.	65001.
MANT	41173.	0.	38976.	0.	80149.
SP	53245.	0.	0.	0.	53245.
ELEC	0.	0.	4050.	0.	4050.
UC	36296.	0.	0.	0.	36296.
WTR	0.	0.	261.	0.	261.
SW	11271.	0.	0.	0.	11271.
SLDG	0.	0.	14104.	0.	14104.
LW	0.	0.	0.	0.	0.
SC	0.	0.	1106.	0.	1106.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	6485.	0.	6485.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	285401.	0.	0.	0.	285401.
TDOM	562250.	0.	190981.	0.	753231.
OH	86872.	0.	74394.	0.	161266.
TOTL	649122.	0.	265375.	0.	914497.
CR	231750.	0.	107127.	0.	338877.
WCC	9299.	0.	4775.	0.	14073.
MISC	70494.	0.	32586.	0.	103080.
TCC	311543.	0.	144488.	0.	456031.
TOTL	960665.	0.	409863.	0.	1370527.

HSC-30-DA(50), ESP

MODEL BOILER 7  
 BOILER ROUTINE UNDR SO2 ROUTINE= DA PM ROUTINE= ESPC FLOW FLAG= 1

S STAR (METRIC)= 0.645  
 S DSTAR (METRIC)= 20.409

SPECIFIC COLLECTION AREA (SQ FT/1000 ACFM) = 117.3  
 TOTAL PLATE AREA (SQ FT) = 1293.3

BOILER SPECIFICATIONS

Q= 30.0 FLW= 11029. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58

PM EMISSIONS

UNC= 0.657 CTR= 0.050 EFF= 92.40 CRF= 0.1315

SO2 EMISSIONS

UNC= 5.700 CTR= 2.850 EFF= 50.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 7

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	587246.	0.	0.	63190.	650436.
INST	519713.	0.	0.	73932.	593645.
TD	1106959.	0.	393131.	137122.	1637212.
IND	361673.	0.	0.	45799.	407472.
TDI	1468632.	0.	0.	182921.	1651553.
CONT	293726.	0.	0.	36584.	330311.
TK	1762358.	0.	675434.	219506.	2657297.
LAND	2000.	0.	0.	0.	2000.
WC	92986.	0.	45165.	5875.	144025.
TOTL	1857344.	0.	720599.	225380.	2803322.
DL	90863.	0.	105000.	9998.	205860.
SPRV	44001.	0.	21000.	0.	65001.
MANT	41173.	0.	31451.	11202.	83825.
SP	53245.	0.	0.	1010.	54255.
ELEC	0.	0.	1949.	0.	1949.
UC	36296.	0.	0.	572.	36868.
WTR	0.	0.	261.	0.	261.
SW	11271.	0.	0.	718.	11989.
SLDG	0.	0.	13408.	0.	13408.
LW	0.	0.	0.	0.	0.
SC	0.	0.	1106.	0.	1106.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	6485.	0.	6485.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	285401.	0.	0.	0.	285401.
TDOM	562250.	0.	180659.	23499.	766407.
OH	86872.	0.	72437.	8774.	168083.
TOTL	649122.	0.	253096.	32272.	934490.
CR	231750.	0.	88820.	28865.	349435.
WCC	9299.	0.	4516.	587.	14403.
MISC	70494.	0.	27017.	8780.	106292.
TCC	311543.	0.	120353.	38233.	470129.
TOTL	960665.	0.	373449.	70505.	1404617.

HSC-30-DA(90), DA/PM

MODEL BOILER 8  
 BOILER ROUTINE UNDR SO2 ROUTINE= DAC PM ROUTINE= 4-01-82 FLOW FLAG= 1

S STAR (METRIC)= 1.161  
 S DSTAR (METRIC)= 36.737  
 P DSTAR (METRIC)= 8.014  
**BOILER SPECIFICATIONS**  
 Q= 30.0 FLW= 11029. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 1.81 H= 11800. S= 3.54 A= 10.58  
**PM EMISSIONS**  
 UNC= 0.657 CTR= 0.100 EFF= 84.80 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= 5.700 CTR= 0.570 EFF= 90.00 CRF= 0.1315  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWN= 1.80  
**COST SUMMARY TABLE - RUN NO. 8**

---

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	587246.	0.	0.	0.	587246.
INST	519713.	0.	0.	0.	519713.
TD	1106959.	0.	548604.	0.	1655563.
IND	361673.	0.	0.	0.	361673.
TDI	1468632.	0.	0.	0.	1468632.
CONT	293726.	0.	0.	0.	293726.
TK	1762358.	0.	905534.	0.	2667892.
LAND	2000.	0.	0.	0.	2000.
WC	92986.	0.	53346.	0.	146332.
TOTL	1857344.	0.	958880.	0.	2816224.
DL	90863.	0.	105000.	0.	195863.
SPRV	44001.	0.	21000.	0.	65001.
MANT	41173.	0.	43888.	0.	85061.
SP	53245.	0.	0.	0.	53245.
ELEC	0.	0.	4320.	0.	4320.
UC	36296.	0.	0.	0.	36296.
WTR	0.	0.	280.	0.	280.
SW	11271.	0.	0.	0.	11271.
SLDG	0.	0.	25062.	0.	25062.
LW	0.	0.	0.	0.	0.
SC	0.	0.	2024.	0.	2024.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	11811.	0.	11811.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	285401.	0.	0.	0.	285401.
TDOM	562250.	0.	213385.	0.	775635.
OH	86872.	0.	75671.	0.	162543.
TOTL	649122.	0.	289056.	0.	938178.
CR	231750.	0.	119078.	0.	350828.
WCC	9299.	0.	5335.	0.	14633.
MISC	70494.	0.	36221.	0.	106716.
TCC	311543.	0.	160634.	0.	472177.
TOTL	960665.	0.	449690.	0.	1410354.

# HSC-30-DA(90), ESP

MODEL BOILER 9  
 BOILER ROUTINE UNDR SO2 ROUTINE= DA PM ROUTINE= ESPC FLOW FLAG= 1

S STAR (METRIC)= 1.161  
 S DSTAR (METRIC)= 36.737

SPECIFIC COLLECTION AREA (SQ FT/1000 ACFM) = 117.3  
 TOTAL PLATE AREA (SQ FT) 1293.3

## BOILER SPECIFICATIONS

Q= 30.0 FLW= 11029. CF= 0.600 CRF= 0.1315

## FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58

## PM EMISSIONS

UNC= 0.657 CTR= 0.050 EFF= 92.40 CRF= 0.1315

## SO2 EMISSIONS

UNC= 5.700 CTR= 0.570 EFF= 90.00 CRF= 0.1315

## COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 9

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	587246.	0.	0.	63190.	350436.
INST	519713.	0.	0.	73932.	593645.
TD	1106959.	0.	462560.	137122.	1706641.
IND	361673.	0.	0.	45799.	407472.
TDI	1468632.	0.	0.	182921.	1651553.
CONT	293726.	0.	0.	36584.	330311.
TK	1762358.	0.	778189.	219506.	2760052.
LAND	2000.	0.	0.	0.	2000.
WC	92986.	0.	50891.	5875.	149752.
TOTL	1857344.	0.	829080.	225380.	2911804.
DL	90863.	0.	105000.	9998.	205860.
SPRV	44001.	0.	21000.	0.	65001.
MANT	41173.	0.	37005.	11202.	89379.
SP	53245.	0.	0.	1010.	54255.
ELEC	0.	0.	2079.	0.	2079.
UC	36296.	0.	0.	572.	36868.
WTR	0.	0.	280.	0.	280.
SW	11271.	0.	0.	718.	11989.
SLDG	0.	0.	24367.	0.	24367.
LW	0.	0.	0.	0.	0.
SC	0.	0.	2024.	0.	2024.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	11811.	0.	11811.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	285401.	0.	0.	0.	285401.
TDOM	562250.	0.	203565.	23499.	789313.
OH	86872.	0.	73881.	8774.	169527.
TOTL	649122.	0.	277446.	32272.	958840.
CR	231750.	0.	102332.	28865.	362947.
WCC	9299.	0.	5089.	587.	14975.
MISC	70494.	0.	31128.	8780.	110402.
TCC	311543.	0.	138548.	38233.	488324.
TOTL	960665.	0.	415994.	70505.	1447162.

HSC-75-Unc, Unc

MODEL BOILER 10 4-01-82  
BOILER RQUTINE UNDR SO2 ROUTINE= PM ROUTINE= FLOW FLAG= 1  
  
BOILER SPECIFICATIONS  
    Q= 75.0 FLW= 27573. CF= 0.600 CRF= 0.1315  
FUEL SPECIFICATIONS  
    FC= 1.81 H= 11800. S= 3.54 A= 10.58  
PM EMISSIONS  
    UNC= CTR= EFF= CRF=  
SO2 EMISSIONS  
    UNC= CTR= EFF= CRF=  
COST RATES  
    ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 10

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1051134.	0.	0.	0.	1051134.
INST	951692.	0.	0.	0.	951692.
TD	2002826.	0.	0.	0.	2002826.
IND	653711.	0.	0.	0.	653711.
TDI	2656537.	0.	0.	0.	2656537.
CONT	531307.	0.	0.	0.	531307.
TK	3187844.	0.	0.	0.	3187844.
LAND	2000.	0.	0.	0.	2000.
WC	189693.	0.	0.	0.	189693.
TOTL	3379536.	0.	0.	0.	3379536.
DL	110903.	0.	0.	0.	110903.
SPRV	125519.	0.	0.	0.	125519.
MANT	117640.	0.	0.	0.	117640.
SP	85724.	0.	0.	0.	85724.
ELEC	0.	0.	0.	0.	0.
UC	53069.	0.	0.	0.	53069.
WTR	0.	0.	0.	0.	0.
SW	28178.	0.	0.	0.	28178.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	713502.	0.	0.	0.	713502.
TDOM	1234535.	0.	0.	0.	1234535.
OH	147615.	0.	0.	0.	147615.
TOTL	1382150.	0.	0.	0.	1382150.
CR	419202.	0.	0.	0.	419202.
WCC	18969.	0.	0.	0.	18969.
MISC	127514.	0.	0.	0.	127514.
TCC	565685.	0.	0.	0.	565685.
TOTL	1947834.	0.	0.	0.	1947834.

HSC-75-Unc, SM

MODEL BOILER 11                                  4-01-82  
BOILER ROUTINE UNDR    SO2 ROUTINE=                                  PM ROUTINE= SM                                  FLOW FLAG= 1  
  
BOILER SPECIFICATIONS  
  Q= 75.0 FLW= 27573. CF= 0.600 CRF= 0.1315  
FUEL SPECIFICATIONS  
  FC= 1.81 H= 11800. S= 3.54 A= 10.58  
PM EMISSIONS  
  UNC= 0.657 CTR= 0.400 EFF= 39.10 CRF= 0.1315  
SO2 EMISSIONS  
  UNC=        CTR=        EFF=        CRF= .  
COST RATES  
  ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDBG= 15.00 SWD= 15.00 ALWD= 1.80

**COST SUMMARY TABLE - RUN NO. 11**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1051134.	0.	0.	70899.	1122033.
INST	951692.	0.	0.	0.	951692.
TD	2002826.	0.	0.	70899.	2073725.
IND	653711.	0.	0.	23633.	677344.
TDI	2656537.	0.	0.	94532.	2751069.
CONT	531307.	0.	0.	18906.	550214.
TK	3187844.	0.	0.	113439.	3301282.
LAND	2000.	0.	0.	0.	2000.
WC	189693.	0.	0.	4890.	194582.
TOTL	3379536.	0.	0.	118328.	3497864.
DL	110903.	0.	0.	6788.	117690.
SPRV	125519.	0.	0.	1018.	126538.
MANT	117640.	0.	0.	5789.	123428.
SP	85724.	0.	0.	473.	86197.
ELEC	0.	0.	0.	4732.	4732.
UC	53069.	0.	0.	0.	53069.
WTR	0.	0.	0.	0.	0.
SW	28178.	0.	0.	760.	28938.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	713502.	0.	0.	0.	713502.
TDOM	1234535.	0.	0.	19558.	1254093.
OH	147615.	0.	0.	5694.	153309.
TOTL	1382150.	0.	0.	25252.	1407401.
CR	419202.	0.	0.	14917.	434119.
WCC	18969.	0.	0.	489.	19458.
MISC	127514.	0.	0.	4538.	132051.
TCC	565685.	0.	0.	19944.	585628.
TOTL	1947834.	0.	0.	45196.	1993029.

HSC-75-Unc, SSS

MODEL BOILER 12                          4-01-82  
 BOILER ROUTINE UNDR    SO2 ROUTINE=                          PM ROUTINE= SSS                          FLOW FLAG=    1  
**BOILER SPECIFICATIONS**  
 Q= 75.0 FLW= 27573. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 1.81 H= 11800. S= 3.54 A= 10.58  
**PM EMISSIONS**  
 UNC= 0.657 CTR= 0.200 EFF= 69.60 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC=                  CTR=                  EFF=                  CRF=                   
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 12

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1051134.	0.	0.	128875.	1180009.
INST	951692.	0.	0.	0.	951692.
TD	2002826.	0.	0.	128875.	2131701.
IND	653711.	0.	0.	42958.	696670.
TDI	2656537.	0.	0.	171834.	2828370.
CONT	531307.	0.	0.	34367.	565674.
TK	3187844.	0.	0.	206200.	3394044.
LAND	2000.	0.	0.	0.	2000.
WC	189693.	0.	0.	7546.	197239.
TOTL	3379536.	0.	0.	213746.	3593282.
DL	110903.	0.	0.	9502.	120405.
SPRV	125519.	0.	0.	1425.	126945.
MANT	117640.	0.	0.	9586.	127226.
SP	85724.	0.	0.	859.	86584.
ELEC	0.	0.	0.	7460.	7460.
UC	53069.	0.	0.	0.	53069.
WTR	0.	0.	0.	0.	0.
SW	28178.	0.	0.	1351.	29529.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	713502.	0.	0.	0.	713502.
TDOM	1234535.	0.	0.	30184.	1264719.
OH	147615.	0.	0.	8408.	156023.
TOTL	1382150.	0.	0.	38592.	1420741.
CR	419202.	0.	0.	27115.	446317.
WCC	18969.	0.	0.	755.	19724.
MISC	127514.	0.	0.	8248.	135762.
TCC	565685.	0.	0.	36118.	601802.
TOTL	1947834.	0.	0.	74710.	2022543.

HSC-75-Unc, VS

MODEL BOILER 13  
 BOILER ROUTINE UNDR SO2 ROUTINE= 4-01-82 PM ROUTINE= VS FLOW FLAG= 1

BOILER SPECIFICATIONS

Q= 75.0 FLW= 27573. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58

PM EMISSIONS

UNC= 0.657 CTR= 0.100 EFF= 84.80 CRF= 0.1315

SO2 EMISSIONS

UNC= CTR= EFF= CRF=

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 13

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	1051134.	0.	0.	90169.	1141302.
INST	951692.	0.	0.	59482.	1011175.
TD	2002826.	0.	0.	149651.	2152477.
IND	653711.	0.	0.	50895.	704606.
TDI	2656537.	0.	0.	200546.	2857082.
CONT	531307.	0.	0.	40109.	571416.
TK	3187844.	0.	0.	240655.	3428498.
LAND	2000.	0.	0.	0.	2000.
WC	189693.	0.	0.	11260.	200953.
TOTL	3379536.	0.	0.	251915.	3631450.
DL	110903.	0.	0.	13575.	124478.
SPRV	125519.	0.	0.	0.	125519.
MANT	117640.	0.	0.	12355.	129994.
SP	85724.	0.	0.	0.	85724.
ELEC	0.	0.	0.	0.	0.
UC	53069.	0.	0.	17463.	70532.
WTR	0.	0.	0.	0.	0.
SW	28178.	0.	0.	1647.	29825.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	713502.	0.	0.	0.	713502.
TDOM	1234535.	0.	0.	45039.	1279574.
OH	147615.	0.	0.	10814.	158429.
TOTL	1382150.	0.	0.	55854.	1438003.
CR	419202.	0.	0.	31646.	450848.
WCC	18969.	0.	0.	1126.	20095.
MISC	127514.	0.	0.	9626.	137140.
TCC	565685.	0.	0.	42398.	608083.
TOTL	1947854.	0.	0.	98252.	2046085.

HSC-75-Unc, ESP

MODEL BOILER 14  
 BOILER ROUTINE UNDR SO2 ROUTINE= 4-01-82 PM ROUTINE= ESPC FLOW FLAG= 1

SPECIFIC COLLECTION AREA (SQ FT/1000 ACFM) = 117.3  
 TOTAL PLATE AREA (SQ FT) = 3233.3

BOILER SPECIFICATIONS

Q= 75.0 FLW= 27573. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58

PM EMISSIONS

UNC= 0.657 CTR= 0.050 EFF= 92.40 CRF= 0.1315

SO2 EMISSIONS

UNC= CTR= EFF= CRF=

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 14

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1051134.	0.	0.	114921.	1166054.
INST	951692.	0.	0.	134457.	1086149.
TD	2002826.	0.	0.	249377.	2252203.
IND	653711.	0.	0.	83292.	737003.
TDI	2656537.	0.	0.	332669.	2989206.
CONT	531307.	0.	0.	66534..	597841.
TK	3187844.	0.	0.	399203.	3587047.
LAND	2000.	0.	0.	0.	2000.
WC	189693.	0.	0.	7553.	197246.
TOTL	3379536.	0.	0.	406757.	3786292.
DL	110903.	0.	0.	13575.	124478.
SPRV	125519.	0.	0.	0.	125519.
MANT	117640.	0.	0.	11577.	129217.
SP	85724.	0.	0.	1836.	87561.
ELEC	0.	0.	0.	0.	0.
UC	53069.	0.	0.	1430.	54500.
WTR	0.	0.	0.	0.	0.
SW	28178.	0.	0.	1795.	29973.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	713502.	0.	0.	0.	713502.
TDOM	1234535.	0.	0.	30213.	1264748.
OH	147615.	0.	0.	11090.	158705.
TOTL	1382150.	0.	0.	41303.	1423452.
CR	419202.	0.	0.	52495.	471697.
WCC	18969.	0.	0.	755.	19725.
MISC	127514.	0.	0.	15968.	143482.
TCC	565685.	0.	0.	69219.	634903.
TOTL	1947834.	0.	0.	110521.	2058355.

HSC-75-DA(50), DA/PM

MODEL BOILER 15  
 BOILER ROUTINE UNDR SO2 ROUTINE= DAC PM ROUTINE= FLOW FLAG= 1

S STAR (METRIC)= 0.645  
 S DSTAR (METRIC)= 51.023  
 P DSTAR (METRIC)= 20.034

BOILER SPECIFICATIONS

Q= 75.0 FLW= 27573. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58

PM EMISSIONS

UNC= 0.657 CTR= 0.100 EFF= 84.80 CRF= 0.1315

SO2 EMISSIONS

UNC= 5.700 CTR= 2.850 EFF= 50.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLRG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 15

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1051134.	0.	0.	0.	1051134.
INST	951692.	0.	0.	0.	951692.
TD	2002826.	0.	693867.	0.	2696692.
IND	653711.	0.	0.	0.	653711.
TDI	2656537.	0.	0.	0.	2656537.
CONT	531307.	0.	0.	0.	531307.
TK	3187844.	0.	1120522.	0.	4308366.
LAND	2000.	0.	0.	0.	2000.
WC	189693.	0.	62005.	0.	251698.
TOTL	3379536.	0.	1182527.	0.	4562063.
DL	110903.	0.	105000.	0.	215903.
SPRV	125519.	0.	21000.	0.	146519.
MANT	117640.	0.	55509.	0.	173149.
SP	85724.	0.	0.	0.	85724.
ELEC	0.	0.	10126.	0.	10126.
UC	53069.	0.	0.	0.	53069.
WTR	0.	0.	563.	0.	563.
SW	28178.	0.	0.	0.	28178.
SLDG	0.	0.	35695.	0.	35695.
LW	0.	0.	0.	0.	0.
SC	0.	0.	3658.	0.	3658.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	16470.	0.	16470.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	713502.	0.	0.	0.	713502.
TDOM	1234535.	0.	248021.	0.	1482556.
OH	147615.	0.	78692.	0.	226308.
TOTL	1382150.	0.	326714.	0.	1708863.
CR	419202.	0.	147349.	0.	566550.
WCC	18969.	0.	6201.	0.	25170.
MISC	127514.	0.	44821.	0.	172335.
TCC	565685.	0.	198370.	0.	764055.
TOTL	1947834.	0.	525084.	0.	2472917.

HSC-75-DA(50), ESP

MODEL BOILER 16                          4-01-82  
 BOILER ROUTINE UNDR    SO2 ROUTINE= DA                          PM ROUTINE= ESPC                          FLOW FLAG= 1

S STAR (METRIC)= 0.645  
 S DSTAR (METRIC)= 51.023

SPECIFIC COLLECTION AREA (SQ FT/1000 ACFM) = 117.3  
 TOTAL PLATE AREA (SQ FT) = 3233.3

BOILER SPECIFICATIONS

Q= 75.0 FLW= 27573. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58

PM EMISSIONS

UNC= 0.657 CTR= 0.050 EFF= 92.40 CRF= 0.1315

SO2 EMISSIONS

UNC= 5.700 CTR= 2.850 EFF= 50.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 16

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1051134.	0.	0.	114921.	1166054.

INST	951692.	0.	0.	134457.	1086149.
TD	2002826.	0.	601476.	249377.	2853678.
IND	653711.	0.	0.	83292.	737003.
TDI	2656537.	0.	0.	332669.	2989206.
CONT	531307.	0.	0.	66534.	597841.
TK	3187844.	0.	983784.	399203.	4570830.
LAND	2000.	0.	0.	0.	2000.
WC	189693.	0.	58409.	7553.	255655.
TOTL	3379536.	0.	1042193.	406757.	4828185.
DL	110903.	0.	105000.	13575.	229478.
SPRV	125519.	0.	21000.	0.	146519.
MANT	117640.	0.	48118.	11577.	177335.
SP	85724.	0.	0.	1836.	87561.
ELEC	0.	0.	4872.	0.	4872.
UC	53069.	0.	0.	1430.	54500.
WTR	0.	0.	563.	0.	563.
SW	28178.	0.	0.	1795.	29973.
SLDG	0.	0.	33955.	0.	33955.
LW	0.	0.	0.	0.	0.
SC	0.	0.	3658.	0.	3658.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	16470.	0.	16470.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	713502.	0.	0.	0.	713502.
TDOM	1234535.	0.	233637.	30213.	1498385.
OH	147615.	0.	76771.	11090.	235475.
TOTL	1382150.	0.	310408.	41303.	1733859.
CR	419202.	0.	129368.	52495.	601064.
WCC	18969.	0.	5841.	755.	25566.
MISC	127514.	0.	39351.	15968.	182833.
TCC	565685.	0.	174560.	69219.	809463.
TOTL	1947834.	0.	484968.	110521.	2543322.

HSC-75-DA(90), DA/PM

MODEL BOILER 17  
 BOILER ROUTINE UNDR      SO2 ROUTINE= DAC      4-01-82  
 PM ROUTINE=      FLOW FLAG=      1

S STAR (METRIC)=      1.161  
 S DSTAR (METRIC)=      91.842

P DSTAR (METRIC)=      20.034  
**BOILER SPECIFICATIONS**  
 Q=      75.0 FLW= 27573. CF=      0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC=      1.81 H=      11800. S=      3.54 A=      10.58  
**PM EMISSIONS**  
 UNC=      0.657 CTR=      0.100 EFF=      84.80 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC=      5.700 CTR=      0.570 EFF=      90.00 CRF= 0.1315  
**COST RATES**  
 ELEC= 0.0258 WTR=      0.15 LIME= 35.00 ALS=      8.00 SASH= 90.00 SLDG= 15.00 SWD=      15.00 ALWD=      1.80

COST SUMMARY TABLE - RUN NO.      17

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	1051134.	0.	0.	0.	1051134.
INST	951692.	0.	0.	0.	951692.
TD	2002826.	0.	775111.	0.	2777937.
IND	653711.	0.	0.	0.	653711.
TDI	2656537.	0.	0.	0.	2656537.
CONT	531307.	0.	0.	0.	531307.
TK	3187844.	0.	1240764.	0.	4428608.
LAND	2000.	0.	0.	0.	2000.
WC	189693.	0.	74746.	0.	264439.
TOTL	3379536.	0.	1315510.	0.	4695046.
DL	110903.	0.	105000.	0.	215903.
SPRV	125519.	0.	21000.	0.	146519.
MANT	117640.	0.	62009.	0.	179648.
SP	85724.	0.	0.	0.	85724.
ELEC	0.	0.	10799.	0.	10799.
UC	53069.	0.	0.	0.	53069.
WTR	0.	0.	605.	0.	605.
SW	28178.	0.	0.	0.	28178.
SLDG	0.	0.	63091.	0.	63091.
LW	0.	0.	0.	0.	0.
SC	0.	0.	6697.	0.	6697.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	29785.	0.	29785.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	713502.	0.	0.	0.	713502.
TDOM	1234535.	0.	298986.	0.	1533520.
OH	147615.	0.	80382.	0.	227997.
TOTL	1382150.	0.	379368.	0.	1761517.
CR	419202.	0.	163160.	0.	582362.
WCC	18969.	0.	7475.	0.	26444.
MISC	127514.	0.	49631.	0.	177144.
TCC	565685.	0.	220266.	0.	785950.
TOTL	1947834.	0.	599633.	0.	2547467.

HSC-75-DA(90), ESP

MODEL BOILER 18  
 BOILER ROUTINE UNDR SO2 ROUTINE= DA      4-01-82  
 PM ROUTINE= ESPC      FLOW FLAG= 1

S STAR (METRIC)= 1.161  
 S DSTAR (METRIC)= 91.842

SPECIFIC COLLECTION AREA (SQ FT/1000 ACFM) = 117.3  
 TOTAL PLATE AREA (SQ FT) = 3233.3

BOILER SPECIFICATIONS

Q= 75.0 FLW= 27573. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58

PM EMISSIONS

UNC= 0.657 CTR= 0.050 EFF= 92.40 CRF= 0.1315

SO2 EMISSIONS

UNC= 5.700 CTR= 0.570 EFF= 90.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 18

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1051134.	0.	0.	114921.	1166054.
INST	951692.	0.	0.	134457.	1086149.
TD	2002826.	0.	700727.	249377.	2952930.
IND	653711.	0.	0.	83292.	737003.
TDI	2656537.	0.	0.	332669.	2989206.
CONT	531307.	0.	0.	66534.	597841.
TK	3187844.	0.	1130676.	399203.	4717723.
LAND	2000.	0.	0.	0.	2000.
WC	189693.	0.	71423.	7553.	268669.
TOTL	3379536.	0.	1202099.	406757.	4988391.
DL	110903.	0.	105000.	13575.	229478.
SPRV	125519.	0.	21000.	0.	146519.
MANT	117640.	0.	56058.	11577.	185275.
SP	85724.	0.	0.	1836.	87561.
ELEC	0.	0.	5196.	0.	5196.
UC	53049.	0.	0.	1430.	54500.
WTR	0.	0.	605.	0.	605.
SW	28178.	0.	0.	1795.	29973.
SLDG	0.	0.	61351.	0.	61351.
LW	0.	0.	0.	0.	0.
SC	0.	0.	6697.	0.	6697.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	29785.	0.	29785.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	713502.	0.	0.	0.	713502.
TDOM	1234535.	0.	285693.	30213.	1550440.
OH	147615.	0.	78835.	11090.	237540.
TOTL	1382150.	0.	364528.	41303.	1787979.
CR	419202.	0.	148684.	52495.	620381.
WCC	18969.	0.	7142.	755.	26867.
MISC	127514.	0.	45227.	15968.	188709.
TCC	565685.	0.	201053.	69219.	835956.
TOTL	1947834.	0.	565581.	110521.	2623935.

HSC-150-Unc, Unc

MODEL BOILER 19                                  4-01-82  
 BOILER ROUTINE SPRD    SO2 ROUTINE=                                  PM ROUTINE=                                  FLOW FLAG= 1  
**BOILER SPECIFICATIONS**  
 Q= 150.0 FLW= 55146. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 1.81 H= 11800. S= 3.54 A= 10.58  
**PM EMISSIONS**  
 UNC= CTR= EFF= CRF=                                   
**SO2 EMISSIONS**  
 UNC= CTR= EFF= CRF=                                   
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 19

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2542138.	0.	0.	0.	2542138.
INST	2165530.	0.	0.	0.	2165530.
TD	4707668.	0.	0.	0.	4707668.
IND	1515863.	0.	0.	0.	1515863.
TDI	6223531.	0.	0.	0.	6223531.
CONT	1244706.	0.	0.	0.	1244706.
TK	7468237.	0.	0.	0.	7468237.
LAND	2000.	0.	0.	0.	2000.
WC	266406.	0.	0.	0.	266406.
TOTL	7736643.	0.	0.	0.	7736643.
DL	186128.	0.	0.	0.	186128.
SPRV	78752.	0.	0.	0.	78752.
MANT	85796.	0.	0.	0.	85796.
SP	153400.	0.	0.	0.	153400.
ELEC	0.	0.	0.	0.	0.
UC	69844.	0.	0.	0.	69844.
WTR	0.	0.	0.	0.	0.
SW	16229.	0.	0.	0.	16229.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1427004.	0.	0.	0.	1427004.
TDOM	2017152.	0.	0.	0.	2017152.
OH	186898.	0.	0.	0.	186898.
TOTL	2204049.	0.	0.	0.	2204049.
CR	982073.	0.	0.	0.	982073.
WCC	26641.	0.	0.	0.	26641.
MISC	298729.	0.	0.	0.	298729.
TCC	1307443.	0.	0.	0.	1307443.
TOTL	3511492.	0.	0.	0.	3511492.

# HSC-150-Unc, SM

MODEL BOILER 20  
 BOILER ROUTINE SPRD SO2 ROUTINE= 4-01-82 PM ROUTINE= SM FLOW FLAG= 1  
**BOILER SPECIFICATIONS**  
 Q= 150.0 FLW= 55146. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 1.81 H= 11800. S= 3.54 A= 10.58  
**PM EMISSIONS**  
 UNC= 2.540 CTR= 0.600 EFF= 76.40 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= CTR= EFF= CRF=  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWN= 1.80

## COST SUMMARY TABLE - RUN NO. 20

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2542138.	0.	0.	119387.	2661524.
INST	2165530.	0.	0.	0.	2165530.
TD	4707668.	0.	0.	119387.	4827054.
IND	1515863.	0.	0.	39796.	1555658.
TDI	6223531.	0.	0.	159183.	6382713.
CONT	1244706.	0.	0.	31836.	1276542.
TK	7468237.	0.	0.	191019.	7659255.
LAND	2000.	0.	0.	0.	2000.
WC	266406.	0.	0.	9856.	276262.
TOTL	7736643.	0.	0.	200875.	7937517.
DL	186128.	0.	0.	9769.	195897.
SPRV	78752.	0.	0.	1465.	80217.
MANT	85796.	0.	0.	6459.	92255.
SP	153400.	0.	0.	796.	154196.
ELEC	0.	0.	0.	9463.	9463.
UC	69844.	0.	0.	0.	69844.
WTR	0.	0.	0.	0.	0.
SW	16229.	0.	0.	11471.	27700.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.

LYE	0.	0.	0.	0.	0.
FUEL	1427004.	0.	0.	0.	1427004.
TDOM	2017152.	0.	0.	39424.	2056575.
OH	186898.	0.	0.	7738.	194636.
TOTL	2204049.	0.	0.	47162.	2251210.
CR	982073.	0.	0.	25119.	1007192.
WCC	26641.	0.	0.	986.	27626.
MISC	298729.	0.	0.	7641.	306370.
TCC	1307443.	0.	0.	33745.	1341188.
TOTL	3511492.	0.	0.	80907.	3592398.

HSC-150-Unc, SSS

MODEL BOILER 21  
 BOILER ROUTINE SPRD SO2 ROUTINE= 4-01-82 PM ROUTINE= SSS FLOW FLAG= 1  
**BOILER SPECIFICATIONS**  
 Q= 150.0 FLW= 55146. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 1.81 H= 11800. S= 3.54 A= 10.58  
**PM EMISSIONS**  
 UNC= 2.540 CTR= 0.200 EFF= 92.10 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= CTR= EFF= CRF=  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 21

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	2542138.	0.	0.	222357.	2764494.
INST	2165530.	0.	0.	0.	2165530.
TD	4707668.	0.	0.	222357.	4930024.
IND	1515863.	0.	0.	74119.	1589981.
TDI	6223531.	0.	0.	296476.	6520006.
CONT	1244706.	0.	0.	59295.	1304001.
TK	7468237.	0.	0.	355771.	7824007.
LAND	2000.	0.	0.	0.	2000.
WC	266406.	0.	0.	14447.	280854.
TOTL	7736643.	0.	0.	370218.	8106860.
DL	186128.	0.	0.	13676.	199804.
SPRV	78752.	0.	0.	2051.	80803.
MANT	85796.	0.	0.	11998.	97794.
SP	153400.	0.	0.	1482.	154882.
ELEC	0.	0.	0.	14745.	14745.
UC	69844.	0.	0.	0.	69844.
WTR	0.	0.	0.	0.	0.
SW	16229.	0.	0.	13836.	30065.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1427004.	0.	0.	0.	1427004.
TDOM	2017152.	0.	0.	57789.	2074941.
OH	186898.	0.	0.	11697.	198595.
TOTL	2204049.	0.	0.	69486.	2273535.
CR	982073.	0.	0.	46784.	1028857.
WCC	26641.	0.	0.	1445.	28085.
MISC	298729.	0.	0.	14231.	312960.
TCC	1307443.	0.	0.	62459.	1369902.
TOTL	3511492.	0.	0.	131946.	3643437.

HSC-150-Unc, VS

MODEL BOILER 22    4-01-82  
 BOILER ROUTINE SPRD    SO2 ROUTINE=    PM ROUTINE= VS    FLOW FLAG= 1  
**BOILER SPECIFICATIONS**  
 Q= 150.0 FLW= 55146. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 1.81 H= 11800. S= 3.54 A= 10.58  
**PM EMISSIONS**  
 UNC= 2.540 CTR= 0.100 EFF= 96.10 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC=    CTR=    EFF=    CRF=    COST RATES  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80  
**COST SUMMARY TABLE - RUN NO. 22**  
 -----

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2542138.	0.	0.	153422.	2695559.
INST	2165530.	0.	0.	105061.	2270590.
TD	4707668.	0.	0.	258483.	4966150.
IND	1515863.	0.	0.	86326.	1602189.
TDI	6223531.	0.	0.	344809.	6568339.
CONT	1244706.	0.	0.	68962.	1313667.
JK	7468237.	0.	0.	413770.	7882007.
LAND	2000.	0.	0.	0.	2000.
WC	266406.	0.	0.	21902.	288308.
TOTL	7736643.	0.	0.	435672.	8172315.
DL	186128.	0.	0.	19538.	205665.
SPRV	78752.	0.	0.	0.	78752.
MANT	85796.	0.	0.	20185.	105981.
SP	153400.	0.	0.	0.	153400.
ELEC	0.	0.	0.	0.	0.
UC	69844.	0.	0.	33456.	103301.
WTR	0.	0.	0.	0.	0.
SW	16229.	0.	0.	14428.	30657.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1427004.	0.	0.	0.	1427004.
TDOM	2017152.	0.	0.	87606.	2104758.
OH	186898.	0.	0.	16189.	203087.
TOTL	2204049.	0.	0.	103795.	2307844.
CR	982073.	0.	0.	54411.	1036484.
WCC	26641.	0.	0.	2190.	28831.
MISC	298729.	0.	0.	16551.	315280.
TCC	1307443.	0.	0.	73152.	1380594.
TOTL	3511492.	0.	0.	176947.	3688439.

## HSC-150-Unc, ESP

MODEL BOILER 23  
 BOILER ROUTINE SPRD SO2 ROUTINE= 4-01-82 PM ROUTINE= ESPC FLOW FLAG= 1

SPECIFIC COLLECTION AREA (SQ FT/1000 ACFM) = 189.3  
 TOTAL PLATE AREA (SQ FT) - 10440.7

## BOILER SPECIFICATIONS

Q= 150.0 FLW= 55146. CF= 0.600 CRF= 0.1315

## FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58

## PM EMISSIONS

UNC= 2.540 CTR= 0.050 EFF= 98.00 CRF= 0.1315

## SO2 EMISSIONS

UNC= CTR= EFF= CRF=

## COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWN= 1.80

## COST SUMMARY TABLE - RUN NO. 23

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	2542138.	0.	0.	359167.	2901304.
INST	2165530.	0.	0.	395084.	2560613.
TD	4707668.	0.	0.	754250.	5461918.
IND	1515863.	0.	0.	251920.	1767782.
TDI	6223531.	0.	0.	1006170.	7229701.
CONT	1244706.	0.	0.	201234.	1445940.
TK	7468237.	0.	0.	1207404.	8675641.
LAND	2000.	0.	0.	0.	2000.
WC	266406.	0.	0.	14481.	290887.
TOTL	7736643.	0.	0.	1221884.	8958527.
DL	186128.	0.	0.	19538.	205665.
SPRV	78752.	0.	0.	0.	78752.
MANT	85794.	0.	0.	12919.	98715.
SP	153400.	0.	0.	5554.	158954.
ELEC	0.	0.	0.	0.	0.
UC	69844.	0.	0.	5190.	75034.
WTR	0.	0.	0.	0.	0.
SW	16229.	0.	0.	14723.	30952.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1427004.	0.	0.	0.	1427004.
TDOM	2017152.	0.	0.	57923.	2075075.
OH	186898.	0.	0.	15744.	202642.
TOTL	2204049.	0.	0.	73667.	2277716.
CR	982073.	0.	0.	158774.	1140846.
WCC	26641.	0.	0.	1448.	28089.
MISC	298729.	0.	0.	48296.	347026.
TCC	1307443.	0.	0.	208518.	1515960.
TOTL	3511492.	0.	0.	282185.	3793677.

# HSC-150-DA(50), DA/PM

MODEL BOILER 24                          4-01-82  
 BOILER ROUTINE SPRD    SO2 ROUTINE= DAC    PM ROUTINE=                          FLOW FLAG= 1

S STAR (METRIC)= 0.645  
 S DSTAR (METRIC)= 102.047  
 P DSTAR (METRIC)= 193.938  
**BOILER SPECIFICATIONS**  
 Q= 150.0 FLW= 55146. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 1.81 H= 11800. S= 3.54 A= 10.58  
**PM EMISSIONS**  
 UNC= 2.540 CTR= 0.100 EFF= 96.10 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= 5.700 CTR= 2.850 EFF= 50.00 CRF= 0.1315  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

**COST SUMMARY TABLE - RUN NO. 24**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	2542138.	0.	0.	0.	2542138.
INST	2165530.	0.	0.	0.	2165530.
TD	4707668.	0.	958181.	0.	5665848.
IND	1515863.	0.	0.	0.	1515863.
TDI	6223531.	0.	0.	0.	6223531.
CONT	1244706.	0.	0.	0.	1244706.
TK	7468237.	0.	1511707.	0.	8979944.
LAND	2000.	0.	0.	0.	2000.
WC	266406.	0.	87509.	0.	353916.
TOTL	7736643.	0.	1599216.	0.	9335859.
DL	186128.	0.	105000.	0.	291128.
SPRV	78752.	0.	21000.	0.	99752.
MANT	85796.	0.	76654.	0.	162450.
SP	153400.	0.	0.	0.	153400.
ELEC	0.	0.	20252.	0.	20252.
UC	69844.	0.	0.	0.	69844.
WTR	0.	0.	1068.	0.	1068.
SW	16229.	0.	0.	0.	16229.
SLDG	0.	0.	85039.	0.	85039.
LW	0.	0.	0.	0.	0.
SC	0.	0.	7912.	0.	7912.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	33113.	0.	33113.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1427004.	0.	0.	0.	1427004.
TDOM	2017152.	0.	350038.	0.	2367189.
OH	186898.	0.	84190.	0.	271088.
TOTL	2204049.	0.	434228.	0.	2638277.
CR	982073.	0.	198789.	0.	1180862.
WCC	26641.	0.	8751.	0.	35392.
MISC	298729.	0.	60468.	0.	359198.
TCC	1307443.	0.	268009.	0.	1575451.
TOTL	3511492.	0.	702237.	0.	4213728.

HSC-150-DA(50), ESP

MODEL BOILER 25  
 BOILER ROUTINE SPRD SO2 ROUTINE= DA 4-01-82 PM ROUTINE= ESPC FLOW FLAG= 1

S STAR (METRIC)= 0.645  
 S DSTAR (METRIC)= 102.047

SPECIFIC COLLECTION AREA (SQ FT/1000 ACFM) = 189.3  
 TOTAL PLATE AREA (SQ FT) = 10440.7

BOILER SPECIFICATIONS

Q= 150.0 FLW= 55146. CF= 0.600 CRF= 0.1315  
 FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58  
 PM EMISSIONS  
 UNC= 2.540 CTR= 0.050 EFF= 98.00 CRF= 0.1315  
 SO2 EMISSIONS  
 UNC= 5.700 CTR= 2.850 EFF= 50.00 CRF= 0.1315  
 COST RATES  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SND= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 25

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	2542138.	0.	0.	359167.	2901304.
INST	2165530.	0.	0.	395084.	2560613.
TD	4707668.	0.	834849.	754250.	6296767.
IND	1515863.	0.	0.	251920.	1767782.
TDI	6223531.	0.	0.	1006170.	7229701.
CONT	1244706.	0.	0.	201234.	1445940.
TK	7468237.	0.	1329176.	1207404.	10004817.
LAND	2000.	0.	0.	0.	2000.
WC	266406.	0.	78206.	14481.	359094.
TOTL	7736643.	0.	1407382.	1221884.	10365909.
DL	186128.	0.	105000.	19538.	310665.
SPRV	78752.	0.	21000.	0.	99752.
MANT	85796.	0.	66788.	12919.	165503.
SP	153400.	0.	0.	5554.	158954.
ELEC	0.	0.	9745.	0.	9745.
UC	69844.	0.	0.	5190.	75034.
WTR	0.	0.	1068.	0.	1068.
SW	16229.	0.	0.	14723.	30952.
SLDG	0.	0.	68201.	0.	68201.
LW	0.	0.	0.	0.	0.
SC	0.	0.	7912.	0.	7912.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	33113.	0.	33113.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1427004.	0.	0.	0.	1427004.
TDOM	2017152.	0.	312826.	57923.	2387900.
OH	186898.	0.	81625.	15744.	284267.
TOTL	2204049.	0.	394450.	73667.	2672166.
CR	982073.	0.	174787.	158774.	1315632.
WCC	26641.	0.	7821.	1448.	35909.
MISC	298729.	0.	53167.	48296.	400193.
TCC	1307443.	0.	235774.	208518.	1751734.
TOTL	3511492.	0.	630225.	282185.	4423901.

HSC-150-DA(90), DA/PM

MODEL BOILER 26                          4-01-82  
 BOILER ROUTINE SPRD    SO2 ROUTINE= DAC                          PM ROUTINE=                          FLOW FLAG= 1

S STAR (METRIC)= 1.161  
 S DSTAR (METRIC)= 183.684  
 P DSTAR (METRIC)= 193.938

BOILER SPECIFICATIONS

Q= 150.0 FLW= 55146. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58

PM EMISSIONS

UNC= 2.540 CTR= 0.100 EFF= 96.10 CRF= 0.1315

SO2 EMISSIONS

UNC= 5.700 CTR= 0.570 EFF= 90.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 26

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2542138.	0.	0.	0.	2542138.
INST	2165530.	0.	0.	0.	2165530.
TD	4707668.	0.	1053447.	0.	5761115.
IND	1515863.	0.	0.	0.	1515863.
TDI	6223531.	0.	0.	0.	6223531.
CONT	1244706.	0.	0.	0.	1244706.
TK	7468237.	0.	1652701.	0.	9120938.
LAND	2000.	0.	0.	0.	2000.
WC	266406.	0.	111770.	0.	378176.
TOTL	7736643.	0.	1764470.	0.	9501113.
DL	186128.	0.	105000.	0.	291128.
SPRV	78752.	0.	21000.	0.	99752.
MANT	85796.	0.	84276.	0.	170072.

SP	153400.	0.	0.	0.	153400.
ELEC	0.	0.	21598.	0.	21598.
UC	69844.	0.	0.	0.	69844.
WTR	0.	0.	1147.	0.	1147.
SW	16229.	0.	0.	0.	16229.
SLDG	0.	0.	139832.	0.	139832.
Ld	0.	0.	0.	0.	0.
SC	0.	0.	14485.	0.	14485.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	59741.	0.	59741.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1427004.	0.	0.	0.	1427004.
TDOM	2017152.	0.	447079.	0.	2464231.
OH	186898.	0.	86172.	0.	273070.
TOTL	2204049.	0.	533251.	0.	2737299.
CR	982073.	0.	217330.	0.	1199403.
WCC	26641.	0.	11177.	0.	37818.
MISC	298729.	0.	66108.	0.	364837.
TCC	1307443.	0.	294615.	0.	1602058.
TOTL	3511492.	0.	827866.	0.	4339357.

HSC-150-DA(90), ESP

MODEL BOILER 27  
 BOILER ROUTINE SPRD SO2 ROUTINE= DA 4-01-82 PM ROUTINE= ESPC FLOW FLAG= 1

S STAR (METRIC)= 1.161  
 S DSTAR (METRIC)= 183.684

SPECIFIC COLLECTION AREA (SQ FT/1000 ACFM) = 189.3  
 TOTAL PLATE AREA (SQ FT) = 10440.7

BOILER SPECIFICATIONS

Q= 150.0 FLW= 55146. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58

PM EMISSIONS

UNC= 2.540 CTR= 0.050 EFF= 98.00 CRF= 0.1315

SO2 EMISSIONS

UNC= 5.700 CTR= 0.570 EFF= 90.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 27

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2542138.	0.	0.	359167.	2901304.
INST	2165530.	0.	0.	395084.	2560613.
TD	4707668.	0.	964908.	754250.	6426825.
IND	1515863.	0.	0.	251920.	1767782.
TDI	6223531.	0.	0.	1006170.	7229701.
CONT	1244706.	0.	0.	201234.	1445940.
TK	7468237.	0.	1521663.	1207404.	10197304.
LAND	2000.	0.	0.	0.	2000.
WC	266406.	0.	102988.	14481.	383875.
TOTL	7736643.	0.	1624650.	1221884.	10583177.
DL	186128.	0.	105000.	19538.	310665.
SPRV	78752.	0.	21000.	0.	99752.
MANT	85796.	0.	77193.	12919.	175907.
SP	153400.	0.	0.	5554.	158954.
ELEC	0.	0.	10393.	0.	10393.
UC	69844.	0.	0.	5190.	75034.
WTR	0.	0.	1147.	0.	1147.
SW	16229.	0.	0.	14723.	30952.
SLDG	0.	0.	122993.	0.	122993.
LW	0.	0.	0.	0.	0.
SC	0.	0.	14485.	0.	14485.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	59741.	0.	59741.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1427004.	0.	0.	0.	1427004.
TDOM	2017152.	0.	411951.	57923.	2487026.
OH	186898.	0.	84330.	15744.	286972.
TOTL	2204049.	0.	496282.	73667.	2773997.
CR	982073.	0.	200099.	158774.	1340944.
WCC	26641.	0.	10299.	1448.	38388.
MISC	298729.	0.	60867.	48296.	407892.
TCC	1307443.	0.	271264.	208518.	1787223.
TOTL	3511492.	0.	767545.	282185.	4561222.

HSC-400-Unc, Unc

MODEL BOILER 28	4-01-82				
BOILER ROUTINE PLVR	SO2 ROUTINE=	PM ROUTINE=		FLOW FLAG=	3
<b>BOILER SPECIFICATIONS</b>					
Q= 400.0 FLW= 141646 CF= 0.600 CRF= 0.1315					
<b>FUEL SPECIFICATIONS</b>					
FC= 1.81 H= 11800. S= 3.54 A= 10.38					
<b>PM EMISSIONS</b>					
UNC= CTR= EFF= CRF=					
<b>SO2 EMISSIONS</b>					
UNC= CTR= EFF= CRF=					
<b>COST RATES</b>					
ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80					
<b>COST SUMMARY TABLE - RUN NO. 28</b>					
ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	7300607.	0.	0.	0.	7300607.
INST	3907605.	0.	0.	0.	3907605.
TD	11208212.	0.	0.	0.	11208212.
IND	3507363.	0.	0.	0.	3507363.
TDI	14715575.	0.	0.	0.	14715575.
CONT	2943114.	0.	0.	0.	2943114.
TK	17658688.	0.	0.	0.	17658688.
LAND	4000.	0.	0.	0.	4000.
WC	671217.	0.	0.	0.	671217.
TOTL	18333904.	0.	0.	0.	18333904.
DL	406848.	0.	0.	0.	406848.
SPRV	110674.	0.	0.	0.	110674.
MANT	215444.	0.	0.	0.	215444.
SP	262766.	0.	0.	0.	262766.
ELEC	0.	0.	0.	0.	0.
UC	396920.	0.	0.	0.	396920.
WTR	0.	0.	0.	0.	0.
SW	24274.	0.	0.	0.	24274.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
 LYE	0.	0.	0.	0.	0.
FUEL	3805344.	0.	0.	0.	3805344.
TDOM	5222270.	0.	0.	0.	5222270.
DH	380945.	0.	0.	0.	380945.
TOTL	5603214.	0.	0.	0.	5603214.
 CR	2322117.	0.	0.	0.	2322117.
WCC	67122.	0.	0.	0.	67122.
MISC	706348.	0.	0.	0.	706348.
TCC	3095585.	0.	0.	0.	3095585.
TOTL	8698799.	0.	0.	0.	8698799.

HSC-400-Unc, SM

MODEL BOILER 29  
 BOILER ROUTINE PLVR SO2 ROUTINE= 4-01-82  
 PM ROUTINE= SM FLOW FLAG= 3  
 BOILER SPECIFICATIONS  
 Q= 400.0 FLW= 141646 CF= 0.600 CRF= 0.1315  
 FUEL SPECIFICATIONS  
 FC= 1.81 H= 11800. S= 3.54 A= 10.58  
 PM EMISSIONS  
 UNC= 3.810 CTR= 1.000 EFF= 73.80 CRF= 0.1315  
 SO2 EMISSIONS  
 - UNC= CTR= EFF= CRF=  
 COST RATES  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 29

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	7300607.	0.	0.	242193.	7542799.
INST	3907605.	0.	0.	0.	3907605.
TD	11208212.	0.	0.	242193.	11450404.
IND	3507363.	0.	0.	80731.	3588093.
TDI	14715575.	0.	0.	322924.	15038498.
CONT	2943114.	0.	0.	64585.	3007698.
TK	17658688.	0.	0.	387509.	18046192.
LAND	4000.	0.	0.	0.	4000.
WC	671217.	0.	0.	26189.	697406.
TOTL	18333904.	0.	0.	413698.	18747600.
DL	406848.	0.	0.	19706.	426555.
SPRV	110674.	0.	0.	2956.	113630.
MANT	215444.	0.	0.	11925.	227369.
SP	262766.	0.	0.	1615.	264380.
ELEC	0.	0.	0.	24247.	24247.
UC	396920.	0.	0.	0.	396920.
WTR	0.	0.	0.	0.	0.
SW	24274.	0.	0.	44308.	68582.
SLDG.	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3805344.	0.	0.	0.	3805344.
TDOM	5222270.	0.	0.	104757.	5327026.
OH	380945.	0.	0.	15324.	396269.
TOTL	5603214.	0.	0.	120081.	5723295.
CR	2322117.	0.	0.	50957.	2373074.
WCC	67122.	0.	0.	2619.	69741.
MISC	706348.	0.	0.	15500.	721848.
TCC	3095585.	0.	0.	69077.	3164661.
TOTL	8698799.	0.	0.	189158.	8887956.

HSC-400-Unc, SSS

MODEL BOILER 30  
 BOILER ROUTINE PLVR SO2 ROUTINE= 4-01-82 PM ROUTINE= SSS FLOW FLAG= 3  
**BOILER SPECIFICATIONS**  
 Q= 400.0 FLW= 141646 CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 1.81 H= 11800. S= 3.54 A= 10.58  
**PM EMISSIONS**  
 UNC= 3.810 CTR= 0.200 EFF= 94.80 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= CTR= EFF= CRF= --  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80  
**COST SUMMARY TABLE - RUN NO. 30**

---

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	7300607.	0.	0.	466227.	7766833.
INST	3907605.	0.	0.	0.	3907605.
TD	11208212.	0.	0.	466227.	11674438.
IND	3507363.	0.	0.	155409.	3662771.
TDI	14715575.	0.	0.	621636.	15337210.
CONT	2943114.	0.	0.	124327.	3067441.
TK	17658688.	0.	0.	745963.	18404640.
LAND	4000.	0.	0.	0.	4000.
WC	671217.	0.	0.	38295.	709512.
TOTL	18333904.	0.	0.	784258.	19118160.
DL	406848.	0.	0.	27589.	434437.
SPRV	110674.	0.	0.	4138.	114812.
MANT	215444.	0.	0.	24227.	239671.
SP	262766.	0.	0.	3108.	265874.
ELEC	0.	0.	0.	37195.	37195.
UC	396920.	0.	0.	0.	396920.
WTR	0.	0.	0.	0.	0.
SW	24274.	0.	0.	56922.	81197.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3805344.	0.	0.	0.	3805344.
TDOM	5222270.	0.	0.	153180.	5375449.
OH	380945.	0.	0.	23633.	404578.
TOTL	5603214.	0.	0.	176813.	5780026.
CR	2322117.	0.	0.	98094.	2420211.
WCC	67122.	0.	0.	3829.	70951.
MISC	706348.	0.	0.	29839.	736186.
TCC	3095585.	0.	0.	131762.	3227347.
TOTL	8698799.	0.	0.	308575.	9007373.

## HSC-400-Unc, VS

MODEL BOILER 31  
BOILER ROUTINE PLVR SO2 ROUTINE=4-01-82  
PM ROUTINE= VS

FLOW FLAG= 3

## BOILER SPECIFICATIONS

Q= 400.0 FLW= 141646 CF= 0.600 CRF= 0.1315

## FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58

## PM EMISSIONS

UNC= 3.810 CTR= 0.100 EFF= 97.40 CRF= 0.1315

## SO2 EMISSIONS

UNC= CTR= EFF= CRF=

## COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

## COST SUMMARY TABLE - RUN NO. 31

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	7300607.	0.	0.	351059.	7651665.
INST	3907605.	0.	0.	247473.	4155078.
TD	11208212.	0.	0.	598532.	11806743.
IND	3507363.	0.	0.	197034.	3704396.
TDI	14715575.	0.	0.	795566.	15511140.
CONT	2943114.	0.	0.	159113.	3102227.
TK	17658688.	0.	0.	954679.	18613360.
LAND	4000.	0.	0.	0.	4000.
WC	671217.	0.	0.	57037.	728254.
TOTL	18333904.	0.	0.	1011716.	19345616.
DL	406848.	0.	0.	39413.	446261.
SPRV	110674.	0.	0.	0.	110674.
MANT	215444.	0.	0.	46285.	261729.
SP	262766.	0.	0.	0.	262766.
ELEC	0.	0.	0.	0.	0.
UC	396920.	0.	0.	83953.	480872.
WTR	0.	0.	0.	0.	0.
SW	24274.	0.	0.	58499.	82773.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3805344.	0.	0.	0.	3805344.
TDOM	5222270.	0.	0.	228149.	5450419.
OH	380945.	0.	0.	34105.	415050.
TOTL	5603214.	0.	0.	262254.	5865468.
CR	2322117.	0.	0.	125540.	2447657.
WCC	67122.	0.	0.	5704.	72825.
MISC	706348.	0.	0.	38187.	744535.
TCC	3095585.	0.	0.	169431.	3265016.
TOTL	8698799.	0.	0.	431685.	9130484.

HSC-400-Unc, ESP

MODEL BOILER 32                          4-01-82  
 BOILER ROUTINE PLVR    SO2 ROUTINE=                          PM ROUTINE= ESPC                          FLOW FLAG=    3

SPECIFIC COLLECTION AREA (SQ FT/1000 ACFM) =    220.0

TOTAL PLATE AREA (SQ FT) =    31090.4

BOILER SPECIFICATIONS

Q=    400.0 FLW= 141646    CF=    0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC=    1.81 H=    11800. S=    3.54 A=    10.58

PM EMISSIONS

UNC=    3.810 CTR= 0.050 EFF= 98.70 CRF= 0.1315

SO2 EMISSIONS

UNC=    CTR=    EFF=    CRF=

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO.    32

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	7300607.	0.	0.	495871.	7796477.
INST	3907605.	0.	0.	545458.	4453063.
TD	11208212.	0.	0.	1041329.	12249540.
IND	3507363.	0.	0.	347804.	3855166.
TDI	14715575.	0.	0.	1389132.	16104707.
CONT	2943114.	0.	0.	277826.	3220940.
TK	17658688.	0.	0.	1666958.	19325632.
LAND	4000.	0.	0.	0.	4000.
WC	671217.	0.	0.	36665.	707882.
TOTL	18333904.	0.	0.	1703623.	20037520.
DL	406848.	0.	0.	39413.	446261.
SPRV	110674.	0.	0.	0.	110674.
MANT	215444.	0.	0.	23850.	239294.
SP	262766.	0.	0.	7668.	270434.
ELEC	0.	0.	0.	0.	0.
UC	396920.	0.	0.	16442.	413362.
WTR	0.	0.	0.	0.	0.
SW	24274.	0.	0.	59288.	83562.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3805344.	0.	0.	0.	3805344.
JDOM	5222270.	0.	0.	146660.	5368930.
OH	380945.	0.	0.	30266.	411211.
TOTL	5603214.	0.	0.	176926.	5780139.
CR	2322117.	0.	0.	219205.	2541321.
WCC	67122.	0.	0.	3667.	70788.
MISC	706348.	0.	0.	66678.	773026.
TCC	3095585.	0.	0.	289550.	3385134.
TOTL	8698799.	0.	0.	466476.	9165274.

HSC-400-DA(50), DA/PM

MODEL BOILER 33  
BOILER ROUTINE PLVR

SO2 ROUTINE= DAC

4-01-82

PM ROUTINE=

FLOW FLAG= 3

S STAR (METRIC)= 0.645  
S DSTAR (METRIC)= 272.124

P DSTAR (METRIC)= 793.911

BOILER SPECIFICATIONS

Q= 400.0 FLW= 141646 CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 1.81 H= 11800. S= 3.54 A= 10.58

PM EMISSIONS

UNC= 3.810 CTR= 0.100 EFF= 97.40 CRF= 0.1315

SO2 EMISSIONS

UNC= 5.700 CTR= 2.850 EFF= 50.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 33

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	7300607.	0.	0.	0.	7300607.
INST	3907605.	0.	0.	0.	3907605.
TD	11208212.	0.	1500361.	0.	12708573.
IND	3507363.	0.	0.	0.	3507363.
TDI	14715575.	0.	0.	0.	14715575.
CONT	2943114.	0.	0.	0.	2943114..
TK	17658688.	0.	2350533.	0.	20009216.
LAND	4000.	0.	0.	0.	4000.
WC	671217.	0.	165409.	0.	836626.
TOTL	18333904.	0.	2515942.	0.	20849840.
DL	406848.	0.	105000.	0.	511848.
SPRV	110674.	0.	21000.	0.	131674.
MANT	215444.	0.	120029.	0.	335473.
SP	262766.	0.	0.	0.	262766.
ELEC	0.	0.	51890.	0.	51890.
UC	396920.	0.	0.	0.	396920.
WTR	0.	0.	2644.	0.	2644.
SW	24274.	0.	0.	0.	24274.
SLDG	0.	0.	251284.	0.	251284.
LW	0.	0.	0.	0.	0.
SC	0.	0.	21203.	0.	21203.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	88589.	0.	88589.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3805344.	0.	0.	0.	3805344.
TDOM	5222270.	0.	661638.	0.	5883907.
OH	380945.	0.	95467.	0.	476412.
TOTL	5603214.	0.	757105.	0.	6360319.
CR	2322117.	0.	309095.	0.	2631212.
WCC	67122.	0.	16541.	0.	83663.
MISC	706348.	0.	94021.	0.	800369.
TCC	3095585.	0.	419657.	0.	3515242.
TOTL	8698799.	0.	1176762.	0.	9875561.

# HSC-400-DA(50), ESP

MODEL BOILER 34                          4-01-82  
 BOILER ROUTINE PLVR                    SO2 ROUTINE= DA                          PM ROUTINE= ESPC                          FLOW FLAG= 3

S STAR (METRIC)= 0.645  
 S DSTAR (METRIC)= 272.124

SPECIFIC COLLECTION AREA (SQ FT/1000 ACFM) = 220.0  
 TOTAL PLATE AREA (SQ FT) = 31090.4

**BOILER SPECIFICATIONS**

Q= 400.0 FLW= 141646 CF= 0.600 CRF= 0.1315

**FUEL SPECIFICATIONS**

FC= 1.81 H= 11800. S= 3.54 A= 10.58

**PM EMISSIONS**

UNC= 3.810 CTR= 0.050 EFF= 98.70 CRF= 0.1315

**SO2 EMISSIONS**

UNC= 5.700 CTR= 2.850 EFF= 50.00 CRF= 0.1315

**COST RATES**

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

**COST SUMMARY TABLE - RUN NO. 34**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	7300607.	0.	0.	495871.	7796477.
INST	3907605.	0.	0.	545458.	4453063.
TD	11208212.	0.	1325946.	1041329.	13575486.
IND	3507363.	0.	0.	347804.	3855166.
TDI	14715575.	0.	0.	1389132.	16104707.
CONT	2943114.	0.	0.	277826.	3220940.
TK	17658688.	0.	2092399.	1666958.	21418016.
LAND	4000.	0.	0.	0.	4000.
WC	671217.	0.	137958.	36665.	845839.
TOTL	18333904.	0.	2230356.	1703623.	22267872.
DL	406848.	0.	105000.	39413.	551261.
SPRV	110674.	0.	21000.	0.	131674.
MANT	215444.	0.	106076.	23850.	345370.
SP	262766.	0.	0.	7668.	270434.
ELEC	0.	0.	24968.	0.	24968.
UC	396920.	0.	0.	16442.	413362.
WTR	0.	0.	2644.	0.	2644.
SW	24274.	0.	0.	59288.	83562.
SLDG	0.	0.	182351.	0.	182351.
LW	0.	0.	0.	0.	0.
SC	0.	0.	21203.	0.	21203.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	88589.	0.	88589.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3805344.	0.	0.	0.	3805344.
TDOM	5222270.	0.	551830.	146660.	5920760.
OH	380945.	0.	91840.	30266.	503050.
TOTL	5603214.	0.	643670.	176926.	6423808.
CR	2322117.	0.	275150.	219205.	2816471.
WCC	67122.	0.	13796.	3667.	84584.
MISC	706348.	0.	83696.	66678.	856722.
TCC	3095585.	0.	372642.	289550.	3757776.
TOTL	8698799.	0.	1016312.	466476.	10181585.

HSC-400-DA(90), DA/PM

MODEL BOILER 35                          4-01-82  
 BOILER ROUTINE PLVR    SO2 ROUTINE= DAC                          PM ROUTINE=                          FLOW FLAG=    3

S STAR (METRIC)=    1.161  
 S DSTAR (METRIC)=    489.824  
 P DSTAR (METRIC)=    793.911  
**BOILER SPECIFICATIONS**  
 Q=    400.0 FLW= 141546    CF=    0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC=    1.81 H=    11800 S=    3.54 A=    10.58  
**PM EMISSIONS**  
 UNC=    3.810 CTR= 0.100 EFF=    97.40 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC=    5.700 CTR= 0.570 EFF=    90.00 CRF= 0.1315  
**COST RATES**  
 ELEC= 0.0258 WTR=    0.15 LIME= 35.00 ALS=    8.00 SASH= 90.00 SLDG= 15.00 SWR=    15.00 ALWD=    1.80  
**COST SUMMARY TABLE - RUN NO. 35**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
------	--------	-------------	-------------	------------	-------

EQUIP	7300607.	0.	0.	0.	7300607.
INST	3907605.	0.	0.	0.	3907605.
TD	11208212.	0.	1626037.	0.	12834249.
IND	3507363.	0.	0.	0.	3507363.
TDI	14715575.	0.	0.	0.	14715575.
CONT	2943114.	0.	0.	0.	2943114.
TK	17658688.	0.	2536534.	0.	20195216.
LAND	4000.	0.	0.	0.	4000.
WC	671217.	0.	227519.	0.	898736.
TOTL	18333904.	0.	2764053.	0.	21097952.
DL	406848.	0.	105000.	0.	511848.
SPRV	110674.	0.	21000.	0.	131674.
MANT	215444.	0.	130083.	0.	345527.
SP	262766.	0.	0.	0.	262766.
ELEC	0.	0.	55340.	0.	55340.
UC	396920.	0.	0.	0.	396920.
WTR	0.	0.	2839.	0.	2839.
SW	24274.	0.	0.	0.	24274.
SLDG	0.	0.	397397.	0.	397397.
LW	0.	0.	0.	0.	0.
SC	0.	0.	38820.	0.	38820.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	159597.	0.	159597.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3805344.	0.	0.	0.	3805344.
TDOM	5222270.	0.	910076.	0.	6132346.
OH	380945.	0.	98082.	0.	479026.
TOTL	5603214.	0.	1008158.	0.	6611371.
CR	2322117.	0.	333554.	0.	2655671.
WCC	67122.	0.	22752.	0.	89874.
MISC	706348.	0.	101461.	0.	807809.
TCC	3095585.	0.	457767.	0.	3553352.
TOTL	8698799.	0.	1465925.	0.	10164724.

HSC-400-DA(90), ESP

MODEL BOILER 36  
BOILER ROUTINE PLVR SO2 ROUTINE= DA 4-01-82 PM ROUTINE= ESPC FLOW FLAG= 3

S STAR (METRIC)= 1.161

S DSTAR (METRIC)= 489.824

SPECIFIC COLLECTION AREA (SQ FT/1000 ACFM) = 220.0

TOTAL PLATE AREA (SQ FT) = 31090.4

BOILER SPECIFICATIONS

Q= 400.0 FLW= 141646 CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 1.81 H= 11800 S= 3.54 A= 10.58

PM EMISSIONS

UNC= 3.810 CTR= 0.050 EFF= 98.70 CRF= 0.1315

SO2 EMISSIONS

UNC= 5.700 CTR= 0.570 EFF= 90.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 36

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	7300607.	0.	0.	495871.	7796477.
INST	3907605.	0.	0.	545458.	4453063.
TD	11208212.	0.	1516610.	1041329.	13766150.
IND	3507363.	0.	0.	347804.	3855166.
TDI	14715575.	0.	0.	1389132.	16104707.
CONT	2943114.	0.	0.	277826.	3220940.
TK	17658688.	0.	2374582.	1666958.	21700208.
LAND	4000.	0.	0.	0.	4000.
WC	671217.	0.	200920.	36665.	908801.
TOTL	18333904.	0.	2575501.	1703623.	22613008.
DL	406848.	0.	105000.	39413.	551261.
SPRV	110674.	0.	21000.	0.	131674.
MANT	215444.	0.	121329.	23850.	360623.
SP	262766.	0.	0.	7668.	270434.
ELEC	0.	0.	26628.	0.	26628.
UC	396920.	0.	0.	16442.	413362.
WTR	0.	0.	2839.	0.	2839.
SW	24274.	0.	0.	59288.	83562.
SLDG	0.	0.	328464.	0.	328464.
LW	0.	0.	0.	0.	0.
SC	0.	0.	38820.	0.	38820.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	159597.	0.	159597.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3805344.	0.	0.	0.	3805344.
TDOM	5222270.	0.	803678.	146660.	6172608.
OH	380945.	0.	95805.	30266.	507016.
TOTL	5603214.	0.	899484.	176926.	6679622.
CR	2322117.	0.	312258.	219205.	2853578.
WCC	67122.	0.	20092.	3667.	90880.
MISC	706348.	0.	94983.	66678.	868009.
TCC	3095585.	0.	427333.	289550.	3812466.
TOTL	8698799.	0.	1326816.	466476.	10492090.

LSC-30-Unc, Unc

MODEL BOILER 1  
 BOILER ROUTINE UNDR SO2 ROUTINE= 4-06-82 PM ROUTINE= FLOW FLAG= 1  
 BOILER SPECIFICATIONS Q= 30.0 FLW= 11334. CF= 0.600 CRF= 0.1315  
 FUEL SPECIFICATIONS FC= 2.41 H= 9600. S= 0.60 A= 5.40  
 PM EMISSIONS UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0  
 SO2 EMISSIONS UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0  
 COST RATES ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE RUN NO. 1

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	713439.	0.	0.	0.	713439.
INST	630975.	0.	0.	0.	630975.
TD	1344413.	0.	0.	0.	1344413.
IND	437820.	0.	0.	0.	437820.
TDI	1782233.	0.	0.	0.	1782233.
CONT	356447.	0.	0.	0.	356447.
TK	2138679.	0.	0.	0.	2138679.
LAND	2000.	0.	0.	0.	2000.
WC	103737.	0.	0.	0.	103737.
TOTL	2244416.	0.	0.	0.	2244416.
DL	90863.	0.	0.	0.	90863.
SPRV	44001.	0.	0.	0.	44001.
MANT	41173.	0.	0.	0.	41173.
SP	65485.	0.	0.	0.	65485.
ELEC	0.	0.	0.	0.	0.
UC	35718.	0.	0.	0.	35718.
WTR	0.	0.	0.	0.	0.
SW	11092.	0.	0.	0.	11092.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	380009.	0.	0.	0.	380009.
TDOM	668339.	0.	0.	0.	668339.
OH	90054.	0.	0.	0.	90054.
TOTL	758393.	0.	0.	0.	758393.
CR	281236.	0.	0.	0.	281236.
WCC	10374.	0.	0.	0.	10374.
MISC	85547.	0.	0.	0.	85547.
TCC	377157.	0.	0.	0.	377157.
TOTL	1135550.	0.	0.	0.	1135550.

LSC-30-Unc, SM

MODEL BOILER 2  
 BOILER ROUTINE UNDR SO2 ROUTINE= 4-06-82 PM ROUTINE= SM FLOW FLAG= 1

BOILER SPECIFICATIONS  
 Q= 30.0 FLW= 11334. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40

PM EMISSIONS  
 UNC= 0.807 CTR= 0.400 EFF= 50.00 CRF= 0.1315

SO2 EMISSIONS  
 UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0

COST RATES  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 2

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	713439.	0.	0.	36338.	749777.
INST	630975.	0.	0.	0.	630975.
TD	1344413.	0.	0.	36338.	1380751.
IND	437820.	0.	0.	12113.	449933.
TDI	1782233.	0.	0.	48451.	1830683.
CONT	356447.	0.	0.	9690.	366137.
TK	2139679.	0.	0.	58141.	2196820.
LAND	2000.	0.	0.	0.	2000.
WC	103737.	0.	0.	3504.	107242.
TOTL	2244416.	0.	0.	61646.	2306061.
DL	90863.	0.	0.	4999.	95862.
SPRU	44001.	0.	0.	750.	44751.
MANT	41173.	0.	0.	5601.	46773.
SP	65485.	0.	0.	242.	65727.
ELEC	0.	0.	0.	1945.	1945.
UC	35718.	0.	0.	0.	35718.
WTR	0.	0.	0.	0.	0.
SW	11092.	0.	0.	481.	11573.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	380009.	0.	0.	0.	380009.
TDOM	668339.	0.	0.	14018.	682357.
OH	90054.	0.	0.	4513.	94568.
TOTL	758393.	0.	0.	18531.	776925.
CR	281236.	0.	0.	7646.	288882.
WCC	10374.	0.	0.	350.	10724.
MISC	85547.	0.	0.	2326.	87873.
TCC	377157.	0.	0.	10322.	387479.
TOTL	1135550.	0.	0.	28853.	1164402.

LSC-30-Unc, SSS

MODEL BOILER 3                          4-06-82  
 BOILER ROUTINE UNDR    SO2 ROUTINE=                          PM ROUTINE= SSS                          FLOW FLAG= 1

BOILER SPECIFICATIONS

Q= 30.0 FLW= 11334. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 2.41 H= 9600. S= 0.60 A= 5.40

PM EMISSIONS

UNC= 0.807 CTR= 0.200 EFF= 75.20 CRF= 0.1315

SO2 EMISSIONS

UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE RUN NO. 3

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	713439.	0.	0.	64023.	777462.
INST	630975.	0.	0.	0.	630975.
TD	1344413.	0.	0.	64023.	1408434.
IND	437820.	0.	0.	21341.	459161.
TDI	1782233.	0.	0.	85364.	1867597.
CONT	356447.	0.	0.	17073.	373519.
TK	2138679.	0.	0.	102437.	2241116.
LAND	2000.	0.	0.	0.	2000.
WC	103737.	0.	0.	5190.	108927.
TOTL	2244416.	0.	0.	107627.	2352043.
DL	90863.	0.	0.	6998.	97861.
SPRV	44001.	0.	0.	1050.	45051.
MANT	41173.	0.	0.	8453.	49626.
SP	65485.	0.	0.	427.	65912.
ELEC	0.	0.	0.	3114.	3114.
UC	35718.	0.	0.	0.	35718.
WTR	0.	0.	0.	0.	0.
SW	11092.	0.	0.	718.	11809.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	380009.	0.	0.	0.	380009.
TDOM	668339.	0.	0.	20760.	689099.
OH	90054.	0.	0.	6501.	96555.
TOTL	758393.	0.	0.	27261.	785654.
CR	281236.	0.	0.	13470.	294707.
WCC	10374.	0.	0.	519.	10893.
MISC	85547.	0.	0.	4097.	89645.
TCC	377157.	0.	0.	18087.	395244.
TOTL	1135550.	0.	0.	45347.	1180897.

LSC-30-Unc, VS

MODEL BOILER	4		4-06-82		
BOILER ROUTINE	UNDR	S02 ROUTINE=	PM ROUTINE=	VS	FLOW FLAG=
BOILER SPECIFICATIONS					
Q= 30.0 FLW= 11334. CF= 0.600 CRF= 0.1315					
FUEL SPECIFICATIONS					
FC= 2.41 H= 9600. S= 0.60 A= 5.40					
PM EMISSIONS					
UNC= 0.807 CTR= 0.100 EFF= 87.60 CRF= 0.1315					
S02 EMISSIONS					
UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0					
COST RATES					
ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80					
COST SUMMARY TABLE - RUN NO. 4					
ITEM	BOILER	NOX CONTROL	S02 CONTROL	PM CONTROL	TOTAL
EQUIP	713439.	0.	0.	52916.	766355.
INST	630975.	0.	0.	32639.	663613.
TD	1344413.	0.	0.	85554.	1429967.
IND	437820.	0.	0.	30027.	467847.
TDI	1782233.	0.	0.	115581.	1897814.
CONT	356447.	0.	0.	23116.	379563.
TK	2138679.	0.	0.	138697.	2277376.
LAND	2000.	0.	0.	0.	2000.
WC	103737.	0.	0.	6471.	110208.
TOTL	2244416.	0.	0.	145168.	2389584.
DL	90863.	0.	0.	9998.	100860.
SPRV	44001.	0.	0.	0.	44001.
MANT	41173.	0.	0.	7657.	48830.
SP	65485.	0.	0.	0.	65485.
ELEC	0.	0.	0.	0.	0.
UC	35718.	0.	0.	7393.	43111.
WTR	0.	0.	0.	0.	0.
SW	11092.	0.	0.	836.	11928.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	380009.	0.	0.	0.	380009.
TDOM	668339.	0.	0.	25884.	694223.
OH	90054.	0.	0.	7589.	97644.
TOTL	758393.	0.	0.	33473.	791867.
CR	281236.	0.	0.	18239.	299475.
WCC	10374.	0.	0.	647.	11021.
MISC	85547.	0.	0.	5548.	91095.
TCC	377157.	0.	0.	24434.	401591.
TOTL	1135550.	0.	0.	57907.	1193457.

LSC-30-Unc, FF

MODEL BOILER	5	4-06-82			
BOILER ROUTINE	UNDR	S02 ROUTINE=	PM ROUTINE=	FF	FLOW FLAG=
1					
<b>BOILER SPECIFICATIONS</b>					
Q= 30.0 FLW= 11334. CF= 0.600 CRF= 0.1315					
<b>FUEL SPECIFICATIONS</b>					
FC= 2.41 H= 9600. S= 0.60 A= 5.40					
<b>PM EMISSIONS</b>					
UNC= 0.807 CTR= 0.050 EFF= 93.80 CRF= 0.1315					
<b>S02 EMISSIONS</b>					
UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0					
<b>COST RATES</b>					
ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80					
<b>COST SUMMARY TABLE - RUN NO. 5</b>					
ITEM	BOILER	NOX CONTROL	S02 CONTROL	PM CONTROL	TOTAL
EQUIP	713439.	0.	0.	68816.	782255.
INST	630975.	0.	0.	66805.	697780.
TD	1344413.	0.	0.	135621.	1480034.
IND	437820.	0.	0.	53261.	491081.
TDI	1782233.	0.	0.	188882.	1971115.
CONT	356447.	0.	0.	37776.	394223.
TK	2138679.	0.	0.	226659.	2365337.
LAND	2000.	0.	0.	0.	2000.
WC	103737.	0.	0.	7642.	111379.
 TOTAL	 2244416.	 0.	 0.	 234300.	 2478716.
DL	90863.	0.	0.	9998.	100860.
SPRV	44001.	0.	0.	0.	44001.
MANT	41173.	0.	0.	11202.	52374.
SP	65485.	0.	0.	3064.	68548.
ELEC	0.	0.	0.	0.	0.
UC	35718.	0.	0.	5408.	41126.
WTR	0.	0.	0.	0.	0.
SW	11092.	0.	0.	895.	11987.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	380009.	0.	0.	0.	380009.
TDOM	668339.	0.	0.	30566.	698905.
OH	90054.	0.	0.	9308.	99362.
TOTAL	758393.	0.	0.	39874.	798267.
CR	281236.	0.	0.	29806.	311042.
WCC	10374.	0.	0.	764.	11138.
MISC	85547.	0.	0.	9066.	94613.
TCC	377157.	0.	0.	39636.	416793.
TOTAL	1135550.	0.	0.	79510.	1215059.

LSC-30-DS(50), DS/PM

MODEL BOILER 6  
 BOILER ROUTINE UNDR SO2 ROUTINE= DS PM ROUTINE= FLOW FLAG= 1

S STAR (METRIC) = 0.134  
 S DSTAR (METRIC) = 4.252  
**BOILER SPECIFICATIONS**  
 Q= 30.0 FLW= 11334. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
**PM EMISSIONS**  
 UNC= 0.807 CTR= 0.100 EFF= 87.60 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= 1.190 CTR= 0.595 EFF= 50.00 CRF= 0.1315

**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

**COST SUMMARY TABLE - RUN NO. 6**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	713439.	0.	0.	0.	713439.
INST	630975.	0.	0.	0.	630975.
TD	1344413.	0.	317561.	0.	1661974.
IND	437820.	0.	0.	0.	437820.
TDI	1782233.	0.	0.	0.	1782233.
CONT	356447.	0.	0.	0.	356447.
TK	2138679.	0.	580391.	0.	2719069.
LAND	2000.	0.	0.	0.	2000.
WC	103737.	0.	41344.	0.	145082.
TOTL	2244416.	0.	621735.	0.	2866151.
DL	90863.	0.	105000.	0.	195863.
SPRV	44001.	0.	21000.	0.	65001.
MANT	41173.	0.	31556.	0.	72729.
SP	65485.	0.	0.	0.	65485.
ELEC	0.	0.	3294.	0.	3294.
UC	35718.	0.	0.	0.	35718.
WTR	0.	0.	160.	0.	160.
SW	11092.	0.	2597.	0.	13688.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	1770.	0.	1770.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	380009.	0.	0.	0.	380009.
TDOM	668339.	0.	165377.	0.	833716.
OH	90054.	0.	72465.	0.	162519.
TOTL	758393.	0.	237842.	0.	996235.
CR	281236.	0.	76321.	0.	357558.
WCC	10374.	0.	4134.	0.	14508.
MISC	85547.	0.	23216.	0.	108763.
TCC	377157.	0.	103671.	0.	480828.
TOTL	1135550.	0.	341513.	0.	1477063.

LSC-30-DA(50), DA/PM

MODEL BOILER 7	4-06-82				
BOILER ROUTINE UNDR	S02 ROUTINE= DAC	PM ROUTINE=		FLOW FLAG= 1	
 S STAR (METRIC)= 0.134					
S DSTAR (METRIC)= 4.252					
P DSTAR (METRIC)= 10.465					
BOILER SPECIFICATIONS					
Q= 30.0 FLW= 11334. CF= 0.600 CRF= 0.1315					
FUEL SPECIFICATIONS					
FC= 2.41 H= 9600. S= 0.60 A= 5.40					
PM EMISSIONS					
UNC= 0.807 CTR= 0.100 EFF= 87.60 CRF= 0.1315					
S02 EMISSIONS					
UNC= 1.190 CTR= 0.595 EFF= 50.00 CRF= 0.1315					
COST RATES					
ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80					
COST SUMMARY TABLE - RUN NO. 7					
ITEM	BOILER	NOX CONTROL	S02 CONTROL	PM CONTROL	TOTAL
EQUIP	713439.	0.	0.	0.	713439.
INST	630975.	0.	0.	0.	630975.
TD	1344413.	0.	375726.	0.	1720139.
IND	437820.	0.	0.	0.	437820.
TDI	1782233.	0.	0.	0.	1782233.
CONT	356447.	0.	0.	0.	356447.
TK	2138679.	0.	649675.	0.	2788353.
LAND	2000.	0.	0.	0.	2000.
WC	103737.	0.	41417.	0.	145155.
TOTL	2244416.	0.	691092.	0.	2935508.
DL	90863.	0.	105000.	0.	195863.
SPRV	44001.	0.	21000.	0.	65001.
MANT	41173.	0.	30058.	0.	71231.
SP	65485.	0.	0.	0.	65485.
ELEC	0.	0.	3888.	0.	3888.
UC	35718.	0.	0.	0.	35718.
WTR	0.	0.	214.	0.	214.
SW	11092.	0.	0.	0.	11092.
 SLDG	0.	0.	3472.	0.	3472.
LW	0.	0.	0.	0.	0.
SC	0.	0.	822.	0.	822.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	1215.	0.	1215.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	380009.	0.	0.	0.	380009.
TDOM	668339.	0.	165669.	0.	834008.
OH	90054.	0.	72075.	0.	162129.
TOTL	758393.	0.	237744.	0.	996138.
CR	281236.	0.	85432.	0.	366668.
WCC	10374.	0.	4142.	0.	14515.
MISC	85547.	0.	25987.	0.	111534.
TCC	377157.	0.	115561.	0.	492718.
TOTL	1135550.	0.	353305.	0.	1488854.

LSC-30-DA(50), FF

MODEL BOILER 8  
 BOILER ROUTINE UNDR SO2 ROUTINE= DA 4-06-82 PM ROUTINE= FF FLOW FLAG= 1

S STAR (METRIC)= 0.134  
 S DSTAR (METRIC)= 4.252  
 BOILER SPECIFICATIONS  
 Q= 30.0 FLW= 11334. CF= 0.600 CRF= 0.1315  
 FUEL SPECIFICATIONS  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
 PM EMISSIONS  
 UNC= 0.807 CTR= 0.050 EFF= 93.80 CRF= 0.1315  
 SO2 EMISSIONS  
 UNC= 1.190 CTR= 0.595 EFF= 50.00 CRF= 0.1315  
 COST RATES  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 8

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	713439.	0.	0.	68816.	782255.
INST	630975.	0.	0.	66805.	697780.
TD	1344413.	0.	271887.	135621.	1751921.
IND	437820.	0.	0.	53261.	491081.
TDI	1782233.	0.	0.	188882.	1971115.
CONT	356447.	0.	0.	37776.	394223.
TK	2138679.	0.	495993.	226659.	2861330.
LAND	2000.	0.	0.	0.	2000.
WC	103737.	0.	38609.	7642.	149988.
TOTL	2244416.	0.	534602.	234300.	3013318.
DL	90863.	0.	105000.	9998.	205860.
SPRV	44001.	0.	21000.	0.	65001.
MANT	41173.	0.	21751.	11202.	74125.
SP	65485.	0.	0.	3064.	68548.
ELEC	0.	0.	1871.	0.	1871.
UC	35718.	0.	0.	5408.	41126.
WTR	0.	0.	214.	0.	214.
SW	11092.	0.	0.	895.	11987.
SLDG	0.	0.	2564.	0.	2564.
LW	0.	0.	0.	0.	0.
SC	0.	0.	822.	0.	822.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	1215.	0.	1215.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	380009.	0.	0.	0.	380009.
TDOM	668339.	0.	154436.	30566.	853341.
OH	90054.	0.	69915.	9308.	169277.
TOTL	758393.	0.	224351.	39874.	1022618.
CR	281236.	0.	65223.	29806.	376265.
WCC	10374.	0.	3861.	764.	14999.
MISC	85547.	0.	19840.	9066.	114453.
TCC	377157.	0.	88924.	39636.	505717.
TOTL	1135550.	0.	313275.	79510.	1528333.

LSC-30-DA(90), DA/PM

MODEL BOILER 9                          4-06-82  
 BOILER ROUTINE UNDR    SO2 ROUTINE= DAC                          PM ROUTINE=                          FLOW FLAG= 1

S STAR (METRIC)= 0.242  
 S DSTAR (METRIC)= 7.654  
 P DSTAR (METRIC)= 10.465

BOILER SPECIFICATIONS

Q= 30.0 FLW= 11334. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 2.41 H= 9600. S= 0.60 A= 5.40

PM EMISSIONS

UNC= 0.807 CTR= 0.100 EFF= 87.60 CRF= 0.1315

SO2 EMISSIONS

UNC= 1.190 CTR= 0.119 EFF= 90.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 9

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	713439.	0.	0.	0.	713439.
INST	630975.	0.	0.	0.	630975.
TD	1344413.	0.	411402.	0.	1755814.
IND	437820.	0.	0.	0.	437820.
TDI	1782233.	0.	0.	0.	1782233.
CONT	356447.	0.	0.	0.	356447.
TK	2138679.	0.	702474.	0.	2841153.
LAND	2000.	0.	0.	0.	2000.
WC	103737.	0.	43006.	0.	146743.
TOTL	2244416.	0.	745480.	0.	2989895.
DL	90863.	0.	105000.	0.	195863.
SPRV	44001.	0.	21000.	0.	65001.
MANT	41173.	0.	32912.	0.	74085.
SF	65485.	0.	0.	0.	65485.
ELEC	0.	0.	3946.	0.	3946.
UC	35718.	0.	0.	0.	35718.
WTR	0.	0.	233.	0.	233.
SW	11092.	0.	0.	0.	11092.
SLDG	0.	0.	5755.	0.	5755.
LW	0.	0.	0.	0.	0.
SC	0.	0.	851.	0.	851.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	2324.	0.	2324.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	380009.	0.	0.	0.	380009.
TDOM	668339.	0.	172022.	0.	840361.
OH	90054.	0.	72817.	0.	162871.
TOTL	758393.	0.	244839.	0.	1003233.
CR	281236.	0.	92375.	0.	373612.
WCC	10374.	0.	4301.	0.	14674.
MISC	85547.	0.	28099.	0.	113646.
TCC	377157.	0.	124775.	0.	501932.
TOTL	1135550.	0.	369614.	0.	1505164.

LSC-30-DA(90), FF

MODEL BOILER 10                          4-06-82  
 BOILER ROUTINE UNDR    SO2 ROUTINE= DA                          PM ROUTINE= FF                          FLOW FLAG= 1

S STAR (METRIC)= 0.242  
 S DSTAR (METRIC)= 7.654  
**BOILER SPECIFICATIONS**  
 Q= 30.0 FLW= 11334. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
**PM EMISSIONS**  
 UNC= 0.807 CTR= 0.050 EFF= 93.80 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= 1.190 CTR= 0.119 EFF= 90.00 CRF= 0.1315  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 10

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	713439.	0.	0.	68816.	782255.
INST	630975.	0.	0.	66805.	697780.
TD	1344413.	0.	309545.	135621.	1789579.
IND	437820.	0.	0.	53261.	491081.
TDI	1782233.	0.	0.	188882.	1971115.
CONT	356447.	0.	0.	37776.	394223.
TK	2138679.	0.	551727.	226659.	2917063.
LAND	2000.	0.	0.	0.	2000.
WC	103737.	0.	40229.	7642.	151608.
TOTL	2244416.	0.	591956.	234300.	3070672.
DL	90863.	0.	105000.	9998.	205860.
SPRV	44001.	0.	21000.	0.	65001.
MANT	41173.	0.	24764.	11202.	77138.
SP	65485.	0.	0.	3064.	68548.
ELEC	0.	0.	1899.	0.	1899.
UC	35718.	0.	0.	5408.	41126.
WTR	0.	0.	233.	0.	233.
SW	11092.	0.	0.	895.	11987.
SLDG	0.	0.	4847.	0.	4847.
LW	0.	0.	0.	0.	0.
SC	0.	0.	851.	0.	851.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	2324.	0.	2324.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	380009.	0.	0.	0.	380009.
TDOM	668339.	0.	160918.	30566.	859823.
OH	90054.	0.	70699.	9308.	170060.
TOTL	758393.	0.	231616.	39874.	1029883.
CR	281236.	0.	72552.	29806.	383594.
WCC	10374.	0.	4023.	764.	15161.
MISC	85547.	0.	22069.	9066.	116683.
TCC	377157.	0.	98644.	39636.	515437.
TOTL	1135550.	0.	330260.	79510.	1545319.

LSC-75-Unc, Unc

MODEL BOILER 11                          4-06-82  
 BOILER ROUTINE UNDR    SO2 ROUTINE=                          PM ROUTINE=                          FLOW FLAG=    1

BOILER SPECIFICATIONS

Q= 75.0 FLW= 28334. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 2.41 H= 9600. S= 0.60 A= 5.40

PM EMISSIONS

UNC=                  CTR=                  EFF=                  CRF=

SO2 EMISSIONS

UNC=                  CTR=                  EFF=                  CRF=

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 11

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1274262.	0.	0.	0.	1274262.
INST	1153531.	0.	0.	0.	1153531.
TD	2427793.	0.	0.	0.	2427793.
IND	791344.	0.	0.	0.	791344.
TDI	3219136.	0.	0.	0.	3219136.
CONT	643827.	0.	0.	0.	643827.
TK	3862963.	0.	0.	0.	3862963.
LAND	2000.	0.	0.	0.	2000.
WC	213998.	0.	0.	0.	213998.
TOTL	4078960.	0.	0.	0.	4078960.
DL	110903.	0.	0.	0.	110903.
SPRV	125519.	0.	0.	0.	125519.
MANT	117640.	0.	0.	0.	117640.
SP	105430.	0.	0.	0.	105430.
ELEC	0.	0.	0.	0.	0.
UC	52224.	0.	0.	0.	52224.
WTR	0.	0.	0.	0.	0.
SW	27729.	0.	0.	0.	27729.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	950022.	0.	0.	0.	950022.
TDOM	1489466.	0.	0.	0.	1489466.
OH	152739.	0.	0.	0.	152739.
TOTL	1642204.	0.	0.	0.	1642204.
CR	507980.	0.	0.	0.	507980.
WCC	21400.	0.	0.	0.	21400.
MISC	154519.	0.	0.	0.	154519.
TCC	683898.	0.	0.	0.	683898.
TOTL	2326101.	0.	0.	0.	2326101.

LSC-75-Unc, SM

MODEL BOILER 12  
BOILER ROUTINE UNDR

SO2 ROUTINE=

4-06-82

PM ROUTINE= SM

FLOW FLAG= 1

**BOILER SPECIFICATIONS**

Q= 75.0 FLW= 28334. CF= 0.600 CRF= 0.1315

**FUEL SPECIFICATIONS**

FC= 2.41 H= 9600. S= 0.60 A= 5.40

**PM EMISSIONS**

UNC= 0.807 CTR= 0.400 EFF= 50.00 CRF= 0.1315

**SO2 EMISSIONS**

UNC= CTR= EFF= CRF=

**COST RATES**

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

**COST SUMMARY TABLE - RUN NO. 12**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1274262.	0.	0.	72366.	1346627.
INST	1153531.	0.	0.	0.	1153531.
TD	2427793.	0.	0.	72366.	2500158.
IND	791344.	0.	0.	24122.	815466.
TDI	3219136.	0.	0.	96488.	3315623.
CONT	643827.	0.	0.	19298.	663125.
TK	3862963.	0.	0.	115785.	3978748.
LAND	2000.	0.	0.	0.	2000.
WC	213998.	0.	0.	5036.	219033.
TOTL	4078960.	0.	0.	120821.	4199780.
DL	110903.	0.	0.	6788.	117690.
SPRV	125519.	0.	0.	1018.	126538.
MANT	117640.	0.	0.	5789.	123428.
SP	105430.	0.	0.	482.	105913.
ELEC	0.	0.	0.	4862.	4862.
UC	52224.	0.	0.	0.	52224.
WTR	0.	0.	0.	0.	0.
SW	27729.	0.	0.	1203.	28932.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	950022.	0.	0.	0.	950022.
TDOM	1489466.	0.	0.	20142.	1509608.
OH	152739.	0.	0.	5696.	158435.
TOTL	1642204.	0.	0.	25838.	1668042.
CR	507980.	0.	0.	15226.	523205.
WCC	21400.	0.	0.	504.	21903.
MISC	154519.	0.	0.	4631.	159150.
TCC	683898.	0.	0.	20361.	704259.
TOTL	2326101.	0.	0.	46199.	2372300.

LSC-75-Unc, SSS

MODEL BOILER 13	4-06-82				
BOILER ROUTINE UNDR	SO2 ROUTINE=	PM ROUTINE= SSS	FLOW FLAG=	1	
<b>BOILER SPECIFICATIONS</b>					
Q= 75.0 FLW= 28334. CF= 0.600 CRF= 0.1315					
<b>FUEL SPECIFICATIONS</b>					
FC= 2.41 H= 9600. S= 0.60 A= 5.40					
<b>PM EMISSIONS</b>					
UNC= 0.807 CTR= 0.200 EFF= 75.20 CRF= 0.1315					
<b>SO2 EMISSIONS</b>					
UNC= CTR= EFF= CRF=					
<b>COST RATES</b>					
ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWB= 1.80					
<b>COST SUMMARY TABLE - RUN NO. 13</b>					
ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1274262.	0.	0.	131667.	1405928.
INST	1153531.	0.	0.	0.	1153531.
TD	2427793.	0.	0.	131667.	2559459.
IND	791344.	0.	0.	43889.	835233.
TDI	3219136.	0.	0.	175556.	3394691.
CONT	643827.	0.	0.	35111.	678938.
TK	3862963.	0.	0.	210667.	4073629.
LAND	2000.	0.	0.	0.	2000.
WC	213998.	0.	0.	7722.	221720.
TOTL	4078960.	0.	0.	218389.	4297349.
DL	110903.	0.	0.	9502.	120405.
SPRV	125519.	0.	0.	1425.	126945.
MANT	117640.	0.	0.	9627.	127266.
SP	105430.	0.	0.	878.	106308.
ELEC	0.	0.	0.	7662.	7662.
UC	52224.	0.	0.	0.	52224.
WTR	0.	0.	0.	0.	0.
SW	27729.	0.	0.	1795.	29523.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	950022.	0.	0.	0.	950022.
TDOM	1489466.	0.	0.	30889.	1520355.
OH	152739.	0.	0.	8423.	161162.
TOTL	1642204.	0.	0.	39313.	1681516.
CR	507980.	0.	0.	27703.	535682.
WCC	21400.	0.	0.	772.	22172.
MISC	154519.	0.	0.	8427.	162945.
TCC	683898.	0.	0.	36902.	720799.
TOTL	2326101.	0.	0.	76214.	2402315.

LSC-75-Unc, VS

MODEL BOILER 14	4-06-82				
BOILER ROUTINE UNDR	S02 ROUTINE=	PM ROUTINE= VS	FLOW FLAG=	1	
<b>BOILER SPECIFICATIONS</b>					
Q= 75.0 FLW= 28334. CF= 0.600 CRF= 0.1315					
<b>FUEL SPECIFICATIONS</b>					
FC= 2.41 H= 9600. S= 0.60 A= 5.40					
<b>PM EMISSIONS</b>					
UNC= 0.807 CTR= 0.100 EFF= 87.60 CRF= 0.1315					
<b>S02 EMISSIONS</b>					
UNC= CTR= EFF= CRF=					
<b>COST RATES</b>					
ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80					
<b>COST SUMMARY TABLE - RUN NO. 14</b>					
ITEM	BOILER	NOX CONTROL	S02 CONTROL	PM CONTROL	TOTAL
EQUIP	1274262.	0.	0.	91915.	1366177.
INST	1153531.	0.	0.	60741.	1214271.
TD	2427793.	0.	0.	152656.	2580449.
IND	791344.	0.	0.	51873.	843217.
TDI	3219136.	0.	0.	204529.	3423664.
CONT	643827.	0.	0.	40906.	684733.
TK	3862963.	0.	0.	245434.	4108397.
LAND	2000.	0.	0.	0.	2000.
WC	213998.	0.	0.	11371.	225369.
TOTL	4078960.	0.	0.	256805.	4335765.
DL	110903.	0.	0.	13575.	124478.
SPRV	125519.	0.	0.	0.	125519.
MANT	117640.	0.	0.	12355.	129994.
SP	105430.	0.	0.	0.	105430.
ELEC	0.	0.	0.	0.	0.
UC	52224.	0.	0.	17463.	69686.
WTR	0.	0.	0.	0.	0.
SW	27729.	0.	0.	2090.	29819.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	950022.	0.	0.	0.	950022.
TDOM	1489466.	0.	0.	45483.	1534948.
OH	152739.	0.	0.	10814.	163553.
TOTL	1642204.	0.	0.	56297.	1698501.
CR	507980.	0.	0.	32275.	540254.
WCC	21400.	0.	0.	1137.	22537.
MISC	154519.	0.	0.	9817.	164336.
TCC	683898.	0.	0.	43229.	727127.
TOTL	2326101.	0.	0.	99526.	2425627.

LSC-75-Unc, FF

MODEL BOILER 15                          4-06-82  
 BOILER ROUTINE UNDR    SO2 ROUTINE=                          PM ROUTINE= FF                          FLOW FLAG= 1

BOILER SPECIFICATIONS

Q= 75.0 FLW= 28334. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 2.41 H= 9600. S= 0.60 A= 5.40  
 PM EMISSIONS

UNC= 0.807 CTR= 0.050 EFF= 93.80 CRF= 0.1315

SO2 EMISSIONS

UNC= CTR= EFF= CRF=

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 15

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1274262.	0.	0.	166764.	1441026.
INST	1153531.	0.	0.	221228.	1374759.
TD	2427793.	0.	0.	387992.	2815785.
IND	791344.	0.	0.	113010.	904354.
TDI	3219136.	0.	0.	501002.	3720137.
CONT	643827.	0.	0.	100200.	744027.
TK	3862963.	0.	0.	601202.	4464165.
LAND	2000.	0.	0.	0.	2000.
WC	213998.	0.	0.	11995.	225993.
TOTL	4078960.	0.	0.	613197.	4692156.
DL	110903.	0.	0.	13575.	124478.
SPRV	125519.	0.	0.	0.	125519.
MANT	117640.	0.	0.	11577.	129217.
SP	105430.	0.	0.	7638.	113069.
ELEC	0.	0.	0.	0.	0.
UC	52224.	0.	0.	12951.	65174.
WTR	0.	0.	0.	0.	0.
SW	27729.	0.	0.	2238.	29967.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	950022.	0.	0.	0.	950022.
TDOM	1489466.	0.	0.	47979.	1537445.
OH	152739.	0.	0.	12598.	165337.
TOTL	1642204.	0.	0.	60577.	1702781.
CR	507980.	0.	0.	79058.	587038.
WCC	21400.	0.	0.	1199.	22599.
MISC	154519.	0.	0.	24048.	178567.
TCC	683898.	0.	0.	104306.	788203.
TOTL	2326101.	0.	0.	164883.	2490983.

LSC-75-DS(50), DS/PM

MODEL BOILER 16  
 BOILER ROUTINE UNDR SO2 ROUTINE= DS PM ROUTINE= FLOW FLAG= 1

S STAR (METRIC) = 0.134  
 S DSTAR (METRIC) = 10.630

BOILER SPECIFICATIONS

Q= 75.0 FLW= 28334. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 2.41 H= 9600. S= 0.60 A= 5.40

PM EMISSIONS

UNC= 0.807 CTR= 0.100 EFF= 87.60 CRF= 0.1315

SO2 EMISSIONS

UNC= 1.190 CTR= 0.595 EFF= 50.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 16

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1274262.	0.	0.	0.	1274262.
INST	1153531.	0.	0.	0.	1153531.
TD	2427793.	0.	599363.	0.	3027156.
IND	791344.	0.	0.	0.	791344.
TDI	3219136.	0.	0.	0.	3219136.
CONT	643827.	0.	0.	0.	643827.
TK	3862963.	0.	997458.	0.	4860420.
LAND	2000.	0.	0.	0.	2000.
WC	213998.	0.	47136.	0.	261134.
TOTL	4078960.	0.	1044594.	0.	5123553.
DL	110903.	0.	105000.	0.	215903.
SPRV	125519.	0.	21000.	0.	146519.
MANT	117640.	0.	44246.	0.	161985.
SP	105430.	0.	0.	0.	105430.
ELEC	0.	0.	6982.	0.	6982.
UC	52224.	0.	0.	0.	52224.
WTR	0.	0.	401.	0.	401.
SW	27729.	0.	6492.	0.	34221.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	4425.	0.	4425.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	950022.	0.	0.	0.	950022.
TDOM	1489466.	0.	188546.	0.	1678011.
OH	152739.	0.	75764.	0.	228503.
TOTL	1642204.	0.	264310.	0.	1906513.
CR	507980.	0.	131166.	0.	639145.
WCC	21400.	0.	4714.	0.	26113.
MISC	154519.	0.	39898.	0.	194417.
TCC	683898.	0.	175778.	0.	859675.
TOTL	2326101.	0.	440087.	0.	2766188.

LSC-75-DA(50), DA/PM

MODEL BOILER 17                          4-06-82  
 BOILER ROUTINE UNDR    SO2 ROUTINE= DAC    PM ROUTINE=    FLOW FLAG= 1

S STAR (METRIC)= 0.134  
 S DSTAR (METRIC)= 10.630  
 P DSTAR (METRIC)= 26.163  
**BOILER SPECIFICATIONS**  
 Q= 75.0 FLW= 28334. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
**PM EMISSIONS**  
 UNC= 0.807 CTR= 0.100 EFF= 87.60 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= 1.190 CTR= 0.595 EFF= 50.00 CRF= 0.1315  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 17

---

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1274262.	0.	0.	0.	1274262.
INST	1153531.	0.	0.	0.	1153531.
TD	2427793.	0.	549173.	0.	2976965.
IND	791344.	0.	0.	0.	791344.
TDI	3219136.	0.	0.	0.	3219136.
CONT	643827.	0.	0.	0.	643827.
TK	3862963.	0.	906376.	0.	4769338.
LAND	2000.	0.	0.	0.	2000.
WC	213998.	0.	48805.	0.	262803.
TOTL	4078960.	0.	955181.	0.	5034141.
DL	110903.	0.	105000.	0.	215903.
SPRV	125519.	0.	21000.	0.	146519.
MANT	117640.	0.	43934.	0.	161573.
SP	105430.	0.	0.	0.	105430.
ELEC	0.	0.	9721.	0.	9721.
UC	52224.	0.	0.	0.	52224.
WTR	0.	0.	463.	0.	463.
SW	27729.	0.	0.	0.	27729.
SLDG	0.	0.	9116.	0.	9116.
LW	0.	0.	0.	0.	0.
SC	0.	0.	2693.	0.	2693.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	3295.	0.	3295.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	950022.	0.	0.	0.	950022.
TDOM	1489466.	0.	195221.	0.	1684687.
OH	152739.	0.	75683.	0.	228422.
TOTL	1642204.	0.	270904.	0.	1913108.
CR	507980.	0.	119188.	0.	627168.
WCC	21400.	0.	4881.	0.	26280.
MISC	154519.	0.	36255.	0.	190774.
TCC	583898.	0.	160324.	0.	844222.
TOTL	2326101.	0.	431228.	0.	2757329.

## LSC-75-DA(50), FF

MODEL BOILER 18  
BOILER ROUTINE UNDR

SO2 ROUTINE= DA

4-06-82

PM ROUTINE= FF

FLOW FLAG= 1

S STAR (METRIC)= 0.134  
 S DSTAR (METRIC)= 10.630  
**BOILER SPECIFICATIONS**  
 Q= 75.0 FLW= 28334. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
**PM EMISSIONS**  
 UNC= 0.807 CTR= 0.050 EFF= 93.80 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= 1.190 CTR= 0.595 EFF= 50.00 CRF= 0.1315  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

## COST SUMMARY TABLE - RUN NO. 18

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1274262.	0.	0.	166764.	1441026.
INST	1153531.	0.	0.	221228.	1374759.
TD	2427793.	0.	428814.	387992.	3244598.
IND	791344.	0.	0.	113010.	904354.
TDI	3219136.	0.	0.	501002.	3720137.
CONT	643827.	0.	0.	100200.	744027.
TK	3862963.	0.	728244.	601202.	5192408.
LAND	2000.	0.	0.	0.	2000.
WC	213998.	0.	44569.	11995.	270562.
TOTL	4078960.	0.	772813.	613197.	5464969.
DL	110903.	0.	105000.	13575.	229478.
SPRV	125519.	0.	21000.	0.	146519.
MANT	117640.	0.	34305.	11577.	163522.
SP	105430.	0.	0.	7638.	113069.
ELEC	0.	0.	4677.	0.	4677.
UC	52224.	0.	0.	12951.	65174.
WTR	0.	0.	463.	0.	463.
SW	27729.	0.	0.	2238.	29967.
SLDG	0.	0.	6844.	0.	6844.
LW	0.	0.	0.	0.	0.
SC	0.	0.	2693.	0.	2693.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	3295.	0.	3295.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	950022.	0.	0.	0.	950022.
TDOM	1489466.	0.	178278.	47979.	1715722.
OH	152739.	0.	73179.	12598.	238516.
TOTL	1642204.	0.	251457.	60577.	1954238.
CR	507980.	0.	95764.	79058.	682802.
WCC	21400.	0.	4457.	1199.	27056.
MISC	154519.	0.	29130.	24048.	207696.
TCC	683898.	0.	129351.	104306.	917554.
TOTL	2326101.	0.	380808.	164883.	2871790.

LSC-75-DA(90), DA/PM

MODEL BOILER 19                          4-06-82  
 BOILER ROUTINE UNDR    SO2 ROUTINE= DAC                          PM ROUTINE=                          FLOW FLAG=    1

S STAR (METRIC)=    0.242  
 S DSTAR (METRIC)=    19.134  
 P DSTAR (METRIC)=    26.163  
**BOILER SPECIFICATIONS**  
 Q=    75.0 FLW= 28334. CF=    0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC=    2.41 H=    9600. S=    0.60 A=    5.40  
**PM EMISSIONS**  
 UNC=    0.807 CTR= 0.100 EFF=    87.60 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC=    1.190 CTR= 0.119 EFF=    90.00 CRF= 0.1315  
**COST RATES**  
 ELEC= 0.0258 WTR=    0.15 LIME= 35.00 ALS=    8.00 SASH= 90.00 SLDG= 15.00 SWD=    15.00 ALWD=    1.80

**COST SUMMARY TABLE - RUN NO. 19**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	1274262.	0.	0.	0.	1274262.
INST	1153531.	0.	0.	0.	1153531.
TD	2427793.	0.	595733.	0.	3023525.
IND	791344.	0.	0.	0.	791344.
TDI	3219136.	0.	0.	0.	3219136.
CONT	643827.	0.	0.	0.	643827.
TK	3862963.	0.	975284.	0.	4838247.
LAND	2000.	0.	0.	0.	2000.
WC	213998.	0.	51927.	0.	265925.
TOTL	4078960.	0.	1027212.	0.	5106171.
DL	110903.	0.	105000.	0.	215903.
SPRV	125519.	0.	21000.	0.	146519.
MANT	117640.	0.	47659.	0.	165298.
SP	105430.	0.	0.	0.	105430.
ELEC	0.	0.	9865.	0.	9865.
UC	52224.	0.	0.	0.	52224.
WTR	0.	0.	506.	0.	506.
SW	27729.	0.	0.	0.	27729.
SLDG	0.	0.	14824.	0.	14824.
LW	0.	0.	0.	0.	0.
SC	0.	0.	2788.	0.	2788.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	6069.	0.	6069.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	950022.	0.	0.	0.	950022.
TDOM	1489466.	0.	207710.	0.	1697175.
OH	152739.	0.	76651.	0.	229390.
TOTL	1642204.	0.	284361.	0.	1926564.
CR	507980.	0.	128250.	0.	636230.
WCC	21400.	0.	5193.	0.	26593.
MISC	154519.	0.	39011.	0.	193530.
TCC	683898.	0.	172454.	0.	856352.
TOTL	2326101.	0.	456815.	0.	2782915.

## LSC-75-DA(90), FF

MODEL BOILER 20  
 BOILER ROUTINE UNDR SO2 ROUTINE= DA PM ROUTINE= FF FLOW FLAG= 1

S STAR (METRIC)= 0.242  
 S DSTAR (METRIC)= 19.134  
**BOILER SPECIFICATIONS**  
 Q= 75.0 FLW= 28334. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
**PM EMISSIONS**  
 UNC= 0.807 CTR= 0.050 EFF= 93.80 CRF= 0.1315

**SO2 EMISSIONS**  
 UNC= 1.190 CTR= 0.119 EFF= 90.00 CRF= 0.1315  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

**COST SUMMARY TABLE - RUN NO. 20**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	1274262.	0.	0.	166764.	1441026.
INST	1153531.	0.	0.	221228.	1374759.
TD	2427793.	0.	482647.	387992.	3298432.
IND	791344.	0.	0.	113010.	904354.
TDI	3219136.	0.	0.	501002.	3720137.
CONT	643827.	0.	0.	100200.	744027.
TK	3862963.	0.	807917.	601202.	5272082.
LAND	2000.	0.	0.	0.	2000.
WC	213998.	0.	47818.	11995.	273811.
TOTL	4078960.	0.	855736.	613197.	5547891.
DL	110903.	0.	105000.	13575.	229478.
SPRV	125519.	0.	21000.	0.	146519.
MANT	117640.	0.	38612.	11577.	167828.
SP	105430.	0.	0.	7638.	113069.
ELEC	0.	0.	4747.	0.	4747.
UC	52224.	0.	0.	12951.	65174.
WTR	0.	0.	506.	0.	506.
SW	27729.	0.	0.	2238.	29967.
SLDG	0.	0.	12552.	0.	12552.
LW	0.	0.	0.	0.	0.
SC	0.	0.	2788.	0.	2788.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	6069.	0.	6069.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	950022.	0.	0.	0.	950022.
TDOM	1489466.	0.	191273.	47979.	1728718.
OH	152739.	0.	74299.	12598.	239636.
TOTL	1642204.	0.	265572.	60577.	1968353.
CR	507980.	0.	106241.	79058.	693279.
WCC	21400.	0.	4782.	1199.	27381.
MISC	154519.	0.	32317.	24048.	210883.
TCC	683898.	0.	143340.	104306.	931543.
TOTL	2326101.	0.	408912.	164883.	2899894.

LSC-150-Unc, Unc

MODEL BOILER 21  
 BOILER ROUTINE SPRD SO2 ROUTINE= 4-06-82 PM ROUTINE= FLOW FLAG= 1

BOILER SPECIFICATIONS  
 Q= 150.0 FLW= 56669. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40

PM EMISSIONS  
 UNC= CTR= EFF= CRF=

SO2 EMISSIONS  
 UNC= CTR= EFF= CRF=

COST RATES  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 21

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2732516.	0.	0.	0.	2732516.
INST	2327704.	0.	0.	0.	2327704.
TD	5060220.	0.	0.	0.	5060220.
IND	1629384.	0.	0.	0.	1629384.
TDI	6689604.	0.	0.	0.	6689604.
CONT	1337920.	0.	0.	0.	1337920.
TK	8027524.	0.	0.	0.	8027524.
LAND	2000.	0.	0.	0.	2000.
WC	304323.	0.	0.	0.	304323.
TOTL	8333846.	0.	0.	0.	8333846.
DL	186128.	0.	0.	0.	186128.
SPRV	78752.	0.	0.	0.	78752.
MANT	85796.	0.	0.	0.	85796.
SP	153400.	0.	0.	0.	153400.
ELEC	0.	0.	0.	0.	0.
UC	69844.	0.	0.	0.	69844.
WTR	0.	0.	0.	0.	0.
SW	10276.	0.	0.	0.	10276.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1900043.	0.	0.	0.	1900043.
TDOM	2484239.	0.	0.	0.	2484239.
OH	186898.	0.	0.	0.	186898.
TOTL	2671136.	0.	0.	0.	2671136.
CR	1055619.	0.	0.	0.	1055619.
WCC	30432.	0.	0.	0.	30432.
MISC	321101.	0.	0.	0.	321101.
TCC	1407151.	0.	0.	0.	1407151.
TOTL	4078287.	0.	0.	0.	4078287.

LSC-150-Unc, SM

MODEL BOILER 22  
 BOILER ROUTINE SPRD SO2 ROUTINE= 4-06-82 PM ROUTINE= SM FLOW FLAG= 1

BOILER SPECIFICATIONS  
 Q= 150.0 FLW= 56669. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40

PM EMISSIONS  
 UNC= 3.130 CTR= 0.600 EFF= 80.80 CRF= 0.1315

SO2 EMISSIONS  
 UNC= CTR= EFF= CRF=

COST RATES  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 22

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	2732516.	0.	0.	121856.	2854372.
INST	2327704.	0.	0.	0.	2327704.
TD	5060220.	0.	0.	121856.	5182076.
IND	1629384.	0.	0.	40619.	1670002.
TBI	6689604.	0.	0.	162475.	6852079.
CONT	1337920.	0.	0.	32495.	1370415.
TK	8027524.	0.	0.	194970.	8222494.
LAND	2000.	0.	0.	0.	2000.
WC	304323.	0.	0.	10798.	315120.
TOTL	8333846.	0.	0.	205768.	8539613.
DL	186128.	0.	0.	9769.	195897.
SPRV	78752.	0.	0.	1465.	80217.
MANT	85796.	0.	0.	6459.	92255.
SP	153400.	0.	0.	812.	154212.
ELEC	0.	0.	0.	9724.	9724.
UC	69844.	0.	0.	0.	69844.
WTR	0.	0.	0.	0.	0.
SW	10276.	0.	0.	14960.	25236.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1900043.	0.	0.	0.	1900043.
TDOM	2484239.	0.	0.	43190.	2527429.
OH	186898.	0.	0.	7742.	194640.
TOTL	2671136.	0.	0.	50932.	2722068.
CR	1055619.	0.	0.	25639.	1081257.
WCC	30432.	0.	0.	1080.	31512.
MISC.	321101.	0.	0.	7799.	328900.
TCC	1407151.	0.	0.	34517.	1441668.
TOTL	4078287.	0.	0.	85449.	4163736.

LSC-150-Unc, SSS

MODEL BOILER 23  
 BOILER ROUTINE SPRD SO2 ROUTINE= 4-06-82  
 PM ROUTINE= SSS FLOW FLAG= 1  
 BOILER SPECIFICATIONS  
 Q= 150.0 FLW= 56669. CF= 0.600 CRF= 0.1315  
 FUEL SPECIFICATIONS  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
 PM EMISSIONS  
 UNC= 3.130 CTR= 0.200 EFF= 93.60 CRF= 0.1315  
 SO2 EMISSIONS  
 UNC= CTR= EFF= CRF=

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 23

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2732516.	0.	0.	227173.	2959689.
INST	2327704.	0.	0.	0.	2327704.
TD	5060220.	0.	0.	227173.	5287393.
IND	1629384.	0.	0.	75724.	1705108.
TDI	6689604.	0.	0.	302897.	6992501.
CONT	1337920.	0.	0.	60579.	1398499.
TK	8027524.	0.	0.	363477.	8391000.
LAND	2000.	0.	0.	0.	2000.
WC	304323.	0.	0.	15448.	319770.
TOTL	8333846.	0.	0.	378925.	8712770.
DL	186128.	0.	0.	13676.	199804.
SPRV	78752.	0.	0.	2051.	80803.
MANT	85796.	0.	0.	12079.	97875.
SP	153400.	0.	0.	1514.	154914.
ELEC	0.	0.	0.	15145.	15145.
UC	69844.	0.	0.	0.	69844.
WTR	0.	0.	0.	0.	0.
SW	10276.	0.	0.	17325.	27601.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1900043.	0.	0.	0.	1900043.
TDOM	2484239.	0.	0.	61792.	2546030.
OH	186898.	0.	0.	11726.	198624.
TOTL	2671136.	0.	0.	73518.	2744654.
CR	1055619.	0.	0.	47797.	1103416.
WCC	30432.	0.	0.	1545.	31977.
MISC	321101.	0.	0.	14539.	335640.
TCC	1407151.	0.	0.	63881.	1471032.
TOTL	4078287.	0.	0.	137399.	4215686.

LSC-150-Unc, VS

MODEL BOILER 24	4-06-82				
BOILER ROUTINE SPRD	SO2 ROUTINE=	PM ROUTINE= VS		FLOW FLAG=	1
<b>BOILER SPECIFICATIONS</b>					
Q= 150.0 FLW= 56669. CF= 0.600 CRF= 0.1315					
<b>FUEL SPECIFICATIONS</b>					
FC= 2.41 H= 9600. S= 0.60 A= 5.40					
<b>PM EMISSIONS</b>					
UNC= 3.130 CTR= 0.100 EFF= 96.80 CRF= 0.1315					
<b>SO2 EMISSIONS</b>					
UNC= CTR= EFF= CRF=					
<b>COST RATES</b>					
ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80					
<b>COST SUMMARY TABLE - RUN NO. 24</b>					
ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2732516.	0.	0.	156914.	2889430.
INST	2327704.	0.	0.	107578.	2435281.
TD	5060220.	0.	0.	264492.	5324712.
IND	1629384.	0.	0.	88283.	1717666.
TDI	6689604.	0.	0.	352775.	7042378.
CONT	1337920.	0.	0.	70555.	1408474.
TK	8027524.	0.	0.	423330.	8450853.
LAND	2000.	0.	0.	0.	2000.
WC	304323.	0.	0.	22774.	327096.
TOTL	8333846.	0.	0.	446103.	8779949.
DL	186128.	0.	0.	19538.	205665.
SPRV	78752.	0.	0.	0.	78752.
MANT	85796.	0.	0.	20185.	105981.
SP	153400.	0.	0.	0.	153400.
ELEC	0.	0.	0.	0.	0.
UC	69844.	0.	0.	33456.	103301.
WTR	0.	0.	0.	0.	0.
SW	10276.	0.	0.	17916.	28193.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
 NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1900043.	0.	0.	0.	1900043.
TDOM	2484239.	0.	0.	91095.	2575333.
OH	186898.	0.	0.	16189.	203087.
TOTL	2671136.	0.	0.	107284.	2778420.
CR	1055619.	0.	0.	55668.	1111286.
WCC	30432.	0.	0.	2277.	32710.
MISC	321101.	0.	0.	16933.	338034.
TCC	1407151.	0.	0.	74878.	1482029.
TOTL	4078287.	0.	0.	182162.	4260449.

LSC-150-Unc, FF

MODEL BOILER 25	4-06-82				
BOILER ROUTINE SPRD	SO2 ROUTINE=	PM ROUTINE= FF	FLOW FLAG= 1		
<b>BOILER SPECIFICATIONS</b>					
Q= 150.0 FLW= 56669. CF= 0.600 CRF= 0.1315					
<b>FUEL SPECIFICATIONS</b>					
FC= 2.41 H= 9600. S= 0.60 A= 5.40					
<b>PM EMISSIONS</b>					
UNC= 3.130 CTR= 0.050 EFF= 98.40 CRF= 0.1315					
<b>SO2 EMISSIONS</b>					
UNC= CTR= EFF= CRF=					
<b>COST RATES</b>					
ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80					
<b>COST SUMMARY TABLE - RUN NO. 25</b>					
ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2732516.	0.	0.	325760.	3058275.
INST	2327704.	0.	0.	338045.	2665749.
TD	5060220.	0.	0.	663805.	5724024.
IND	1629384.	0.	0.	199647.	1829030.
TDI	6689604.	0.	0.	863452.	7553055.
CONT	1337920.	0.	0.	172690.	1510610.
TK	8027524.	0.	0.	1036142.	9063665.
LAND	2000.	0.	0.	0.	2000.
WC	304323.	0.	0.	22746.	327069.
TOTL	8333846.	0.	0.	1058887.	9392733.
DL	186128.	0.	0.	19538.	205665.
SPRV	78752.	0.	0.	0.	78752.
MANT	85796.	0.	0.	12919.	98715.
SP	153400.	0.	0.	15245.	168645.
ELEC	0.	0.	0.	0.	0.
UC	69844.	0.	0.	25071.	94915.
WTR	0.	0.	0.	0.	0.
SW	10276.	0.	0.	18212.	28488.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1900043.	0.	0.	0.	1900043.
TDOM	2484239.	0.	0.	90984.	2575223.
OH	186898.	0.	0.	18264.	205162..
TOTL	2671136.	0.	0.	109248.	2780383.
CR	1055619.	0.	0.	136253.	1191871.
WCC	30432.	0.	0.	2275.	32707.
MISC	321101.	0.	0.	41446.	362547.
TCC	1407151.	0.	0.	179973.	1587123.
TOTL	4078287.	0.	0.	289221.	4367507.

LSC-150-DS(50), DS/PM

MODEL BOILER 26  
 BOILER ROUTINE SPRD SO2 ROUTINE= DS PM ROUTINE= FLOW FLAG= 1

S STAR (METRIC) = 0.134  
 S DSTAR (METRIC) = 21.260  
**BOILER SPECIFICATIONS**  
 Q= 150.0 FLW= 56669. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
**PM EMISSIONS**  
 UNC= 3.130 CTR= 0.100 EFF= 96.80 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= 1.190 CTR= 0.595 EFF= 50.00 CRF= 0.1315  
**COST RATES**

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

**COST SUMMARY TABLE - RUN NO. 26**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2732516.	0.	0.	0.	2732516.
INST	2327704.	0.	0.	0.	2327704.
TD	5060220.	0.	991508.	0.	6051727.
IND	1629384.	0.	0.	0.	1629384.
TDI	6689604.	0.	0.	0.	6689604.
CONT	1337920.	0.	0.	0.	1337920.
TK	8027524.	0.	1577831.	0.	9605355.
LAND	2000.	0.	0.	0.	2000.
WC	304323.	0.	59216.	0.	363538.
TOTL	8333846.	0.	1637046.	0.	9970892.
DL	186128.	0.	105000.	0.	291128.
SPRV	78752.	0.	21000.	0.	99752.
HANT	85796.	0.	62166.	0.	147962.
SP	153400.	0.	0.	0.	153400.
ELEC	0.	0.	12326.	0.	12326.
UC	69844.	0.	0.	0.	69844.
WTR	0.	0.	802.	0.	802.
SW	10276.	0.	26720.	0.	36996.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	8849.	0.	8849.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1900043.	0.	0.	0.	1900043.
TDOM	2484239.	0.	236863.	0.	2721102.
OH	186898.	0.	80423.	0.	267321.
TOTL	2671136.	0.	317287.	0.	2988422.
CR	1055619.	0.	207485.	0.	1263103.
WCC	30432.	0.	5922.	0.	36354.
MISC	321101.	0.	63113.	0.	384214.
TCC	1407151.	0.	276520.	0.	1683670.
TOTL	4078287.	0.	593806.	0.	4672093.

LSC-150-DA(50), DA/PM

MODEL BOILER 27                          4-06-82  
 BOILER ROUTINE SPRD    SO2 ROUTINE= DAC    PM ROUTINE=                          FLOW FLAG= 1

S STAR (METRIC)= 0.134  
 S DSTAR (METRIC)= 21.260  
 P DSTAR (METRIC)= 242.150

BOILER SPECIFICATIONS

Q= 150.0 FLW= 56669. CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 2.41 H= 9600. S= 0.60 A= 5.40

PM EMISSIONS

UNC= 3.130 CTR= 0.100 EFF= 96.80 CRF= 0.1315

SO2 EMISSIONS

UNC= 1.190 CTR= 0.595 EFF= 50.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 27

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2732516.	0.	0.	0.	2732516.
INST	2327704.	0.	0.	0.	2327704.
TD	5060220.	0.	810758.	0.	5870977.
IND	1629384.	0.	0.	0.	1629384.
TDI	6689604.	0.	0.	0.	6689604.
CONT	1337920.	0.	0.	0.	1337920.
TK	8027524.	0.	1293521.	0.	9321045.
LAND	2000.	0.	0.	0.	2000.
WC	304323.	0.	64689.	0.	369012.
TOTL	8333846.	0.	1358210.	0.	9692056.
DL	186128.	0.	105000.	0.	291128.
SPRV	78752.	0.	21000.	0.	99752.
MANT	85796.	0.	64861.	0.	150657.
SP	153400.	0.	0.	0.	153400.
ELEC	0.	0.	19442.	0.	19442.
UC	69844.	0.	0.	0.	69844.
WTR	0.	0.	879.	0.	879.
SW	10276.	0.	0.	0.	10276.
SLDG	0.	0.	35004.	0.	35004.
LW	0.	0.	0.	0.	0.
SC	0.	0.	5810.	0.	5810.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	6762.	0.	6762.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1900043.	0.	0.	0.	1900043.
TDOM	2484239.	0.	258757.	0.	2742996.
OH	186898.	0.	81124.	0.	268022.
TOTL	2671136.	0.	339881.	0.	3011017.
CR	1055619.	0.	170098.	0.	1225717.
WCC	30432.	0.	6469.	0.	36901.
MISC	321101.	0.	51741.	0.	372842.
TCC	1407151.	0.	228308.	0.	1635458.
TOTL	4078287.	0.	568189.	0.	4646475.

LSC-150-DA(50), FF

MODEL BOILER 28  
 BOILER ROUTINE SPRD SO2 ROUTINE= DA      4-06-82      PM ROUTINE= FF      FLOW FLAG= 1  
  
 S STAR (METRIC)= 0.134  
 S DSTAR (METRIC)= 21.260  
 BOILER SPECIFICATIONS  
 Q= 150.0 FLW= 56669. CF= 0.600 CRF= 0.1315  
 FUEL SPECIFICATIONS  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
 PM EMISSIONS  
 UNC= 3.130 CTR= 0.050 EFF= 98.40 CRF= 0.1315  
 SO2 EMISSIONS  
 UNC= 1.190 CTR= 0.595 EFF= 50.00 CRF= 0.1315  
 COST RATES  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 28

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2732516.	0.	0.	325760.	3058275.
INST	2327704.	0.	0.	338045.	2665749.
TD	5060220.	0.	609376.	663805.	6333399.
IND	1629384.	0.	0.	199647.	1829030.
TDI	6689604.	0.	0.	863452.	7553055.
CONT	1337920.	0.	0.	172690.	1510610.
TK	8027524.	0.	995476.	1036142.	10059140.
LAND	2000.	0.	0.	0.	2000.
WC	304323.	0.	52884.	22746.	379952.
TOTL	8333846.	0.	1048359.	1058887.	10441092.
DL	186128.	0.	105000.	19538.	310665.
SPRV	78752.	0.	21000.	0.	99752.
MANT	85796.	0.	48750.	12919.	147465.
SP	153400.	0.	0.	15245.	168645.
ELEC	0.	0.	9355.	0.	9355.
UC	69844.	0.	0.	25071.	94915.
WTR	0.	0.	879.	0.	879.
SW	10276.	0.	0.	18212.	28488.
SLDG	0.	0.	13979.	0.	13979.
LW	0.	0.	0.	0.	0.
SC	0.	0.	5810.	0.	5810.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	6762.	0.	6762.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1900043.	0.	0.	0.	1900043.
TDOM	2484239.	0.	211535.	90984.	2786758.
OH	186898.	0.	76935.	18264.	282096.
TOTL	2671136.	0.	288470.	109248.	3068853.
CR	1055619.	0.	130905.	136253.	1322776.
WCC	30432.	0.	5288.	2275.	37995.
MISC	321101.	0.	39819.	41446.	402366.
TCC	1407151.	0.	176012.	179973.	1763135.
TOTL	4078287.	0.	464482.	289221.	4831989.

LSC-150-DA(90), DA/PM

MODEL BOILER 29                          4-06-82  
 BOILER ROUTINE SPRD    SO2 ROUTINE= DAC    PM ROUTINE=                          FLOW FLAG= 1

S STAR (METRIC)= 0.242  
 S DSTAR (METRIC)= 38.268  
 P DSTAR (METRIC)= 242.150  
 BOILER SPECIFICATIONS

Q= 150.0 FLW= 56669. CF= 0.600 CRF= 0.1315  
 FUEL SPECIFICATIONS  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
 PM EMISSIONS  
 UNC= 3.130 CTR= 0.100 EFF= 96.80 CRF= 0.1315  
 SO2 EMISSIONS  
 UNC= 1.190 CTR= 0.119 EFF= 90.00 CRF= 0.1315  
 COST RATES  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 29

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2732516.	0.	0.	0.	2732516.
INST	2327704.	0.	0.	0.	2327704.
TD	5060220.	0.	857321.	0.	5917541.
IND	1629384.	0.	0.	0.	1629384.
TDI	6689604.	0.	0.	0.	6689604.
CONT	1337920.	0.	0.	0.	1337920.
TK	8027524.	0.	1362434.	0.	9389958.
LAND	2000.	0.	0.	0.	2000.
WC	304323.	0.	70005.	0.	374328.
TOTL	8333846.	0.	1432439.	0.	9766285.
DL	186128.	0.	105000.	0.	291128.
SPRV	78752.	0.	21000.	0.	99752.
MANT	85796.	0.	68586.	0.	154382.
SP	153400.	0.	0.	0.	153400.
ELEC	0.	0.	19730.	0.	19730.
UC	69844.	0.	0.	0.	69844.
WTR	0.	0.	960.	0.	960.
SW	10276.	0.	0.	0.	10276.
SLDG	0.	0.	46419.	0.	46419.
LW	0.	0.	0.	0.	0.
SC	0.	0.	6016.	0.	6016.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	12310.	0.	12310.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1900043.	0.	0.	0.	1900043.
TDOM	2484239.	0.	280020.	0.	2764259.
OH	186898.	0.	82092.	0.	268990.
TOTL	2671136.	0.	362113.	0.	3033248.
CR	1055619.	0.	179160.	0.	1234779.
WCC	30432.	0.	7001.	0.	37433.
MISC	321101.	0.	54497.	0.	375598.
TCC	1407151.	0.	240658.	0.	1647808.
TOTL	4078287.	0.	602770.	0.	4681057.

LSC-150-DA(90), FF

MODEL BOILER 30  
 BOILER ROUTINE SPRD SO2 ROUTINE= DA PM ROUTINE= FF FLOW FLAG= 1

S STAR (METRIC)= 0.242  
 S DSTAR (METRIC)= 38.268  
**BOILER SPECIFICATIONS**  
 Q= 150.0 FLW= 56669. CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
**PM EMISSIONS**  
 UNC= 3.130 CTR= 0.050 EFF= 98.40 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= 1.190 CTR= 0.119 EFF= 90.00 CRF= 0.1315  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 30

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	2732516.	0.	0.	325760.	3058275.
INST	2327704.	0.	0.	338045.	2665749.
TD	5060220.	0.	679919.	663805.	6403942.
IND	1629384.	0.	0.	199647.	1829030.
TDI	6689604.	0.	0.	863452.	7553055.
CONT	1337920.	0.	0.	172690.	1510610.
TK	8027524.	0.	1099879.	1036142.	10163544.
LAND	2000.	0.	0.	0.	2000.
WC	304323.	0.	58642.	22746.	385710.
TOTL	8333846.	0.	1138520.	1058887.	10551253.
DL	186128.	0.	105000.	19538.	310665.
SPRV	78752.	0.	21000.	0.	99752.
MANT	85796.	0.	54393.	12919.	153108.
SP	153400.	0.	0.	15245.	168645.
ELEC	0.	0.	9494.	0.	9494.
UC	69844.	0.	0.	25071.	94915.
WTR	0.	0.	960.	0.	960.
SW	10276.	0.	0.	18212.	28488.
SLDG	0.	0.	25394.	0.	25394.
LW	0.	0.	0.	0.	0.
SC	0.	0.	6016.	0.	6016.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	12310.	0.	12310.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	1900043.	0.	0.	0.	1900043.
TDOM	2484239.	0.	234567.	90984.	2809789.
OH	186898.	0.	78402.	18264.	283564.
TOTL	2671136.	0.	312969.	109248.	3093352.
CR	1055619.	0.	144634.	136253.	1336505.
WCC	30432.	0.	5864.	2275.	38571.
MISC	321101.	0.	43995.	41446.	406542.
TCC	1407151.	0.	194493.	179973.	1781616.
TOTL	4078287.	0.	507462.	289221.	4874969.

LSC-400-Unc, Unc

MODEL BOILER	31	4-06-82													
BOILER ROUTINE	PLVR	S02 ROUTINE=	PM ROUTINE=	FLOW FLAG=	3										
BOILER SPECIFICATIONS															
Q= 400.0 FLW= 145912 CF= 0.600 CRF= 0.1315															
FUEL SPECIFICATIONS															
FC= 2.41 H= 9600. S= 0.60 A= 5.40															
PM EMISSIONS															
UNC=	CTR=	EFF=	CRF=												
S02 EMISSIONS															
UNC=	CTR=	EFF=	CRF=												
COST RATES															
ELEC=	0.0258	WTR=	0.15	LIME=	35.00	ALS=	8.00	SASH=	90.00	SLDG=	15.00	SWD=	15.00	ALWD=	1.80
COST SUMMARY TABLE - RUN NO. 31															
ITEM	BOILER	NOX CONTROL	S02 CONTROL	PM CONTROL	TOTAL										
EQUP	7560504.	0.	0.	0.	7560504.										
INST	4021223.	0.	0.	0.	4021223.										
TD	11581727.	0.	0.	0.	11581727.										
IND	3594800.	0.	0.	0.	3594800.										
TDI	15176527.	0.	0.	0.	15176527.										
CONT	3035305.	0.	0.	0.	3035305.										
TK	18211824.	0.	0.	0.	18211824.										
LAND	4000.	0.	0.	0.	4000.										
WC	774010.	0.	0.	0.	774010.										
TOTL	18989824.	0.	0.	0.	18989824.										
DL	406848.	0.	0.	0.	406848.										
SPRV	110674.	0.	0.	0.	110674.										
MANT	215444.	0.	0.	0.	215444.										
SP	262766.	0.	0.	0.	262766.										
ELEC	0.	0.	0.	0.	0.										
UC	396920.	0.	0.	0.	396920.										
WTR	0.	0.	0.	0.	0.										
SW	15136.	0.	0.	0.	15136.										
SLDG	0.	0.	0.	0.	0.										
LW	0.	0.	0.	0.	0.										
SC	0.	0.	0.	0.	0.										
LMS	0.	0.	0.	0.	0.										
LIME	0.	0.	0.	0.	0.										
NH3	0.	0.	0.	0.	0.										
LYE	0.	0.	0.	0.	0.										
FUEL	5066783.	0.	0.	0.	5066783.										
TDOM	6474571.	0.	0.	0.	6474571.										
OH	380945.	0.	0.	0.	380945.										
TOTL	6855515.	0.	0.	0.	6855515.										
CR	2394854.	0.	0.	0.	2394854.										
WCC	77401.	0.	0.	0.	77401.										
MISC	728473.	0.	0.	0.	728473.										
TCC	3200727.	0.	0.	0.	3200727.										
TOTL	10056242.	0.	0.	0.	10056242.										

LSC-400-Unc, SM

MODEL BOILER 32  
BOILER ROUTINE PLVR SO2 ROUTINE=

4-06-82  
PM ROUTINE= SH

FLOW FLAG= 3

BOILER SPECIFICATIONS

Q= 400.0 FLW=145912 CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
**PM EMISSIONS**  
 UNC= 2.390 CTR= 1.000 EFF= 58.20 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= CTR= EFF= CRF= 0  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 32

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	7560504.	0.	0.	247678.	7808181.
INST	4021223.	0.	0.	0.	4021223.
TD	11581727.	0.	0.	247678.	11829404.
IND	3594800.	0.	0.	82559.	3677359.
TDI	15176527.	0.	0.	330237.	15506764.
CONT	3035305.	0.	0.	66047.	3101352.
TK	18211824.	0.	0.	396284.	18608096.
LAND	4000.	0.	0.	0.	4000.
WC	774010.	0.	0.	20784.	794794.
TOTL	18989824.	0.	0.	417068.	19406880.
DL	406848.	0.	0.	19706.	426555.
SPRV	110674.	0.	0.	2956.	113630.
MANT	215444.	0.	0.	11925.	227369.
SP	262766.	0.	0.	1651.	264417.
ELEC	0.	0.	0.	24980.	24980.
UC	396920.	0.	0.	0.	396920.
WTR	0.	0.	0.	0.	0.
SW	15136.	0.	0.	21918.	37054.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	5066783.	0.	0.	0.	5066783.
TDOM	6474571.	0.	0.	83136.	6557707.
OH	380945.	0.	0.	15334.	396279.
TOTL	6855515.	0.	0.	98470.	6953984.
CR	2394854.	0.	0.	52111.	2446965.
WCC	77401.	0.	0.	2078.	79479.
MISC	728473.	0.	0.	15851.	744324.
TCC	3200727.	0.	0.	70041.	3270768.
TOTL	10056242.	0.	0.	168511.	10224753.

LSC-400-Unc, SSS

MODEL BOILER 33  
 BOILER ROUTINE PLVR SO2 ROUTINE= 4-06-82 PM ROUTINE= SSS FLOW FLAG= 3  
**BOILER SPECIFICATIONS**  
 Q= 400.0 FLW=145912 CF= 0.600 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
**PM EMISSIONS**  
 UNC= 2.390 CTR= 0.200 EFF= 91.60 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= CTR= EFF= CRF=  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 33

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	7560504.	0.	0.	477284.	8037787.
INST	4021223.	0.	0.	0.	4021223.
TD	11581727.	0.	0.	477284.	12059010.
IND	3594800.	0.	0.	159095.	3753894.
TDI	15176527.	0.	0.	636379.	15812905.
CONT	3035305.	0.	0.	127276.	3162580.
TK	18211824.	0.	0.	763654.	18975472.
LAND	4000.	0.	0.	0.	4000.
WC	774010.	0.	0.	33049.	807059.
TOTL	18989824.	0.	0.	796703.	19786512.
DL	406848.	0.	0.	27589.	434437.
SPRV	110674.	0.	0.	4138.	114812.
MANT	215444.	0.	0.	24455.	239899.
SP	262766.	0.	0.	3182.	265948.
ELEC	0.	0.	0.	38301.	38301.
UC	396920.	0.	0.	0.	396920.
WTR	0.	0.	0.	0.	0.
SW	15136.	0.	0.	34532.	49668.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	5066783.	0.	0.	0.	5066783.
TDOM	6474571.	0.	0.	132197.	6606767.
OH	380945.	0.	0.	23711.	404656.
TOTL	6855515.	0.	0.	155908.	7011422.
CR	2394854.	0.	0.	100421.	2495274.
WCC	77401.	0.	0.	3305.	80706.
MISC	728473.	0.	0.	30546.	759019.
TCC	3200727.	0.	0.	134272.	3334998.
TOTL	10056242.	0.	0.	290179.	10346421.

LSC-400-Unc, VS

MODEL BOILER 34	4-06-82				
BOILER ROUTINE PLVR	S02 ROUTINE=	PM ROUTINE= VS		FLOW FLAG=	3
<b>BOILER SPECIFICATIONS</b>					
Q= 400.0 FLW=145912 CF= 0.600 CRF= 0.1315					
<b>FUEL SPECIFICATIONS</b>					
FC= 2.41 H= 9600. S= 0.60 A= 5.40					
<b>PM EMISSIONS</b>					
UNC= 2.390 CTR= 0.100 EFF= 95.80 CRF= 0.1315					
<b>S02 EMISSIONS</b>					
UNC= CTR= EFF= CRF=					
<b>COST RATES</b>					
ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80					
<b>COST SUMMARY TABLE - RUN NO. 34</b>					
ITEM	BOILER	NOX CONTROL	S02 CONTROL	PM CONTROL	TOTAL
EQUIP	7560504.	0.	0.	360859.	7921362.
INST	4021223.	0.	0.	254535.	4275758.
TD	11581727.	0.	0.	615394.	12197121.
IND	3594800.	0.	0.	202523.	3797323.
TDI	15176527.	0.	0.	817917.	15994444.
CONT	3035305.	0.	0.	143583.	3198888.
TK	18211824.	0.	0.	981501.	19193312.
LAND	4000.	0.	0.	0.	4000.
WC	774010.	0.	0.	51440.	825450.
TOTL	18989824.	0.	0.	1032941.	20022752.
DL	406848.	0.	0.	39413.	446261.
SPRV	110674.	0.	0.	0.	110674.
MANT	215444.	0.	0.	46285.	261729.
SP	262766.	0.	0.	0.	262766.
ELEC	0.	0.	0.	0.	0.
UC	396920.	0.	0.	83953.	480872.
WTR	0.	0.	0.	0.	0.
SW	15136.	0.	0.	36109.	51245.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	5066783.	0.	0.	0.	5066783.
TDOM	6474571.	0.	0.	205759.	6680329.
OH	380945.	0.	0.	34105.	415050.
TOTL	6853515.	0.	0.	239864.	7095378.
CR	2394854.	0.	0.	129067.	2523921.
WCC	77401.	0.	0.	5144.	82545.
MISC	728473.	0.	0.	39260.	767733.
TCC	3200727.	0.	0.	173471.	3374198.
TOTL	10056242.	0.	0.	413335.	10469577.

LSC-400-Unc, FF

MODEL BOILER 35                          4-06-82  
 BOILER ROUTINE PLVR    SO2 ROUTINE=                          PM ROUTINE= FF                          FLOW FLAG= 3

BOILER SPECIFICATIONS

Q= 400.0 FLW=145912 CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 2.41 H= 9600. S= 0.60 A= 5.40

PM EMISSIONS

UNC= 2.390 CTR= 0.050 EFF= 97.90 CRF= 0.1315

SO2 EMISSIONS

UNC= CTR= EFF= CRF=

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 35

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	7560504.	0.	0.	810402.	8370905.
INST	4021223.	0.	0.	497045.	4518268.
TD	11581727.	0.	0.	1307446.	12889173.
IND	3594800.	0.	0.	433166.	4027945.
TDI	15176527.	0.	0.	1740611.	16917136.
CCNT	3035305.	0.	0.	348122.	3383427.
TK	18211824.	0.	0.	2088733.	20300544.
LAND	4000.	0.	0.	0.	4000.
WC	774010.	0.	0.	50205.	824215.
TOTL	18989824.	0.	0.	2138938.	21128752.
DL	406848.	0.	0.	39413.	446261.
SPRV	110674.	0.	0.	0.	110674.
MANT	215444.	0.	0.	23850.	239294.
SP	262766.	0.	0.	39051.	301817.
ELEC	0.	0.	0.	0.	0.
UC	396920.	0.	0.	61609.	458529.
WTR	0.	0.	0.	0.	0.
SW	15136.	0.	0.	36897.	52033.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	5066783.	0.	0.	0.	5066783.
TDOM	6474571.	0.	0.	200820.	6675391.
OH	380945.	0.	0.	38425.	419370.
TOTL	6855515.	0.	0.	239245.	7094760.
CR	2394854.	0.	0.	274668.	2669522.
WCC	77401.	0.	0.	5021.	82422.
MISC	728473.	0.	0.	83549.	812022.
TCC	3200727.	0.	0.	363238.	3563965.
TOTL	10056242.	0.	0.	602483.	10658725.

LSC-400-DS(50), DS/PM

MODEL BOILER 36  
 BOILER ROUTINE PLVR SO2 ROUTINE= DS PM ROUTINE= FLOW FLAG= 3

S STAR (METRIC) = 0.134  
 S DSTAR (METRIC) = 56.693  
 BOILER SPECIFICATIONS  
 Q= 400.0 FLW=145912 CF= 0.600 CRF= 0.1315  
 FUEL SPECIFICATIONS  
 FC= 2.41 H= 9600. S= 0.60 A= 5.40  
 PM EMISSIONS  
 UNC= 2.390 CTR= 0.100 EFF= 95.80 CRF= 0.1315  
 SO2 EMISSIONS  
 UNC= 1.190 CTR= 0.595 EFF= 50.00 CRF= 0.1315  
 COST RATES  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWU= 1.80

COST SUMMARY TABLE - RUN NO. 36

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	7560504.	0.	0.	0.	7560504.
INST	4021223.	0.	0.	0.	4021223.
TD	11581727.	0.	2027351.	0.	13609078.
IND	3594800.	0.	0.	0.	3594800.
TDI	15176527.	0.	0.	0.	15176527.
CONT	3035305.	0.	0.	0.	3035305.
TK	18211824.	0.	3243762.	0.	21455584.
LAND	4000.	0.	0.	0.	4000.
WC	774010.	0.	89015.	0.	863025.
TOTL	18989824.	0.	3332776.	0.	22322592.
DL	406848.	0.	105000.	0.	511848.
SPRV	110674.	0.	21000.	0.	131674.
MANT	215444.	0.	118101.	0.	333545.
SP	262766.	0.	0.	0.	262766.
ELEC	0.	0.	26718.	0.	26718.
UC	396920.	0.	0.	0.	396920.
WTR	0.	0.	2060.	0.	2060.
SW	15136.	0.	59582.	0.	74718.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	23598.	0.	23598.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	5066783.	0.	0.	0.	5066783.
TDOM	6474571.	0.	356059.	0.	6830629.
OH	380945.	0.	94966.	0.	475911.
TOTL	6855515.	0.	451025.	0.	7306539.
CR	2394854.	0.	426555.	0.	2821408.
WCC	77401.	0.	8901.	0.	86302.
MISC	728473.	0.	129750.	0.	858223.
TCC	3200727.	0.	565207.	0.	3765933.
TOTL	10056242.	0.	1016231.	0.	11072473.

LSC-400-DA(50), DA/PM

MODEL BOILER 37                          4-06-82  
 BOILER ROUTINE PLVR    SO2 ROUTINE= DAC                          PM ROUTINE=                          FLOW FLAG=    3  
  
 S STAR (METRIC)=    0.134  
 S DSTAR (METRIC)=    56.693  
 P DSTAR (METRIC)=    484.482  
 BOILER SPECIFICATIONS  
 Q=    400.0 FLW= 145912    CF=    0.600 CRF= 0.1315  
 FUEL SPECIFICATIONS  
 FC=    2.41 H=    9600. S=    0.60 A=    5.40  
 PM EMISSIONS  
 UNC=    2.390 CTR= 0.100 EFF=    95.80 CRF= 0.1315  
 SO2 EMISSIONS  
 UNC=    1.190 CTR= 0.595 EFF=    50.00 CRF= 0.1315  
 COST RATES  
 ELEC= 0.0258 WTR=    0.15 LIME= 35.00 ALS=    8.00 SASH= 90.00 SLDG= 15.00 SWD=    15.00 ALWD=    1.80

COST SUMMARY TABLE - RUN NO.    37

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	7560504.	0.	0.	0.	7560504.
INST	4021223.	0.	0.	0.	4021223.
TD	11581727.	0.	1271267.	0.	12852994.
IND	3594800.	0.	0.	0.	3594800.
TDI	15176527.	0.	0.	0.	15176527.
CONT	3035305.	0.	0.	0.	3035305.
TK	18211824.	0.	2011474.	0.	20223296.
LAND	4000.	0.	0.	0.	4000.
WC	774010.	0.	98391.	0.	872401.
TOTL	18989824.	0.	2109865.	0.	21099680.
DL	406848.	0.	105000.	0.	511848.
SPRV	110674.	0.	21000.	0.	131674.
MANT	215444.	0.	101701.	0.	317146.
SP	262766.	0.	0.	0.	262766.
ELEC	0.	0.	49942.	0.	49942.
UC	396920.	0.	0.	0.	396920.
WTR	0.	0.	2184.	0.	2184.
SW	15136.	0.	0.	0.	15136.
SLDG	0.	0.	79826.	0.	79826.
LW	0.	0.	0.	0.	0.
SC	0.	0.	15592.	0.	15592.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	18320.	0.	18320.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	5066783.	0.	0.	0.	5066783.
TDOM	6474571.	0.	393565.	0.	6868136.
OH	380945.	0.	90702.	0.	471647.
TOTL	6855515.	0.	484267.	0.	7339782.
CR	2394854.	0.	264509.	0.	2659362.
WCC	77401.	0.	9839.	0.	87240.
MISC	728473.	0.	80459.	0.	808932.
TCC	3200727.	0.	354807.	0.	3555533.
TOTL	10056242.	0.	839074.	0.	10895316.

LSC-400-DA(50), FF

MODEL BOILER 38  
BOILER ROUTINE PLVR

SO2 ROUTINE= DA

4-06-82

PM ROUTINE= FF

FLOW FLAG= 3

S STAR (METRIC)= 0.134  
S DSTAR (METRIC)= 56.693

BOILER SPECIFICATIONS

Q= 400.0 FLW= 145912 CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= , 2.41 H= 9600. S= 0.60 A= 5.40

PM EMISSIONS

UNC= 2.390 CTR= 0.050 EFF= 97.90 CRF= 0.1315

SO2 EMISSIONS

UNC= 1.190 CTR= 0.595 EFF= 50.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 38

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	7560504.	0.	0.	810402.	8370905.
INST	4021223.	0.	0.	497045.	4518268.
TD	11581727.	0.	998046.	1307446.	13887218.
IND	3594800.	0.	0.	433166.	4027965.
TDI	15176527.	0.	0.	1740611.	16917136.
CONT	3035305.	0.	0.	348122.	3383427.
TK	18211824.	0.	1607106.	2088733.	21907648.
LAND	4000.	0.	0.	0.	4000.
WC	774010.	0.	75933.	50205.	900148.
TOTL	18989824.	0.	1683038.	2138938.	22811776.
DL	406848.	0.	105000.	39413.	551261.
SPRV	110674.	0.	21000.	0.	131674.
MANT	215444.	0.	79844.	23850.	319138.
SP	262766.	0.	0.	39051.	301817.
ELEC	0.	0.	24031.	0.	24031.
UC	396920.	0.	0.	61609.	458529.
WTR	0.	0.	2184.	0.	2184.
SW	15136.	0.	0.	36897.	52033.
SLDG	0.	0.	37760.	0.	37760.
LW	0.	0.	0.	0.	0.
SC	0.	0.	15592.	0.	15592.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	18320.	0.	18320.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	5066783.	0.	0.	0.	5066783.
TDOM	6474571.	0.	303731.	200820.	6979121.
OH	380945.	0.	85019.	38425.	504390.
TOTL	6855515.	0.	388750.	239245.	7483509.
CR	2394854.	0.	211334.	274668.	2880856.
WCC	77401.	0.	7593.	5021.	90015.
MISC	728473.	0.	64284.	83549.	876306.
TCC	3200727.	0.	283212.	363238.	3847176.
TOTL	10056242.	0.	671962.	602483.	11330686.

LSC-400-DA(90), DA/PM

MODEL BOILER 39  
 BOILER ROUTINE PLVR SO2 ROUTINE= DAC PM ROUTINE= FLOW FLAG= 3

S STAR (METRIC)= 0.242  
 S DSTAR (METRIC)= 102.047  
 P DSTAR (METRIC)= 484.482

BOILER SPECIFICATIONS

Q= 400.0 FLW=145912 CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 2.41 H= 9600. S= 0.60 A= 5.40

PM EMISSIONS

UNC= 2.390 CTR= 0.100 EFF= 95.80 CRF= 0.1315

SO2 EMISSIONS

UNC= 1.190 CTR= 0.119 EFF= 90.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 39

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	7560504.	0.	0.	0.	7560504.
INST	4021223.	0.	0.	0.	4021223.
TD	11581727.	0.	1338179.	0.	12919906.
IND	3594800.	0.	0.	0.	3594800.
TDI	15176527.	0.	0.	0.	15176527.
CONT	3035305.	0.	0.	0.	3035305.
TK	18211824.	0.	2110504.	0.	20322320.
LAND	4000.	0.	0.	0.	4000.
WC	774010.	0.	111411.	0.	885421.
TOTL	18989824.	0.	2221915.	0.	21211728.
DL	406848.	0.	105000.	0.	511848.
SPRV	110674.	0.	21000.	0.	131674.
MANT	215444.	0.	107054.	0.	322499.
SP	262766.	0.	0.	0.	262766.
ELEC	0.	0.	50682.	0.	50682.
UC	396920.	0.	0.	0.	396920.
WTR	0.	0.	2386.	0.	2386.
SW	15136.	0.	0.	0.	15136.
SLDG	0.	0.	110266.	0.	110266.
LW	0.	0.	0.	0.	0.
SC	0.	0.	16144.	0.	16144.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	33113.	0.	33113.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	5066783.	0.	0.	0.	5066783.
TDOM	6474571.	0.	445646.	0.	6920216.
OH	380945.	0.	92094.	0.	473039.
TOTL	6855515.	0.	537740.	0.	7393255.
CR	2394854.	0.	277531.	0.	2672385.
WCC	77401.	0.	11141.	0.	88542.
MISC	728473.	0.	84420.	0.	812893.
TCC	3200727.	0.	373093.	0.	3573819.
TOTL	10056242.	0.	910833.	0.	10967074.

LSC-400-DA(90), FF

MODEL BOILER 40                    04-07-82  
 BOILER ROUTINE PLVR                SO2 ROUTINE= DA                PM ROUTINE= FF                FLOW FLAG= 3

S STAR (METRIC)= 0.242  
 S DSTAR (METRIC)= 102.047

BOILER SPECIFICATIONS

Q= 400.0 FLW= 145912 CF= 0.600 CRF= 0.1315

FUEL SPECIFICATIONS

FC= 2.41 H= 9600. S= 0.60 A= 5.40

PM EMISSIONS

UNC= 2.390 CTR= 0.050 EFF= 97.90 CRF= 0.1315

SO2 EMISSIONS

UNC= 1.190 CTR= 0.119 EFF= 90.00 CRF= 0.1315

COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 40

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
------	--------	-------------	-------------	------------	-------

EQUIP	7560504.	0.	0.	810402.	8370905.
INST	4021223.	0.	0.	497045.	4518268.
TD	11581727.	0.	1101460.	1307446.	13990633.
IND	3594800.	0.	0.	433166.	4027965.
TDI	15176527.	0.	0.	1740611.	16917136.
CONT	3035305.	0.	0.	348122.	3383427.
TK	18211824.	0.	1760160.	2088733.	22060704.
LAND	4000.	0.	0.	0.	4000.
WC	774010.	0.	89587.	50205.	913802.
TOTL	18989824.	0.	1849746.	2138938.	22978496.
DL	406848.	0.	105000.	39413.	551261.
SPRV	110674.	0.	21000.	0.	131674.
MANT	215444.	0.	88117.	23850.	327411.
SP	262766.	0.	0.	39051.	301817.
ELEC	0.	0.	24387.	0.	24387.
UC	396920.	0.	0.	61609.	458529.
WTR	0.	0.	2386.	0.	2386.
SW	15136.	0.	0.	36897.	52033.
SLDG	0.	0.	68201.	0.	68201.
LW	0.	0.	0.	0.	0.
SC	0.	0.	16144.	0.	16144.
LMS	0.	0.	0.	0.	0.
LIHE	0.	0.	33113.	0.	33113.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	5066783.	0.	0.	0.	5066783.
TDOM	6474571.	0.	358348.	200820.	7033738.
OH	380945.	0.	87170.	38425.	506541.
TOTL	6855315.	0.	445518.	239245.	7540277.
CR	2394854.	0.	231461.	274668.	2900983.
WCC	77401.	0.	8959.	5021.	91380.
MISC	728473.	0.	70406.	83549.	882429.
TCC	3200727.	0.	310826.	363238.	3874791.
TOTL	10056242.	0.	756344.	602483.	11415068.

RES-30-Unc, Unc

MODEL BOILER 1  
 BOILER ROUTINE RES1 SO2 ROUTINE= 4-07-82 PM ROUTINE= FLOW FLAG= 6  
**BOILER SPECIFICATIONS**  
 Q= 30.0 FLW= 9007. CF= 0.550 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 4.85 H= 18500. S= 3.00 A= 0.10  
**PM EMISSIONS**  
 UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0  
**SO2 EMISSIONS**  
 UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 1

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	115427.	0.	0.	0.	115427.
INST	185897.	0.	0.	0.	185897.
TD	301324.	0.	0.	0.	301324.
IND	99259.	0.	0.	0.	99259.
TDI	400583.	0.	0.	0.	400583.
CONT	80117.	0.	0.	0.	80117.
TK	480699.	0.	0.	0.	480699.
LAND	2000.	0.	0.	0.	2000.
WC	94718.	0.	0.	0.	94718.
TOTL	577417.	0.	0.	0.	577417.
DL	52584.	0.	0.	0.	52584.
SPRV	34207.	0.	0.	0.	34207.
MANT	15980.	0.	0.	0.	15980.
SP	20522.	0.	0.	0.	20522.
ELEC	0.	0.	0.	0.	0.
UC	21998.	0.	0.	0.	21998.
WTR	0.	0.	0.	0.	0.
SW	0.	0.	0.	0.	0.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	701019.	0.	0.	0.	701019.
TDOM	846311.	0.	0.	0.	846311.
OH	47832.	0.	0.	0.	47832.
TOTL	894142.	0.	0.	0.	894142.
CR	63212.	0.	0.	0.	63212.
WCC	9472.	0.	0.	0.	9472.
MISC	19228.	0.	0.	0.	19228.
TCC	91912.	0.	0.	0.	91912.
TOTL	986054.	0.	0.	0.	986054.

RES-30-Unc, ESP

MODEL BOILER 2  
 BOILER ROUTINE RES1 SO2 ROUTINE= 4-07-82  
 PM ROUTINE= ESPO FLOW FLAG= 6

SPECIFIC COLLECTOR AREA(SQ FT/1000 ACFM)= 400.0

TOTAL PLATE AREA (SQ FT)= 3602.7

**BOILER SPECIFICATIONS**

Q= 30.0 FLW= 9007. CF= 0.550 CRF= 0.1315

**FUEL SPECIFICATIONS**

FC= 4.85 H= 18500. S= 3.00 A= 0.10

**PM EMISSIONS**

UNC= 0.230 CTR= 0.050 EFF= 78.30 CRF= 0.1315

**SO2 EMISSIONS**

UNC= 0.0 CTR= 0.0 EFF= 0.0 CRF= 0.0

**COST RATES**

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

**COST SUMMARY TABLE RUN NO. 2**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	115427.	0.	0.	112477.	227904.
INST	185897.	0.	0.	131599.	317196.
TD	301324.	0.	0.	244076.	545400.
IND	99259.	0.	0.	81521.	180780.
TDI	400583.	0.	0.	325597.	726180.
CONT	80117.	0.	0.	65119.	145236.
TK	480699.	0.	0.	390717.	871416.
LAND	2000.	0.	0.	0.	2000.
WC	94718.	0.	0.	5205.	99923.
TOTL	577417.	0.	0.	395922.	973339.
DL	52584.	0.	0.	8331.	60915.
SPRV	34207.	0.	0.	0.	34207.
MANT	15980.	0.	0.	9335.	25315.
SP	20522.	0.	0.	1797.	22320.
ELEC	0.	0.	0.	0.	0.
UC	21998.	0.	0.	1356.	23354.
WTR	0.	0.	0.	0.	0.
SW	0.	0.	0.	0.	0.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	701019.	0.	0.	0.	701019.
TDOM	846311.	0.	0.	20819.	867130.
OH	47832.	0.	0.	7560.	55391.
TOTL	894142.	0.	0.	28379.	922521.
CR	63212.	0.	0.	51379.	114591.
WCC	9472.	0.	0.	520.	9992.
MISC	19228.	0.	0.	15629.	34857.
TCC	91912.	0.	0.	67528.	159440.
TOTL	986054.	0.	0.	95907.	1081961.

RES-30-NATH(50), NATH/PM

MODEL BOILER 3                          4-07-82  
 BOILER ROUTINE RES1    SO2 ROUTINE= NATH    PM ROUTINE=                          FLOW FLAG= 6

S STAR (METRIC)= 0.349  
 S DSTAR (METRIC)= 11.032  
**BOILER SPECIFICATIONS**  
 Q= 30.0 FLW= 9007. CF= 0.550 CRF= 0.1315  
**FUEL SPECIFICATIONS**

FC= 4.85 H= 18500. S= 3.00 A= 0.10  
**PM EMISSIONS**  
 UNC= 0.230 CTR= 0.050 EFF= 78.30 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= 3.210 CTR= 1.610 EFF= 50.00 CRF= 0.1315  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 3

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	115427.	0.	0.	0.	115427.
INST	185897.	0.	0.	0.	185897.
TD	301324.	0.	165350.	0.	466674.
IND	99259.	0.	0.	0.	99259.
TDI	400583.	0.	0.	0.	400583.
CONT	80117.	0.	0.	0.	80117.
TK	480699.	0.	319118.	0.	799817.
LAND	2000.	0.	0.	0.	2000.
UC	94718.	0.	42338.	0.	137056.
TOTL	577417.	0.	361456.	0.	938873.
DL	52584.	0.	105000.	0.	157584.
SPRV	34207.	0.	21000.	0.	55207.
MANT	15980.	0.	13228.	0.	29208.
SP	20522.	0.	0.	0.	20522.
ELEC	0.	0.	1465.	0.	1465.
UC	21998.	0.	0.	0.	21998.
WTR	0.	0.	222.	0.	222.
SW	0.	0.	0.	0.	0.
SLDG	0.	0.	3990.	0.	3990.
LW	0.	0.	2173.	0.	2173.
SC	0.	0.	22274.	0.	22274.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	701019.	0.	0.	0.	701019.
TDOM	846311.	0.	169352.	0.	1015663.
OH	47832.	0.	67699.	0.	115531.
TOTL	894142.	0.	237052.	0.	1131194.
CR	63212.	0.	41964.	0.	105176.
WCC	9472.	0.	4234.	0.	13706.
MISC	19228.	0.	12765.	0.	31993.
TCC	91912.	0.	58962.	0.	150874.
TOTL	986054.	0.	296014.	0.	1282068.

RES-30-NATH(50), ESP

MODEL BOILER 4                          4-07-82  
 BOILER ROUTINE RES1                    SO2 ROUTINE= NATH                    PM ROUTINE= ESP0                    FLOW FLAG= 6

S STAR (METRIC)= 0.349  
 S DSTAR (METRIC)= 11.032

SPECIFIC COLLECTOR AREA(SQ FT/1000 ACFM)= 400.0

TOTAL PLATE AREA (SQ FT)= 3602.7

**BOILER SPECIFICATIONS**

Q= 30.0 FLW= 9007. CF= 0.550 CRF= 0.1315

**FUEL SPECIFICATIONS**

FC= 4.85 H= 18500. S= 3.00 A= 0.10

**PM EMISSIONS**

UNC= 0.230 CTR= 0.050 EFF= 78.30 CRF= 0.1315

**SO2 EMISSIONS**

UNC= 3.210 CTR= 1.610 EFF= 50.00 CRF= 0.1315

**COST RATES**

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 4

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	115427.	0.	0.	112477.	227904.
INST	185897.	0.	0.	131599.	317496.
TD	301324.	0.	165350.	244076.	710750.
IND	99259.	0.	0.	81521.	180780.
TDI	400583.	0.	0.	325597.	726180.
CONT	80117.	0.	0.	65119.	145236.
TK	480699.	0.	319118.	390717.	1190533.
LAND	2000.	0.	0.	0.	2000.
WC	94718.	0.	42338.	5205.	142261.
TOTL	577417.	0.	361456.	395922.	1334794.
DL	52584.	0.	105000.	8331.	165915.

SPRV	34207.	0.	21000.	0.	55207.
MANT	15980.	0.	13228.	9335.	38543.
SP	20322.	0.	0.	1797.	22320.
ELEC	0.	0.	1465.	0.	1465.
UC	21998.	0.	0.	1356.	23354.
WTR	0.	0.	222.	0.	222.
SW	0.	0.	0.	0.	0.
SLDG	0.	0.	3990.	0.	3990.
LW	0.	0.	2173.	0.	2173.
SC	0.	0.	22274.	0.	22274.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	701019.	0.	0.	0.	701019.
TDOM	846311.	0.	169352.	20819.	1036482.
OH	47832.	0.	67699.	7560.	123091.
TOTL	894142.	0.	237052.	28379.	1159572.
CR	63212.	0.	41964.	51379.	156555.
WCC	9472.	0.	4234.	520.	14226.
MISC	19228.	0.	12765.	15629.	47621.
TCC	91912.	0.	58962.	67528.	218402.
TOTL	986054.	0.	296014.	95907.	1377975.

RES-30-NATH(90), NATH/PM

MODEL BOILER 5  
 BOILER ROUTINE RES1 SO2 ROUTINE= NATH PM ROUTINE= FLOW FLAG= 6

S STAR (METRIC)= 0.628  
 S DSTAR (METRIC)= 19.858  
**BOILER SPECIFICATIONS**  
 Q= 30.0 FLW= 9007. CF= 0.550 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC= 4.85 H= 18500. S= 3.00 A= 0.10  
**PM EMISSIONS**  
 UNC= 0.230 CTR= 0.050 EFF= 78.30 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= 3.210 CTR= 0.321 EFF= 90.00 CRF= 0.1315  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

**COST SUMMARY TABLE - RUN NO. 5**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	115427.	0.	0.	0.	115427.
INST	185897.	0.	0.	0.	185897.
TD	301324.	0.	181732.	0.	483056.
IND	99259.	0.	0.	0.	99259.
TDI	400583.	0.	0.	0.	400583.
CONT	80117.	0.	0.	0.	80117.
TK	480699.	0.	343363.	0.	824062.
LAND	2000.	0.	0.	0.	2000.
WC	94718.	0.	47649.	0.	142367.
TOTL	577417.	0.	391012.	0.	968429.
DL	52584.	0.	105000.	0.	157584.
SPRV	34207.	0.	21000.	0.	55207.
MANT	15980.	0.	14539.	0.	30519.
SP	20522.	0.	0.	0.	20522.
ELEC	0.	0.	1632.	0.	1632.
UC	21998.	0.	0.	0.	21998.
WTR	0.	0.	316.	0.	316.
SW	0.	0.	0.	0.	0.
SLDG	0.	0.	7172.	0.	7172.
LW	0.	0.	3911.	0.	3911.
SC	0.	0.	37025.	0.	37025.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	701019.	0.	0.	0.	701019.
TDOM	846311.	0.	190596.	0.	1036907.
OH	47932.	0.	68040.	0.	115872.
TOTL	894142.	0.	258636.	0.	1152778.
CR	63212.	0.	45152.	0.	108364.
WCC	9472.	0.	4765.	0.	14237.
MISC	19228.	0.	13735.	0.	32962.
TCC	91912.	0.	63652.	0.	155563.
TOTL	986054.	0.	322288.	0.	1308341.

RES-30-NATH(90), ESP

MODEL BOILER 6  
 BOILER ROUTINE RES1 SO2 ROUTINE= NATH 4-07-82 PM ROUTINE= ESPO FLOW FLAG= 6

S STAR (METRIC)= 0.628  
 S DSTAR (METRIC)= 19.858

SPECIFIC COLLECTOR AREA(SQ FT/1000 ACFM)= 400.0

TOTAL PLATE AREA (SQ FT)= 3602.7

**BOILER SPECIFICATIONS**

Q= 30.0 FLW= 9007. CF= 0.550 CRF= 0.1315

**FUEL SPECIFICATIONS**

FC= 4.85 H= 18500. S= 3.00 A= 0.10

**PM EMISSIONS**

UNC= 0.230 CTR= 0.050 EFF= 78.30 CRF= 0.1315

**SO2 EMISSIONS**

UNC= 3.210 CTR= 0.321 EFF= 90.00 CRF= 0.1315

**COST RATES**

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

**COST SUMMARY TABLE - RUN NO. 6**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	115427.	0.	0.	112477.	227904.
INST	185897.	0.	0.	131599.	317496.
TD	301324.	0.	181732.	244076.	727132.
IND	99259.	0.	0.	81521.	180780.
TDI	400583.	0.	0.	325597.	726180.
CONT	80117.	0.	0.	65119.	145236.
TK	480699.	0.	343363.	390717.	1214779.
LAND	2000.	0.	0.	0.	2000.
WC	94718.	0.	47649.	5205.	147572.
TOTL	577417.	0.	391012.	395922.	1364350.
DL	52584.	0.	105000.	8331.	165915.
SPRV	34207.	0.	21000.	0.	55207.
MANT	15980.	0.	14539.	9335.	39853.
SP	20522.	0.	0.	1797.	22320.
ELEC	0.	0.	1632.	0.	1632.
UC	21998.	0.	0.	1356.	23354.
WTR	0.	0.	316.	0.	316.
SW	0.	0.	0.	0.	0.
SLDG	0.	0.	7172.	0.	7172.
LW	0.	0.	3911.	0.	3911.
SC	0.	0.	37025.	0.	37025.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	701019.	0.	0.	0.	701019.
TDOM	846311.	0.	190596.	20819.	1057725.
OH	47832.	0.	68040.	7560.	123431.
TOTL	894142.	0.	258636.	28379.	1181156.
CR	63212.	0.	45152.	51379.	159743.
WCC	9472.	0.	4765.	520.	14757.
MISC	19228.	0.	13735.	15629.	48591.
TCC	91912.	0.	63652.	67528.	223092.
TOTL	986054.	0.	322288.	95907.	1404248.

RES-30-DA(90), DA/PM

MODEL BOILER 7                                  4-07-82  
 BOILER ROUTINE RES1    SO2 ROUTINE= DAC                                  PM ROUTINE=                                  FLOW FLAG=    6

S STAR (METRIC)=    0.628  
 S DSTAR (METRIC)=    19.858  
 P DSTAR (METRIC)=    1.035  
**BOILER SPECIFICATIONS**  
 Q=    30.0 FLW= 9007. CF= 0.550 CRF= 0.1315  
**FUEL SPECIFICATIONS**  
 FC=    4.85 H= 18500. S= 3.00 A= 0.10  
**PM EMISSIONS**  
 UNC= 0.230 CTR= 0.100 EFF= 56.50 CRF= 0.1315  
**SO2 EMISSIONS**  
 UNC= 3.210 CTR= 0.321 EFF= 90.00 CRF= 0.1315  
**COST RATES**  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

**COST SUMMARY TABLE - RUN NO. 7**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	115427.	0.	0.	0.	115427.
INST	185897.	0.	0.	0.	185897.
TD	301324.	0.	467849.	0.	769172.
IND	99259.	0.	0.	0.	99259.
TDI	400583.	0.	0.	0.	400583.
CONT	80117.	0.	0.	0.	80117.
TK	480699.	0.	786016.	0.	1266714.
LAND	2000.	0.	0.	0.	2000.
WC	94718.	0.	46296.	0.	141014.
TOTL	577417.	0.	832312.	0.	1409728.
DL	52584.	0.	105000.	0.	157584.
SPRV	34207.	0.	21000.	0.	55207.
MANT	15980.	0.	37428.	0.	53408.
SP	20522.	0.	0.	0.	20522.
ELEC	0.	0.	3025.	0.	3025.
UC	21998.	0.	0.	0.	21998.
WTR	0.	0.	204.	0.	204.
SW	0.	0.	0.	0.	0.
SLDG	0.	0.	12034.	0.	12034.
LW	0.	0.	0.	0.	0.
SC	0.	0.	713.	0.	713.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	5780.	0.	5780.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	701019.	0.	0.	0.	701019.
TDOM	846311.	0.	185184.	0.	1031495.
OH	47832.	0.	73991.	0.	121823.
TOTL	894142.	0.	259175.	0.	1153317.
CR	63212.	0.	103361.	0.	166573.
WCC	9472.	0.	4630.	0.	14101.
MISC	19228.	0.	31441.	0.	50669.
TCC	91912.	0.	139431.	0.	231343.
TOTL	986054.	0.	398607.	0.	1384660.

## RES-30-DA(90), ESP

MODEL BOILER 8  
 BOILER ROUTINE RES1 SO2 ROUTINE= DA 4-07-82 PM ROUTINE= ESPO FLOW FLAG= 6

S STAR (METRIC)= 0.628  
 S DSTAR (METRIC)= 19.858

SPECIFIC COLLECTOR AREA(SQ FT/1000 ACFM)= 400.0  
 TOTAL PLATE AREA (SQ FT)= 3602.7

## BOILER SPECIFICATIONS

Q= 30.0 FLW= 9007. CF= 0.550 CRF= 0.1315

## FUEL SPECIFICATIONS

FC= 4.85 H= 18500. S= 3.00 A= 0.10

## PM EMISSIONS

UNC= 0.230 CTR= 0.050 EFF= 78.30 CRF= 0.1315

## SO2 EMISSIONS

UNC= 3.210 CTR= 0.321 EFF= 90.00 CRF= 0.1315

## COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

## COST SUMMARY TABLE - RUN NO. 8

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	115427.	0.	0.	112477.	227904.
INST	185897.	0.	0.	131599.	317196.
TD	301324.	0.	375895.	244076.	921294.
IND	99259.	0.	0.	81521.	180780.
TDI	400583.	0.	0.	325597.	726180.
CONT	80117.	0.	0.	65119.	145236.
TK	480699.	0.	649924.	390717.	1521339.
LAND	2000.	0.	0.	0.	2000.
WC	94718.	0.	44044.	5205.	143967.
TOTL	577417.	0.	693968.	395922.	1667305.
DL	52584.	0.	105000.	8331.	165915.
SPRV	34207.	0.	21000.	0.	55207.
MANT	15980.	0.	30072.	9335.	55386.
SP	20522.	0.	0.	1797.	22320.
ELEC	0.	0.	1456.	0.	1456.
UC	21998.	0.	0.	1356.	23354.
WTR	0.	0.	204.	0.	204.
SW	0.	0.	0.	0.	0.
SLDG	0.	0.	11951.	0.	11951.
LW	0.	0.	0.	0.	0.
SC	0.	0.	713.	0.	713.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	5780.	0.	5780.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	701019.	0.	0.	0.	701019.
TDOM	846311.	0.	176176.	20819.	1043306.
OH	47832.	0.	72079.	7560.	127470.
TOTL	894142.	0.	248254.	28379.	1170774.
CR	63212.	0.	85465.	51379.	200056.
WCC	9472.	0.	4404.	520.	14397.
MISC	19228.	0.	25997.	15629.	60854.
TCC	91912.	0.	115866.	67528.	275306.
TOTL	986054.	0.	364121.	95907.	1446081.

RES-150-Unc, Unc

MODEL BOILER	9	4-07-82			
BOILER ROUTINE RNG1	SO2 ROUTINE=	PM ROUTINE=		FLOW FLAG=	6
<b>BOILER SPECIFICATIONS</b>					
Q= 150.0 FLW= 45034. CF= 0.550 CRF= 0.1315					
<b>FUEL SPECIFICATIONS</b>					
FC= 4.85 H= 18500. S= 3.00 A= 0.10					
<b>PM EMISSIONS</b>					
UNC= 0.230 CTR= 0.050 EFF= 78.30 CRF= 0.1315					
<b>SO2 EMISSIONS</b>					
UNC= CTR= EFF= CRF=					
<b>COST RATES</b>					
ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80					
<b>COST SUMMARY TABLE - RUN NO. 9</b>					
ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	773660.	0.	0.	0.	773660.
INST	339734.	0.	0.	0.	339734.
TD	1113393.	0.	0.	0.	1113393.
IND	357298.	0.	0.	0.	357298.
TDI	1470690.	0.	0.	0.	1470690.
CONT	294138.	0.	0.	0.	294138.
TK	1764827.	0.	0.	0.	1764827.
LAND	2000.	0.	0.	0.	2000.
WC	359108.	0.	0.	0.	359108.
TOTL	2125934.	0.	0.	0.	2125934.
DL	105825.	0.	0.	0.	105825.
SPRV	34207.	0.	0.	0.	34207.
MANT	34329.	0.	0.	0.	34329.
SP	48068.	0.	0.	0.	48068.
ELEC	0.	0.	0.	0.	0.
UC	46105.	0.	0.	0.	46105.
WTR	0.	0.	0.	0.	0.
SW	0.	0.	0.	0.	0.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3505095.	0.	0.	0.	3505095.
TDOM	3773628.	0.	0.	0.	3773628.
OH	89579.	0.	0.	0.	89579.
TOTL	3863206.	0.	0.	0.	3863206.
CR	232075.	0.	0.	0.	232075.
WCC	35911.	0.	0.	0.	35911.
MISC	70593.	0.	0.	0.	70593.
TCC	338579.	0.	0.	0.	338579.
TOTL	4201784.	0.	0.	0.	4201784.

RES-150-Unc, ESP

MODEL BOILER 10  
 BOILER ROUTINE RNG1 SO2 ROUTINE= 4-07-82 PM ROUTINE= ESPO FLOW FLAG= 6

SPECIFIC COLLECTOR AREA(SQ FT/1000 ACFM)= 400.0

TOTAL PLATE AREA (SQ FT)= 18013.7

**BOILER SPECIFICATIONS**

Q= 150.0 FLW= 45034. CF= 0.550 CRF= 0.1315

**FUEL SPECIFICATIONS**

FC= 4.85 H= 18500. S= 3.00 A= 0.10

**PM EMISSIONS**

UNC= 0.230 CTR= 0.050 EFF= 78.30 CRF= 0.1315

**SO2 EMISSIONS**

UNC= CTR= EFF= CRF=

**COST RATES**

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE - RUN NO. 10

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	773660.	0.	0.	311087.	1084746.
INST	339734.	0.	0.	342196.	681930.
TD	1113393.	0.	0.	653282.	1766675.
IND	357298.	0.	0.	218196.	575494.
TDI	1470690.	0.	0.	871479.	2342168.
CONT	294138.	0.	0.	174296.	468434.
TK	1764827.	0.	0.	1045774.	2810601.
LAND	2000.	0.	0.	0.	2000.
WC	359108.	0.	0.	9659.	368767.
TOTL	2125934.	0.	0.	1055433.	3181367.
DL	105825.	0.	0.	16281.	122106.
SPRV	34207.	0.	0.	0.	34207.
MANT	34329.	0.	0.	10766.	45094.
SP	48068.	0.	0.	4811.	52878.
ELEC	0.	0.	0.	0.	0.
UC	46105.	0.	0.	6780.	52885.
WTR	0.	0.	0.	0.	0.
SW	0.	0.	0.	0.	0.
SLDG	0.	0.	0.	0.	0.
LW	0.	0.	0.	0.	0.
SC	0.	0.	0.	0.	0.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	0.	0.	0.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3505095.	0.	0.	0.	3505095.
TDOM	3773628.	0.	0.	38637.	3812265.
OH	89579.	0.	0.	13167.	102746.
TOTL	3863206.	0.	0.	51805.	3915010.
CR	232075.	0.	0.	137519.	369594.
WCC	35911.	0.	0.	966.	36877.
MISC	70593.	0.	0.	41831.	112424.
TCC	338579.	0.	0.	180316.	518895.
TOTL	4201784.	0.	0.	232121.	4433904.

## RES-150-DA(50), DA/PM

MODEL BOILER 11

4-07-82

BOILER ROUTINE RNG1 SO2 ROUTINE= DAC PM ROUTINE= FLOW FLAG= 6

S STAR (METRIC)= 0.349  
 S DSTAR (METRIC)= 55.160  
 P DSTAR (METRIC)= 5.175

## BOILER SPECIFICATIONS

Q= 150.0 FLW= 45034. CF= 0.550 CRF= 0.1315

## FUEL SPECIFICATIONS

FC= 4.85 H= 18500. S= 3.00 A= 0.10

## PM EMISSIONS

UNC= 0.230 CTR= 0.100 EFF= 56.50 CRF= 0.1315

## SO2 EMISSIONS

UNC= 3.210 CTR= 1.610 EFF= 50.00 CRF= 0.1315

## COST RATES

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

## COST SUMMARY TABLE - RUN NO. 11

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	773660.	0.	0.	0.	773660.
INST	339734.	0.	0.	0.	339734.
TD	1113393.	0.	797059.	0.	1910451.
IND	357298.	0.	0.	0.	357298.
TDI	1470690.	0.	0.	0.	1470690.
CCNT	294138.	0.	0.	0.	294138.
TK	1764827.	0.	1273246.	0.	3038073.
LAND	2000.	0.	0.	0.	2000.
WC	359108.	0.	64991.	0.	424099.
TOTL	2125934.	0.	1338236.	0.	3464170.
DL	105825.	0.	105000.	0.	210825.
SPRV	34207.	0.	21000.	0.	55207.
MANT	34329.	0.	63765.	0.	98093.
SP	48068.	0.	0.	0.	48068.
ELEC	0.	0.	14581.	0.	14581.
UC	46105.	0.	0.	0.	46105.
WTR	0.	0.	747.	0.	747.
SW	0.	0.	0.	0.	0.
SLDG	0.	0.	34083.	0.	34083.
LW	0.	0.	0.	0.	0.
SC	0.	0.	4454.	0.	4454.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	16335.	0.	16335.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3505095.	0.	0.	0.	3505095.
TDOM	3773628.	0.	259964.	0.	4033591.
OH	89579.	0.	80839.	0.	170417.
TOTL	3863206.	0.	340802.	0.	4204008.
CR	232075.	0.	167432.	0.	399507.
WCC	35911.	0.	6499.	0.	42410.
MISC	70593.	0.	50930.	0.	121523.
TCC	338579.	0.	224861.	0.	563439.
TOTL	4201784.	0.	565663.	0.	4767447.

RES-150-DA(50), ESP

MODEL BOILER 12                          4-07-82  
 BOILER ROUTINE RNG1    SO2 ROUTINE= DA                          PM ROUTINE= ESPO                          FLOW FLAG= 6

S STAR (METRIC)= 0.349  
 S DSTAR (METRIC)= 55.160

SPECIFIC COLLECTOR AREA(SQ FT/1000 ACFM)= 400.0  
 TOTAL PLATE AREA (SQ FT)= 18013.7

**BOILER SPECIFICATIONS**

Q= 150.0 FLW= 45034. CF= 0.550 CRF= 0.1315

**FUEL SPECIFICATIONS**

FC= 4.85 H= 18500. S= 3.00 A= 0.10

**PM EMISSIONS**

UNC= 0.230 CTR= 0.050 EFF= 78.30 CRF= 0.1315

**SO2 EMISSIONS**

UNC= 3.210 CTR= 1.610 EFF= 50.00 CRF= 0.1315

**COST RATES**

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

**COST SUMMARY TABLE - RUN NO. 12**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUP	773660.	0.	0.	311087.	1084746.
INST	339734.	0.	0.	342196.	681930.
TD	1113393.	0.	688805.	653282.	2455480.

IND	357298.	0.	0.	218196.	575494.
TDI	1470690.	0.	0.	871479.	2342168.
CONT	294138.	0.	0.	174296.	468434.
TK	1764827.	0.	1113031.	1045774.	3923632.
LAND	2000.	0.	0.	0.	2000.
WC	359108.	0.	60832.	9659.	429598.
TOTL	2125934.	0.	1173862.	1055433.	4355229.
DL	105825.	0.	105000.	16281.	227106.
SPRV	34207.	0.	21000.	0.	55207.
MANT	34329.	0.	55104.	10766.	100199.
SP	48068.	0.	0.	4811.	52878.
ELEC	0.	0.	7016.	0.	7016.
UC	46105.	0.	0.	6780.	52885.
WTR	0.	0.	747.	0.	747.
SW	0.	0.	0.	0.	0.
SLDG	0.	0.	33671.	0.	33671.
LW	0.	0.	0.	0.	0.
SC	0.	0.	4454.	0.	4454.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	16335.	0.	16335.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3505095.	0.	0.	0.	3505095.
TDOM	3773628.	0.	243326.	38637.	4055591.
OH	89579.	0.	78587.	13167.	181333.
TOTL	3863206.	0.	321914.	51805.	4236923.
CR	232075.	0.	146364.	137519.	515958.
WCC	35911.	0.	6083.	966.	42960.
MISC	70593.	0.	44521.	41831.	156945.
TCC	338579.	0.	196968.	180316.	715863.
TOTL	4201784.	0.	518881.	232121.	4952785.

## RES-150-DA(90), DA/PM

MODEL BOILER 13                          4-07-82  
 BOILER ROUTINE RNG1    SO2 ROUTINE= DAC    PM ROUTINE=                          FLOW FLAG= 6

S STAR (METRIC)= 0.628  
 S DSTAR (METRIC)= 99.289  
 P DSTAR (METRIC)= 5.175  
 BOILER SPECIFICATIONS

Q= 150.0 FLW= 45034. CF= 0.550 CRF= 0.1315  
 FUEL SPECIFICATIONS  
 FC= , 4.85 H= 18500. S= 3.00 A= 0.10  
 PM EMISSIONS  
 UNC= 0.230 CTR= 0.100 EFF= 56.50 CRF= 0.1315  
 SO2 EMISSIONS  
 UNC= 3.210 CTR= 0.321 EFF= 90.00 CRF= 0.1315  
 COST RATES  
 ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

COST SUMMARY TABLE RUN NO. 13

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	773660.	0.	0.	0.	773660.
INST	339734.	0.	0.	0.	339734.
TD	1113393.	0.	881329.	0.	1994722.
IND	357298.	0.	0.	0.	357298.
TDI	1470690.	0.	0.	0.	1470690.
CONT	294138.	0.	0.	0.	294138.
TK	1764827.	0.	1397966.	0.	3162793.
LAND	2000.	0.	0.	0.	2000.
WC	359108.	0.	77227.	0.	436335.
TOTL	2125934.	0.	1475193.	0.	3601127.
DL	105825.	0.	105000.	0.	210825.
SPRV	34207.	0.	21000.	0.	55207.
MANT	34329.	0.	70506.	0.	104835.
SP	48068.	0.	0.	0.	48068.
ELEC	0.	0.	15126.	0.	15126.
UC	46105.	0.	0.	0.	46105.
WTR	0.	0.	806.	0.	806.
SW	0..	0.	0.	0.	0.
SLDG	0.	0.	61232.	0.	61232.
LW	0.	0.	0.	0.	0.
SC	0.	0.	5710.	0.	5710.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	29529.	0.	29529.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3505095.	0.	0.	0.	3505095.
TDOM	3773628.	0.	308910.	0.	4082537.
OH	89579.	0.	82592.	0.	172170.
TOTL	3863206.	0.	391502.	0.	4254707.
CR	232075.	0.	183833.	0.	415907.
WCC	35911.	0.	7723.	0.	43634.
MISC	70593.	0.	55919.	0.	126512.
TCC	338579.	0.	247474.	0.	586052.
TOTL	4201784.	0.	638975.	0.	4840759.

RES-150-DA(90), ESP

MODEL BOILER 14                          4-07-82  
 BOILER ROUTINE RNG1    SO2 ROUTINE= DA                          PM ROUTINE= ESPO                          FLOW FLAG= 6

S STAR (METRIC)= 0.628  
 S DSTAR (METRIC)= 99.289

SPECIFIC COLLECTOR AREA(SQ FT/1000 ACFM)= 400.0

TOTAL PLATE AREA (SQ FT)= 18013.7

**BOILER SPECIFICATIONS**

Q= 150.0 FLW= 45034. CF= 0.550 CRF= 0.1315

**FUEL SPECIFICATIONS**

FC= 4.85 H= 18500. S= 3.00 A= 0.10

**PM EMISSIONS**

UNC= 0.230 CTR= 0.050 EFF= 78.30 CRF= 0.1315

**SO2 EMISSIONS**

UNC= 3.210 CTR= 0.321 EFF= 90.00 CRF= 0.1315

**COST RATES**

ELEC= 0.0258 WTR= 0.15 LIME= 35.00 ALS= 8.00 SASH= 90.00 SLDG= 15.00 SWD= 15.00 ALWD= 1.80

**COST SUMMARY TABLE - RUN NO. 14**

ITEM	BOILER	NOX CONTROL	SO2 CONTROL	PM CONTROL	TOTAL
EQUIP	773660.	0.	0.	311087.	1084746.
INST	339734.	0.	0.	342196.	681930.
TD	1113393.	0.	791121.	653282.	2557796.
IND	357298.	0.	0.	218196.	575494.
TDI	1470690.	0.	0.	871479.	2342168.
CONT	294138.	0.	0.	174296.	468434.
TK	1764827.	0.	1264459.	1045774.	4075060.
LAND	2000.	0.	0.	0.	2000.
WC	359108.	0.	73358.	9659.	442125.
TOTL	2125934.	0.	1337817.	1055433.	4519184.

DL	105825.	0.	105000.	16281.	227106.
SPRV	34207.	0.	21000.	0.	55207.
MANT	34329.	0.	63290.	10766.	108384.
SP	48068.	0.	0.	4811.	52878.
ELEC	0.	0.	7278.	0.	7278.
UC	46105.	0.	0.	6780.	52885.
WTR	0.	0.	806.	0.	806.
SW	0.	0.	0.	0.	0.
SLDG	0.	0.	60820.	0.	60820.
LW	0.	0.	0.	0.	0.
SC	0.	0.	5710.	0.	5710.
LMS	0.	0.	0.	0.	0.
LIME	0.	0.	29529.	0.	29529.
NH3	0.	0.	0.	0.	0.
LYE	0.	0.	0.	0.	0.
FUEL	3505095.	0.	0.	0.	3505095.
TDOM	3773628.	0.	293434.	38637.	4105698.
OH	89579.	0.	80715.	13167.	183461.
TOTL	3863206.	0.	374149.	51805.	4289159.
CR	232075.	0.	166276.	137519.	535870.
WCC	35911.	0.	7336.	966.	44213.
MISC	70593.	0.	50578.	41831.	163002.
TCC	338579.	0.	224190.	180316.	743085.
TOTL	4201784.	0.	598339.	232121.	5032243.

## APPENDIX D

### COST ESCALATION METHODS

Two cost escalation methods are presented for converting the costs presented in this report (mid-1978 \$) to a later year basis. Both methods account for the general inflation trend in equipment and labor.

It is important to differentiate between nominal and real interest rates when using these methods. The nominal interest rate is the actual cost of capital without adjustment for inflation. This is the contract rate paid to acquire capital to construct a control device. The real interest rate is the nominal rate adjusted for inflation. This interest rate is the rate paid for capital in constant dollars. For example, if the nominal interest rate was 16 percent and the general inflation rate was 10 percent then the real interest rate would be 6 percent.

The two escalation methods differ in where the cost escalation to current dollars occurs in the calculations. In the real interest method, all costing is done in constant 1978 dollars using the real interest rate. Then, the resulting annualized cost is brought up to current dollars using a factor to account for inflation. In the nominal interest method, the individual costs of equipment and labor are each brought up to current dollars using inflation factors first. Then, a nominal interest rate is used to calculate the annualized costs. The result is the current dollar cost in the first year. Each subsequent year uses the same capital cost charge but must have the operation and maintenance costs adjusted to that year. Thus, the second method has the disadvantage of not giving a constant dollar level cost for the life of the project. Instead, it tends to "front end load" the cost since the capital charge component of the annualized costs in constant dollars goes down each year.

To convert costs to a later year basis, the following escalation factors may be used:<sup>1</sup>

<u>Basis</u>	<u>Escalation Factor</u>
mid-1979	1.09
mid-1980	1.19
mid-1981	1.37
mid-1982	1.44

---

<sup>1</sup>Economic Indicators. Chemical Engineering. 85(21):7, September 25, 1978; 86(20):7, September 24, 1979; 87(21):7, October 20, 1980; 88(21):7, October 19, 1981; 89(9):7, August \_\_, 1982; 90( ):7.

**TECHNICAL REPORT DATA**  
*(Please read Instructions on the reverse before completing)*

1. REPORT NO. EPA-450/3/82-021	2.	3. RECIPIENT'S ACCESSION NO.
4. TITLE AND SUBTITLE <b>Costs of Sulfur Dioxide, Particulate Matter, and Nitrogen Oxide Controls on Fossil Fuel Fired Industrial Boilers</b>		5. REPORT DATE August 1982
7. AUTHOR(S)		6. PERFORMING ORGANIZATION CODE
9. PERFORMING ORGANIZATION NAME AND ADDRESS Office of Air Quality Planning and Standards U.S. Environmental Protection Agency Research Triangle Park, North Carolina 27711		8. PERFORMING ORGANIZATION REPORT NO.
		10. PROGRAM ELEMENT NO.
		11. CONTRACT/GRANT NO. 68-02-3058
12. SPONSORING AGENCY NAME AND ADDRESS DAA for Air Quality Planning and Standards Office of Air, Noise, and Radiation U.S. Environmental Protection Agency Research Triangle Park, North Carolina 27711		13. TYPE OF REPORT AND PERIOD COVERED Final
		14. SPONSORING AGENCY CODE
15. SUPPLEMENTARY NOTES		
16. ABSTRACT  This report is a resource document for the development of Federal standards of performance for control of sulfur dioxide, particulate matter and nitrogen oxides emissions from new industrial boilers. It gives capital and annualized costs for a variety of control technologies that can be applied to gas, oil, and coal fired industrial boilers. In addition to control costs for 30, 75, 150, and 400 million Btu per hour size model boilers, cost algorithms and a computer program are given in detail to allow for automated cost data development.		
17. KEY WORDS AND DOCUMENT ANALYSIS		
a. DESCRIPTORS  Boilers, Industrial Costs, Capital and Annualized Air Pollution Control Costs	b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group
18. DISTRIBUTION STATEMENT Unlimited		19. SECURITY CLASS ( <i>This Report</i> ) Unclassified
		20. SECURITY CLASS ( <i>This page</i> ) Unclassified
		21. NO. OF PAGES . 245
		22. PRICE