

United States
Environmental Protection
Agency


Office of Air Quality
Planning and Standards
Research Triangle Park NC 27711

EPA-450/3-89-16
May 1989

Air



Model Boiler Cost Analysis for Controlling Nitrogen Oxides (NO_x) Emissions from Small Steam Generating Units



NSPS

**MODEL BOILER COST ANALYSIS
FOR CONTROLLING NITROGEN OXIDES (NO_x)
EMISSIONS FROM SMALL STEAM GENERATING UNITS**

Emission Standards Division

U.S. Environmental Protection Agency
Office of Air and Radiation
Office of Air Quality Planning and Standards
Research Triangle Park, N.C. 27711

May 1989

This report has been reviewed by the Emission Standards Division of the Office of Air Quality Planning and Standards, EPA, and approved for publication. Mention of trade names or commercial products is not intended to constitute endorsement or recommendation of use. Copies of the report are available through the Library Service Office (MD-35), U.S. Environmental Protection Agency, Research Triangle Park, N.C. 27711, or from National Technical Information Services, 5285 Port Royal Road, Springfield, Virginia 22161.

TABLE OF CONTENTS

| <u>Section</u> | | <u>Page</u> |
|----------------|---|-------------|
| 1.0 | INTRODUCTION..... | 1 |
| 2.0 | SUMMARY..... | 2 |
| 3.0 | MODEL BOILER COSTING METHODOLOGY..... | 4 |
| 4.0 | MODEL BOILER COST ANALYSIS RESULTS..... | 6 |
| | 4.1 NATURAL GAS, INDUSTRIAL FUEL PRICE..... | 6 |
| | 4.2 NATURAL GAS, COMMERCIAL FUEL PRICE..... | 7 |
| | 4.3 DISTILLATE OIL..... | 8 |
| | 4.4 RESIDUAL OIL..... | 9 |
| | 4.5 COAL..... | 9 |
| 5.0 | REFERENCES..... | 10 |

LIST OF TABLES

| <u>Table</u> | <u>Page</u> |
|--------------|---|
| 1 | PROJECTED FUEL PRICES FOR EPA REGION V..... 11 |
| 2 | MODEL BOILER NO. COST ANALYSIS FOR NATURAL GAS-FIRED BOILERS IN REGION V: INDUSTRIAL FUEL PRICES AND 0.26 CAPACITY FACTOR..... 12 |
| 3 | MODEL BOILER NO. COST ANALYSIS FOR NATURAL GAS-FIRED BOILERS IN REGION V: INDUSTRIAL FUEL PRICES AND 0.55 CAPACITY FACTOR..... 13 |
| 4 | COST-EFFECTIVENESS RESULTS FOR NATURAL GAS-FIRED BOILERS IN REGION V: INDUSTRIAL FUEL PRICES AND 0.26 CAPACITY FACTOR..... 14 |
| 5 | COST-EFFECTIVENESS RESULTS FOR NATURAL GAS-FIRED BOILERS IN REGION V: INDUSTRIAL FUEL PRICES AND 0.55 CAPACITY FACTOR..... 15 |
| 6 | MODEL BOILER NO. COST ANALYSIS FOR NATURAL GAS-FIRED BOILERS IN REGION V: COMMERCIAL FUEL PRICES AND 0.26 CAPACITY FACTOR..... 16 |
| 7 | MODEL BOILER NO. COST ANALYSIS FOR NATURAL GAS-FIRED BOILERS IN REGION V: COMMERCIAL FUEL PRICES AND 0.55 CAPACITY FACTOR..... 17 |
| 8 | COST-EFFECTIVENESS RESULTS FOR NATURAL GAS-FIRED BOILERS IN REGION V: COMMERCIAL FUEL PRICES AND 0.26 CAPACITY FACTOR..... 18 |
| 9 | COST-EFFECTIVENESS RESULTS FOR NATURAL GAS-FIRED BOILERS IN REGION V: COMMERCIAL FUEL PRICES AND 0.55 CAPACITY FACTOR..... 19 |
| 10 | MODEL BOILER NO. COST ANALYSIS FOR DISTILLATE OIL-FIRED BOILERS IN REGION V: 0.26 CAPACITY FACTOR..... 20 |
| 11 | MODEL BOILER NO. COST ANALYSIS FOR DISTILLATE OIL-FIRED BOILERS IN REGION V: 0.55 CAPACITY FACTOR..... 21 |
| 12 | COST-EFFECTIVENESS RESULTS FOR DISTILLATE OIL-FIRED BOILERS IN REGION V: 0.26 CAPACITY FACTOR..... 22 |
| 13 | COST-EFFECTIVENESS RESULTS FOR DISTILLATE OIL-FIRED BOILERS IN REGION V: 0.55 CAPACITY FACTOR..... 23 |

LIST OF TABLES (CONTINUED)

| <u>Table</u> | | <u>Page</u> |
|--------------|---|-------------|
| 14 | MODEL BOILER NO. COST FOR RESIDUAL OIL-FIRED BOILERS IN REGION V: 0 ^x .26 CAPACITY FACTOR..... | 24 |
| 15 | MODEL BOILER NO. COST FOR RESIDUAL OIL-FIRED BOILERS IN REGION V: 0 ^x .55 CAPACITY FACTOR..... | 25 |
| 16 | COST-EFFECTIVENESS RESULTS FOR RESIDUAL OIL-FIRED BOILERS IN REGION V: 0.26 CAPACITY FACTOR..... | 26 |
| 17 | COST-EFFECTIVENESS RESULTS FOR RESIDUAL OIL-FIRED BOILERS IN REGION V: 0.55 CAPACITY FACTOR..... | 27 |
| 18 | MODEL BOILER NO. COST ANALYSIS FOR COAL-FIRED BOILERS IN REGION V: 0 ^x .26 CAPACITY FACTOR..... | 28 |
| 19 | MODEL BOILER NO. COST ANALYSIS FOR COAL-FIRED BOILERS IN REGION V: 0 ^x .55 CAPACITY FACTOR..... | 29 |
| 20 | COST-EFFECTIVENESS RESULTS FOR COAL-FIRED BOILERS IN REGION V: 0.26 CAPACITY FACTOR..... | 30 |
| 21 | COST-EFFECTIVENESS RESULTS FOR COAL-FIRED BOILERS IN REGION V: 0.55 CAPACITY FACTOR..... | 31 |

1.0 INTRODUCTION

This report presents estimates of the costs and cost effectiveness associated with controlling nitrogen oxides (NO_x) emissions from small boilers. The report was prepared as part of the project to develop new source performance standards (NSPS) for small boilers under Section 111 of the Clean Air Act. Small boilers are defined as industrial-commercial-institutional boilers having heat input capacities of 29 MW (100 million Btu/hour) or less. A discussion of available NO_x emissions data is presented in the report entitled, "Overview of the Regulatory Baseline, Technical Basis, and Alternative Control Levels for Nitrogen Oxides (NO_x) Emission Standards for Small Steam Generating Units".¹

As discussed in Reference 1, it is not possible to establish uncontrolled or controlled NO_x emission levels for small boilers. However, in order to develop estimates of the potential cost and cost effectiveness of NO_x control for small boilers, it was assumed that low excess air (LEA) technology could reduce NO_x emissions from uncontrolled levels by 20 percent. Furthermore, it was assumed that baseline (i.e., uncontrolled) emissions could be approximated as the midpoint of the range of uncontrolled NO_x emissions data for each fuel/boiler type combination. For this reason, however, the emission reduction estimates and corresponding cost and cost effectiveness values can only be viewed as rough approximations and are of use for example purposes only.²

2.0 SUMMARY

Capital, operation and maintenance (O&M), and annualized costs were estimated for model boilers firing natural gas, distillate oil, residual oil, and coal. Boilers with a range of heat input capacities were examined. Costs were determined for both uncontrolled model boilers and model boilers equipped with LEA for NO_x control. Rough approximations of baseline (i.e., uncontrolled) and controlled (LEA) NO_x emissions were used to estimate the cost effectiveness of applying NO_x controls to small boilers.

The results of the analysis are presented in Tables 2 through 21. These tables show similar trends in costs and cost effectiveness for each fuel type. The difference in capital costs between baseline and NO_x-controlled boilers decreases with increasing boiler size. This can be attributed to the economies of scale associated with LEA application and its associated compliance requirements. The difference in annualized costs decreases with increasing boiler size and capacity factor. This trend results from the increased boiler efficiencies provided by operating with LEA, which translate into fuel savings. These fuel savings act to offset the additional LEA costs for spare parts, maintenance, and annualized capital costs.

For boilers subject to continuous compliance and ranging in size from 2.9 to 29 MW (10 to 100 million Btu/hour) and in capacity factor from 0.26 to 0.55, the cost effectiveness of LEA ranges from:

- o natural gas (priced for the industrial sector) - \$314,000 to \$3,110/Mg (\$285,000 to \$2,820/ton);
- o natural gas (priced for the commercial sector) - \$314,000 to \$2,440/Mg (\$285,000 to \$1,850/ton);
- o distillate oil - \$156,000 to \$2,440/Mg (\$141,000 to \$2,220/ton);
- o residual oil - \$104,000 to \$1,610/Mg (\$94,000 to \$1,460/ton); and
- o coal - \$107,000 to \$2,350/Mg (\$97,000 to \$2,130/ton).

Requiring excess emission reporting rather than continuous compliance results in lower cost effectiveness values. For boilers ranging from 2.9 to 29 MW (10 to 100 million Btu/hour) in size and in capacity factor from 0.26 to 0.55, the cost effectiveness of LEA ranges from:

- o natural gas (priced for the industrial sector) - \$225,000 to \$1,040/Mg (\$205,000 to \$940/ton);
- o natural gas (priced for the commercial sector) - \$225,000 to \$0/Mg (\$205,000 to \$0/ton);
- o distillate oil - \$112,000 to (-\$305)/Mg [\$102,000 to (-\$277)/ton];
- o residual oil - \$75,000 to \$576/Mg (\$68,000 to \$522/ton); and
- o coal - \$78,100 to \$1,520/Mg (\$70,900 to \$1,380/ton).

3.0 MODEL BOILER COSTING METHODOLOGY

This model boiler cost analysis estimates capital, O&M, and annualized costs using the methodology discussed in Reference 3. The selection of the model boiler types and sizes used in this analysis is discussed in Reference 4. All costs are presented in June 1985 dollars. Capital and O&M costs were updated from other time bases using the Chemical Engineering (CE) plant cost and Bureau of Labor Statistics (BLS) producer price indices, respectively. The total cost for each model system includes the costs of the boiler, fuel, and add-on NO_x control equipment, where applicable.

Nitrogen oxides control for all fuel/boiler types is based on the application of LEA combustion modification. A description of LEA technology is provided in Reference 1. The additional equipment and modifications required for LEA control are an oxygen trim system (comprising an oxygen analyzer and air flow regulators) and windbox modifications (for multi-burner boilers).⁵ These account for the increased capital costs required for installing LEA on an uncontrolled boiler.

Annual O&M costs increase with the application of LEA due to associated costs for spare parts, maintenance labor, and maintenance materials. However, these cost increases are offset, in part, by lower fuel requirements for LEA-controlled boilers compared to uncontrolled boilers because of the higher boiler efficiencies associated with LEA operation. Lower fuel requirements translate to lower annual fuel costs.

The fuel prices used in this analysis are projected delivered fuel prices in EPA Region V for the time period from 1992 to 2007. These prices, presented in Table 1, have been levelized over this period and are expressed in June 1985 dollars.^{6,7} Region V fuel prices were used for illustrative purposes. Similar cost results are expected for other EPA regions.

Two sets of natural gas price projections are used in this analysis corresponding to boilers operating in the industrial and commercial natural gas market sectors. Projected prices for coal, residual oil, and distillate oil, on the other hand, are not expected to vary significantly between these sectors. Hence, only one set of price projections is used for these boiler fuels.

The two boiler compliance options examined in this memorandum are: (1) continuous compliance, including Appendix F quality assurance procedures; and (2) excess emission reporting requirements. Continuous compliance increases capital costs by \$10,000 over excess emission reporting, due primarily to the development of a required quality control plan. Annual O&M costs are \$17,000 greater for continuous compliance than for excess emission reporting.

4.0 MODEL BOILER COST ANALYSIS RESULTS

4.1 NATURAL GAS, INDUSTRIAL FUEL PRICE

Tables 2 and 3 present the costs of both uncontrolled and LEA-equipped model boilers operating at capacity factors of 0.26 and 0.55, respectively. Capital costs for boilers equipped with LEA are about 25 percent higher than baseline costs at the 2.9 MW (10 million Btu/hour) size. This capital cost increase drops to about 5 percent at the 29 MW (100 million Btu/hour) size. This decrease is due to the economies of scale associated with LEA application (and compliance requirements) and is observed for each fuel type examined.

For the 0.26 capacity factor, applying LEA increases annualized costs by roughly 16 percent over baseline costs at the 2.9 MW (10 million Btu/hour) boiler size and by 2 percent at the 29 MW (100 million Btu/hour) boiler size. This decline in the cost increase associated with the use of LEA is primarily due to the increased fuel savings resulting from LEA use in larger boiler sizes. As discussed in Section 3.0, the application of LEA control results in higher boiler efficiencies and, hence, lower annual fuel costs than baseline boilers. As boiler size and capacity factor increase, the magnitude of this fuel cost savings increases and acts to offset the additional LEA costs for spare parts, maintenance, and annualized capital costs. These trends are observed for each fuel type examined.

Tables 4 and 5 present the annualized costs for natural gas-fired model boilers at capacity factors of 0.26 and 0.55, respectively. The cost effectiveness of LEA control is also presented. Cost effectiveness results are provided for both continuous compliance and excess emission reporting requirements.

The average cost effectiveness values for LEA control decrease as the boiler size increases for both capacity factors. The values range from \$314,000/Mg (\$285,000/ton) for continuous compliance at the 2.9 MW (10 million Btu/hour) boiler size and 0.26 capacity factor to \$3,110/Mg (\$2,820/ton) at the 29 MW (100 million Btu/hour) boiler size and 0.55

capacity factor. The decrease in cost effectiveness is due primarily to three factors:

- (1) fuel savings increase with increasing boiler size and capacity factor, thus reducing incremental costs for control;
- (2) capital costs for LEA equipment and NO_x monitors are distributed over larger annual NO_x reductions as boiler size and capacity factor increase, due to economies of scale; and
- (3) estimated emission reductions are greater on a heat input basis for larger boiler sizes than for small sizes. This is because uncontrolled NO_x emissions generally increase with boiler size for package boilers due to higher characteristic heat release rates. Since a constant 20 percent NO_x reduction has been assumed, the magnitude of this NO_x reduction, on a heat input basis, increases as boiler size increases.

Requiring excess emission reporting rather than continuous compliance results in lower cost effectiveness values. The average cost effectiveness under excess emission reporting ranges from \$225,000/Mg (\$205,000/ton) at the 2.9 MW (10 million Btu/hour) boiler size and 0.26 capacity factor to \$1,040/Mg (\$940/ton) at 29 MW (100 million Btu/hour) and 0.55 capacity factor.

4.2 NATURAL GAS, COMMERCIAL FUEL PRICE

Tables 6 and 7 present the costs for baseline and LEA control on small boilers firing natural gas priced for the commercial market sector. Tables 8 and 9 present the corresponding cost effectiveness results. Although annualized costs for baseline and LEA control are higher with the commercial gas price than with the industrial natural gas price, the differences in costs between these two alternatives, as well as the cost effectiveness

values, are smaller. This is because the commercial gas price is higher than the industrial price, thus increasing fuel savings and decreasing the cost difference between baseline and LEA-controlled boilers.

The cost effectiveness of LEA control with continuous compliance ranges from \$314,000/Mg (\$285,000/ton) at the 2.9 MW (10 million Btu/hour) size and 0.26 capacity factor to \$2,040/Mg (\$1,850/ton) at the 29 MW (100 million Btu/hour) size and 0.55 capacity factor. When excess emission reporting is required, cost effectiveness ranges from \$225,000/Mg (205,000/ton) for the 2.9 MW (10 million Btu/hour) boiler at a capacity factor of 0.26 to \$0/Mg (\$0/ton) at the 29 M (100 million Btu/hour) size and 0.55 capacity factor. There is no net cost increase at this size and capacity factor because fuel savings are equal to the total nonfuel costs of LEA application.

4.3 DISTILLATE OIL

Tables 10 and 11 show costs for baseline and LEA-controlled small boilers firing distillate oil and operating at capacity factors of 0.26 and 0.55, respectively. Tables 12 and 13 list the corresponding cost-effectiveness results.

The distillate oil-fired model boilers exhibit cost and cost-effectiveness trends similar to those observed for natural gas-fired boilers. With continuous compliance, the cost effectiveness of applying LEA to uncontrolled distillate oil-fired boilers ranges from \$156,000/Mg (\$141,000/ton) at the 2.9 MW (10 million Btu/hour) boiler size and 0.26 capacity factor to \$2,440/Mg (\$2,220/ton) at the 29 MW (100 million Btu/hour) boiler size and 0.55 capacity factor. For the same range in size and capacity factor, the cost effectiveness for excess emission reporting ranges from \$112,000/Mg (\$102,000/ton) to (-\$305/Mg) [-\$277/ton]. The negative cost effectiveness for the latter case results because fuel savings are greater than the nonfuel LEA costs.

4.4 RESIDUAL OIL

Costs for uncontrolled and LEA-controlled model boilers firing residual oil are presented in Tables 14 and 15. Cost effectiveness results for the residual oil-fired boilers are given in Tables 16 and 17.

Trends in cost and cost effectiveness for firing residual oil parallel those for firing natural gas and distillate oil. Fuel savings for residual oil due to LEA application are smaller, however, because of the lower fuel price for residual oil compared to natural gas. Also, there is no change in estimated NO_x emission reductions as a function of boiler size.

Under continuous compliance, the cost effectiveness of applying LEA to uncontrolled residual oil-fired boilers ranges from \$104,000/Mg (\$94,000/ton) at the 2.9 MW (10 million Btu/hour) boiler size and 0.26 capacity factor to \$1,610/Mg (\$1,460/ton) at the 29 MW (100 million Btu/hour) boiler size and 0.55 capacity factor. For the same range in size and capacity factor, cost effectiveness for excess emission reporting ranges from \$75,000/Mg (\$68,000/ton) to \$576/Mg (\$522/ton).

4.5 COAL

Tables 18 and 19 present baseline and LEA control costs for coal-fired model boilers operating at capacity factors of 0.26 and 0.55, respectively. The corresponding cost effectiveness results are presented in Tables 20 and 21. The cost and cost effectiveness trends observed for firing coal are similar to those exhibited by the other fuel types.

Under continuous compliance, the cost effectiveness of applying LEA to uncontrolled coal-fired boilers ranges from \$107,000/Mg (\$97,000/ton) at the 2.9 MW (10 million Btu/hour) boiler size and 0.26 capacity factor to \$2,350/Mg (\$2,130/ton) at the 29 MW (100 million Btu/hour) boiler size and 0.55 capacity factor. For the same range in size and capacity factor, cost effectiveness for excess emission reporting ranges from \$78,000/Mg (\$70,900/ton) to \$1,520/Mg (\$1,380/ton).

5.0 REFERENCES

1. Overview of the Regulatory Baseline, Technical Basis, and Alternative Control Levels for Nitrogen Oxides (NO_x) Emission Standards for Small Steam Generating Units. U.S. Environmental Protection Agency, Research Triangle Park, N.C. EPA Publication No. EPA-450/3-89-13. May 1989
2. Memorandum from Martinez, J. A., Radian Corporation, to Small Boiler Docket. December 17, 1987. Development of Baseline and Controlled NO_x Emission Estimates for Small Boilers.
3. Industrial Boiler SO₂ Cost Report. Prepared by Radian Corporation. Prepared for U.S. Environmental Protection Agency, Research Triangle Park, NC. EPA Publication No. EPA-450/3-85-011. November 1984. p. 90.
4. U.S. Environmental Protection Agency. Small Steam Generating Unit Characteristics and Emission Control Techniques. Research Triangle Park, N.C. March 31, 1989
5. Technology Assessment Report for Industrial Boiler Applications: NO_x Combustion Modification. Prepared by Acurex Corporation. Prepared for the U.S. Environmental Protection Agency, Research Triangle Park, NC. EPA Publication No. EPA-600/7-79-178f. December 1979. p. 4-3.
6. Letter from Hogan, T., Energy and Environmental Analysis, Inc., to Link, T. E., EPA/EAB. June 5, 1987. Annualized Industrial Fuel Prices.
7. Letter from Hogan, T., Energy and Environmental Analysis, Inc., to Link, T. E., EPA/EAB. July 28, 1987. Annualized Commercial Oil and Gas Prices.

TABLE 1. PROJECTED FUEL PRICES FOR EPA REGION V

| | \$/GJ (\$/million Btu) ^a |
|---------------------------|-------------------------------------|
| Natural Gas: ^b | |
| Industrial | 4.95 (5.22) |
| Commercial | 6.11 (6.44) |
| Distillate Oil | 6.03 (6.36) |
| Residual Oil (3% Sulfur) | 4.63 (4.88) |
| Coal (F-Bituminous) | 2.38 (2.51) |

^aLevelized prices in June 1985 dollars.

^bCarriage market prices.

TABLE 2. MODEL BOILER NO_x COST ANALYSIS FOR NATURAL GAS-FIRED BOILERS IN REGION V
INDUSTRIAL FUEL PRICES AND 0.26 CAPACITY FACTOR^{a,b}

| Boiler size/control | Emission factor ^c ng/J (lb/MMBtu) | Annual NO _x emissions ^x Mg/yr (tons/yr) | Capital costs (\$1,000) | O & M costs (\$1,000/yr) | | | Annualized cost (\$1,000/yr) |
|-----------------------|---|---|-------------------------------|--------------------------|---------|-------|------------------------------------|
| | | | | Fuel | Nonfuel | Total | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | |
| Baseline | 43 (0.10) | 1.0 (1.1) | 435 | 119 | 174 | 293 | 363 |
| LEA ^d | 34 (0.08) | 0.8 (0.9) | 546 | 117 | 225 | 342 | 427 |
| 7.3 MW (25 MMBtu/hr) | | | | | | | |
| Baseline | 43 (0.10) | 2.6 (2.8) | 718 | 297 | 231 | 528 | 644 |
| LEA | 34 (0.08) | 2.1 (2.3) | 830 | 292 | 282 | 574 | 706 |
| 15 MW (50 MMBtu/hr) | | | | | | | |
| Baseline | 81 (0.19) | 10 (11) | 1,466 | 594 | 274 | 868 | 1,109 |
| LEA | 64 (0.15) | 7.7 (8.5) | 1,579 | 585 | 325 | 910 | 1,166 |
| 22 MW (75 MMBtu/hr) | | | | | | | |
| Baseline | 81 (0.19) | 15 (16) | 1,888 | 892 | 318 | 1,210 | 1,520 |
| LEA | 64 (0.15) | 11.5 (13) | 2,003 | 877 | 370 | 1,247 | 1,572 |
| 29 MW (100 MMBtu/hr) | | | | | | | |
| Baseline | 81 (0.19) | 19 (21) | 2,269 | 1,189 | 361 | 1,550 | 1,922 |
| LEA | 64 (0.15) | 15 (17) | 2,385 | 1,170 | 412 | 1,582 | 1,971 |

^aAll costs are in June 1985 dollars.

^bCosts for continuous compliance, including Appendix F, are included with LEA costs. The detailed excess emission costs can be calculated by subtracting \$10,000 from the Capital costs, \$17,000 from the O&M costs, and \$18,000 from the Annualized costs for LEA.

^cReference 2.

^dLEA = Low excess air.

TABLE 3. MODEL BOILER NO_x COST ANALYSIS FOR NATURAL GAS-FIRED BOILERS IN REGION V
INDUSTRIAL FUEL PRICES AND 0.55 CAPACITY FACTOR^{a,b}

| Boiler size/control | Emission factor ^c ng/J (lb/MMBtu) | | Annual NO _x emissions ^x Mg/yr (tons/yr) | | Capital costs (\$1,000) | O & M costs (\$1,000/yr) | | | Annualized cost (\$1,000/yr) |
|-----------------------|---|--------|---|-------|-------------------------------|--------------------------|---------|-------|------------------------------------|
| | | | | | | Fuel | Nonfuel | Total | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | | | |
| Baseline | 43 | (0.10) | 2.2 | (2.4) | 454 | 251 | 220 | 471 | 543 |
| LEA ^d | 34 | (0.08) | 1.7 | (1.9) | 565 | 247 | 271 | 518 | 605 |
| 7.3 MW (25 MMBtu/hr) | | | | | | | | | |
| Baseline | 43 | (0.10) | 5.4 | (6) | 758 | 629 | 291 | 920 | 1,041 |
| LEA | 34 | (0.08) | 4.3 | (4.8) | 869 | 619 | 342 | 961 | 1,097 |
| 15 MW (50 MMBtu/hr) | | | | | | | | | |
| Baseline | 81 | (0.19) | 21 | (23) | 1,536 | 1,257 | 346 | 1,603 | 1,851 |
| LEA | 64 | (0.15) | 16 | (18) | 1,648 | 1,237 | 397 | 1,634 | 1,898 |
| 22 MW (75 MMBtu/hr) | | | | | | | | | |
| Baseline | 81 | (0.19) | 31 | (34) | 1,988 | 1,886 | 401 | 2,287 | 2,607 |
| LEA | 64 | (0.15) | 24 | (27) | 2,101 | 1,856 | 452 | 2,308 | 2,644 |
| 29 MW (100 MMBtu/hr) | | | | | | | | | |
| Baseline | 81 | (0.19) | 41 | (45) | 2,398 | 2,515 | 455 | 2,970 | 3,356 |
| LEA | 64 | (0.15) | 33 | (36) | 2,513 | 2,475 | 507 | 2,982 | 3,383 |

^aAll costs are in June 1985 dollars.

^bCosts for continuous compliance, including Appendix F, are included with LEA costs. The detailed excess emission costs can be calculated by subtracting \$10,000 from the Capital costs, \$17,000 from the O&M costs, and 18,000 from the Annualized costs for LEA.

^cReference 2.

^dLEA = Low excess air.

TABLE 4. COST-EFFECTIVENESS RESULTS FOR NATURAL GAS-FIRED BOILERS IN REGION V
INDUSTRIAL FUEL PRICES AND 0.26 CAPACITY FACTOR^a

| Boiler size/control | Emission factor ^b ng/J(lb/MMBtu) | Annual emissions Mg/yr (ton/yr) | Continuous compliance ^c | | | Excess emission reporting ^e | | |
|-----------------------|--|---------------------------------------|------------------------------------|---|-----------|--|---|-----------|
| | | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | | |
| Baseline | 43 (0.10) | 1.0 (1.1) | 363 | - | - | 363 | - | - |
| LEA | 34 (0.08) | 0.8 (0.9) | 427 | 314,000 | (285,000) | 409 | 225,000 | (205,000) |
| 7.3 MW (25 MMBtu/hr) | | | | | | | | |
| Baseline | 43 (0.10) | 2.6 (3) | 644 | - | - | 644 | - | - |
| LEA | 34 (0.08) | 2.1 (2.3) | 706 | 122,000 | (110,000) | 688 | 86,200 | (78,300) |
| 15 MW (50 MMBtu/hr) | | | | | | | | |
| Baseline | 81 (0.19) | 10 (11) | 1,109 | - | - | 1,109 | - | - |
| LEA | 64 (0.15) | 8 (8) | 1,166 | 27,800 | (25,200) | 1,148 | 19,000 | (17,200) |
| 22 MW (75 MMBtu/hr) | | | | | | | | |
| Baseline | 81 (0.19) | 15 (16) | 1,520 | - | - | 1,520 | - | - |
| LEA | 64 (0.15) | 12 (13) | 1,572 | 16,900 | (15,300) | 1,554 | 11,000 | (10,000) |
| 29 MW (100 MMBtu/hr) | | | | | | | | |
| Baseline | 81 (0.19) | 19 (21) | 1,922 | - | - | 1,922 | - | - |
| LEA | 64 (0.15) | 15 (17) | 1,971 | 11,900 | (10,800) | 1,953 | 7,550 | (6,850) |

^aAll costs are in June 1985 dollars.

^bReference 2.

^cCosts include emission monitoring requirements for showing continuous compliance, including Appendix F.

^dCost increase associated with application of LEA control divided by the amount of emission reduction achieved.

^eCosts include excess emission reporting requirements.

TABLE 5. COST-EFFECTIVENESS RESULTS FOR NATURAL GAS-FIRED BOILERS IN REGION V
INDUSTRIAL PRICES AND 0.55 CAPACITY FACTOR^a

| Boiler size/control | Emission factor ^b ng/J(lb/MMBtu) | Annual emissions Mg/yr (ton/yr) | Continuous compliance ^c | | | Excess emission reporting ^e | | |
|-----------------------|--|---------------------------------------|------------------------------------|---|-----------|--|---|----------|
| | | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | | |
| Baseline | 43 (0.10) | 2.2 (2.4) | 543 | - | - | 543 | - | - |
| LEA | 34 (0.08) | 1.7 (1.9) | 605 | 144,000 | (130,000) | 587 | 102,000 | (92,000) |
| 7.3 MW (25 MMBtu/hr) | | | | | | | | |
| Baseline | 43 (0.10) | 5 (6) | 1,041 | - | - | 1,041 | - | - |
| LEA | 34 (0.08) | 4 (5) | 1,097 | 51,900 | (47,100) | 1,079 | 35,200 | (31,900) |
| 15 MW (50 MMBtu/hr) | | | | | | | | |
| Baseline | 81 (0.19) | 21 (23) | 1,851 | - | - | 1,851 | - | - |
| LEA | 64 (0.15) | 16 (18) | 1,898 | 10,800 | (9,820) | 1,880 | 6,680 | (6,060) |
| 22 MW (75 MMBtu/hr) | | | | | | | | |
| Baseline | 81 (0.19) | 31 (34) | 2,607 | - | - | 2,607 | - | - |
| LEA | 64 (0.15) | 24 (27) | 2,644 | 5,680 | (5,150) | 2,626 | 2,920 | (2,650) |
| 29 MW (100 MMBtu/hr) | | | | | | | | |
| Baseline | 81 (0.19) | 41 (45) | 3,356 | - | - | 3,356 | - | - |
| LEA | 64 (0.15) | 33 (36) | 3,383 | 3,110 | (2,820) | 3,365 | 1,040 | (940) |

^aAll costs are in June 1985 dollars.

^bReference 2.

^cCosts include emission monitoring requirements for showing continuous compliance, including Appendix F.

^dCost increase associated with application of LEA control divided by the amount of emission reduction achieved.

^eCosts include excess emission reporting requirements.

TABLE 6. MODEL BOILER NO_x COST ANALYSIS FOR NATURAL GAS-FIRED BOILERS IN REGION V
COMMERCIAL FUEL PRICES AND 0.26 CAPACITY FACTOR^{a,b}

| Boiler size/control | Emission factor ^c ng/J (lb/MMBtu) | Annual NO _x emissions ^x Mg/yr (tons/yr) | Capital costs (\$1,000) | O & M costs (\$1,000/yr) | | | Annualized cost (\$1,000/yr) |
|-----------------------|---|---|-------------------------------|--------------------------|---------|-------|------------------------------------|
| | | | | Fuel | Nonfuel | Total | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | |
| Baseline | 43 (0.10) | 1.0 (1.1) | 437 | 147 | 174 | 321 | 391 |
| LEA ^d | 34 (0.08) | 0.8 (0.9) | 548 | 144 | 225 | 369 | 455 |
| 7.3 MW (25 MMBtu/hr) | | | | | | | |
| Baseline | 43 (0.10) | 2.6 (2.8) | 724 | 367 | 230 | 597 | 714 |
| LEA | 34 (0.08) | 2.1 (2.3) | 836 | 361 | 281 | 642 | 775 |
| 15 MW (50 MMBtu/hr) | | | | | | | |
| Baseline | 81 (0.19) | 9.7 (11) | 1,478 | 733 | 274 | 1,007 | 1,249 |
| LEA | 64 (0.15) | 7.7 (8.5) | 1,591 | 722 | 324 | 1,046 | 1,304 |
| 22 MW (75 MMBtu/hr) | | | | | | | |
| Baseline | 81 (0.19) | 15 (16) | 1,905 | 1,100 | 318 | 1,418 | 1,730 |
| LEA | 64 (0.15) | 12 (13) | 2,020 | 1,083 | 369 | 1,452 | 1,779 |
| 29 MW (100 MMBtu/hr) | | | | | | | |
| Baseline | 81 (0.19) | 19 (21) | 2,292 | 1,467 | 361 | 1,828 | 2,202 |
| LEA | 64 (0.15) | 15 (17) | 2,408 | 1,443 | 413 | 1,856 | 2,246 |

^aAll costs are in June 1985 dollars.

^bCosts for continuous compliance, including Appendix F, are included with LEA costs. The detailed excess emission costs can be calculated by subtracting \$10,000 from the Capital costs, \$17,000 from the O&M costs, and \$18,000 from the Annualized costs for LEA.

^cReference 2.

^dLEA = Low excess air

TABLE 7. MODEL BOILER NO_x COST ANALYSIS FOR NATURAL GAS-FIRED BOILERS IN REGION V
COMMERCIAL FUEL PRICES AND 0.55 CAPACITY FACTOR^a

| Boiler size/control | Emission factor ^c ng/J (lb/MMBtu) | Annual NO _x emissions ^x Mg/yr (tons/yr) | Capital costs (\$1,000) | O & M costs (\$1,000/yr) | | | Annualized cost (\$1,000/yr) |
|-----------------------|---|---|-------------------------------|--------------------------|---------|-------|------------------------------------|
| | | | | Fuel | Nonfuel | Total | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | |
| Baseline | 43 (0.10) | 2.2 (2.4) | 459 | 310 | 220 | 530 | 602 |
| LEA ^d | 34 (0.08) | 1.8 (1.9) | 570 | 305 | 270 | 575 | 663 |
| 7.3 MW (25 MMBtu/hr) | | | | | | | |
| Baseline | 43 (0.10) | 5.5 (6.1) | 770 | 776 | 291 | 1,067 | 1,189 |
| LEA | 34 (0.08) | 4.4 (4.9) | 881 | 763 | 343 | 1,106 | 1,243 |
| 15 MW (50 MMBtu/hr) | | | | | | | |
| Baseline | 81 (0.19) | 21 (23) | 1,560 | 1,551 | 346 | 1,897 | 2,148 |
| LEA | 64 (0.15) | 17 (18) | 1,673 | 1,527 | 397 | 1,924 | 2,189 |
| 22 MW (75 MMBtu/hr) | | | | | | | |
| Baseline | 81 (0.19) | 31 (35) | 2,024 | 2,327 | 401 | 2,728 | 3,052 |
| LEA | 64 (0.15) | 25 (27) | 2,137 | 2,290 | 452 | 2,742 | 3,082 |
| 29 MW (100 MMBtu/hr) | | | | | | | |
| Baseline | 81 (0.19) | 42 (46) | 2,447 | 3,103 | 455 | 3,558 | 3,948 |
| LEA | 64 (0.15) | 33 (37) | 2,561 | 3,053 | 507 | 3,560 | 3,966 |

^aAll costs are in June 1985 dollars.

^bCosts for continuous compliance, including Appendix F, are included with the LEA costs. The detailed excess emission costs can be calculated by subtracting \$10,000 from the Capital costs, \$17,000 from the O&M costs, and \$18,000 from the Annualized costs for LEA.

^cReference 2.

^dLEA = Low excess air

TABLE 8. COST-EFFECTIVENESS RESULTS FOR NATURAL GAS-FIRED BOILERS IN REGION V
COMMERCIAL FUEL PRICES AND 0.26 CAPACITY FACTOR^a

| Boiler size/control | Emission factor ^b ng/J (lb/MMBtu) | Annual emissions Mg/yr (ton/yr) | Continuous compliance ^c | | | Excess emission reporting ^e | | |
|-----------------------|---|---------------------------------------|------------------------------------|---|-----------|--|---|-----------|
| | | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | | |
| Baseline | 43 (0.10) | 1.0 (1.1) | 391 | - | - | 391 | - | - |
| LEA | 34 (0.08) | 0.8 (0.9) | 455 | 314,000 | (285,000) | 437 | 225,000 | (205,000) |
| 7.3 MW (25 MMBtu/hr) | | | | | | | | |
| Baseline | 43 (0.10) | 2.6 (2.8) | 714 | - | - | 714 | - | - |
| LEA | 34 (0.08) | 2.1 (2.3) | 775 | 120,000 | (108,500) | 757 | 84,300 | (76,500) |
| 15 MW (50 MMBtu/hr) | | | | | | | | |
| Baseline | 81 (0.19) | 10 (11) | 1,249 | - | - | 1249 | - | - |
| LEA | 64 (0.15) | 7.7 (8.5) | 1,304 | 26,800 | (24,300) | 1286 | 18,000 | (16,400) |
| 22 MW (75 MMBtu/hr) | | | | | | | | |
| Baseline | 81 (0.19) | 15 (16) | 1,730 | - | - | 1730 | - | - |
| LEA | 64 (0.15) | 12 (13) | 1,779 | 15,900 | (14,400) | 1761 | 10,070 | (9,140) |
| 29 MW (100 MMBtu/hr) | | | | | | | | |
| Baseline | 81 (0.19) | 19 (21) | 2,202 | - | - | 2202 | - | - |
| LEA | 64 (0.15) | 15 (17) | 2,246 | 10,720 | (9,720) | 2228 | 6,330 | (5,750) |

^aAll costs are in June 1985 dollars.

^bReference 2.

^cCosts include emission monitoring requirements for showing continuous compliance, including Appendix F.

^dCost increase associated with application of LEA control divided by the amount of emission reduction achieved.

^eCosts include excess emission reporting requirements.

TABLE 9. COST-EFFECTIVENESS RESULTS FOR NATURAL GAS-FIRED BOILERS IN REGION V
COMMERCIAL FUEL PRICES AND 0.55 CAPACITY FACTOR^a

| Boiler size/control | Emission factor ^b ng/J (lb/MMBtu) | Annual emissions Mg/yr (ton/yr) | Continuous compliance ^c | | | Excess emission reporting ^e | | |
|-----------------------|---|---------------------------------------|------------------------------------|---|-----------|--|---|----------|
| | | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | | |
| Baseline | 43 (0.10) | 2.2 (2.4) | 602 | - | - | 602 | - | - |
| LEA | 34 (0.08) | 1.8 (1.9) | 663 | 139,000 | (126,000) | 645 | 97,800 | (88,800) |
| 7.3 MW (25 MMBtu/hr) | | | | | | | | |
| Baseline | 43 (0.10) | 5.5 (6.1) | 1,189 | - | - | 1189 | - | - |
| LEA | 34 (0.08) | 4.4 (4.9) | 1,243 | 49,100 | (44,600) | 1225 | 32,800 | (29,700) |
| 15 MW (50 MMBtu/hr) | | | | | | | | |
| Baseline | 81 (0.19) | 21 (23) | 2,148 | - | - | 2148 | - | - |
| LEA | 64 (0.15) | 17 (18) | 2,189 | 9,270 | (8,410) | 2171 | 5,200 | (4,720) |
| 22 MW (75 MMBtu/hr) | | | | | | | | |
| Baseline | 81 (0.19) | 31 (35) | 3,052 | - | - | 3052 | - | - |
| LEA | 64 (0.15) | 25 (27) | 3,082 | 4,520 | (4,100) | 3064 | 1,809 | (1,642) |
| 29 MW (100 MMBtu/hr) | | | | | | | | |
| Baseline | 81 (0.19) | 42 (46) | 3,948 | - | - | 3948 | - | - |
| LEA | 64 (0.15) | 33 (37) | 3,966 | 2,040 | (1,850) | 3948 | 0 | 0 |

^aAll costs are in June 1985 dollars.

^bReference 2.

^cCosts include emission monitoring requirements for showing continuous compliance, including Appendix F.

^dCost increase associated with application of LEA control divided by the amount of emission reduction achieved.

^eCosts include excess emission reporting requirements.

TABLE 10. MODEL BOILER NO_x COST ANALYSIS FOR DISTILLATE OIL-FIRED BOILERS IN REGION V
0.26 CAPACITY FACTOR^{a,b}

| Boiler size/control | Emission factor ^c ng/J (lb/MMBtu) | Annual NO _x emissions ^x Mg/yr (tons/yr) | Capital costs (\$1,000) | O & M costs (\$1,000/yr) | | | Annualized cost (\$1,000/yr) |
|-----------------------|---|---|-------------------------------|--------------------------|---------|-------|------------------------------------|
| | | | | Fuel | Nonfuel | Total | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | |
| Baseline | 94 (0.22) | 2.3 (2.5) | 437 | 145 | 174 | 319 | 389 |
| LEA ^d | 77 (0.18) | 1.8 (2.0) | 548 | 142 | 225 | 367 | 453 |
| 7.3 MW (25 MMBtu/hr) | | | | | | | |
| Baseline | 94 (0.22) | 5.6 (6.2) | 724 | 362 | 231 | 593 | 710 |
| LEA | 77 (0.18) | 4.6 (5.1) | 835 | 356 | 281 | 637 | 770 |
| 15 MW (50 MMBtu/hr) | | | | | | | |
| Baseline | 56 (0.13) | 6.7 (7.4) | 1,477 | 724 | 274 | 998 | 1,240 |
| LEA | 43 (0.10) | 5.1 (5.6) | 1,590 | 712 | 325 | 1,037 | 1,294 |
| 22 MW (75 MMBtu/hr) | | | | | | | |
| Baseline | 56 (0.13) | 10 (11) | 1,904 | 1,086 | 318 | 1,404 | 1,716 |
| LEA | 43 (0.10) | 7.7 (8.5) | 2,019 | 1,068 | 369 | 1,437 | 1,765 |
| 29 MW (100 MMBtu/hr) | | | | | | | |
| Baseline | 56 (0.13) | 13 (15) | 2,290 | 1,449 | 361 | 1,810 | 2,184 |
| LEA | 43 (0.10) | 10 (11) | 2,406 | 1,424 | 412 | 1,836 | 2,227 |

^aAll costs are in June 1985 dollars.

^bCosts for continuous compliance, including Appendix F, are included with LEA costs. The detailed excess emission costs can be calculated by subtracting \$10,000 from the Capital costs, \$17,000 from the O&M costs, and \$18,000 from the Annualized costs for LEA.

^cReference 2.

^dLEA = Low excess air

TABLE 11. MODEL BOILER NO_x COST ANALYSIS FOR DISTILLATE OIL-FIRED BOILERS IN REGION V
0.55 CAPACITY FACTOR^{a,b}

| Boiler size/control | Emission factor ^c ng/J (lb/MMBtu) | Annual NO _x emissions ^x Mg/yr (tons/yr) | Capital costs (\$1,000) | O & M costs (\$1,000/yr) | | | Annualized cost (\$1,000/yr) |
|-----------------------|---|---|-------------------------------|--------------------------|---------|-------|------------------------------------|
| | | | | Fuel | Nonfuel | Total | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | |
| Baseline | 94 (0.22) | 4.8 (5.3) | 459 | 306 | 220 | 526 | 598 |
| LEA ^d | 77 (0.18) | 3.9 (4.3) | 569 | 301 | 270 | 571 | 659 |
| 7.3 MW (25 MMBtu/hr) | | | | | | | |
| Baseline | 94 (0.22) | 12 (13) | 769 | 766 | 292 | 1,058 | 1,179 |
| LEA | 77 (0.18) | 10 (11) | 880 | 753 | 343 | 1,096 | 1,233 |
| 15 MW (50 MMBtu/hr) | | | | | | | |
| Baseline | 56 (0.13) | 14 (16) | 1,559 | 1,532 | 346 | 1,878 | 2,128 |
| LEA | 43 (0.10) | 11 (12) | 1,671 | 1,506 | 397 | 1,903 | 2,169 |
| 22 MW (75 MMBtu/hr) | | | | | | | |
| Baseline | 56 (0.13) | 21 (23) | 2,022 | 2,298 | 401 | 2,699 | 3,023 |
| LEA | 43 (0.10) | 16 (18) | 2,135 | 2,260 | 452 | 2,712 | 3,051 |
| 29 MW (100 MMBtu/hr) | | | | | | | |
| Baseline | 56 (0.13) | 28 (31) | 2,444 | 3,064 | 456 | 3,520 | 3,909 |
| LEA | 43 (0.10) | 22 (24) | 2,558 | 3,013 | 506 | 3,519 | 3,925 |

^aAll costs are in June 1985 dollars.

^bCosts for continuous compliance, including Appendix F, are included with LEA costs. The detailed excess emission costs can be calculated by subtracting \$10,000 from the Capital costs, \$17,000 from the O&M costs, and \$18,000 from the Annualized costs for LEA.

^cReference 2.

^dLEA = Low excess air

TABLE 12. COST-EFFECTIVENESS RESULTS FOR DISTILLATE OIL-FIRED BOILERS IN REGION V
0.26 CAPACITY FACTOR^a

| Boiler size/control | Emission factor ^b ng/J (lb/MMBtu) | Annual emissions Mg/yr (ton/yr) | Continuous compliance ^c | | | Excess emission reporting ^e | | |
|-----------------------|---|---------------------------------------|------------------------------------|---|-----------|--|---|-----------|
| | | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | | |
| Baseline | 94 (0.22) | 2.3 (2.5) | 389 | - | - | 389 | - | - |
| LEA | 77 (0.18) | 1.8 (2.0) | 453 | 156,000 | (141,000) | 435 | 112,000 | (102,000) |
| 7.3 MW (25 MMBtu/hr) | | | | | | | | |
| Baseline | 94 (0.22) | 5.6 (6.2) | 710 | - | - | 710 | - | - |
| LEA | 77 (0.18) | 4.6 (5.1) | 770 | 58,500 | (53,000) | 752 | 40,900 | (37,100) |
| 15 MW (50 MMBtu/hr) | | | | | | | | |
| Baseline | 56 (0.13) | 6.7 (7.4) | 1,240 | - | - | 1,240 | - | - |
| LEA | 43 (0.10) | 5.1 (5.6) | 1,294 | 34,900 | (31,600) | 1,276 | 23,200 | (21,100) |
| 22 MW (75 MMBtu/hr) | | | | | | | | |
| Baseline | 56 (0.13) | 10 (11) | 1,716 | - | - | 1,716 | - | - |
| LEA | 43 (0.10) | 7.7 (8.5) | 1,765 | 21,100 | (19,100) | 1,747 | 13,300 | (12,110) |
| 29 MW (100 MMBtu/hr) | | | | | | | | |
| Baseline | 56 (0.13) | 13 (15) | 2,184 | - | - | 2,184 | - | - |
| LEA | 43 (0.10) | 10 (11) | 2,227 | 13,900 | (12,600) | 2,209 | 8,070 | (7,320) |

^aAll costs are in June 1985 dollars.

^bReference 2.

^cCosts include emission monitoring requirements for showing continuous compliance, including Appendix F.

^dCost increase associated with application of LEA control divided by the amount of emission reduction achieved.

^eCosts include excess emission reporting requirements.

TABLE 13. COST-EFFECTIVENESS RESULTS FOR DISTILLATE OIL-FIRED BOILERS IN REGION V
0.55 CAPACITY FACTOR^a

| Boiler size/control | Emission factor ^b ng/J (lb/MMBtu) | Annual emissions Mg/yr (ton/yr) | Continuous compliance ^c | | | Excess emission reporting ^e | | |
|-----------------------|---|---------------------------------------|------------------------------------|---|----------|--|---|----------|
| | | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | | |
| Baseline | 94 (0.22) | 4.8 (5.3) | 598 | - | - | 598 | - | - |
| LEA | 77 (0.18) | 3.9 (4.3) | 659 | 70,200 | (63,700) | 641 | 50,000 | (45,000) |
| 7.3 MW (25 MMBtu/hr) | | | | | | | | |
| Baseline | 94 (0.22) | 12 (13) | 1,179 | - | - | 1,179 | - | - |
| LEA | 77 (0.18) | 10 (11) | 1,233 | 24,900 | (22,600) | 1,215 | 16,600 | (15,000) |
| 15 MW (50 MMBtu/hr) | | | | | | | | |
| Baseline | 56 (0.13) | 14 (16) | 2,128 | - | - | 2,128 | - | - |
| LEA | 43 (0.10) | 11 (12) | 2,169 | 12,500 | (11,400) | 2,151 | 7,020 | (6,370) |
| 22 MW (75 MMBtu/hr) | | | | | | | | |
| Baseline | 56 (0.13) | 21 (23) | 3,023 | - | - | 3,023 | - | - |
| LEA | 43 (0.10) | 16 (18) | 3,051 | 5,700 | (5,170) | 3,033 | 2,040 | (1,850) |
| 29 MW (100 MMBtu/hr) | | | | | | | | |
| Baseline | 56 (0.13) | 28 (31) | 3,909 | - | - | 3,909 | - | - |
| LEA | 43 (0.10) | 22 (24) | 3,925 | 2,440 | (2,220) | 3,907 | -305 | -277 |

^aAll costs are in June 1985 dollars.

^bReference 2.

^cCosts include emission monitoring requirements for showing continuous compliance, including Appendix F.

^dCost increase associated with application of LEA control divided by the amount of emission reduction achieved.

^eCosts include excess emission reporting requirements.

TABLE 14. MODEL BOILER NO_x COST FOR RESIDUAL OIL-FIRED BOILERS IN REGION V
0.26 CAPACITY FACTOR^{a,b}

| Boiler size/control | Emission factor ^c ng/J (lb/MMBtu) | Annual NO _x emissions Mg/yr (tons/yr) | Capital costs (\$1,000) | O & M costs (\$1,000/yr) | | | Annualized cost (\$1,000/yr) |
|-----------------------|---|--|-------------------------------|--------------------------|---------|-------|------------------------------------|
| | | | | Fuel | Nonfuel | Total | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | |
| Baseline | 128 (0.30) | 3.1 (3.4) | 447 | 111 | 174 | 285 | 358 |
| LEA ^d | 103 (0.24) | 2.5 (2.7) | 558 | 109 | 225 | 334 | 422 |
| 7.3 MW (25 MMBtu/hr) | | | | | | | |
| Baseline | 128 (0.30) | 7.7 (8.5) | 738 | 278 | 230 | 508 | 628 |
| LEA | 103 (0.24) | 6.2 (6.8) | 850 | 273 | 282 | 555 | 690 |
| 15 MW (50 MMBtu/hr) | | | | | | | |
| Baseline | 180 (0.42) | 22 (24) | 1,492 | 556 | 273 | 829 | 1,075 |
| LEA | 145 (0.34) | 17 (19) | 1,605 | 546 | 325 | 871 | 1,132 |
| 22 MW (75 MMBtu/hr) | | | | | | | |
| Baseline | 180 (0.42) | 32 (36) | 1,917 | 834 | 317 | 1,151 | 1,467 |
| LEA | 145 (0.34) | 26 (29) | 2,032 | 820 | 369 | 1,189 | 1,520 |
| 29 MW (100 MMBtu/hr) | | | | | | | |
| Baseline | 180 (0.42) | 43 (47) | 2,300 | 1,111 | 361 | 1,472 | 1,850 |
| LEA | 145 (0.34) | 35 (38) | 2,416 | 1,093 | 412 | 1,505 | 1,899 |

^aAll costs are in June 1985 dollars.

^bCosts for continuous compliance, including Appendix F, are included with LEA costs. The detailed excess emission costs can be calculated by subtracting \$10,000 from the Capital costs, \$17,000 from the O&M costs, and \$18,000 from the Annualized costs for LEA.

^cReference 2.

^dLEA = Low excess air

TABLE 15. MODEL BOILER NO_x COST FOR RESIDUAL OIL-FIRED BOILERS IN REGION V
0.55 CAPACITY FACTOR^{a,b}

| Boiler size/control | Emission factor ^c ng/J (lb/MMBtu) | Annual NO _x emissions Mg/yr (tons/yr) | Capital costs (\$1,000) | O & M costs (\$1,000/yr) | | | Annualized cost (\$1,000/yr) |
|-----------------------|---|--|-------------------------------|--------------------------|---------|-------|------------------------------------|
| | | | | Fuel | Nonfuel | Total | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | |
| Baseline | 128 (0.30) | 6.5 (7.2) | 466 | 235 | 219 | 454 | 529 |
| LEA ^d | 103 (0.24) | 5.2 (5.7) | 577 | 231 | 270 | 501 | 591 |
| 7.3 MW (25 MMBtu/hr) | | | | | | | |
| Baseline | 128 (0.30) | 16 (18) | 776 | 588 | 291 | 879 | 1,003 |
| LEA | 103 (0.24) | 13 (14) | 887 | 578 | 342 | 920 | 1,060 |
| 15 MW (50 MMBtu/hr) | | | | | | | |
| Baseline | 180 (0.42) | 46 (50) | 1,558 | 1,176 | 345 | 1,521 | 1,774 |
| LEA | 145 (0.34) | 37 (41) | 1,671 | 1,156 | 397 | 1,553 | 1,820 |
| 22 MW (75 MMBtu/hr) | | | | | | | |
| Baseline | 180 (0.42) | 68 (75) | 2,011 | 1,763 | 402 | 2,165 | 2,489 |
| LEA | 145 (0.34) | 55 (61) | 2,125 | 1,734 | 452 | 2,186 | 2,527 |
| 29 MW (100 MMBtu/hr) | | | | | | | |
| Baseline | 180 (0.42) | 91 (100) | 2,422 | 2,351 | 456 | 2,807 | 3,197 |
| LEA | 145 (0.34) | 74 (81) | 2,537 | 2,312 | 506 | 2,818 | 3,225 |

^aAll costs are in June 1985 dollars.

^bCosts for continuous compliance, including Appendix F, are included with LEA costs. The detailed excess emission costs can be calculated by subtracting \$10,000 from the Capital costs, \$17,000 from the O&M costs, and \$18,000 from the Annualized costs for LEA.

^cReference 2.

^dLEA = Low excess air

TABLE 16. COST-EFFECTIVENESS RESULTS FOR RESIDUAL OIL-FIRED BOILERS IN REGION V
0.26 CAPACITY FACTOR^a

| Boiler size/control | Emission factor ^b ng/J(1b/MMBtu) | Annual emissions Mg/yr (ton/yr) | Continuous compliance ^c | | | Excess emission reporting ^e | | |
|-----------------------|--|---------------------------------------|------------------------------------|---|----------|--|---|----------|
| | | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | | |
| Baseline | 128 (0.30) | 3.1 (3.4) | 358 | - | - | 358 | - | - |
| LEA | 103 (0.24) | 2.5 (2.7) | 422 | 104,000 | (94,000) | 404 | 75,000 | (68,000) |
| 7.3 MW (25 MMBtu/hr) | | | | | | | | |
| Baseline | 128 (0.30) | 7.7 (8.5) | 628 | - | - | 628 | - | - |
| LEA | 103 (0.24) | 6.2 (6.8) | 690 | 40,300 | (36,600) | 672 | 28,600 | (26,000) |
| 15 MW (50 MMBtu/hr) | | | | | | | | |
| Baseline | 180 (0.42) | 22 (24) | 1,075 | - | - | 1,075 | - | - |
| LEA | 145 (0.34) | 17 (19) | 1,132 | 13,900 | (12,600) | 1,114 | 9,500 | (8,620) |
| 22 MW (75 MMBtu/hr) | | | | | | | | |
| Baseline | 180 (0.42) | 32 (36) | 1,467 | - | - | 1,467 | - | - |
| LEA | 145 (0.34) | 26 (29) | 1,520 | 8,610 | (7,810) | 1,502 | 5,680 | (5,160) |
| 29 MW (100 MMBtu/hr) | | | | | | | | |
| Baseline | 180 (0.42) | 43 (47) | 1,850 | - | - | 1,850 | - | - |
| LEA | 145 (0.34) | 35 (38) | 1,899 | 5,970 | (5,410) | 1,881 | 3,780 | (3,430) |

^aAll costs are in June 1985 dollars.

^bReference 2.

^cCosts include emission monitoring requirements for showing continuous compliance, including Appendix F.

^dCost increase associated with the application of LEA control divided by the amount of emission reduction achieved.

^eCosts include excess emission reporting requirements.

TABLE 17. COST-EFFECTIVENESS RESULTS FOR RESIDUAL OIL-FIRED BOILERS IN REGION V
0.55 CAPACITY FACTOR^a

| Boiler size/control | Emission factor ^b ng/J (lb/MMBtu) | Annual emissions Mg/yr (ton/yr) | Continuous compliance ^c | | | Excess emission reporting ^e | | |
|-----------------------|---|---------------------------------------|------------------------------------|---|----------|--|---|----------|
| | | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | | |
| Baseline | 128 (0.30) | 6.5 (7.2) | 529 | - | - | 529 | - | - |
| LEA | 103 (0.24) | 5.2 (5.7) | 591 | 48,000 | (43,000) | 573 | 34,000 | (31,000) |
| 7.3 MW (25 MMBtu/hr) | | | | | | | | |
| Baseline | 128 (0.30) | 16 (18) | 1,003 | - | - | 1,003 | - | - |
| LEA | 103 (0.24) | 13 (14) | 1,060 | 17,500 | (15,900) | 1,042 | 12,000 | (10,900) |
| 15 MW (50 MMBtu/hr) | | | | | | | | |
| Baseline | 180 (0.42) | 46 (50) | 1,774 | - | - | 1,774 | - | - |
| LEA | 145 (0.34) | 37 (41) | 1,820 | 5,300 | (4,810) | 1,802 | 3,220 | (2,930) |
| 22 MW (75 MMBtu/hr) | | | | | | | | |
| Baseline | 180 (0.42) | 68 (75) | 2,489 | - | - | 2,489 | - | - |
| LEA | 145 (0.34) | 55 (61) | 2,527 | 2,920 | (2,650) | 2,509 | 1,535 | (1,393) |
| 29 MW (100 MMBtu/hr) | | | | | | | | |
| Baseline | 180 (0.42) | 91 (100) | 3,197 | - | - | 3,197 | - | - |
| LEA | 145 (0.34) | 74 (81) | 3,225 | 1,612 | (1,463) | 3,207 | 576 | (522) |

^aAll costs are in June 1985 dollars.

^bReference 2.

^cCosts include emission monitoring requirements for showing continuous compliance, including Appendix F.

^dCost increase associated with application of LEA control divided by the amount of emission reduction achieved.

^eCosts include excess emission reporting requirements.

TABLE 18. MODEL BOILER NO_x COST ANALYSIS FOR COAL-FIRED BOILERS IN REGION V
0.26 CAPACITY FACTOR^{a,b}

| Boiler size/control | Emission factor ^c ng/J (lb/MMBtu) | Annual NO _x emissions Mg/yr (tons/yr) | Capital costs (\$1,000) | O & M costs (\$1,000/yr) | | | Annualized cost (\$1,000/yr) |
|-----------------------|---|--|-------------------------------|--------------------------|---------|-------|------------------------------------|
| | | | | Fuel | Nonfuel | Total | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | |
| Baseline | 141 (0.33) | 3.4 (3.7) | 1,508 | 57 | 269 | 326 | 575 |
| LEA ^d | 115 (0.27) | 2.8 (3.1) | 1,622 | 56 | 320 | 376 | 641 |
| 7.3 MW (25 MMBtu/hr) | | | | | | | |
| Baseline | 141 (0.33) | 8.5 (9.3) | 2,706 | 143 | 373 | 516 | 964 |
| LEA | 115 (0.27) | 6.9 (7.6) | 2,823 | 141 | 424 | 565 | 1,029 |
| 15 MW (50 MMBtu/hr) | | | | | | | |
| Baseline | 218 (0.51) | 26 (29) | 4,816 | 286 | 567 | 853 | 1,653 |
| LEA | 175 (0.41) | 21 (23) | 4,935 | 281 | 619 | 900 | 1,717 |
| 22 MW (75 MMBtu/hr) | | | | | | | |
| Baseline | 218 (0.51) | 39 (43) | 6,931 | 429 | 633 | 1,062 | 2,216 |
| LEA | 175 (0.41) | 32 (35) | 7,054 | 422 | 685 | 1,107 | 2,278 |
| 29 MW (100 MMBtu/hr) | | | | | | | |
| Baseline | 218 (0.51) | 52 (58) | 8,905 | 572 | 707 | 1,279 | 2,763 |
| LEA | 175 (0.41) | 42 (46) | 9,030 | 563 | 759 | 1,322 | 2,823 |

^aAll costs are in June 1985 dollars.

^bCosts for continuous compliance, including Appendix F, are included with LEA costs. The detailed excess emission costs can be calculated by subtracting \$10,000 from the Capital costs, \$17,000 from the O&M costs, and \$18,000 from the Annualized costs for LEA.

^cReference 2.

^dLEA = Low excess air

TABLE 19. MODEL BOILER NO_x COST ANALYSIS FOR COAL-FIRED BOILERS IN REGION V
0.55 CAPACITY FACTOR^{a,b}

| Boiler size/control | Emission factor ^c ng/J (lb/MMBtu) | Annual NO _x emissions ^x Mg/yr (tons/yr) | Capital costs (\$1,000) | O & M costs (\$1,000/yr) | | | Annualized cost (\$1,000/yr) |
|-----------------------|---|---|-------------------------------|--------------------------|---------|-------|------------------------------------|
| | | | | Fuel | Nonfuel | Total | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | |
| Baseline | 141 (0.33) | 7.2 (7.9) | 1,526 | 121 | 334 | 455 | 706 |
| LEA ^d | 115 (0.27) | 5.9 (6.5) | 1,641 | 119 | 385 | 504 | 771 |
| 7.3 MW (25 MMBtu/hr) | | | | | | | |
| Baseline | 141 (0.33) | 18 (20) | 2,739 | 302 | 468 | 770 | 1,222 |
| LEA | 115 (0.27) | 15 (16) | 2,855 | 298 | 518 | 816 | 1,284 |
| 15 MW (50 MMBtu/hr) | | | | | | | |
| Baseline | 218 (0.51) | 55 (61) | 4,867 | 605 | 694 | 1,299 | 2,104 |
| LEA | 175 (0.41) | 44 (49) | 4,986 | 595 | 746 | 1,341 | 2,163 |
| 22 MW (75 MMBtu/hr) | | | | | | | |
| Baseline | 218 (0.51) | 83 (91) | 6,999 | 907 | 775 | 1,682 | 2,842 |
| LEA | 175 (0.41) | 67 (74) | 7,121 | 893 | 826 | 1,719 | 2,897 |
| 29 MW (100 MMBtu/hr) | | | | | | | |
| Baseline | 218 (0.51) | 111 (122) | 8,989 | 1,209 | 865 | 2,074 | 3,566 |
| LEA | 175 (0.41) | 89 (98) | 9,114 | 1,191 | 916 | 2,107 | 3,617 |

^aAll costs are in June 1985 dollars.

^bCosts for continuous compliance, including Appendix F, are included with LEA costs. The detailed excess emission costs can be calculated by subtracting \$10,000 from the Capital costs, \$17,000 from the O&M costs, and \$18,000 from the Annualized costs for LEA.

^cReference 2.

^dLEA = Low excess air

TABLE 20. COST-EFFECTIVENESS RESULTS FOR COAL-FIRED BOILERS IN REGION V
0.26 CAPACITY FACTOR^a

| Boiler size/control | Emission factor ^b ng/J(lb/MMBtu) | Annual emissions Mg/yr (ton/yr) | Continuous compliance ^c | | | Excess emission reporting ^e | | |
|-----------------------|--|---------------------------------------|------------------------------------|---|----------|--|---|----------|
| | | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | | |
| Baseline | 141 (0.33) | 3.4 (3.7) | 575 | - | - | 575 | - | - |
| LEA | 115 (0.27) | 2.8 (3.1) | 641 | 107,000 | (97,000) | 623 | 78,100 | (70,900) |
| 7.3 MW (25 MMBtu/hr) | | | | | | | | |
| Baseline | 141 (0.33) | 8.5 (9.3) | 964 | - | - | 964 | - | - |
| LEA | 115 (0.27) | 6.9 (7.6) | 1,029 | 42,300 | (38,400) | 1,011 | 30,600 | (27,800) |
| 15 MW (50 MMBtu/hr) | | | | | | | | |
| Baseline | 218 (0.51) | 26 (29) | 1,653 | - | - | 1,653 | - | - |
| LEA | 175 (0.41) | 21 (23) | 1,717 | 12,500 | (11,300) | 1,699 | 8,970 | (8,140) |
| 22 MW (75 MMBtu/hr) | | | | | | | | |
| Baseline | 218 (0.51) | 39 (43) | 2,216 | - | - | 2,216 | - | - |
| LEA | 175 (0.41) | 32 (35) | 2,278 | 8,060 | (7,320) | 2,260 | 5,720 | (5,190) |
| 29 MW (100 MMBtu/hr) | | | | | | | | |
| Baseline | 218 (0.51) | 52 (58) | 2,763 | - | - | 2,763 | - | - |
| LEA | 175 (0.41) | 42 (46) | 2,823 | 5,850 | (5,310) | 2,805 | 4,100 | (3,720) |

^aAll costs are in June 1985 dollars.

^bReference 2.

^cCosts include emission monitoring requirements for showing continuous compliance, including Appendix F.

^dCost increase associated with application of LEA control divided by the amount of emission reduction achieved.

^eCosts include excess emission reporting requirements.

TABLE 21. COST-EFFECTIVENESS RESULTS FOR COAL-FIRED BOILERS IN REGION V
0.55 CAPACITY FACTOR^a

| Boiler size/control | Emission factor ^b ng/J (lb/MMBtu) | Annual emissions Mg/yr (ton/yr) | Continuous compliance ^c | | | Excess emission reporting ^e | | |
|-----------------------|---|---------------------------------------|------------------------------------|---|----------|--|---|----------|
| | | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | | Annualized cost (\$1000/yr) | Average cost effectiveness ^d \$/Mg (\$/ton) | |
| 2.9 MW (10 MMBtu/hr) | | | | | | | | |
| Baseline | 141 (0.33) | 7.2 (7.9) | 706 | - | - | 706 | - | - |
| LEA | 115 (0.27) | 5.9 (6.5) | 771 | 50,000 | (45,000) | 753 | 36,100 | (32,800) |
| 7.3 MW (25 MMBtu/hr) | | | | | | | | |
| Baseline | 141 (0.33) | 18 (20) | 1,222 | - | - | 1,222 | - | - |
| LEA | 115 (0.27) | 15 (16) | 1,284 | 19,100 | (17,300) | 1,266 | 13,500 | (12,300) |
| 15 MW (50 MMBtu/hr) | | | | | | | | |
| Baseline | 218 (0.51) | 55 (61) | 2,104 | - | - | 2,104 | - | - |
| LEA | 175 (0.41) | 44 (49) | 2,163 | 5,440 | (4,940) | 2,145 | 3,780 | (3,430) |
| 22 MW (75 MMBtu/hr) | | | | | | | | |
| Baseline | 218 (0.51) | 83 (91) | 2,842 | - | - | 2,842 | - | - |
| LEA | 175 (0.41) | 67 (74) | 2,897 | 3,380 | (3,070) | 2,879 | 2,270 | (2,060) |
| 29 MW (100 MMBtu/hr) | | | | | | | | |
| Baseline | 218 (0.51) | 111 (122) | 3,566 | - | - | 3,566 | - | - |
| LEA | 175 (0.41) | 89 (98) | 3,617 | 2,350 | (2,130) | 3,599 | 1,520 | (1,380) |

^aAll costs are in June 1985 dollars.

^bReference 2.

^cCosts include emission monitoring requirements for showing continuous compliance, including Appendix F.

^dCost increase associated with application of LEA control divided by the amount of emission reduction achieved.

^eCosts include excess emission reporting requirements.

| TECHNICAL REPORT DATA <i>(Please read Instructions on the reverse before completing)</i> | | |
|---|--|--|
| 1. REPORT NO. EPA/450-3-89-16 | 2. | 3. RECIPIENT'S ACCESSION NO. |
| 4. TITLE AND SUBTITLE Model Boiler Cost Analysis for Controlling Nitrogen Oxides (NO _x) Emissions from Small Steam Generating Units | | 5. REPORT DATE May 1989 |
| | | 6. PERFORMING ORGANIZATION CODE |
| 7. AUTHOR(S) | | 8. PERFORMING ORGANIZATION REPORT NO. |
| 9. PERFORMING ORGANIZATION NAME AND ADDRESS Emission Standards Division Office of Air Quality Planning and Standards U.S. Environmental Protection Agency Research Triangle Park, North Carolina 27711 | | 10. PROGRAM ELEMENT NO. |
| | | 11. CONTRACT/GRANT NO. 68-02-4378 |
| 12. SPONSORING AGENCY NAME AND ADDRESS Office of Air Quality Planning and Standards Office of Air and Radiation U.S. Environmental Protection Agency Research Triangle Park, North Carolina 27711 | | 13. TYPE OF REPORT AND PERIOD COVERED Final |
| | | 14. SPONSORING AGENCY CODE EPA/200/04 |
| 15. SUPPLEMENTARY NOTES | | |
| 16. ABSTRACT This report presents estimates of the cost and cost effectiveness associated with controlling nitrogen oxides (NO _x) emissions from small coal-, oil-, and gas-fired industrial-commercial-institutional steam generating units (small boilers). The report was prepared during development of proposed new source performance standards (NSPS) for small boilers (boilers with heat input capacities of 100 million Btu/hour or less). | | |
| 17. KEY WORDS AND DOCUMENT ANALYSIS | | |
| a. DESCRIPTORS | b. IDENTIFIERS/OPEN ENDED TERMS | c. COSATI Field/Group |
| Air Pollution Pollution Control Standards of Performance Steam Generating Units | Industrial Boilers Small Boilers Air Pollution Control | |
| 18. DISTRIBUTION STATEMENT Release unlimited | 19. SECURITY CLASS (This Report) Unclassified | 21. NO. OF PAGES |
| | 20. SECURITY CLASS (This page) Unclassified | 22. PRICE |

INSTRUCTIONS

1. **REPORT NUMBER**
Insert the EPA report number as it appears on the cover of the publication.
2. **LEAVE BLANK**
3. **RECIPIENTS ACCESSION NUMBER**
Reserved for use by each report recipient.
4. **TITLE AND SUBTITLE**
Title should indicate clearly and briefly the subject coverage of the report, and be displayed prominently. Set subtitle, if used, in smaller type or otherwise subordinate it to main title. When a report is prepared in more than one volume, repeat the primary title, add volume number and include subtitle for the specific title.
5. **REPORT DATE**
Each report shall carry a date indicating at least month and year. Indicate the basis on which it was selected (e.g., *date of issue, date of approval, date of preparation, etc.*).
6. **PERFORMING ORGANIZATION CODE**
Leave blank.
7. **AUTHOR(S)**
Give name(s) in conventional order (*John R. Doe, J. Robert Doe, etc.*). List author's affiliation if it differs from the performing organization.
8. **PERFORMING ORGANIZATION REPORT NUMBER**
Insert if performing organization wishes to assign this number.
9. **PERFORMING ORGANIZATION NAME AND ADDRESS**
Give name, street, city, state, and ZIP code. List no more than two levels of an organizational hierarchy.
10. **PROGRAM ELEMENT NUMBER**
Use the program element number under which the report was prepared. Subordinate numbers may be included in parentheses.
11. **CONTRACT/GRANT NUMBER**
Insert contract or grant number under which report was prepared.
12. **SPONSORING AGENCY NAME AND ADDRESS**
Include ZIP code.
13. **TYPE OF REPORT AND PERIOD COVERED**
Indicate interim final, etc., and if applicable, dates covered.
14. **SPONSORING AGENCY CODE**
Insert appropriate code.
15. **SUPPLEMENTARY NOTES**
Enter information not included elsewhere but useful, such as: Prepared in cooperation with, Translation of, Presented at conference of, To be published in, Supersedes, Supplements, etc.
16. **ABSTRACT**
Include a brief (200 words or less) factual summary of the most significant information contained in the report. If the report contains a significant bibliography or literature survey, mention it here.
17. **KEY WORDS AND DOCUMENT ANALYSIS**
 - (a) **DESCRIPTORS** - Select from the Thesaurus of Engineering and Scientific Terms the proper authorized terms that identify the major concept of the research and are sufficiently specific and precise to be used as index entries for cataloging.
 - (b) **IDENTIFIERS AND OPEN-ENDED TERMS** - Use identifiers for project names, code names, equipment designators, etc. Use open-ended terms written in descriptor form for those subjects for which no descriptor exists.
 - (c) **COSATI FIELD GROUP** - Field and group assignments are to be taken from the 1965 COSATI Subject Category List. Since the majority of documents are multidisciplinary in nature, the Primary Field/Group assignment(s) will be specific discipline, area of human endeavor, or type of physical object. The application(s) will be cross-referenced with secondary Field/Group assignments that will follow the primary posting(s).
18. **DISTRIBUTION STATEMENT**
Denote releasability to the public or limitation for reasons other than security for example "Release Unlimited." Cite any availability to the public, with address and price.
19. & 20. **SECURITY CLASSIFICATION**
DO NOT submit classified reports to the National Technical Information service.
21. **NUMBER OF PAGES**
Insert the total number of pages, including this one and unnumbered pages, but exclude distribution list, if any.
22. **PRICE**
Insert the price set by the National Technical Information Service or the Government Printing Office, if known.