



# Research and Development

ENVIRONMENTAL ASSESSMENT OF  
AN ENHANCED OIL RECOVERY  
STEAM GENERATOR EQUIPPED  
WITH A LOW-NO<sub>x</sub> BURNER  
Volume I. Technical Results

## Prepared for

Office of Air Quality Planning and Standards

## Prepared by

Air and Energy Engineering Research  
Laboratory  
Research Triangle Park NC 27711

## **RESEARCH REPORTING SERIES**

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into nine series. These nine broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and a maximum interface in related fields. The nine series are:

1. Environmental Health Effects Research
2. Environmental Protection Technology
3. Ecological Research
4. Environmental Monitoring
5. Socioeconomic Environmental Studies
6. Scientific and Technical Assessment Reports (STAR)
7. Interagency Energy-Environment Research and Development
8. "Special" Reports
9. Miscellaneous Reports

This report has been assigned to the INTERAGENCY ENERGY-ENVIRONMENT RESEARCH AND DEVELOPMENT series. Reports in this series result from the effort funded under the 17-agency Federal Energy/Environment Research and Development Program. These studies relate to EPA's mission to protect the public health and welfare from adverse effects of pollutants associated with energy systems. The goal of the Program is to assure the rapid development of domestic energy supplies in an environmentally-compatible manner by providing the necessary environmental data and control technology. Investigations include analyses of the transport of energy-related pollutants and their health and ecological effects; assessments of, and development of, control technologies for energy systems; and integrated assessments of a wide range of energy-related environmental issues.

## **EPA REVIEW NOTICE**

This report has been reviewed by the participating Federal Agencies, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the Government, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

This document is available to the public through the National Technical Information Service, Springfield, Virginia 22161.

EPA-600/7-86-003a  
February 1986

# **ENVIRONMENTAL ASSESSMENT OF AN ENHANCED OIL RECOVERY STEAM GENERATOR EQUIPPED WITH A LOW-NO<sub>x</sub> BURNER**

## **Volume I Technical Results**

By

C. Castaldini, L. R. Waterland, and H. I. Lips  
Acurex Corporation  
Energy & Environmental Division  
555 Clyde Avenue  
P.O. Box 7555  
Mountain View, California 94039

EPA Contract No. 68-02-3188

EPA Project Officer: R. E. Hall  
Air and Energy Engineering Research Laboratory  
Research Triangle Park, North Carolina 27711

for

U.S. ENVIRONMENTAL PROTECTION AGENCY  
Office of Research and Development  
Washington, DC 20460

## ACKNOWLEDGEMENTS

The authors wish to extend their gratitude to Craig Jackson of the Getty Oil Corporation and to Gary Sams of CE-Natco for their interest and cooperation in this test program. Special recognition is also extended to the Acurex field test team of M. Chips, P. Kaufmann, G. Chips, J. Oblack, M. Murtiff, and G. Murphy, under the supervision of B. C. DaRos.

## CONTENTS

	Acknowledgements . . . . .	ii
	Figures . . . . .	iv
	Tables . . . . .	v
1	Introduction . . . . .	1-1
2	Source Description . . . . .	2-1
3	Emission Results . . . . .	3-1
	3.1 Performance/Emission Mapping Tests . . . . .	3-1
	3.2 Environmental Assessment Testing . . . . .	3-11
	3.2.1 Burner and Steamer Operation . . . . .	3-14
	3.2.2 Criteria Pollutant and Other Gas Phase Species Emissions . . . . .	3-14
	3.2.3 Organic Species Emissions . . . . .	3-19
4	Quality Assurance Activities . . . . .	4-1
	4.1 Accuracy Determinations . . . . .	4-1
	4.2 Precision Determinations . . . . .	4-2
5	Summary . . . . .	5-1
A	Appendix . . . . .	A-1
	A. Sampling and Analysis Methods . . . . .	A-1
	A.1 Continuous Monitoring System . . . . .	A-1
	A.2 Particulate and Sulfur Oxide Emissions . . . . .	A-3
	A.3 Organic Emissions . . . . .	A-6
	A.4 Particle Size Distribution . . . . .	A-10
	A.5 C <sub>1</sub> to C <sub>6</sub> Hydrocarbon Sampling and Analysis . . . . .	A-12
	A.6 N <sub>2</sub> O Emissions . . . . .	A-14

## FIGURES

<u>Figure</u>		<u>Page</u>
2-1	The MHI PM burner nozzle . . . . .	2-2
2-2	Schematic of test steamer . . . . .	2-4
3-1	NO <sub>x</sub> emissions versus flue gas O <sub>2</sub> . . . . .	3-4
3-2	CO emissions versus flue gas O <sub>2</sub> . . . . .	3-8
3-3	Effect of OFA rate on NO <sub>x</sub> and CO emissions from the low-NO <sub>x</sub> burner . . . . .	3-9
3-4	Effect of FGR rate on NO <sub>x</sub> and CO emissions from the low-NO <sub>x</sub> burner . . . . .	3-10
3-5	NO <sub>x</sub> emissions versus CO for the MHI low-NO <sub>x</sub> . . . . .	3-12
3-6	Emitted particle size distribution . . . . .	3-18
3-7	N <sub>2</sub> O versus NO <sub>x</sub> emissions for external combustion sources . . . . .	3-20
A-1	Continuous monitoring system . . . . .	A-2
A-2	Schematic of Method 5/8 sampling train . . . . .	A-5
A-3	Source assessment sampling system schematic . . . . .	A-7
A-4	Flue gas analysis protocol for SASS samples . . . . .	A-8
A-5	Flue gas sample analysis protocol . . . . .	A-9
A-6	Organic analysis methodology . . . . .	A-11
A-7	C <sub>1</sub> to C <sub>6</sub> hydrocarbon sampling system . . . . .	A-13

## TABLES

<u>Table</u>		<u>Page</u>
1-1	Completed Tests During the Current Program . . . . .	1-4
2-1	Fuel Ultimate Analysis . . . . .	2-5
2-2	Fuel Trace Element Concentrations . . . . .	2-6
3-1	Flue Gas Emissions Summary: Conventional Burner . . . .	3-3
3-2	MHI Burner Performance Test Results . . . . .	3-6
3-3	Steamer/Burner Operating Conditions: Comprehensive Tests . . . . .	3-15
3-4	Steamer Thermal Efficiency . . . . .	3-15
3-5	Flue Gas Emissions . . . . .	3-16
3-6	Total Organic Emissions Summary . . . . .	3-22
3-7	Summary of Infrared Spectra of Total Sample Extracts . .	3-22
3-8	Compound Classes and Fragment Ions Searched for by Direct Insertion Probe LRMS . . . . .	3-24
3-9	SASS Particulate Extract LRMS Results . . . . .	3-24
3-10	Compounds Sought in the GC/MS Analysis and Their Detection Limits (ng/μl Injected) . . . . .	3-25
3-11	Compounds Detected in the GC/MS Analyses . . . . .	3-26
4-1	XAD-2 Resin Spike and Recovery Results . . . . .	4-3
4-2	Duplicate GC/MS Analysis Results for the XAD-2 Extract. .	4-3
A-1	Continuous Monitoring Equipment in the Mobile Laboratory . . . . .	A-4
A-2	Gas Chromatograph Specifications . . . . .	A-15

## SECTION 1

### INTRODUCTION

This report describes and presents results for a set of environmental assessment tests performed for the Environmental Protection Agency's Air and Energy Engineering Research Laboratory (EPA/AEERL) under the Combustion Modification Environmental Assessment (CMEA) program, EPA Contract No. 68-02-3188. The CMEA started in 1976 with a 3-year study, the NO<sub>x</sub> Control Technology Environmental Assessment (NO<sub>x</sub> EA, EPA Contract No. 68-02-2160), having the following four objectives:

- Identify potential multimedia environmental effects of stationary combustion sources and combustion modification technology
- Develop and document control application guidelines to minimize these effects
- Identify stationary source and combustion modification R&D priorities
- Disseminate program results to intended users

During the first year of the NO<sub>x</sub> EA, data for the environmental assessment were compiled and methodologies were developed. Furthermore, priorities for the schedule and level of effort to be devoted to evaluating the various source/fuel/control combinations were identified. This effort revealed major data gaps, particularly for noncriteria pollutants (organic emissions and trace elements) for virtually all combinations of stationary



combustion sources and combustion modification techniques. Consequently, a series of seven environmental field test programs was undertaken to fill these data gaps. The results of these tests are documented in seven individual reports (References 1-1 through 1-7) and in the NO<sub>x</sub> EA final report summarizing the entire 3-year effort (Reference 1-8).

The current CMEA program has, as major objectives, the continuation of multimedia environmental field tests initiated in the original NO<sub>x</sub> EA program. These new tests, using standardized Level 1 sampling and analytical procedures (Reference 1-9) are aimed at filling the remaining data gaps and addressing the following priority needs:

- Advanced NO<sub>x</sub> controls
- Alternate fuels
- Secondary sources
- EPA program data needs
  - Residential oil combustion
  - Wood firing in residential, commercial, and industrial sources
  - High interest emissions determination (e.g., listed and candidate hazardous air pollutant species)
- Nonsteady-state operation

The petroleum reserves which can be recovered through primary production methods have been essentially exhausted in the oil fields in Kern County, California. These fields still contain significant reserves, although the remaining crude is too viscous to be produced by normal means. This crude is currently being produced using what has been termed enhanced oil recovery (EOR). In one popular process, near saturated (80 to 90 percent quality)

steam is injected into a field. This steam heats the oil, thereby decreasing its viscosity and allowing it to be pumped.

The steam for injection is raised by crude oil-fired steam generators (often termed steamers) which have uncontrolled  $\text{NO}_x$  emissions in the 300 ppm range. Since Kern County is only in borderline attainment of the  $\text{NO}_2$  ambient air quality standard, EOR steamers have received close regulatory attention with respect to reducing  $\text{NO}_x$  emissions.

One approach to reducing  $\text{NO}_x$  emissions from these steamers incorporates a low- $\text{NO}_x$  emission burner design. One such burner was developed in Japan by Mitsubishi Heavy Industries (MHI) and is currently marketed in the United States by CE-Natco (a steamer manufacturer).

A steamer equipped with an MHI low- $\text{NO}_x$  burner was tested in the current CMEA program. These tests, described in this report, were conducted to quantify a broad emissions spectrum from the burner and to compare selected species emissions to those from a steamer equipped with a "standard" burner. Thus, a similar unit with a standard burner was also tested (in less depth, however) in this program.

In addition to the tests described in this report, another EOR steamer, this one equipped with a low- $\text{NO}_x$  burner developed under EPA contract by the Energy & Environmental Research Corporation, was also tested. Results from these tests are documented in Reference 1-10.

Table 1-1 lists all the tests performed in the CMEA program, outlining the source tested, fuel used, combustion modifications implemented and the level of sampling and analysis performed in each case. Results of these test programs are discussed in separate reports.

TABLE 1-1. COMPLETED TESTS DURING THE CURRENT PROGRAM<sup>a</sup>

Source	Description	Test points unit operation	Sampling protocol	Test collaborator
Spark-ignited, natural-gas-fired reciprocating internal combustion engine	Large bore, 6-cylinder, opposed piston, 186-kW (250 Bhp)/cyl, 900-rpm Model 38TDSB-1/8	-- Baseline (pre-NSPS) -- Increased air-fuel ratio aimed at meeting proposed NSPS of 700 ppm corrected to 15 percent O <sub>2</sub> and standard atmospheric conditions	Engine exhaust: -- SASS -- Method 5 -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous NO, NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> , CH <sub>4</sub> , TUHC Fuel Lube oil	Fairbanks Morse Division of Colt Industries
Compression ignition, diesel-fired, reciprocating internal combustion engine	Large bore, 6-cylinder opposed piston, 261-kW (350 Bhp)/cyl, 900-rpm Model 38TDD8-1/8	-- Baseline (pre-NSPS) -- Fuel injection retard aimed at meeting proposed NSPS of 600 ppm corrected to 15 percent O <sub>2</sub> and standard atmospheric conditions	Engine exhaust: -- SASS -- Method 8 -- Method 5 -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous NO, NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> , CH <sub>4</sub> , TUHC Fuel Lube oil	Fairbanks Morse Division of Colt Industries
Low-NO <sub>x</sub> , residential, condensing-heating system furnished by Karlsons Blueburner Systems Ltd. of Canada	Residential hot water heater equipped with M.A.N. low-NO <sub>x</sub> burner, 0.55 ml/s (0.5 gal/hr) firing capacity, condensing flue gas	Low-NO <sub>x</sub> burner design by M.A.N.	Furnace exhaust: -- SASS -- Method 8 -- Method 5 -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous NO, NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> , CH <sub>4</sub> , TUHC Fuel Waste water	New test
Rocketdyne/EPA low-NO <sub>x</sub> residential forced warm air furnace	Residential warm air furnace with modified high-pressure burner and firebox, 0.83 ml/s (0.75 gal/hr) firing capacity	Low-NO <sub>x</sub> burner design and integrated furnace system	Furnace exhaust: -- SASS -- Method 8 -- Controlled condensation -- Method 5 -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous NO, NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> , CH <sub>4</sub> , TUHC Fuel	New test

(continued)

TABLE 1-1. (continued)

Source	Description	Test points unit operation	Sampling protocol	Test collaborator
Pulverized coal-fired utility boiler, Conesville station	400-MW tangentially fired; new NSPS design aimed at meeting 301 ng/J NO <sub>x</sub> limit	ESP inlet and outlet, one test	ESP inlet and outlet -- SASS -- Method 5 -- Controlled condensation -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous NO, NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> Coal Bottom ash ESP ash	Exxon Research and Engineering (ER&E) conducting corrosion tests
Nova Scotia Technical College industrial boiler	1.14 kg/s steam (9,000 lb/hr) firetube fired with a mixture of coal-oil-water (COW)	-- Baseline (COW) -- Controlled SO <sub>2</sub> emissions with limestone addition	Boiler outlet -- SASS -- Method 5 -- Method 8 -- Controlled condensation -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , CO <sub>2</sub> , CO, NO <sub>x</sub> Fuel	Envirocon performed particulate and sulfur emission tests
Adelphi University industrial boiler	1.89 kg/s steam (15,000 lb/hr) hot water firetube fired with a mixture of coal-oil-water (COW)	-- Baseline (COW) -- Controlled SO <sub>2</sub> emissions with soda ash (Na <sub>2</sub> CO <sub>3</sub> ) addition	Boiler outlet -- SASS -- Method 5 -- Method 8 -- Controlled condensation -- Gas Sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , CO <sub>2</sub> , NO <sub>x</sub> , SO <sub>2</sub> , CO Fuel	Adelphi University
Pittsburgh Energy Technology Center (PETC) industrial boiler	3.03 kg/s steam (24,000 lb/hr) watertube fired with a mixture of coal-oil (COM)	-- Baseline test only with COM	Boiler outlet -- SASS -- Method 5 -- Controlled condensation -- Continuous O <sub>2</sub> , CO <sub>2</sub> , NO <sub>x</sub> , THHC, CO Fuel	PETC and General Electric (GE)

(continued)

TABLE 1-1. (continued)

Source	Description	Test points unit operation	Sampling protocol	Test collaborator
TOSCO Refinery vertical crude oil heater	2.54 Ml/day (16,000 bbl/day) natural draft process heater burning oil/refinery gas	-- Baseline -- Staged combustion using air injection lances	Heater outlet -- SASS -- Method 5 -- Controlled condensation -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO, CO <sub>2</sub> , HC -- H <sub>2</sub> O grab sample Fuel oil Refinery gas	KVB coordinating the staged combustion operation and continuous emission monitoring
Mohawk-Getty Oil industrial boiler	8.21 kg/s steam (65,000 lb/hr) watertube burning mixture of refinery gas and residual oil	-- Baseline -- Ammonia injection using the noncatalytic Thermal DeNO <sub>x</sub> Process	Economizer outlet -- SASS -- Method 5, 17 -- Controlled condensation -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Ammonia emissions -- H <sub>2</sub> O grab sample -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO, CO <sub>2</sub> Fuels (refinery gas and residual oil)	New test
Industrial boiler	2.52 kg/s steam (20,000 lb/hr) watertube burning wood waste	-- Baseline (dry wood) -- Wet (green) wood	Boiler outlet -- SASS -- Method 5 -- Controlled condensation -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO Fuel Flyash	North Carolina Department of Natural Resources, EPA IERL-RTP
Industrial boiler	3.16 kg/s steam (29,000 lb/hr) firetube with refractory firebox burning wood waste	-- Baseline (dry wood)	Outlet of cyclone particulate collector -- SASS -- Method 5 -- Controlled condensation -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO Fuel Bottom ash	North Carolina Department of Natural Resources, EPA IERL-RTP

(continued)

TABLE 1-1. (continued)

Source	Description	Test points unit operation	Sampling protocol	Test collaborator
Enhanced oil recovery steam generator	15 MW (50 million Btu/hr) steam generator burning crude oil equipped with MHI low-NO <sub>x</sub> burner	-- Performance mapping -- Low NO <sub>x</sub> operation	Steamer outlet: -- SASS -- Method 5 -- Method 8 -- Andersen impactors -- Gas sample (C <sub>1</sub> - C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO, CO <sub>2</sub> -- H <sub>2</sub> O grab sample Fuel	Getty Oil Company, CE-Natco
Pittsburgh Energy Technology Center (PETC) industrial boiler	3.03 kg/s steam (24,000 lb/hr) watertube fired with a coal-water slurry (CWS)	-- Baseline test only with CWS	Boiler outlet: -- SASS -- Method 5 -- Method 8 -- Gas sample (C <sub>1</sub> - C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO, CO <sub>2</sub> , TUHC -- H <sub>2</sub> O grab sample Fuel Bottom ash Collector hopper ash	PETC and General Electric
Spark-ignited, natural gas-fuel reciprocating internal combustion engine -- nonselective NO <sub>x</sub> reduction catalyst	610 kW (818 hp) Waukesha rich-burn engine equipped with DuPont NSCR system	-- Low NO <sub>x</sub> (with catalyst) -- 15-day emissions monitoring	Catalyst inlet and outlet -- SASS -- NH <sub>3</sub> -- HCN -- H <sub>2</sub> O grab sample -- Continuous O <sub>2</sub> , CO <sub>2</sub> , NO <sub>x</sub> TUHC Lube oil	Southern California Gas Company
Industrial boiler	180 kg/hr steam (400 lb/hr) stoker fired with a mixture of coal and waste plastic beverage containers	-- Baseline (coal) -- Coal and plastic waste	Boiler outlet -- SASS -- VOST -- Method 5 -- Method 8 -- HCl -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO, CO <sub>2</sub> , TUHC -- H <sub>2</sub> O grab sample Fuel Bottom ash Cyclone ash	Vermont Agency of Environmental Conservation

(continued)

TABLE 1-1. (concluded)

Source	Description	Test points unit operation	Sampling protocol	Test collaborator
Industrial boiler	7.6 kg/s steam (60,000 lb/hr) watertube retrofit for coal-water-slurry (CWS) firing	-- Baseline test with CWS -- 30-day emissions monitoring	Boiler outlet -- SASS -- VOST -- Method 5 -- Method 8 -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- N <sub>2</sub> O grab sample -- Continuous NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> , TUHC, SO <sub>2</sub> Fuel	EPRI, DuPont
Enhanced oil recovery steam generator	15 MW (50 million Btu/hr) steam generator burning crude oil, equipped with the EPA/EER low NO <sub>x</sub> burner	-- Low NO <sub>x</sub> (with burner) -- 30-day emission monitoring	Steamer outlet -- SASS -- VOST -- Method 5 -- Method 8 -- Controlled condensation -- Andersen impactors -- Grab sample (C <sub>1</sub> -C <sub>6</sub> HC) -- N <sub>2</sub> O grab sample -- Continuous NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> , SO <sub>2</sub> Fuel	Chevron U.S.A., EERC
Spark-ignited, natural gas-fired reciprocating internal combustion engine -- selective NO <sub>x</sub> reduction catalyst	1490 kW (2000 hp) Ingersoll-Rand lean burn engine equipped with Englehard SCR system	-- Low NO <sub>x</sub> (with catalyst) -- 15-day emissions monitoring	Catalyst inlet and outlet -- SASS -- VOST -- NH <sub>3</sub> -- HCN -- N <sub>2</sub> O grab sample -- Continuous O <sub>2</sub> , CO <sub>2</sub> , CO, NO, NO <sub>x</sub> , NO <sub>x</sub> + NH <sub>3</sub> Lube oil	Southern California Gas Company

<sup>a</sup>Acronyms used in the table: EERC, The Energy and Environmental Research Corporation; EPA IERL-RTP, The Environmental Protection Agency's Industrial Environmental Research Laboratory-Research Triangle Park; EPRI, The Electric Power Research Institute; HC, hydrocarbons; NSCR, nonselective catalytic reduction; NSPS, new source performance standard; SASS, source assessment sampling system; SCR, selective catalytic reduction; TUHC, total unburned hydrocarbon; VOST, volatile organic sampling train

## REFERENCES FOR SECTION 1

- 1-1. Larkin, R. and E. B. Higginbotham, "Combustion Modification Controls for Stationary Gas Turbines: Volume II. Utility Unit Field Test," EPA-600/7-81-122b, NTIS PB82-226473, July 1981.
- 1-2. Higginbotham, E. B., "Combustion Modification Controls for Residential and Commercial Heating Systems: Volume II. Oil-fired Residential Furnace Field Test," EPA-600/7-81-123b, NTIS PB82-231175, July 1981.
- 1-3. Higginbotham, E. B. and P. M. Goldberg, "Combustion Modification NO<sub>x</sub> Controls for Utility Boilers: Volume I. Tangential Coal-fired Unit Field Test," EPA-600/7-81-124a, NTIS PB82-227265, July 1981.
- 1-4. Sawyer, J. W. and E. B. Higginbotham, "Combustion Modification NO<sub>x</sub> Controls for Utility Boilers: Volume II. Pulverized-coal Wall-fired Unit Field Test," EPA-600/7-81-124b, NTIS PB82-227273, July 1981.
- 1-5. Sawyer, J. W. and E. B. Higginbotham, "Combustion Modification NO<sub>x</sub> Controls for Utility Boilers: Volume III. Residual-oil Wall-fired Unit Field Test," EPA-600/7-81-124c, NTIS PB82-227281, July 1981.
- 1-6. Goldberg, P. M. and E. B. Higginbotham, "Industrial Boiler Combustion Modification NO<sub>x</sub> Controls: Volume II. Stoker Coal-fired Boiler Field Test -- Site A," EPA-600/7-81-126b, NTIS PB82-231085, July 1981.
- 1-7. Lips, H. I. and E. B. Higginbotham, "Industrial Boiler Combustion Modification NO<sub>x</sub> Control: Volume III. Stoker Coal-fired Boiler Field Test -- Site B," EPA-600/7-81-126c, NTIS PB82-231095, July 1981.
- 1-8. Waterland, L. R., et al., "Environmental Assessment of Stationary Source NO<sub>x</sub> Control Technologies -- Final Report," EPA-600/7-82-034, NTIS PB82-249350, May 1982.
- 1-9. Lentzen, D. E., et al., "IERL-RTP Procedures Manual: Level 1 Environmental Assessment (Second Edition)," EPA-600/7-78-201, NTIS PB293795, October 1978.
- 1-10. Castaldini, C., et al., "Environmental Assessment of an Enhanced Oil Recovery Steam Generator Equipped with the EPA Low-NO<sub>x</sub> Burner," Acurex Draft Report TR-85-174/EED, January 1985.



## SECTION 2

### SOURCE DESCRIPTION

Tests were performed on two CE-Natco model STOF steam generators rated at 50 million Btu/hr heat output. One unit was equipped with a standard North American burner; the other had been retrofitted with the PM low-NO<sub>x</sub> burner manufactured by Mitsubishi Heavy Industries (MHI). The primary objective of the tests was to measure the NO<sub>x</sub> reduction performance of this burner as a function of its operational parameter settings (when compared to a standard burner) and to obtain data on emissions of noncriteria pollutant categories and species at a nominal low-NO<sub>x</sub> setting.

Figure 2-1 illustrates the physical design of the MHI PM burner. As shown, the rectangular burner throat is divided into five nozzles. Typically about 30 percent of the total combustion air is delivered through the central primary air nozzle. This air is mixed with a centralized oil spray comprising approximately half the total fuel fired, forming an oxygen deficient diffusion flame. A premixed flame is obtained by mixing the remaining fuel with about 60 percent of the total air, evenly delivered through each of the upper and lower nozzles. This mixing takes place in a zone offset from the burner which delays ignition until the fuel and air have mixed.

The remaining combustion air (about 10 percent) is delivered through an overfire air (OFA) injection system which injects this air approximately




Figure 2-1. The MHI PM burner nozzle.

halfway down the length of the cylindrical furnace through three sets of three ports equally spaced around the furnace circumference. This OFA is designed to ensure that sufficient excess air and mixing are achieved before combustion gas leaves the furnace.

Recirculated flue gas is delivered to the nozzles separating the central (diffusion) and outer (premix) air nozzles. This gas is used to shape the diffusion flame and to maintain separation between the diffusion and premixed flames. Typically about 15 percent of the total combustion product gas is recirculated.

Figure 2-2 shows a sketch of the steamer retrofitted with the burner system. The additional flue gas recirculation (FGR) and OFA systems along with the burner are shown.

In the test program performed, one day of flue gas emission testing was performed on the steamer equipped with the conventional burner. In these tests, flue gas  $\text{NO}_x$  emissions were measured at two steamer loads while varying the excess air fuel. The steamer equipped with the low- $\text{NO}_x$  burner was then subjected to two days of performance/emissions mapping tests in which flue gas composition ( $\text{NO}_x$ , CO,  $\text{CO}_2$ ,  $\text{O}_2$  and smoke) was characterized while varying burner operation at full steamer load. In these tests, the following were varied: the FGR rate; the relative distribution of combustion air among the premixed flame nozzles, the diffusion flame nozzles, and the OFA ports; and the overall excess air level. Finally, comprehensive emissions testing (flue gas organics, particulate load, particle-size distribution, and  $\text{SO}_2$  and  $\text{SO}_3$  emissions) was performed on the low- $\text{NO}_x$  burner-equipped steamer with the burner set at a nominal low- $\text{NO}_x$  condition.




Figure 2-2. Schematic of test steamer.

The fuel fired in both steamers for all tests was local Kern County crude. The fuel ultimate analysis is given in Table 2-1.

The concentrations of 72 trace elements in the fuel were also obtained using spark source mass spectrometry (SSMS) supplemented by atomic absorption spectrometry. Results of these analyses are given in Table 2-2.

TABLE 2-1. FUEL ULTIMATE ANALYSIS

Component (wt percent)	
Carbon	86.88
Hydrogen	10.84
Sulfur	1.06
Nitrogen	0.76
Oxygen	0.43
Ash	0.03
Higher heating, MJ/kg	43.2
value (Btu/lb)	(18,560)
API gravity	13.3

TABLE 2-2. FUEL TRACE ELEMENT CONCENTRATIONS

Element	Concentration ( $\mu\text{g/g}$ )	Element	Concentration ( $\mu\text{g/g}$ )	Element	Concentration ( $\mu\text{g/g}$ )
Aluminum	4.0	Holmium	--	Samarium	--
Antimony	0.07	Iodine	--	Scandium	0.08
Arsenic	0.4	Iridium	--	Selenium	0.2
Barium	0.5	Iron	95	Silicon	34
Beryllium	<0.01	Lanthanum	0.4	Silver	0.03
Bismuth	-- <sup>a</sup>	Lead	0.3	Sodium	22
Boron	0.2	Lithium	0.1	Strontium	0.5
Bromine	0.3	Lutetium	--	Tantalum	2
Cadmium	--	Magnesium	14	Tellurium	0.06
Calcium	48	Manganese	0.4	Terbium	--
Cerium	0.2	Mercury	<0.01	Thallium	--
Cesium	--	Molybdenum	1	Thorium	0.8
Chlorine	4	Neodymium	<0.2	Thulium	--
Chromium	0.8	Nickel	90	Tin	0.07
Cobalt	2	Niobium	<0.03	Titanium	3
Copper	5	Osmium	--	Tungsten	--
Dysprosium	--	Palladium	--	Uranium	--
Erbium	--	Phosphorus	0.8	Vanadium	80
Europium	--	Platinum	--	Ytterbium	--
Fluorine	27	Potassium	4	Yttrium	0.6
Gadolinium	--	Praseodymium	0.06	Zinc	1
Gallium	0.5	Rhenium	--	Zirconium	0.3
Germanium	0.2	Rhodium	--		
Gold	--	Rubidium	0.02		
Hafnium	--	Ruthenium	--		

<sup>a</sup> -- denotes present at less than the detection limit of 0.02  $\mu\text{g/g}$ .

## SECTION 3

### EMISSION RESULTS

As noted in Section 2, the objectives of these tests were to evaluate the  $\text{NO}_x$  emission reduction performance of the MHI PM low  $\text{NO}_x$  burner system retrofitted to an enhanced oil recovery steam generator and to quantitate emissions of noncriteria pollutant species from the retrofit steamer. To satisfy these objectives a brief series of flue gas emission measurement tests was performed on an identical unit equipped with a conventional burner. A relatively comprehensive series of performance/emission mapping tests was performed next on the unit equipped with the low  $\text{NO}_x$  burner. Finally, a set of comprehensive environmental assessment flue gas characterization tests was performed on the low  $\text{NO}_x$  burner equipped-steamer with burner operation set at a nominal low  $\text{NO}_x$  setting.

Section 3.1 summarizes results of the tests of the conventional burner-equipped steamer and the performance/emission mapping tests on the low  $\text{NO}_x$  burner-equipped steamer. Results of the comprehensive emission testing of the low  $\text{NO}_x$  burner-equipped steamer are discussed in Section 3.2.

#### 3.1 PERFORMANCE/EMISSION MAPPING TESTS

Flue gas emissions of  $\text{NO}_x$ , CO,  $\text{CO}_2$ ,  $\text{O}_2$ , and stack gas smoke readings were measured on the steamer equipped with a conventional North American burner at two loads (full load and about 75 percent of rated capacity) and several excess air settings. These measurements were performed at the stack

using a continuous flue gas monitoring system as described in Appendix A. To supplement these measurements, Getty Oil Company personnel performed complementary monitoring of the combustion gas at the steamer furnace exit.

Results of these tests are summarized in Table 3-1. The data in the table clearly suggest that there was some combustion gas dilution through air inleakage between the furnace outlet sampling location and the stack sampling location. Stack  $O_2$  levels are consistently higher and  $CO_2$  consistently lower than corresponding furnace outlet levels. CO levels (corrected to 3 percent  $O_2$ ) are comparable at the two locations at full load. However,  $NO_x$  levels at full load were generally about 40 to 50 ppm higher at the stack location than at the furnace outlet. At 75 percent load,  $NO_x$  levels at both locations were comparable; however, CO levels were apparently increased. Reasons for both these apparent increases (if they were indeed real) can only be speculated.

The stack location  $NO_x$  emissions data are plotted in Figure 3-1 as  $NO_x$  versus stack gas  $O_2$ . The figure shows a steady decrease in  $NO_x$  emissions as excess air is reduced until flue gas  $O_2$  falls below about 3 percent. Below this  $O_2$  level, the rate of  $NO_x$  emissions increases. However, referring to Table 3-1, as flue gas  $O_2$  is decreased below 3 percent, the smoke number increases to unacceptable levels. For practical operation, then, the conventional burner appears capable of attaining full load  $NO_x$  emissions of about 300 ppm (3 percent  $O_2$ ) with flue gas  $O_2$  about 3.7 percent at acceptable CO emissions and smoke number. At 75 percent load,  $NO_x$  emissions are reduced to about 250 ppm (3 percent  $O_2$ ) at flue gas  $O_2$  of 4.0 percent and acceptable CO and smoke number.

Following the conventional burner-equipped unit testing, a relatively comprehensive series of performance emission mapping tests was performed on



TABLE 3-1. FLUE GAS EMISSIONS SUMMARY: CONVENTIONAL BURNER

Test no.	Fuel flow		Heat input		Stack <sup>a</sup>					Furnace outlet <sup>b</sup>				
	(l/s)	(BPD)	(MW)	(million Btu/hr)	O <sub>2</sub> (%)	CO <sub>2</sub> (%)	CO (ppm) <sup>c</sup>	NO <sub>x</sub> (ppm) <sup>c</sup>	Smoke	O <sub>2</sub> (%)	CO <sub>2</sub> (%)	CO (ppm) <sup>c</sup>	NO <sub>x</sub> (ppm) <sup>c</sup>	SO <sub>2</sub> (ppm) <sup>c</sup>
<u>Full load</u>														
1	0.39	210	16.3	55.5	3.7	12.8	23	302	--	3.0	14.1	42	263	580
2	0.39	210	16.3	55.5	5.1	12.0	34	340	3.0	4.4	12.9	48	288	580
3	0.39	210	16.3	55.5	6.6	10.8	31	365	4.0	6.2	11.5	49	305	584
4	0.39	210	16.3	55.5	3.7	13.1	42	305	4.0	2.8	14.1	42	256	593
5	0.39	210	16.3	55.5	2.9	12.2	54	278	8.0	1.9	14.8	46	227	598
6	0.39	210	16.5	56.3	2.3	14.4	46	197	8.5	1.3	15.3	54	206	603
<u>75% load</u>														
7	0.29	160	12.4	42.3	4.2	13.3	78	246	4.0	2.8	14.1	40	254	584
8	0.29	160	12.4	42.3	6.4	11.7	96	296	2.5	5.3	12.1	46	300	608
9	0.29	160	12.4	42.3	6.1	12.7	133	290	3.0	4.0	13.2	42	277	578

<sup>a</sup>Emission measurements by Acurex.<sup>b</sup>Emission measurements by Getty Oil Company.<sup>c</sup>Dry at 3 percent O<sub>2</sub>.




Figure 3-1. NO<sub>x</sub> emissions versus flue gas O<sub>2</sub>.

the steamer equipped with the low  $\text{NO}_x$  burner. Recall from Section 2 that this burner directs combustion air to a central diffusion flame nozzle, outboard premixed flame nozzles, and overfire air injection ports. Thus, the distribution of combustion air among these streams, as well as the total air fired, are adjustable burner operating parameters. In addition, the rate at which flue gas is recirculated to the burner (to separate the diffusion and premixed air flames) is a further adjustable parameter. All of these were varied in the testing performed.

Results of the performance/emission mapping tests are summarized in Table 3-2. Again, flue gas composition both at the steamer stack and at the furnace outlet (measurements performed by Getty Oil Company personnel) are shown. For these tests there was general agreement between the stack  $\text{O}_2$  and  $\text{CO}_2$  readings and those at the furnace outlet. This suggests that negligible air inleakage occurred between these locations for the low  $\text{NO}_x$  burner-equipped steamer, in contrast to the apparent case for the steamer with the conventional burner. Corresponding  $\text{NO}_x$  and CO levels were, in general, similarly comparable (although for a few test points stack CO levels were significantly higher than furnace outlet levels).

The data in Table 3-2 show that  $\text{NO}_x$  emissions from the unit varied from 95 to 180 ppm (corrected to 3 percent  $\text{O}_2$ ) with changes in the parameters investigated. Certain conditions resulted in  $\text{NO}_x$  emissions at the stack below 100 ppm (3 percent  $\text{O}_2$ , dry), but these were, in general, accompanied by high CO emissions and high smoke spot. Conditions which resulted in  $\text{NO}_x$  in the 110 ppm range with moderate CO are also noted.

The variation in  $\text{NO}_x$  emissions with overall excess air (stack gas  $\text{O}_2$ ) for this unit was shown in Figure 3-1. The scatter in the figure results

TABLE 3-2. MHI BURNER PERFORMANCE TEST RESULTS

Test no.	Air distribution				Fuel rate		Heat input		Stack <sup>b</sup>					Furnace outlet <sup>c</sup>					
	FGR rate (%)	OFA (%)	Premix <sup>a</sup> flame air (%)	Diffusion <sup>a</sup> flame air (%)	(l/s)	(BPD)	(MW)	(Million Btu/hr)	O <sub>2</sub> (%)	CO <sub>2</sub> (%)	CO (ppm) <sup>d</sup>	NO <sub>x</sub> (ppm) <sup>d</sup>	TUHC (ppm) <sup>d</sup>	Smoke	O <sub>2</sub> (%)	CO (ppm) <sup>d</sup>	CO <sub>2</sub> (%)	NO <sub>x</sub> (ppm) <sup>d</sup>	SO <sub>2</sub> (ppm) <sup>d</sup>
1	8.9	19	48	33	0.383	208	16.1	55.0	3.5	13.4	99	119	3.2	>10	4.3	70	12.9	124	597
2	9.4	18	52	30	0.385	209	16.2	55.2	2.7	13.9	266	102	4.4	10	3.3	80	13.9	113	594
3	13.4	19	52	29	0.381	207	16.0	54.7	2.6	13.9	215	99	3.2	9.5	3.1	80	13.9	108	582
4	9.9	19	53	29	0.390	212	16.4	56.0	2.5	14.0	236	95	5.3	10	3.1	73	14.0	109	592
5	9.9	13	52	35	0.379	206	16.0	54.5	2.6	14.0	269	97	3.9	8	3.0	76	13.9	105	576
6	9.4	15	51	34	0.377	205	15.9	54.2	3.4	13.9	60	119	2.2	6	4.0	59	13.0	126	573
7	8.8	15	51	34	0.388	211	16.3	55.8	3.8	13.3	60	140	1.4	3.5	4.4	44	12.9	140	581
8	9.1	11	56	33	0.386	210	16.3	55.5	3.2	13.2	51	145	1.1	3.5	3.3	45	13.9	144	568
9	9.8	9	57	34	0.386	210	16.3	55.5	2.2	14.6	79	110	1.0	8	2.3	58	14.5	112	585
10	9.3	8	57	35	0.388	211	16.3	55.8	3.1	13.3	141	111	4.5	10	2.2	104	14.7	102	616
11	8.8	8	57	35	0.386	210	16.3	55.5	4.1	12.5	70	145	8.5	6	3.2	54	13.8	126	595
12	8.2	8	58	34	0.396	215	16.7	56.8	4.2	12.5	64	180	8.6	3.5	4.2	46	12.9	174	570
13	8.4	8	55	37	0.388	211	16.3	55.8	4.2	12.4	51	126	1.8	4	4.6	55	12.5	125	587
14	8.8	8	55	37	0.390	212	16.4	56.0	3.4	13.0	85	111	1.1	8	3.6	67	13.5	114	573
15	6.6	8	55	37	0.390	212	16.4	56.0	4.2	12.3	66	131	1.4	6	4.5	58	12.7	131	572
16	2.6	8	55	37	0.390	212	16.4	56.0	4.2	12.3	54	152	1.1	2.5	4.6	53	12.6	149	582
17	8.4	7	59	34	0.405	220	17.0	58.2	4.2	12.6	60	143	1.4	4	4.1	50	13.1	144	556
18	9.1	6	58	36	0.377	205	15.9	54.2	3.6	12.9	62	116	0.5	6	3.3	64	13.8	113	558
19	9.8	7	58	35	0.386	210	16.3	55.5	2.8	13.5	80	106	0	8	2.3	87	14.5	98	574
20	9.8	3	62	35	0.388	211	16.3	55.8	2.8	13.6	64	133	0	6	2.5	55	14.5	126	583
21	9.5	10	54	36	0.386	210	16.3	55.5	3.0	13.3	93	106	0	8	2.5	68	14.5	108	586
(SASS)																			

<sup>a</sup>Premix and diffusion nozzle combustion air flows were not measured. Values shown here were estimated based on blower discharge pressure and static pressure readings in the windbox for diffusion and premix zones.

<sup>b</sup>Emission measurements by Acurex.

<sup>c</sup>Emission measurements by Getty Oil Company.

<sup>d</sup>Dry at 3 percent O<sub>2</sub>.

from changes in  $\text{NO}_x$  emissions with the split in air flowrates among the diffusion and premixed flames and the OFA ports, and FGR rates at constant overall excess air. In general, though,  $\text{NO}_x$  emissions with the low- $\text{NO}_x$  burner at full load were roughly half those of the conventional burner at a given flue gas  $\text{O}_2$ .

Figure 3-2 shows steamer stack gas CO emissions versus stack gas  $\text{O}_2$  for both burners at full load. Again the scatter in the data for the low- $\text{NO}_x$  burner results from variations in air distribution and FGR rate at constant stack  $\text{O}_2$ . The data in Figure 3-2 show that CO emissions from the low- $\text{NO}_x$  burner increased steeply at flue gas  $\text{O}_2$  below 2.5 to 3.0 percent. This contrasts with conventional burner behavior where CO emissions were still low at flue gas  $\text{O}_2$  down to 2.5 percent. The higher CO levels from the low- $\text{NO}_x$  burner, which were accompanied by high smoke spot (see Table 3-2) are attributed to flame impingement which was observed at the 4 and 8 o'clock positions at virtually all burner settings. Higher CO levels are attributed to increased flame impingement and excessively low diffusion zone stoichiometries during low  $\text{O}_2$  and high OFA tests.

The effect of OFA flowrate on both CO and  $\text{NO}_x$  levels for the low- $\text{NO}_x$  burner is illustrated in Figure 3-3. CO levels decrease sharply at OFA rates below 10 percent. At 3 percent OFA, CO levels are nearly those of the conventional burner (see Figure 3-2).  $\text{NO}_x$  emissions at minimum OFA, however, are not significantly higher than those at high OFA rates.

The effect of FGR on  $\text{NO}_x$  and CO emissions from the low- $\text{NO}_x$  burner is shown in Figure 3-4. FGR had a greater effect at a higher  $\text{O}_2$  and lower OFA levels (4 percent and 8 percent OFA) than it did at lower  $\text{O}_2$  and higher OFA levels ( $\text{O}_2$  of 2.6 percent and 19 percent OFA). CO responded in an opposite






Figure 3-2. CO emissions versus flue gas O<sub>2</sub>.



<sup>a</sup>Diff: Diffusion flame air  
<sup>b</sup>Prem: Premixed flame air

Figure 3-3. Effect of OFA rate on NO<sub>x</sub> and CO emissions from the low-NO<sub>x</sub> burner.



<sup>a</sup>Diff: Diffusion flame air  
<sup>b</sup>Prem: Premixed flame air

Figure 3-4. Effect of FGR rate on NO<sub>x</sub> and CO emissions from the low NO<sub>x</sub> burner.



manner. This can be explained in part by the greater mixing occurring at higher burner stoichiometries combined with lower FGR rates. This mixing tended to partly cancel the low-NO<sub>x</sub> properties of the split flame. Conversely, the higher FGR rates combined with lower burner stoichiometry, while keeping the flames separate, will tend to cause greater impingement of the premix flame, which increased the CO levels.

Figure 3-5 shows a crossplot of the NO<sub>x</sub>/CO emission data for the low-NO<sub>x</sub> burner. This figure shows that, as the burner is adjusted to give NO<sub>x</sub> emissions below about 110 ppm (3 percent O<sub>2</sub>), CO emissions (and smoke, see Table 3-2) increase significantly. Thus, for this burner/steamer combination, minimum NO<sub>x</sub> emissions at acceptable operation appear to be 110 ppm.

### 3.2 ENVIRONMENTAL ASSESSMENT TESTING

Following the performance/emission mapping tests discussed in Section 3.2, a set of burner operating conditions was selected for comprehensive emissions testing. The sampling protocol for these comprehensive tests included:

- Continuous monitoring for NO<sub>x</sub>, O<sub>2</sub>, CO, CO<sub>2</sub>, and total unburned hydrocarbons (TUHC)
- Source assessment sampling system (SASS) for particulate size fractionation, and organic emissions
- EPA Method 5/8 for particulate mass emissions, and SO<sub>2</sub> and SO<sub>3</sub> emissions
- Andersen impactor train sampling for particle size distribution determination




Figure 3-5. NO<sub>x</sub> emissions versus CO for the MHI low NO<sub>x</sub> burner.

- Grab sample for onsite analysis of C<sub>1</sub> to C<sub>6</sub> hydrocarbons by gas chromatography (GC)
- Grab sample for laboratory analysis of N<sub>2</sub>O

All flue gas sampling for these tests was performed at the steamer stack. In addition, as for other testing performed in this program, Getty Oil Company personnel performed continuous flue gas monitoring at the steamer furnace outlet.

The analysis protocol for SASS samples included:

- Analyzing SASS train samples for total organic content in two boiling point ranges: 100° to 300°C by total chromatographable organics (TCO) analysis and greater than 300°C by gravimetry (GRAV)
- Analyzing the SASS train sorbent module and particulate extracts for the 58 semivolatile organic priority pollutant species including many of the PAH compounds
- Performing infrared (IR) spectrometry analysis of the GRAV residue of organic sample extracts
- Performing direct insertion probe low resolution mass spectrometry (LRMS) analysis of selected sample extracts

All aspects of the sampling and analysis protocols conformed to a modified EPA Level 1 protocol (Reference 3-1). Details of the procedures used are discussed in Appendix A.

Bioassay testing of SASS samples, a normal part of the comprehensive testing performed in this project, was not done in these tests due to the limited amount of particulate sample obtained and the very low organic content of the sorbent module extract.

Results of these comprehensive tests are discussed in the following subsections. Section 3.2.1 further details the steamer operating condition during the tests performed; Section 3.2.2 presents the criteria pollutant and other gas phase species emission results; and Section 3.3.3 summarizes organic category and species emission results.

#### 3.2.1 Burner and Steamer Operation

The burner operating conditions selected for comprehensive testing matched those noted for Test 21 in Table 3-2. This operating point was selected since it represented about a minimum  $\text{NO}_x$  condition with CO emissions below 100 ppm (see Figure 3-5). The specific steamer and burner operating conditions for these tests are summarized in Table 3-3.

The steamer efficiency noted in Table 3-3 was calculated based on the ASME heat loss method (ASME PTC 4.1). The relative contributions to the calculations are summarized in Table 3-4. As shown in this table, most of the efficiency loss was through dry gas loss and moisture loss from the fuel hydrogen. The overall efficiency noted (82.8 percent) compares favorably to the efficiency of conventional burner-equipped units.

#### 3.2.2 Criteria Pollutant and Other Gas Phase Species Emissions

Table 3-5 summarizes the gaseous and particulate emission levels measured during the comprehensive tests. Continuous emission monitor measurements from both the stack location and the furnace outlet location (obtained by Getty Oil personnel) are noted in the table. As shown in the table, steamer stack  $\text{NO}_x$  emissions were just below 110 ppm (3 percent  $\text{O}_2$ ) with CO emissions of 93 ppm (3 percent  $\text{O}_2$ ), negligible TUHC emissions, and a smoke reading of 8.

TABLE 3-3. STEAMER/BURNER OPERATING CONDITIONS:  
COMPREHENSIVE TESTS

Fuel flow, 1/s (BPD)	0.386 (210)
Heat input, MW (million Btu/hr)	16.3 (55.5)
Feedwater flow, 1/s (BPD)	6.72 (3,650)
Steam pressure, MPa (psig)	4.55 (660)
Air flows (percent)	
Diffusion	36
Premix	54
Overfire	10
FGR rate (percent)	9.5
Steamer efficiency (percent)	82.8

TABLE 3-4. STEAMER THERMAL EFFICIENCY

Heat loss efficiency (percent)	
Dry gas loss	6.8
Loss due to fuel moisture	--
Loss due to water from the combustion of fuel hydrogen	6.3
Loss due to combustibles in the flyash	0.6
Radiation loss	2.0
Unmeasured loss	1.5
Total loss	17.2
Efficiency (percent)	82.8

TABLE 3-5. FLUE GAS EMISSIONS

Pollutant	Stack <sup>a</sup>		Furnace outlet <sup>b</sup>			
	Range	Average	Range	Average		
As measured:						
O <sub>2</sub> , percent dry	2.7 to 3.3	3.0	2.4 to 2.7	2.5		
CO <sub>2</sub> , percent dry	13.1 to 13.5	13.3	14.4 to 14.5	14.4		
NO <sub>x</sub> , ppm dry	108 to 115	106	110 to 112	111		
N <sub>2</sub> O, ppm dry	12.9 to 20.5 <sup>c</sup>	17.0	--d	--d		
CO, ppm dry	45 to 135	93	68 to 75	71		
TUHC, ppm dry	<1	<1	--d	--d		
SO <sub>2</sub> , ppm dry						
Continuous monitor	--d	--c	550 to 610	600		
Method 8	--e	594	--d	--d		
SO <sub>3</sub> , ppm	--e	3.1	--d	--d		
Method 8						
Bacharach smoke number	8	8	--d	--d		
	ppm	ng/J <sup>f</sup>	1b/million Btu <sup>f</sup>	ppm	ng/J <sup>f</sup>	1b/million Btu <sup>f</sup>
Corrected to 3% O <sub>2</sub>						
NO <sub>x</sub> (as NO <sub>2</sub> )	106	73.7	0.171	108	77.2	0.179
N <sub>2</sub> O	17	11	0.026	--d	--d	--d
CO	93	39	0.091	69	29	0.069
TUHC (as CH <sub>4</sub> )	<1	<0.2	<0.001	--d	--d	--d
SO <sub>2</sub>						
Continuous monitor	--d	--d	--d	584	565	1.31
Method 8	594	574	1.34	--d	--d	--d
SO <sub>3</sub> (as H <sub>2</sub> SO <sub>4</sub> )						
Method 8	3.1	4.5	0.010	--d	--d	--d
Particulate	mg/dscm					
Method 5	39	14	0.033	--d	--d	--d
SASS	118	30	0.071	--d	--d	--d
Andersen	579	219	0.0489	--d	--d	--d

<sup>a</sup>Emission measurements by Acurex.<sup>b</sup>Emission measurements by Getty Oil Company.<sup>c</sup>Range over duplicate analysis of 6 separate gas samples.<sup>d</sup>Measurement not performed at this location.<sup>e</sup>Extractive sampling procedure, range not applicable.<sup>f</sup>Heat input basis.<sup>g</sup>Average of two trains run.

The data in Table 3-5 show relatively good agreement between the monitor measurements at the stack and furnace outlet locations. In addition, there was good agreement between the flue gas SO<sub>2</sub> levels measured with a continuous monitor at the furnace outlet and by the Method 8 train run at the stack.

The Method 8 results suggest that SO<sub>3</sub> represents about 0.5 percent of the total sulfur oxides present in the flue gas. This ratio is significantly lower than the 5 to 10 percent range typical for residual oil-fired utility and industrial boilers (Reference 3-2). The SO<sub>2</sub> and SO<sub>3</sub> levels measured by Method 8 in the flue gas would be as expected for complete conversion of all the sulfur in a 1.2 weight percent sulfur fuel oil with heating value as noted in Table 2-1. This compares favorably to the 1.06 percent sulfur content measured in the fuel.

Particulate emissions were measured at 39 mg/dscm by Method 5, 118 mg/dscm by SASS, and 57 mg/dscm as an average of two Andersen impactor trains. These are in fair agreement. The Method 5 result is the most trustworthy, since this reference method involves a multipoint (traverse) isokinetic sampling procedure.

Particle size distribution results from the two Andersen impactor trains run are shown in Figure 3-6. Results from the two runs are similar. The mean particle diameter of emitted particulate was in the 3 to 4  $\mu$ m range, for runs 1 and 2, respectively.

Emissions of nitrous oxide were also measured in these tests. The level noted, at 17 ppm, is about 16 percent of the NO<sub>x</sub> emission level. Tests of several other fossil fuel combustion sources have shown that N<sub>2</sub>O emissions are generally in the range of 20 percent of the NO<sub>x</sub> emission level. These




Figure 3-6. Emitted particle size distribution.



data are summarized in Figure 3-7. The point noted for this study falls on the curve corresponding to other data. The curve noted in Figure 3-7 was obtained from a least squares fit of all the data points shown in the figure, with the constraint that the curve pass through the origin. The relationship shown,  $N_2O = 0.22 NO_x$ , had a correlation coefficient ( $r^2$ ) of 0.88.


### 3.2.3 Organic Species Emissions

Organic analyses were performed on specified flue gas samples according to EPA Level 1 protocol (Reference 3-1) as outlined in Appendix A. Volatile organics having boiling points in the  $C_1$  to  $C_6$  range of less than  $100^\circ C$  ( $212^\circ F$ ) were determined by analysis of flue gas grab samples by onsite gas chromatography. The SASS train particulate, organic module sorbent (XAD-2), and organic module condensate (OMC) samples were extracted with methylene chloride in a Soxhlet apparatus. The extracts (XAD-2 and OMC extracts were combined) were then subjected to total chromatographable organic (TCO) and gravimetric (GRAV) analyses to determine species within the  $100^\circ$  to  $300^\circ C$  ( $212^\circ$  to  $572^\circ F$ ), and greater than  $300^\circ C$  ( $572^\circ F$ ) boiling point ranges, respectively. Infrared (IR) spectra of the GRAV residue of the extracts were also obtained.

The extracts were also analyzed via gas chromatography/mass spectrometry (GC/MS) for the semivolatile organic priority pollutant species (including many polynuclear aromatic hydrocarbons (PAH's)). Other major chromatogram peaks were identified and approximately quantitated.

Since the total organic contents (TCO and GRAV) of the extract samples were less than 15 mg, liquid chromatographic separations were not performed. However, low resolution mass spectrometry (LRMS) analysis of the particulate extract was performed.

3-20



AB4-0742

Figure 3-7.  $N_2O$  versus  $NO_x$  emissions for external combustion sources.

#### 3.2.3.1 Total Organic Analysis

Table 3-6 summarizes measured organic emissions from the low NO<sub>x</sub> burner-equipped steamer by organic boiling point range. The organic emissions are dominated by the volatile (C<sub>1</sub> to C<sub>6</sub>) fraction, which is further composed primarily of compounds in the C<sub>3</sub> and C<sub>4</sub> boiling range. No semivolatile organics were detected. Nonvolatile organics (nominally C<sub>16</sub>+) were found in the particulate, though not in the sorbent module. This confirms the high smoke emissions for the tests and suggests soot formation was occurring.

The C<sub>1</sub>, C<sub>3</sub>, and C<sub>4</sub> volatile hydrocarbon levels noted in Table 3-6 correspond to 0.3, 4.6, and 0.9 ppm, respectively, as measured. The total hydrocarbon monitor (which was unheated) read <1 ppm (see Table 3-5) for the tests. The two measurements are in fair agreement; most C<sub>4</sub> would not reach the total hydrocarbon monitor, and the response factor for C<sub>3</sub> hydrocarbon would be less than 1 ppm (as methane).

#### 3.2.3.2 Infrared Spectra of Total Sample Extracts

The results of the IR spectrometry analysis of total sample extracts are summarized in Table 3-7. The SASS particulate spectrum suggest only the presence of aliphatic hydrocarbons in the organic fraction. The XAD-2 extract spectrum is consistent with the presence of oxygenated species such as carboxylic acids and alcohols. An interpretable spectrum for this sample was obtained despite its low organic content as noted in Table 3-6.

#### 3.2.3.3 Low Resolution Mass Spectrometry Analysis of Total Sample Extracts

The SASS particulate extract was subjected to LRMS analysis via direct insertion probe to obtain compound category composition information. The compound categories searched for with the characteristic ions used to

TABLE 3-6. TOTAL ORGANIC EMISSIONS SUMMARY

Organic category	mg/dscm	ng/J
Volatile organics analyzed in the field by gas chromatography		
C <sub>1</sub>	0.2	0.07
C <sub>2</sub>	0	0
C <sub>3</sub>	8.4	3.0
C <sub>4</sub>	2.2	0.80
C <sub>5</sub>	0	0
C <sub>6</sub>	0	0
Total C <sub>1</sub> -C <sub>6</sub>	10.8	3.9
Semivolatile organics analyzed by TCO		
Filter	--	--
XAD-2	<0.004	<0.001
Total C <sub>7</sub> -C <sub>16</sub>	<0.004	<0.001
Nonvolatile organics analyzed by gravimetry		
Filter	0.3	0.11
XAD-2	<0.1	<0.04
Total C <sub>16</sub> +	0.3	1.1
Total organics	11.1	4.0

TABLE 3-7. SUMMARY OF INFRARED SPECTRA OF TOTAL SAMPLE EXTRACTS

Sample	Wave number (cm <sup>-1</sup> )	Intensity	Possible assignment	Possible compound categories present
Particulate extract	2980-2910	Strong	C-H stretch	Aliphatic hydrocarbons
XAD-2	3500-3020	Strong	O-H stretch	Oxygenated hydrocarbons such as carboxylic acids or alcohols
	1660	Strong	C=O stretch	
	1270-1130	Strong	C-O stretch	

identify them are listed in Table 3-8. Table 3-9 notes compound categories found and their relative abundance (intensity). As noted, aliphatic hydrocarbons was the major organic category present in the sample. Minor categories present were ketones and heterocyclic nitrogen compounds. Specific compounds detected suggested that the ketones were chiefly fluoren-9-one, and the nitrogen heterocyclics were chiefly ethyl carbazole. The LRMS results suggest that fluoren-9-one and ethyl carbazole were present at levels in the 250  $\mu\text{g/g}$  of particulate range. Confirmation of this by GC/MS is discussed in Section 3.2.3.4.

#### 3.2.3.4 Gas Chromatography/Mass Spectrometry of Total Sample Extracts

Capillary column GC/MS analyses for the semivolatile organic priority pollutant species, a category which includes several polynuclear aromatic hydrocarbons (PAH's), were performed on the SASS particulate and XAD-2 extracts. The compounds sought in the analyses and their respective detection limits are listed in Table 3-10. In addition, major peaks in the chromatogram, other than these compounds, were identified and quantitated. Results of the analyses are summarized in Table 3-11.

Of the PAH's, only naphthalene, phenanthrene, and pyrene were found, and, except for the naphthalene, which was present at the highest concentration, these were found only in the particulate. The other species detected were generally oxygenated aromatics and fused aromatics. Benzoic acid was present at relatively high levels, followed by fluoren-9-one and ethyl carbazole. The levels of the fluorenone and ethyl carbazole, at 180 and 110  $\mu\text{g/g}$  particulate respectively, confirm the qualitative results of the LRMS analyses discussed in Section 3.2.3.3.

TABLE 3-8. COMPOUND CLASSES AND FRAGMENT IONS SEARCHED FOR BY DIRECT INSERTION PROBE LRMS

Compound class	Fragment ions (m/e <sup>-</sup> )
Polynuclear aromatic hydrocarbons	178,202,216,228,252,276
Aliphatic hydrocarbons	57,71
Halogenated aliphatics	49,63,79,81,93,95,107,109
Aromatic hydrocarbons	50,51,77,78,79,91
Ethers	45,59,73
Alcohols	45,59,61,73,75
Phenols	51,77,94
Nitriles	54,68,82
Phthalate esters	149,167
Amines	44,58
Ketones	51,71
N-heterocyclics	117,129,167,179
Mercaptans, sulfides	47,61,75
Benzothiophenes	57,58,59,69,70,85,97,111,125
Carboxylic acids	60,73,149
Amides	58,72,86,100

TABLE 3-9. SASS PARTICULATE EXTRACT LRMS RESULTS<sup>a</sup>

Intensity <sup>b</sup>	Category	MW range
Major categories		
100	Aliphatic hydrocarbons	150 to 250
10	Heterocyclic nitrogen compounds	150 to 200
10	Ketones	150 to 200
1	Polynuclear aromatic hydrocarbons	150 to 250
Specific compounds		
10	Fluoren-9-one	180
10	Ethyl carbazole	195

<sup>a</sup>Total organic content of this sample is 3.0 mg/g particulate, GRAV compounds.

<sup>b</sup>100: major component; 10: minor component; 1: trace component.

TABLE 3-10. COMPOUNDS SOUGHT IN THE GC/MS ANALYSIS AND THEIR DETECTION LIMITS (ng/ $\mu$ l INJECTED)

<u>Acid compounds</u>			
2,4,6-trichlorophenol	5	2-nitrophenol	5
p-chloro-m-cresol	5	4-nitrophenol	20
2-chlorophenol	5	2,4-dinitrophenol	20
2,4-dichlorophenol	5	4,6-dinitro-o-cresol	20
2,4-dimethylphenol	5	pentachlorophenol	5
		phenol	1
<u>Base neutral compounds</u>			
1,2,4-trichlorobenzene	1	benzo(c)phenanthrene	40
1,2-dichlorobenzene	1	bis(2-chloroethoxy)methane	1
1,2-diphenylhydrazine	1	bis(2-chloroethyl)ether	1
(as azobenzene)		bis(2-chloroisopropyl)ether	1
1,3-dichlorobenzene	1	bis(2-ethylhexyl)phthalate	1
1,4-dichlorobenzene	1	butyl benzyl phthalate	1
2,4-dinitrotoluene	1	chrysene	1
2,6-dinitrotoluene	1	di-n-butyl phthalate	1
2-chloronaphthalene	1	di-n-octyl phthalate	1
3,3'-dichlorobenzidine	5	dibenzo(a,h)anthracene	5
3-methyl cholanthrene	40	dibenzo(c,g)carbazole	40
4-bromophenyl phenyl ether	1	diethyl phthalate	1
4-chlorophenyl phenyl ether	1	dimethyl phthalate	1
7,12-dimethyl benz(a)anthracene	40	fluoranthene	1
N-nitrosodi-n-propylamine	5	fluorene	1
N-nitrosodimethylamine	NA	hexachlorobenzene	1
N-nitrosodiphenylamine	1	hexachlorobutadiene	1
acenaphthene	1	hexachlorocyclopentadiene	1
acenaphthylene	1	hexachloroethane	1
anthracene	1	indeno(1,2,3-cd)pyrene	5
benzo(ghi)perylene	5	isophorone	1
benzidine	20	naphthalene	1
benzo(b)fluoranthene	1	nitrobenzene	1
benzo(k)fluoranthene	1	perylene	40
benzo(a)anthracene	1	phenanthrene	1
benzo(a)pyrene	1	pyrene	1

TABLE 3-11. COMPOUNDS DETECTED IN THE GC/MS ANALYSES

Species	Filter particulate <sup>a</sup> ( $\mu\text{g/g}$ )	( $\mu\text{g/dscm}$ )	XAD-2 extract <sup>a, b</sup> ( $\mu\text{g/dscm}$ )	Total flue gas <sup>c</sup> ( $\mu\text{g/dscm}$ )
<u>Semivolatile organic priority pollutants</u>				
Naphthalene	1.6	0.19	1.2	1.4
Phenanthrene	2.6	0.30	<0.04	0.30
Phenol	1.9	0.22	<0.04	0.22
Pyrene	0.97	0.11	<0.04	0.11
<u>Other compounds identified</u>				
Benzofurandione	--	--	0.44	0.44
Benzoic acid	--	--	34	34
Benzothiazole	28	3.3	--	3.3
Dichlorodibenzosulfone	--	--	0.52	0.52
Ethyl benzoate	--	--	0.40	0.40
Ethyl carbazole	110	13	--	13
Fluoren-9-one	180	20	--	20
Terphenyl	45	5.2	--	5.2

<sup>a</sup>27.0 dscm sampled, 3.11g particulate on filter.

<sup>b</sup>Average of duplicate injections.

<sup>c</sup>Sum of average of duplicate XAD-2 result plus filter result.



### REFERENCES FOR SECTION 3

- 3-1. Lentzen, D. E., et.al., "IERL-RTP Procedures Manual: Level 1 Environmental Assessment (Second Edition)", EPA 600/7-78-201, NTIS PB293795, October 1978.
- 3-2. Waterland, L. R., et.al., "Environmental Assessment of Stationary Source NO<sub>x</sub> Control Technologies --Final Report," EPA-600/7-82-034, NTIS PB82-249350, May 1982.
- 3-3. DeRosier, R., "Environmental Assessment of a Watertube Boiler Firing Coal/Oil Mixture," Acurex Report TR-81-87/EE, March 1984.
- 3-4. DeRosier, R., "Environmental Assessment of a Crude-Oil Heater Using Staged Air Lances for NO<sub>x</sub> Reduction," Acurex Report TR-82-94/EE, November 1983.
- 3-5. DeRosier, R., and L. R. Waterland, "Environmental Assessment of a Watertube Boiler Firing a Coal-Water-Slurry," Acurex Report TR-84-156/EE, February 1985.
- 3-6. Castaldini, C., et.al., "Environmental Assessment of NH<sub>3</sub> Injection for an Industrial Package Boiler," Acurex Draft Report TR-83-139/EE, November 1983.
- 3-7. Waterland, L. R., et.al., "Environmental Assessment of a Commercial Boiler Firing a Coal/Plastic Waste Mixture," Acurex Draft Report TR-85-\_\_\_/EE, February 1985.
- 3-8. VanBuren, D., and L. R. Waterland, "Environmental Assessment of a Coal-Water-Slurry-Fired Industrial Boiler," Acurex Draft Report TR-84-155/EE, March 1985.
- 3-9. Castaldini, C., et al., "Environmental Assessment of an Enhanced Oil Recovery Steam Generator Equipped with the EPA Low NO<sub>x</sub> Burner," Acurex Draft Report TR-85-174/EE, January 1985.

## SECTION 4

### QUALITY ASSURANCE ACTIVITIES

Specific quality assurance (QA) activities performed to determine the accuracy and precision of the laboratory analyses performed on samples collected in this test program included:

- Spiking a sample of cleaned XAD-2 resin from the lot used in this test with TCO, GRAV, and semivolatile priority pollutant compounds and analyzing the spiked resin to determine the accuracy (recovery) of the resin extraction and subsequent analyses
- Analyzing NBS flyash for mercury to determine the accuracy of the atomic absorption technique used
- Performing duplicate TCO and GC/MS injections on the SASS train XAD-2 extract to determine the precision of these measurements

The following paragraphs discuss results of these QA activities.

#### 4.1 ACCURACY DETERMINATIONS

A sample of XAD-2 resin from the cleaned lot used for these tests was spiked with 3.0 mg bis(2-ethylhexyl)phthalate, 200 µg tetradecane, and 100 µg each of dg-naphthalene, phenanthrene, and pyrene. Thus, this resin contained 0.3 mg TCO compounds (tetradecane and naphthalene) 3.2 mg GRAV compounds (the phthalate, phenanthrene, and pyrene) and 100 µg each of the three polynuclear aromatics for the semivolatile organic priority pollutant analysis.

Results of the analyses of this spiked resin are shown in Table 4-1. As noted, the recovery of the TCO analysis was 125 percent, of the GRAV analysis was 81 percent, and averaged 77 percent for the GC/MS analyses. If these are interpreted to be the accuracy of these measurements, all fall within the project accuracy objective (Reference 4-1) also noted in Table 4-1.

A sample of NBS 1633a flyash was analyzed by the cold vapor atomic absorption technique used for sample determinations in this project. The analysis result was 0.18 ppm Hg in the sample; the NBS certified value is 0.16 ppm. Thus, the accuracy of this measurement was within 11 percent, again within the QA objective of  $\pm 20$  percent for this measurement.

#### 4.2 PRECISION DETERMINATIONS

The XAD-2 extract samples from the SASS train for this test were analyzed in duplicate for TCO content, and for the semivolatile organic priority pollutants and other major peaks by GC/MS. The two TCO measures were 0.087 and 0.094 ng/injection, giving a relative standard deviation of 5.5 percent. This is within the precision objective of this measurement of 10 percent (Reference 4-1).

Results of the duplicate GC/MS injections are summarized in Table 4-2. The relative standard deviations for all compounds quantitated were well within the project precision objective of 50 percent for this measurement.

TABLE 4-1. XAD-2 RESIN SPIKE AND RECOVERY RESULTS

Measurement	Spiked amount (mg)	Recovered amount (mg)	Percent recovery	Implied accuracy	Accuracy objective <sup>a</sup>
Total chromatographable organics (TCO)	0.3	0.4	125	+25	±50
Gravimetric organics (GRAV)	3.2	2.6	81	-19	±50
Semivolatile organic priority pollutants:					
dg-Naphthalene	0.1	0.077	77	-23	
Phenanthrene	0.1	0.077	77	-23	
Pyrene	0.1	0.077	77	-23	
Average			77	-23	-50 +100

<sup>a</sup>Reference 4-1.

TABLE 4-2. DUPLICATE GC/MS ANALYSIS RESULTS FOR THE XAD-2 EXTRACT

Compound	Run 1 µg/train	Run 2 µg/train	Relative standard deviation (%)
Phenol	26	37	24.7
Benzofurandione	10	14	23.6
Benzoic acid	960	900	4.6
Dichlorodibenzosulfone	13	15	10.1
Ethyl benzoate	10	12	12.9

#### REFERENCE FOR SECTION 4

- 4-1. "Quality Assurance Plan for the Combustion Modification Environmental Assessment," Acurex Corporation for EPA Contract 68-02-2160, September 10, 1982.

## SECTION 5

### SUMMARY

A comprehensive emissions testing program was performed on an enhanced oil recovery steam generator (EOR steamer) equipped with an MHI PM low NO<sub>x</sub> burner, with less detailed comparison testing performed on an identical unit equipped with a conventional North American burner.

Full load NO<sub>x</sub> emissions from the conventional burner-equipped boiler varied from 365 ppm (corrected to 3 percent O<sub>2</sub>) with stack O<sub>2</sub> of 6.6 percent to 197 ppm with stack O<sub>2</sub> of 2.3 percent. However, smoke emission levels were unacceptably high at the lower O<sub>2</sub>, lower NO<sub>x</sub> levels. A practical NO<sub>x</sub> emission limit (acceptable CO and smoke emissions) of about 300 ppm (corrected to 3 percent O<sub>2</sub>) with flue gas O<sub>2</sub> of 3.7 percent could be maintained. At 75 percent load NO<sub>x</sub> emissions were reduced to about 250 ppm with stack O<sub>2</sub> of 4.0 percent and acceptable CO and smoke emissions.

Full load NO<sub>x</sub> emissions from the low-NO<sub>x</sub> burner-equipped steamer varied from 95 to 180 ppm (corrected to 3 percent O<sub>2</sub>) with variations in the overall excess air level (as measured by stack O<sub>2</sub>), the distribution of combustion air among the burner's premixed flame nozzle, diffusion flame nozzle, and overfire (OFA) air ports, and the rate of flue gas recirculation (FGR) to the burner to separate premixed and diffusion flames. Again, unacceptably high CO and smoke emissions existed at the lower NO<sub>x</sub> conditions. A NO<sub>x</sub> emission

level of about 110 ppm (3 percent O<sub>2</sub>) could be maintained with acceptable CO and smoke.

Comprehensive emissions testing of the low-NO<sub>x</sub> burner-equipped boiler was performed with the burner operation at a nominal low-NO<sub>x</sub> setting. With 54 percent of the combustion air supplied to the burner's premix flame, 36 percent to the diffusion flame, and 10 percent to the OFA ports, and with 9.5 percent FGR and 3.0 percent stack O<sub>2</sub>, NO<sub>x</sub> emissions were 106 ppm, CO emissions were 93 ppm, and Bacharach smoke number was 8. At this condition SO<sub>2</sub> and SO<sub>3</sub> emissions were 594 ppm and 3.1 ppm respectively, and particulate emissions were 39 mg/dscm. The mean particle size of the particulate was in the 3 to 4 μm range (two separate impactor train runs).

Total organic emissions were 11.1 mg/dscm, 97 percent of which was in the volatile (C<sub>1</sub> to C<sub>6</sub>) boiling point range; the remainder was in the nonvolatile (>C<sub>16</sub>) boiling point range. The nonvolatiles were condensed on flue gas particulate and consisted largely of aliphatic hydrocarbons, heterocyclic nitrogen compounds (ethyl carbazole), and ketones (fluorenone).

Of the polynuclear aromatic hydrocarbons specifically analyzed for in flue gas emissions, only naphthalene (1.4 μg/dscm), phenanthrene (0.3 μg/dscm), and pyrene (0.11 μg/dscm) were detected. Other compounds identified as comprising the flue gas organics included benzoic acid, ethyl carbazole, and fluoren-9-one with emission levels in the 13 to 34 μg/dscm range, and phenol, benzofurandione, benzothiazole, ethyl benzoate, and terphenyl with emission levels in the 0.1 to 5.2 μg/dscm range.

## APPENDIX A

### SAMPLING AND ANALYSIS METHODS

Emission test equipment was provided primarily by Acurex Corporation. Onsite equipment included a continuous flue gas monitoring system; the source assessment sampling system (SASS) for particulate mass, semivolatile, and nonvolatile organic emissions measurement; a combined EPA Method 5 and 8 train for measuring particulate, SO<sub>2</sub> and SO<sub>3</sub> emissions; an Andersen cascade impactor train for measuring emitted particle size distribution; gas grab sampling equipment and an onsite gas chromatograph equipped with a flame ionization detector (GC/FID) for determining flue gas C<sub>1</sub> to C<sub>6</sub> hydrocarbon emissions; and gas grab sampling equipment for laboratory determination of N<sub>2</sub>O emissions by gas chromatography using an electron capture detector (GC/ECD). All the above flue gas emission sampling was performed at the steam generator stack.

In addition, Getty Oil Company provided flue gas monitoring of O<sub>2</sub>, CO<sub>2</sub>, CO, NO<sub>x</sub>, and SO<sub>2</sub> at the steam generator furnace outlet location.

The following sections summarize the equipment sampling and analysis procedures used by Acurex in the evaluation of the steam generator/low NO<sub>x</sub> burner.

#### A.1 CONTINUOUS MONITORING SYSTEM

Rack-mounted monitors and recorders located in a mobile emission laboratory were used for continuous measurement of NO<sub>x</sub>, CO, total unburned



1. In situ filter, 0.7 $\mu$ , 99.999 percent efficient
2. Exhaust duct
3. 316 stainless steel probe
4. Four pass conditioner-dryer, 316 stainless steel internals
5. 3/8-inch unheated Teflon tubing
6. Teflon-lined sample pump
7. 3/8-inch heated Teflon tubing
8. Rotameter
9. 1/4-inch Teflon tubing
10. Calibration gas manifold
11. Calibration gas selector valve
12. Calibration gas cylinders
13. Backpressure regulator




Figure A-1. Continuous monitoring system.

hydrocarbon (TUHC), CO<sub>2</sub>, and O<sub>2</sub>. Figure A-1 illustrates the continuous flue gas extractive sampling system and monitors arrangement. Flue gas was drawn through an in-stack filter and a heated stainless steel probe to a gas conditioning and refrigeration system designed to remove water. An unheated line was then used to bring the conditioned gas to the monitors. Calibration gases were used to monitor and correct the drift in the instruments. The calibration gases follow the same path as the flue gas being monitored in that both are conditioned at the stack prior to analysis. Table A-1 lists the instrumentation constituting the continuous monitoring and flue gas extractive sampling system used in this test program.

## A.2 PARTICULATE AND SULFUR OXIDE EMISSIONS

Particulate mass emissions were measured in accordance with EPA Reference Method 5 and SO<sub>2</sub> and SO<sub>3</sub> emissions were measured in accordance with EPA Reference Method 8. A combined Method 5/8 train employing the Acurex High Volume Stack Sampler (HVSS), illustrated schematically in Figure A-2, was used in this program. A glass-lined stainless-steel probe was used to isokinetically extract the gas sample from the stack. Particulate was removed by a heated 142 mm (5.6 in.) diameter glass fiber filter. Both the filter and the sampling probes were maintained at 120°C (250°F) as specified by Method 5.

The impinger train consisted of four glass impingers with a fritted glass filter placed between the first and second impingers as specified by Method 8. The first impinger contained 100 ml of 80 percent isopropanol (20 percent water); the second and third impingers contained 100 ml of 3 percent H<sub>2</sub>O<sub>2</sub> in water; and the fourth impinger contained 200g of silica gel.

TABLE A-1. CONTINUOUS MONITORING EQUIPMENT IN THE MOBILE LABORATORY

Instrument	Principle of operation	Manufacturer	Instrument model	Range
NO NO <sub>x</sub>	Chemiluminescence	Thermo Electron	10 AR	0-100 ppm 0-500 ppm 0-1,000 ppm 0-5,000 ppm
CO	Nondispersive infrared (NDIR)	ANARAD	500R	0-1,000 ppm
TUHC	Flame ionization detector	Beckman	400	0-10 ppm 0-100 ppm 0-1000 ppm
CO <sub>2</sub>	Nondispersive infrared (NDIR)	ANARAD	AR500	0-20 percent
O <sub>2</sub>	Fuel cell	Teledyne		0-5 percent 0-25 percent
Sample gas conditioner	Refrigerant dryer-condenser	Hankinson	E-4G-SS	10 scfm
Strip chart recorder	Dual pen analog	Linear	400	0-10 mV 0-100 mV 0-1V 0-10V

A-5




Figure A-2. Schematic of Method 5/8 sampling train.

SO<sub>3</sub> (H<sub>2</sub>SO<sub>4</sub> mist) is collected in the first impinger and SO<sub>2</sub> (oxidized to SO<sub>4</sub>) in the second and third. These were determined in the laboratory by titration with 0.01N barium perchlorate using thorin indicator.

### A.3 ORGANIC EMISSIONS

Emissions of organic compounds and compound categories were sampled using the source assessment sampling system (SASS). Designed for Level 1 environmental assessment (Reference A-1), the SASS collects large quantities of gas and solid samples required for subsequent analyses of inorganic and organic emissions.

The SASS, illustrated in Figure A-3, is generally similar to the system utilized for total particulate mass emission tests (a high volume Method 5 train) with the exception of:


- Particulate cyclones heated in the oven with the filter to 230°C (450°F)
- The addition of a gas cooler and organic sampling module
- The addition of necessary vacuum pumps to allow a sampling rate of 2 l/s (4 cfm)

The particulate cyclones shown were not used for these tests because of the low particulate loading in the flue gas.

Schematics outlining the standard sampling and analytical procedures using the SASS equipment are presented in Figures A-4 and A-5. The inorganic analyses of SASS train samples noted in the figures were not performed for these tests.


The SASS train particulate, XAD-2 resin, and organic module condensate (OMC) were extracted with methylene chloride in a Soxhlet apparatus. The

A-7



Note: T.C. = Thermocouple

Figure A-3. Source assessment sampling system schematic.



\* If required, sample should be set aside for biological analysis at this point.

<sup>1</sup> This step is required to define the total mass of particulate catch. If the sample exceeds 10% of the total cyclone and filter sample weight, proceed to analysis. If the sample is less than 10% of the catch, hold in reserve.

Figure A-4. Flue gas analysis protocol for SASS samples.




Figure A-5. Flue gas sample analysis protocol.



XAD-2 and OMC organic extracts were combined for analysis. The extracts were analyzed for total organic content in two boiling point ranges: 100° to 300°C (nominally C<sub>7</sub> to C<sub>16</sub> organics) by GC/FID for total chromatographable organics (TCO) and >300°C (nominally >C<sub>16</sub> organics) by gravimetry (GRAV). Infrared (IR) spectra were obtained of the GRAV residue of extracts. GC/mass spectrometry (MS) in accordance with EPA Method 625 for the semivolatile organic priority pollutant species was also performed on extract samples. Extract samples containing total organic content corresponding to emissions of >0.5 mg/dscm were analyzed by low resolution mass spectrometry to identify the major compound categories present. Figure A-6 illustrates the organic analysis methodology generally followed.

#### A.4 PARTICLE SIZE DISTRIBUTION

An Andersen 2000 Mark III in-stack cascade impactor was used to measure particle size distribution. The impactor was preheated inside the stack for 30 minutes prior to the start of sampling. Sampling was performed isokinetically at a point of average stack gas velocity.

The Mark III impactor consists of multiple stages which collect different particle sizes. Each stage consists of orifices of a specific diameter above a collection plate containing a glass fiber substrate. The orifice sizes of each stage are different and are arranged in descending order, the largest being stage 0.

For sampling, the stack gas was drawn in through the stainless-steel nozzle into the heated preseparator and impactor. The gas flowed through a stainless-steel probe and a Teflon line into the condensor train consisting of a series of 3 Lexan impingers. The gas was then pulled through a carbon




Figure A-6. Organic analysis methodology.

vane pump, dry gas meter, and calibrated orifice. The temperature of the gas leaving the impactor and the impactor temperature were measured during each test with type K thermocouples.

After a test, the Mark III impactor was carefully disassembled and the glass fiber substrates returned to their original foil containers. Any particulate matter which adhered to the impaction plates was brushed onto the appropriate filter. The samples were desiccated for 24 hours and weighed to the nearest 0.01 mg. The nozzle and Mark III inlet cone were rinsed thoroughly with acetone into a labeled amber jar. These washings were transferred to tared aluminum pans, evaporated, then desiccated for 24 hour and weighed to the nearest 0.1 mg.

#### A.5 C<sub>1</sub> TO C<sub>6</sub> HYDROCARBON SAMPLING AND ANALYSIS

Samples of flue gas for C<sub>1</sub> to C<sub>6</sub> hydrocarbon analysis were collected using a grab sampling procedure employing the apparatus illustrated in Figure A-7. The equipment consisted of a heated, 0.64-cm (1/4-in.) OD pyrex-lined, stainless-steel probe fitted with a 7- $\mu$ m sintered stainless-steel filter at the probe inlet. The outlet of the probe was directly attached to a diaphragm vacuum pump which was in turn attached to a 500-ml stainless-steel heated sampling cylinder. The sampling cylinder was insulated with heat tape powered by a varying voltage controller. The heating jacket kept the sample gas above the dew point to minimize sample loss due to water condensation.

Prior to sampling, the gas cylinder was purged with stack gas for 3 minutes and then sealed. The trapped flue gas was then analyzed onsite with a Varian Model 3700 gas chromatograph (GC) equipped with a flame ionization detector.

A-13




Figure A-7. C<sub>1</sub> to C<sub>6</sub> hydrocarbon sampling system.

Table A-2 lists the design specifications of the Varian GC. A 1.85m (6 ft) long, 0.32 cm (1/8 in.) diameter stainless-steel column packed with Poropak Q 60/80 mesh was used to separate the hydrocarbons into their respective components ( $C_1$  to  $C_6$ ). The GC was calibrated with repeated injections of a Scott Speciality standard gas containing  $C_1$  to  $C_6$  hydrocarbons (each having a concentration of 15 ppm). The chromatographic responses for the standards and the samples were recorded on a Hewlett Packard Model 3390A reporting integrator.

#### A.6 N<sub>2</sub>O EMISSIONS

Stack gas grab samples were extracted into stainless-steel cylinders similar to those used for  $C_1$  to  $C_6$  hydrocarbon sampling (Section A.5) for laboratory analysis for N<sub>2</sub>O. For the analysis each sample cylinder was externally heated to 120°C (250°F); then a 1-ml sample was withdrawn with a gas-tight syringe for injection into a gas chromatograph. The analytical equipment consisted of a Varian 3700 gas chromatograph equipped with a <sup>63</sup>Ni electron capture detector and a 3.65m (12 ft) stainless-steel column packed with Poropak Super Q, 80/100 mesh. The injector temperature was kept at 80°C, the detector at 350°C, and the column temperature at 33°C. Elution time for N<sub>2</sub>O was approximately 5 minutes, with a flowrate of 20 ml/min of nitrogen.

TABLE A-2. GAS CHROMATOGRAPH SPECIFICATIONS

Varian Model 3700 Gas Chromatograph:

Sensitivity	$1 \times 10^{-12}$ A/mV at attenuation 1 and range $10^{-12}$ A/mV
Zero range	$-10^{-11}$ to $10^{-9}$ A (reversible with internal switch)
Noise (inputs capped)	$5 \times 10^{-15}$ A; 0.5 $\mu$ V peak to peak
Time constant	220 ms on all ranges (approximate 1 sec response to 99 percent of peak)
Gas required	Carrier gas (helium), combustion air, fuel gas (hydrogen)

<b>TECHNICAL REPORT DATA</b> <i>(Please read Instructions on the reverse before completing)</i>		
1. REPORT NO. <b>EPA-600/7-86-003a</b>	2.	3. RECIPIENT'S ACCESSION NO.
4. TITLE AND SUBTITLE <b>Environmental Assessment of an Enhanced Oil Recovery Steam Generator Equipped with a Low-NOx Burner; Volume I. Technical Results</b>		5. REPORT DATE <b>February 1986</b>
		6. PERFORMING ORGANIZATION CODE
7. AUTHOR(S) <b>C. Castaldini, L.R. Waterland, and H.I. Lips</b>		8. PERFORMING ORGANIZATION REPORT NO. <b>TR-84-161/EE</b>
9. PERFORMING ORGANIZATION NAME AND ADDRESS <b>Acurex Corporation P.O. Box 7555 Mountain View, California 94039</b>		10. PROGRAM ELEMENT NO.
		11. CONTRACT/GRANT NO. <b>68-02-3188</b>
12. SPONSORING AGENCY NAME AND ADDRESS <b>EPA, Office of Research and Development Air and Energy Engineering Research Laboratory Research Triangle Park, NC 27711</b>		13. TYPE OF REPORT AND PERIOD COVERED <b>Final; 1/84 - 1/85</b>
		14. SPONSORING AGENCY CODE <b>EPA/600/13</b>
15. SUPPLEMENTARY NOTES <b>AEERL project officer is Robert E. Hall, Mail Drop 65, 91S/541-2477. Volume II is a data supplement.</b>		
16. ABSTRACT <b>The report discusses results from sampling flue gas from an enhanced oil recovery steam generator (EOR steamer) equipped with an MHI PM low-NOx burner. The tests included burner performance/emission mapping tests, comparative testing of an identical steamer steamer equipped with a conventional burner, and comprehensive testing of the low-NOx-burner-equipped steamer. Comprehensive test measurements included continuous flue gas monitoring; source assessment sampling system testing with subsequent laboratory analysis to give total flue gas organics in two boiling point ranges and specific quantitation on the semivolatile organic priority pollutants; C1 to C6 hydrocarbon sampling; Methods 5/8 sampling for particulate and SO2 and SO3 emissions; and emitted particle size distribution tests using Andersen impactors. Full-load NOx emissions of 110 ppm (3% O2) could be maintained from the low-NOx burner at acceptable CO and smoke emissions, compared to about 300 ppm (3% O2) from the conventional-burner-equipped steamer. At this low-NOx condition, CO, SO2, and SO3 emissions were 93, 594, and 3.1 ppm, respectively. Particulate emissions were 39 mg/dscm with a mean particle diameter of 3 to 4 micrometers. Total organic emissions were 11.1 mg/dscm, almost exclusively volatile (C1 to C6) organics. Three PAHs were detected at from 0.1 to 1.4 micrograms/dscm.</b>		
17. KEY WORDS AND DOCUMENT ANALYSIS		
a. DESCRIPTORS	b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group
Pollution Boilers Oil Burners Crude Oil Oil Recovery Assessments	Pollution Control Stationary Sources Low-NOx Burners Environmental Assessment	13B 13A  11H, 08G 08I 14B
18. DISTRIBUTION STATEMENT  <b>Release to Public</b>	19. SECURITY CLASS (This Report) <b>Unclassified</b>	21. NO. OF PAGES <b>69</b>
	20. SECURITY CLASS (This page) <b>Unclassified</b>	22. PRICE