



# Research and Development

ENVIRONMENTAL ASSESSMENT OF  
A RECIPROCATING ENGINE  
RETROFITTED WITH  
SELECTIVE CATALYTIC REDUCTION  
Volume I. Technical Results

## Prepared for

Office of Air Quality Planning and Standards

## Prepared by

Air and Energy Engineering Research  
Laboratory  
Research Triangle Park NC 27711

## **RESEARCH REPORTING SERIES**

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into nine series. These nine broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and a maximum interface in related fields. The nine series are:

1. Environmental Health Effects Research
2. Environmental Protection Technology
3. Ecological Research
4. Environmental Monitoring
5. Socioeconomic Environmental Studies
6. Scientific and Technical Assessment Reports (STAR)
7. Interagency Energy-Environment Research and Development
8. "Special" Reports
9. Miscellaneous Reports

This report has been assigned to the INTERAGENCY ENERGY-ENVIRONMENT RESEARCH AND DEVELOPMENT series. Reports in this series result from the effort funded under the 17-agency Federal Energy/Environment Research and Development Program. These studies relate to EPA's mission to protect the public health and welfare from adverse effects of pollutants associated with energy systems. The goal of the Program is to assure the rapid development of domestic energy supplies in an environmentally-compatible manner by providing the necessary environmental data and control technology. Investigations include analyses of the transport of energy-related pollutants and their health and ecological effects; assessments of, and development of, control technologies for energy systems; and integrated assessments of a wide range of energy-related environmental issues.

## **EPA REVIEW NOTICE**

This report has been reviewed by the participating Federal Agencies, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the Government, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

This document is available to the public through the National Technical Information Service, Springfield, Virginia 22161.

EPA-600/7-86-014a  
April 1986

ENVIRONMENTAL ASSESSMENT OF A RECIPROCATING ENGINE  
RETROFITTED WITH SELECTIVE CATALYTIC REDUCTION

Volume I: Technical Results

by

Carlo Castaldini and Larry R. Waterland  
Acurex Corporation  
555 Clyde Avenue  
P.O. Box 7555  
Mountain View, California 94039

EPA Contract 68-02-3188

EPA Project Officer: J. A. McSorley  
Air and Energy Engineering Research Laboratory  
Research Triangle Park, North Carolina 27711

for

U.S. ENVIRONMENTAL PROTECTION AGENCY  
Office of Research and Development  
Washington, DC 20460

## ABSTRACT

Comprehensive emission measurements and 15-day continuous emission monitoring was performed for a 1,500 kW (2000 hp) gas-fired, four-stroke turbocharged reciprocating engine equipped with an ammonia-based selective catalytic reduction system for NO<sub>x</sub> control. Emission reductions were held at about 80 percent using an ammonia-to-NO ratio of about 1.0. NO<sub>x</sub> levels at the catalyst inlet ranged from 2,200 to 2,600 ppm at an exhaust gas oxygen level of about 11 percent. NO<sub>x</sub> levels at the catalyst outlet ranged between 65 and 120 ppm. The catalyst had relatively minor effect on CO and particulate emissions, but increased total cyanides by three orders of magnitude (from 7 µg/dscm to 2.4 mg/dscm) across the catalyst. Total organics decreased about 70 percent from 4.9 mg/dscm to 1.5 mg/dscm. Analyses showed benzene and toluene as the major organic constituents in the catalyst exhaust. Polycyclic aromatics also decreased across the catalyst. The 15-day continuous monitoring tests showed that the catalyst was generally able to maintain NO<sub>x</sub> reductions at about 80 percent. Departures from these levels occurred only during brief load surges and ammonia flowrate spikes.

## CONTENTS

<u>Section</u>		<u>Page</u>
	Figures . . . . .	iv
	Tables . . . . .	v
1	Introduction . . . . .	1-1
2	Source Description and Operation . . . . .	2-1
3	Emission Results . . . . .	3-1
	3.1 Sampling Protocol . . . . .	3-1
	3.2 Criteria Pollutant and Other Vapor Species Emissions . . . . .	3-3
	3.3 Organic Species Emissions . . . . .	3-9
	3.4 Extended Continuous Emission Monitoring . . . . .	3-15
4	Quality Assurance Activities . . . . .	4-1
	4.1 NO <sub>x</sub> Certification Results . . . . .	4-1
	4.2 Spiked XAD-2 Resin Analysis . . . . .	4-2
	4.3 Ammonia Spike Sample Analysis . . . . .	4-2
	4.4 Duplicate Organic Analysis of XAD-2 Extract . . . . .	4-4
5	Summary . . . . .	5-1
	Appendix A . . . . .	A-1

## FIGURES

<u>Number</u>		<u>Page</u>
3-1	Sampling sites and analysis test matrix . . . . .	3-2
3-2	Test activity schedule . . . . .	3-4
3-3	Exhaust O <sub>2</sub> and CO <sub>2</sub> for the extended continuous monitoring period . . . . .	3-17
3-4	Exhaust NO <sub>x</sub> levels for the extended continuous monitoring period . . . . .	3-18
3-5	Catalyst NO <sub>x</sub> reduction efficiency for the extended monitoring period . . . . .	3-19
3-6	Catalyst outlet NH <sub>3</sub> emissions for the extended continuous monitoring period . . . . .	3-20
3-7	Exhaust CO levels for the extended continuous monitoring period . . . . .	3-21
3-8	Exhaust hydrocarbon levels for the extended continuous monitoring period . . . . .	3-22

## TABLES

<u>Number</u>		<u>Page</u>
1-1	Completed Tests During the Current Program . . . . .	1-5
2-1	Engine/Compressor Specification . . . . .	2-2
2-2	Engine Operation . . . . .	2-4
2-3	Natural Gas Fuel Analysis . . . . .	2-5
3-1	Criteria and other Gas Phase Species Emissions: Comprehensive Tests . . . . .	3-5
3-2	Ammonia Measurements, PPM Dry as Measured . . . . .	3-7
3-3	N <sub>2</sub> O Emissions: IC Engine/SCR Tests . . . . .	3-9
3-4	Compounds Sought in the GC/MS and Their Detection Limits (ng/ul Injected) . . . . .	3-11
3-5	Volatile Organics Sought in GC/MS Analysis . . . . .	3-12
3-6	Total Organic and Semivolatile Organic Priority Pollutant Emissions: IC Engine/SCR System Tests, XAD-2 Plus OMC Extract . . . . .	3-13
3-7	IR Spectra Summary . . . . .	3-14
3-8	Volatile Organic Sampling Train Results: Catalyst Outlet . . . . .	3-16
4-1	XAD-2 Resin Spike and Recovery Results . . . . .	4-3
4-2	Duplicate GC/MS Analysis Results for the Catalyst Outlet XAD-2 Extract . . . . .	4-4



## ACKNOWLEDGEMENTS

This test was performed in cooperation with Southern California Gas Company (SoCal). Much appreciation is extended to G. Gardetta and E. Harris of SoCal. Special recognition and thanks are extended to the Acurex field test crew of C. Milburn, M. Murray, V. Barkus, and P. Kaufmann.



## SECTION 1

### INTRODUCTION

This report describes and presents results for a set of environmental assessment tests performed for the Industrial Environmental Research Laboratory/Research Triangle Park (IERL/RTP) of EPA under the Combustion Modification Environmental Assessment (CMEA) program, EPA Contract No. 68-02-3188. The CMEA started in 1976 with a 3-year study, the NO<sub>x</sub> Control Technology Environmental Assessment (NO<sub>x</sub> EA, EPA Contract No. 68-02-2160), having the following objectives:

- Identify potential multimedia environmental effects of stationary combustion sources and combustion modification technology
- Develop and document control application guidelines to minimize these effects
- Identify stationary source and combustion modification R&D priorities
- Disseminate program results to intended users

During the first year of the NO<sub>x</sub> EA, data and methodologies for the environmental assessment were compiled. Furthermore, priorities for the schedule and level of effort for developing emission data for the various source/fuel/control combinations were identified. This effort revealed major data gaps, particularly for noncriteria pollutants (organic emissions and trace elements) for virtually all combinations of stationary combustion

sources and combustion modification techniques. Consequently, a series of seven environmental field test programs was undertaken to fill these data gaps. The results of these tests are documented in seven individual reports (References 1-1 through 1-7) and in the NO<sub>x</sub> EA final report summarizing the entire 3-year effort (Reference 1-8).

The current CMEA program has, as major objectives, the continuation of multimedia environmental field tests initiated in the original NO<sub>x</sub> EA program. These new tests, using standardized sampling and analytical procedures (Reference 1-9) are aimed at filling remaining data gaps and addressing the following priority needs:

- Advanced NO<sub>x</sub> controls
- Alternate fuels
- Secondary sources
- EPA program data needs
  - Residential oil combustion
  - Wood firing in residential, commercial, and industrial sources
  - High interest emissions determination (e.g., listed and candidate hazardous air-pollutant species)
- Nonsteady-state operations

In California, the South Coast Air Quality Management District (SCAQMD) continues to be in nonattainment of both federal and state NO<sub>2</sub> standards. Reciprocating internal combustion engines (ICE's) in this district are estimated to contribute 14 percent of the NO<sub>x</sub> (about 59 Mg/day (65 tons/day)) from all stationary sources and 5.1 percent of the total NO<sub>x</sub> emissions in the basin (References 1-10 and 1-11). Furthermore, since acid precipitation in noncoal-burning regions such as the SCAQMD is being increasingly attributed

to NO<sub>x</sub> emissions from sources with low stacks, reciprocating ICE's are being viewed as possibly contributing to the acid rain problem.

In 1979, the California Air Resources Board (CARB) proposed a control strategy for ICE's that called for retrofit of these sources with selective and nonselective treatment catalysts (SCR and NSCR, respectively). In keeping with this CARB strategy, the SCAQMD passed rule 1110 calling for demonstration tests of SCR and NSCR technologies for engine NO<sub>x</sub> control. Southern California Gas Company (SoCal) has conducted several performance tests to evaluate SCR and NSCR catalysts for their applicability in reducing NO<sub>x</sub> from SoCal operated ICE's. However, data on sustained NO<sub>x</sub> reduction performance associated with these technologies are currently limited (Reference 1-12). In addition, some potential environmental concerns have been raised. In the case of SCR, for example, the breakthrough of ammonia from the catalyst has been highlighted. For NSCR, the formation of ammonia and cyanide gases are also concerns.

In response to these data requirements and environmental concerns, a lean-burn reciprocating ICE operated by SoCal and retrofitted with a commercially available SCR system was selected for testing under the CMEA program. The objective of the tests was to quantify multimedia emissions (including organics, ammonia, and N<sub>2</sub>O) at the inlet and outlet of the SCR catalytic reactor. In addition to these tests, NO<sub>x</sub> reduction performance of the SCR was monitored continuously over 15 days under typical operating conditions. A similar field test program was conducted on a rich-burn engine retrofitted with a NSCR reactor. The results of these tests are documented in a separate report (Reference 1-13).

Table 1-1 lists all the tests performed in the CMEA program, outlining the source tested, fuel used, combustion modifications implemented and the level of sampling and analysis performed in each case. Results of these test programs are discussed in separate reports.

TABLE 1-1. COMPLETED TESTS DURING THE CURRENT PROGRAM

Source	Description	Test points unit operation	Sampling protocol	Test collaborator
Spark-ignited, natural-gas-fueled reciprocating internal combustion engine	Large-bore, 6-cylinder, opposed piston, 186 kW (250 Bhp)/cyl, 900 rpm, Model 38TDS8-1/8	-- Baseline (pre-NSPS) -- Increased air-fuel ratio aimed at meeting proposed NSPS of 700 ppm corrected to 15 percent O <sub>2</sub> and standard atmospheric conditions	Engine exhaust: -- SASS -- Method 5 -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous NO, NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> , CH <sub>4</sub> , THC Fuel Lube oil	Fairbanks Morse Division of Colt Industries
Compression-ignition, diesel-fueled reciprocating internal combustion engine	Large-bore, 6-cylinder opposed piston, 261-kW (350 Bhp)/cyl, 900-rpm, Model 38TDD8-1/8	-- Baseline (pre-NSPS) -- Fuel injection retard aimed at meeting proposed NSPS of 600 ppm corrected to 15 percent O <sub>2</sub> and standard atmospheric conditions	Engine exhaust: -- SASS -- Method 8 -- Method 5 -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous NO, NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> , CH <sub>4</sub> , THC Fuel Lube oil	Fairbanks Morse Division of Colt Industries
Low-NO <sub>x</sub> residential condensing heating system furnished by Karlsons Blueburner Systems Ltd. of Canada	Residential hot water heater equipped with M.A.N. low-NO <sub>x</sub> burner, 0.55 ml/s (0.5 gal/hr) firing capacity, condensing flue gas	Low-NO <sub>x</sub> burner design by M.A.N.	Furnace exhaust: -- SASS -- Method 8 -- Method 5 -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous NO, NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> , CH <sub>4</sub> , THC Fuel Waste water	New test
Rocketdyne/EPA low-NO <sub>x</sub> residential forced warm air furnace	Residential warm air furnace with modified high pressure burner and firebox, 0.83 ml/s (0.75 gal/hr) firing capacity	Low-NO <sub>x</sub> burner design and integrated furnace system	Furnace exhaust: -- SASS -- Method 8 -- Controlled condensation -- Method 5 -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous NO, NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> , CH <sub>4</sub> , THC Fuel	New test

(continued)

TABLE 1-1. (continued)

Source	Description	Test points unit operation	Sampling protocol	Test collaborator
Pulverized coal-fired utility boiler, Gonesville station	400-MW tangentially fired; new NSPS design aimed at meeting 301 ng/J NO <sub>x</sub> limit	ESP inlet and outlet, one test	ESP inlet and outlet: -- SASS -- Method 5 -- Controlled condensation -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous NO, NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> Coal Bottom ash ESP ash	Exxon Research and Engineering (ER&E) conducting corrosion tests
Nova Scotia Technical College industrial boiler	1.14 kg/s steam (9,000 lb/hr) firetube fired with a mixture of coal-oil-water (COW)	-- Baseline (COW) -- Controlled SO <sub>2</sub> emissions with limestone injection	Boiler outlet: -- SASS -- Method 5 -- Method 8 -- Controlled condensation -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , CO <sub>2</sub> , CO, NO <sub>x</sub> Fuel	Envirocon performed particulate and sulfur emission tests
Adelphi University industrial boiler	1.89 kg/s steam (15,000 lb/hr) hot water firetube fired with a mixture of coal-oil-water (COW)	-- Baseline (COW) -- Controlled SO <sub>2</sub> emissions with Na <sub>2</sub> CO <sub>3</sub> injection	Boiler outlet: -- SASS -- Method 5 -- Method 8 -- Controlled condensation -- Gas Sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , CO <sub>2</sub> , NO <sub>x</sub> , CO Fuel	Adelphi University
Pittsburgh Energy Technology Center (PETC) industrial boiler	3.03 kg/s steam (24,000 lb/hr) watertube fired with a mixture of coal-oil (COM)	-- Baseline test only with COM	Boiler outlet: -- SASS -- Method 5 -- Controlled condensation -- Continuous O <sub>2</sub> , CO <sub>2</sub> , NO <sub>x</sub> , THHC, CO -- N <sub>2</sub> O grab sample Fuel	PETC and General Electric (GE)

(continued)

TABLE 1-1. (continued)

Source	Description	Test points unit operation	Sampling protocol	Test collaborator
TOSCO Refinery vertical crude oil heater	2.54 Ml/day (16,000 bbl/day) natural draft process heater burning oil/refinery gas	-- Baseline -- Staged combustion using air injection lances	Heater outlet: -- SASS -- Method 5 -- Controlled condensation -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO, CO <sub>2</sub> , HC -- N <sub>2</sub> O, grab sample Fuel oil Refinery gas	KVB coordinated the staged combustion operation and continuous emission monitoring
Mohawk-Getty Oil industrial boiler	8.21 kg/s steam (65,000 lb/hr) watertube burning mixture of refinery gas and residual oil	-- Baseline -- Ammonia injection using the noncatalytic thermal deNO <sub>x</sub> process	Economizer outlet: -- SASS -- Method 5, 17 -- Controlled condensation -- Gas Sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Ammonia emissions -- N <sub>2</sub> O grab sample -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO, CO <sub>2</sub> Fuels (refinery gas and residual oil)	Mohawk-Getty Oil
Industrial boiler	2.52 kg/s steam (20,000 lb/hr) watertube burning woodwaste	-- Baseline (dry wood) -- Green wood	Boiler outlet: -- SASS -- Method 5 -- Controlled condensation -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO Fuel Flyash	North Carolina Department of Natural Resources, EPA IERL-RTP
Industrial boiler	3.16 kg/s steam (29,000 lb/hr) firetube with refractory firebox burning woodwaste	-- Baseline (dry wood)	Outlet of cyclone particulate collector: -- SASS -- Method 5 -- Controlled condensation -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO Fuel Bottom ash	North Carolina Department of Natural Resources, EPA IERL-RTP

(continued)



TABLE 1-1. (continued)

Source	Description	Test points unit operation	Sampling protocol	Test collaborator
Enhanced oil recovery steam generator	15-MW (50 million Btu/hr) steam generator burning crude oil equipped with MHI low-NO <sub>x</sub> burner	-- Performance mapping -- Low NO <sub>x</sub> operation	Steamer outlet -- SASS -- Method 5 -- Method 8 -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO, CO <sub>2</sub> -- N <sub>2</sub> O grab sample Fuel	Getty Oil Company, CE-Natco
Pittsburgh Energy Technology Center (PETC) industrial boiler	3.03 kg/s steam (24,000 lb/hr) watertube fired with a mixture of coal-water slurry (CWS)	-- Baseline test only with CWS	Boiler outlet -- SASS -- Method 5 -- Method 8 -- Gas sample (C <sub>1</sub> -C <sub>6</sub> HC) -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO, CO <sub>2</sub> , TUHC -- N <sub>2</sub> O grab sample Fuel Bottom ash Collector hopper ash	PETC
Spark-ignited, natural- gas-fueled reciprocating internal combustion engine -- nonselective NO <sub>x</sub> reduction catalyst	610-kW (818-hp) Waukesha rich-burn engine equipped with DuPont NSCR system	-- Low-NO <sub>x</sub> (with catalyst) -- 15-day emissions monitoring	Catalyst inlet and outlet -- SASS -- NH <sub>3</sub> -- HCN -- N <sub>2</sub> O grab sample -- Continuous O <sub>2</sub> , CO <sub>2</sub> , NO <sub>x</sub> TUHC Lube oil	Southern California Gas Company
Industrial boiler	180 kg/hr steam (400 lb/hr) stoker fired with a mixture of coal and plastic waste	-- Baseline (coal) -- Coal and plastic waste	Boiler outlet -- SASS -- VOST -- Method 5 -- Method 8 -- HCl -- Continuous O <sub>2</sub> , NO <sub>x</sub> , CO, CO <sub>2</sub> , TUHC -- N <sub>2</sub> O grab sample Fuel Bottom ash Cyclone ash	Vermont Agency of Environmental Conservation

(continued)

TABLE 1-1. (concluded)

Source	Description	Test points unit operation	Sampling protocol	Test collaborator
Industrial boiler	7.6 kg/s steam (60,000 lb/hr watertube retrofit for coal water slurry firing)	-- Baseline test with CMS -- 30-day emissions monitoring	Boiler outlet -- SASS -- VOST -- Method 5 -- Method 8 -- Grab sample (C <sub>1</sub> -C <sub>6</sub> HC) -- N <sub>2</sub> O grab sample -- Continuous NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> , TUHC, SO <sub>2</sub> Fuel	EPRI, DuPont
Enhanced oil recovery steam generator	15-MW (50 million Btu/hr) steam generator burning crude oil, equipped with the EPA/EER low-NO <sub>x</sub> burner	-- Low-NO <sub>x</sub> burner -- 30-day emissions monitoring	Steamer outlet -- SASS -- VOST -- Method 5 -- Method 8 -- Controller condensation -- Andersen impactors -- Grab sample (C <sub>1</sub> -C <sub>6</sub> HC) -- N <sub>2</sub> O grab sample -- Continuous NO <sub>x</sub> , CO, CO <sub>2</sub> , O <sub>2</sub> , SO <sub>2</sub> Fuel	Chevron U.S.A., EERC
Spark-ignited, natural-gas-fueled reciprocating internal combustion engine -- selective NO <sub>x</sub> reduction catalyst	1,500-kW (2,000-hp) Ingersoll-Rand engine equipped with Engelhard SCR system	-- Low NO <sub>x</sub> with catalyst -- 15-day emissions monitoring	Catalyst inlet and outlet -- SASS -- NH <sub>3</sub> -- HCN -- N <sub>2</sub> O grab sample -- Continuous O <sub>2</sub> , CO <sub>2</sub> , NO <sub>x</sub> , TUHC Lube oil	Southern California Gas Company

## REFERENCES FOR SECTION 1



- 1-1. Larkin, R. and E. B. Higginbotham, "Combustion Modification Controls for Stationary Gas Turbines: Volume II. Utility Unit Field Test," EPA-600/7-81-122b, NTIS PB82-226473, July 1981.
- 1-2. Higginbotham, E. B., "Combustion Modification Controls for Residential and Commercial Heating Systems: Volume II. Oil-fired Residential Furnace Field Test," EPA-600/7-81-123b, NTIS PB82-231176, July 1981.
- 1-3. Higginbotham, E. B. and P. M. Goldberg, "Combustion Modification NO<sub>x</sub> Controls for Utility Boilers: Volume I. Tangential Coal-fired Unit Field Test," EPA-600/7-81-124a, NTIS PB82-227265, July 1981.
- 1-4. Sawyer, J. W. and E. B. Higginbotham, "Combustion Modification NO<sub>x</sub> Controls for Utility Boilers: Volume II. Pulverized-coal Wall-fired Unit Field Test," EPA-600/7-81-124b, NTIS PB82-227273, July 1981.
- 1-5. Sawyer, J. W. and E. B. Higginbotham, "Combustion Modification NO<sub>x</sub> Controls for Utility Boilers: Volume III. Residual-oil Wall-fired Unit Field Test," EPA-600/7-81-124c, NTIS PB82-227281, July 1981.
- 1-6. Goldberg, P. M. and E. B. Higginbotham, "Industrial Boiler Combustion Modification NO<sub>x</sub> Controls: Volume II. Stoker Coal-fired Boiler Field Test -- Site A," EPA-600/7-81-126b, NTIS PB82-231085, July 1981.
- 1-7. Lips, H. I. and E. B. Higginbotham, "Industrial Boiler Combustion Modification NO<sub>x</sub> Controls: Volume III. Stoker Coal-fired Boiler Field Test -- Site B," EPA-600/7-81-126c, NTIS PB82-231093, July 1981.
- 1-8. Waterland, L. R., et al., "Environmental Assessment of Stationary Source NO<sub>x</sub> Control Technologies -- Final Report," EPA-600/7-82-034, NTIS PB82-249350, May 1982.
- 1-9. Lentzen, D. E., et al., "IERL-RTP Procedures Manual: Level 1 Environmental Assessment (Second Edition)," EPA-600/7-78-201, NTIS PB293795, October 1978.
- 1-10. Bartz, D., et al., "Control of Oxides of Nitrogen from Stationary Sources in the South Coast Air Basin," KVB, Inc., Irvine, California, September 1974.
- 1-11. "Draft Air Quality Management Plan," South Coast Air Quality Management District, El Monte, California, October 1978.

- 1-12. Harris, E. H., "Southern California Gas Company NO<sub>x</sub> Emission Control Program 1982 Annual Report," Southern California Gas Company, Los Angeles, California, February 1983.
- 1-13. Castaldini, C. and L. R. Waterland, "Environmental Assessment of a Reciprocating Engine Retrofitted with Nonselective Catalytic Reduction." EPA-600/7-84-073a, NTIS PB 84 - 224-351, June 1984.

## SECTION 2

### SOURCE DESCRIPTION AND OPERATION

The tests were performed on a four-stroke turbocharged Ingersoll-Rand 412-KVS, 2,000-hp, gas compressor engine equipped with an Engelhard SCR catalyst system. This engine is located at the SoCal Aliso Canyon compressor station on the Northridge, California underground storage field. Table 2-1 summarizes the engine model specifications. The Engelhard Deoxo catalyst system installed in Spring 1984, is a proprietary metal-oxide-based formulation with operating temperature limits of 288° to 427°C (550° to 800°F). The catalyst, located downstream of the engine silencer, was designed to reduce NO<sub>x</sub> emissions by 80 percent or greater, and thereby meet the SCAQMD rule 1110.1. The reducing agent, anhydrous NH<sub>3</sub> gas, is injected into the exhaust gas to react with NO<sub>x</sub> and O<sub>2</sub> in the presence of this metal catalyst and reduce both NO and NO<sub>2</sub>. The SCR chemical reaction process is typically envisioned to be as follows:



The SCR process requires fuel-lean engine operation and the addition of the reducing agent NH<sub>3</sub> in the flue gas upstream of the catalyst. An additional requirement is the NH<sub>3</sub> control system whose function is to maintain the appropriate NH<sub>3</sub>/NO molar ratio (generally set for 1.0 for ≥90 percent NO<sub>x</sub>

TABLE 2-1. ENGINE/COMPRESSOR SPECIFICATION

Engine:

Manufacturer	Ingersoll-Rand
Model	412DT-KVS
Cycle	4-strokes
Air charging	Turbocharged (dual)
Number of cylinders	V-12
Bore	0.387m (15.25 in.)
Stroke	0.487m (18.0 in.)
Displacement/cylinder	44.8 l (2,735 in. <sup>3</sup> )
Compression ratio	6.5:1
BMEP	1.00 MPa (146 psi)
Bhp/cyl at rpm	125 kW (167 Bhp) at 330 rpm

Compressor:

Manufacturer	Ingersoll-Rand
Bore (first stage)	0.235m (9.25 in.)
Stroke (first stage)	0.381m (15.2 in.)
Bore (second stage)	0.159m (6.25 in.)
Stroke (second stage)	0.381m (15.2 in.)

reduction) with varying  $\text{NO}_x$  concentrations in the exhaust gas and varying engine load. For the Aliso Canyon site, Engelhard installed an ammonia control system which includes a chemiluminescent  $\text{NO}_x$  analyzer to determine the concentrations upstream and downstream of the catalyst and a microprocessor to compare the values and control the ammonia flowrate. Parametric testing of this catalyst conducted in 1982 on slip stream exhaust indicated 90 percent  $\text{NO}_x$  reduction capability with 100 ppm  $\text{NH}_3$  carryover for  $\text{NH}_3/\text{NO}$  of about 1.0 and a gas temperature in the range of about  $400^\circ$  to  $450^\circ\text{C}$  ( $750^\circ$  to  $850^\circ\text{F}$ ) (Reference 2-1).

During the CMEA tests, exhaust emissions ( $\text{NO}_x$ ,  $\text{O}_2$ ,  $\text{CO}$ ,  $\text{CO}_2$ ), and total unburned hydrocarbon (TUHC) were measured on a continuous basis for a period of 15 days during normal engine operation. In addition, a comprehensive emission test program was performed over a 1-day period during which engine load and  $\text{NH}_3$  flowrate were controlled for catalyst  $\text{NO}_x$  reduction of about 80 percent. Table 2-2 summarizes the engine operation and ambient atmospheric conditions during this 1-day comprehensive testing period.

As noted, engine load was maintained relatively constant throughout the comprehensive test period. Engine power output of 1,270  $\text{kW}_t$  (1,700 Bhp) was calculated using compressor performance curves available from the manufacturer. Heat rate based on fuel lower heating value was measured to be about 9,400  $\text{kJ/kWh}$  (6,600  $\text{Btu/Bhp-hr}$ ). Measured turbocharger turbine gas outlet temperature varied from  $370^\circ$  to  $390^\circ\text{C}$  ( $700^\circ$  to  $740^\circ\text{F}$ ). These measurements are considered in error (low) though, as suggested by the catalyst inlet temperature measurement which was between  $390^\circ$  to  $400^\circ\text{C}$  ( $740^\circ$  to  $750^\circ\text{F}$ ).



TABLE 2-2. ENGINE OPERATION

Parameter	Range	Average
<b>Ambient</b>		
Dry bulb temperature, °C (°F)	22 to 33 (72 to 92)	29 (84)
Wet bulb temperature, °C (°F)	19 to 21 (67 to 70)	20 (68)
Relative humidity, percent	45 to 55	50
Barometric pressure, kPa (in. Hg)		96.2 (28.5)
<b>Engine Operation</b>		
Engine load, kW <sub>t</sub> (Bhp) <sup>a</sup>	--	1,270 (1,700)
Fuel flow, scm/hr (scfh)	--	327 (11,550)
Heat input, MW (million Btu/hr) <sup>b</sup>	--	3.29 (11.2)
Specific fuel consumption, kJ/kWh (Btu/Bhp-hr) <sup>b</sup>	--	9,390 (6,610)
Air manifold pressure, kPa (psig)	25 to 28 (3.6 to 4.0)	26.5 (3.85)
Air manifold temperature °C (°F)	68 to 70 (154 to 158)	69 (156)
Speed, rpm	320 to 333	325
Exhaust manifold temperatures, °C (°F)	380 to 382 (716 to 720)	380 (718)
No. 1 cylinder	292 to 360 (560 to 680)	332 (630)
No. 2 cylinder	440 to 455 (820 to 850)	449 (840)
No. 3 cylinder	430 to 440 (800 to 820)	430 (810)
No. 4 cylinder	380 to 390 (720 to 730)	385 (725)
No. 5 cylinder	404 to 415 (760 to 780)	410 (775)
No. 6 cylinder	290 to 350 (550 to 660)	320 (610)
No. 7 cylinder	380 to 390 (710 to 730)	380 (720)
No. 8 cylinder	360 to 370 (680 to 700)	363 (685)
No. 9 cylinder	380 to 390 (700 to 740)	390 (730)
No. 10 cylinder	370 to 393 (700 to 730)	380 (715)
No. 11 cylinder	365 to 370 (690 to 700)	370 (722)
No. 12 cylinder	396 to 404 (745 to 760)	404 (760)
Turbine outlet temperature, °C (°F)		
L	380 to 390 (720 to 740)	390 (730)
R	370 to 380 (700 to 740)	380 (720)
Catalyst inlet temperature, °C (°F)	390 to 400 (740 to 750)	396 (745)
Catalyst outlet temperature, °C (°F)	344 to 382 (652 to 720)	362 (683)
<b>Gas Compressor</b>		
Suction pressure, MPa (psig)	--	4.02 (583)
Interstage pressure, MPa (psig)	--	7.86 (1,140)
Discharge pressure, MPa (psig)	--	19.97 (2,898)
Suction temperature, °C (°F)	26 to 35 (78 to 95)	29 (85)
Interstage temperature, °C (°F)	88 to 93 (190 to 200)	91 (195)
Discharge temperature, °C (°F)	107 to 118 (225 to 245)	113 (235)
<b>NH<sub>3</sub> System</b>		
NH <sub>3</sub> flowrate, standard l/s (scfh)	4.44 to 4.88 (565 to 620)	4.64 (590)

<sup>a</sup>Engine load obtained from engine performance curves.<sup>b</sup>Heat input based on low heating value (LHV) of natural gas from Table 2-3.  
Specific fuel consumption based on LHV of fuel.

Ammonia injection rate varied from 4.44 to 4.88 standard l/s (565 to 620 scfh), corresponding to a  $\text{NH}_3/\text{NO}$  molar ratio of about 1.04 to 1.10. Average  $\text{NH}_3$  injection rate was about 464 standard l/s (590 scfh) corresponding to a  $\text{NH}_3/\text{NO}$  ratio of 1.07.

Table 2-3 summarizes the typical analysis of the natural gas fuel. This analysis, provided by SoCal, corresponds to a sample obtained prior to the comprehensive test program.

It should be noted that prior to the test period, problems were experienced with the  $\text{NH}_3$  control system, specifically the  $\text{NO}_x$  analyses and also the  $\text{NH}_3$  control valve.

TABLE 2-3. NATURAL GAS FUEL ANALYSIS<sup>a</sup>

Component	Percent by volume
$\text{CH}_4$	89.7
$\text{C}_2\text{H}_6$	5.75
$\text{C}_3\text{H}_8$	1.50
$\text{C}_4\text{H}_{10}$	0.40
$\text{C}_5\text{H}_{12}$	0.128
$\text{C}_6\text{H}_{14}$	0.147
$\text{CO}_2$	0.947
$\text{N}_2$	1.30
High heating value <sup>b</sup>	$\text{MJ/m}^3$ (Btu/ft <sup>3</sup> ) 39.8 (1,070)
Low heating value <sup>b</sup>	36.2 (973)
Specific gravity	0.622

<sup>a</sup>Typical fuel analysis

<sup>b</sup>Calculated heating value

## REFERENCE FOR SECTION 2

- 2-1. Harris, E. H., "Southern California Gas Company NO<sub>x</sub> Emission Control Program 1982 Annual Report," Southern California Gas Company, Los Angeles, California, February 1983.


## SECTION 3

### EMISSION RESULTS

The objectives of this test program were: (1) to measure engine exhaust emissions during a 15-day test period to evaluate the continuous performance of the catalyst, utilizing continuous  $\text{NO}_x$  and other gas emission analyzers, and (2) to perform comprehensive tests over a 1-day period to measure the effect of the catalyst on organic emissions as well as on  $\text{NH}_3$  breakthrough and possible formation of HCN. Emission measurements were performed in cooperation with SoCal, owner and operator of the test site, whose field crew and equipment included an emission monitoring laboratory with operating staff.

#### 3.1 SAMPLING PROTOCOL

Figure 3-1 illustrates a schematic of the test site highlighting the sampling locations, sampling and analytical test matrix, and the test team performing the sampling and evaluation. As indicated, continuous monitoring of flue gas was performed alternatively upstream and downstream of the catalytic reactor utilizing heated sample lines. The catalyst inlet sampling location for the continuous monitors was upstream of the  $\text{NH}_3$  injection location to avoid any effect of added  $\text{NH}_3$  on the engine exhaust  $\text{NO}_x$  measurements. The sampling and gas conditioning system for this test program included continuous monitors for  $\text{O}_2$ ,  $\text{CO}_2$ ,  $\text{CO}$ ,  $\text{NO}$ ,  $\text{NO}_x$ , and THC. The continuous monitors were operated throughout a 15-day test period while



<u>Sample Location</u>	<u>Type of Sample</u>	<u>Analyses<sup>a</sup></u>	<u>Test Number</u>
A -- Natural gas to engine	Grab sample -- Fuel	Gas chromatography for composition; heating value, specific gravity	SoCal
B,D -- Catalyst inlet, outlet	Extractive Sample -- Continuous Monitors	O <sub>2</sub> , CO <sub>2</sub> , CO, TUHC, NO, NO <sub>x</sub> ,	Acurex SoCal <sup>b</sup>
	Volatile organic -- sampling train (VOST)	Volatile organics in accordance with EPA Method 624 (catalyst outlet only)	Acurex
C,D -- Catalyst inlet, outlet	Sampling train -- SASS	Particulate by gravimetry, total semivolatile organics by GC/FID, total nonvolatile organics by gravimetry, and semi- and nonvolatile organic compounds in accordance with EPA Method 625	Acurex
	Sampling train -- Modified Method 6	NH <sub>3</sub> by selective ion electrode	Acurex
	Sampling train -- Modified Method 6	HCN by wet chemistry	Acurex
	Grab sample -- Gas bomb	N <sub>2</sub> O by GC/ECD	Acurex
	Grab sample -- Method 7 flasks	NO <sub>x</sub> by Method 7	Acurex

<sup>a</sup>Measurement and analysis techniques used are discussed in detail in Appendix A

<sup>b</sup>NO<sub>x</sub> measurements also provided by SoCal as part of the NH<sub>3</sub> Control System

Figure 3-1. Sampling sites and analysis test matrix.

engine load and  $\text{NH}_3$  injection rate varied slightly. Certification of the  $\text{NO}_x$  analyzer readings was attempted once during this 15-day test period using standard EPA Method 7 protocol.

The source assessment sampling system (SASS), the  $\text{NH}_3$ , and the HCN sampling trains were operated during 1 day of tests at both the inlet and outlet of the catalytic converter. Catalyst inlet location for these sampling systems was downstream of the  $\text{NH}_3$  injection location. Simultaneous inlet and outlet samples were performed to measure any change in the composition of the exhaust gas across the catalyst. Volatile organics were measured at the catalyst outlet only using the volatile organic sampling train (VOST) per EPA protocol (Reference 3-1). These measurements were performed while engine load was maintained constant and  $\text{NH}_3$  injection rate was adjusted for about 80 percent  $\text{NO}_x$  reduction by the catalyst.

Figure 3-2 illustrates the actual test activity schedule. The following sections summarize the emission results. Sections 3.2 and 3.3 present emission results obtained during the comprehensive tests that took place on August 3, 1984. Section 3.4 summarizes results of continuous emission measurements performed over the 15-day test period. EPA Method 7 certification tests, performed on August 2, 1984, are discussed in Section 4. Details of the sampling and analysis procedures used are discussed in Appendix A.

### 3.2 CRITERIA POLLUTANT AND OTHER VAPOR SPECIES EMISSIONS

Table 3-1 summarizes gaseous and particulate emissions measured during the 1-day comprehensive tests performed at about the half-way point of the 15-day continuous monitoring period. Exhaust  $\text{O}_2$  was about 11.2 percent at

Test activity	July						August								
	26	27	28	29	30	31	1	2	3	4	5	6	7	8	9
<ul style="list-style-type: none"> <li>Continuous monitors (inlet/outlet)</li> <li>Comprehensive tests (inlet/outlet)               <ul style="list-style-type: none"> <li>-- VOST (outlet only)</li> <li>-- SASS</li> <li>-- NH<sub>3</sub></li> <li>-- HCN</li> <li>-- N<sub>2</sub>O</li> </ul> </li> <li>Method 7 certification</li> </ul>	△	△													△
									△						
									△						
									△						
									△						
														△	
								△							

Figure 3-2. Test activity schedule.



TABLE 3-1. CRITERIA AND OTHER GAS PHASE SPECIES  
EMISSIONS: COMPREHENSIVE TESTS

Pollutant <sup>a</sup>	Catalyst inlet			Catalyst outlet		
As measured by continuous gas analyzers, range (average):						
O <sub>2</sub> , percent dry	11.1 to 11.3 (11.2)			10.9 to 11.2 (11.1)		
CO <sub>2</sub> , percent dry	5.0 to 5.9 (5.5)			5.1 to 6.0 (5.6)		
CO, ppm dry	180 to 310 (245)			170 to 280 (225)		
NO <sub>x</sub> , ppm dry	2,200 to 2,600 (2,400)			330 to 560 (445)		
TUHC, ppm dry of CH <sub>4</sub> <sup>f</sup>	NA			NA		
Corrected average gaseous emissions:	ppm <sup>b</sup>	ng/J <sup>c</sup>	g/Bhp-hr <sup>d</sup>	ppm <sup>b</sup>	ng/J <sup>c</sup>	g/Bhp-hr <sup>d</sup>
CO	150	171	1.19	138	158	1.10
NO <sub>x</sub> <sup>e</sup>	1,470	2,760	19.2	273	513	3.57
TUHC <sup>f</sup>	NA			NA		
NH <sub>3</sub> <sup>g</sup>	1,084	752	5.23	56	39	0.27
Total cyanide <sup>h</sup>	0.004	0.004	3 x 10 <sup>-5</sup>	1.3	1.4	0.010
Solid particulate:						
SASS solids	-- Negligible			-- Negligible		

<sup>a</sup>Appendix A discusses continuous monitor analyses used, sample gas conditioning system, particulate sampling equipment, and other sampling trains and procedures

<sup>b</sup>Corrected to 15 percent O<sub>2</sub>, dry

<sup>c</sup>On heat input basis using fuel's lower heating value

<sup>d</sup>Shaft output basis

<sup>e</sup>As NO<sub>2</sub> (NO and NO<sub>2</sub> only)

<sup>f</sup>Total hydrocarbon monitor not functioning

<sup>g</sup>Inlet NH<sub>3</sub> measured downstream of NH<sub>3</sub> injection location. Values report an average of two separate measurements

<sup>h</sup>As HCN; value reported is average of two separate measurements

both the inlet and outlet location. This indicates an air-fuel ratio of about 35 on a weight basis.

NO<sub>x</sub> emissions at the engine outlet varied from 2,200 to 2,600 ppm as measured, with an average of 2,400 ppm, corresponding to about 2.76 mg/J heat input basis (19.2 g/Bhp-hr shaft output). NO<sub>x</sub> reduction efficiency by the catalyst ranged between 78 to 85 percent with an average for the day of 81 percent. CO emissions were approximately 10 percent lower at the catalyst outlet compared to the emissions measured in the untreated engine exhaust. Unburned hydrocarbon data were not available for the comprehensive test period due to instrument malfunction. However, test data obtained prior to and following these tests showed TUHC concentration in the range of about 1,500 to 1,800 ppm as measured at both inlet and outlet locations.

NH<sub>3</sub> emissions were measured using a wet impinger method and a continuous method using a NO<sub>x</sub> analyzer. Sampling of NH<sub>3</sub> using the impinger train took place at the inlet to the catalyst, downstream of the NH<sub>3</sub> injection location. Therefore, the measured concentration of NH<sub>3</sub> at this location is the direct result of the NH<sub>3</sub> injected in the engine exhaust for the catalytic reduction of NO<sub>x</sub>. NH<sub>3</sub> concentrations at this location ranged from 1,450 to 2,090 ppm obtained with two separate gas samples. The NH<sub>3</sub> injection rate during this test period was recorded in the range of 4.44 to 4.88 l/s (565 to 620 scfh) which would result in a concentration of 2,422 to 2,700 ppm in the engine exhaust. Therefore, the amount of NH<sub>3</sub> measured at the catalyst inlet by wet chemical analysis accounts for about 60 to 77 percent of the measured NH<sub>3</sub> injection rate.

Table 3-2 summarizes the NH<sub>3</sub> gas concentrations recorded using continuous gas monitors. Using two NO<sub>x</sub> analyzers, the NH<sub>3</sub> was measured by

TABLE 3-2. AMMONIA MEASUREMENTS, PPM DRY AS MEASURED

Emission <sup>a</sup>	Catalyst inlet <sup>b</sup>	Catalyst outlet	Percent change
1. NO	2,000 to 2,400 (2,200)	300 to 590 (445)	-80
2. NO + NO <sub>2</sub>	2,000 to 2,600 (2,400)	330 to 560 (445)	-81
3. NO + NO <sub>2</sub> + NH <sub>3</sub>	2,200 to 2,600 (2,400)	390 to 622 (505)	-79
4. NH <sub>3</sub> (by difference 3-2)	0	20 to 140 (80)	--
5. NH <sub>3</sub> by wet method <sup>c</sup>	NA	65 to 118 (92)	--

<sup>a</sup>Values for emissions (1 through 4) were recorded using continuous analyzers

<sup>b</sup>Measurements upstream of NH<sub>3</sub> injection location

<sup>c</sup>NH<sub>3</sub> measurements by wet method were made downstream of NH<sub>3</sub> injection location, therefore a wet method measurement at the catalyst inlet is not available

the difference in readouts between  $\text{NO} + \text{NO}_2$  and  $\text{NO} + \text{NO}_2 + \text{NH}_3$ . Appendix A describes in detail the technique used. Upstream of the  $\text{NH}_3$  injection location, the two analyzers showed no difference, indicating no  $\text{NH}_3$  present, as expected. At the catalyst outlet location, the two analyzers indicated  $\text{NH}_3$  concentration in the range of 20 to 140 ppm as measured. Using two separate wet chemical analysis measurements,  $\text{NH}_3$  at this location was recorded at 65 and 118 ppm, respectively. Average values were 80 ppm using continuous monitors and about 90 ppm using wet chemical analysis.

Additional sampling was performed to quantitate cyanide and particulate levels in the exhaust across the catalyst. Total cyanides, as HCN, increased by three orders of magnitude from an average of about 4 pg/J (30  $\mu\text{g}/\text{Bhp-hr}$ ) to 1.4 ng/J (10 mg/Bhp-hr). Particulate emission levels were negligible at both sample locations (actual particulate matter collected on the filter showed a decrease after corrections for filter tare and blank).

$\text{N}_2\text{O}$  emissions were measured by gas chromatography with electron capture detection of exhaust gas grab samples taken at the inlet and outlet of the catalyst. Table 3-3 summarizes results of the  $\text{N}_2\text{O}$  emissions sampled on August 8. Corresponding exhaust  $\text{NO}_x$  levels are also shown in the table. As indicated, at the time the  $\text{N}_2\text{O}$  samples were taken the SCR system was effecting about 80 percent  $\text{NO}_x$  reduction. Interestingly,  $\text{N}_2\text{O}$  levels were reduced about 60 percent by the catalyst. The  $\text{N}_2\text{O}$  level was about 4 percent of  $\text{NO}_x$  level in the exhaust at the catalyst inlet and about 9 percent at the catalyst outlet. These are significantly lower than the fractions measured in tests of external combustion sources, which fall in the 15 to 25 percent range (Reference 3-2). However, the  $\text{N}_2\text{O}$  fractions measured in tests of a rich-running engine were also low (2 to 3 percent of  $\text{NO}_x$  emission levels) (Reference 3-3).

TABLE 3-3. N<sub>2</sub>O EMISSIONS: IC ENGINE/SCR TESTS<sup>a</sup>

Compound	Catalyst inlet	Catalyst outlet	Percent reduction
NO <sub>x</sub> , ppm measured	2,600	490	82
ppm at 15% O <sub>2</sub>	1,640	300	
N <sub>2</sub> O, ppm measured	98	43	57
ppm at 15% O <sub>2</sub>	62	26	

<sup>a</sup>Tests performed on August 8

### 3.3 ORGANIC SPECIES EMISSIONS

Organic analyses were performed on the exhaust gas samples collected at the catalyst inlet and outlet locations. SASS samples were analyzed for total semivolatile and nonvolatile organics according to the EPA Level 1 protocol (Reference 3-4) as outlined in Appendix A. Semivolatile organic compounds with boiling points in the nominal C<sub>7</sub> to C<sub>16</sub> range of 100° to 300°C (210° to 570°F) were determined in the laboratory by total chromatographable organic (TCO) analysis of the combined organic module sorbent (XAD-2) and condensate extracts. Nonvolatile organic species having boiling points in the nominal C<sub>16</sub>+ range of >300°C (570°F) were measured by gravimetric (GRAV) analysis of SASS sample extracts.

Infrared spectrometry (IR) was performed on the GRAV residue of SASS train extracts to identify organic functional groups possibly present. Gas chromatography/mass spectrometry (GC/MS) analyses of the XAD-2 extracts were also performed to identify specific polynuclear aromatic hydrocarbons (PAH) and other organic components (the semivolatile organic priority pollutants).

The components sought in the GC/MS analysis and their respective detection limits are listed in Table 3-4.

In addition, emissions of volatile organics were measured at the catalyst outlet using the volatile organic sampling train (VOST) protocol per EPA procedures (Reference 3-1). Analysis of VOST samples was performed also by GC/MS. Volatile organic compounds sought in this analysis are listed in Table 3-5.

### 3.3.1 TCO, GRAV, GC/MS, and IR Analyses of SASS Sample Extracts

Table 3-6 summarizes the results of the organic analyses of the SASS train XAD-2 sorbent module extract for the catalyst inlet and outlet tests. As noted, total organic emissions decreased about 70 percent across the catalyst from 4.9 to 1.5 mg/dscm. The greatest reduction apparently occurred in the nonvolatile fraction. This fraction accounted for 65 percent of the total organic at the catalyst inlet, but only 40 percent at the catalyst outlet.

Two polynuclear aromatic hydrocarbon (PAH) compounds (naphthalene and phenanthrene) and a nitrophenol were measured in the exhaust at the catalyst inlet. Levels of these were significantly reduced at the catalyst outlet. Concentrations were below 10  $\mu\text{g/dscm}$  (about 40  $\mu\text{g/Bhp-hr}$ ) for both test locations.

Table 3-7 summarizes the results of the IR analysis of organic module extracts. The data suggest the presence of aliphatic hydrocarbons and possibly some oxygenated hydrocarbons at both the inlet and outlet locations.

TABLE 3-4. COMPOUNDS SOUGHT IN THE GC/MS AND THEIR DETECTION LIMITS  
(ng/ $\mu$ l INJECTED)

<u>Acid Compounds</u>			
2,4,6-trichlorophenol	5	2-nitrophenol	5
p-chloro-m-cresol	5	4-nitrophenol	20
2-chlorophenol	5	2,4-dinitrophenol	20
2,4-dichlorophenol	5	4,6-dinitro-o-cresol	20
2,4-dimethylphenol	5	pentachlorophenol	5
		phenol	1
<u>Base Neutral Compounds</u>			
1,2,4-trichlorobenzene	1	benzo(c)phenanthrene	40
1,2-dichlorobenzene	1	bis(2-chloroethoxy)methane	1
1,2-diphenylhydrazine	1	bis(2-chloroethyl)ether	1
(as azobenzene)		bis(2-chloroisopropyl)ether	1
1,3-dichlorobenzene	1	bis(2-ethylhexyl)phthalate	1
1,4-dichlorobenzene	1	butyl benzyl phthalate	1
2,4-dinitrotoluene	1	chrysene	1
2,6-dinitrotoluene	1	di-n-butyl phthalate	1
2-chloronaphthalene	1	di-n-octyl phthalate	1
3,3'-dichlorobenzidine	5	dibenzo(a,h)anthracene	5
3-methyl cholanthrene	40	dibenzo(c,g)carbazole	40
4-bromophenyl phenyl ether	1	diethyl phthalate	1
4-chlorophenyl phenyl ether	1	dimethyl phthalate	1
7,12-dimethyl benz(a)anthracene	40	fluoranthene	1
N-nitrosodi-n-propylamine	5	fluorene	1
N-nitrosodimethylamine	NA	hexachlorobenzene	1
N-nitrosodiphenylamine	1	hexachlorobutadiene	1
acenaphthene	1	hexachlorocyclopentadiene	1
acenaththylene	1	hexachloroethane	1
anthracene	1	indeno(1,2,3-cd)pyrene	5
benzo(ghi)perylene	5	isophorone	1
benzidine	20	naphthalene	1
benzo(b)fluoranthene	1	nitrobenzene	1
benzo(k)fluoranthene	1	perylene	40
benzo(a)anthracene	1	phenanthrene	1
benzo(a)pyrene	1	pyrene	1



TABLE 3-5. VOLATILE ORGANICS SOUGHT IN GC/MS ANALYSIS

<u>Chlorinated Aliphatics</u>	<u>Chlorinated Ethers</u>
Chloromethane	Epichlorohydrin
Dichloromethane	2-chloroethyl vinyl ether
Chloroform	
Tetrachloromethane	<u>Aldehydes</u>
Chloroethane	Acetaldehyde
1,1-dichloroethane	Acrolein
1,2-dichloroethane	
1,1,1-trichloroethane	<u>Amines and Nitriles</u>
1,1,2-trichloroethane	Acrylonitrile
1,1,2,2-tetrachloroethane	
1,2-dichloropropane	<u>Aromatic Hydrocarbons</u>
Hexachlorocyclohexane	Benzene
Vinyl chloride	Toluene
1,1-dichloroethylene	Ethyl benzene
1,2-dichloroethylene	o-xylene
Trichloroethylene	m-xylene
Tetrachloroethylene	p-xylene
Alkyl chloride	
1,3-dichloropropene	
Chloroprene	
<u>Ethers</u>	<u>Chlorinated Aromatics</u>
Ethylene oxide	Chlorobenzene
Propylene oxide	

TABLE 3-6. TOTAL ORGANIC AND SEMIVOLATILE ORGANIC PRIORITY POLLUTANT EMISSIONS: IC ENGINE/SCR SYSTEM TESTS, XAD-2 PLUS OMC EXTRACT

Component	Catalyst inlet		Catalyst outlet	
	(mg/train)	(mg/dscm)	(mg/train)	(mg/dscm)
Total semivolatile organics (C <sub>1</sub> to C <sub>16</sub> by TCO)	44	1.7	22 <sup>a</sup>	0.9
Total nonvolatile organics (C <sub>16</sub> + by gravimetry)	83	3.2	16	0.6
Total semi- and nonvolatile organics	127	4.9	38	1.5
Semivolatile organic priority pollutants	(μg/train)	(μg/dscm)	(μg/train) <sup>a</sup>	(μg/dscm)
Naphthalene	220	8.4	10	0.4
Phenanthrene	10	0.4	<10	<0.4
2-Nitrophenol	140	5.3	<10	<0.4
Di-n-butyl phthalate <sup>b</sup>	80	3.1	140	5.5
Bis (2-ethylhexyl) phthalate <sup>b</sup>	50	1.9	25	1.0
Other semivolatile organic priority pollutants	<10	<0.4	<10	<0.4

<sup>a</sup>Average of duplicate injections

<sup>b</sup>Suspected contaminants, commonly found in laboratory blanks

TABLE 3-7. IR SPECTRA SUMMARY

Sample	Wave number (cm <sup>-1</sup> )	Intensity <sup>a</sup>	Assignment	Possible compound categories present
XAD-2 + OMC extract, catalyst inlet	3350	W	OH stretch	Aliphatic hydrocarbons possibly with some oxygenates such as aldehydes and alcohols
	2955	S	CH alkyl	
	2920	S	CH alkyl	
	2850	S	CH alkyl	
	1570	S	Not assigned	
	1460	S	CH bend <sup>b</sup>	
	1340	W	CH bend <sup>b</sup>	
	1260	M	C-O stretch <sup>b</sup>	
	1055	M	C-O stretch <sup>b</sup>	
	950	W	C-C stretch	
	880	M	CH rock	
	770	W	CH rock	
	700	W	CH rock	
	635	W	CH rock	
XAD-2 + OMC extract, catalyst outlet	2955	S	CH alkyl	Aliphatic hydrocarbons possibly with some oxygenates such as carboxylic acids and ketones
	2920	S	CH alkyl	
	2850	S	CH alkyl	
	1710	S	C=O stretch	
	1450	M	CH bend <sup>b</sup>	
	1410	W	CH bend <sup>b</sup>	
	1255	S	C-O stretch	
	800	M	CH rock	

<sup>a</sup>S = strong, M = moderate, W = weak<sup>b</sup>Tentative assignment

### 3.3.2 Volatile Organic Emissions

Table 3-8 summarizes results of the volatile organic sampling train (VOST) testing of the engine. Only one abbreviated set (two runs) of VOST tests was performed; sampling was at the catalyst outlet. As shown, benzene and several substituted benzenes were emitted at highest concentrations: benzene at 915  $\mu\text{g/dscm}$ , toluene at 247  $\mu\text{g/dscm}$ , xylenes at 85  $\mu\text{g/dscm}$ , chlorobenzene at 61  $\mu\text{g/dscm}$ , and ethylbenzene at 20  $\mu\text{g/dscm}$ . Small amounts of chlorinated ethylenes and ethanes were also detected, although these compounds are often Tenax contaminants. The protocol is described in Appendix A.

### 3.4 EXTENDED CONTINUOUS EMISSION MONITORING

Continuous monitoring for exhaust gas  $\text{O}_2$ ,  $\text{CO}_2$ ,  $\text{CO}$ ,  $\text{NO}_x$ , and TUHC was performed over a 15-day period from July 26 to August 9, 1984. Actual emission measurements for SCR performance did not begin until July 27 due to  $\text{NH}_3$  feed problems and control. The engine was operated under normal conditions with no restrictions on load during this period.  $\text{NH}_3$  injection rate was controlled by the automatic  $\text{NO}_x$  feedback system installed on this unit as part of the SCR control package.  $\text{NH}_3$  feedrate was set to provide 80 percent reduction in  $\text{NO}_x$ . Figures 3-3 through 3-8 illustrate emission data obtained over this test period. The emission data represent hourly averages of the data taken on 5- to 15-min intervals.

Exhaust  $\text{O}_2$  and  $\text{CO}_2$ , illustrated in Figure 3-3, show that engine operation was fairly steady throughout the 14 days of actual emissions testing. Gaps on the test data indicate engine shutdowns generally due to lubrication system malfunction. This is most evident during the period

TABLE 3-8. VOLATILE ORGANIC SAMPLING TRAIN RESULTS: CATALYST OUTLETA

Compound	Field blank ( $\mu\text{g}/\text{trap}$ pair)	Method blank ( $\mu\text{g}/\text{trap}$ pair)	Run 1		( $\mu\text{g}/\text{dscm}$ ) corrected <sup>b</sup>	Run 2		( $\mu\text{g}/\text{dscm}$ ) corrected <sup>b</sup>	Average ( $\mu\text{g}/\text{dscm}$ )
			( $\mu\text{g}/\text{trap}$ pair)			( $\mu\text{g}/\text{trap}$ pair)			
			Measured	Corrected <sup>b</sup>		Measured	Corrected <sup>b</sup>		
Benzene	ND <sup>c</sup>	13	ND	--	--	32,000	32,000	1,830	915
Chlorobenzene	ND	5	1,700	1,700	81	720	715	41	61
1,2-dichloroethane	ND	ND	ND	--	--	5	--	--	--
1,1,1-trichloroethane	45	ND	ND	--	--	101	--	--	--
1,1,2,2-tetrachloroethane	ND	9	60	--	--	11	--	--	--
Chloroethane	ND	ND	56	56	2.7	16	16	0.9	1.8
Chloroform	ND	ND	11	--	--	10	--	--	--
1,1-dichloroethene	ND	ND	31	31	1.5	26	26	1.5	1.5
t-1,2-dichloroethene	ND	ND	7	--	--	ND	--	--	--
Ethylbenzene	ND	5	700	695	33	127	122	7.0	20
Methylene chloride	1,205	38	1,200	--	--	1,700	--	--	--
Chloromethane	111	58	155	--	--	130	--	--	--
Bromomethane	5	2	6	--	--	5	--	--	--
Tetrachloroethene	ND	ND	ND	--	--	85	85	4.8	2.4
Toluene	ND	31	6,000	5,970	285	3,700	3,670	209	247
Trichloroethene	ND	ND	ND	--	--	3	--	--	--
Vinyl chloride	ND	ND	11	--	--	5	--	--	--
Acetone	5	ND	720	715	34	ND	--	--	17
Total xylenes	ND	10	ND	--	--	3,000	2,990	170	85

<sup>a</sup>Traps desorbed and analyzed in pairs (Tenax and Tenax/charcoal)

<sup>b</sup>Corrected = measured - maximum of field or method blank. If this not greater than 10 times the blank value and greater than 10 times the method detection limit of 1 ng/trap pair, then assumed not significant, denoted by double dashes.

<sup>c</sup>ND denotes less than the method detection limit of 1 ng/trap pair




Figure 3-3. Exhaust  $O_2$  and  $CO_2$  for the extended continuous monitoring period.




Figure 3-4. Exhaust  $\text{NO}_x$  levels for the extended continuous monitoring period.




Figure 3-5. Catalyst NO<sub>x</sub> reduction efficiency for the extended monitoring period.






Figure 3-6. Catalyst outlet  $\text{NH}_3$  emissions for the extended continuous monitoring period.




Figure 3-7. Exhaust CO levels for the extended continuous monitoring period.




Figure 3-8. Exhaust hydrocarbon levels for the extended continuous monitoring period.

August 5 to 7. Comprehensive tests discussed in the previous sections were performed on August 3.

NO<sub>x</sub> emissions are illustrated in Figure 3-4. Catalyst inlet levels ranged from 1,200 to 1,600 ppm corrected to 15 percent O<sub>2</sub>. Catalyst outlet levels ranged from about 100 to 400 ppm (at 15 percent O<sub>2</sub>) with most of the measurements showing NO<sub>x</sub> of about 200 ppm. Corresponding NO<sub>x</sub> reduction efficiencies are shown in Figure 3-5. Catalyst performance averaged about 80 percent with the exception of a brief period during August when NH<sub>3</sub> flowrate was accidentally interrupted.

Figure 3-6 illustrates the catalyst outlet NH<sub>3</sub> recorded using continuous NO<sub>x</sub> analyzers as described in Appendix A. For the most part, NH<sub>3</sub> emissions throughout the test period were about 55 ppm at 15 percent O<sub>2</sub> (90 ppm as measured). Figures 3-7 and 3-8 illustrate trends in both CO and TUHC emissions. CO emissions showed a large variation from about 60 to 300 ppm (also corrected to 15 percent O<sub>2</sub>). Changes in CO from average values of about 140 to 150 ppm recorded during the comprehensive tests may be attributed to surges in engine load recorded during some portion of the test period and small variations in air/fuel ratios and ambient temperatures. TUHC data were not obtained for much of the test period due to instrument malfunction. Available data indicate TUHC levels in the range of about 750 to 1,250 ppm (at 15 percent O<sub>2</sub>) with no significant difference between the catalyst inlet and outlet locations.

### REFERENCES FOR SECTION 3

- 3-1. "Protocol for the Collection and Analysis of Volatile POHC's Using VOST," EPA-600/8-84-007, NTIS PB84-170042, March 1984.
- 3-2. Waterland, L. R., et al., "Environmental Assessment of Industrial Boilers Firing Coal-Liquid Mixtures and Wood," in Proceedings of the 1982 Joint Symposium of Stationary Combustion NO<sub>x</sub> Control, Volume II. EPA 600/9-85-022b, NTIS PB 85-235612, July 1985.
- 3-3. Castaldini, C. and L. R. Waterland, "Environmental Assessment of a Reciprocating Engine Retrofitted with Nonselective Catalytic Reduction," EPA 600/7-84-073a, NTIS PB84-224351, June 1984.
- 3-4. Lentzen, D. E., et al., "IERI-RTP Procedures Manual: Level 1 Environmental Assessment -- Second Edition," EPA-600/7-78-201, NTIS PB 293795, October 1978.

## SECTION 4

### QUALITY ASSURANCE ACTIVITIES

Specific quality assurance (QA) activities performed to determine the accuracy and precision of the measurements made in this test program included:

- Performing EPA Method 7 certification tests to establish the accuracy of the NO<sub>x</sub> continuous analyzers used in the tests
- Spiking a sample of cleaned XAD-2 resin with TCO, GRAV, and semivolatile priority pollutant compounds and analyzing the spiked resin to determine the accuracy (recovery) of the resin extraction and subsequent analyses
- Analyzing a blind spike sample for ammonia to determine the accuracy of the selective ion electrode analysis technique used
- Performing duplicate TCO and GC/MS injections on the SASS train XAD-2 extract to determine the precision of these measurements

The following paragraphs discuss results of these QA activities.

#### 4.1 NO<sub>x</sub> CERTIFICATION RESULTS

EPA Method 7 tests were performed once during the 15-day continuous monitoring period, on August 2, 1984. The intent of the tests was to certify the NO<sub>x</sub> analyzers by simultaneous measurement of emissions at the catalyst outlet. NO<sub>x</sub> emissions by continuous monitors at the catalyst outlet measured between 330 and 550 ppm, dry (445 ppm average) at stack conditions of about

11 percent O<sub>2</sub>. By contrast, EPA Method 7 results obtained from 27 separate samples indicated NO<sub>x</sub> levels between 40 and 370 ppm with an average value of about 132 ppm. During the same test period, visual observation of the SoCal NO<sub>x</sub> monitoring instrumentation indicated NO<sub>x</sub> in the range of 350 to 600 at the catalyst outlet, reflecting SCR NO<sub>x</sub> reduction performance settings of 80 percent. These SoCal NO<sub>x</sub> measurements using continuous monitors were generally in good agreement with emissions recorded by the Acurex monitors. Both SoCal and Acurex NO<sub>x</sub> instrumentation consisted of Thermo-Electron Model 10 AR monitors equipped with molybdenum and stainless steel converters. The Acurex monitors (two were used as discussed in Appendix A) were calibrated at least twice daily with high (2750 ppm), low (190 ppm), and zero (nitrogen) certified span gases. SoCal and Acurex monitors were also found to be in relatively good agreement for catalyst inlet NO<sub>x</sub> concentrations (less than 2 percent). In light of agreement between emissions obtained by SoCal and Acurex using continuous monitors, the EPA Method 7 results are deemed suspect. Therefore, results of the monitor certification tests are considered inconclusive.

#### 4.2 SPIKED XAD-2 RESIN ANALYSES

After extraction of the XAD-2 field blank, the same resin was spiked with 10 mg bis(2-ethylhexyl)phthalate, 40 mg hexadecane, and 400 µg each of naphthalene, phenanthrene, pyrene, and dodecane. Thus, this resin contained 41 mg TCO compounds (dodecane, hexadecane, and naphthalene), 51 mg GRAV compounds (the phthalate, phenanthrene, pyrene and hexadecane), and 400 µg each of three polynuclear aromatics for the semivolatile organic priority pollutant analysis (hexadecane will respond in both the TCO and GRAV analyses).

TABLE 4-1. XAD-2 RESIN SPIKE AND RECOVERY RESULTS

Measurement	Spiked amount (mg)	Recovered amount (mg)	Percent recovery	Implied accuracy	Accuracy objective <sup>a</sup>
Total chromatographable organics (TCO)	41.0	29.0	71	-29	±50
Gravimetric organics (GRAY)	51.0	39.0	76	-24	±50
Semivolatile organic priority pollutants:					
Naphthalene	0.4	0.31	78	-22	
Phenanthrene	0.4	0.34	85	-15	
Pyrene	0.4	0.25	62	-38	
Bis (2-ethylhexyl) phthalate	0.4	0.28			
Average			70	-30	-50 +100

<sup>a</sup>Reference 4-1.



Results of the analyses of this spiked resin are shown in Table 4-1. As noted, the recovery of the TCO analysis was 71 percent, the GRAV analysis was 76 percent, and averaged 74 percent for the GC/MS analyses. If these are interpreted to be the accuracy of these measurements, all fall within the project accuracy objective (Reference 4-1) also noted in Table 4-1.

#### 4.3 AMMONIA SPIKE SAMPLE ANALYSIS

An ammonia audit sample was prepared by adding a known amount of ammonium hydroxide to a volume of 0.1N HCl and submitted as a blind spike for analysis. The analysis result was 0.38 mg NH<sub>3</sub> per ml of solution, versus the spiked amount of 0.48 mg/ml. This implies an analytical accuracy of -21 percent.

#### 4.4 DUPLICATE ORGANIC ANALYSES OF XAD-2 EXTRACT

The XAD-2 extract samples from the catalyst outlet SASS train for this test were analyzed in duplicate for TCO content, and for the semivolatile organic priority pollutants and other major peaks by GC/MS. The two TCO measures were 21 and 24 mg/train, giving a relative standard deviation of 9.4 percent. This is within the precision objective of this measurement of 10 percent (Reference 4-1).

Results of the duplicate GC/MS injections are summarized in Table 4-2. The relative standard deviations for all compounds quantitated were well within the project precision objective of 50 percent for this measurement.

TABLE 4-2. DUPLICATE GC/MS ANALYSIS RESULTS FOR THE  
CATALYST OUTLET XAD-2 EXTRACT

Compound	Run 1 ( $\mu\text{g}/\text{train}$ )	Run 2 ( $\mu\text{g}/\text{train}$ )	Relative standard deviation (percent)
Naphthalene	10	10	0
Di-n-butyl phthalate	160	120	20.2
Bis (2-ethylhexyl) phthalate	30	20	28.3

#### REFERENCE FOR SECTION 4

- 4-1. "Quality Assurance Plan for the Combustion Modification Environmental Assessment," Acurex Corporation under EPA Contract 68-02-2160, September 10, 1982.

## SECTION 5

### SUMMARY

Field tests were performed in a lean-burn 1,500-kW (2,000-hp) reciprocating internal combustion engine retrofitted with an ammonia-based selective catalytic reduction (SCR) system for  $\text{NO}_x$  reduction. Two series of tests were performed: a comprehensive test program to characterize catalyst inlet and outlet exhaust gas composition at a catalyst  $\text{NO}_x$  reduction performance target of 80 percent; and a 15-day exhaust monitoring program to measure the catalyst performance under typical engine operation. Prior to the test period, problems were experienced with the  $\text{NH}_3$  control system, specifically, the  $\text{NO}_x$  analyzer and also the  $\text{NH}_3$  control valve.

$\text{NO}_x$  emission reduction during the 1-day comprehensive tests was maintained relatively constant at about 80 percent using an  $\text{NH}_3/\text{NO}$  molar ratio of about 1.0. Catalyst inlet  $\text{NO}_x$  levels from the four-stroke turbocharged engine ranged between 2,200 and 2,600 ppm as measured at about 11 percent excess  $\text{O}_2$ . At the catalyst outlet,  $\text{NO}_x$  ranged from 330 to 560 ppm.  $\text{NH}_3$  carryover measured at the catalyst outlet ranged between 65 and 120 ppm (about 80 ppm average) using an extractive sampling system. Continuous monitoring techniques suggested  $\text{NH}_3$  carryover levels in the range of 20 to 140 ppm (about 80 ppm average). Other emission measurements suggest relatively minor effects of the catalyst on CO and particulate emissions. Total cyanides increased from about 7  $\mu\text{g}/\text{dscm}$  to 2.4  $\text{mg}/\text{dscm}$  across the

catalyst. Total organics (C<sub>7+</sub>) decreased about 70 percent from 4.9 mg/dscm to 1.5 mg/dscm. Analyses for volatile organics showed benzene and toluene as the major compounds with catalyst outlet gas concentrations of about 920 and 250 µg/dscm, respectively. Semivolatile organic analyses showed a general decrease of PAH compounds (naphthalene and phenanthrene) across the catalyst. Outlet concentrations of these and other organics were generally below 0.4 µg/dscm (1.6 µg/Bhp-hr).

During the extended 15-day continuous monitoring of criteria gas emissions, catalyst NO<sub>x</sub> reduction performance was maintained at about 80 percent. Brief periods of reduced catalytic performance were attributed to engine load surges and an occasional malfunction in the NH<sub>3</sub> injection flowrate. NH<sub>3</sub> carryover emissions at the catalyst outlet ranged from 0 to about 150 ppm. Overall, the SCR system tested was found capable of maintaining 80 percent NO<sub>x</sub> reduction with no significant environmental impact apart from NH<sub>3</sub> carryover of generally less than 100 ppm and cyanide formation to 1.3 ppm.

## APPENDIX A

### SAMPLING AND ANALYSIS METHODS

Emissions test equipment was provided by Acurex Corporation. Onsite equipment included a continuous monitoring system for emissions measurements of gaseous criteria pollutants; the SASS train for particulate mass, semivolatile and nonvolatile organics; a VOST train by volatile organics; two separate sampling trains for  $\text{NH}_3$  and HCN measurement; gas grab sampling equipment for determining  $\text{N}_2\text{O}$  emissions by laboratory gas chromatography, and for validation of  $\text{NO}_x$  measurements with EPA Method 7. The following sections summarize the sampling and analysis equipment and methods used in the field and laboratory.

#### A.1 CONTINUOUS MONITORING SYSTEM

Acurex provided a continuous monitoring system modified to allow online simultaneous  $\text{NO}$ ,  $\text{NO}_x$ , and  $\text{NH}_3$  sampling capability alternatively at the inlet and outlet of the catalytic reactor. Figure A-1 illustrates a simplified schematic of the gas conditioning and monitoring system. The monitoring capability included  $\text{O}_2$ ,  $\text{CO}_2$ ,  $\text{CO}$  (high and low concentrations),  $\text{NO}$ ,  $\text{NO}_x$ ,  $\text{NO}_x + \text{NH}_3$ , and TUHC. The heated sample gas was treated for moisture removal using a permeation dryer. Simultaneous sampling of  $\text{NO}$ ,  $\text{NO}_x$ , and  $\text{NH}_3$  was achieved by using two chemiluminescent analyzers. One was equipped with an unheated molybdenum converter to prevent conversion of  $\text{NH}_3$  to  $\text{NO}$  in the sample gas and one was equipped with a standard heated stainless-steel converter to convert




Figure A-1. Schematic for continuous extractive sampling system.

both  $\text{NO}_2$  and  $\text{NH}_3$  to  $\text{NO}$ .  $\text{NH}_3$  emissions were calculated using the difference in readings between the two analyzers. Table A-1 lists the instrumentation constituting the continuous monitoring and flue gas extractive sampling system. A datalogger was used in addition to strip charts to record data continuously.

## A.2 SEMIVOLATILE AND NONVOLATILE ORGANIC EMISSIONS

Emissions of semivolatile and nonvolatile organics were sampled using the source assessment sampling system (SASS). Designed for Level 1 environmental assessment (Reference A-1), the SASS collects large quantities of gas and solid samples required for subsequent analyses of inorganic and organic emissions.

The SASS, illustrated in Figure A-2, is generally similar to the system utilized for total particulate mass emission tests (a high volume Method 5 train) with the exception of:

- The addition of a gas cooler and organic sampling module
- The addition of necessary vacuum pumps to allow a sampling rate of 2 l/s (4 cfm)

Particulate cyclones shown in Figure A-2 were not used for these tests because of low particulate loading in the flue gas.

Schematics outlining the standard sampling and analytical procedures using the SASS equipment are presented in Figures A-3 and A-4. The following paragraphs briefly describe analytical procedures used in measuring organic emissions.


Quantitative information on total organic emissions was obtained by gas chromatography/flame ionization detector for total chromatographable organics (TCO) and by gravimetry (GRAV) of sample extracts. Infrared spectroscopy

TABLE A-1. CONTINUOUS MONITORING EQUIPMENT IN THE MOBILE LABORATORY

Instrument	Principle of Operation	Manufacturer	Instrument Model	Range
NO NO <sub>x</sub>	Chemiluminescence	Thermo Electron	10 AR	0 to 2.5 ppm 0 to 10 ppm 0 to 25 ppm 0 to 100 ppm 0 to 250 ppm 0 to 1,000 ppm 0 to 2,500 ppm 0 to 10,000 ppm
CO (1)	Nondispersive infrared (NDIR)	ANARAD	500R	0 to 1,000 ppm
CO (2)	Nondispersive infrared (NDIR)	ANARAD	500R	0 to 1.0 percent (10,000 ppm)
CO <sub>2</sub>	Nondispersive infrared (NDIR)	ANARAD	AR500	0 to 20 percent
SO <sub>2</sub>	Pulsed Fluorescence	Thermo Electron	40	0 to 100 ppm 0 to 1,000 ppm 0 to 5,000 ppm 0 to 10,000 ppm
O <sub>2</sub>	Fuel cell	Teledyne		0 to 5 percent 0 to 10 percent 0 to 25 percent
TUHC	Flame ionization detection (FID)	Beckman	400	0 to 500 ppm
Datalogger	Electronic	Acurex/ Autodata	10	99 channels
Sample gas conditioner	Permeation dryer	Permapure	E-4G-SS	10 scfm
Strip chart recorders	Dual pen analog	Linear	400	0 to 10 mV 0 to 100 mV 0 to 1V 0 to 10V




A-5



Note: T.C. = Thermocouple

Figure A-2. Source assessment sampling train schematic.



\* If required, sample should be set aside for biological analysis at this point.

<sup>1</sup> This step is required to define the total mass of particulate catch. If the sample exceeds 10% of the total cyclone and filter sample weight proceed to analysis. If the sample is less than 10% of the catch, hold in reserve.

Figure A-3. Flue gas analysis protocol for SASS samples.




Figure A-4. Flue gas sample analysis protocol.

(IR) and gas chromatography/mass spectroscopy (GC/MS) were used for identification of organic functional groups and for determining polycyclic organic matter (POM) and other organic species concentrations (the semivolatile organic priority pollutants) in extract samples. Figure A-5 illustrates the organic analysis methodology used.

Passivation of the SASS train with 15 percent by volume  $\text{HNO}_3$  solution was performed prior to equipment preparation and sampling to produce biologically inert surfaces. Detailed descriptions of equipment preparation, sampling procedures, and sample recovery are discussed in Reference A-1 and will not be repeated here.

### A.3 VOLATILE ORGANIC EMISSIONS

A volatile organic sampling train (VOST), shown schematically in Figure A-6, was used to measure the low molecular weight volatile organic compounds (boiling points  $\leq 110^\circ\text{C}$ ) in the flue gas according to the EPA protocol (Reference A-2). The train consists of two organic sorbent traps connected in series. The first trap contained  $\sim 1.6\text{g}$  of the porous polymer Tenax-GC; 35/60 mesh. The second trap consisted of  $\sim 1.0\text{g}$  each of Tenax-GC and petroleum-based charcoal. Prior to their use in the field, each trap was conditioned to remove organic compounds. Conditioning consisted of baking each trap at  $190^\circ\text{C}$  with a  $\text{N}_2$  purge for an 8-hr period. The traps were then desorbed at  $190^\circ\text{C}$  directly into a GC/FID. If a trap showed no contaminant peaks greater than 20 ng as benzene or toluene, it was considered ready for sampling. The trap was then sealed at each end with compression fittings, placed in clean, muffled culture tubes, and sealed in a metal can for shipping.




Figure A-5. Organic analysis methodology.




Figure A-6. Schematic of volatile organic sampling train (VOST).

Before the field testing, the entire system was leak-checked at ~15 to 20-in. of vacuum. A leakage rate of 0.05 liter/min was considered acceptable. Ambient air was drawn through a charcoal-filled tube to prevent organic contamination while bringing the system back to ambient pressure.

One set of samples and a field blank were obtained for the test program. The gas sample was obtained at the catalyst outlet (stock) location. A total sample volume of 20 l was taken over a 40-min period (0.5 l/min). Upon completion of the test, the sample traps were removed from the train, sealed, returned to their original culture tubes, and stored in a metal can on ice. The VOST samples were analyzed by GC/MS according to the EPA VOST protocol. Each pair of traps used was thermally desorbed and analyzed for the EPA Method 624 (volatile) priority pollutants.

#### A.4 NH<sub>3</sub> AND HCN SAMPLING AND ANALYSIS

NH<sub>3</sub> and HCN were measured at the inlet and outlet locations of the catalytic converter utilizing two separate sampling trains. Both trains were similar to an EPA Method 6 train except that impinger solutions for NH<sub>3</sub> absorption were acid based (0.1N HCl) and for HCN were caustic based (0.1N NaOH). Concentrations of NH<sub>3</sub> and HCN in solutions were determined in the laboratory using approved wet chemical methods (HCN) or by specific ion electrode (NH<sub>3</sub>) (Reference A-2).

#### A.5 N<sub>2</sub>O SAMPLING AND ANALYSIS

The stack gas grab samples were extracted into stainless-steel cylinders for laboratory analysis for N<sub>2</sub>O using a sampling train illustrated in Figure A-7. For analysis each sample cylinder was externally heated to 120°C (250°F), then a 1-ml sample was withdrawn with a gas-tight syringe for injection into the gas chromatograph (GC) equipped with an electron capture

A-12




Figure A-7. N<sub>2</sub>O sampling system.



detector (ECD). The GC column used was a 10 ft x 1/8 in. stainless-steel column packed with 80/100 mesh chromosorb 101. The flow of nitrogen was 20 ml/min with the column kept at 45°C. Elution time for N<sub>2</sub>O was approximately 5 min.

#### A.6 NO<sub>x</sub> MONITOR CERTIFICATION SAMPLING AND ANALYSIS

Certification of the continuous NO<sub>x</sub> monitor was performed using the standard EPA Method 7 equipment and protocols.

## REFERENCES FOR APPENDIX A

- A-1. Lentzen, D. E., et al., "IERL-RTP Procedures Manual: Level 1 Environmental Assessment (Second Edition)," EPA-600/7-78-201, NTIS PB293795, October 1978.
- A-2. "Protocol for the Collection and Analysis of Volatile POHC's Using VOST," EPA-600/8-84-007, NTIS PB84-170042 March 1984.
- A-3. "Methods for Chemical Analysis of Water and Wastes," EPA-600/4-79-020, NTIS PB 297 686, March 1979.

<b>TECHNICAL REPORT DATA</b> <i>(Please read instructions on the reverse before completing)</i>		
1. REPORT NO. <b>EPA-600/7-86-014a</b>	2.	3. RECIPIENT'S ACCESSION NO.
4. TITLE AND SUBTITLE <b>Environmental Assessment of a Reciprocating Engine Retrofitted with Selective Catalytic Reduction; Volume I. Technical Results</b>		5. REPORT DATE <b>April 1986</b>
		6. PERFORMING ORGANIZATION CODE
7. AUTHOR(S) <b>C. Castaldini and L. R. Waterland</b>		8. PERFORMING ORGANIZATION REPORT NO.
9. PERFORMING ORGANIZATION NAME AND ADDRESS <b>Acurex Corporation Energy and Environmental Division P.O. Box 7555 Mountain View, California 94039</b>		10. PROGRAM ELEMENT NO.
		11. CONTRACT/GRANT NO. <b>68-02-3188</b>
12. SPONSORING AGENCY NAME AND ADDRESS <b>EPA, Office of Research and Development Air and Energy Engineering Research Laboratory Research Triangle Park, NC 27711</b>		13. TYPE OF REPORT AND PERIOD COVERED <b>Final; 3-12/84</b>
		14. SPONSORING AGENCY CODE <b>EPA/600/13</b>
15. SUPPLEMENTARY NOTES <b>AEERL project officer is Joseph A. McSorley, Mail Drop 65, 919/541-2920. Volume II is a data supplement.</b>		
16. ABSTRACT <b>The report gives results of comprehensive emission measurements and 15-day continuous emission monitoring for a 1,500 kW (2000 hp) gas-fired, four-stroke turbocharged reciprocating engine equipped with an ammonia-based selective catalytic reduction system for NOx control. Emission reductions were held at about 80% using an ammonia/NO ratio of about 1.0. NOx levels at the catalyst inlet ranged from 2,200 to 2,600 ppm at an exhaust gas oxygen level of about 11%. NOx levels at the catalyst outlet ranged from 65 to 120 ppm. The catalyst had relatively minor effect on CO and particulate emissions, but increased total cyanides by 3 orders of magnitude (from 7 micrograms/dscm to 2.4 mg/dscm) across the catalyst. Total organics decreased about 70%, from 4.9 to 1.5 mg/dscm. Analyses showed benzene and toluene as the major organic constituents in the catalyst exhaust. Polycyclic aromatics also decreased across the catalyst. The 15-day continuous monitoring tests showed that the catalyst was generally able to maintain NOx reductions at about 80%. Departures from these levels occurred only during brief load surges and ammonia flowrate spikes.</b>		
17. KEY WORDS AND DOCUMENT ANALYSIS		
a. DESCRIPTORS	b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group
<b>Pollution Assessments Reciprocating Engines Gas Engines Catalysis Reduction (Chemistry)</b>	<b>Ammonia Nitrogen Oxides Pollution Control Stationary Sources Environmental Assessment Selective Catalytic Reduction</b>	<b>13B 14B 21G 07D 07B, 07C</b>
18. DISTRIBUTION STATEMENT <b>Release to Public</b>	19. SECURITY CLASS (This Report) <b>Unclassified</b>	21. NO. OF PAGES <b>69</b>
	20. SECURITY CLASS (This page) <b>Unclassified</b>	22. PRICE