



Research and Development

ENVIRONMENTAL ASSESSMENT
OF A COAL/WATER SLURRY FIRED
INDUSTRIAL BOILER
Volume II. Data Supplement

Prepared for

Office of Air Quality Planning and Standards

Prepared by

Air and Energy Engineering Research
Laboratory
Research Triangle Park NC 27711

RESEARCH REPORTING SERIES

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into nine series. These nine broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and a maximum interface in related fields. The nine series are:

- 1. Environmental Health Effects Research**
- 2. Environmental Protection Technology**
- 3. Ecological Research**
- 4. Environmental Monitoring**
- 5. Socioeconomic Environmental Studies**
- 6. Scientific and Technical Assessment Reports (STAR)**
- 7. Interagency Energy-Environment Research and Development**
- 8. "Special" Reports**
- 9. Miscellaneous Reports**

This report has been assigned to the INTERAGENCY ENERGY-ENVIRONMENT RESEARCH AND DEVELOPMENT series. Reports in this series result from the effort funded under the 17-agency Federal Energy/Environment Research and Development Program. These studies relate to EPA's mission to protect the public health and welfare from adverse effects of pollutants associated with energy systems. The goal of the Program is to assure the rapid development of domestic energy supplies in an environmentally-compatible manner by providing the necessary environmental data and control technology. Investigations include analyses of the transport of energy-related pollutants and their health and ecological effects; assessments of, and development of, control technologies for energy systems; and integrated assessments of a wide range of energy-related environmental issues.

EPA REVIEW NOTICE

This report has been reviewed by the participating Federal Agencies, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the Government, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

This document is available to the public through the National Technical Information Service, Springfield, Virginia 22161.

EPA-600/7-86-012b
April 1986

ENVIRONMENTAL ASSESSMENT OF A COAL/WATER SLURRY
FIRED INDUSTRIAL BOILER

Volume II
Data Supplement

By

D. Van Buren and L. R. Waterland
Acurex Corporation
Energy & Environmental Division
555 Clyde Avenue
P.O. Box 7555
Mountain View, California 94039

EPA Contract No. 68-02-3188

EPA Project Officer: J. A. McSorley
Air and Energy Engineering Research Laboratory
Research Triangle Park, North Carolina 27711

For

U.S. ENVIRONMENTAL PROTECTION AGENCY
Office of Research and Development
Washington, DC 20460

ACKNOWLEDGEMENTS

The authors wish to extend their gratitude to R. Perkins and S. Hodorowski of the E. I. du Pont de Nemours & Company and R. Manfred of the Electric Power Research Institute. Their interest and cooperation in this test program and their efforts in arranging the opportunity to test the unit are gratefully acknowledged. Special recognition is also extended to the Acurex field test team of B. C. Daros, S. Smith, M. Murray, P. Kaufmann, and K. Brewster.

CONTENTS

| | | |
|---|--|------|
| 1 | Introduction | 1-1 |
| 2 | Boiler Operation Data | 2-1 |
| 3 | Sampling Data Sheets | 3-1 |
| | 3.1 Continuous Monitoring Data | 3-3 |
| | 3.2 EPA Method 5/8 Field Data | 3-9 |
| | 3.3 Source Assessment Sampling System (SASS) Field Data | 3-25 |
| | 3.4 Volatile Organic Sampling Train (VOST) Field Data | 3-35 |
| | 3.5 C ₁ to C ₆ Hydrocarbon Analysis Data | 3-39 |
| 4 | Laboratory Analysis Results | 4-1 |
| | 4.1 Trace Element Analyses | 4-3 |
| | 4.2 TCO, GRAV, GC/MS, and IR Analyses of SASS Samples | 4-17 |
| | 4.3 GC/MS Analysis of VOST Traps | 4-25 |
| | 4.4 Bioassay Analysis Report | 4-31 |

SECTION 1

INTRODUCTION

The purpose of this data supplement is to document data in greater detail than was possible in Volume I (Technical Results) of this report. It is intended to provide sufficient detail for researchers to perform their own analysis of the data obtained. Readers are referred to the technical volume for objectives, description of source emission results, data interpretation, and conclusions.

The remaining sections of this data supplement contain the following information:

Section 2 -- Boiler Operating Data: pressures, temperatures, and flowrates; efficiency calculations using the ASME heat loss method

Section 3 -- Sampling Data Sheets: continuous monitor data summary; operating data tables and isokinetic calculations for EPA Method 5/8 (for particulate mass and SO₂ and SO₃ emissions), SASS (for trace element and semi- and nonvolatile organic sampling), and VOST (for volatile organic sampling); and C₁ to C₆ hydrocarbon analysis data by onsite GC/FID

Section 4 -- Laboratory Analysis Results: trace element results by spark source mass spectrometry (SSMS), atomic absorption spectroscopy (AAS), and other methods; total chromatographable organic (TCO) and gravimetric (GRAV) results, determination of semivolatile

organic priority pollutants by gas chromatography/mass spectrometry (GC/MS), and infrared (IR) spectra of total sample extracts; analyses of VOST traps by GC/MS; and biological assay reports.

SECTION 2
BOILER OPERATING DATA

BOILER OPERATING DATA: 8-25-83

| Time | Inlet Air Temp. (°F) | Windbox Air Temp. (°F) | Windbox Pressure (in. WC) | Economizer Gas Inlet Temp. (°F) | Header Temp. (°F) | Pump Pressure (psig) | Strainer Discharge Pressure (psig) | Slurry | | Flowrate | |
|---------|-------------------------------|---------------------------------|---------------------------------|--|-------------------------|----------------------------|---|----------------------------|------------------------|----------------------------|------------------------|
| | | | | | | | | Magnetic Meter (gpm) | Mass Meter (gpm) | Magnetic Meter (gpm) | Mass Meter (gpm) |
| 0815 | 85 | 523 | | 540 | 98 | | | 9.38 | 9.95 | | |
| 0930 | 88 | 523 | 11.2 | 525 | 98 | 206 | | 9.36 | 10.09 | | |
| 1015 | 92 | 518 | 11.2 | 532 | 98 | 205 | | 9.36 | 10.11 | | |
| 1115 | 93 | 518 | | 533 | 99 | 204 | | 9.33 | 10.08 | | |
| 1200 | 98 | 520 | 11.2 | 535 | 100 | 204 | | 9.30 | 9.92 | | |
| 1245 | 99 | 520 | 11.2 | 540 | 101 | 204 | | 9.30 | 9.86 | | |
| 1330 | 99 | 521 | 11.2 | 542 | 100 | 210 | 196 | 9.29 | 9.82 | | |
| 1425 | 101 | 522 | 11.2 | 526 | 99 | 214 | 200 | 9.27 | 9.85 | | |
| 1500 | 102 | 519 | 11.2 | 529 | 99 | 212 | 200 | 9.26 | 9.76 | | |
| 1600 | 99 | 517 | 11.2 | 533 | 100 | 214 | 200 | 9.25 | 9.79 | | |
| 1700 | 98 | 520 | 11.2 | 539 | 101 | 210 | 198 | 9.24 | 9.72 | | |
| 1745 | 99 | 517 | 11.2 | 542 | 101 | 210 | 198 | 9.26 | 9.65 | | |
| 1845 | 97 | 518 | 11.2 | 544 | 101 | 210 | 196 | 9.26 | 9.72 | | |
| Average | 96 | 520 | 11.2 | 535 | 100 | 209 | 198 | 9.30 | 9.87 | | |

(continued)

BOILER OPERATING DATA: 8-25-83 (continued)

| Time | Natural Gas Flow | | Steam | | Feedwater | | |
|---------|---|---|--------------------|---------------------------------|-----------------------|--------------------------------------|---------------------------------------|
| | Burner No. 4 (10 ³ scfh) | Air Heater (10 ³ scfh) | Pressure (psig) | Flow (10 ³ lb/hr) | Feed Temp. (°F) | Economizer Inlet Temp. (°F) | Economizer Outlet Temp. (°F) |
| 0815 | 3.72 | 3.73 | 173 | 55.7 | | 262 | 200 |
| 0930 | 3.79 | 3.69 | 176 | 56.0 | 265 | 262 | 200 |
| 1015 | 3.51 | 3.69 | 175 | 55.7 | 265 | 262 | 200 |
| 1115 | 3.21 | 3.61 | 175 | 55.7 | | 262 | 200 |
| 1200 | 2.99 | 3.52 | 175 | 54.6 | 265 | 262 | 200 |
| 1245 | 2.99 | 3.51 | 175 | 55.0 | | 262 | 200 |
| 1330 | 2.94 | 3.51 | 175 | 54.9 | 265 | 262 | 200 |
| 1425 | 2.96 | 3.56 | 175 | 56.5 | | 262 | 200 |
| 1500 | 2.98 | 3.46 | 175 | 55.7 | | 262 | 200 |
| 1600 | 2.93 | 3.35 | 176 | 55.2 | | 262 | 200 |
| 1700 | 2.89 | 3.45 | 174 | 55.9 | 265 | 262 | 200 |
| 1745 | 2.96 | 3.50 | 175 | 55.8 | | 262 | 200 |
| 1845 | 2.96 | 3.55 | 175 | 55.2 | 265 | 262 | 200 |
| Average | 3.14 | 3.55 | 175 | 55.5 | 265 | 262 | 200 |

(continued)

BOILER OPERATING DATA: 8-25-83 (continued)

| Time | Burner #2 | | Burner #3 | | Burner #4 | | Furnace Pressure (in. WC) | Stack Temp. (°F) | Stack O ₂ (% day) |
|---------|---------------------|------------------------|---------------------|------------------------|---------------------|------------------------|---------------------------|------------------|------------------------------|
| | Air Pressure (psig) | Slurry Pressure (psig) | Air Pressure (psig) | Slurry Pressure (psig) | Air Pressure (psig) | Slurry Pressure (psig) | | | |
| 0815 | 206 | 168 | 206 | 166 | 206 | 168 | -0.15 | 571 | 6.7 |
| 0930 | 206 | 166 | 206 | 164 | 204 | 176 | -0.31 | 559 ^a | 6.8 |
| 1015 | 204 | 164 | 206 | 164 | 204 | 176 | -0.31 | 567 | 6.8 |
| 1115 | 206 | 164 | 208 | 164 | 206 | 174 | -0.30 | 572 | 6.8 |
| 1200 | 206 | 164 | 208 | 162 | 204 | 174 | -0.30 | 574 | 6.8 |
| 1245 | 206 | 164 | 208 | 162 | 206 | 174 | -0.31 | 577 | 6.6 |
| 1330 | 204 | 166 | 208 | 166 | 206 | 178 | -0.31 | 580 | 6.8 |
| 1425 | 206 | 167 | 208 | 166 | 206 | 178 | -0.40 | 561 ^b | 7.0 |
| 1500 | 204 | 168 | 207 | 166 | 206 | 179 | -0.16 | 563 | 6.7 |
| 1600 | | | | | | | -0.16 | 568 | 6.7 |
| 1700 | 206 | 168 | 208 | 166 | 206 | 178 | -0.15 | 574 | 7.8 |
| 1745 | 206 | 168 | 208 | 166 | 206 | 178 | -0.16 | 578 | 6.7 |
| 1845 | 206 | 167 | 208 | 166 | 206 | 178 | -0.16 | 576 | 6.8 |
| Average | 206 | 166 | 208 | 165 | 206 | 176 | -0.24 | 571 | 6.8 |

^aSoothflow at 0915^bSoothflow at 1400

SUMMARY SHEET

ASME TEST FORM
FOR ABBREVIATED EFFICIENCY TEST

PTC 4.1-a (1964)

| OWNER OF PLANT | <i>DuPont</i> | | TEST NO. | BOILER NO. | DATE 8-27-67 | | | |
|--|----------------|--------------|---|--|---|-----------------------------------|---------------------------------|-------------|
| TEST CONDUCTED BY | <i>Acuity</i> | | LOCATION | Stack Breach | | | | |
| BOILER MAKE & TYPE | <i>P&W</i> | | OBJECTIVE OF TEST | Emission (Chlor) DURATION/L.C. | | | | |
| STOKER, TYPE & SIZE | | | RATED CAPACITY 600 lb/hr | | | | | |
| PULVERIZER, TYPE & SIZE | | | BURNER, TYPE & SIZE | | | | | |
| FUEL USED <i>C&S</i> | MINE | COUNTY | STATE | SIZE AS FIRED | | | | |
| PRESSURES & TEMPERATURES | | | | FUEL DATA | | | | |
| 1 STEAM PRESSURE IN BOILER DRUM | psia | <i>190</i> | COAL AS FIRED PROX. ANALYSIS | % wt | OIL | | | |
| 2 STEAM PRESSURE AT S. H. OUTLET | psia | | 37 MOISTURE | <i>27.7</i> | 51 FLASH POINT F° | | | |
| 3 STEAM PRESSURE AT R. H. INLET | psia | | 38 VOL MATTER | | 52 Sp. Gravity Deg. API° | | | |
| 4 STEAM PRESSURE AT R. H. OUTLET | psia | | 39 FIXED CARBON | | 53 VISCOSITY AT SSU [*] BURNER SSF | | | |
| 5 STEAM TEMPERATURE AT S. H. OUTLET | F | | 40 ASH | <i>3.2</i> | 44 TOTAL HYDROGEN % wt | | | |
| 6 STEAM TEMPERATURE AT R.H. INLET | F | | TOTAL | | 41 Btu per lb | | | |
| 7 STEAM TEMPERATURE AT R.H. OUTLET | F | | 41 Btu per lb AS FIRED | <i>10410</i> | | | | |
| 8 WATER TEMP. ENTERING (ECON) (BOILER) | F | <i>200</i> | ASH SOFT TEMP. [*] ASTM METHOD | | GAS % VOL | | | |
| 9 STEAM QUALITY% MOISTURE OR P.P.M. | | <i>100</i> | COAL OR OIL AS FIRED ULTIMATE ANALYSIS | 54 | <i>1/2</i> | 0.4 | | |
| 10 AIR TEMP. AROUND BOILER (AMBIENT) | F | <i>56</i> | 43 CARBON | <i>58.6</i> | 55 CH ₄ METHANE | <i>96.0</i> | | |
| 11 TEMP AIR FOR COMBUSTION (This is Reference Temperature) † | F | <i>96</i> | 44 HYDROGEN | <i>3.6</i> | 56 C ₂ H ₂ ACETYLENE | <i>0.2</i> | | |
| 12 TEMPERATURE OF FUEL | F | <i>102</i> | 45 OXYGEN | <i>3.2</i> | 57 C ₂ H ₆ ETHYLENE | <i>0.1</i> | | |
| 13 GAS TEMP. LEAVING (Boiler) (Econ) (Air Htr.) | F | <i>57.1</i> | 46 NITROGEN | <i>1.0</i> | 58 C ₂ H ₆ ETHANE | <i>0.2</i> | | |
| 14 GAS TEMP. ENTERING AH (If conditions to be corrected to guarantee) | F | | 47 SULPHUR | <i>0.4</i> | 59 H ₂ S | — | | |
| UNIT QUANTITIES | | | | 40 ASH | <i>3.2</i> | 60 CO ₂ 1.0 | | |
| 15 ENTHALPY OF SAT. LIQUID (TOTAL HEAT) | Btu/lb | <i>172</i> | 37 MOISTURE | <i>25.7</i> | 61 H ₂ HYDROGEN | — | | |
| 16 ENTHALPY OF (SATURATED) (SUPERHEATED) STM. | Btu/lb | <i>1198</i> | TOTAL <i>1020</i> | | TOTAL <i>1020</i> | | | |
| 17 ENTHALPY OF SAT. FEED TO (BOILER) (ECON.) | Btu/lb | <i>172</i> | COAL PULVERIZATION | | | TOTAL HYDROGEN % wt | | |
| 18 ENTHALPY OF REHEATED STEAM R. H. INLET | Btu/lb | | 48 GRINDABILITY INDEX [*] | | 62 DENSITY 68 F ATM. PRESS. | | | |
| 19 ENTHALPY OF REHEATED STEAM R. H. OUTLET | Btu/lb | | 49 FINENESS % THRU 50 M ^a | | 63 Btu PER CU FT | | | |
| 20 HEAT ABS/LB OF STEAM (ITEM 16 - ITEM 17) | Btu/lb | <i>1026</i> | 50 FINENESS % THRU 200 M ^a | | 41 Btu PER LB | | | |
| 21 HEAT ABS/LB R. H. STEAM (ITEM 19 - ITEM 18) | Btu/lb | | 64 INPUT-OUTPUT EFFICIENCY OF UNIT % | ITEM 31 x 100 ITEM 29 <i>85.3</i> | | | | |
| 22 DRY REFUSE (ASH PIT + ELY ASH) PER LB AS FIRED FUEL | lb/lb | <i>0.261</i> | HEAT LOSS EFFICIENCY | | | Btu/lb A. F. FUEL % of A. F. FUEL | | |
| 23 Btu PER LB IN REFUSE (WEIGHTED AVERAGE) | Btu/lb | <i>520</i> | 65 HEAT LOSS DUE TO DRY GAS | | 66 HEAT LOSS DUE TO MOISTURE IN FUEL | <i>1676</i> <i>16.1</i> | | |
| 24 CARBON BURNED PER LB AS FIRED FUEL | lb/lb | <i>0.561</i> | 66 HEAT LOSS DUE TO MOISTURE IN FUEL | | 67 HEAT LOSS DUE TO H ₂ O FROM COMB. OF F. | <i>374</i> <i>3.6</i> | | |
| 25 DRY GAS PER LB AS FIRED FUEL BURNED | lb/lb | <i>14.7</i> | 67 HEAT LOSS DUE TO H ₂ O FROM COMB. OF F. | | 68 HEAT LOSS DUE TO COMBUST. IN REFUSE | <i>403</i> <i>3.9</i> | | |
| HOURLY QUANTITIES | | | | 68 HEAT LOSS DUE TO COMBUST. IN REFUSE | | 69 HEAT LOSS DUE TO RADIATION | <i>361</i> <i>3.5</i> | |
| 26 ACTUAL WATER EVAPORATED | lb/hr | <i>55500</i> | 69 HEAT LOSS DUE TO RADIATION | | 70 UNMEASURED LOSSES | — | 71 TOTAL | <i>28.0</i> |
| 27 REHEAT STEAM FLOW | lb/hr | | 70 UNMEASURED LOSSES | | 71 TOTAL | | 72 EFFICIENCY = (100 - Item 71) | <i>72.0</i> |
| 28 RATE OF FUEL FIRING (AS FIRED wt) | lb/hr | | 71 TOTAL | | 72 EFFICIENCY = (100 - Item 71) | | 72.0 | |
| 29 TOTAL HEAT INPUT (Item 28 x Item 41) 1000 | kB/hr | <i>66750</i> | 72 EFFICIENCY = (100 - Item 71) | | | | | |
| 30 HEAT OUTPUT IN BLOW-DOWN WATER | kB/hr | | | | | | | |
| 31 TOTAL HEAT (Item 26 x Item 20)+(Item 27 x Item 21)+Item 30 OUTPUT 1000 | kB/hr | <i>56940</i> | | | | | | |
| FLUE GAS ANAL. (BOILER) (ECON) (AIR HTR) OUTLET | | | | | | | | |
| 32 CO ₂ | % VOL | <i>9.5</i> | | | | | | |
| 33 O ₂ | % VOL | <i>7.0</i> | | | | | | |
| 34 CO | % VOL | — | | | | | | |
| 35 N ₂ (BY DIFFERENCE) | % VOL | <i>83.5</i> | | | | | | |
| 36 EXCESS AIR | % | <i>45.5</i> | | | | | | |

* Not Required for Efficiency Testing

† For Point of Measurement See Par. 7.2.8.1-PTC 4.1-1964

| OWNER OF PLANT | TEST NO. | BOILER NO. | DATE |
|--|----------|--------------------|--|
| 30 HEAT OUTPUT IN BOILER BLOW-DOWN WATER = LB OF WATER BLOW-DOWN PER HR X | ITEM 15 | ITEM 17 | kB/hr ----- 1000 ----- |
| 24 If impractical to weigh refuse, this item can be estimated as follows DRY REFUSE PER LB OF AS FIRED FUEL = $\frac{\% \text{ASH IN AS FIRED COAL}}{100 - \% \text{COMB. IN REFUSE SAMPLE}}$ | ITEM 43 | ITEM 22 | ITEM 23 |
| CARBON BURNED PER LB AS FIRED FUEL - $\frac{58.6}{100} - \left[\frac{0.061 \times 5920}{14,500} \right] = 0.561$ | ITEM 22 | ITEM 23 | 0.561 |
| 25 DRY GAS PER LB AS FIRED FUEL BURNED - $\frac{11CO_2 + 8O_2 + 7(N_2 + CO)}{3(CO_2 + CO)} \times (\text{LB CARBON BURNED PER LB AS FIRED FUEL} + \frac{3}{8} S)$ $11 \times \frac{ITEM 32}{S} + 8 \times \frac{ITEM 33}{20} + 7 \left(\frac{ITEM 35}{ITEM 34} + \frac{ITEM 34}{ITEM 34} \right) \times \left[\frac{ITEM 24}{0.561} + \frac{ITEM 47}{0.41} \right] = 17.7$ $3 \times \left(\frac{ITEM 32}{ITEM 34} + \frac{ITEM 34}{ITEM 34} \right)$ | ITEM 32 | ITEM 33 | ITEM 35 ITEM 34 |
| 36 EXCESS AIR $\frac{O_2 - \frac{CO}{2}}{100 \times \frac{.2682N_2 - (O_2 - \frac{CO}{2})}{2}} = \frac{ITEM 33 - \frac{ITEM 34}{2}}{.2682(ITEM 35) - (ITEM 33 - \frac{ITEM 34}{2})} = 45.5$ | ITEM 33 | ITEM 34 | ITEM 35 ITEM 34 |
| 65 HEAT LOSS DUE TO DRY GAS PER LB AS FIRED FUEL $\frac{C_p \times (T_{Vg} - T_{air})}{\text{Unit}} = \frac{ITEM 25 \times 0.24}{ITEM 13 - (ITEM 11)} = 14.7 \times 571.96 = 16.76$ | ITEM 25 | ITEM 13 ITEM 11 | 16.76 $\frac{65}{41} \times 100 = 16.1$ |
| 66 HEAT LOSS DUE TO MOISTURE IN FUEL $\frac{\text{LB H}_2\text{O PER LB AS FIRED FUEL}}{[(ENTHALPY OF VAPOR AT 1 PSIA & T GAS LGV) - (ENTHALPY OF LIQUID AT T AIR)]} = \frac{ITEM 37 \times 1323}{100 \times 64} = 374$ | ITEM 37 | ITEM 13 ITEM 11 | 374 $\frac{66}{41} \times 100 = 3.6$ |
| 67 HEAT LOSS DUE TO H ₂ O FROM COMB. OF H ₂ = $9H_2 \times [(ENTHALPY OF VAPOR AT 1 PSIA & T GAS LGV) - (ENTHALPY OF LIQUID AT T AIR)]$ $= 9 \times \frac{ITEM 44}{100} \times [ITEM 13 - (ENTHALPY OF LIQUID AT T ITEM 11)] = 408$ | ITEM 44 | ITEM 13 ITEM 11 | 408 $\frac{67}{41} \times 100 = 3.9$ |
| 68 HEAT LOSS DUE TO COMBUSTIBLE IN REFUSE $ITEM 22 \times ITEM 23 = 0.061 \times 5920 = 361$ | ITEM 22 | ITEM 23 | 361 $\frac{68}{41} \times 100 = 3.5$ |
| 69 HEAT LOSS DUE TO RADIATION $\frac{\text{TOTAL BTU RADIATION LOSS PER HR}}{\text{LB AS FIRED FUEL} - ITEM 28} = \dots$ | ITEM 28 | ITEM 28 | $\frac{69}{41} \times 100 = 0.9$ |
| 70 UNMEASURED LOSSES ** \dots | ITEM 71 | ITEM 71 | $\frac{70}{41} \times 100 = \dots$ |
| 71 TOTAL \dots | ITEM 71 | ITEM 71 | \dots |
| 72 EFFICIENCY $(100 - ITEM 71)$ | ITEM 71 | ITEM 71 | 72.0 |

† For rigorous determination of excess air see Appendix 9.2 - PTC 4.1-1964

* If losses are not measured, use ABMA Standard Radiation Loss Chart, Fig. 8, PTC 4.1-1964

** Unmeasured losses listed in PTC 4.1 but not tabulated above may be provided for by assigning a mutually agreed upon value for Item 70.

SECTION 3
SAMPLING DATA SHEETS

- 3.1 Continuous Monitoring Data
- 3.2 EPA Method 5/8 Field Data
- 3.3 Source Assessment Sampling System (SASS) Field Data
- 3.4 Volatile Organic Sampling Train (VOST) Field Data
- 3.5 C₁ to C₆ Hydrocarbon Analysis Data

3.1 CONTINUOUS MONITORING DATA

Continuous Monitoring Data : 8/25/83

Stack gas (all readings dry basis) :

| Date/Time | NOx (ppm) | O2 (%) | CO2 (%) | SO2 (ppm) | CO (ppm) | TUHC (ppm) | Temp. (Deg.F) | Comment |
|-----------|--------------|-----------|------------|--------------|-------------|---------------|------------------|---------------------|
| 0:01 | 380. | 7.7 | 9.8 | | 395. | 2. | 563. | |
| 0:30 | 390. | 7.5 | 9.8 | | 425. | 2. | 567. | |
| 1:00 | 385. | 7.4 | 9.8 | | 445. | 2. | 569. | |
| 1:29 | 385. | 7.4 | 9.9 | | 465. | 2. | 570. | |
| 2:00 | 385. | 7.3 | 9.9 | | 490. | 2. | 572. | Sootblow |
| 2:29 | 370. | 7.5 | 9.8 | | 530. | 2. | 552. | |
| 3:00 | 380. | 7.3 | 9.9 | | 535. | 2. | 559. | |
| 3:29 | 380. | 7.2 | 9.9 | | 555. | 2. | 562. | |
| 4:00 | 380. | 7.2 | 9.9 | | 555. | 2. | 566. | |
| 4:30 | 375. | 7.1 | 9.9 | | 590. | 2. | 567. | |
| 5:00 | 370. | 7.0 | 10.0 | | 610. | 2. | 569. | |
| 5:30 | 375. | 7.0 | 9.9 | | 635. | 2. | 571. | |
| 6:00 | 370. | 7.0 | 9.8 | | 660. | 2. | 573. | |
| 6:30 | 370. | 6.9 | 9.9 | | 660. | 2. | 579. | Sootblow |
| 7:00 | 375. | 6.8 | 9.9 | | 730. | 2. | 562. | |
| 7:30 | 370. | 6.8 | 9.9 | | 730. | 1. | 565. | Calibrate monitors |
| 8:50 | 400. | 8.4 | 9.7 | | 230. | 2. | 572. | All monitors online |
| 8:55 | 400. | 8.0 | 9.5 | | 245. | 2. | 574. | |
| 9:00 | 405. | 7.7 | 9.5 | | 220. | 2. | 571. | |
| 9:05 | 400. | 7.7 | 9.4 | | 215. | 1. | 573. | |
| 9:10 | 400. | 7.6 | 9.2 | | 205. | 1. | 573. | |
| 9:14 | 400. | 7.6 | 9.1 | | 205. | 1. | 572. | Sootblow |
| 9:19 | 390. | 7.6 | 8.9 | | 250. | 4. | 560. | |
| 9:25 | 385. | 7.7 | 8.8 | | 200. | 2. | 550. | |
| 9:30 | 385. | 7.6 | 9.3 | | 205. | 3. | 555. | |
| 9:35 | 395. | 7.6 | 9.2 | | 225. | 4. | 557. | |
| 9:39 | 385. | 7.5 | 9.3 | | 205. | 2. | 558. | |
| 9:44 | 390. | 7.5 | 9.3 | | 210. | 2. | 559. | |
| 9:50 | 390. | 7.5 | 9.3 | | 205. | 2. | 560. | |
| 9:55 | 375. | 7.5 | 9.3 | | 215. | 2. | 562. | |
| 10:00 | 390. | 7.5 | 9.5 | | 220. | 2. | 562. | |
| 10:05 | 390. | 7.5 | 9.6 | | 215. | 2. | 563. | |
| 10:10 | 395. | 7.4 | 9.7 | | 215. | 2. | 564. | |
| 10:14 | 390. | 7.4 | 9.8 | | 210. | 1. | 558. | |
| 10:19 | 395. | 7.4 | 9.8 | | 205. | 2. | 570. | |
| 10:25 | 390. | 7.4 | 9.8 | | 210. | 2. | 569. | |
| 10:30 | 390. | 7.4 | 9.5 | | 225. | 4. | 570. | |
| 10:35 | 385. | 7.3 | 9.5 | | 200. | 2. | 571. | |
| 10:39 | 390. | 7.3 | 9.6 | | 215. | 2. | 570. | |
| 10:44 | 380. | 7.4 | 9.6 | | 230. | 2. | 566. | |
| 10:50 | 390. | 7.2 | 10.0 | | 210. | 1. | 569. | |
| 10:55 | 395. | 7.2 | 9.9 | | 215. | 2. | 570. | |
| 11:00 | 385. | 7.2 | 9.8 | | 220. | 2. | 570. | |
| 11:05 | 385. | 7.3 | 9.7 | | 240. | 3. | 570. | |
| 11:10 | 390. | 7.2 | 9.7 | | 220. | 1. | 572. | |

Continuous Monitoring Data : 8/25/83 (continued)

Stack gas (all readings dry basis) :

| Date/Time | NOx (ppm) | O2 (%) | CO2 (%) | SO2 (ppm) | CO (ppm) | TUHC (ppm) | Temp. (Deg.F) | Comment |
|-----------|--------------|-----------|------------|--------------|-------------|---------------|------------------|---------|
| 11:14 | 390. | 7.2 | 9.6 | 220. | 1. | 572. | | |
| 11:19 | 390. | 7.2 | 9.4 | 225. | 1. | 572. | | |
| 11:25 | 395. | 7.2 | 9.3 | 230. | 1. | 576. | | |
| 11:30 | 395. | 7.2 | 9.2 | 230. | 6. | 573. | | |
| 11:35 | 390. | 7.2 | 9.2 | 235. | 3. | 573. | | |
| 11:39 | 390. | 7.2 | 9.3 | 230. | 2. | 573. | | |
| 11:44 | 390. | 7.2 | 9.3 | 245. | 2. | 575. | | |
| 11:50 | 395. | 7.2 | 9.4 | 255. | 1. | 575. | | |
| 11:55 | 395. | 7.2 | 9.4 | 260. | 1. | 574. | | |
| 12:00 | 395. | 7.2 | 9.4 | 250. | 2. | 575. | | |
| 12:05 | 395. | 7.2 | 9.4 | 260. | 1. | 575. | | |
| 12:10 | 400. | 7.1 | 9.4 | 255. | 1. | 574. | | |
| 12:14 | 390. | 7.1 | 9.4 | 265. | 1. | 575. | | |
| 12:19 | 395. | 7.1 | 9.4 | 255. | 1. | 575. | | |
| 12:25 | 390. | 7.1 | 9.5 | 255. | 1. | 576. | | |
| 12:30 | 390. | 7.1 | 9.5 | 255. | 1. | 576. | | |
| 12:35 | 395. | 7.1 | 9.6 | 270. | 1. | 576. | | |
| 12:39 | 395. | 7.1 | 9.7 | 275. | 2. | 576. | | |
| 12:44 | 395. | 7.1 | 9.6 | 270. | 1. | 576. | | |
| 12:50 | 385. | 7.1 | 9.6 | 275. | 1. | 576. | | |
| 12:55 | 390. | 7.0 | 9.7 | 270. | 2. | 576. | | |
| 13:00 | 390. | 7.0 | 9.6 | 280. | 2. | 577. | | |
| 13:05 | 390. | 7.0 | 9.5 | 290. | 2. | 576. | | |
| 13:10 | 395. | 6.9 | 9.5 | 285. | 4. | 576. | | |
| 13:14 | 390. | 7.0 | 9.4 | 285. | 3. | 578. | | |
| 13:19 | 385. | 7.0 | 9.4 | 290. | 2. | 578. | | |
| 13:35 | 395. | 7.1 | 9.8 | 290. | 1. | 579. | | |
| 13:39 | 395. | 7.0 | 9.7 | 295. | 1. | 579. | | |
| 13:44 | 395. | 6.9 | 9.6 | 300. | 1. | 580. | | |
| 13:50 | 400. | 6.9 | 9.4 | 320. | 1. | 579. | | |
| 13:55 | 395. | 6.9 | 9.3 | 320. | 1. | 579. | | |
| 14:00 | 380. | 7.0 | 9.0 | 330. | 1. | 579. | | |
| 14:05 | 385. | 7.0 | 8.9 | 345. | 1. | 580. | | |
| 14:10 | 405. | 6.8 | 9.2 | 345. | 2. | 579. | | |
| 14:14 | 405. | 6.8 | 9.4 | 335. | 1. | 579. | | |
| 14:19 | 395. | 6.8 | 9.2 | 335. | 2. | 571. | Sootblow | |
| 14:25 | 390. | 6.8 | 9.4 | 340. | 1. | 563. | | |
| 14:30 | 400. | 6.8 | 9.3 | 350. | 1. | 564. | | |
| 14:35 | 400. | 6.8 | 9.7 | 340. | 1. | 563. | | |
| 14:39 | 405. | 6.8 | 9.5 | 340. | 1. | 565. | | |
| 14:44 | 410. | 6.8 | 9.4 | 340. | 1. | 564. | | |
| 14:50 | 405. | 6.7 | 9.5 | 325. | 3. | 564. | | |
| 14:55 | 405. | 6.7 | 9.5 | 335. | 4. | 564. | | |
| 15:00 | 405. | 6.6 | 9.7 | 325. | 2. | 565. | | |
| 15:05 | 405. | 6.6 | 9.7 | 335. | 2. | 564. | | |

Continuous Monitoring Data : 8/25/83 (concluded)

Stack gas (all readings dry basis) .

| Date/Time | NOx (ppm) | O2 (%) | CO2 (%) | SO2 (ppm) | CO (ppm) | TUHC (ppm) | Temp. (Deg.F) | Comment |
|-----------|--------------|-----------|------------|--------------|-------------|---------------|------------------|---------------------|
| 15:10 | 410. | 6.6 | 9.6 | | 330. | 1. | 565. | |
| 15:14 | 410. | 6.6 | 9.6 | | 330. | 1. | 565. | |
| 15:19 | 410. | 6.6 | 9.6 | | 335. | 1. | 566. | |
| 15:25 | 405. | 6.7 | 9.5 | | 345. | 1. | 566. | |
| 15:30 | 405. | 6.7 | 9.5 | | 340. | 1. | 566. | |
| 15:35 | 400. | 6.6 | 9.7 | | 335. | 1. | 567 | |
| 15:39 | 405. | 6.6 | 9.6 | | 345. | 1. | 568. | |
| 15:44 | 405. | 6.7 | 9.4 | | 345. | 1. | 568. | |
| 15:50 | 400. | 6.6 | 9.5 | | 350. | 1. | 569. | |
| 15:55 | 390. | 6.6 | 9.5 | | 355. | 1. | 568. | |
| 16:00 | 390. | 6.6 | 9.7 | | 355. | 1. | 569. | |
| 16:04 | 400. | 6.6 | 9.6 | | 360. | 1. | 570. | |
| 16:10 | 395. | 6.6 | 9.4 | | 360. | 1. | 570. | |
| 16:14 | 410. | 6.6 | 9.4 | | 385. | 1. | 570. | |
| 16:20 | 415. | 6.6 | 9.5 | | 370. | 1. | 570. | |
| 16:25 | 410. | 6.6 | 9.5 | | 375. | 1. | 571. | Calibrate monitors |
| 17:14 | 436. | 7.7 | 9.8 | 349. | 209. | 1. | 572. | All monitors online |
| 17:45 | 429. | 5.7 | 9.4 | 349. | 223. | 2. | 576. | Method 8 SO2 test |
| 18:14 | 425. | 7.1 | 9.7 | 349. | 223. | 1. | 579. | |
| 18:45 | 418. | 7.0 | 9.8 | 349. | 234. | | 577. | TUHC monitor |
| 19:00 | 421. | 6.9 | 9.7 | | 266. | | 556. | inoperative |
| 19:29 | 423. | 6.8 | 9.8 | | 278. | | 556. | |
| 20:00 | 413. | 6.7 | 9.7 | | 279. | | 557. | |
| 20:29 | 412. | 6.6 | 9.9 | | 286. | | 560. | |
| 21:00 | 413. | 6.5 | 9.6 | | 320. | | 562. | |
| 21:29 | 408. | 6.4 | 9.7 | | 324. | | 565. | |
| 22:00 | 404. | 6.3 | 9.4 | | 334. | | 567. | |
| 22:29 | 396. | 6.2 | 9.3 | | 349. | | 570. | |
| 23:00 | 404. | 6.2 | 9.3 | | 367. | | 571. | |
| 23:29 | 400. | 6.1 | 9.3 | | 380. | | 571. | |

3.2 EPA METHOD 5/8 FIELD DATA

ACUREX CORPORATION

Run 1 - M-510

Acurex Project No. 307735.71
 Field Dates 8-24/26-83
 Plant DUPONT - MEMPHIS, TN
 Sampling Location BOILER NO 1 CWS
 Sampling Date 8-25-83

FIELD CREW


Crew Chief: ERICK C. DIAZ
 Testing Engineer: 1 PETE KAUFMANN - SASS
2 MARTIN M MURRAY - M-511
 Engr. Technician: 1
2
3
 Lab Technician: 1
2
 Process Engineer: 1
2

FIELD SAMPLE REFERENCE NUMBERS:

| 900222 | IMP1 559.0 <u>50.4</u> | IMP2 578.8 <u>544.2</u> | IMP 3 533.1 <u>514.6</u> | IMP 4 671.9 <u>627.3</u> |
|--------|------------------------------|-------------------------------|--------------------------------|--------------------------------|
| 900215 | | | | |
| 900214 | | 49.6 | 34.6 | 17.5 |
| 900223 | | | | |
| 900224 | | | | |
| 900231 | | | | |
| 900229 | | | | |

TRaverse Point Location for Circular Ducts


PLANT DUPONT - MEMPHIS, TN
DATE 8-24-83
SAMPLING LOCATION
INSIDE OF FAR WALL TO
OUTSIDE OF NIPPLE, (DISTANCE A) 54.5"
INSIDE OF NEAR WALL TO
OUTSIDE OF NIPPLE, (DISTANCE B) 4.5"
STACK I.D., (DISTANCE A - DISTANCE B) 50.0"
NEAREST UPSTREAM DISTURBANCE > 8 DIAM
NEAREST DOWNSTREAM DISTURBANCE
CALCULATOR M. MURRAY



SCHEMATIC OF SAMPLING LOCATION

PRELIMINARY VELOCITY TRAVERSE

PLANT Depot - Memphis, TN
 DATE 8-24-83 1830
 LOCATION Boiler No. 1 - CWM
 STACK I.D.
 BAROMETRIC PRESSURE, in. Hg 29.98 (BS)
 STACK GAUGE PRESSURE, in. H₂O -0.5
 OPERATORS Murray / DKRCS



| TRAVERSE POINT NUMBER | VELOCITY HEAD (Δp_s), in. H ₂ O | STACK TEMPERATURE (T_s), °F |
|-----------------------|--|---------------------------------|
| A-1 | .04 | 519 |
| 2 | .38 | 551 |
| 3 | .50 | 554 |
| 4 | .55 | 556 |
| 5 | .45 | 557 |
| 6 | .48 | 557 |
| 7 | .45 | 558 |
| 8 | .45 | 559 |
| 9 | .48 | 559 |
| 10 | .42 | 5168 |
| 11 | .25 | 516 |
| A-12 | .30 | 493 |
| B-1 | 0 | 548 |
| 2 | 0 | 549 |
| 3 | .35 | 552 |
| 4 | .55 | 554 |
| 5 | .52 | 556 |
| 6 | .45 | 558 |
| 7 | .45 | 558 |
| 8 | .45 | 558 |
| 9 | .40 | 559 |
| 10 | .40 | 558 |
| 11 | .40 | 543 |
| B-12 | .30 | 496 |
| AVERAGE | | |

| TRAVERSE POINT NUMBER | VELOCITY HEAD (Δp_s), in. H ₂ O | STACK TEMPERATURE (T_s), °F |
|-----------------------|--|---------------------------------|
| C-1 | .05 | 535 |
| 2 | .40 | 539 |
| 3 | .40 | 554 |
| 4 | .45 | 556 |
| 5 | .45 | 557 |
| 6 | .42 | 559 |
| 7 | .40 | 559 |
| 8 | .35 | 561 |
| 9 | .35 | 561 |
| 10 | .32 | 560 |
| 11 | .30 | 561 |
| C-12 | .31 | 550 |
| D-1 | .10 | 501 |
| 2 | .25 | 521 |
| 3 | .28 | 527 |
| 4 | .32 | 535 |
| 5 | .30 | 539 |
| 6 | .25 | 542 |
| 7 | .30 | 546 |
| 8 | .33 | 550 |
| 9 | .30 | 550 |
| 10 | .34 | 555 |
| 11 | .33 | 555 |
| 12 | .33 | 555 |
| AVERAGE | | |

EPA (Dur) 233
 4.72 $\sum \Delta p_s$ = .541 $\sqrt{\Delta p}$ avg. = 7
 3-9

$$T_s = 546$$

ISOKINETIC NOZZLE CALCULATION
AND
SAMPLING RATE CALCULATION

Plant Dow Chemical Co. Performed by John W. Smith

Date 8/22/73

Sample Location Furnace #1

Test No./Type 51 #1

$$N_d = \left(\frac{\Delta H T_s}{K T_m \Delta P} \right)^{.25}$$

where: N_d = Nozzle diameter (inches)

| | | |
|---|------------|------|
| Average pressure differential across the orifice meter (in. H ₂ O) | ΔH | 2.2 |
| Temperature stack gas, average (°F) | T_s | 575 |
| Temperature of gas meter, average (°F) | T_m | 70 |
| Stack gas velocity pressure (in H ₂ O) | ΔP | 35 |
| $\left(\frac{(_) (_ + 460)}{(_) (_ + 460)(_)} \right)^{.25}$ | N_d | .367 |

$$\Delta H = K (N_d)^4 \frac{T_m}{T_s} (\Delta P)$$

where: ΔH = Pressure differential across the orifice meter (in H₂O)

| | | |
|--|------------|--------|
| Nozzle diameter, actual (inches) | N_d | .367 |
| Temperature of gas meter (°F) | T_m | 101 |
| Temperature of stack gas (°F) | T_s | 576 |
| Stack gas velocity pressure (in H ₂ O) | ΔP | |
| $\left((_) (_)^4 \left\{ \frac{_ + 460}{_ + 460} (_) \right\} \right)$ | ΔH | |
| Magic number <u> </u> (<u> </u>) ⁴ | $K(N_d)^4$ | 16.991 |

ISOKINETIC SAMPLING WORKSHEET

Plant Lignite Performed by R. S. ...
 Date 5/27/73
 Sample Location Boiler
 Test No./Type 5/8

$$K = \frac{782.687 (C_p)^2 (1-B_{w0})^2 P_s M_d}{K_o^2 M_s P_m}$$

where: K = Constant of fixed and assumed parameters (dimensionless)

| | | |
|---|--------------------------|--|
| Pitot coefficient (dimensionless) | C_p ^{assumed} | .62 |
| Water vapor in the gas stream (proportion by volume) | B_{w0} | .06 |
| Absolute stack gas pressure (in. Hg) | P_s | 14.5 |
| Molecular weight, stack gas dry (1b/1b-mole) | M_d | CO ₂ 44 1= 2.5 1= 2.5 |
| Orifice coefficient (dimensionless) | K_o ^{assumed} | .7126 |
| Molecular weight, stack gas wet (1b/1b-mole) $M_d(1-B_{w0}) + 18(B_{w0})$ | M_s | |
| Absolute meter pressure (in. Hg) | P_m | 29.72 |
| $\frac{782.687 (\underline{\quad})^2 (1-\underline{\quad})^2 (\underline{\quad}) (\underline{\quad})}{(\underline{\quad})^2 (\underline{\quad}) (\underline{\quad})}$ | K | 132.92 |

FIELD DATA

Page 1 of 4

Plant DuPont, McIntosh, AL
 Date 8-25-83
 Sample Location #1 Bayre
 Sample Type EPA 5/8
 Run Number 1
 Operator Murray
 Ambient Temperature 95
 Barometric Pressure 29.98
 Static Pressure, (H₂O) -0.5
 Filter Number(s) #355 (142mm)

Leak Check: Initial at 15" Hg, .015 CFM
 Final at 19" Hg, .0018 CFM
 Pitot Leak Check: off

| Impinger Volumes | | |
|-------------------------------------|-------|----------|
| Initial | Final | Net Gain |
| 584.4 l PA | 100ml | 49.6 |
| 547.2 H ₂ O ₂ | 100ml | 34.6 |
| 514.6 H ₂ O ₂ | 100ml | 17.5 |
| | | |
| | | |
| | | |
| Silica Gel | | |
| 627.3 | 671.3 | 44.6 |
| | | |
| | | |
| SASS Condensate | | |
| | n/a | |
| Total Volume | | |
| | 146.3 | |

Probe Length and Type 5' Teflon
 Nozzle Size & I.D. P 50 0.361"
 Pitot Coefficient & I.D. 0.82 (alpha = 1.1)
 Assumed Moisture 62
 Molecular Weight, Dry, (M_d)
 Meter Box Number NAPP CS-55
 Meter Coefficient 7126
 α Factor .9908
 K =
 $K(N_d)^4 = \frac{1}{(T_m)} \times \frac{1}{(T_s)} = \frac{1}{P}$
 $\Delta H = K(N_d)^4 \left(\frac{T_m}{T_s} \right) (P)$

3-12

| Traverse Point Number | Sampling Time, min | Clock Time (24-hr) Clock | Gas Meter Reading (V _m), ft ³ | Velocity Head (ΔP _s), in. H ₂ O | Orifice Pressure Differential (ΔH), in. H ₂ O | | Temperature °F | | | | | | Pump Vacuum in. Hg | Svgs. IP | |
|-----------------------|--------------------|--------------------------|--|--|--|--------|----------------|-------|----------|----------------|------|-----|--------------------|----------|------|
| | | | | | Desired | Actual | Stack | Probe | Impinger | Organic Module | Oven | In | Out | | |
| 0 | 1654 | | Init. 49.789 | | | | 576 | — | — | — | 175 | 91 | 103 | 8 | 0.0 |
| A-1 | 1654 | | 54500 | 0 | — | — | 576 | — | — | — | 175 | 101 | 101 | 10 | 0.5 |
| 2 | 1656 | | 51.500 | .25 | 2.29 | 2.30 | 579 | — | — | — | 175 | 101 | 101 | 14 | .714 |
| 3 | 1656 | | 53.510 | .51 | 4.69 | 4.70 | 579 | — | — | — | 175 | 103 | 101 | 14 | .714 |
| 4 | 1702 | | 55.895 | .52 | 4.78 | 4.80 | 579 | — | — | — | 185 | 103 | 103 | 14 | .721 |
| 5 | 1704 | | 58.310 | .52 | 4.78 | 4.80 | 579 | | | | 195 | 104 | 102 | 14 | .721 |
| 6 | 1706 | | 60.320 | .51 | 4.70 | 4.70 | 579 | | | | 202 | 105 | 102 | 15 | .714 |
| 7 | 1708 | | 62.679 | .51 | 4.70 | 4.70 | 578 | | | | 202 | 105 | 103 | 15 | .714 |
| 8 | 1710 | | 64.850 | .51 | 4.70 | 4.70 | 579 | | | | 208 | 105 | 103 | 15 | .714 |
| 9 | 1712 | | 67.140 | .49 | 4.14 | 4.10 | 579 | | | | 209 | 105 | 103 | 15 | .671 |

Comments: Probe heats up but thermostat doesn't work
 1ST POINT IN EACH PLOT IS NULL - ports A + B only

5201

7602/E1 Rev 1

E13

| Traverse Point Number | Clock Time (24-hr) Clock | | Gas Meter Reading (V _m), ft ³ | Velocity Head (ΔP _s), in. H ₂ O | Orifice Pressure Differential (ΔH), in. H ₂ O | | Temperature of | | | | | Gas Meter | | Pump Vacuum in. Hg | Avg. ΔP | |
|-----------------------|-----------------------------|-------|---|---|---|--------|----------------|-------|----------|----------------|------|-----------|-----|--------------------|---------|------|
| | Sampling Time, min | 1714 | | | Desired | Actual | Stack | Probe | Impinger | Organic Module | Oven | In | Out | | | |
| | | | | | | | | | | | | 18 | 32 | 30 | 32 | 30 |
| 18 | 1714 | Init. | 67.146 | | | | | | | | | 212 | 105 | 104 | 11 | .566 |
| 10 | 20 | 1716 | 69.20 | .32 | 2.94 | 2.94 | 324 | — | — | — | — | 212 | 105 | 104 | 12 | .548 |
| 11 | 22 | 1718 | 71.100 | .30 | 3.66 | 3.70 | 324 | — | — | — | — | 198 | 104 | 103 | 12 | .566 |
| 12 | 24 | 1720 | 72.995 | .32 | 3.91 | 3.90 | 350 | — | — | — | — | 199 | 105 | 104 | 12 | .566 |
| STAKE B | 24 | 1720 | 72.995 | | | | | | | | | — | — | — | — | — |
| B-1 | 24 | 1722 | 72.995 | 0 | 0 | 0 | 575 | — | — | — | — | 212 | 102 | 103 | 0 | 0 |
| 2 | 28 | 1724 | 73.750 | .05 | 0.46 | 0.5 | 577 | — | — | — | — | 212 | 101 | 103 | 4 | .224 |
| 3 | 30 | 1726 | 75.300 | .30 | 2.76 | 2.8 | 579 | — | — | — | — | 212 | 101 | 103 | 10 | .548 |
| 4 | 32 | 1728 | 77.550 | .55 | 5.07 | 4.90 | 579 | — | — | — | — | 212 | 101 | 103 | 17 | .742 |
| 5 | 34 | 1730 | 79.90 | .575 | 5.53 | 4.70 | 579 | — | — | — | — | 210 | 102 | 103 | 17 | .725 |
| 6 | 36 | 1732 | 82.20 | .50 | 4.60 | 4.60 | 579 | — | — | — | — | 210 | 102 | 103 | 17 | .707 |
| 7 | 38 | 1734 | 84.30 | .48 | 4.42 | 4.40 | 584 | — | — | — | — | 220 | 104 | 103 | 17 | .693 |
| 8 | 40 | 1736 | 86.30 | .50 | 4.58 | 4.40 | 585 | — | — | — | — | 227 | 103 | 103 | 17 | .707 |
| 9 | 42 | 1738 | 88.50 | .45 | 4.12 | 4.10 | 585 | — | — | — | — | 224 | 103 | 103 | 17 | .674 |
| 10 | 44 | 1740 | 90.68 | .45 | 4.12 | 4.10 | 585 | — | — | — | — | 224 | 103 | 103 | 17 | .614 |
| 11 | 46 | 1742 | 92.87 | .40 | 3.68 | 3.70 | 585 | — | — | — | — | 230 | 103 | 102 | 15 | .632 |
| 12 | 48 | 1744 | 94.440 | .3 | 2.76 | 2.8 | 450 | — | — | — | — | 240 | 103 | 102 | 13 | .583 |

5-4-

Run No. 5/8 #1Date 8-25-83Sampling Location #1 Building

Comments:

3-14

| Traverse Point Number | Sampling Time, min | Clock Time (24-hr) Clock | Gas Meter Reading (V_m), ft ³ | Velocity Head (ΔP_s), in. H ₂ O | Orifice Pressure Differential (ΔH), in. H ₂ O | Temperature of | | | | | Gas Meter | Pump Vacuum in. Hg | Avg. \sqrt{AP} | |
|-----------------------|--------------------|-----------------------------|--|--|--|----------------|--------|-------|-------|----------|----------------|--------------------|------------------|---------|
| | | | | | | Desired | Actual | Stack | Probe | Impinger | Organic Module | | | |
| 48 | 1747 | Init. | 94.440 | | | | | | | | | 225 | 101 102 | 5 .224 |
| C - 1 | 50 | 1748 | 95.250 | .05 | .46 | .50 | 571 | - | - | - | - | 225 | 101 102 | 5 .224 |
| 2 | 52 | 1750 | 96.310 | .18 | 1.65 | 1.70 | 571 | - | - | - | - | 230 | 102 101 | 9 .424 |
| 3 | 54 | 1752 | 98.100 | .38 | 3.48 | 3.48 | 582 | - | - | - | - | 230 | 102 101 | 15 .616 |
| 4 | 56 | 1754 | 100.250 | .45 | 4.13 | 4.10 | 582 | - | - | - | - | 230 | 102 102 | 17 .671 |
| 5 | 58 | 1756 | 101.900 | .45 | 4.13 | 4.10 | 582 | - | - | - | - | 228 | 102 101 | 17 .671 |
| 6 | 60 | 1758 | 104.000 | .45 | 4.13 | 4.00 | 579 | - | - | - | - | 230 | 103 102 | 17 .671 |
| 7 | 62 | 1800 | 106.050 | .43 | 3.96 | 4.00 | 579 | - | - | - | - | 235 | 103 102 | 17 .656 |
| 8 | 64 | 1802 | 108.000 | .43 | 3.96 | 4.00 | 579 | - | - | - | - | 230 | 103 102 | 17 .656 |
| 9 | 66 | 1804 | 109.800 | .43 | 3.96 | 3.90 | 579 | - | - | - | - | 215 | 103 102 | 17 .656 |
| 10 | 68 | 1806 | 111.600 | .40 | 3.68 | 3.70 | 579 | - | - | - | - | 219 | 103 102 | 17 .632 |
| 11 | 70 | 1808 | 113.650 | .38 | 3.49 | 3.50 | 519 | - | - | - | - | 220 | 102 102 | 16 .616 |
| 12 | 72 | 1810 | 115.420 | .33 | 3.03 | 3.06 | 579 | - | - | - | - | 220 | 102 102 | 15 .514 |
| | | 1812 | 116 | | | | | | | | | | | |
| D - 1 | 74 | 1814 | 116.450 | .10 | .94 | 1.00 | 558 | - | - | - | - | 225 | 102 102 | 7 .316 |
| 2 | 76 | 1816 | 117.700 | .28 | 2.57 | 2.60 | 586 | - | - | - | - | 220 | 101 103 | 14 .324 |
| 3 | 78 | 1818 | 119.500 | .35 | 3.21 | 3.20 | 585 | - | - | - | - | 220 | 102 102 | 16 .594 |
| 4 | 80 | 1820 | | .32 | 2.92 | 2.90 | 588 | - | - | - | - | 230 | 102 101 | 16 .56 |

72-1

Run No. Method 5/8 #1

Date 8-25-83

Sampling Location #1 BOILER

Comments:

Run No. 110160 5/8 #1

Date 8/23/83

Sampling Location "Bruce"

Comments:

ISOKINETIC PERFORMANCE WORKSHEET & PARTICULATE CALCULATIONS

 Plant Lignite - Memphis, Tn.

 Performed by Dickes

 Date 7-25-81

 Sample Location stack

 Test No./Type 1/11-513

| | | |
|--|-----------|---------------|
| Barometric Pressure (in. Hg) | P_b | <u>~7.7</u> |
| Meter volume (std), $17.64 \left(\frac{V_m}{\alpha} \right) \left(\frac{P_b + \frac{\Delta H}{13.6}}{T_m + 460} \right)$ $17.64 \left(\frac{(85.89)}{1.9904} \right) \left(\frac{(27.98)}{(102.3)} + \frac{(-.7)}{13.6} \right) + \frac{460}{}$ | V_m std | <u>82.124</u> |
| Volume of liquid collected (grams) | V_l_c | <u>146.3</u> |
| Volume of liquid at standard condition (scf) $V_l_c \times 0.04707$ | V_w std | <u>6.846</u> |
| Stack gas proportion of water vapor $\frac{V_w}{V_w + V_m}$ std , $\frac{(6.846)}{(6.846) + (82.124)}$ | B_{wo} | <u>.077</u> |
| Molecular weight, stack gas dry $(lb/lb-mole)$ $(\% CO_2 \times 0.44) + (\% O_2 \times 0.32) + (\% N_2 + \% CO \times 0.28)$ $(9.7 \times 0.44) + (6.9 \times 0.32) + (83.4 + \text{blank} \times 0.28)$ | M_d | <u>29.83</u> |
| Molecular weight, stack gas wet $(lb/lb-mole)$ $M_d(1-B_{wo}) + 18(B_{wo})$, $(29.83)(1-.077) + 18(.077)$ | M_s | <u>28.91</u> |
| Absolute stack pressure (in. Hg) $P_b + \frac{P_{stack} \text{ (in. H}_2\text{O)}}{13.6}$, $(29.98) + \frac{(-.5)}{13.6}$ | P_s | <u>29.74</u> |

7602/5/81/Rev 1

| | | |
|---|------------------------|------------------|
| Temperature stack gas, average (°F) | T _s | 207.7 |
| Stack velocity (fps) 85.49 (C _p) ($\sqrt{\Delta P_s}$ avg) $\sqrt{\frac{T_s \text{ avg} + 460}{P_s M_s}}$ 85.49 (.80) (.603) $\sqrt{\frac{(50.7) + 460}{(29.94)(28.71)}}$ | V _s (avg) | 44.31 |
| Total sample time (minutes) | θ | 70 |
| Nozzle diameter, actual (inches) | N _d | .500 |
| Percent isokinetic (%) 17.33 (T _s + 460)(V _w std + V _m std) $\frac{\theta V_s P_s N_d^2}{17.33 (\underline{\quad} + 460)((\underline{\quad}) + (\underline{\quad}))(\underline{\quad})(\underline{\quad})(\underline{\quad})(\underline{\quad})^2}$ | %I | 92.1 |
| Area of stack (ft ²) $\pi = 3.1416$ $\frac{50 \times 55 \text{ in}}{144 \text{ in}^2}$ $\pi r^2 \div 144, \pi (\underline{\quad})^2 \div 144$ | A _s | 19.097 |
| Stack gas volume at standard conditions (dscfm) 60 (1 - B _{wo}) V _s avg A _s $\left(\frac{528}{T_s \text{ avg} + 460}\right) \left(\frac{P_s}{29.92}\right)$ 60 (1 - <u> </u>) (<u> </u>) (<u> </u>) $\left(\frac{528}{\underline{\quad} + 460}\right) \left(\frac{(\underline{\quad})}{(29.92)}\right)$ | ACFM Q _s | 50,775 24,157 |
| Particulate matter concentration, dry (gr/dscf) 15.432 $\frac{M_p \text{ (grams)}}{V_m \text{ std}}$, 15.432 $\frac{(\underline{\quad})}{(\underline{\quad})}$ | C _s (std) | |
| Emission rate of particulate matter (lb/hr) 0.00857 (Q _s) C _s (std), 0.00857 (<u> </u>) (<u> </u>) | E _p | |

7602/5/81/Rev 1

ACUREX ANALYTICAL REPORT

Sample of: CINEA DuPont, Memphis

Sample Date: _____

Requested By: J. Wierland

I.D. Number: 307735 71

Analytical Method: EPA 318. Ba(Cl₄)₂ titrations, and gravimetric (IPA blank)

Date of Analysis: 10/25/83

| Lab I.D. Number | Component | Analytical Result | Unit |
|-------------------|--|-------------------|------|
| 900215 (Dish #89) | particulate (IPA blank) | 1.19 mg/100mL | mg |
| 900214 | SO ₂ (H ₂ O ₂ Blank) | 2.62 | mg |
| 900224 | SO ₂ | 2161.7 | mg |
| 900223 | SO ₃ (H ₂ SO ₄) | 15.82 | mg |
| 900215 | SO ₃ (H ₂ SO ₄) IPA Blank | 2.02 | mg |

N.B. All reported values have been corrected for blanks.

Analysis By Marta M. Murray
Date 10/25/83

ISOKINETIC CALCULATIONS - USEPA: M/S BASIS

DUPONT-MEMPHIS, TN NO.1

| RUN NUMBER | 1-SASS | 1-M5/8 |
|--------------------------|-----------|---------|
| DATE OF TEST | 8-25-83 | 8-25-83 |
| OPERATOR | PWK | MMM |
| METER VOLUME, CF | 1107.833 | 85.889 |
| METER COEF | 0.997 | 0.9908 |
| BAROMETRIC PRES, HG | 29.98 | 29.98 |
| DELTA H, IN H2O | 2.13 | 3.47 |
| METER TEMP, DEG F | 112.3 | 103.3 |
| STACK TEMP, DEG F | 576.9 | 564.7 |
| CONDENSATE, ML | 2934.9 | 146.3 |
| PERCENT CO2 | 9.5 | 9.7 |
| PERCENT O2 | 7 | 6.9 |
| PERCENT CO | 0 | 0 |
| PERCENT N2 | 83.5 | 83.4 |
| STATIC PRES, IN H2O | -0.5 | -0.5 |
| PITOT COEF | 0.79 | 0.79 |
| SQRT DELTA P, IN H2O | 0.511 | 0.603 |
| STACK AREA, SQ FT | 19.1 | 19.1 |
| NOZZLE DIAM, IN | 0.744 | 0.367 |
| TEST TIME, MIN | 280 | 96 |
| MASS PARTICULATE, G | 0 | 0 |
| F-FACTOR, DSCF/MBTU | 0 | 0 |
| VOLUME, DSCF | 1,032.749 | 82.124 |
| WATER VAPOR, SCF | 138.146 | 6.886 |
| PERCENT MOISTURE | 0.118 | 0.077 |
| MOLECULAR WT DRY, LB/LB | 29.8 | 29.828 |
| MOLECULAR WT WET, LB/LB | 28.41 | 28.91 |
| STACK PRES, IN HG | 29.94 | 29.94 |
| STACK VELOCITY, FT/SEC | 38.10 | 44.31 |
| MASS FLOW, DSCFM | 19,627 | 24,157 |
| MASS FLOW, ACFM | 43,666 | 50,775 |
| PERCENT EXCESS AIR | | |
| PERCENT ISOKINETIC | 118.984 | 92.145 |
| GRAIN LOADING, GR/DSCF | 0.00000 | 0.00000 |
| GRAIN LOADING, GR/ACF | 0.00000 | 0.00000 |
| EMISSION RATE, LB/HR-STD | 0.00000 | 0.00000 |
| EMISSION RATE, LB/MBTU | | |

3.3 SOURCE ASSESSMENT SAMPLING SYSTEM (SASS) FIELD DATA

ACUREX CORPORATION

Run 1-SASSAcurex Project No. 307735.71Field Dates 8-24/26-83Plant SUPPLY - NEMSampling Location Boiler No - CWSSampling Date 8-25-83FIELD CREWCrew Chief: Bruce C. DrRor, C, - C₆, N₂OTesting Engineer: 1 Pete KAUFMAN - SASS2 MARTH M. MURRAY, VOST, M-SEngr. Technician: 1 SHERMAN A. SMITH, GM2 KENT BREWSTER, PRNG

3

Lab Technician: 1 Pete KAUFMAN2 Bruce C. DrRorProcess Engineer: 1 LARRY WATERLAND

2

FIELD SAMPLE REFERENCE NUMBERS:

| | |
|--------|--------|
| 900204 | 900221 |
| 900213 | 900230 |
| 900212 | 900226 |
| 900211 | 900227 |
| 900207 | 900216 |
| 900208 | 900217 |
| 900205 | 900218 |
| 900206 | 900219 |
| 900228 | 900220 |

SASS OPERATION WORKSHEET

Date - 8/25/83

Performed by K. J. Mavinkar

Date - 8/25/83

Sample Location _____

Test No. SASS 1

| | CO_2 | O_2 |
|--------------------------------------|-------------------|--------------|
| Stack Gas Composition | 0.44 | 17.7 |
| Water Vapor in Gas Stream | B_{w0} | 0.05 |
| Static Pressure in. H ₂ O | P_{st} | - .5 |
| Barometric Pressure in. Hg. | P_{bar} | 27.98 |
| Stack Temperature °F | T_s | 545 |
| Square Root ΔP | $\sqrt{\Delta P}$ | 1367 |
| D _c Coefficient | C_p | .83 |

$$M_d = 0.44(\% \text{CO}_2) + 0.32(\% \text{O}_2) + 0.28(\% \text{N}_2 + \% \text{CO}) =$$

$$M_s = M_d (1 - B_{\text{w0}}) + 18(B_{\text{w0}}) =$$

$$\bar{V} = 2.307 + \left(\frac{P_s}{3.6} \right)$$

$$C = 25.40 (C_p) \sqrt{\frac{T_s + 460}{M_s P_s}} =$$

Ideal Nozzle Size

$$N_d = 0.831 \sqrt{\frac{T_s + 460}{P_s V_s}} = 0.75$$

$$\Delta F = (1.588 \times 10^{-3}) \left[\frac{-m - 460}{P_m} \right] \left[\frac{(1 - B_{\text{w0}})}{J D_o^2} \right]^2$$

FIELD DATA

Page 1 of 3

Plant DUST

Date 8/25/83

Sample Location Boiler #1

Sample Type SASS

Run Number 1

Operator KARL WERNER

Ambient Temperature ~95

Barometric Pressure 29.98

Static Pressure, (H₂O) ~5Filter Number(s) 254, 351,
350Leak Check: Initial at 10" Hg, .041 CFM
Final at 10" Hg, .044 CFM

ORG & IMP.

20" .032
.031 .013

Pitot Leak Check: O.K.

Impinger Volumes

| Initial | Final | Net Gain |
|---------|-------|------------|
| STDS | 9715 | 4.11 60 ml |
| STDS | | 1" sec |
| STDS | 18785 | 1.00 78 ml |
| | | 1" sec |
| | | |
| | | |
| | | |
| | | |

Probe Length and Type 3 ft 5.5

Nozzle Size & I.D. P-44 0.744

Pitot Coefficient & I.D. - .71

Assumed Moisture 6%

Molecular Weight, Dry, (M_d)

Meter Box Number 16

Meter Coefficient 3.642

 α Factor .997

K = N/A

 $K(N_d)^4 = \frac{1}{(T_m)} \times \frac{1}{(T_s)} = N/A$ $4H = K(N_d)^4 \left(\frac{T_m}{T_s} \right) (P)$

Silica Gel

| | | |
|-------|--------|-------|
| 803.3 | 1033.1 | 227.8 |
| 851.0 | 1144.1 | 333.1 |

SASS Condensate

59± TH 1

Total Volume

2734.1

SSD .35

| Traverse Point Number | Sampling Time, min | Clock Time (24-hr) Clock | Gas Meter Reading (V _m), ft ³ | Velocity Head (ΔP _s), in. H ₂ O | Orifice Pressure Differential (ΔH), in. H ₂ O | | Temperature of | | | | | | Pump Vacuum in. Hg | Avg. ΔP | |
|-----------------------|--------------------|--------------------------|--|--|--|--------|----------------|-------|----------|----------------|------|-----|--------------------|---------|------|
| | | | | | Desired | Actual | Stack | Probe | Impinger | Organic Module | Oven | In | Out | | |
| 1015 | 6 | Init. 160.652 | | | | | | | | | | | | | |
| | 10 | 200.17 | .26 | .22 | 2.1 | 570 | 395 | | | 63 | 401 | 102 | 96 | 17 | .510 |
| | 20 | 238.43 | .26 | .22 | 2.1 | 573 | 404 | | | 64 | 402 | 105 | 97 | 17 | .510 |
| | 30 | 277.31 | .27 | .22 | 2.1 | 575 | 407 | | | 62 | 402 | 110 | 100 | 18 | .520 |
| | 40 | 316.40 | .26 | .23 | 2.0 | 572 | 397 | | | 62 | 401 | 112 | 102 | 18 | .510 |
| | 50 | 355.60 | .26 | .22 | 2.2 | 574 | 405 | | | 67 | 404 | 116 | 109 | 19 | .510 |
| | 60 | 399.5* | .26 | .22 | 2.2 | 576 | 401 | | | 67 | 404 | 117 | 107 | 20 | .510 |
| | 70 | 435.10 | .26 | .22 | 2.2 | 578 | 411 | | | 63 | 405 | 116 | 108 | 19 | .510 |
| | 80 | 474.15 | .26 | .22 | 2.1 | 578 | 412 | | | 62 | 406 | 116 | 108 | 20 | .510 |
| | 90 | 514.317 | .28 | .24 | 2.1 | 578 | 402 | | | 64 | 405 | 117 | 108 | 20 | .510 |

* indicates no reading or 6.1

76025-1 Rev 1

Comments: Stop at min RH for cleaning filters

3-24

| Traverse Point Number | Clock Time (24-hr) Clock | Sampling Time, min | Gas Meter Reading (Vm), ft ³ | Velocity Head (ΔP _s), in. H ₂ O | Orifice Pressure Differential (ΔH), in. H ₂ O | | Temperature °F | | | | | Pump Vacuum in. Hg | Avg. ΔP | |
|-----------------------|-----------------------------|--------------------|---|--|--|--------|----------------|-------|----------|----------------|------|--------------------|---------|----|
| | | | | | Desired | Actual | Stack | Probe | Impinger | Organic Module | Oven | In | | |
| | | | | | | | | | | | | | | |
| 1215 | 90 | Init. | 514.817 | | | | | | | | | | | |
| | 105 | | 552.05 | .26 | 2.2 | 2.2 | 579 | 399 | | 62 | 363 | 106 | 105 | 16 |
| | 110 | | 592.00 | .26 | 2.2 | 2.2 | 581 | 405 | | 63 | 397 | 111 | 106 | 17 |
| | 120 | | 631.9 | .27 | 2.2 | 2.1 | 582 | 416 | | 63 | 402 | 118 | 108 | 17 |
| | 130 | | — | .26 | 2.2 | 2.2 | 582 | 404 | | 65 | 412 | 118 | 110 | 19 |
| | 140 | | 716.5 | .26 | 2.3 | 2.2 | 584 | 403 | | 63 | 404 | 120 | 111 | 19 |
| | 150 | | 754.0 | .27 | 2.3 | 2.2 | 585 | 409 | | 65 | 403 | 119 | 111 | 19 |
| | 160 | | 794.23 | .24 | 2.3 | 2.2 | 585 | 407 | | 64 | 404 | 118 | 111 | 19 |
| | 170 | | 834.05 | .27 | 2.3 | 2.1 | 586 | 401 | | 64 | 412 | 118 | 111 | 20 |
| stop | 180 | | 873.625 | .29 | 2.3 | 2.0 | 585 | 405 | | 62 | 402 | 115 | 111 | 20 |
| | 190 | | 873.625 | -- | -- | -- | -- | -- | | -- | -- | -- | -- | -- |
| | 190 | | 912.7 | .26 | 2.2 | 2.2 | 583 | 404 | | 64 | 380 | 105 | 106 | 17 |
| | 200 | | 953.31 | .25 | 2.2 | 2.2 | 568 | 394 | | 63 | 397 | 111 | 107 | 18 |
| | 210 | | 993.9 | .26 | 2.2 | 2.2 | 571 | 401 | | 64 | 410 | 117 | 111 | 19 |
| | 220 | | 1031.3 | .25 | 2.3 | 2.0 | 571 | 411 | | 64 | 450 | 107 | 113 | 19 |
| | 230 | | 74.0 | .26 | 2.3 | 2.1 | 570 | 413 | | 64 | 432 | 120 | 112 | 19 |
| | 240 | | 115.2 | .27 | 2.3 | 2.1 | 570 | 413 | 6 | 64 | 454 | 122 | 114 | 19 |
| | 250 | | 153.5 | .27 | 2.2 | 2.0 | 577 | 423 | | 65 | 402 | 123 | 114 | 20 |

Run No. SASS 1

Date 8/25/83

Sampling Location Boiler #1

Comments: Min LED stop to discharge filter + sil. w. gel and allow plant to blow out

Run No. 515

Date 4/27/23

Sampling Location Pelican

Comments:

$$\begin{array}{r} 3241 \\ \hline 38 \\ - 3043 \\ \hline 78 \end{array}$$

ISOKINETIC PERFORMANCE WORKSHEET & PARTICULATE CALCULATIONS

 Plant Dow T. Memphis, TN

 Performed by D. R. B.

 Date 3-25-83

 Sample Location Boiler Room

 Test No./Type - 2423

| | | |
|---|-----------|----------|
| Barometric Pressure (in. Hg) | P_b | 27.75 |
| Meter volume (std), $17.64 \left(\frac{V_m}{\alpha} \right) \left(\frac{P_b + \frac{\Delta H}{13.6}}{T_m + 460} \right)$ $17.64 \left(\frac{7.933}{(0.917)} \right) \left(\frac{(29.98) + \frac{(2.13)}{13.6}}{(112.0) + 460} \right)$ | V_m std | 1032.747 |
| Volume of liquid collected (grams) | V_l_c | 2734.7 |
| Volume of liquid at standard condition (scf) $V_l_c \times 0.04707$ | V_w std | 133.146 |
| Stack gas proportion of water vapor $\frac{V_w \text{ std}}{V_w \text{ std} + V_m \text{ std}}, \quad \frac{(\underline{\hspace{2cm}})}{(\underline{\hspace{2cm}}) + (\underline{\hspace{2cm}})}$ | B_{wo} | .118 |
| Molecular weight, stack gas dry (lb/lb-mole) $(\% CO_2 \times 0.44) + (\% O_2 \times 0.32) + (\% N_2 + \% CO \times 0.28)$ $(\underline{9.5} \times 0.44) + (\underline{7.0} \times 0.32) + (\underline{63.5} + \underline{\hspace{2cm}} \times 0.28)$ | M_d | 29.8 |
| Molecular weight, stack gas wet (lb/lb-mole) $M_d(1-B_{wo}) + 18(B_{wo}), \quad \underline{29.8}(1-\underline{.118}) + 18(\underline{.118})$ | M_s | 29.41 |
| Absolute stack pressure (in. Hg) $P_b + \frac{P_{stack} \text{ (in. H}_2\text{O)}}{13.6}, \quad (29.79) + \frac{(+C.S.)}{13.6}$ | P_s | 29.94 |

7602/5/81/Rev 1

| | | |
|---|---------------------|---------|
| Temperature stack gas, average ($^{\circ}$ F) | T_s | 212.1 |
| Stack velocity (fps) 85.49 (C_p) ($\sqrt{\Delta P_s \text{ avg}}$) | $v_s(\text{avg})$ | 38.10 |
| $85.49 (\underline{C_p})(\sqrt{\frac{T_s \text{ avg} + 460}{P_s \text{ avg} M_s}})$ $85.49 (\underline{C_p})(\underline{\frac{(T_s \text{ avg} + 460)}{(P_s \text{ avg})(M_s)}})$ | | |
| Total sample time (minutes) | θ | ~ 12 |
| Nozzle diameter, actual (inches) | N_d | 2.74 |
| Percent isokinetic (%) 17.33 ($T_s + 460$) ($V_w \text{ std} + V_m \text{ std}$) | %I | 118.754 |
| $\frac{\theta \ v_s \ p_s \ N_d^2}{17.33 ((\underline{v_s} + 460) ((\underline{V_w \text{ std}}) + (\underline{V_m \text{ std}})))}$ $\frac{(\underline{\theta})(\underline{v_s})(\underline{p_s})(\underline{N_d^2})}{(\underline{17.33})(\underline{(\underline{v_s} + 460)})(\underline{((\underline{V_w \text{ std}}) + (\underline{V_m \text{ std}}))})^2}$ | | |
| Area of stack (ft^2) $\pi = 3.1416$ $\pi r^2 \div 144, \quad \pi (\underline{r})^2 \div 144$ | A_s | 19.097 |
| Stack gas volume at standard conditions (dscfm) 60 ($1 - B_{wo}$) $V_s \text{ avg } A_s \left(\frac{528}{T_s \text{ avg} + 460} \right) \left(\frac{P_s}{29.92} \right)$ | $AcFm$ | 43,666 |
| $60 (1 - \underline{B_{wo}})(\underline{V_s \text{ avg}})(\underline{A_s}) \left(\frac{528}{\underline{T_s \text{ avg} + 460}} \right) \left(\frac{(\underline{P_s})}{(\underline{29.92})} \right)$ | Q_s | 19,627 |
| Particulate matter concentration, dry (gr/dscf) 15.432 $\frac{M_p \text{ (grams)}}{V_m \text{ std}}$, $15.432 \frac{(\underline{M_p \text{ (grams)}})}{(\underline{V_m \text{ std}})}$ | $C_s \text{ (std)}$ | |
| Emission rate of particulate matter (lb/hr) 0.00857 (Q_s) $C_s \text{ (std)}$, 0.00857 ($\underline{Q_s}$) ($\underline{C_s \text{ (std)}}$) | E_p | |

7602/5/81/Rev 1

3.4 VOLATILE ORGANIC SAMPLING TRAIN (VOST) FIELD DATA

ACUREX CORPORATION

Run 1-VOS-Acurex Project No. 207725.71Field Dates 8-24/26-83Plant DURON - MEMPHIS, TNSampling Location COOLER 1 to 1Sampling Date 8-25-83FIELD CREW

Crew Chief: Bruc C. DeRo
Testing Engineer: 1 Platt M. Murray
2 _____
Engr. Technician: 1 _____
2 _____
3 _____
Lab Technician: 1 _____
2 _____
Process Engineer: 1 _____
2 _____

FIELD SAMPLE REFERENCE NUMBERS:

| | | |
|----------------|---------------|---------------|
| TRIP Blank | 819612 | 819608 |
| TRIP Blank | 819613 | 819609 |
| | 819610 | 819601 |
| | 819611 | 819600 |
| Field BLANK | 819598 | |
| Field BLANK | 819599 | |

Volatile Organic Sampling Sampling Train (VOST) Data Sheet

Plant DYER'S MIMOSA, TN

Project No. 51155-11

Date 5-25-85

Operator J. A. L. S. G. C.

Sample Location Bottom of the river

Barometric Pressure (in. Hg) 14.1

Run No.)

Ambient Temperature ($^{\circ}$ F) _____

Notes: TEMPERATURE (°F) at time of trap use

SET A DRIVE 45° -10P -

JET 13 10 S * 15 S

卷之二十一 113

15

3.5 C₁ TO C₆ HYDROCARBON ANALYSIS DATA

GAS CHROMAT APH OPERATING CONDITIONS AND FIELD LOG

Client EPA/CMEA, Location DUPONT-MEMPHIS, Job No. 307725.71

07:54:34
 Injection Date 8-25-83, Time 07:48:17, Instrument ID VARIAN 940
 Recorder/Printout Reference No. 37+58, Recorder ID 3390A/HP
 Purpose of Run CALIBRATION STD.

Sample Description He 66 cc/m Air 66 cc/m H₂ 20 cc/m

GC CONDITIONS

Amount Injected 1cc, Inj. Port or Sample Loop Used JNT
 Detector Used: FID X, ECD , FPD , TCD (Current)
 Detector Attenuation 10⁻¹¹, Amplifier or Range
 Column: Liquid Phase , Solid Phase POROPACK P,
 Length 10', O.D. 1/8", I.D. , Material SS
 Temperature: Injector 220°, Oven 160°, Detector 220°
 Temperature Program N/A

Analysis: Methane 16.8 Ethane 16.3 Propane 15.5 n-Butane 15.3 n-Pentane 16.7 n-Hexane 15.1 BAL N₂ $\pm 5\%$

SAMPLE RUN

Sampling Method CYL ND AAL 7244 (E15f1) SCOTT SPEC.

| RT | Area (Ave. of 2 runs) | Peak Height | Amount (ppm) | Component |
|------|-----------------------------|-------------|--------------|----------------|
| .04 | N/A | | N/A | AIR |
| .33 | 38536 | .0005322435 | 16.8 | C ₁ |
| .52 | 10425 | .0014225296 | 15.3 | C ₂ |
| .84 | 11862 | .0012618541 | 16.3 | C ₃ |
| 1.63 | 15355 | .0010171453 | 16.7 | C ₄ |
| 2.75 | 19896 | .000737779 | 15.5 | C ₅ |
| 8.23 | 23637 | .0006361913 | 15.1 | C ₆ |

Name of Operator Brian C. Dabbs, Date 8-25 1983

GAS CHROMAT APH OPERATING CONDITIONS AND FIELD LOG

Client EPA/CMEA, Location DuPont-Memphis, Job No. 207735.71

Injection Date 8-25-83, Time 11:25:27, Instrument ID VARIAN 740
 Recorder/Printout Reference No. 44, Recorder ID 3390A/HP
 Purpose of Run SAMPLE NO 900199 C-C ANALYSIS

Sample Description TIME 1055 STACK TEMP 570°F
SAMPLE ROOM TEMP @ 380°F

GC CONDITIONS

Amount Injected 1cc, Inj. Port or Sample Loop Used INJ
 Detector Used: FID X, ECD , FPD , TCD (Current)
 Detector Attenuation 10^-1, Amplifier or Range
 Column: Liquid Phase , Solid Phase POROPACK R,
 Length 10', O.D. 1/8", I.D. , Material SS
 Temperature: Injector 220°C, Oven 160°C, Detector 220°C
 Temperature Program N/A

SAMPLE RUN

Sampling Method GRAB

| RT | Area | Peak Height | Amount () | Component |
|------|-------|-------------|------------|----------------|
| 0.03 | 2620 | | | Air |
| 0.32 | 22411 | | | C ₁ |
| 0.42 | 5422 | | | C ₂ |
| 0.98 | 2035 | | | C ₃ |
| 1.54 | 582 | | | C ₄ |
| | | | | |
| | | | | |
| | | | | |

Name of Operator Roger C. Dyer, Date 8-25 1983

GAS CHROMAT APH OPERATING CONDITIONS AND FIELD LOG

Client EPA/C.N.E.A., Location Airport-Memphis, Job No. 307735.71

Injection Date 8-25-83, Time 11:43:57, Instrument ID 1A101W940
 Recorder/Printout Reference No. 45, Recorder ID 3390A/HP
 Purpose of Run Sample N. 900199 C.-C₆ Analysis

Sample Description Time 1055 STACK TEMP 570°F
Sample Room TEMP @ 382°F

GC CONDITIONS

Amount Injected 1cc, Inj. Port or Sample Loop Used inj
 Detector Used: FID X, ECD , FPD , TCD (Current)
 Detector Attenuation 10⁻¹¹, Amplifier or Range
 Column: Liquid Phase , Solid Phase Poropak R.
 Length , O.D. , I.D. , Material
 Temperature: Injector 220 °C, Oven 160 °C, Detector 220 °C
 Temperature Program u/a

SAMPLE RUN

Sampling Method Gas

| RT | Area | Peak Height | Amount () | Component |
|------|-------|-------------|------------|----------------|
| 0.04 | 4570 | | | A ₁ |
| 0.34 | 20250 | | | C ₁ |
| 1.04 | 2019 | | | C ₃ |
| 1.64 | 924 | | | C ₄ |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Name of Operator Bruce C. Dara, Date 8-25 1983

GAS CHROMAT APH OPERATING CONDITIONS AND FIELD LOG

Client EPA/CNEA, Location DUPONT-MEMPHIS, Job No. 307735.71

Injection Date 8-25-83, Time 11:55:46, Instrument ID VARIAN 940
 Recorder/Printout Reference No. 46, Recorder ID 3390A/HP
 Purpose of Run Sample No 900199 C₁-C₆ Analysis

Sample Description TIME 1055 STACK TEMP 570°F
SAMPLE BOTTLED @ 295°F

GC CONDITIONS

Amount Injected 1.00, Inj. Port or Sample Loop Used INJ
 Detector Used: FID X, ECD , FPD , TCD (Current)
 Detector Attenuation 10⁻¹¹, Amplifier or Range
 Column: Liquid Phase , Solid Phase POROPAC R,
 Length 10', O.D. 1/8", I.D. , Material SS
 Temperature: Injector 320°C, Oven 160°C, Detector 220°C
 Temperature Program N/A

SAMPLE RUN

Sampling Method Cegas

| RT | Area | Peak Height | Amount () | Component |
|------|-------|-------------|------------|----------------|
| 0.03 | 3219 | | | A ₁ |
| 0.34 | 20009 | | | C ₁ |
| 1.04 | 1957 | | | C ₃ |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Name of Operator Roger C. Dakin, Date 8-25- 1983

GAS CHROMAT APH OPERATING CONDITIONS AND FIELD LOG

Client EPA/CMAA, Location DuPont-Memphis Job No. SO773571

Injection Date 8-, Time 12:09:50, Instrument ID VARIAN 940
 Recorder/Printout Reference No. 48, Recorder ID 3390A/H.A.
 Purpose of Run Catalyst Standard n-C₆

Sample Description in-allcane

GC CONDITIONS

Amount Injected 1 cc, Inj. Port or Sample Loop Used INJ
 Detector Used: FID X, ECD , FPD , TCD (Current)
 Detector Attenuation 10^-1, Amplifier or Range
 Column: Liquid Phase , Solid Phase PORAPAK R,
 Length 10', O.D. 1/8, I.D. , Material
 Temperature: Injector 220 °C, Oven 160 °C, Detector 220 °C
 Temperature Program N/A

SAMPLE RUN

Sampling Method CAL GAS A&L 7244

| RT | Area | Peak Height | Amount () | Component |
|------|-------|-------------|------------|----------------|
| 0.03 | 3324 | | | N ₂ |
| 0.35 | 35195 | | | C ₁ |
| 0.56 | 12600 | | | C ₂ |
| 0.93 | 14730 | | | C ₃ |
| 1.86 | 15045 | | | C ₄ |
| 4.15 | 24736 | | | C ₅ |
| 9.70 | 26515 | | | C ₆ |

Name of Operator Bruce C. Dohle, Date 8-25 1983

GAS CHROMATAPH OPERATING CONDITIONS AND FIELD LOG

Client EPA/CMEA, Location DUPONT-MEMPHIS, Job No. 307735.71

Injection Date 8-25-83, Time 14:44:15, Instrument ID VARIAN 740
 Recorder/Printout Reference No. 51, Recorder ID 3390A/HP
 Purpose of Run Sample 900201 C-C₆ Analysis

Sample Description _____

GC CONDITIONS

Amount Injected 1 cc, Inj. Port or Sample Loop Used int
 Detector Used: FID X, ECD , FPD , TCD (Current)
 Detector Attenuation 10⁻¹, Amplifier or Range
 Column: Liquid Phase , Solid Phase ,
 Length 10', O.D. 1/8", I.D. , Material SS
 Temperature: Injector 220 °C, Oven 160 °C, Detector 320 °C
 Temperature Program

SAMPLE RUN

Sampling Method Grav @ 1435

| RT | Area | Peak Height | Amount () | Component |
|------|-------|-------------|------------|-----------------|
| 0.03 | 1370 | | | A _{ii} |
| 0.32 | 16122 | | | C ₁ |
| 0.43 | 3561 | | | C ₂ |
| 1.02 | 1610 | | | C ₃ |
| | | | | |
| | | | | |
| | | | | |

Name of Operator Bruce G. Dales, Date 8-25-83

GAS CHROMAT APH OPERATING CONDITIONS AND FIELD LOG

Client FAA/CMEA, Location DuPont-Memphis, Job No. 307735.71

Injection Date 8-25-83, Time 17:59:40, Instrument ID VARIAN 940
 Recorder/Printout Reference No. 52, Recorder ID SS70A/HP
 Purpose of Run Samples No 900201

Sample Description _____

GC CONDITIONS

Amount Injected 1cc, Inj. Port or Sample Loop Used INJ
 Detector Used: FID X, ECD , FPD , TCD (Current)
 Detector Attenuation 10^-1, Amplifier or Range _____
 Column: Liquid Phase _____, Solid Phase POROPACK R,
 Length 10', O.D. 1/8", I.D. , Material SS
 Temperature: Injector 220 °C, Oven 160 °C, Detector 220 °C
 Temperature Program N/A

SAMPLE RUN

Sampling Method GRAB @ 1235

| RT | Area | Peak Height | Amount () | Component |
|-------|-------|-------------|------------|----------------|
| 0.041 | 3943 | | | A ₁ |
| 0.34 | 16219 | | | C ₁ |
| 0.45 | 3880 | | | C ₂ |
| 1.01 | 2751 | | | C ₃ |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Name of Operator Bruce C. Dahm, Date 8-25 1983

GAS CHROMAT APH OPERATING CONDITIONS AND FIELD LOG

Client EPA/C.N.F.A., Location DURANT, M.E.N., Job No. 307735.71

Injection Date 8-25-83, Time 15:22:10, Instrument ID VARIAN 940
 Recorder/Printout Reference No. 53, Recorder ID 3390A/H.P.
 Purpose of Run SAMPLE 500201 C-C₆ ANALYSIS

Sample Description _____

GC CONDITIONS

Amount Injected 1.0, Inj. Port or Sample Loop Used INJ
 Detector Used: FID X, ECD , FPD , TCD (Current)
 Detector Attenuation 10⁻¹, Amplifier or Range
 Column: Liquid Phase , Solid Phase POROMATIC R,
 Length 10', O.D. 1/8", I.D. , Material SS
 Temperature: Injector 220 °C, Oven 160 °C, Detector 220 °C
 Temperature Program

SAMPLE RUN

Sampling Method G.R.A.B @ 1435

| RT | Area | Peak Height | Amount () | Component |
|------|-------|-------------|------------|----------------|
| 0.03 | 2832 | | | A ₁ |
| 0.34 | 16669 | | | C ₁ |
| 0.44 | 3738 | | | C ₂ |
| 0.95 | 7256 | | | C ₃ |
| | | | | |
| | | | | |
| | | | | |

Name of Operator Bruce Daskalos, Date 8-25 1983

GAS CHROMATAPH OPERATING CONDITIONS AND FIELD LOG

Client EPA/CMCA, Location DUPONT-MEMPHIS, Job No. 307785.71

Injection Date 8-25-83, Time 15:59:52, Instrument ID VACRIM 940
 Recorder/Printout Reference No. 55, Recorder ID 3390A/H/P
 Purpose of Run C₁-C₆ Analysis

Sample Description Sample 900202

GC CONDITIONS

Amount Injected 1 cc, Inj. Port or Sample Loop Used IN
 Detector Used: FID X, ECD , FPD , TCD (Current)
 Detector Attenuation 10^-1, Amplifier or Range
 Column: Liquid Phase , Solid Phase POROPAC R,
 Length 10', O.D. 1/8", I.D. , Material SS
 Temperature: Injector 220 °C, Oven 160 °C, Detector 220 °C
 Temperature Program

SAMPLE RUN

Sampling Method GRAB @ 1555

| RT | Area | Peak Height | Amount () | Component |
|------|-------|-------------|------------|----------------|
| 0.03 | 2651 | | | A ₁ |
| 0.33 | 15909 | | | C ₁ |
| 0.44 | 3603 | | | C ₂ |
| 1.01 | 2503 | | | C ₃ |
| | | | | |
| | | | | |
| | | | | |

Name of Operator Bruce C. Dyer, Date 8-25-1983

GAS CHROMAT APH OPERATING CONDITIONS AND FIELD LOG

Client EPA/CMEA, Location DUPONT-MEN, Job No. 367735.71

Injection Date 8-25-82, Time 16:21:26, Instrument ID VARIAN 740
 Recorder/Printout Reference No. 56, Recorder ID 3340A/HP
 Purpose of Run C₁-C₆ ANALYSIS

Sample Description Sample 900201

GC CONDITIONS

Amount Injected _____, Inj. Port or Sample Loop Used _____
 Detector Used: FID __, ECD __, FPD __, TCD __ (Current __)
 Detector Attenuation 10^-11, Amplifier or Range _____
 Column: Liquid Phase _____, Solid Phase POROPACK R,
 Length 10', O.D. 1/8", I.D. _____, Material _____
 Temperature: Injector 220 °C, Oven 160 °C, Detector 220 °C
 Temperature Program _____

SAMPLE RUN

Sampling Method GEMB Q 1555

| RT | Area | Peak Height | Amount () | Component |
|-------|-------|-------------|------------|----------------|
| 0.04 | 1448 | | | Air |
| 0.33 | 16034 | | | C ₁ |
| 0.44 | 3685 | | | C ₂ |
| 1.03 | 1766 | | | C ₃ |
| 13.08 | 3121 | | | C ₆ |
| | | | | |
| | | | | |

Name of Operator Brian C. Doh, Date 8-25 1983

GAS CHROMAT APH OPERATING CONDITIONS AND FIELD LOG

Client EPA/CMEA, Location DUPONT-MCM, Job No. 367735.71Injection Date 8-25-83, Time 17:14:05, Instrument ID VARIAN 940Recorder/Printout Reference No. 58, Recorder ID _____Purpose of Run C₁-C₄ ANALYSISSample Description SAMPLE 900225

GC CONDITIONS

Amount Injected 1 cc, Inj. Port or Sample Loop Used in-jDetector Used: FID x, ECD , FPD , TCD (Current)Detector Attenuation 10^-11, Amplifier or Range _____Column: Liquid Phase , Solid Phase POROPAK R,Length 10', O.D. 1/8", I.D. , Material SSTemperature: Injector 220 °C, Oven 180 °C, Detector 220 °CTemperature Program n/a

SAMPLE RUN

Sampling Method GROUT @ 1720

| RT | Area | Peak Height | Amount () | Component |
|------|------|-------------|------------|----------------|
| 0.03 | 1036 | | | Air |
| 0.31 | 8125 | | | C ₁ |
| 0.43 | 773 | | | C ₂ |
| 0.84 | 9171 | | | C ₃ |
| 1.90 | 1445 | | | C ₄ |
| | | | | |

Name of Operator Bruce C. DePree, Date 8-25 1983

GAS CHROMAT APH OPERATING CONDITIONS AND FIELD LOG

Client EPA/CMEA, Location DuPont, Mem., Job No. 307735.71

Injection Date 8-25-83, Time 17:31:16, Instrument ID VARIAN 940
 Recorder/Printout Reference No. 66, Recorder ID 3370A/HP
 Purpose of Run C₁-C₆ analysis

Sample Description 900225

GC CONDITIONS

Amount Injected 1cc, Inj. Port or Sample Loop Used inj
 Detector Used: FID X, ECD , FPD , TCD (Current)
 Detector Attenuation 10^-11, Amplifier or Range
 Column: Liquid Phase , Solid Phase PrePak R,
 Length 10', O.D. 1/8", I.D. , Material SS
 Temperature: Injector 220 °C, Oven 160 °C, Detector 220 °C
 Temperature Program N/A

SAMPLE RUN

Sampling Method Grav @ 1720

| RT | Area | Peak Height | Amount () | Component |
|------|------|-------------|------------|----------------|
| 0.01 | 447 | | | Ary |
| 0.32 | 7738 | | | C ₁ |
| 0.43 | 1511 | | | C ₂ |
| 1.19 | 3544 | | | C ₃ |
| | | | | |
| | | | | |
| | | | | |

Name of Operator Bruce G. Dufresne, Date 8-25-83 19:52

GAS CHROMAT APH OPERATING CONDITIONS AND FIELD LOG

Client EPA/CMEA, Location DUPONT-MEMPHIS, Job No. 307735.71

Injection Date 8-25-83, Time 17:42:21, Instrument ID VARIAN 940
 Recorder/Printout Reference No. 61, Recorder ID 3390A/HP
 Purpose of Run C₁-C₆ Analysis

Sample Description 900 225

GC CONDITIONS

Amount Injected 1cc, Inj. Port or Sample Loop Used INJ
 Detector Used: FID X, ECD , FPD , TCD (Current)
 Detector Attenuation 10⁻¹¹, Amplifier or Range
 Column: Liquid Phase , Solid Phase POROPAK R.
 Length 10', O.D. 1/8", I.D. , Material SS
 Temperature: Injector 220 °C, Oven 160 °C, Detector 220 °C
 Temperature Program N/A

SAMPLE RUN

Sampling Method GRAB @ 1720

| RT | Area | Peak Height | Amount () | Component |
|------|------|-------------|------------|----------------|
| 0.03 | 412 | | | Air |
| 0.31 | 8043 | | | C ₁ |
| 0.43 | 541 | | | C ₂ |
| 1.23 | 1463 | | | C ₃ |
| | | | | |
| | | | | |
| | | | | |

Name of Operator Bruce C. Dabbs, Date 8-25-83 19 83

GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client EPA/CMEA, Location WYOMING-MEM, Job No. 30795.71

Injection Date 8-25-83, Time 18:19:23, Instrument ID VARIAN 940
 Recorder/Printout Reference No. 65+70, Recorder ID 3370A/HP
 Purpose of Run SAMPLE BOMB BLANK - C, -C, ANALYSIS

Sample Description N₂

GC CONDITIONS

Amount Injected 1cc, Inj. Port or Sample Loop Used inj.
 Detector Used: FID X, ECD , FPD , TCD (Current)
 Detector Attenuation 10⁻¹¹, Amplifier or Range
 Column: Liquid Phase , Solid Phase POROPAK R,
 Length 10', O.D. 1/8", I.D. , Material SS
 Temperature: Injector 220 °C, Oven 160 °C, Detector 220 °C
 Temperature Program N/A.

SAMPLE RUN

Sampling Method PURGE SAMPLE BOMB IN N₂

| RT | Area (Average of 2 samples) | Peak Height | Amount () | Component |
|------|-----------------------------------|-------------|------------|----------------|
| 0.05 | 351 | | | N ₂ |
| 0.32 | 16408 | | | C ₁ |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Name of Operator Bruce C. DePew, Date 8-25 1983

GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client EPA/CMEA, Location DUPONT-MEMPHIS, Job No. 307735.71

Injection Date 8-25-83, Time 19:10:04, Instrument ID VARIAN 940
 Recorder/Printout Reference No. 74 + 73, Recorder ID 3390A/HP
 Purpose of Run CALIBRATION STATION

Sample Description SCOTT CYL N. AAL-7244

GC CONDITIONS

Amount Injected 1cc, Inj. Port or Sample Loop Used IN-1
 Detector Used: FID x, ECD , FPD , TCD (Current)
 Detector Attenuation 10^-11, Amplifier or Range
 Column: Liquid Phase , Solid Phase POROPACK R.
 Length 10', O.D. 1/8", I.D. , Material SS
 Temperature: Injector 220 °C, Oven 160 °C, Detector 220 °C
 Temperature Program N/A

SAMPLE RUN

Sampling Method AAL 7244 SCOTT

| RT | Area (Aver. of) | Peak Height ppm/meter | Amount (ppm) ± 5% | Component |
|-------|--------------------|--------------------------|----------------------|----------------|
| .05 | 24593 | 0.683×10^{-3} | 16.8 | N_2 |
| .34 | 11089 | 1.300×10^{-3} | 15.3 | C ₁ |
| .55 | 13973 | 1.167×10^{-3} | 16.3 | C ₂ |
| .97 | 17482 | 0.955×10^{-3} | 16.7 | C ₄ |
| 2.1 | 22122 | 0.701×10^{-3} | 15.5 | C ₅ |
| 4.89 | 23832 | 0.634×10^{-3} | 15.1 | C ₆ |
| 12.14 | | | | |

Name of Operator Bruce C. Dahl, Date 8-25 1983

SECTION 4
LABORATORY ANALYSIS RESULTS

- 4.1 Trace Element Analyses
- 4.2 TCO, GRAV, GC/MS, and IR Analyses of SASS Samples
- 4.3 GC/MS Analysis of VOST Traps
- 4.4 Bioassay Analysis Report

4.1 TRACE ELEMENT ANALYSES

COMMERCIAL TESTING & ENGINEERING CO.



Reply to

Instrumental Analysis Division
490 Orchard Street
Golden, CO 80401

December 30, 1983

Phone: 303-278-9521

Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039

Re: IAD #97-N312-116-10
Subcontract #SW59159A
Release #12

Analytical Report

Ten samples were received for analysis on December 14, 1983. These samples were assigned our IAD identification #97-N312-116-10.

Trace element analysis is being performed using spark source mass spectrometry. Reports will be forwarded upon completion of the analysis.

After appropriate preparation of each of the samples, arsenic and antimony were determined using hydride generation atomic absorption spectrophotometry, and mercury was determined using cold vapor flameless atomic absorption spectrophotometry.

The results of these determinations are presented in Table No. I and are reported in parts per million (ppm) on an "as received" basis.

Carbon and hydrogen were determined by an external laboratory in accordance with the procedures of ASTM, Part 05.05, Method D3178.

The results of these determinations are presented in Table No. II and are reported in weight percent (wt. %) on an "as received" basis except sample 900209 which is reported on a dry basis with the moisture at 107°C also reported.



Table No. I
(ppm - As Received)

| <u>Sample ID</u> | <u>Mercury (Hg)</u> | <u>Arsenic (As)</u> | <u>Antimony (Sb)</u> |
|-------------------------------------|---------------------|---------------------|----------------------|
| 1) 900204 DM Filter +1 μ m | 0.08 | xxxx | xxxx |
| 2) 902175 DM Filter Blank | 0.03 | xxxx | xxxx |
| 3) 900217 DM 10 μ m + 3 μ m | 0.08 | xxxx | xxxx |
| 4) 900206 DM XAD-2 | 0.05 | xxxx | xxxx |
| 5) 900205 DM XEAD-2 Blank | 0.02 | xxxx | xxxx |
| 6) 900219 DM Impinger 1 | 0.004 | xxxx | xxxx |
| 7) 900208 DM Impinger 1 Blank | 0.004 | xxxx | xxxx |
| 8) 900209 DM CWS Fuel | 0.02* | xxxx | xxxx |
| 9) 900220 DM Impinger 2 & 3 | <0.0002 | 0.002 | <0.001 |
| 10) 900207 DM Impinger 2 & 3 Blank | 0.003 | 0.007 | 0.003 |

Table No. II
(Wt. % - As Received)

| <u>Sample ID</u> | <u>Carbon</u> | <u>Hydrogen</u> | <u>Moisture</u> |
|-------------------------------------|---------------|-----------------|-----------------|
| 1) 900204 DM Filter + 1 μ m | 13.13 | 0.09 | xxxx |
| 3) 900217 DM 10 μ m + 3 μ m | 42.67 | 0.13 | xxxx |
| 8) 900209 DM CWS Fuel | 82.56* | 5.03* | 74.41 |

*Reported on Dry Basis

If you have any questions concerning these results, please call.

Harold A. Connell
Harold A. Connell
Assistant Lab Manager

Robert L. Taylor 30 Dec 83
Robert L. Taylor, Ph.D., Mngr.
Instrumental Analysis Division



COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

Reply to

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

To: Mr. Christopher Mann
 Acurex Corporation
 555 Clyde Avenue
 Mountain View, CA 94039

Date: February 8, 1984

Subcontract #SW59159A
 P. O. No.: Release #12

Sample No.: 900209 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS IAD No.: 97-N312-116-1C
 DM CWS fuel

CONCENTRATION IN PPM WEIGHT
 Dry Coal Basis

| ELEMENT | CONC. | ELEMENT | CONC. | ELEMENT | CONC. | ELEMENT | CONC. |
|------------|-------|--------------|-------|------------|-------|------------|-------|
| Uranium | 2 | Terbium | | Ruthenium | | Vanadium | 8 |
| Thorium | 4 | Gadolinium | | Molybdenum | 2 | Titanium | MC |
| Bismuth | | Europium | 0.3 | Niobium | 1 | Scandium | 3 |
| Lead | 3 | Samarium | 2 | Zirconium | 6 | Calcium | 270 |
| Thallium | | Neodymium | 2 | Yttrium | 4 | Potassium | MC |
| Mercury | NR | Praseodymium | 0.9 | Strontium | 17 | Chlorine | 610 |
| Gold | | Cerium | 4 | Rubidium | 2 | Sulfur | MC |
| Platinum | | Lanthanum | 6 | Bromine | 8 | Phosphorus | 460 |
| Iridium | | Barium | 23 | Selenium | 8 | Silicon | MC |
| Osmium | | Cesium | | Arsenic | 1 | Aluminum | MC |
| Rhenium | | Iodine | 5 | Germanium | 0.6 | Magnesium | MC |
| Tungsten | | Tellurium | <0.7 | Gallium | 3 | Sodium | MC |
| Tantalum | | Antimony | 2 | Zinc | 6 | Fluorine | NR |
| Hafnium | | Tin | 0.5 | Copper | 8 | Oxygen | NR |
| Lutetium | | Indium | STD | Nickel | 3 | Nitrogen | NR |
| Ytterbium | | Cadmium | | Cobalt | 3 | Carbon | NR |
| Thulium | | Silver | | Iron | MC | Boron | 8 |
| Erbium | | Palladium | | Manganese | 6 | Beryllium | 9 |
| Holmium | | Rhodium | | Chromium | 31 | Lithium | 50 |
| Dysprosium | | | | | | Hydrogen | NR |

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.2 ppm

MC — Major Component > 1000 ppm

INT — Interference

Approved:
4-5

Robert L. Jay Jr.
7 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

Reply to

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

To: Mr. Christopher Mann
 Acurex Corporation
 555 Clyde Avenue
 Mountain View, CA 94039

Date: February 8, 1984

P. O. No.: Subcontract #SW59159A
 Release #12

Sample No.: 900217

DM 10 μm + 3 μm

SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS

IAD No.: 97-N312-116-10

CONCENTRATION IN PPM WEIGHT

| ELEMENT | CONC. | ELEMENT | CONC. | ELEMENT | CONC. | ELEMENT | CONC. |
|------------|-------|--------------|----------|------------|-------|------------|-------|
| Uranium | 7 | Terbium | 0.9 | Ruthenium | | Vanadium | 120 |
| Thorium | 13 | Gadolinium | 4 | Molybdenum | 12 | Titanium | MC |
| Bismuth | | Europium | 1 | Niobium | 18 | Scandium | 20 |
| Lead | 28 | Samarium | 7 | Zirconium | 45 | Calcium | MC |
| Thallium | 0.4 | Neodymium | 12 | Yttrium | 41 | Potassium | MC |
| Mercury | NR | Praseodymium | 8 | Strontium | 250 | Chlorine | 590 |
| Gold | | Cerium | 26 | Rubidium | 18 | Sulfur | MC |
| Platinum | | Lanthanum | 32 | Bromine | 30 | Phosphorus | 600 |
| Iridium | | Barium | 330 | Selenium | 8 | Silicon | MC |
| Osmium | | Cesium | 2 | Arsenic | 14 | Aluminum | MC |
| Rhenium | | Iodine | 7 | Germanium | 5 | Magnesium | MC |
| Tungsten | 0.9 | Tellurium | | Gallium | 41 | Sodium | MC |
| Tantalum | 2 | Antimony | 5 | Zinc | 100 | Fluorine | NR |
| Hafnium | 0.8 | Tin | 2 | Copper | 84 | Oxygen | NR |
| Lutetium | 0.2 | Indium | STD | Nickel | 320 | Nitrogen | NR |
| Ytterbium | 1 | Cadmium | ≤ 1 | Cobalt | 30 | Carbon | NR |
| Thulium | 0.5 | Silver | 1 | Iron | MC | Boron | 20 |
| Erbium | 3 | Palladium | | Manganese | 20 | Beryllium | 87 |
| Holmium | 4 | Rhodium | | Chromium | 180 | Lithium | >440 |
| Dysprosium | 7 | | | | | Hydrogen | NR |

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.1 ppm

MC — Major Component > 1000 ppm

INT — Interference

Approved:

4-6

Robert L. Jaylyn
7 Feb - 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES, 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401 PHONE 303 274-9521

Reply to

To: Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039

Date: February 8, 1924

Subcontract #SW59159A
P. O. No.: Release #12

Analyst: G. Meagher

Sample No.: 900204

Sample No.: 900204 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS IAD No. 97-N312-116-10
DM filter + 1 μm CONCENTRATION IN PPM WEIGHT

| ELEMENT | CONC. | ELEMENT | CONC. | ELEMENT | CONC. | ELEMENT | CONC. |
|------------|-------|--------------|-------|------------|-------|------------|-------|
| Uranium | 75 | Terbium | 4 | Ruthenium | MC | Vanadium | MC |
| Thorium | 91 | Gadolinium | 13 | Molybdenum | 12 | Titanium | MC |
| Bismuth | 16 | Europium | 4 | Niobium | 27 | Scandium | 82 |
| Lead | 310 | Samarium | 22 | Zirconium | 140 | Calcium | MC |
| Thallium | 10 | Neodymium | 32 | Yttrium | 93 | Potassium | MC |
| Mercury | NR | Praseodymium | 25 | Strontium | 680 | Chlorine | 400 |
| Gold | | Cerium | 120 | Rubidium | 46 | Sulfur | MC |
| Platinum | | Lanthanum | 180 | Bromine | 82 | Phosphorus | MC |
| Iridium | | Barium | MC | Selenium | 17 | Silicon | MC |
| Osmium | | Cesium | 7 | Arsenic | 59 | Aluminum | MC |
| Rhenium | | Iodine | 4 | Germanium | 38 | Magnesium | MC |
| Tungsten | 9 | Tellurium | 1 | Gallium | 180 | Sodium | MC |
| Tantalum | 1 | Antimony | 42 | Zinc | 400 | Fluorine | NR |
| Hafnium | 5 | Tin | 15 | Copper | 140 | Oxygen | NR |
| Lutetium | 1 | Indium | STD | Nickel | 770 | Nitrogen | NR |
| Ytterbium | 11 | Cadmium | 3 | Cobalt | 130 | Carbon | NR |
| Thulium | 1 | Silver | 4 | Iron | MC | Boron | 89 |
| Erbium | 8 | Palladium | | Manganese | 43 | Beryllium | 710 |
| Holmium | 10 | Rhodium | | Chromium | 490 | Lithium | >600 |
| Dysprosium | 16 | | | | | Hydrogen | NR |

STD = Internal Standard

NR = Not Reported

All elements not detected < 0.2 ppm

MC - Major Component >1000 ppm

INT = Interference

Approved:

4-7

7 Feb '84

COMMERCIAL TESTING & ENGINEERING CO.

Reply to

GENERAL OFFICES 1919 SOUTH HIGHLAND AVE SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

To: Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039

Date: February 3, 1984

Subcontract No. SW59159A
P. O. No.: Release No. 12

Analyst: G. Meagher

Sample No.: 900205 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS IAD No. 97-N312-116-10
DM XAD-2 Blank CONCENTRATION IN PPM WEIGHT

| ELEMENT | CONC. | ELEMENT | CONC. | ELEMENT | CONC. | ELEMENT | CONC. |
|------------|-------|---|-------|------------|-------|------------|-------|
| Uranium | | Terbium | | Ruthenium | | Vanadium | 0.05 |
| Thorium | | Gadolinium | | Molybdenum | 0.4 | Titanium | 1 |
| Bismuth | | Europium | | Niobium | | Scandium | 0.1 |
| Lead | | Samarium | | Zirconium | <0.05 | Calcium | 10 |
| Thallium | | Neodymium | | Yttrium | | Potassium | 10 |
| Mercury | NR | Praseodymium | | Strontium | 0.05 | Chlorine | 50 |
| Gold | | Cerium | 0.1 | Rubidium | <0.05 | Sulfur | 10 |
| Platinum | *0.3 | Lanthanum | 0.2 | Bromine | 0.1 | Phosphorus | 5 |
| Iridium | | Barium | 0.4 | Selenium | 0.2 | Silicon | 25 |
| Osmium | | Cesium | 0.2 | Arsenic | <0.05 | Aluminum | 1 |
| Rhenium | | Iodine | 0.05 | Germanium | | Magnesium | 5 |
| Tungsten | | Tellurium | | Gallium | 0.1 | Sodium | 25 |
| Tantalum | | Antimony | | Zinc | 3 | Fluorine | =15 |
| Hafnium | | Tin | | Copper | 1 | Oxygen | NR |
| Lutetium | | Indium | STD | Nickel | 35 | Nitrogen | NR |
| Ytterbium | | Cadmium | | Cobalt | 0.1 | Carbon | NR |
| Thulium | | Silver | | Iron | 5 | Boron | 0.1 |
| Erbium | | Palladium | | Manganese | 5 | Beryllium | |
| Holmium | | Rhodium | | Chromium | 15 | Lithium | 0.1 |
| Dysprosium | | *Probable contamination from sample preparation | | | | Hydrogen | NR |

STD - Internal Standard

NR - Not Reported

All elements not detected < 0.05 ppm

MC - Major Component > 500 ppm

INT - Interference

Approved:

4-9

Robert L. Jaylin
7 Feb 84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 AREA CODE 312 953-9300

Reply to

INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN, COLORADO 80401, PHONE: 303 278-9521

To: Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039

Date: February 8, 1984

Analyst: G. Meagher

Subcontract #SW59159A
P. O. No.: Release #12

Sample No.: 900219 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS IAD No.: 97-N312-116-10
DM impinger 1 CONCENTRATION IN $\mu\text{g/mL}$

| ELEMENT | CONC. | ELEMENT | CONC. | ELEMENT | CONC. | ELEMENT | CONC. |
|------------|--------------|--------------|--------------|------------|----------|------------|--------------|
| Uranium | | Terbium | | Ruthenium | | Vanadium | 0.01 |
| Thorium | | Gadolinium | | Molybdenum | 0.2 | Titanium | ≤ 0.009 |
| Bismuth | | Europium | | Niobium | 0.004 | Scandium | <0.001 |
| Lead | 0.1 | Samarium | | Zirconium | 0.002 | Calcium | 0.4 |
| Thallium | | Neodymium | ≤ 0.001 | Yttrium | <0.001 | Potassium | 0.2 |
| Mercury | NR | Praseodymium | | Strontium | 0.003 | Chlorine | 0.9 |
| Gold | | Cerium | <0.001 | Rubidium | <0.001 | Sulfur | MC |
| Platinum | | Lanthanum | | Bromine | 0.03 | Phosphorus | 0.09 |
| Iridium | | Barium | 0.03 | Selenium | 0.06 | Silicon | 2 |
| Osmium | | Cesium | <0.001 | Arsenic | 0.003 | Aluminum | 0.03 |
| Rhenium | | Iodine | 0.01 | Germanium | <0.001 | Magnesium | 0.4 |
| Tungsten | 0.004 | Tellurium | ≤ 0.002 | Gallium | 0.005 | Sodium | MC |
| Tantalum | <0.001 | Antimony | 0.003 | Zinc | 0.7 | Fluorine | NR |
| Hafnium | | Tin | 0.02 | Copper | 1 | Oxygen | NR |
| Lutetium | | Indium | STD | Nickel | 1 | Nitrogen | NR |
| Ytterbium | | Cadmium | 0.003 | Cobalt | 0.04 | Carbon | NR |
| Thulium | | Silver | 0.004 | Iron | MC | Boron | 0.003 |
| Erbium | | Palladium | | Manganese | 0.4 | Beryllium | |
| Holmium | ≤ 0.009 | Rhodium | | Chromium | MC | Lithium | 0.02 |
| Dysprosium | | | | | | Hydrogen | NR |

STD - Internal Standard

NR - Not Reported

All elements not detected $< 0.001 \mu\text{g/mL}$

MC - Major Component $> 10 \mu\text{g/mL}$

INT - Interference

Approved:

4-10

Robert L. Taylor
7 Feb '84

COMMERCIAL TESTING & ENGINEERING CO.

Reply to

GENERAL OFFICES 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD ILLINOIS 60148 AREA CODE 312 953-9300
INSTRUMENTAL ANALYSIS DIVISION, 490 ORCHARD STREET, GOLDEN COLORADO 80401, PHONE 303 278-9521

To: Mr. Christopher Mann
Acurex Corporation
555 Clyde Avenue
Mountain View, CA 94039

Date: February 8, 1984

P. O. No.: Subcontract #SW59159A

Analyst: G. Meagher

Release #12

Sample No.: 900208 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS IAD No.: 97-N312-116-10
DM impinger 1 Blank

CONCENTRATION IN $\mu\text{g/mL}$

| ELEMENT | CONC. | ELEMENT | CONC. | ELEMENT | CONC. | ELEMENT | CONC. |
|------------|-------|----------------|-------|------------|--------|------------|--------|
| Uranium | | Terbium | | Ruthenium | | Vanadium | |
| Thorium | | Gadolinium | | Molybdenum | *0.4 | Titanium | <0.001 |
| Bismuth | | Europium | | Niobium | | Scandium | |
| Lead | | Samarium | | Zirconium | 0.007 | Calcium | 0.08 |
| Thallium | | Neodymium | | Yttrium | | Potassium | 0.04 |
| Mercury | NR | Praseodymium | | Strontium | 0.001 | Chlorine | 0.2 |
| Gold | | Cerium | | Rubidium | | Sulfur | 0.3 |
| Platinum | | Lanthanum | | Bromine | 0.005 | Phosphorus | 0.03 |
| Iridium | | Barium | 0.004 | Selenium | 0.005 | Silicon | 1 |
| Osmium | | Cesium | | Arsenic | <0.001 | Aluminum | 0.006 |
| Rhenium | | Iodine | 0.001 | Germanium | | Magnesium | 0.1 |
| Tungsten | | Tellurium | | Gallium | 0.001 | Sodium | 0.1 |
| Tantalum | | Antimony | | Zinc | 0.01 | Fluorine | NR |
| Hafnium | | Tin | 0.02 | Copper | <0.001 | Oxygen | NR |
| Lutetium | | Indium | STD | Nickel | 0.007 | Nitrogen | NR |
| Ytterbium | | Cadmium | 0.002 | Cobalt | 0.01 | Carbon | NR |
| Thulium | | Silver | | Iron | 0.08 | Boron | 0.002 |
| Erbium | | Palladium | | Manganese | | Beryllium | |
| Holmium | | Rhodium | | Chromium | 0.01 | Lithium | 0.005 |
| Dysprosium | | *Heterogeneous | | | | Hydrogen | NR |

STD — Internal Standard

NR — Not Reported

All elements not detected <0.001 $\mu\text{g/mL}$

MC — Major Component >10 $\mu\text{g/mL}$

INT — Interference

Approved:

4-11

Robert L. Taylor
7 Feb-84

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953 9300

ROBERT L. TAYLOR, Ph.D.
MANAGER
INSTRUMENTAL ANALYSIS DIVISION



PLEASE ADDRESS ALL CORRESPONDENCE TO
490 ORCHARD ST., GOLDEN, CO 80401
OFFICE TEL. (303) 278-9521

Mr. Christopher Mann
Acurex Corporation
P.O. Box 7555
Mountain View, CA 94039

RE: IAD #97-N814-116-05
Subcontract #SW 59159A
Release # 14

Analytical Report

Five samples, previously analyzed for trace elements by spark source mass spectrometry, under our IAD identification #97-N312-116-10, were logged in under our IAD identification #97-N814-116-05 on February 22, 1984.

Fluorine was determined using specific ion electrode methodology. Depending on the sample type and the amount of sample available, Sulfur was determined either turbidimetrically or by X-ray fluorescence spectrometry. The remaining elemental analysis was performed using either atomic absorption/emission spectrophotometry or X-ray fluorescence spectrometry.

The results of these determinations are presented in the following tables. Samples #1, 2 and 5 are reported in micrograms per gram ($\mu\text{g/g}$) on an "as received" basis, except #5 which is reported on a dry coal basis. Samples #3 and 4 are reported in micrograms per millilitre ($\mu\text{g/mL}$) on an "as received" basis.

If you have any questions concerning these results, please call.

Harold A. Connell

Harold A. Connell
Assistant Lab Manager

Robert L. Taylor

Robert L. Taylor, Ph.D., Mngr. 16 May 84
Instrumental Analysis Div.

as

4-12



Charter Member

OVER 40 BRANCH LABORATORIES STRATEGICALLY LOCATED IN PRINCIPAL COAL MINING AREAS,
TIDEWATER AND GREAT LAKES PORTS, AND RIVER LOADING FACILITIES

Table No. I
(Wt.%-As Received)

| Parameter | 900204 DM Filter + 1 μm |
|----------------|---------------------------------------|
| Aluminum (Al) | 4.29 |
| Barium (Ba) | 0.13 |
| Calcium (Ca) | 0.52 |
| Fluorine (F) | 0.03 (300 $\mu\text{g/g}$) |
| Iron (Fe) | 3.07 |
| Potassium (K) | 0.99 |
| Lithium (Li) | 0.004 (44 $\mu\text{g/g}$) |
| Magnesium (Mg) | 0.23 |
| Sodium (Na) | 0.54 |
| Phosphorus (P) | 0.06 (600 $\mu\text{g/g}$) |
| Sulfur (S) | 0.30 |
| Silicon (Si) | 5.13 |
| Titanium (Ti) | 0.57 |
| Vanadium (V) | 0.04 (400 $\mu\text{g/g}$) |

Table No. II
(Wt.%-As Received)

| Parameter | 900217 DM 10 μm + 3 μm |
|----------------|---|
| Aluminum (Al) | 9.19 |
| Calcium (Ca) | 0.41 |
| Fluorine (F) | <0.01 |
| Iron (Fe) | 2.25 |
| Potassium (K) | 0.90 |
| Lithium (Li) | 0.009 (87 $\mu\text{g/g}$) |
| Magnesium (Mg) | 0.25 |
| Sodium (Na) | 0.88 |
| Sulfur (S) | 0.06 (640 $\mu\text{g/g}$) |
| Silicon (Si) | 13.17 |
| Titanium (Ti) | 0.54 |



Table No. III
($\mu\text{g}/\text{mL}$ -As Received)

| Parameter | 900219 DM Impinger 1 |
|---------------|-------------------------|
| Chromium (Cr) | 29 |
| Fluorine (F) | 19 |
| Iron (Fe) | 150 |
| Sodium (Na) | 380 |
| Sulfur (S) | 4,700 (0.47%) |

Table No. IV
($\mu\text{g}/\text{mL}$ -As Received)

| Parameter | 900208 DM Impinger 1 Blank |
|--------------|-------------------------------|
| Fluorine (F) | 0.43 |

Table No. V
($\mu\text{g/g}$ -Dry Coal Basis)

| Parameter | 900209 DM CWS Fuel |
|----------------|-----------------------|
| Aluminum (Al) | 7,000 (0.70%) |
| Fluorine (F) | 34 |
| Iron (Fe) | 1,700 (0.17%) |
| Potassium (K) | 80 |
| Magnesium (Mg) | 200 |
| Sodium (Na) | 70 |
| Silicon (Si) | 12,800 (1.28%) |
| Titanium (Ti) | 400 |
| Moisture | 74.41% |



4.2 TCO, GRAV, GC/MS, AND IR ANALYSES OF SASS SAMPLES

Acurex/ES (CMEA)
M/S 2-2260

January 18, 1984
Acurex ID: 8310-004
Client PO#: 307736.72

Attention: Larry Waterland

Sample: Memphis, 1 SASS Train; Received 8/29/83

The above samples were analyzed by Level 1 protocol. The XAD and OMC extracts were combined per your instruction. Organic extracts were also analyzed for the semivolatile priority pollutants by gas chromatography/mass spectrometry employing a J&W SE-54 30 meter capillary column. The column was held at 30°C for 2 minutes, then ramped at 10°C per minute to 27°C. In addition to the priority pollutants, other organics including benzo(c)phenanthrene, dibenzo(c,g)carbazole, 7,12-dimethylbenzo(a)anthracene, 3-methylcholanthrene, and perylene were sought employing the computerized library search and manual interpretation. The assignment and quantitation of these organics is tentative since analytical standards of these compounds were not available for analysis. Benzo(c)phenanthrene, dibenzo(c,g)carbazole, 7,12-dimethylbenzo(a)anthracene, 3-methylcholanthrene and perylene were not detected in any of the samples at levels above 400 µg per 10 ml of extract.

Submitted by:

Greg Nicoll
Greg Nicoll
Operations Manager

Viorica Lopez-Avila, Ph.D.
Viorica Lopez-Avila, Ph.D.
Technical Director

GN/VLA/ats

Enclosures



ANALYSIS LABORATORIES

DATA REPORTING FORM

CUSTOMER CMEA DATE January 19, 1984
CUSTOMER CONTRACT NO. 307736.72 ACUREX CONTRACT NO. _____
RESULTS REPORT TO _____ TELEPHONE _____
ADDRESS _____

* Duplicate injections

ANALYST U. Spannagel, C. Beeman, S. Kraska

REVIEWER - J. C. L. Tammell

IR REPORT

SAMPLE: 8311-30-2

$10 \mu + 3\mu$

IR REPORT

SAMPLE: 8311-30-1 Filters + 1μ

IR REPORT

SAMPLE:

8310-04-12

XAD

IA REPORT

SAMPLE: 8310-04-13 XAD Blk

4.3 GC/MS ANALYSIS OF VOST TRAPS



Energy & Environmental Division

Acurex/ES

September 27, 1983
Acurex ID#: 8309-006
Client PO#: 307736.72
Page 1 of 4

Attention: Carlo Castaldini

Subject: Analysis of 3 Tenax Traps and 3 Tenax/Charcoal Traps for Volatile Priority Pollutants and Allyl Chloride.

Enclosed please find the results of the gas chromatographic/mass spectrometric analyses of the 6 Tenax and Tenax/Charcoal traps from the CMEA tests at Memphis. Analyses for propylene oxide, ethylene oxide and 2-nitropropane were not performed due to unavailability of standards. Allyl chloride standard was not available, however retention time and mass spectrum of compound were available from a previous project performed recently at Acurex. Analyses were performed on September 7, 1983.

Results are summarized in Tables 1 and 2. Analyses were performed according to procedures in the VOST protocol^a. A Nutech desorption unit interfaced to a Tekmar LSC-2 purge and trap device was used. The GC/MS conditions are summarized in Table 3.

If you have any questions regarding these analyses, please call.

Prepared by: William G. Hellier
William G. Hellier
Staff Chemist

Approved by: Viorica Lopez-Avila
Viorica Lopez-Avila, Ph.D.
Technical Director

WGH/VLA/ats

a - Draft Protocol for the Collection and Analysis of Volatile POHCs using a Volatile Organic Sampling Train (VOST) by Envirodyne Engineers, Inc., April 1983.

Table 1. Percent Recovery of VOA Standards Spiked on Traps

| Compound | Spiking Level (ng) | | | Tenax | | | Tenax/Charcoal | | |
|-----------------------------------|--------------------|-----|-----|-------|-----|-----|----------------|-----|-----|
| | 50 | 100 | 200 | 50 | 100 | 200 | 50 | 100 | 200 |
| Chloromethane | 260 | 219 | 188 | 0 | 0 | 0 | 0 | 0 | 0 |
| Bromomethane | 128 | 108 | 157 | 146 | 168 | 160 | 160 | 160 | 160 |
| Vinyl chloride | 114 | 114 | 188 | 121 | 134 | 130 | 130 | 130 | 130 |
| Chloroethane | 148 | 120 | 185 | 100 | 107 | 100 | 100 | 100 | 100 |
| Dichloromethane | 248 | 130 | 116 | 210 | 122 | 72 | 72 | 72 | 72 |
| 1,1-Dichloroethylene | 160 | 133 | 171 | 115 | 106 | 99 | 99 | 99 | 99 |
| 1,1-Dichloroethane | 146 | 131 | 157 | 110 | 98 | 101 | 101 | 101 | 101 |
| Trans-1,2-dichloroethylene | 156 | 120 | 157 | 108 | 95 | 105 | 105 | 105 | 105 |
| Chloroform | 142 | 123 | 146 | 100 | 85 | 104 | 104 | 104 | 104 |
| 1,2-Dichloroethane | 103 | 96 | 110 | 108 | 94 | 110 | 110 | 110 | 110 |
| 1,1,1-Trichloroethane | 144 | 128 | 174 | 121 | 100 | 113 | 113 | 113 | 113 |
| Carbon tetrachloride | 130 | 114 | 181 | 105 | 103 | 116 | 116 | 116 | 116 |
| Dichlorobromomethane | 106 | 116 | 148 | 102 | 119 | 144 | 144 | 144 | 144 |
| 1,2-Dichloropropane | 88 | 91 | 95 | 105 | 97 | 108 | 108 | 108 | 108 |
| 1,3-Dichloropropene(trans) | 200 | 106 | 61 | 211 | 100 | 59 | 59 | 59 | 59 |
| Trichloroethylene | 110 | 103 | 111 | 150 | 121 | 135 | 135 | 135 | 135 |
| Chlorodibromomethane | 39 | 57 | 59 | 106 | 144 | 185 | 185 | 185 | 185 |
| 1,1,2-Trichloroethane | 101 | 56 | 52 | 94 | 117 | 116 | 116 | 116 | 116 |
| 1,3-Dichloropropene(cis) | 67 | 59 | 83 | 102 | 101 | 123 | 123 | 123 | 123 |
| Benzene | 360 | 232 | 157 | 164 | 99 | 104 | 104 | 104 | 104 |
| 2-Chloroethyl vinyl ether | 67 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Bromoform | 0 | 11 | 16 | 90 | 210 | 250 | 250 | 250 | 250 |
| Tetrachloroethylene | 106 | 98 | 110 | 165 | 101 | 104 | 104 | 104 | 104 |
| 1,1,2,2-Tetrachloroethane | 17 | 17 | 19 | 72 | 94 | 87 | 87 | 87 | 87 |
| Toluene | 101 | 96 | 95 | 280 | 101 | 106 | 106 | 106 | 106 |
| Chlorobenzene | 48 | 62 | 48 | 94 | 96 | 100 | 100 | 100 | 100 |
| Ethylbenzene | 51 | 64 | 50 | 176 | 84 | 115 | 115 | 115 | 115 |
| <u>Percent Surrogate Recovery</u> | | | | | | | | | |
| Toluene-d ₈ | 87 | 89 | 82 | 88 | 89 | 95 | | | |

Table 2. Test Results

| Test # | Concentration (ng/trap) | | | | | |
|-----------------------------------|-------------------------|--------|--------|--------|--------|--------|
| | 1A | 1B | 3A | 3B | 4A | 4B |
| Trap ID | 25 | 7A | 29 | 3B | 24 | 36A |
| Acurex ID | 819600 | 819601 | 819610 | 819611 | 819598 | 819599 |
| Chloromethane | 140 | 1010 | 115 | 735 | 132 | 429 |
| Vinyl chloride | ND | 98 | ND | 159 | ND | ND |
| Chloroethane | ND | 154 | ND | 248 | ND | ND |
| Dichloromethane | 694 | 673 | 943 | 2050 | 2120 | 2711 |
| Trans-1,2-dichloroethylene | ND | ND | ND | ND | 49 | 24 |
| Chloroform | 22 | 18 | 8 | 13 | 16 | 16 |
| 1,2-Dichloroethane | 7 | ND | ND | ND | ND | ND |
| 1,1,1-Trichloroethane | 38 | 25 | 47 | 84 | 268 | 330 |
| Carbon tetrachloride | ND | ND | ND | ND | 42 | 40 |
| 1,3-Dichloropropene(trans) | 30 | 53 | 31 | 74 | 43 | 54 |
| Trichloroethylene | 138 | 13 | 104 | 441 | 1370 | 1900 |
| Benzene | 586 | 35 | 681 | 81 | 193 | 147 |
| 2-Chloroethyl vinyl ether | 747 | 468 | 1180 | 1000 | 610 | 1530 |
| Tetrachloroethylene | ND | ND | ND | 57 | ND | 227 |
| 1,1,2,2-Tetrachloroethane | 15 | 38 | 33 | 27 | 59 | 55 |
| Toluene | 595 | 361 | 953 | 755 | 1450 | 1210 |
| Chlorobenzene | ND | ND | 28 | ND | ND | ND |
| Ethylibenzene | 22 | 89 | 58 | 66 | 58 | 44 |
| Allyl chloride | ND | ND | ND | ND | ND | ND |
| Trichlorofluoromethane | ND | 3640 | 241 | 7910 | 4990 | 1970 |
| <u>Percent Surrogate Recovery</u> | | | | | | |
| Toluene-d ₈ | 78 | 92 | 101 | 109 | 97 | 92 |

ND - Not detected (Detection limit- 5 ng per trap)

Table 3. GC/MS Operating Conditions

- Instrument: Finnigan 1020 GC/MS System interfaced with an INCOS 2300 data system
- Column: 1 percent SP-1000 on Carbopack B 60/80 mesh
- Injector Temperature: 220°C (for spiking internal standards)
- Separator Temperature: 250°C
- Carrier Gas: Helium at 40 mL/min
- Temperature Program 45°C (3 min hold) to 250°C (10 min hold) at 8°C/min
- Multiplier Voltage: 1600V
- Mass Range: 40 to 250 amu
- Scan Rate: 3 sec/scan
- Total Scans Acquired: 700

4.4 BIOASSAY ANALYSIS REPORT

In the following, samples with the prefix "DM" are for these tests.

Samples with prefixes "HR" or "RA" are for other tests performed.



BIONETICS

5516 Nicholson Lane Kensington Maryland 20895 301 881-5600 • Telex 89-8369

April 18, 1984

Dr. Larry Waterland
Acurex Corporation
485 Clyde Avenue
Mountain View, California 94042

RE: Acurex Subcontract No. RB59178A
Release No. 6

Dear Larry:

Enclosed are three bound, and one unbound, copies of the final reports for the five XAD resin extract samples and six ash samples submitted for testing and evaluation in IERL-EPA Level 1 Ames/Salmonella mutagenesis and CHO cytotoxicity bioassays. All studies were conducted and evaluated under IERL-EPA Level 1 guidelines.

Bioassay of the samples took slightly longer than normal because a phased testing approach was used with the XAD-2 resin extract samples. This phased approach involved initial CHO cytotoxicity testing, then preliminary range-finding Ames tests with only one strain, followed by one or more definitive Ames assays. By using this approach, we were able to adequately test and evaluate all samples.

The summary of the bioassay data, the criteria used to evaluate the results, the critical data upon which the evaluations were based, and a graphic display of the relative ranking of the samples are presented in the attached tables and figures.

If you have any questions or comments concerning these reports or future testing, please fell free to contact me at (301) 881-5600, extension 536.

Sincerely,

LITTON BIONETICS, INC.

Robert R. Young
Environmental Assessment Section
Department of Molecular Toxicology

RRY/mg

Enclosures: Ames and CHO 7330-7346 Reports.

cc: Contracts, LBI No. 20993, 20988

TABLE 1
BIOASSAY SUMMARY TABLE

Technical Directive or Project No. LBI Project No. 20988 and 20993.

Contract No. EPA No. 68-02-3188; ACUREX Subcontract No. RB 59178A Release No. 6.

| Sample Identification | Health Effects Tests | | | | | Ecological Effects Tests | | | | | Notes |
|---|----------------------|------------------|------------------|-----------------|------|--------------------------|-------|--------|--------------|-------------|-----------------------|
| | AMES Salmonella | RAM Cytotoxicity | CHO Cytotoxicity | Rodent Toxicity | Fish | Fresh Water | | Marine | | Terrestrial | |
| | | | | | | Invertebrate | Algal | Fish | Invertebrate | Algal | Plant Stress Ethylene |
| HR XAD-2 EXTRACT, INLET (819369) | H | | M/H | | | | | | | | |
| HR XAD-2 EXTRACT, OUTLET (819370) | M | M | | | | | | | | | |
| RA XAD-2 EXTRACT, TEST 1 (819459) | H | M | | | | | | | | | |
| RA XAD-2 EXTRACT, TEST 2 (819465) | M | | H/M | | | | | | | | |
| DM XAD-2 EXTRACT (900206) | M | M | | | | | | | | | |
| RA BOTTOM ASH, TEST 1 (819488) | ND | ND | | | | | | | | | |
| RA BOTTOM ASH, TEST 2 (819498) | ND | ND | | | | | | | | | |
| RA CYCLONE ASH, TEST 1 (819476) | M/H | ND | | | | | | | | | |
| RA CYCLONE ASH, TEST 2 (819504) | L/M | ND | | | | | | | | | |
| DM FILTER + 1 μm PART. (900204) | ND | L | | | | | | | | | |
| DM 10 μm + 3 μm PART. (900218) | ND | L | | | | | | | | | |

ND = No Detectable Toxicity

L = Low Toxicity

M = Moderate Toxicity

H = High Toxicity

TABLE 2
DEFINITION OF TOXICITY CATEGORIES FOR HEALTH EFFECTS ASSAYS

| Assay ^a | Activity Measured ^b | Sample Type ^c | MAD ^d | Units | Range of Concentration or Dosage | | | |
|--------------------|--|--------------------------|------------------------|---------------------------------|----------------------------------|-------------------------------------|-------------------------------------|--|
| | | | | | High | Moderate | Low | Not Detectable (ND) |
| Ames | MEC (mutagenesis) | S AL, NAL E | 5 200 5000 | mg/plate μl/plate L/plate | <0.05 <2 <50 | 0.05-0.5 2-20 50-500 | 0.5-5 20-200 500-5000 | ND at >5 ND at >200 ND at >5000 |
| RAM | EC ₅₀ (lethality) | S AL NAL E | 1 600 20 1000 | mg/ml μl/ml μl/ml L/ml | <0.01 <6 <0.2 <10 | 0.01-0.1 6-60 0.2-2 10-100 | 0.1-1 60-600 2-20 100-1000 | ND at >1 ND at >600 ND at >20 ND at >1000 |
| CHO | EC ₅₀ (lethality) | S AL NAL E | 1 600 20 1000 | mg/ml μl/ml μl/ml L/ml | <0.01 <6 <0.2 <10 | 0.01-0.1 6-60 0.2-2 10-100 | 0.1-1 60-600 2-20 100-1000 | ND at >1 ND at >600 ND at >20 ND at >1000 |
| WAT | LD ₅₀ (lethality and toxic signs) | S AL, NAL | 5 5 | gm/kg ml/kg | <0.05 <0.05 | 0.05-0.5 0.05-0.5 | 0.5-5 0.5-5 | ND at >5 ND at >5 |

^aStandard test abbreviations are as follows:

- Ames: Ames Salmonella/microsome mutagenesis assay
- RAM: Rabbit alveolar macrophage cytotoxicity assay
- CHO: Rodent cell clonal toxicity assay
- WAT: Acute in vivo test in rodents (whole animal test)

^bStandard abbreviations for measured endpoints are as follows:

- MEC: Minimum effective concentration
- EC₅₀: Calculated concentration expected to produce effect in 50 percent of population
- LD₅₀: Calculated dose expected to kill 50 percent of population

^cS = Solid, AL = Aqueous liquid, NAL = Nonaqueous liquid, E = Extract and/or concentrate of unknown organic content (use equivalent volume of SASS train gas)

^dMAD = Maximum applicable dose

TABLE 3

HEALTH EFFECTS CRITICAL DATA SUMMARY FORM^a

Contract No. EPA No. 68-02-3188 Technical Directive or Project No. LBI No. 20988 and 20993 Site Sampled HR, RA and DM
 Acurex Subcontract No. RB 59178A
 Release No. 6

| Sample Identification | Ames Mutagenicity [MEC] ^b | CHO Clonal Toxicity [EC50] ^c | RAM Cytotoxicity [EC50] ^c | | | Rodent Toxicity | | |
|------------------------------------|--------------------------------------|---|--------------------------------------|-----------------|-----|-------------------------------|-------------------|--------------------------|
| | | | Viability | Viability Index | ATP | ATP/Per 10 ⁶ Cells | LD50 ^d | Toxic Signs ^e |
| HR XAD-2 EXTRACT, INLET 819369 | 25 ^f | 11.5 ^f | | | | | | |
| HR XAD-2 EXTRACT, OUTLET 819370 | 100 | 18.4 | | | | | | |
| RA XAD-2 EXTRACT, TEST 1 819459 | 20 | 35.2 | | | | | | |
| RA XAD-2 EXTRACT, TEST 2 819465 | 137.5 | 9.35 | | | | | | |
| DM XAD-2 EXTRACT 900206 | 200 | 16.0 | | | | | | |
| RA BOTTOM ASH, TEST 1 819488 | >10000 | >1000 (4000) | | | | | | |
| RA BOTTOM ASH, TEST 2 819498 | >10000 | 1400 | | | | | | |
| RA CYCLONE ASH, TEST 1 819476 | 50 | >1000 (5000) | | | | | | |
| RA CYCLONE ASH, TEST 2 819504 | 500 | >1000 (1200) | | | | | | |
| DM FILTER + 1 µm PART. 900204 | >10000 | 140 | | | | | | |
| DM 10 µm + 3 µm PART. 900218 | >10000 | 450 | | | | | | |
| | | | | | | | | |

^aThe assays, observed parameters and evaluation criteria are presented in IERL-RTP Procedures Manual; Level 1 Environmental Assessment Biological Tests, [EPA Contract No. 68-02-2681, Litton Bionetics, Inc., Kensington, Md.]

^bMEC: Minimum Effective Concentration - Lowest concentration for any tester strain giving a mutagenic response.

^cEC₅₀: Effective concentration that reduces the observed parameter to 50 percent of the appropriate negative control.

^dLD₅₀: The dose lethal to 50 percent of treated animals.

^eToxic signs are identified in a numbered list in the Level 1 manual. Only the number is reported here.

^fConcentrations are µg organics per plate for Ames assay and per ml of culture medium for the CHO assay. Values in parenthesis are extrapolated values.




Figure 1. Ranking of test material toxicity using EC_{50} in EPA level 1 CHO clonal toxicity assay.




Figure 2. Ranking of test material mutagenicity using minimum effective concentration in EPA level 1 Ames mutagenesis assay.

TECHNICAL REPORT DATA
(Please read Instructions on the reverse before completing)

| | | |
|---|---|--|
| 1. REPORT NO. EPA-600/7-86-012b | 2. | 3. RECIPIENT'S ACCESSION NO. |
| 4. TITLE AND SUBTITLE Environmental Assessment of a Coal/Water Slurry Fired Industrial Boiler; Volume II. Data Supplement | | 5. REPORT DATE April 1986 |
| 6. PERFORMING ORGANIZATION CODE | | 7. AUTHOR(S) D. Van Buren and L. R. Waterland |
| 8. PERFORMING ORGANIZATION REPORT NO. | | 9. PERFORMING ORGANIZATION NAME AND ADDRESS Acurex Corporation Energy and Environmental Division P.O. Box 7555 Mountain View, California 94039 |
| 10. PROGRAM ELEMENT NO. | | 11. CONTRACT/GRANT NO. 68-02-3188 |
| 12. SPONSORING AGENCY NAME AND ADDRESS EPA, Office of Research and Development Air and Energy Engineering Research Laboratory Research Triangle Park, NC 27711 | | 13. TYPE OF REPORT AND PERIOD COVERED Final; 7/83 - 4/85 |
| | | 14. SPONSORING AGENCY CODE EPA/600/13 |
| 15. SUPPLEMENTARY NOTES AEERL project officer is Joseph A. McSorley, Mail Drop 65, 919/541-2920. Volume I contains technical results. | | |
| 16. ABSTRACT The report gives results of comprehensive emission measurements and analyses for a 7.6 kg/s (60,000 lb/hr) watertube industrial boiler firing a coal/water slurry. Measurements included continuous monitoring of flue gas; quantitation of semivolatile organics and 73 trace elements; volatile organic sampling train (VOST) quantitation of volatile organic priority pollutants; EPA Method 5/8 for particulate and SO _x ; controlled condensation for SO _x ; Andersen impactors for particle size distribution; and grab samples for N ₂ O. Emissions of NO _x , SO ₂ , CO, and hydrocarbons averaged 510, 450, 285, and 1 ppm, corrected to 3% oxygen. Particulate emissions were 4.3 g/dscm, and particle size was biased to larger size fractions with over half of particulate mass at 10 micrometers or greater. Over 90% were 3 micrometers or greater. Combustible losses were high with over 40% carbon content in particulate. Total organic emissions were 15 to 17 mg/dscm with half in the C1 to C6 range. Naphthalene was the only semivolatile detected. | | |
| 17. KEY WORDS AND DOCUMENT ANALYSIS | | |
| a. DESCRIPTORS Pollution Assessments Slurries Coal Water Combustion | b. IDENTIFIERS/OPEN ENDED TERMS Water Tube Boilers | c. COSATI Field/Group 13B 13A 14B 11G 21D 07B 21B |
| 18. DISTRIBUTION STATEMENT Release to Public | 19. SECURITY CLASS (This Report) Unclassified | 21. NO. OF PAGES 91 |
| | 20. SECURITY CLASS (This page) Unclassified | 22. PRICE |