

ABMA

American
Boiler Manufacturers
Association

1500 Wilson Boulevard
Arlington VA 22209

DoE

United States
Department
of Energy

Division of Power Systems
Energy Technology Branch
Washington DC 20545

EPA


United States
Environmental Protection
Agency

Industrial Environmental Research
Laboratory
Research Triangle Park NC 27711

EPA-600/7-80-137b
May 1980

Field Tests of Industrial Stoker Coal-fired Boilers for Emissions Control and Efficiency Improvement — Site J (Data Supplement)

Interagency
Energy/Environment
R&D Program Report



RESEARCH REPORTING SERIES

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into nine series. These nine broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and a maximum interface in related fields. The nine series are:

1. Environmental Health Effects Research
2. Environmental Protection Technology
3. Ecological Research
4. Environmental Monitoring
5. Socioeconomic Environmental Studies
6. Scientific and Technical Assessment Reports (STAR)
7. Interagency Energy-Environment Research and Development
8. "Special" Reports
9. Miscellaneous Reports

This report has been assigned to the INTERAGENCY ENERGY-ENVIRONMENT RESEARCH AND DEVELOPMENT series. Reports in this series result from the effort funded under the 17-agency Federal Energy/Environment Research and Development Program. These studies relate to EPA's mission to protect the public health and welfare from adverse effects of pollutants associated with energy systems. The goal of the Program is to assure the rapid development of domestic energy supplies in an environmentally-compatible manner by providing the necessary environmental data and control technology. Investigations include analyses of the transport of energy-related pollutants and their health and ecological effects; assessments of, and development of, control technologies for energy systems; and integrated assessments of a wide range of energy-related environmental issues.

EPA REVIEW NOTICE

This report has been reviewed by the participating Federal Agencies, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the Government, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

This document is available to the public through the National Technical Information Service, Springfield, Virginia 22161.

EPA-600/7-80-137b

May 1980

Field Tests of Industrial Stoker Coal-fired Boilers for Emissions Control and Efficiency Improvement — Site J (Data Supplement)

by

**J.O. Burlingame, R.A. Parker, W.M. Jackson,
and J.D. Demont**

**KVB, Inc.
6176 Olson Memorial Highway
Minneapolis, Minnesota 55422**

**IAG/Contract Nos. IAG-D7-E681 (EPA), EF-77-C-01-2609 (DoE)
Program Element No. EHE624**

Project Officers: R. Hall (EPA) and W. Harvey, Jr. (DoE)

**Industrial Environmental Research Laboratory
Office of Environmental Engineering and Technology
Research Triangle Park, NC 27711**

Prepared for

**U.S. ENVIRONMENTAL PROTECTION AGENCY
Office of Research and Development
Washington, DC 20460**

**U.S. DEPARTMENT OF ENERGY
Division of Power Systems/Energy Technology Branch
Washington, DC 20545**

and

**AMERICAN BOILER MANUFACTURERS ASSOCIATION
1500 Wilson Boulevard
Arlington, VA 22209**

ABSTRACT

The Data Supplement is a compilation of test data presented in greater detail than was practical in the Final Technical Report. It is intended to provide the necessary details to other researchers who are interested in performing their own analysis. Readers are referred to the contract final report for information as to objectives, description of facility tested and coals fired, test equipment and procedures, interpretations and conclusions. The Final Technical Report also contains data summaries not found in this volume. The Supplement contains panel board data for each test, detailed particulate, O₂, CO₂, NO, SO₂ and SO₃ data, particle size distribution data, chemical analysis of the coal, coal size consistency data, combustible analysis and overfire air traverse data.

KVB 4-15900-545

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
Foreword	iv
CONVERSION FACTORS	v
1.0 PANEL BOARD DATA	1
1.1 Control Room Data Sheets	2
2.0 PARTICULATE DATA	31
2.1 Particulate Data Summary	32
2.2 Particulate Data Sheets	34
2.3 Particulate Lab Worksheets.	50
3.0 GASEOUS DATA	66
3.1 Gaseous Emission Summary	67
3.2 Gaseous Emission Data Sheets.	68
3.3 SOx Data Sheets	81
4.0 PARTICLE SIZE DISTRIBUTION	83
4.1 Brink	84
4.2 SASS	90
5.0 FUEL AND ASH ANALYSIS	91
5.1 Commercial Testing Analysis.	92
5.2 Combustibles Analysis	117
5.3 Coal Sieve Analysis	118
6.0 OVERFIRE AIR TRAVERSES	131
6.1 Overfire Air Data Sheets	132

Foreword

The purpose of this Data Supplement Volume is to document data in greater detail than was practical in the Final Technical Report.¹ It is intended to provide the necessary details to other researchers who are interested in performing their own analysis. Readers are referred to the contract final report for information as to objectives, description of facility tested and coals fired, test equipment and procedures, interpretations and conclusions. The final Technical Report also contains data summaries not found in this volume.

The data in this volume are arranged by type (i.e., Panel Board Data, Particulate Data, etc.) and within each type by test number. Data summaries where they exist are at the front of each section. The boiler tested is referred to as Boiler J; as it is the tenth boiler tested under the program entitled, "A Testing Program to Update Equipment Specifications and Design Criteria for Stoker Fired Boilers".

KVB 4-15900-545

¹ Langsjoen, P. L., et al., "Field Tests of Industrial Stoker Coal-Fired Boilers for Emissions Control and Efficiency Improvement - Site J.

CONVERSION FACTORS

ENGLISH AND METRIC UNITS TO SI UNITS

<u>To Convert From</u>	<u>To</u>	<u>Multiply By</u>
in	cm	2.540
in ²	cm ²	6.452
ft	m	0.3048
ft ²	m ²	0.09290
ft ³	m ³	0.02832
lb	Kg	0.4536
lb/hr	Mg/s	0.1260
lb/10 ⁶ BTU	ng/J	430
g/Mcal	ng/J	239
BTU	J	1054
BTU/lb	J/kg	2324
BTU/hr	W	0.2929
J/sec	W	1.000
J/hr	W	3600
BTU/ft/hr	W/m	0.9609
BTU/ft/hr	J/hr/m	3459
BTU/ft ² /hr	W/m ²	3.152
BTU/ft ² /hr	J/hr/m ²	11349
BTU/ft ³ /hr	W/m ³	10.34
BTU/ft ³ /hr	J/hr/m ³	37234
psia	Pa	6895
"H ₂ O	Pa	249.1
Rankine	Celsius	C = 5/9R-273
Fahrenheit	Celsius	C = 5/9(F-32)
Celsius	Kelvin	K = C+273
Rankine	Kelvin	K = 5/9R

FOR TYPICAL COAL FUEL

ppm @ 3% O ₂ (SO ₂)	ng/J (lb/10 ⁶ Btu)	0.851 (1.98x10 ⁻³)
ppm @ 3% O ₂ (SO ₃)	ng/J (lb/10 ⁶ Btu)	1.063 (2.47x10 ⁻³)
ppm @ 3% O ₂ (NO)*	ng/J (lb/10 ⁶ Btu)	0.399 (9.28x10 ⁻⁴)
ppm @ 3% O ₂ (NO ₂)	ng/J (lb/10 ⁶ Btu)	0.611 (1.42x10 ⁻³)
ppm @ 3% O ₂ (CO)	ng/J (lb/10 ⁶ Btu)	0.372 (8.65x10 ⁻⁴)
ppm @ 3% O ₂ (CH ₄)	ng/J (lb/10 ⁶ Btu)	0.213 (4.95x10 ⁻⁴)
g/kg of fuel**		

*Federal environmental regulations express NO_x in terms of NO₂; thus NO units should be converted using the NO₂ conversion factor.

**Based on higher heating value of 10,000 Btu/lb. For a heating value other than 10,000 Btu/lb, multiply the conversion factor by 10,000/(Btu/lb).

CONVERSION FACTORS

SI UNITS TO ENGLISH AND METRIC UNITS

<u>To Convert From</u>	<u>To</u>	<u>Multiply By</u>
cm	in	0.3937
cm ²	in ²	0.1550
m	ft	3.281
m ²	ft ²	10.764
m ³	ft ³	35.315
Kg	lb	2.205
Mg/s	lb/hr	7.937
ng/J	lb/10 ⁶ BTU	0.00233
ng/J	g/Mcal	0.00418
J	BTU	0.000948
J/kg	BTU/lb	0.000430
J/hr/m	BTU/ft/hr	0.000289
J/hr/m ²	BTU/ft ² /hr	0.0000881
J/hr/m ³	BTU/ft ³ /hr	0.0000269
W	BTU/hr	3.414
W	J/hr	0.000278
W/m	BTU/ft/hr	1.041
W/m ²	BTU/ft ² /hr	0.317
W/m ³	BTU/ft ³ /hr	0.0967
Pa	psia	0.000145
Pa	"H ₂ O	0.004014
Kelvin	Fahrenheit	F = 1.8K-460
Celsius	Fahrenheit	F = 1.8C+32
Fahrenheit	Rankine	R = F+460
Kelvin	Rankine	R = 1.8K

FOR TYPICAL COAL FUEL

ng/J	ppm @ 3% O ₂ (SO ₂)	1.18
ng/J	ppm @ 3% O ₂ (SO ₃)	0.941
ng/J	ppm @ 3% O ₂ (NO)	2.51
ng/J	ppm @ 3% O ₂ (NO ₂)	1.64
ng/J	ppm @ 3% O ₂ (CO)	2.69
ng/J	ppm @ 3% O ₂ (CH ₄)	4.69
ng/J	g/kg of fuel	0.000233

SI PREFIXES

Multiplication Factor	Prefix	SI Symbol
10^{18}	exa	E
10^{15}	peta	P
10^{12}	tera	T
10^9	giga	G
10^6	mega	M
10^3	kilo	k
10^2	hecto*	h
10^1	deka*	da
10^{-1}	deci*	d
10^{-2}	centi*	c
10^{-3}	milli	m
10^{-6}	micro	μ
10^{-9}	nano	n
10^{-12}	pico	p
10^{-15}	femto	f
10^{-18}	atto	a

*Not recommended but occasionally used

**EMISSION UNITS CONVERSION FACTORS
FOR TYPICAL COAL FUEL (HV = 13,320 BTU/LB)**

Multiply To Obtain	By	% Weight in Fuel		lbs/10 ⁶ Btu		grams/10 ⁶ Cal		PPM (Dry @ 3% O ₂)		Grains/SCF. (Dry @ 12% CO ₂)	
		S	N	SO ₂	NO ₂	SO ₂	NO ₂	SO _x	NO _x	SO ₂	NO ₂
% Weight In Fuel	S	1		0.666	/	0.370	/	13.2x10 ⁻⁴	/	1.48	/
	N			/	0.405	/	0.225	/	5.76x10 ⁻⁴	/	.903
lbs/10 ⁶ Btu	SO ₂	1.50	/	1		(.556)	/	19.8x10 ⁻⁴	/	(2.23)	/
	NO ₂	/	2.47			/	(.556)	/	14.2x10 ⁻⁴	/	(2.23)
grams/10 ⁶ Cal	SO ₂	2.70	/	1		(1.8)	/	35.6x10 ⁻⁴	/	(4.01)	/
	NO ₂	/	4.44			/	(1.8)	/	25.6x10 ⁻⁴	/	(4.01)
PPM (Dry @ 3% O ₂)	SO _x	758	/	505	/	281	/	1		1127	/
	NO _x	/	1736	/	704	/	391			/	1566
Grains/SCF (Dry @ 12% CO ₂)	SO ₂	.676	/	(.448)	/	(.249)	/	8.87x10 ⁻⁴	/	1	
	NO ₂	/	1.11	/	(.448)	/	(.249)	/	6.39x10 ⁻⁴		

NOTE: 1. Values in parenthesis can be used for all flue gas constituents such as oxides of carbon, oxides of nitrogen, oxides of sulfur, hydrocarbons, particulates, etc.
2. Standard reference temperature of 530°R was used.

SECTION 1.0
PANEL BOARD DATA

	<u>PAGE</u>
1.1 CONTROL ROOM DATA	2

KVB

Steam Flow, lbs/hr 33,766
 Coal Flow, lbs/hr 3200
 % Design Capacity 48.2
 lb steam/lb coal 11.3

PANEL BOARD DATA
 ABMA TEST SITE J

TEST NO.	01			
TEST DATE	6-3-79			
TEST COAL	Ohio			
TEST CONDITIONS	35,000 ^{LB} /HR			
<u>COAL</u>				
TIME	13:30		15:30	
POUNDS ADDED	filled		3 tons	
<u>STEAM</u> TIME	13:25	14:23	15:25	15:56
INTEGRATOR READING	50876	50917	50962	50978
<u>CHART RECORDER</u>				
STEAM FLOW Klbs/hr	36	36	32	35
AIR FLOW, RELATIVE	33	35	32	
<u>DRAFT GAUGES</u>				
WIND BOX "H ₂ O	1.4	2.0	1.4	
FURNACE "H ₂ O	0.2	0.2	0.2	
BOILER OUT "H ₂ O	-0.8	-0.5	-0.6	
DUST COLLECTOR "H ₂ O	-3.0	-3.5	-3.0	
STOKER ZONE #1	0	0	0	
#2	0.2	0.2	0.2	
#3	0	0	0	
#4	0	0	0	
#5	0	0	0	
#6	0	0	0	

KVB

Steam Flow, lbs/hr 51,652
 Coal Flow, lbs/hr 4219
 % Design Capacity 73.5
 lb steam/lb coal 12.2

PANEL BOARD DATA
 ABMA TEST SITE J

TEST NO.	2				
TEST DATE	6-4-79				
TEST COAL	Ohio				
TEST CONDITIONS	50,000 ^{LB} /HR		as found		
<u>COAL</u>					
TIME	1:45			4:50	
POUNDS ADDED	filled			13010 pounds	
<u>STEAM</u>	TIME	1:47	2:46	3:44	4:51
INTEGRATOR READING		51732	51794	51863	51930
<u>CHART RECORDER</u>					
STEAM FLOW Klbs/hr		50	50	52	
AIR FLOW, RELATIVE		52	54	54	
<u>DRAFT GAUGES</u>					
WIND BOX "H ₂ O		1.4	1.3	1.3	
FURNACE "H ₂ O		0.25	0.25	0.25	
BOILER OUT "H ₂ O		-0.8	-0.5	-0.5	
DUST COLLECTOR "H ₂ O		-3.2	-3.5	-3.5	
STOKER ZONE #1		0.4	0.6	0.5	
#2		0.8	1.0	0.9	
#3		0.5	0.6	0.5	
#4		0	0	0	
#5		0	0	0	
#6		0	0	0	

KVB

TEST #02

<u>PRESSURE GAUGES</u>					
STEAM PRESSURE psig	138	114	150		
FEEDWATER psig	164	170	169		
AIR PRESSURE psig					
<u>CONTROLS</u>					
BOILER MASTER	100	100	47		
STOKER	88	100	25		
FORCED DRAFT	70	70	65		
OVERFIRE AIR	67	68	65		
INDUCED DRAFT	-0.2	-0.2	-0.2		
<u>STOKER</u>					
COAL GATE POSITION	7.2	7.7	7.5		
WIND BOX POSITION #1	0	0	0		
#2	0	0	0		
#3	0	0	0		
#4	0	0	0		
#5	0	0	0		
#6	0	0	0		
OVERFIRE AIR PRESSURE "H ₂ O	3.5				
TEMP. F.D. FAN °F					
TEMP. F.W. °F					

KVB

Steam Flow, lbs/hr _____
 Coal Flow, lbs/hr _____
 % Design Capacity _____
 lb steam/lb coal _____

PANEL BOARD DATA
 ABMA TEST SITE J

TEST NO.	03				
TEST DATE	6-5-79				
TEST COAL	Ohio				
TEST CONDITIONS	70,000 LB/HR	low O ₂			
<u>COAL</u>					
TIME	10:00				
POUNDS ADDED	filled	BOILER	STARTED	SMOKING	
<u>STEAM</u> TIME	1000	REALLY	BAD,	SO	TESTING
INTEGRATOR READING	52500	WAS	STOPPED		
<u>CHART RECORDER</u>					
STEAM FLOW Klbs/hr	70				
AIR FLOW, RELATIVE	58				
<u>DRAFT GAUGES</u>					
WIND BOX "H ₂ O					
FURNACE "H ₂ O	0.25				
BOILER OUT "H ₂ O					
DUST COLLECTOR "H ₂ O					
STOKER ZONE #1	0.5				
#2	1.2				
#3	1.0				
#4	0.2				
#5	0				
#6	0				

KVB

TEST #03

<u>PRESSURE GAUGES</u>					
STEAM PRESSURE psig	130				
FEEDWATER psig	195				
AIR PRESSURE psig					
<u>CONTROLS</u>					
BOILER MASTER	100				
STOKER	44				
FORCED DRAFT	85				
OVERFIRE AIR	60				
INDUCED DRAFT	-0.2				
<u>STOKER</u>					
COAL GATE POSITION	8.4				
WIND BOX POSITION #1	0				
#2	0				
#3	0				
#4	0				
#5	0				
#6	0				
OVERFIRE AIR PRESSURE "H ₂ O					
TEMP. F.D. FAN °F					
TEMP. F.W. °F					

KVB

Steam Flow, lbs/hr 71,822
 Coal Flow, lbs/hr 6000
 % Design Capacity 102.6
 lb steam/lb coal 12.0

PANEL BOARD DATA

ABMA TEST SITE J

TEST NO.	5			
TEST DATE	6-12-79			
TEST COAL	OHIO			
TEST CONDITIONS	70,000			
<u>COAL</u>				
TIME	3:15			5:45
POUNDS ADDED	full			7 1/2 tons
<u>STEAM</u> Time	3:22	4:18	5:22	5:37
INTEGRATOR READING $\times 800$	58,775	58,959	58,954	58,977
<u>CHART RECORDER</u>				
STEAM FLOW Klbs/hr	73	70	74	
AIR FLOW, RELATIVE	59	57	58	
<u>DRAFT GAUGES</u>				
WIND BOX "H ₂ O	2.0	2.2	2.3	
FURNACE "H ₂ O	-0.2	-0.2	-0.2	
BOILER OUT "H ₂ O	-0.8	-0.7	-0.7	
DUST COLLECTOR "H ₂ O	-7.0	-7.2	-7.0	
STOKER ZONE #1	0.6	0.7	0.7	
#2	1.4	1.5	1.5	
#3	1.1	0.9	1.1	
#4	0.1	0.1	0.1	
#5	0	0	0	
#6	0	0	0	

KVB

<u>PRESSURE GAUGES</u>			
STEAM PRESSURE psig	130	125	132
FEEDWATER psig	170	190	190
AIR PRESSURE psig	50	50	50
<u>CONTROLS</u>			
BOILER MASTER	100	100	100
STOKER	100	100	100
FORCED DRAFT	100	100	100
OVERFIRE AIR	70	70	70
INDUCED DRAFT	0.2	-0.2	-0.2
<u>STOKER</u>			
COAL GATE POSITION	11.0	10.7	10.7
WIND BOX POSITION #1	0	0	0
#2	0	0	0
#3	0	0	0
#4	0	0	0
#5	0	0	0
#6	0	0	0
OVERFIRE AIR PRESSURE "H ₂ O	7 3/4"		
TEMP. F.D. FAN °F	70		
TEMP. F.W. °F	215		

KVB

Steam Flow, lbs/hr 69,016
 Coal Flow, lbs/hr 49,41
 % Design Capacity 78.6
 lb steam/lb coal 1.41

PANEL BOARD DATA
 ABMA TEST SITE J

TEST NO.	6			
TEST DATE	6-13-79			
TEST COAL	Kentucky			
TEST CONDITIONS	70,000			
<u>COAL</u>				
TIME	11:15			2:05
POUNDS ADDED	filled			7 ton
<u>STEAM</u> Time	11:05	12:08	1:07	2:10
INTEGRATOR READING	59,674	59,766	59,850	59,940
<u>CHART RECORDER</u>				
STEAM FLOW Klbs/hr	70	72	70	
AIR FLOW, RELATIVE	56	58	57	
<u>DRAFT GAUGES</u>				
WIND BOX "H ₂ O	2.4	2.2	2.4	
FURNACE "H ₂ O	0.25	0.25	0.20	
BOILER OUT "H ₂ O	-0.7	-0.8	-0.8	
DUST COLLECTOR "H ₂ O	-6.5	-7.0	-6.7	
STOKER ZONE #1	0.5	0.4	0.5	
#2	1.1	1.0	1.0	
#3	0.7	0.5	0.5	
#4	0	0	0	
#5	0	0	0	
#6	0	0	0	

KVB

<u>PRESSURE GAUGES</u>					
STEAM PRESSURE psig	140	140	142		
FEEDWATER psig	195	225	173		
AIR PRESSURE psig	50	50	50		
<u>CONTROLS</u>					
BOILER MASTER	50	100	50		
STOKER	50	100	50		
FORCED DRAFT	35	50	50		
OVERFIRE AIR	55	60	60		
INDUCED DRAFT	0.1	0.2	0.2		
<u>STOKER</u>					
COAL GATE POSITION					
WIND BOX POSITION #1	9.0	8.5	8.2		
#2	0	0	0		
#3	0	0	0		
#4	0	0	0		
#5	0	0	0		
#6	0	0			
OVERFIRE AIR PRESSURE "H ₂ O	4"		4"		
TEMP. F.D. FAN °F		70	70		
TEMP. F.W. °F		217	220		

KVB

Steam Flow, lbs/hr 59,463
 Coal Flow, lbs/hr 4800
 % Design Capacity 84.9
 lb steam/lb coal 12.4

PANEL BOARD DATA

ABMA TEST SITE J

TEST NO.	7			
TEST DATE	6-14-79			
TEST COAL	OH10			
TEST CONDITIONS	60,000			
<u>COAL</u>				
TIME	11:00		13:15	
POUNDS ADDED	filled		10,800	
<u>STEAM</u> Time	11:00	12:15	13:14	
INTEGRATOR READING	60635	60725	60801	
<u>CHART RECORDER</u>				
STEAM FLOW Klbs/hr	61	60		
AIR FLOW, RELATIVE	47	50		
<u>DRAFT GAUGES</u>				
WIND BOX "H ₂ O	2.0	2.2		
FURNACE "H ₂ O	-0.20	-0.20		
BOILER OUT "H ₂ O	-0.5	-0.6		
DUST COLLECTOR "H ₂ O	-4.5	-5.0		
STOKER ZONE #1	0.3	0.3		
#2	0.7	0.7		
#3	0.4	0.5		
#4	0	0		
#5	0	0		
#6	0	0		

KVB

<u>PRESSURE GAUGES</u>				
STEAM PRESSURE psig	147	140		
FEEDWATER psig	146	202		
AIR PRESSURE psig	50	50		
<u>CONTROLS</u>				
BOILER MASTER	25	60		
STOKER	25	60		
FORCED DRAFT	55	60		
OVERFIRE AIR	60	60		
INDUCED DRAFT	-0.2	-0.2		
<u>STOKER</u>				
COAL GATE POSITION	8.4	8.5		
WIND BOX POSITION #1	0	0		
#2	0	0		
#3	0	0		
#4	0	0		
#5	0	0		
#6	0	0		
OVERFIRE AIR PRESSURE "H ₂ O	4.25	4.25		
TEMP. F.D. FAN °F	80	81		
TEMP. F.W. °F	224	224		

KVB

Steam Flow, lbs/hr 5,200
 Coal Flow, lbs/hr 4,138
 % Design Capacity 73.1
 lb steam/lb coal 12.4

PANEL BOARD DATA
 ABMA TEST SITE J

TEST NO.	8			
TEST DATE	6-15-79			
TEST COAL	Kentucky			
TEST CONDITIONS	50,000			
<u>COAL</u>				
TIME	10:25			12:50
POUNDS ADDED	filled			10,000
<u>STEAM</u> Time	10:22	11:26	12:27	12:52
INTEGRATOR READING	61550	61620	61684	61710
<u>CHART RECORDER</u>				
STEAM FLOW Klbs/hr	53	52	52	
AIR FLOW, RELATIVE	40	41	42	
<u>DRAFT GAUGES</u>				
WIND BOX "H ₂ O	1.4	1.3	1.3	
FURNACE "H ₂ O	-0.2	-0.20	0.25	
BOILER OUT "H ₂ O	-0.8	-0.5	-0.5	
DUST COLLECTOR "H ₂ O	-3.2	-3.5	-3.5	
STOKER ZONE #1	0.2	0.2	0.2	
#2	0.7	0.7	0.6	
#3	0	0.1	0.1	
#4	0	0	0	
#5	0	0	0	
#6	0	0	0	

KVB

<u>PRESSURE GAUGES</u>					
STEAM PRESSURE psig	125	145	140		
FEEDWATER psig	200	165	190		
AIR PRESSURE psig	50	50	50		
<u>CONTROLS</u>					
BOILER MASTER	100	40	60		
STOKER	100	40	60		
FORCED DRAFT	45	40	45		
OVERFIRE AIR	45	45	47		
INDUCED DRAFT	-0.2	0.2	-0.2		
<u>STOKER</u>					
COAL GATE POSITION	6.8	6.7	6.9		
WIND BOX POSITION #1	0	0	0		
#2	0	0	0		
#3	0	0	0		
#4	0	0	0		
#5	0	0	0		
#6	0	0	0		
OVERFIRE AIR PRESSURE "H ₂ O		2.5			
TEMP. F.D. FAN °F		83			
TEMP. F.W. °F		224			

KVB

Steam Flow, lbs/hr 34,699
 Coal Flow, lbs/hr 47.6
 % Design Capacity 47.6
 lb steam/lb coal 12.2

PANEL BOARD DATA

ABMA TEST SITE J

TEST NO.	9			
TEST DATE	6-16-79			
TEST COAL	Kentucky			
TEST CONDITIONS	35,000			
<u>COAL</u>				
TIME	1030			13:10
POUNDS ADDED	filled			7600
<u>STEAM</u> Time	10:25	11:36	12:25	13:11
INTEGRATOR READING $\times 800$	62376	62426	62462	62496
<u>CHART RECORDER</u>				
STEAM FLOW Klbs/hr	35,000	38	35	
AIR FLOW, RELATIVE	36	38	38	
<u>DRAFT GAUGES</u>				
WIND BOX "H ₂ O	1.4	2.0	1.6	
FURNACE "H ₂ O	-0.15	-0.15	-0.15	
BOILER OUT "H ₂ O	-0.5	-0.5	-0.4	
DUST COLLECTOR "H ₂ O	-2.7	-3.5	-3.2	
STOKER ZONE #1	0.3	0.4	0.3	
#2	0.7	0.9	0.8	
#3	0	0.1	0.1	
#4	0	0	0	
#5	0	0	0	
#6	0	0	0	

KVB

<u>PRESSURE GAUGES</u>					
STEAM PRESSURE psig	142	140	140		
FEEDWATER psig	180	185	181		
AIR PRESSURE psig	50	50	50		
<u>CONTROLS</u>					
BOILER MASTER	40	50	50		
STOKER	40	50	50		
FORCED DRAFT	20	20	18		
OVERFIRE AIR	37	42	42		
INDUCED DRAFT	-0.1	-0.1	-0.1		
<u>STOKER</u>					
COAL GATE POSITION	5.7	5.8	5.7		
WIND BOX POSITION #1	0	0	0		
#2	0	0	0		
#3	0	0	0		
#4	0	0	0		
#5	0	0	0		
#6	0	0	0		
OVERFIRE AIR PRESSURE "H ₂ O	2.25				
TEMP. F.D. FAN °F	82				
TEMP. F.W. °F		224			

KVB

Steam Flow, lbs/hr 71,714
 Coal Flow, lbs/hr 5414
 % Design Capacity 102.5
 lb steam/lb coal 13.2

PANEL BOARD DATA
 ABMA TEST SITE J

TEST NO.	13			
TEST DATE	6-19-79			
TEST COAL	OHIO			
TEST CONDITIONS	2,000 lbs/hr			
<u>COAL</u>				
TIME	10:55	13:30		
POUNDS ADDED	filled	7 tons		
<u>STEAM</u> Time	12:53	13:57		
INTEGRATOR READING $\times 800$	14823	64913		
<u>CHART RECORDER</u>				
STEAM FLOW Klbs/hr	68	68		
AIR FLOW, RELATIVE	56	58		
<u>DRAFT GAUGES</u>				
WIND BOX "H ₂ O	2.0	2.0		
FURNACE "H ₂ O	-0.2	-0.2		
BOILER OUT "H ₂ O	-0.6	-0.7		
DUST COLLECTOR "H ₂ O	-5.2	-6.0		
STOKER ZONE #1	0.7	0.5		
#2	1.5	1.0		
#3	0.8	0.7		
#4	0	0		
#5	0	0		
#6	0	0		

KVB

<u>PRESSURE GAUGES</u>					
STEAM PRESSURE psig	140	135			
FEEDWATER psig	145	142			
AIR PRESSURE psig	50	50			
<u>CONTROLS</u>					
BOILER MASTER	48	60			
STOKER	50	65			
FORCED DRAFT	75	75			
OVERFIRE AIR	30	30			
INDUCED DRAFT	0.1	0.1			
<u>STOKER</u>					
COAL GATE POSITION	9.5	9.0			
WIND BOX POSITION #1	0	0			
#2	0	0			
#3	0	0			
#4	0	0			
#5	0	0			
#6	0	0			
OVERFIRE AIR PRESSURE "H ₂ O	1				
TEMP. F.D. FAN °F	75				
TEMP. F.W. °F	224				

KVB

Steam Flow, lbs/hr 68,000
 Coal Flow, lbs/hr 5876
 % Design Capacity 97.1
 lb steam/lb coal 11.6

PANEL BOARD DATA
 ABMA TEST SITE J

TEST NO.	14				
TEST DATE					
TEST COAL	OHIO				
TEST CONDITIONS	70,000 complete				
<u>COAL</u>					
TIME	11:45				
POUNDS ADDED	filled				
<u>STEAM</u> Time	11:47	12:15	12:47	13:15	13:47
INTEGRATOR READING	65813		65898		65984
<u>CHART RECORDER</u>					
STEAM FLOW Klbs/hr	70,000		63,000	68,000	70,000
AIR FLOW, RELATIVE	59		55	59	57
<u>DRAFT GAUGES</u>					
WIND BOX "H ₂ O	1.8	1.7	1.9	1.8	2.0
FURNACE "H ₂ O	-0.2	-0.2	-0.25	-0.	-0.25
BOILER OUT "H ₂ O	-0.7	-0.7	-0.7	-0.7	-0.7
DUST COLLECTOR "H ₂ O	-6.8	-7.0	-6.5	-6.5	-6.5
STOKER ZONE #1	0.4	0.4	0.6	0.7	1.0
#2	1.1	1.1	1.5	1.3	1.7
#3	0.8	0.7	0.7	1.0	1.4
#4	0	0	0	0.2	0.3
#5	0	0	0	0	0
#6	0	0	0	0	0

KVB

Steam Flow, lbs/hr 68,000
 Coal Flow, lbs/hr 5876
 % Design Capacity 97.1
 lb steam/lb coal 11.6

PANEL BOARD DATA

ABMA TEST SITE J

TEST NO.	14				
TEST DATE					
TEST COAL	OH 10				
TEST CONDITIONS	70,000				
<u>COAL</u>					
TIME					16:55
POUNDS ADDED					30,360 <i>added</i>
<u>STEAM</u> Time	14:19	14:47	15:15	15:47	16:47
INTEGRATOR READING <i>X800</i>		66068		66153	66238
<u>CHART RECORDER</u>					
STEAM FLOW Klbs/hr	68,000	68,000	70,000	67,000	
AIR FLOW, RELATIVE	58	59	59	56	
<u>DRAFT GAUGES</u>					
WIND BOX "H ₂ O	2.0	2.0	1.7	2.0	
FURNACE "H ₂ O	-2.5	-2.5	-0.2	-0.2	
BOILER OUT "H ₂ O	-0.7	-0.7	-0.70	-0.7	
DUST COLLECTOR "H ₂ O	-6.5	-6.5	-7.0	-6.5	
STOKER ZONE #1	0.7	0.7	0.3	0.5	
#2	1.5	1.5	1.0	1.2	
#3	1.2	1.2	0.8	0.8	
#4	0.3	0.3	0.1	0	
#5	0	0	0	0	
#6	0	0	0	0	

KVB

<u>PRESSURE GAUGES</u>					
STEAM PRESSURE psig	140	145	130	138	138
FEEDWATER psig	187	187	197	144	187
AIR PRESSURE psig	50	50	50	50	50
<u>CONTROLS</u>					
BOILER MASTER	71	22	100	100	90
STOKER	71	25	100	100	90
FORCED DRAFT	50	55	55	56	60
OVERFIRE AIR	100	60	100	100	70
INDUCED DRAFT	-0.2	-0.2	-0.2	-0.2	-0.2
<u>STOKER</u>					
COAL GATE POSITION	10.1	10.5	10.5	10.5	10.1
WIND BOX POSITION #1	0	0	0	0	0
#2	0	0	0	0	0
#3	0	0	0	0	0
#4	0	0	0	0	0
#5	0	0	0	0	0
#6	0	0	0	0	0
OVERFIRE AIR PRESSURE "H ₂ O		7 3/4"			
TEMP. F.D. FAN °F		80			
TEMP. F.W. °F		224			

KVB

<u>PRESSURE GAUGES</u>					
STEAM PRESSURE psig	140	140	150	135	150
FEEDWATER psig	145	189	180	180	187
AIR PRESSURE psig	50	50	50	50	50
<u>CONTROLS</u>					
BOILER MASTER	100	75		82	20
STOKER	100	75		80	45
FORCED DRAFT	55	55		45	60
OVERFIRE AIR	100	100		100	85
INDUCED DRAFT	-0.2	-0.2		-0.2	-0.2
<u>STOKER</u>					
COAL GATE POSITION	10.1	10.1	10.1	10.1	10.1
WIND BOX POSITION #1	0	0	0	0	0
#2	0	0	0	0	0
#3	0	0	0	0	0
#4	0	0	0	0	0
#5	0	0	0	0	0
#6	0	0	0	0	0
OVERFIRE AIR PRESSURE "H ₂ O	7 3/4				7 1/2
TEMP. F.D. FAN °F					80
TEMP. F.W. °F	225				230

KVB

NOTES

TEST NO:	14				
	Coal used				
	Bunker leveled at 11:45				
	pounds added	250	1980	1470	2010
		2030	2020	2100	1960
		1970	2010	2030	1970
TEST NO:		2000	1980	2000	2080
					/ total 30,760 lbs
	Bunker leveled off at 16:55				
TEST NO:					
TEST NO:					

KVB

Steam Flow, lbs/hr 65,760
 Coal Flow, lbs/hr 5143
 % Design Capacity 93.9
 lb steam/lb coal 12.8

PANEL BOARD DATA

ABMA TEST SITE J

TEST NO.	15				
TEST DATE	6-28-79				
TEST COAL	Kentucky				
TEST CONDITIONS	as found				
<u>Sass - SDx</u>					
<u>COAL</u>					
TIME	12:00	1300	14:09	15:00	16:00
POUNDS ADDED	filled				
<u>STEAM</u>					
INTEGRATOR READING	71512	71592	71688	71759	71842
<u>CHART RECORDER</u>					
STEAM FLOW Klbs/hr	66	65	63	68	70
AIR FLOW, RELATIVE	54	54	55	55	56
<u>DRAFT GAUGES</u>					
WIND BOX "H ₂ O	2.4	2.4	2.2	2.4	1.6
FURNACE "H ₂ O	-0.20	-0.20	-0.25	-0.23	-0.20
BOILER OUT "H ₂ O	-0.7	-0.7	-0.8	-0.8	-0.6
DUST COLLECTOR "H ₂ O	-5.5	-5.5	-6.5	-6.7	-5.5
STOKER ZONE #1	0.6	0.6	0.6	0.7	0.5
"H ₂ O #2	1.1	1.1	1.2	1.4	0.9
#3	0.5	0.5	0.6	0.7	0.5
#4	0	0	0	0	0
#5	0	0	0	0	0
#6	0	0	0	0	0

KVB

Steam Flow, lbs/hr 65,760
 Coal Flow, lbs/hr 5143
 % Design Capacity 43.9
 lb steam/lb coal 12.8

PANEL BOARD DATA

ABMA TEST SITE J

TEST NO.	15			
TEST DATE	6-28-79			
TEST COAL	Kentucky			
TEST CONDITIONS	as found			
<i>Sass - Sox</i>				
<u>COAL</u>				
TIME	17:00			
POUNDS ADDED	13.5 tons			
<u>STEAM</u>				
INTEGRATOR READING	71923			
<u>CHART RECORDER</u>				
STEAM FLOW Klbs/hr	66			
AIR FLOW, RELATIVE	54			
<u>DRAFT GAUGES</u>				
WIND BOX "H ₂ O	1.6			
FURNACE "H ₂ O	-0.22			
BOILER OUT "H ₂ O	-0.6			
DUST COLLECTOR "H ₂ O	-5.4			
STOKER ZONE #1	0.5			
#2	1.0			
#3	0.5			
#4	0			
#5	0			
#6	0			

KVB

<u>PRESSURE GAUGES</u>					
STEAM PRESSURE psig	145	125	135	144	145
FEEDWATER psig	180	150	160	170	170
AIR PRESSURE psig	50	50	50	50	50
<u>CONTROLS</u>					
BOILER MASTER	25	100	100	27	25
STOKER	25	60	100	27	40
FORCED DRAFT	50	75	100	45	62
OVERFIRE AIR	60	65	80	90	70
INDUCED DRAFT	0.2	-0.2	-0.2	-0.2	-0.2
<u>STOKER</u>					
COAL GATE POSITION	8.2	9.0	9.3	9.5	9.2
WIND BOX POSITION #1	0	0	0	0	0
#2	0	0	0	0	0
#3	0	0	0	0	0
#4	0	0	0	0	0
#5	0	0	0	0	0
#6	0	0	0	0	0
OVERFIRE AIR PRESSURE "H ₂ O		6.5		6.5	4.25 →
TEMP. F.D. FAN °F		80	82		
TEMP. F.W. °F		216		216	

KVB

<u>PRESSURE GAUGES</u>					
STEAM PRESSURE psig	145				
FEEDWATER psig	210				
AIR PRESSURE psig	50				
<u>CONTROLS</u>					
BOILER MASTER	25				
STOKER	30				
FORCED DRAFT	62				
OVERFIRE AIR	50				
INDUCED DRAFT	-0.2				
<u>STOKER</u>					
COAL GATE POSITION	9.5				
WIND BOX POSITION #1	0				
#2	0				
#3	0				
#4	0				
#5	0				
#6	0				
OVERFIRE AIR PRESSURE °H ₂ O					
TEMP. F.D. FAN °F					
TEMP. F.W. °F					

KVB

Steam Flow, lbs/hr 64,800
 Coal Flow, lbs/hr 5200
 % Design Capacity 92.6
 lb steam/lb coal 12.5

PANEL BOARD DATA

ABMA TEST SITE J

TEST NO.	16				
TEST DATE	6-30-74				
TEST COAL	DH10				
TEST CONDITIONS	as found				
<u>Sassd50x</u>					
<u>COAL</u>					
TIME	11:15				16:15
POUNDS ADDED	filled				13 tons
<u>STEAM</u>					
INTEGRATOR READING	11:15	12:30	13:30	14:30	16:12
<u>CHART RECORDER</u>					
					73632
STEAM FLOW Klbs/hr	70	60	65	62	65
AIR FLOW, RELATIVE	56	55	52	55	58
<u>DRAFT GAUGES</u>					
WIND BOX "H ₂ O	1.8	2.1	2.4	2.2	2.1
FURNACE "H ₂ O	-0.20	-0.20	-0.21	-0.20	-0.25
BOILER OUT "H ₂ O	-0.7	-0.7	-0.7	-0.7	-0.8
DUST COLLECTOR "H ₂ O	-6.4	-6.5	-6.3	-6.6	-7.0
STOKER ZONE #1	0.2	0.2	0.3	0.5	0.7
#2	0.7	1.8	1.0	1.0	1.5
#3	0.3	0.2	0.2	0.2	1.0
#4	0	0	0	0	0
#5	0	0	0	0	0
#6	0	0	0	0	0

KVB

<u>PRESSURE GAUGES</u>					
STEAM PRESSURE psig	137	130	130	120	125
FEEDWATER psig	162	135	147	150	178
AIR PRESSURE psig	50	50	50	50	50
<u>CONTROLS</u>					
BOILER MASTER	36	60	55	100	45
STOKER	59	90	85	65	35
FORCED DRAFT	90	90	85	85	70
OVERFIRE AIR	65	50	75	70	100
INDUCED DRAFT	-0.2	-0.2	-0.2	-0.2	-0.2
<u>STOKER</u>					
COAL GATE POSITION	8.5	8.5	8.3	9.0	9.4
WIND BOX POSITION #1	0	0	0	0	0
#2	0	0	0	0	0
#3	0	0	0	0	0
#4	0	0	0	0	0
#5	0	0	0	0	0
#6	0	0	0	0	0
OVERFIRE AIR PRESSURE "H ₂ O	6		6		8 1/2
TEMP. F.D. FAN °F	75		75		73
TEMP. F.W. °F	216		216		217

SECTION 2.0
PARTICULATE DATA

	<u>PAGE</u>
2.1 PARTICULATE DATA SUMMARY	32
2.2 PARTICULATE DATA	34
2.3 PARTICULATE LAB WORKSHEETS	50

BLR OUT AREA = 30.65 ft²
 STACK AREA = 18.35 ft²

PARTICULATE DATA SUMMARY
 PART I

LOCATION: ABMA TEST SITE J

TEST NO.	Total Mass mgm.	Dry Gas Volume ft ³	Liquid Coll. ml.	Baro. Press. "Hg	Static Press. "H ₂ O	Pitot ΔP "H ₂ O	Orifice ΔH "H ₂ O	Stack Gas Temp. °R	Excess O ₂ %	Sampling Time min.	Nozzle Dia. in.	Pitot Factor n.d.	Fuel Factor SCF/10 ⁶ BTU	Flue Gas MW g/g mole
BLR 01	428.1	48.57	59	29.52	-0.18	0.705	1.29	934	10.2	60.17	0.378	0.837	9634	28.85
STACK 01	125.3	43.582	50.5	29.52	-0.12	0.092	0.63	779	9.7	72.42	0.375	0.817	9634	28.95
BLR 02	976.7	55.354	59.8	29.42	-0.625	0.493	1.55	970	10.6	60.5	0.316	0.837	9773	29.15
STACK 02	432.1	10.897	127	29.36	-0.02	0.20	1.34	820	10.8	120	0.377	0.817	9773	29.05
BLR 05	1313.6	34.074	59	29.55	-2.0	0.65	0.61	1008	7.9	60	0.235	0.837	10453	29.04
STACK 05	284.7	47.897	74	29.70	-0.26	0.243	0.75	827	8.3	72	0.312	0.817	10453	29.11
BLR 06	1811.5	88.781	100	29.88	-1.25	0.59	1.62	1040	8.1	98.23	0.316	0.837	9553	29.34
STACK 06	303.9	60.202	80	29.88	-0.26	0.22	0.67	816	8.7	96	0.312	0.817	9553	29.20
BLR 07	635.9	50.867	78	29.85	-1.25	0.46	1.31	969	8.7	60	0.316	0.837	9804	29.09
STACK 07	1783	41.189	63	29.85	-0.21	0.185	0.56	800	9.2	72	0.312	0.817	9804	29.06
BLR 08	632.5	40.699	69	29.80	-0.625	0.747	0.837	943	9.0	60	0.316	0.837	9537	28.85
STACK 08	143.9	47.375	72	29.80	-0.06	0.105	0.769	777	9.2	72	0.377	0.817	9537	29.11
BLR 09	440.2	40.627	52	29.69	-0.78	0.26	0.83	920	12.7	60	0.316	0.837	10721	28.95
STACK 09	150.6	42.458	59	29.69	-0.12	0.087	0.62	763	11.5	72	0.377	0.817	10721	28.95
BLR 13														
STACK 13														
BLR 14	272.67	105.410	149	29.67	-2.0	0.58	3.7	998	8.8	80.23	0.377	0.837	10013	29.19
STACK 14	428.4	74.664	130	29.67	-0.28	0.216	0.68	821	9.0	120	0.313	0.817	10013	28.97

PARTICULATE DATA SUMMARY
PART II

Location ASMA TEST SITE I - corrected

TEST NO.	LOAD %	O ₂ %	CONDITIONS	EMISSIONS			Moisture %	Stack Gas Velocity Ft/sec	Stack Gas Flow SCF/sec	Isokin. %
				lb/10 ⁶ BTU	GR/SCF	LB/HR				
BLR OUT 01	48.2	10.2	OHIO COAL AS FOUND	0.369	0.137	41	5.50	33.96	582	95
STACK 01	48.2	9.7	↓	0.115	0.045	6	5.27	20.23	249	101
BLR OUT 02	73.8	10.6	↓	0.779	0.276	125	4.93	53.47	879	101
STACK 02	73.8	10.8	↓	0.188	0.065	12	5.56	30.62	356	100
BLR OUT 05	102.6	7.9	LOW O ₂	1.442	0.602	307	7.66	62.67	993	104
STACK 05	102.6	8.3	↓	0.228	0.092	19	6.86	33.68	393	104
BLR OUT 06	98.6	8.1	KENTUCKY COAL AS FOUND	0.699	0.314	153	5.06	59.08	946	95
STACK 06	98.6	8.7	↓	0.182	0.078	15	5.92	31.69	377	102
BLR OUT 07	94.9	9.7	OHIO COAL	0.462	0.193	85	6.77	51.34	856	100
STACK 07	94.9	9.2	↓	0.167	0.067	12	6.77	28.85	350	101
BLR OUT 08	73.1	9.0	KENTUCKY COAL	0.574	0.240	87	7.45	40.87	700	98
STACK 08	73.1	9.2	↓	0.114	0.047	6	6.73	21.42	267	104
BLR OUT 09	49.6	12.2	↓	0.617	0.168	57	5.75	37.78	661	102
STACK 09	49.6	11.5	↓	0.185	0.054	7	6.15	19.41	245	102
BLR OUT 14	97.1	8.8	OHIO COAL HIGH O ₂	0.984	0.399	193	6.28	58.64	942	98
STACK 14	97.1	9.0	↓	0.224	0.089	17	7.67	31.73	373	103

PARTICULATE

DATA

Leak Check Rate

ISOKINETICS = _____

TEST NUMBER 1

Vac in. Hg ft³/min

DATE 5-3-79

Sampling Time Per Point, Min
3.0

Before
After

OPERATOR T.A.P

FUEL OHIO

SITE J

PROBE LOCATION STACK

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F						O ₂ , %	Vac.
		Δ P _s	Δ H	Meter Reading	Stack	Probe	Oven	Impingers		Meter		
								In	Out			
ME-1	1330	.08	.58	5298.62	318	240	310		88	85		22.0
2		.08	.58	5300.35	315	250	310		80	100		22.0
3		.11	.80	5302.33	320	255	310		80	100		2.0
4		.12	.87	5304.38	320	250	310		75	100		2.0
5		.13	.90	5306.45	320	250	300		80	102		2.0
6		.13	.90	5308.51	320	255	300		82	108		2.0
7		.10	.70	5310.38	320	260	290		78	102		22.0
8		.07	.48	5311.81	310	255	285		75	105		22.0
9		.07	.48	5313.35	310	250	270		82	110		22.0
10		.07	.48	5314.75	310	250	285		80	115		22.0
11		.07	.48	5316.59	310	250	290		80	118		2.0
12		.07	.48	5317.68	—	250	285		82	118		22.0
ME-1		.09	.60	5319.40	320	220	270		82	115		22.0
2		.10	.68	5321.20	320	220	270		82	118		22.0
3		.11	.75	5323.06	325	250	270		88	120		22.0
4	325	.11	.75	5325.13	330	250	265		88	118		22.0
5		.12	.82	5327.10	330	250	260		80	118		22.0
6		.11	.75	5328.97	325	250	270		80	115		22.0
7		.09	.60	5330.60	322	250	270		82	115		22.0
8		.06	.41	5332.02	320	250	275		85	115		22.0
9		.10	.68	5333.76	320	260	265		90	115		22.0
10		.09	.60	5335.49	318	250	270		90	115		22.0
11		.05	.34	5336.73	—	235	270		90	115		22.0
12		.08	.55	5338.404	—	250	290		90	120		22.0
Average		.092	.63	43.582	319							

Nomograph Setup

METER VOL. END 5338.404
START 5296.960
SAMPLE VOL. 43.582 ft³

C pitot	Stack Press. In. Hg-Gauge	Barometric Pressure
.837	29.52	

Percent O₂ = 0.12

P_{meter} = C
P_{stack} = T_{stack}
T_{meter} = ΔP
ΔHg = Noz(Ideal) =
% H₂O = 5.3 Noz(Actual) = .375

Imp.	Vol. (End)	Vol. (Start)	ΔVol. (ml)
#1	135	100	33
#2	105	100	5
#3	0	0	0
Total			38
#4	g(End)	g(Start)	Δgrams
Silica Gel	148.5	130	12.5
Total Vol. H ₂ O			50.5 ml

PARTICULATE

DATA

Leak Check Rate

ISOINETICS = 102

TEST NUMBER 2

Vac in. Hg ft³/min

DATE 6-4-79

Sampling Time Per Point, Min
7 1/2

Before
After

OPERATOR J J

FUEL 0410

SITE J

PROBE LOCATION Buick-Out #4

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F							
		ΔPs	ΔH	Meter Reading	Stack	Probe	Oven	Impingers		Meter	O ₂ %	Vac.
								In	Out			
1		.52	1.61	5351.36	500	200	250			110		5.2
2		.57	1.80	5357.85	500	200	250			110		9.8
3		.49	1.51	5364.43	480	200	280			120		9.8
4		.48	1.50	5371.47	500	200	280			123		9.8
5	*	.50	1.58	5450.00 5686.70	540	200	260			105		10.0
6		.54	1.70	5693.64	530	200	300			105		11.3
7		.50	1.58	5700.71	530	200	280			110		10.0
8		.34	1.10	5706.33	500	190	310			115		20
60.5												
Average		0.4925	1.5475		510F	470R						

Nomograph Setup

METER VOL. END
START 5344.37
SAMPLE VOL. ft³

Stack Press. In. Hg-Gauge
Barometric Pressure
837 -0.025" Hg 29.42

Percent O₂ =

P_{meter} = C
P_{stack} = T_{stack}
T_{meter} = ΔP
ΔH_g = Noz (Ideal) =
Noz (Actual) = .316
H₂O = 5.1
V_s = 5317
P = .6

Imp.	Vol. (End)	Vol. (Start)	ΔVol. (ml)
#1	138	100	38
#2	108	100	8
#3	0	0	0
Total			46
Imp.	c (End)	c (Start)	Δgrams
#4	143.8	130	13.8
Total Vol. H ₂ O			59.8 ml

PARTICULATE

DATA

Leak Check Rate

ISOKINETICS = 957

TEST NUMBER 2 1st comp.

DATE 6-4-79

OPERATOR R.H.P.

FUEL OHIO

SITE J

PROBE LOCATION Stack

Sampling Time Per Point, Min.
5.0

Vac
in. Hg ft³/min
Before
After

Sample Point	Time	METER CONDITIONS			TC		TEMPERATURES, °F				O ₂ , %	Vac.	
		ΔP _s	ΔH	Meter Reading	Stack	Probe	Oven	Impingers		Meter			
								In	Out				
NE 1	14:25	.19	1.30	2929.36	355	250	295		70	98			2.2
2		.19	1.30	2933.67	350	260	350		70	98			2.2
3		.24	1.55	2938.33	355	260	310		73	100			2.8
4		.23	1.50	2942.95	355 345	260	305		72	100			2.7
5		.23	1.50	2947.47	355	265	295		76	102			2.5
6		.23	1.50	2952.00	355 348	260	285		75	105			3.0
7		.19	1.30	2956.28	360	260	290						
8		.19	1.30	2960.43	360	260	285		78	110			2.4
9		.18	1.150	2964.42	355	260	285		70	105			2.3
10		.18	1.15	2968.39	355 344	260	285		70	110			2.3
11		.18	1.15	2972.37	350	260	280		70	110			2.3
12		.13	.85	2975.79	350	250	270		72	110			2.2
NW 1		.21	1.35	2980.23	355 364	260	280		70	105			3.3
2		.22	1.42	2984.58	360 364	260	290		75	110			3.2
3		.23	1.50	2989.11	360	270	285		78	105			3.4
4		.23	1.50	2994.03	352 365	270	285		72	100			3.4
5		.21	1.45	2998.34	360	270	285		72	101			3.4
6		.23	1.60	3003.12	353 360	270	285		72	100			3.6
7		.21	1.50	3007.65	360	270	285		72	98			3.3
8		.20	1.40	3012.09	365 370	260	285		72	98			3.2
9		.20	1.40	3016.54	370	250	275		72	98			3.5
10		.14	1.35	3020.93	370	250	280		73	100			3.3
11		.19	1.35	3025.28	365	260	280		73	100			3.8
12		.13	.90	3028.905	365	270	285		73	99			2.8
Average		.120	1.34	103.697	360					98			

Nomograph Setup:

METER VOL. END 3028.905
START 2925.008
SAMPLE VOL. 103.897

C _{pitot}	Stack Press. In. Hg-Gauge	Barometric Pressure
.817	-.0214	29.36

Percent O₂ =

P_{meter} = C = Imp. Vol. (End) Vol. (Start) ΔVol. (ml)
P_{stack} = T_{stack} = #1 172 - 100 = 72
T_{meter} = ΔP = #2 135 - 100 = 35
ΔHg = 5.5 Noz (Ideal) = .377 #3 1 - 0 = 1
% H₂O = Noz (Actual) = Total 108

#4 c(End) c(Start) μgrams
S. Sica (a) 210 - 200.0 = 10
Total Vol. H₂O 127 ml

PARTICULATE

DATA

Leak Check Rate

ISOKINETICS = 105

TEST NUMBER 5

Vac
in. Hg ft³/min

DATE 6-13-79

Sampling Time
Per Point, Min
7 1/2

Before
After

OPERATOR JD

FUEL Oil

SITE J

PROBE LOCATION Bunker

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F							O ₂ , %	Vac.
		ΔP _s	ΔH	Meter Reading	Stack	Probe	Oven	Impingers		Meter			
								In	Out				
1		.56	.53	5725.98	550	150	280			100		4.1	
2		.72	.68	5730.49	560	150	310			100		4.6	
3		.70	.65	5734.75	560	180	300			100		5.0	
4		.58	.55	5738.73	520	150	300			100		4.5	
5	*	.60	.56	5371.98 5370.15								5.0	
6		.68	.64	5379.67								5.2	
7		.72	.67	5384.15								5.5	
8		.64	.60	5388.34								5.0	
Average		.65	.61	16.870 17.204	548								

1.056

METER VOL. END []
START 5721.86
SAMPLE VOL. 34.074 ft³

C _{pitot}	Stack Press. In. Hg-Gauge	Barometric Pressure
.837	-2.0" H ₂ O	29.70

Percent O₂ = []

Nomograph Setup:

P _{meter}	C	Imp.	Vol. (End)	Vol. (Start)	ΔVol. (ml)
#1		#1	142	100	42
#2		#2	108	100	8
#3		#3	0	0	0
Total					50

ΔH₂O = 7.6 Noz (Actual) = .235

P = 2.0

38

Silica α	g(End)	g(Start)	Δgrams
#4	139	130	9
Total Vol. H ₂ O			59 ml

PARTICULATE

DATA

Leak Check Rate _____ ISOKINETICS = 90.2
 Vac _____
 in. Hg _____ ft³/min _____

Sampling Time
 Per Point, Min
3.0

Before _____
 After _____

TEST NUMBER 5
 DATE 6-18-77
 OPERATOR RAP
 FUEL OHIO
 SITE J
 PROBE LOCATION STACK-#4

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F						O ₂	Vac.
		ΔP _s	ΔH	Meter Reading	Stack	Probe	Oven	Impingers		Meter		
								In	Out			
NE-1	15:30	.30	.96	3042.57	365	220	300		68	75		3.5
2		.33	1.05	3045.02	370	250	300		65	75		3.8
3		.32	1.01	3047.36	370	260	305		68	78		3.5
4		.29	.93	3049.62	375	240	305		65	80		3.2
5		.28	.90	3051.86	380	250	300		67	80		3.2
6		.26	.84	3054.05	380	250	295		63	80		3.0
7		.24	.77	3056.12	380	260	290		63	83		5.0
8		.21	.67	3058.02	370	260	290		62	82		2.8
9		.20	.64	3059.86	365	255	295		63	83		2.4
10		.24	.73	3061.04	370	250	295		63	83		2.6
11		.20	.60	3063.12	360	250	290		62	83		2.2
12		.17	.52	3065.32	—	245	285		62	80		2.0
NW-1		.28	.85	3067.41	365	220	250		72	90		2.0
2		.27	.81	3069.48	365	250	255		68	90		3.0
3		.26	.79	3071.50	365	280	270		65	91		3.0
4		.26	.79	3074.52	360	285	272		65	92		2.9
5		.25	.75	3075.49	360	280	275		68	92		2.8
6		.25	.75	3077.46	360	280	275		68	92		2.8
7		.23	.70	3079.35	360	280	275		70	92		2.8
8		.21	.64	3081.14	365	280	275		70	92		2.5
9		.21	.64	3082.94	365	280	275		70	93		2.5
10		.22	.67	3084.76	365	270	270		71	95		2.5
11		.22	.67	3086.59	360	275	275		71	96		2.5
12		.15	.46	3088.125	—	270	270		71	96		2.0
Average		.243	.75	41.897	367				87 →			

3040.228 Nomograph Setup

METER VOL. END	START	3040.228	P _{meter} =	C	Imp.	Vol. (End)	Vol. (Start)	ΔVol. (ml)
SAMPLE VOL.		ft ³	P _{stack} =	T _{stack} =	#1	149	100	49
C _{pitot}	Stack Press. In. Hg-Gauge	Barometric Pressure	T _{meter} =	ΔP =	#2	114	100	14
	817.26	29.70	ΔHg =	Noz (Ideal) =	#3	0	0	0
Percent O ₂ =			% H ₂ O =	Noz (Actual) =	Total			
					312 #4	q (End)	q (Start)	Δgrams
					39 Silica Gel	211	200	11
								Total Vol. H ₂ O 14 ml

PARTICULATE

DATA

Leak Check Rate ISOKINETICS = 96.0
 Vac in. Hg ft³/min

TEST NUMBER 6
 DATE
 OPERATOR JD
 FUEL Kent
 SITE J
 PROBE LOCATION Boiler out

Sampling Time
 per Point, Min
10

Before
 After

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F						O ₂ , %	Vac.
		ΔP _s	ΔH	Meter Reading	Stack	Probe	Oven	Impingers		Meter		
								In	Out			
* A1	10	.48	1.31	5401.68	1							5.7
1.0516 2	10	.52	1.41	5410.10	550							6.2
3	13	.69	1.90	5422.35	1							8.5
4	13	.74	2.00	5434.42	1							9.0
				5746.75	1							
+14 Sec A5	13	.54	1.50	5758.27		180	208			98		7.5
6	13	.61	1.70	5770.15								
7	13	.65	1.80	5782.13		220	220			120		7.2
8	13	.50	1.40	5792.51	↓							
Average		.59	1.62	43021 45.760	550							

METER VOL. END 5342.51
 START
 SAMPLE VOL. 88.2 ft³

C _{PI} (Std)	Stack Press. in. Hg-Gauge	Barometric Pressure
.837	-1.25 1/4	29.58

Percent O₂ =

Meter corr B* 1.05%

Memorandum Setup

Imp.	Vol. (End)	Vol. (Start)	ΔVol. (ml)
#1	140	100	40
#2	128	100	28
#3	0	0	0
Total			68
#4	162	130	32
Total Vol. H ₂ O			100 ml

F_{meter} = C =
 P_{stack} = T_{stack} =
 T_{meter} = ΔP =
 W_{H₂O} = 5.0 Noz (Actual) = .316
 Y = .68 **40**

PARTICULATE

DATA

Leak Check Rate

ISOKINETICS - _____

TEST NUMBER

6

Vac
in. Hg ft³/min

DATE

6-13-79

Sampling Time
Per Point, Min
4.0

Before
After

OPERATOR

P.A.P.

FUEL

MENT.

SITE

J

PROBE LOCATION STAR#4

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F						O ₂ , %	Vac.
		ΔP _s	ΔH	Meter Reading	Stack	Probe	Oven	Impingers		Meter		
								In	Out			
WE-1	11.11	.25	.78	3091.07	355	260	260		70	82		2.8
2		.17	.53	3093.38	350	265	265		65	82		2.2
3		.23	.72	3096.02	345	265	270		55	82		2.5
4		.23	.72	3098.65	355	250	280		55	85		2.5
5		.23	.72	3101.32	350	265	280		53	85		2.5
6		.23	.72	3103.95	350	265	280		53	88		3.5
7		.21	.65	3106.42	355	255	270		58	90		3.5
8		.19	.61	3108.79	360	260	260		57	92		3.0
9		.23	.72	3111.42	355	245	245		60	91		3.8
10		.21	.65	3113.94	350	250	250		58	91		3.5
11		.21	.65	3116.43	350	255	250		58	91		3.5
12		.16	.50	3118.60	—	260	250		58	92		2.8
NU-1		.24	.75	3121.32	355	220	230		62	95		
2		.26	.81	3124.06	360	255	245		58	95	*	4.0
3		.25	.74	3126.64	360	285	250		59	96		3.9
4		.28	.82	3129.38	360	280	260		59	97		4.0
5		.25	.74	3131.96	365	280	270		62	98		3.8
6		.25	.74	3134.52	365	280	270		62	100		3.9
7		.22	.64	3136.93	365	280	270		63	101		3.5
8		.22	.64	3139.35	360	280	275		63	102		3.5
9		.22	.64	3141.73	360	280	280		64	102		3.5
10		.22	.64	3144.17	360	275	285		65	102		3.5
11		.21	.62	3146.49	355	280	285		67	104		3.2
12		.15	.44	3148.46	—	275	300		68	105		3.4
Average		.22	.67	60.202	356					93.6		

Nomograph Setup

METER VOL. — END
START 2088.266
SAMPLE VOL. _____ ft³

C _{Pitot}	Stack Press. In. Hg-Gauge	Barometric Pressure
.817	-.26 W.P.	29.88

Percent O₂ = _____

P_{meter} = C =
P_{stack} = T_{stack} =
T_{meter} = ΔP =
ΔHg = Noz(Ideal) =
% H₂O = Noz(Actual) = .312

Imp.	Vol. (End)	Vol. (Start)	ΔVol. (ml)
#1	154	100	54
#2	112	100	12
#3	1	0	1
Total			67

*NOMO CHANGE .63

41

#4	g(End)	g(Start)	Δgrams
Silica Gel	143	130	13
Total Vol. H ₂ O			80 ml

PARTICULATE

DATA

Leak Check Rate

ISOkinetics = 100%

TEST NUMBER 7

Vac in. Hg ft³/min

DATE 6-14-79

Sampling Time Per Point, Min
7 1/2

Before
After

Filter #115

OPERATOR J.D.

FUEL OIL

SITE J

PROBE LOCATION 3, 11, 20, 24

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F					O ₂ , %	Vac.
		ΔP _s	ΔH	Meter Reading	Stack	Probe	Oven	IMDINGS			
								In	Out		
A 1		.32	.91	5811.65	510	150	310			100	4.1
2		.47	1.35	5817.62	520	180	310			101	5.2
3		.50	1.41	5823.90	535	180	300			110	5.3
4		.40	1.13	5829.50	490	180	300			110	4.5
				5445.00							
* B 1		.48	1.37	5451.34	500	150	250			110	5.1
2		.49	1.40	5457.59	520	200	270			111	5.3
3		.53	1.50	5464.11	500	210	300			118	6.0
4		.50	1.41	5470.34	500	195	300			122	5.5
Average		.46	1.31	24.22 26.647	969						

METER VOL. END []
START 5805.28
SAMPLE VOL. 62.627 ft³

C _{pitot}	Stack Press. In. Hg-Gauge	Barometric Pressure
.837	-1.25	29.85

Percent O₂ = []

Nomograph Setup

P_{meter} = C
P_{stack} = T_{stack}
T_{meter} = ΔP
ΔH_g = Noz(Ideal) =
% H₂O = Noz(Actual) = .316
V = .60

Imp.	Vol. (End)	Vol. (Start)	ΔVol. (ml)
#1	153	100	53
#2	112	100	12
#3	0	0	0
Total			65

#4	e(End)	e(Start)	Δgrams
Silica Ge	143	130	13
Total Vol. H ₂ O			78 ml

* meter corr. 1.0516

42

PARTICULATE

DATA

Leak Check Rate

ISOKINETICS = _____

TEST NUMBER 7

Vac
in. Hg ft³/min

DATE 6-14-79

Sampling Time
Per Point, Min
3.0

Before
After

OPERATOR RAP

FUEL KENT.

SITE J

PROBE LOCATION STACK #4

Filter # 10

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F							O ₂ , %	Vac.
		Δ P _s	Δ H	Meter Reading	Stack	Probe	Oven	Impingers		Meter			
								In	Out				
NE-1	11:00	.16	.48	3154.128	330	265	310		70	82			2.3
2		.18	.55	3155.86	330	260	320		68	82			2.5
3		.19	.59	3157.63	335	260	300		65	84			2.6
4		.18	.55	3159.39	335	260	295		65	84			2.5
5		.20	.61	3161.25	335	260	285		62	87			2.6
6		.21	.64	3163.09	340	260	280		63	89			2.9
7		.20	.61	3164.91	340	255	280		63	90			2.8
8		.18	.55	3166.61	340	260	280		63	92			2.5
9		.17	.52	3168.32	340	255	280		65	92			2.4
10		.17	.52	3169.95	340	260	270		68	94			2.4
11		.17	.52	3171.1	335	260	270		67	95			2.4
12		.15	.46	3173.20	—	255	275		67	98			2.0
NW-1		.20	.61	3175.01	340	220	250		71	100			2.7
2		.20	.61	3176.79	—	—	—		—	—			—
3		.21	.64	3178.61	345	270	270		65	100			2.8
4		.21	.64	3181.44	345	265	265		66	100			2.8
5		.22	.66	3182.28	345	260	270		66	100			3.0
6		.21	.64	3184.09	345	265	270		68	101			3.0
7		.19	.57	3185.75	—	—	—		—	—			—
8		.19	.57	3187.45	345	260	270		70	102			2.5
9		.20	.60	3189.17	350	280	270		70	102			2.6
10		.18	.54	3190.79	345	280	270		68	103			2.8
11		.16	.48	3192.35	340	250	270		68	105			2.3
12		.11	.33	3193.622	—	250	270		68	105			2.0
Average		.185	.56	41.189	340	—	—		—	95			—

Nomograph Setup

METER VOL. END 3152.433
START 3152.433
SAMPLE VOL. ft³

C _p tot	Stack Press. In. Hg-Gauge	Barometric Pressure
.817	-.2172°	29.85

Percent O₂ =

P_{meter} = C
P_{stack} = T_{stack}
T_{meter} = ΔP
ΔHg = Noz(Ideal)=
% H₂O = Noz(Actual)=

Imp.	Vol. (End)	Vol. (Start)	ΔVol. (ml)
#1	144	100	44
#2	109	100	9
#3	1	0	1
Total			54
#4	g(End)	g(Start)	Δgrams
Silica Cel	139	130	9
Total Vol. H ₂ O			63 ml

PARTICULATE

DATA

Leak Check Rate

ISOKINETICS = _____

TEST NUMBER 8

Vac
in. Hg ft³/min

DATE 6-15-76

Sampling Time
Per Point, Min
7 1/2

Before
After

OPERATOR JD

FUEL Kent

SITE J

PROBE LOCATION Duileout

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F					O ₂ %	Vac.	
		ΔP _s	ΔH	Meter Reading	Stack	Probe	Oven	Impingers				Meter
								In	Out			
B 1		.30	.85	5479.91	460	150	280			105	3.9	
2		.29	.81	5485.80	480	180	290			110	3.7	
3		.32	.90	5489.83	460	190	290			115	4.0	
4		.34	.96	5495.13	480	150	300			120	4.2	
				5841.22								
A 1		.26	.74	5845.48	480	150	250			100	3.9	
2		.30	.85	5851.04	500	190	280			100	4.1	
3		.28	.79	5855.85	510	180	280			105	4.0	
4		.28	.74	5860.55	440	170	300			110	4.1	
Average		0.297	0.837	21.368 ⁵ 1933	483°F							

METER VOL. END []
START 5474.81
SAMPLE VOL. 21.368 ft³

C _p tot	Stack Press. in. Hg-Gauge	Barometric Pressure
.837	-5/8	29.80

Percent O₂ = []

Nomograph Setup

F_{meter} = C =
P_{stack} = T_{stack} =
T_{meter} = Δt =
ΔHg = Noz (Ideal) =
% H₂O = 8.6 Noz (Actual) = .316

F = .66

* meter corr. 1.0516

Imp.	Vol. (End)	Vol. (Start)	ΔVol. (ml)
#1	150	100	50
#2	109	100	9
#3	0	0	0
Total			59

#4	g (End)	g (Start)	grams
Silica Gel	140	130	10
Total Vol. H ₂ O			69 ml

PARTICULATE

DATA

Leak Check Rate

ISOKINETICS = _____

TEST NUMBER **B**

Vac in. Hg ft³/min

DATE **6-5-79**

Sampling Time Per Point, Min
3.0

Before
After

6-11-1145

OPERATOR **RAP**

FUEL **VENT.**

SITE **J**

PROBE LOCATION **Stack #4**

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F							O ₂ %	Vac.
		ΔP _s	ΔH	Meter Reading	Stack	Probe	Oven	Impingers		Meter			
								In	Out				
NE-1	10:25	.09	.70	3198.25	310	250	290		80	85		4.8	
2		.11	.85	3200.39	310	260	285		70	86		5.5	
3		.09	.70	3202.35	310	260	290		70	88		4.8	
4		.10	.75	3204.33	315	240	250		78	90		4.7	
5		.12	.90	3206.52	320	250	250		68	90		5.5	
6		.14	1.05	3208.89	320	260	255		70	90		6.1	
7		.12	.90	3211.09	320	260	255		70	91		5.2	
8		.12	.90	3213.27	320	260	255		71	95		5.2	
9		.10	.75	3215.23	320	265	260		72	95		4.5	
10		.09	.67	3217.07	320	265	255		72	97		4.0	
11		.09	.67	3218.90	310	260	255		70	100		3.8	
12		.05	.38	3220.32	—	265	260		70	100		2.3	
NW-1		.10	.75	3222.29	310	220	220		78	100		4.5	
2		.10	.75	3224.29	315	240	240		70	101		4.5	
3		.12	.85	3226.35	320	250	240		72	101		4.8	
4		.11	.78	3228.31	320	255	245		72	102		4.5	
5		.10	.71	3230.18	322	260	250		72	102		4.0	
6		.13	.92	3232.32	325	260	255		71	102		5.0	
7		.12	.85	3234.37	320	255	260		70	103		4.8	
8		.13	.92	3236.47	320	255	260		72	103		4.8	
9		.12	.85	3238.53	320	255	265		72	103		4.7	
10		.12	.85	3240.58	320	255	275		72	103		4.7	
11		.09	.64	3242.37	315	250	280		73	104		3.6	
12		.05	.36	3243.653	—	250	275		75	105		2.0	
Average		.105	.764	47.315	317								

Nomograph Setup

METER VOL.	END	START
		3198.278
SAMPLE VOL.		ft ³
C _{pitot}	Stack Press. In. Hg-Gauge	Barometric Pressure
.817	.06 H ₂ O	29.80
Percent O ₂		

	Imp.	Vol. (End)	Vol. (Start)	ΔVol. (ml)
P _{meter} = C	#1	152	100	52
P _{stack} = T _{stack}	#2	110	100	10
T _{meter} = ΔP	#3		0	
ΔH _g = Noz(Ideal) =				
% H ₂ O = 6.7				
				Total 62
	#4	g(End)	g(Start)	Δgrams
Silica Gel		140	130	10
				Total Vol. H ₂ O 12 ml

26
45

PARTICULATE

DATA

Leak Check Rate

ISOkinetics = _____

TEST NUMBER 9

Vac
in. Hg ft³/min

DATE 6-16-74

Sampling Time
Per Point, Min
7 1/2

Before
After

OPERATOR J.J.

FUEL Kent.

SITE J

PROBE LOCATION Boiler Out

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F				O ₂ %	Vac.	
		ΔP _s	ΔH	Meter Reading	Stack	Probe	Oven	In. Dingers			Meter
								In	Out		
A 1		.24	.68	5878.77	460	150	240			100	2.8
2		.27	.77	5883.55	480	180	270			105	3.0
3		.22	.62	5887.83	480	190	290			110	2.6
4		.24	.68	5892.26	460	180	300			112	2.8
				5500.00							
* B 1		.28	.79	5505.90	440	150	200			111	2.8
2		.31	.87	5510.98	460	180	250			195	3.0
3		.42	1.20	5515.85	460	180	290			120	3.7
4		.38	1.09	5521.46	440	180	320			122	3.5
Average		.26	.83		420R						

METER VOL. END
START
SAMPLE VOL. ft³

Pitot	Stack Press. in. Hg Gauge	Barometric Pressure
.837	-.78" H ₂ O	29.69

Percent O₂ =

Nemograph Setup:

P _{meter} =	C	=	PH 1.6	#1	Imp. Vol. (End)	Vol. (Start)	ΔVol. (ml)
P _{stack} =	T _{stack}	=	PH 2.5	#2	135	100	35
T _{meter} =	ΔP	=			107	100	7
ΔH _g =	Noz (Ideal) =	#3			0	0	0
% H ₂ O =	Noz (Actual) =	.316					Total 42

γ = .66

* meter corr 1.0516
Initial Imp Water pH 5.3

#4	c (End)	o (Start)	Δgrams
Silica Cal	170	130	40
Total Vol. H ₂ O			52 ml

PARTICULATE

DATA

Leak Check Rate

ISOKINETICS = _____

TEST NUMBER 9

Vac
in. Hg ft³/min

DATE 6-16-75

Sampling Time Per Point, Min
<u>3.0</u>

Before
After

OPERATOR RAP
FUEL Kent.
SITE J
PROBE LOCATION Stack

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F						O ₂ %	Vac.
		ΔP _s	ΔH	Meter Reading	Stack	Probe	Oven	Impingers		Meter		
								In	Out			
NE ₁	10:18	.08	.56	3249.62	300	280	320	72	90			2.5
2		.08	.56	3251.87	300	260	320	70	90			2.4
3		.09	.64	3253.28	300	260	320	68	91			2.9
4		.11	.78	3255.32	300	265	315	70	91			3.2
5		.11	.78	3257.35	305	265	310	70	92			3.2
6		.10	.71	3259.31	305	260	310	70	92			3.0
7		.09	.64	3261.18	305	265	310	71	93			2.8
8		.06	.43	3262.68	305	260	305	70	97			2.0
9		.07	.50	3264.36	295	265	305	65	95			2.2
10		.05	.36	3265.68	295	265	310	62	97			2.0
11		.05	.36	3267.13	290	260	300	61	97			2.0
12		.05	.36	3268.48	—	260	300	60	98			2.0
1		.07	.50	3270.14	305	220	280	72	102			—
2		.09	.64	3272.00	305	250	280	65	102			2.7
3		.11	.78	3274.01	305	270	275	68	102			2.0
4		.12	.85	3276.14	305	260	280	68	103			3.3
5		.10	.71	3278.05	310	260	270	67	103			2.9
6		.11	.77	3280.62	305	265	275	65	102			3.1
7		.14	1.0	3287.27	310	270	275	63	103			4.0
8		.12	.85	3284.35	315	265	270	68	110			3.8
9		.10	.71	3286.30	310	260	270	70	110			3.3
10		.07	.50	3287.86	310	250	270	70	110			2.3
11		.07	.50	3289.46	300	250	270	70	110			2.3
12		.05	.36	3290.808	—	250	265	71	111			2.0
Average		.087	.62	42.958	303F				95F			

METER VOL.	END	
	START	
SAMPLE VOL.		ft ³
C _{total}	Stack Press. In. Hg-Gauge	Barometric Pressure
.817	-.12	29.69
Percent O ₂		

Nomograph Setup

P _{meter} =	C	Imp.	Vol. (End)	Vol. (Start)	ΔVol. (ml)
P _{stack} =	T _{stack} = pH 1.601		140	100	40
T _{meter} =	ΔP = pH 25.02		108	100	8
ΔHg =	Noz (Ideal) = .377 #3		1	0	1
% H ₂ O =	Noz (Actual) =				Total 49

#4	g (End)	g (Start)	Δgrams
Silica (el)	140	130	10
			Total Vol. H ₂ O 59 ml

Initial Imp. pH 5.3

47

PARTICULATE

DATA

Leak Check Rate

ISOTHERMICS

TEST NUMBER

Vac
in. Hg ft³/min

DATE

OPERATOR

FUEL

SITE

PROBE LOCATION

Sampling Time
Per Point, Min
10

Before
After

M-1701A
JD
air
Dieter 05

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F							O ₂ %	Vac.
		ΔP _s	ΔH	Meter Reading	Stack	Probe	Oven	Infinders		Meter			
								In	Out				
A	1	.56	3.50	5916.00	530	250	340				100		12.0
	2	.68	4.30	5930.54	530	250	340				105		15.0
	3	.50	3.20	5943.45	530	250	310				105		11.0
	4	.52	3.30	5956.30	520	250	300				110		12.0
B	1	5.0	3.20	5969.15	520	180	290				110		12.5
	2	6.8	4.30	5983.23	540	260	280				110		22.0
	3	7.0	4.40	5996.47	590	290	300				110		23.0
	4	7.3	4.40	6009.76	540	250	300				110		20.0
Average		.58	3.7		537.5								

Nomograph Setup

METER VOL. END **7903.35**
START **105.41**
SAMPLE VOL. **105.41** ft³

C _{pitot}	Stack Press. In. Hg-Gauge	Barometric Pressure
.877		29.67

Percent O₂ =

P_{meter} = C
P_{stack} = T_{stack} = ph 1.0₁₁
T_{meter} = ΔP = ph 2.5₀₂
ΔH_g = Noz (Ideal) = #3
% H₂O = Noz (Actual) = .377
P = .30

Imp.	Vol. (End)	Vol. (Start)	ΔVol. (ml)
	185	100	85
	136	160	36
	0	0	0
			Total 121

g (End)	g (Start)	Δgrams
158	130	28

Total Vol. H₂O **149** ml

48

PARTICULATE

DATA

Comp. Test #2

Leak Check Rate

ISO KINETICS = _____

TEST NUMBER

14

Vac
in. Hg ft³/min

DATE

6-20-79

Sampling Time
Per Point, Min
5.0

Before
After

OPERATOR

RAP

FUEL

OHIO

SITE

J

PROBE LOCATION Stack #4

Sample Point	Time	METER CONDITIONS			TEMPERATURES, °F						O ₂ %	Vac.
		Δ P _s	Δ H	Meter Reading	Stack	Probe	Oven	Impingers		Meter		
								In	Out			
NE ₁	11:45	.22	.64	3297.89	350	250	250		82	88		3.5
2		.27	.80	3301.38	360	270	260		82	90		4.2
3		.27	.80	3304.76	365	270	265		63	90		4.2
4	*	.26	.77	3308.16	365	265	265		64	91		4.0
5		.25	.73	3311.42	365	230	230		68	94		3.9
6		.22	.65	3314.50	365	240	240		64	96		3.7
7		.22	.65	3317.55	365	250	250		67	98		3.7
8		.23	.67	3320.64	360	260	250		68	98		3.8
9		.18	.53	3323.44	355	260	255		65	100		3.2
10		.19	.56	3326.28	350	655	260		65	101		3.3
11		.19	.56	3329.11	345*	260	270		64	102		3.3
12		.16	.47	3331.62	—	260	270		65	102		3.0
NEW	6min	.20	.63	3385.32	360	240	245		78	105	*	4.0
*2	2min	.21	.67	3338.50	355	270	—		65	101		4.0
3		.25	.79	3342.02	365	260	260		62	82		4.8
4		.25	.79	3345.41	365	280	270		62	90		4.7
5		.24	.75	3348.73	365	280	270		62	91		4.5
6		.22	.67	3351.84	365	265	265		65	92		4.3
7		.20	.62	3354.85	365	250	265		68	95		4.0
8		.20	.62	3357.82	365	265	265		68	98		4.0
9		.19	.59	3360.70	365	265	265		66	101		3.8
10		.20	.62	3363.66	365	265	270		65	102		4.0
11		.20	.62	3366.58	365	255	265		63	103		4.0
12		.17	.54	3369.366	—	250	260		65	105		3.7
Average		.216	.68	7-1.664	—					96		

SEVERE STORM

METER VOL. END
START 3294.702
SAMPLE VOL. 1.3

Stack Press. In. Hg-Gauge	Barometric Pressure
.29 H ₂ O	

Percent O₂ =

Nomenclature Setup

F _{meter} = C	T _{stack} = pH 1.30	Imp. Vol. (End)	Vol. (Start)	Δ Vol. (r-1)
F _{stack} =	T _{meter} = pH 2.50	191	100	91
F _{meter} = C		121	100	21
Δ H _g =	Noz (Ideal) = #3	0	0	0
H ₂ O = 7.7	Noz (Actual) = 313	Total 112		

F = .59

* H₂ therm. = 338

#4	c (End)	c (Start)	Δ c (r-1)
227	209	18	

Total Vol. H₂O 130

49

PARTICULATE LAB WORKSHEET

TEST NO. 1 ^{BLR 017} (Inlet, Outlet)

LOCATION Site J

Date _____

Box No. _____

Eng. _____

Test Description _____

Dry Gas Meter Vol (ft³)

Final _____
 Initial _____
 Δ DgV _____

Impinger Water Vol (ml)

Final _____
 Initial _____
 Δ Vlc _____

1	2	3	Total

CONTENT		H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.
BOTTLE NO.		X	—	—	—	X
BEAKER NO.			25	23	1	
DATE WT.			—	—	—	
TARE WT.	1		95.9771	50.1574	.8510	
	2		95.9771	50.1572	.8513	
	3	95.9770	50.1569	.8514		
	4	—	—	—		
AVG.		95.9771	50.1572	0.8512		

POST TEST WTS.

1	X	96.0947	50.3647	.9570	X
2		96.0925	50.3640	.9561	
3		96.0923	50.3639	.9554	
4		—	—	—	
AVG.		96.0932	50.3642	0.9562	
Δ WT.		0.1161	0.2070	0.1050	

Δ Vlc = _____ ml
 Δ DgV = _____ ft³
 Δ Mn 428.1 mgm

LOAD _____ klb/hr
 O₂ _____ %
 REMARKS: _____

PARTICULATE LAB WORKSHEET

TEST NO. MECH OUT / (Inlet, ~~Outlet~~) LOCATION Site J
 Date _____ Box No. _____ Eng. _____
 Test Description _____

Dry Gas Meter Vol (ft³)
 Final _____
 Initial _____
 Δ DgV _____

		Impinger Water Vol (ml)			
		1	2	3	Total
Final					
Initial					
Δ Vlc					

CONTENT	H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.	
BOTTLE NO.		—		—		
BEAKER NO.		26		2		
DATE WT.		—		—		
TARE WT.	1	97.0261		.7880		
	2	97.0262		.7882		
	3	97.0266		.7883		
	4	—		—		
AVG.		97.0263		0.7882		

POST TEST WTS.

	1	97.0573		.8852		
	2	97.0540		.8840		
	3	97.0554		.8833		
	4	—		—		
AVG.		97.0556		0.8842		
Δ WT.		0.0293		0.096		

Δ Vlc = _____ ml LOAD _____ klb/hr
 Δ DgV = _____ ft³ O₂ _____ %
 Δ Mn 125.3 mgm REMARKS: _____

PARTICULATE LAB WORKSHEET

TEST NO. 2 ^{BLR OUT} (Inlet, Outlet) LOCATION Site J
 Date 6-4-79 Box No. _____ Eng. _____
 Test Description _____

Dry Gas Meter Vol (ft³)

Final _____
 Initial _____
 Δ DgV _____

Impinger Water Vol (ml)

	1	2	3	Total
Final				
Initial				
Δ Vlc				

CONTENT	H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.
BOTTLE NO.		—	—	—	
BEAKER NO.		27	28	8	
DATE WT.		—	—	—	
TARE WT.	1	104.4577	50.3050	.7375	
	2	104.4578	50.3047	.7372	
	3	104.4586	50.3050	.7373	
	4	—	—	—	
AVG.		104.4580	50.3049	.7373	

POST TEST WTS.

	1	104.6151	50.9958	.8670	
	2	104.6129	50.9955	.8673	
	3	104.6131	50.9957	.8674	
	4	—	—	—	
AVG.		104.6137	50.9957	.8672	
Δ WT.		0.1557	0.6908	0.1299	

Δ Vlc = _____ ml
 Δ DgV = _____ ft³
 Δ Mn 976.4 mgm

LOAD _____ klb/hr
 O₂ _____ %

REMARKS: _____

PARTICULATE LAB WORKSHEET

TEST NO. 5 ^{MECH-OUT} (Inlet, Outlet) LOCATION Side J
 Date 6-12-79 Box No. _____ Eng. _____
 Test Description _____

Dry Gas Meter Vol (ft³)
 Final _____
 Initial _____
 Δ DgV _____

Final
 Initial
 Δ Vlc

Impinger Water Vol (ml)

1	2	3	Total

CONTENT		H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.
BOTTLE NO.		X	—	X	—	X
BEAKER NO.			31 32		5	
DATE WT.			—		—	
TARE WT.	1		97.7662		.7476	
	2		97.7660		.7478	
	3	97.7661	.7471			
	4	—	—			
AVG.		97.7661	.7475			

POST TEST WTS.

1	X	97.8747	X	.9231	X
2		97.8751		.9234	
3		97.8752		.9234	
4		—		—	
AVG.		97.8750		0.9233	
Δ WT.		0.1089	0.1758		

Δ Vlc = _____ ml

LOAD _____ klb/hr

Δ DgV = _____ ft³

O₂ _____ %

Δ Mn 284.7 mgm

REMARKS: _____

PARTICULATE LAB WORKSHEET

TEST NO. 6 ^{BLR OUT} (Inlet, Outlet)

LOCATION Side J

Date 6-13-79 Box No. _____

Eng. _____

Test Description _____

Dry Gas Meter Vol (ft³)

Final _____
 Initial _____
 Δ DgV _____

Impinger Water Vol (ml)

	1	2	3	Total
Final				
Initial				
Δ Vlc				

CONTENT	H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.	
BOTTLE NO.	X	—	—	—	X	
BEAKER NO.		36	34	4		
DATE WT.		—	—	—		
TARE WT.		1	95.9774	50.3270		.7895
		2	95.9773	50.3270		.7893
	3	95.9774	50.3271	.7893		
	4	—	—	—		
AVG.		95.9774	50.3270	0.7894		

POST TEST WTS.

	1	X	96.2451	51.6351	1.0256	X
	2		96.2453	51.6338	1.0263	
	3		96.2458	51.6337	1.0266	
	4		—	—	—	
AVG.			96.2454	51.6337	1.0262	
Δ WT.		0.2680	1.3067	0.2368		

Δ Vlc = _____ ml
 Δ DgV = _____ ft³
 Δ Mn 1811.5 mgm

LOAD _____ klb/hr
 O₂ _____ %

REMARKS: _____

PARTICULATE LAB WORKSHEET

TEST NO. 6 ^{MECH} (Inlet, ~~Outlet~~) LOCATION side J
 Date 6-13-79 Box No. _____ Eng. _____
 Test Description _____

Dry Gas Meter Vol (ft³)
 Final _____
 Initial _____
 Δ DgV _____

Final _____
 Initial _____
 Δ Vlc _____

Impinger Water Vol (ml)			
1	2	3	Total

CONTENT	H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.
BOTTLE NO.	 	—	 	—	
BEAKER NO.	 	33	 	6	
DATE WT.	 	—	 	—	
TARE WT.	1	104.3509	 	.7525	
	2	104.3511	 	.7526	
	3	104.3514	 	.7524	
	4	—	 	—	
AVG.		104.3511	 	0.7525	

POST TEST WTS.

	1	104.4802	 	.9268	
	2	104.4806	 	.9268	
	3	104.4811	 	.9272	
	4	—	 	—	
AVG.		104.4806	 	0.9269	
Δ WT.		0.1295	 	0.1744	

Δ Vlc = _____ ml
 Δ DgV = _____ ft³
 Δ Mn 303.9 mgm

LOAD _____ klb/hr
 O₂ _____ %

REMARKS: _____

PARTICULATE LAB WORKSHEET

TEST NO. 7 ^{BLP OUT} (Inlet, Outlet) LOCATION side J
 Date _____ Box No. _____ Eng. _____
 Test Description _____

Dry Gas Meter Vol (ft³)
 Final _____
 Initial _____
 Δ DgV _____

		Impinger Water Vol (ml)			
		1	2	3	Total
Final	_____				
Initial	_____				
Δ Vlc	_____				

CONTENT	H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.
BOTTLE NO.		—	—	—	
BEAKER NO.		38	35	15	
DATE WT.		—	—	—	
TARE WT.	1	104.4559	64.5799	.7384	
	2	104.4567	64.5801	.7385	
	3	104.4554	64.5801	.7387	
	4	—	—	—	
AVG.		104.4560	64.5800	.7385	

POST TEST WTS.

	1	104.6014	64.9283	.8836	
	2	104.6020	64.9273	.8823	
	3	104.6024	64.9283	.8805	
	4	—	—	—	
AVG.		104.6019	64.9280	0.8805	
Δ WT.		0.1459	0.3480	0.1420	

Δ Vlc = _____ ml LOAD _____ klb/hr
 Δ DgV = _____ ft³ O₂ _____ %
 Δ Mn 635.9 mgm REMARKS: _____

PARTICULATE LAB WORKSHEET

TEST NO. 7 ^{MECH OUT} (Inlet, Outlet)

LOCATION Site J

Date _____ Box No. _____

Eng. _____

Test Description _____

Dry Gas Meter Vol (ft³)

Final _____
Initial _____
Δ DgV _____

Impinger Water Vol (ml)

	1	2	3	Total
Final				
Initial				
Δ Vlc				

CONTENT	H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.
BOTTLE NO.		—		—	
BEAKER NO.		39		10	
DATE WT.		—		—	
TARE WT.	1	95.5720		.7510	
	2	95.5711		.7508	
	3	95.5703		.7506	
	4	—		—	
AVG.		95.5711		.7508	

POST TEST WTS.

	1	95.6090		.8926	
	2	95.6087		.8917	
	3	95.6086		.8911	
	4	—		—	
AVG.		95.6088		.8914	
Δ WT.		0.0377		0.1406	

Δ Vlc = _____ ml

LOAD _____ k lb/hr

Δ DgV = _____ ft³

O₂ _____ %

Δ Mn 178.3 mgm

REMARKS: _____

PARTICULATE LAB WORKSHEET

TEST NO. 8 ^{BLR OUT} (Inlet, Outlet) LOCATION side J
 Date _____ Box No. _____ Eng. _____
 Test Description _____

Dry Gas Meter Vol (ft³)
 Final _____
 Initial _____
 Δ DgV _____

		Impinger Water Vol (ml)			
		1	2	3	Total
Final					
Initial					
Δ Vlc					

CONTENT	H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.
BOTTLE NO.		—	—	—	
BEAKER NO.		40	31	16	
DATE WT.		—	—	—	
TARE WT.	1	97.0244	105.2116	.7344	
	2	97.0248	105.2118	.7342	
	3	97.0244	105.2118	.7337	
	4	—	—	—	
AVG.		97.0245	105.2115	.7341	

POST TEST WTS.

	1	97.1668	105.5810	.8545	
	2	97.1673	105.5809	.8547	
	3	97.1676	105.5814	.8537	
	4	—	—	—	
AVG.		97.1672	105.5811	.8543	
Δ WT.		0.1427	0.3696	0.1202	

Δ Vlc = _____ ml
 Δ DgV = _____ ft³
 Δ Mn 632.5 mgm

LOAD _____ klb/hr
 O₂ _____ %

REMARKS: _____

PARTICULATE LAB WORKSHEET

TEST NO. 8 ^{MECH} (Inlet, Outlet) LOCATION Sik J
 Date _____ Box No. _____ Eng. _____
 Test Description _____

Dry Gas Meter Vol (ft³)
 Final _____
 Initial _____
 Δ DgV _____

Final _____
 Initial _____
 Δ Vlc _____

Impinger Water Vol (ml)			
1	2	3	Total

CONTENT	H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.	
BOTTLE NO.	X	—	X	—	X	
BEAKER NO.		42		11		
DATE WT.		—		—		
TARE WT.		1		95.0094		.5912
		2		95.0100		.5910
	3	95.0091	.5908			
	4	—	—			
AVG.		95.0095		.5910		

POST TEST WTS.

1	X	95.0392	X	.7057	X
2		95.0402		.7046	
3		95.0409		.7039	
4		—		—	
AVG.				95.0401	
Δ WT.		0.0306		0.1133	

Δ Vlc = _____ ml
 Δ DgV = _____ ft³
 Δ Mn 143.9 mgm

LOAD _____ klb/hr
 O₂ _____ %

REMARKS: _____

PARTICULATE LAB WORKSHEET

TEST NO. 9 ^{BLR OUT} (Inlet, Outlet)

LOCATION Site J

Date _____

Box No. _____

Eng. _____

Test Description _____

Dry Gas Meter Vol (ft³)

Final _____
 Initial _____
 Δ DgV _____

Impinger Water Vol (ml)

	1	2	3	Total
Final				
Initial				
Δ Vlc				

CONTENT	H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.
BOTTLE NO.		—	—	—	
BEAKER NO.		50	41	17	
DATE WT.		—	—	—	
TARE WT.	1	104.4578	50.8311	.7896	
	2	104.4577	50.8310	.7895	
	3	104.4576	50.8306	.7897	
	4	—	—	—	
AVG.		104.4577	50.8309	.7896	

POST TEST WTS.

1		104.6163	51.0025	.8999	
2		104.6164	51.0026	.8999	
3		104.6164	51.0025	.8999	
4		—	—	—	
AVG.		104.6164	51.0025	.8995	
Δ WT.		0.1587	0.1716	0.1099	

Δ Vlc = _____ ml
 Δ DgV = _____ ft³
 Δ Mn 440.2 mgm

LOAD _____ klb/hr
 O₂ _____ %

REMARKS: _____

PARTICULATE LAB WORKSHEET

TEST NO. 9 ^{MECH OUT} (Inlet, Outlet) LOCATION Site J
 Date _____ Box No. _____ Eng. _____
 Test Description _____

Dry Gas Meter Vol (ft³)
 Final _____
 Initial _____
 Δ DgV _____

Impinger Water Vol (ml)
 Final _____
 Initial _____
 Δ Vlc _____

1	2	3	Total

CONTENT		H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.
BOTTLE NO.		X	—	X	—	X
BEAKER NO.			55		18	
DATE WT.			—		—	
TARE WT.	1		95.9792		.5868	
	2		95.9791		.5867	
	3	95.9793	.5864			
	4	—	—			
AVG.		95.9792	.5866			

POST TEST WTS.

	1	X	96.0125	X	.9059	X
	2		96.0129		.7035	
	3		96.0130		.7037	
	4		—		—	
AVG.			96.0128		.7036	
Δ WT.		0.0336	0.1170			

Δ Vlc = _____ ml LOAD _____ klb/hr
 Δ DgV = _____ ft³ O₂ _____ %
 Δ Mn 150.6 mgm REMARKS: _____

PARTICULATE LAB WORKSHEET

TEST NO. 14 ^{BLR OUT} (Inlet, Outlet)

LOCATION Site J

Date _____

Box No. _____

Eng. _____

Test Description _____

Dry Gas Meter Vol (ft³)

Final _____
 Initial _____
 Δ DgV _____

Impinger Water Vol (ml)

Final _____
 Initial _____
 Δ Vlc _____

1	2	3	Total

CONTENT	H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.	
BOTTLE NO.	X	—	—	—	X	
BEAKER NO.		56	37	21		
DATE WT.		—	—	—		
TARE WT.		1	95.0115	63.3967		.9317
		2	95.0112	63.3970		.9315
	3	95.0110	63.3970	.9316		
	4	—	—	—		
AVG.		95.0112	63.3969	.9316		

POST TEST WTS.

	1	95.2491	65.6095	1.2104	X
	2	95.2501	65.6058	1.2114	
	3	95.2502	65.6057	1.2108	
	4	—	—	—	
AVG.		95.2498	65.6057	1.2109	
Δ WT.		0.2386	2.2088	0.2793	

Δ Vlc = _____ ml
 Δ DgV = _____ ft³
 Δ Mn = 2726.7 mgm

LOAD _____ klb/hr
 O₂ _____ %

REMARKS: _____

PARTICULATE LAB WORKSHEET

TEST NO. 14 *MECH OUT* (Inlet, Outlet) LOCATION side J
 Date _____ Box No. _____ Eng. _____
 Test Description #2nd. COMPLIANCE

Dry Gas Meter Vol (ft³)
 Final _____
 Initial _____
 Δ DgV _____

Final _____
 Initial _____
 Δ Vlc _____

Impinger Water Vol (ml)			
1	2	3	Total

CONTENT	H ₂ O RINSE	ACETONE RINSE	DRY FLASK	FILTER NO.	BLANK NO.
BOTTLE NO.		—		—	
BEAKER NO.		58		19	
DATE WT.		—		—	
TARE WT.	1	104.3524		.5840	
	2	104.3518		.5841	
	3	104.3521		.5839	
	4	—		—	
AVG.		104.3521		.5840	

POST TEST WTS.

	1	104.5261		.8519	
	2	104.5260		.8384	
	3	104.5261		.8383	
	4	—		—	
AVG.		104.5261		.8384	
Δ WT.		0.1740		0.2544	

Δ Vlc = _____ ml
 Δ DgV = _____ ft³
 Δ Mn 428.4 mgm

LOAD _____ klb/hr
 O₂ _____ %
 REMARKS: _____

SECTION 3.0
GASEOUS DATA

	<u>PAGE</u>
3.1 GASEOUS EMISSION SUMMARY	67
3.2 GASEOUS EMISSIONS DATA SHEETS	68
3.3 SO _x DATA SHEETS	81

GASEOUS EMISSION SUMMARY

Location: TEST SITE J

Fuel: KENTUCKY AND OHIO

TEST NO.	DATE	LOAD %	CONDITIONS	BOILER OUTLET					STACK				SO ₂ ppm Dry	SO ₃ ppm Dry	NOTES	
				O ₂ % Dry	CO ₂ % Dry	CO ppm Dry	NO ppm Dry	NO ₂ ppm Wet	HC ppm Wet	O ₂ % Dry	CO ₂ % Dry	CO ppm Dry				NO ppm Dry
01	6-3-79	48.2	PART OHIO COAL	10.2	6.7	005	291	0		9.7	7.3	005	253			
2	6-4-79	73.8	PART	10.6	8.1		304	0	107	10.8	7.9		267			
3	6-5-79		scratched	7.5	10.4		231	0	80	—	—		—			
4	6-6-79		scratched	9.1	9.0		258	0		7.6	10.1		171			
5	6-12-79	102.6	PART, Low O ₂ ↓	7.9	10.2		287	0		8.3	9.9		305			
6	6-13-79	98.6	PART KENT COAL	8.1	10.1		247	0		9.7	9.7		265			
7	6-14-79	84.9	{ OHIO COAL	8.7	9.6		276	0		9.2	9.3		288			
8	6-15-79	73.1	{ KENT COAL	9.0	9.4		203	0		9.2	9.6		222			
9	6-16-79	49.6	↓ ↓	12.2	7.0		306	005		11.5	7.5		261			
10	6-17-79		OFA TRAVERSE													
11	6-17-79		↓													
12	6-17-79		↓													
13	6-19-79	102.5	BRINK OHIO COAL	7.9	10.1		206			7.8	10.4		227			
14	6-20-79	97.1	PART, high O ₂ ↓	8.8	9.9		280			9.0	9.5		256			
15	6-28-79	93.9	SASS, SO _x KENT COAL	7.9	9.9		236	↓		8.2	9.8		231	1008	5	
16	6-30-79	92.6	SASS, SO _x OHIO COAL	8.9	8.9	↓	320			9.2	8.7	↓	324	1468	11	

NOTE: All parts per million (ppm) figures are corrected to a 3% O₂ constant dilution factor

#15900

57

REV.

KVB

GASEOUS EMISSIONS DATA

TEST SITE J
 TEST NO #6
 DATE 6-13-79

FUEL Kty.
 LOAD 70,000
 CONDITIONS as found
 DATA TAKEN BY MJ

RH = 36%

Probe Position	Time	O ₂ % (dry)	CO ₂ % (dry)	CO		NO		HOT LINE SAMPLES, PPM (WET)								REMARKS	
				ppm(dry)		ppm(dry)		NOx		NO		NO ₂		HC			
				unc	cor	unc	cor	unc	cor	unc	cor	unc	cor	unc	cor		
Bl-out																	
2356	1130	6.6	11.2			80	100										
2756	1150	8.3	10.0			180	256										Cal.
2756	1200	6.1	11.4			180	218	160	191	160	194		0				
Stack	1215	8.0	10.2			160	222										
	1230	10.5	8.5			180	310										
	1240	9.4	9.0			175	272										Cal change Ref
	1250	8.2	10.0			185	261										
	1:00	7.2	10.7			199	260										
Bl-out	110	7.0	10.9			190	246										
	120	7.5	9.1			180	283										
	130	7.5	9.0			180	283	180	223	180	223		0				
	150	9.7	8.8			165	244										
	200	7.7	10.2			185	255										
	205	8.0	10.3			195	271										
	215	8.0	10.2			210	291										

AVERAGES

BlR	8.1	10.1					247							0		
STACK	8.7	9.7					265									

NOTE: Parts per million (ppm) figures are corrected to 3% O₂

KVB

GASEOUS EMISSIONS DATA

TEST SITE J
 TEST NO # 7
 DATE 6-14-77

FUEL Ohio
 LOAD 62,000
 CONDITIONS as found
 DATA TAKEN BY MJ

Probe Position	Time	O ₂ (dry)	CO ₂ (dry)	CO		NO		HOT LINE SAMPLES, PPM (WET)								REMARKS			
				ppm(dry)		ppm(dry)		NOx		NO		NO ₂		HC					
				unc	cor	unc	cor	unc	cor	unc	cor	unc	cor	unc	cor				
Blowt																			
23567	11:15	9.0	9.4			160	241												Cgl. Start
	11:25	9.4	9.0			180	280												Cgl.
	11:35	9.0	9.4			190	286	170	256	170	256	0	0						
	11:40	8.8	9.5			195	288												
Stack	11:50	9.0	9.4			190	286												
	11:55	9.1	9.4			185	281												Charged side
	12:05	9.4	9.0			190	296												
Blowt	12:10	9.0	9.2			210	316												
2356	12:20	7.8	10.2			200	273	162	221	162	221	0	0						
	12:30	7.5	10.5			195	260												
	12:45	8.5	9.7			190	274												
	1:00	7.5	8.9			183	284												
	1:10	8.0	10.2			185	257												

AVERAGES

Blowt		9.7	9.6				276													
Stack		9.2	9.3				286													

NOTE: Parts per million (ppm) figures are corrected to 3% O₂

KVB

GASEOUS EMISSIONS DATA

TEST SITE J
 TEST NO #8
 DATE 6-15-79

FUEL Kentucky
 LOAD 50K
 CONDITIONS no found
 DATA TAKEN BY MJ

Probe Position	Time	O ₂ % (dry)	CO ₂ % (dry)	CO - ppm(dry)		NO ppm(dry)		HOT LINE SAMPLES, PPM (WET)								REMARKS	
								NOx		NO		NO ₂		HC			
				unc	cor	unc	cor	unc	cor	unc	cor	unc	cor	unc	cor		
Bl. out																	
23 st	1040	6.0	11.4			130											
	1050	5.5	12.0			136		90		90		0					lost load
	1130	9.1	9.3			132	200										Stop Test
	1145	9.0	9.4			134	202	97	146	77	146	0	0				Start
	1215	9.0	9.4			137	206										
Stack	1220	9.1	9.4			141	214										
	1235	9.1	9.6			142	215										
	1250	9.2	10.0			144	224										
	1.00	9.2	9.4			150	224										

AVERAGES

BLR		9.0	9.4				203						0			
STACK		9.2	9.6				222									

NOTE: Parts per million (ppm) figures are corrected to 3% O₂

KVB

GASEOUS EMISSIONS DATA

TEST SITE J FUEL Kerosene
 TEST NO 9 LOAD 35,000
 DATE 6-12-79 CONDITIONS as found
 DATA TAKEN BY MT

Probe Position	Time	O ₂ (dry)	CO ₂ (dry)	CO		NO		HOT LINE SAMPLES, PPM (WET)								REMARKS	
				ppm(dry)		ppm(dry)		NOx		NO		NO ₂		HC			
				unc	cor	unc	cor	unc	cor	unc	cor	unc	cor	unc	cor		
Stack	1040	11.2	7.8			130	240										
	1050	11.2	7.7			127	234										
	1105	11.5	7.4			129	246										
Blowout	1115	11.9	7.0			135	268										Charge side cal
2356	1120	11.9	7.4			143	284										
	1130	12.0	7.1			143	288										
	1140	12.0	7.1			155	312										
	1155	11.6	7.4			145	279										
Stack	1200	11.6	7.6			150	289										
	1210	11.2	7.8			145	268										
	1220	11.9	7.2			149	284										
Blowout	1230	12.1	7.0			142	289										
2356	1150	12.5	6.6			155	330										
2356	115	13.0	6.4			158	358										

AVERAGES

Stack	12.2	7.0																
Stack	11.5	7.5					261											

NOTE: Parts per million (ppm) figures are corrected to 3% O₂

KVB

GASEOUS EMISSIONS DATA

TEST SITE	J	FUEL	Kentucky
TEST NO	15	LOAD	65,000 ^{LB} /HR
DATE	6-28-79	CONDITIONS	~8% O ₂
		DATA TAKEN BY	J03

Probe Position	Time	O ₂ % (dry)	CO ₂ % (dry)	CO		NO		HOT LINE SAMPLES, PPM (WET)								REMARKS	
				ppm(dry)		ppm(dry)		NOx		NO		NO ₂		HC			
				unc	cor	unc	cor	unc	cor	unc	cor	unc	cor	unc	cor		
BLR	1215	8.5	9.6		065	140	202										
STACK	1300	8.2	9.8			148	209										
BLR	1400	8.8	9.5			180	266										T _{wet} = 70F T _{dry} = 82F
BLR	1340	7.0	10.6			170	219										RH = 56%
STACK	1430	8.1	9.7			150	252										
BLR	1530	7.2	10.6			178	233										
BLR	1600	7.2	10.6			165	216										
BLR	1630	8.7	9.5			170	249										
BLR	1700	7.8	10.0			175	237										
BLR	1720	8.3	9.5			188	263										

AVERAGES

BLR	7.9	9.9				236											
STACK	8.2	9.8				231											

NOTE: Parts per million (ppm) figures are corrected to 3% O₂

KVB

GASEOUS EMISSIONS DATA

TEST SITE J
 TEST NO 16
 DATE 6-30-79

FUEL Ohio
 LOAD 70,000 LB/HR
 CONDITIONS ~8% O₂ as found
 DATA TAKEN BY Job

Probe Position	Time	O ₂ (dry)	CO ₂ (dry)	CO		NO		HOT LINE SAMPLES, PPM (WET)								REMARKS		
				ppm(dry)		ppm(dry)		NOx		NO		NO ₂		HC				
				unc	cor	unc	cor	unc	cor	unc	cor	unc	cor	unc	cor			
BLR	1200	7.4	9.8		005	180	239											
STACK	1245	8.5	9.2			180	260											Twet = 68°F
BLR	1330	9.5	8.7			235	369											Tdry = 75°F
BLR	1400	9.3	8.8			202	312											RH = 70%
BLR	1440	8.5	7.2			200	289											
BLR	1530	9.7	8.2			245	391											
STACK	1600	9.8	8.2			240	387											

AVERAGES

BLR		8.9	8.9				320											
STACK		9.2	8.1				314											

NOTE: Parts per million (ppm) figures are corrected to 3% O₂

Local _____

SOx DATA SHEET

Date _____ Probe Location & Probe Length 3' - NW PORT

Unit # _____ Fuel KENTUCKY Load _____

Test Description: _____

Test No.	Box No.	Sample Time	Meter Temp. (T)	Meter (P) Press.	Meter Reading	(P) Baro. Press.	Port	Purge Time	O2
15A	1	15:40	97	- 0 -	0.000	2974.	Stack NW	20.0'	
		15:54	94		1.000				
15B	1	16:20	93		0.000			16:35	
		16:34	90		1.000			20.0	
15C		17:00	88		0.000			17:13	
		17:12	86		1.000			20.0	

SAMPLED BY

Test # 15A

Test # 15B

Test # 15C

	SO2	SO3	SOx	SO2	SO3	SOx	SO2	SO3	SOx
Normality N	0.108								
Dilution Factor F	25	1		20	1		20	1	
Blank B									
Averages									
Ml. of Titrant A	5.4 5.3 5.3	.9		8.5 8.5 8.6	.6		7.2 7.2 7.3	.8	
Averages	5.3			8.5	.6		7.2	.8	
460 + T									
Sample Vol. V									
P + p									
A - B									

TITRATED BY R.M.P.

$$SO_2 = \frac{(A-B)(N)(F)(460+T)(24)}{V(P+p)}$$

$$SO_2 = \frac{(5.3)(0.108)(25)(553.5)}{(1.00)(24)}$$

$$SO_2 = \boxed{641.5} \quad SO_3 = \boxed{4.2}$$

$$SO_3 = \frac{(\quad)(\quad)(\quad)(\quad)(24)}{(\quad)(\quad)}$$

SO2 @ 3% O2 = 104.2
 SO3 @ 3% O2 = 0.1
 SOx @ 3% O2 = 104.3

$$SO_2 = \frac{8.5(0.108)(20)(551.5)(24)}{(\quad)(\quad)}$$

$$SO_2 = \boxed{817}$$

$$SO_3 = \frac{(\quad)(\quad)(\quad)(\quad)(24)}{(\quad)(\quad)}$$

$$SO_3 = \boxed{2.55}$$

SO2 @ 3% O2 = 1151.5
 SO3 @ 3% O2 = 7.1
 SOx @ 3% O2 = 1158.6

$$SO_2 = \frac{7.2(0.108)(20)(547)(24)}{(\quad)(\quad)}$$

$$SO_2 = \boxed{686.5}$$

$$SO_3 = \frac{(\quad)(\quad)(\quad)(\quad)(24)}{(\quad)(\quad)}$$

$$SO_3 = \boxed{3.5}$$

SO2 @ 3% O2 = 961.6
 SO3 @ 3% O2 = 5.4
 SOx @ 3% O2 = 967.0

Local Side J

SOx DATA SHEET

Date 6-30-79 Probe Location & Probe Length 3' - NW PORT STACK

Unit # 4 Fuel ONFO Load _____

Test Description: _____

Test No.	Box No.	Sample Time	Meter Temp. (T)	Meter (P) Press.	Meter Reading	(P) Baro. Press.	Port	Purge Time	O2
16A	3	13:32	64°	-0-	0.000	29.26	NW	13:51	
		13:47	64		1.200			14:11	
16B	1	14:13	63		0.000			14:37	
		14:34	63		1.200			14:57	
16C	1	15:10	62		0.000			15:25	
		15:25	62		1.200			15:50	

SAMPLED BY R.P.P.

Test # 16A

Test # 16B

Test # 16C

	SO2	SO3	SOx	SO2	SO3	SOx	SO2	SO3	SOx
Normality N	.0108	→	→	→	→	→	→	→	→
Dilution Factor F	20	1		20	1		20	1	
Blank B	→	→	→	→	→	→	→	→	→
Averages									
Ml. of Titrant A	11.7 11.8 11.8	1.9		11.2 11.3 11.2	1.8		14.3 14.3 14.2	2.2	
Averages	11.8	1.9		11.2	1.8		14.3	2.2	
460 + T	524	→		523	→		522		
Sample Vol. V	1.200	→		1.200	→		1.200	→	
P + p	29.26	→		29.26	→		29.26	→	
A - B	11.8	1.9		11.2	1.8		14.3	2.2	

TITRATED BY R.P.P.

$$SO_2 = \frac{(A-B)(N)(F)(460+T)(24)}{V(P+p)}$$

$$SO_2 = \frac{(\quad)(\quad)(\quad)(\quad)(24)}{(\quad)(\quad)}$$

$$SO_2 = \boxed{913} \quad SO_3 = \boxed{1.3}$$

$$SO_3 = \frac{(\quad)(\quad)(\quad)(\quad)(24)}{(\quad)(\quad)}$$

$$SO_2 @ 3\% O_2 = \frac{13900}{117}$$

$$SO_3 @ 3\% O_2 = \frac{117}{117}$$

$$SOx @ 3\% O_2 = \frac{1408}{117}$$

$$SO_2 = \frac{(\quad)(\quad)(\quad)(\quad)(24)}{(\quad)(\quad)}$$

$$SO_2 = \boxed{864}$$

$$SO_3 = \frac{(\quad)(\quad)(\quad)(\quad)(24)}{(\quad)(\quad)}$$

$$SO_3 = \boxed{6.9}$$

$$SO_2 @ 3\% O_2 = \frac{13218}{11.6}$$

$$SO_3 @ 3\% O_2 = \frac{11.6}{11.6}$$

$$SOx @ 3\% O_2 = \frac{1332.2}{11.6}$$

$$SO_2 = \frac{(\quad)(\quad)(\quad)(\quad)(24)}{(\quad)(\quad)}$$

$$SO_2 = \boxed{1102}$$

$$SO_3 = \frac{(\quad)(\quad)(\quad)(\quad)(24)}{(\quad)(\quad)}$$

$$SO_3 = \boxed{0.4}$$

$$SO_2 @ 3\% O_2 = \frac{1686.0}{12.9}$$

$$SO_3 @ 3\% O_2 = \frac{12.9}{12.9}$$

$$SOx @ 3\% O_2 = \frac{1699}{12.9}$$

283676 Rev

SECTION 4.0
PARTICLE SIZE DISTRIBUTION

	PAGE
4.1 BRINK	84
4.2 SASS	90

KVB

BRINK CASCADE IMPACTOR DATA SHEET

TEST NO. 13 LOAD 70,000 LB/HR
 TEST SITE T % O₂ 7.8%
 TEST DATE 6-19-79 FUEL Ohio
 SAMPLE LOCATION BLR out SPECIAL CONDITIONS as found

GAS VELOCITY DETERMINATION

PITOT TUBE ΔP .65 BAROMETRIC PRESS in. Hg, P_{bar} 29.87
 GAS TEMP. °R, T_s 480 940 GAS STATIC PRESS in. H₂O -1.7 H₂O
 PITOT CORRECTION FACTOR, C_p .86 GAS STATIC PRESS in. Hg abs, P_s 29.74
 MOLECULAR WT. FLUE GAS, M_{Ws} 29.4

$$V_s = 85.48 C_p \left(\frac{T_s \Delta P}{P_s M_{Ws}} \right)^{1/2} = \underline{61.45} \text{ ft/sec}$$

IMPACTOR FLOW RATE DETERMINATION

NOZZLE DIAMETER inches, D_n .059
 NOZZLE AREA ft², A_n 1.902 x 10⁻⁵ A_n = π(D_n/24)²
 $Q_s = V_s A_n 60 = \underline{.070} \text{ ft}^3/\text{min}$ at nozzle
 $Q_c = Q_s \left(\frac{P_s M_{Ws}}{1.3 T_s} \right)^{1/2} = \underline{.059} \text{ ft}^3/\text{min}$ corrected to calibration conditions
 PRESSURE DROP ACROSS IMPACTOR FROM CALIBRATION CURVE 16.5 in. H₂O
 OPERATING VACUUM (corrected for static pressure of duct) 18.2 in. H₂O

ISOKINETICS DETERMINATION

	SAMPLE TIME (θ)	METER READING (V _m)	METER TEMP (T _m)
INITIAL	<u>000</u> →	→	<u>80</u>
FINAL	<u>42.126</u>	<u>1.50</u>	<u>98</u>
Δ			

%H₂O = 6.0 %

$$I = \frac{1.667 T_s V_m P_{bar}}{\theta T_m V_s P_s A_n \left(1 - \frac{\%H_2O}{100}\right)} = \underline{\hspace{2cm}}$$

KVB

BRINK CASCADE IMPACTOR LAB WORKSHEET

TEST No. 13 LOCATION Site J - Blarout #4
 TEST DATE 6-19-79 ENGINEER _____
 TEST DESCRIPTION _____

SET #1

PRE TEST WEIGHTS (GRAMS)

PLATE NO.	CYCLONE	1	2	3	4	5	FINAL FILTER	
DATE WT.								
TARE WT.	1	.1136	3.5085	3.0907	3.9792	3.7788	3.9004	.0370
	2	.1137	3.5085	3.0907	3.9791	3.7788	3.9005	.0380
	3	—	—	—	—	—	—	—
	4	—	—	—	—	—	—	—
AVERAGE		.1136	3.5085	3.0907	3.9791	3.7788	3.9004	.0379

POST TEST WEIGHTS (GRAMS)

DATE WT.								
GROSS WT.	1	.1266	3.5106	3.0922	3.9803	3.7799	3.9013	.0380
	2	.1268	3.5107	3.0922	3.9805	3.7799	3.9012	.0383
	3	—	3.5105	3.0921	3.9805	3.7798	3.9012	.0384
	4	—	—	—	—	—	—	—
AVERAGE		.1267	3.5106	3.0922	3.9804	3.7799	3.9012	.0382

NET TEST RESULTS (MILLIGRAMS)

NET WT.	0.0131	0.0021	0.0015	0.0013	0.0011	0.0008	0.0003
PERCENT	6.9	1.4	7.4	6.4	5.4	4.0	1.5

TOTAL NET WEIGHT 20.2 mgm

KVB

BRINK CASCADE IMPACTOR DATA REDUCTION

TEST NO. <u>13</u>	LOAD <u>70,000 L^R/HR</u>
TEST SITE <u>J</u>	% O ₂ <u>78 %</u>
TEST DATE <u>6-19-79</u>	FUEL <u>Oil</u>
SAMPLE LOCATION <u>BLR-OUT</u>	SPECIAL CONDITIONS <u>as found</u>

D _p - Density of particles <u>2.5</u> g/cm ³	V _m - Dry gas volume _____ SCF
μ - Viscosity of flue gas <u>2.59 × 10⁻⁴</u> poise	M _n - Total particulate mass _____ mgm
M _w - Molecular wt. flue gas <u>29.04</u> g/g mole	C _n - Total concentration _____ grains/SCF
ΔP _I - Pressure drop across impactor <u>16.5</u> in H ₂ O	I - Percent isokinetics _____ %
P _s - Absolute stack pressure <u>29.74</u> in. Hg	V _s - Gas velocity _____ ft/sec.
T _s - Absolute stack temperature <u>940</u> °R	D _n - Nozzle diameter _____ in.
Q _s - Actual flow rate at stack conditions <u>0.070</u> ft ³ /min	

Stage Number	CYCLONE	1	2	3	4	5	FINAL FILTER
D _j - Jet Diameter, cm		0.2490	0.1775	0.1396	0.0946	0.0731	
F _j - Press. factor, n.d.		0.0210	0.0273	0.0345	0.0403	0.3277	
D _{s, 50} Stokes diameter, μm		2.95	1.70	1.13	0.55	0.32	
D _{A, 50} Aerodynamic diameter, μm		4.78	2.80	1.90	0.97	0.60	
D _{AI, 50} Aerodynamic impaction diameter, μm		4.98	3.00	2.09	1.16	0.787	
M _n - Particulate mass, mgm	13.1	2.1	1.5	1.3	1.1	0.8	0.3
% - Percent of Total	64.4	10.4	7.4	6.4	5.4	4.0	1.5
Cumulative percent	35.1	24.7	17.3	10.9	5.5	1.5	0
C _n - Concentration, grains/SCF							
Cumulative concentration, grains/SCF							

KVB

BRINK CASCADE IMPACTOR LAB WORKSHEET

TEST No. 13 LOCATION Site J - MECH #4
 TEST DATE 6-19-79 ENGINEER _____
 TEST DESCRIPTION _____

SET #2

PRE TEST WEIGHTS (GRAMS)

PLATE NO.		CYCLONE	1	2	3	4	5	FINAL FILTER
DATE WT.		X						
TARE WT.	1		3.4130	3.2716	3.4911	3.4646	3.3010	.0304
	2		3.4124	3.2709	3.4966	3.4639	3.3012	.0378
	3		3.4128	3.2710	3.4966	3.4639	3.3012	.0377
	4		—	—	—	—	—	—
AVERAGE			3.4126	3.2709	3.4966	3.4639	3.3012	.0377

POST TEST WEIGHTS (GRAMS)

DATE WT.		X						
GROSS WT.	1		3.4132	3.2719	3.4972	3.4650	3.3019	.0381
	2		3.4132	3.2719	3.4970	3.4649	3.3020	.0380
	3		3.4131	3.2720	3.4972	3.4651	3.3021	.0382
	4		—	—	—	—	—	—
AVERAGE			3.4132	3.2719	3.4971	3.4650	3.3020	.0381

NET TEST RESULTS (MILLIGRAMS)

NET WT.	—	0.0006	0.0010	0.0005	0.0011	0.0008	0.0004
PERCENT	—	13.6	22.7	11.4	25.0	18.2	9.1

TOTAL NET WEIGHT 4.4 mgm

KVB

BRINK CASCADE IMPACTOR DATA REDUCTION

TEST NO. <u>13</u>	LOAD <u>70,000 LB/HR</u>
TEST SITE <u>J</u>	% O ₂ <u>7.9%</u>
TEST DATE <u>6-19-79</u>	FUEL <u>Ohio Coal</u>
SAMPLE LOCATION <u>STACK</u>	SPECIAL CONDITIONS <u>AS FOUND</u>

ρ_p - Density of particles <u>2.5</u> g/cm ³	V_m - Dry gas volume _____ SCF
μ - Viscosity of flue gas <u>2.32×10^{-4}</u> poise	M_n - Total particulate mass _____ mgm
M_w - Molecular wt. flue gas <u>29.04</u> g/g mole	C_n - Total concentration _____ $\frac{\text{grains}}{\text{SCF}}$
ΔP_I - Pressure drop across impactor <u>9.0</u> in H ₂ O	I - Percent isokinetics _____ %
P_s - Absolute stack pressure <u>29.87</u> in. Hg	V_s - Gas velocity _____ ft/sec.
T_s - Absolute stack temperature <u>805</u> °R	D_n - Nozzle diameter _____ in.
Q_s - Actual flow rate at stack conditions <u>0.047</u> ft ³ /min	

Stage Number	CYCLONE	1	2	3	4	5	FINAL FILTER
D_j - Jet Diameter, cm		0.2490	0.1775	0.1396	0.0946	0.0731	
F_j - Press. factor, n.d.		0.0210	0.0273	0.0395	0.0903	0.3277	
$D_{s,50}$ Stokes diameter, μm		3.49	2.04	1.38	0.71	0.43	
$D_{A,50}$ Aerodynamic diameter, μm		5.60	3.31	2.26	1.20	0.77	
$D_{AI,50}$ Aerodynamic impaction diameter, μm		5.75	3.46	2.41	1.35	0.912	
M_n - Particulate mass, mgm	0	0.6	1.0	0.5	1.1	0.8	0.4
% - Percent of Total	0	13.6	22.7	11.4	25.0	18.2	9.1
Cumulative percent	100.0	86.4	63.7	52.3	27.3	9.1	0
C_n - Concentration, grains/SCF							
Cumulative concentration, grains/SCF							



SITE J

SASS GRAVIMETRICS

Test 15		<u>%</u>	<u>% Passing</u>
	10 μ	0.4739	24.77
	3 μ	0.1265	6.61
	1 μ	0.1979	10.35
	Filters	0.6897	58.27
		<u>0.4249</u>	0
	Total	<u>1.9129</u>	<u>100.00</u>
Test 16	10 μ	0.2905	19.06
	3 μ	None	-
	1 μ	0.2358	15.47
	Filter	<u>0.9975</u>	<u>65.46</u>
	Total	<u>1.5238</u>	<u>99.99</u>

SECTION 5.0
FUEL AND ASH ANALYSIS

	<u>PAGE</u>
5.1 COMMERCIAL TESTING ANALYSIS	92
5.2 COMBUSTIBLE ANALYSIS	117
5.3 COAL SIEVE ANALYSIS	118

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 284-1173

KVB
A Research-Cottrell Company
6176 Olson Memorial Highway
Minneapolis, MN 55422

June 28, 1979

Sample identification
by KVB

Test No. 1
Sample: Ohio Coal
Test Site: J

Kind of sample reported to us: **Coal**
Sample taken at: **----**
Sample taken by: **KVB**
Date sampled: **----**
Date received: **6/23/79**

Analysis report no. 71-34526

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	2.89	XXXXX
% Ash	6.31	6.50
% Volatile	37.43	38.54
% Fixed Carbon	53.37	54.96
	<u>100.00</u>	<u>100.00</u>
Btu/lb.	13572	13976
% Sulfur	1.06	1.09

FUSION TEMPERATURE OF ASH

	<u>Reducing</u>	<u>Oxidizing</u>
Initial Deformation	XXXX °F	XXXX °F
Softening (H = W)	XXXX °F	XXXX °F
Softening (H = 1/2 W)	XXXX °F	XXXX °F
Fluid	..XXX °F	XXXX °F

H -- Cone Height
W -- Cone Width

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

92

R. A. Houser

R. A. HOUSER, Manager, Midwest Division



Charter Member

Original Copy Watermarked
For Your Protection

RAH/ br

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 · AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

► **KVB**
A Research-Cottrell Company
6176 Olson Memorial Highway
Minneapolis, MN 55422

June 28, 1979

Sample identification
by KVB

Kind of sample reported to us **Coal**
Sample taken at **----**
Sample taken by **KVB**
Date sampled **----**
Date received **6/23/79**

Test No. 2
Sample: Ohio Coal
Test Site: J

Analysis report no. 71-34530

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	3.12	xxxxx
% Ash	7.06	7.29
% Volatile	37.62	38.83
% Fixed Carbon	52.20	53.88
	<u>100.00</u>	<u>100.00</u>
Btu/lb.	13405	13837
% Sulfur	1.52	1.57

FUSION TEMPERATURE OF ASH

	<u>Reducing</u>	<u>Oxidizing</u>
Initial Deformation	xxxx °F	xxxx °F
Softening (H=W)	xxxx °F	xxxx °F
Softening (H = 1/2 W)	xxxx °F	xxxx °F
Fluid	xxxx °F	xxxx °F

H = Cone Height
W = Cone Width

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

93

R. A. Hoover
R. A. HOOPER, manager, Midwest Division



Charter Member

Original Copy Watermarked
For Your Protection

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/ br

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

► KVB, INC.
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 17, 1979

Sample identification
by KVB, Inc.

Kind of sample reported to us	Ohio Coal	Test No. 5
Sample taken at	Test site J	
Sample taken by	KVB, Inc.	
Date sampled	6/12/79	
Date received	7/12/79	

Analysis report no. 71- 35626

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	4.44	xxxxx
% Ash	10.22	10.69
% Volatile	37.19	38.92
% Fixed Carbon	48.15	50.39
	<u>100.00</u>	<u>100.00</u>
Btu/lb.	12570	13154
% Sulfur	2.18	2.28

FUSION TEMPERATURE OF ASH

	<u>Reducing</u>		<u>Oxidizing</u>	
Initial Deformation	xxx °F		xxx °F	
Softening (H=W)	xxx °F		xxx °F	
Softening (H = 1/2 W)	xxx °F		xxx °F	
Fluid	xxx °F		xxx °F	

H = Cone Height
W = Cone Width

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

94

R. A. Houser
R. A. HOUSER, Manager, Midwest Division



Charter Member

Original Copy Watermarked
For Your Protection

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/dh

filed

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

► KVB, INC.
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 17, 1979

Sample identification
by KVB, Inc.

Kind of sample reported to us	Kentucky Coal	Test No. 6
Sample taken at	Test site J	
Sample taken by	KVB, Inc.	
Date sampled	6/13/79	
Date received	7/12/79	

Analysis report no. 71- 35632

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	2.02	xxxxx
% Ash	4.18	4.27
% Volatile	40.58	41.42
% Fixed Carbon	53.22	54.31
	<u>100.00</u>	<u>100.00</u>
Btu/lb.	13966	14254
% Sulfur	1.30	1.33

FUSION TEMPERATURE OF ASH

	<u>Reducing</u>		<u>Oxidizing</u>	
Initial Deformation	xxx	°F	xxx	°F
Softening (H=W)	xxx	°F	xxx	°F
Softening (H= 1/2 W)	xxx	°F	xxx	°F
Fluid	xxx	°F	xxx	°F

H = Cone Height
W = Cone Width

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

95

R. A. Houser

R. A. HOUSER, Manager, Midwest Division



Charter Member

Original Copy Watermarked
For Your Protection

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/dh

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

KVB, INC.
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 17, 1979

Sample identification
by KVB, Inc.

Kind of sample reported to us Ohio Coal

Test No. 7

Sample taken at Test site J

Sample taken by KVB, Inc.

Date sampled 6/14/79

Date received 7/12/79

Analysis report no. 71- 35630

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	2.93	xxxxx
% Ash	7.11	7.32
% Volatile	38.89	40.06
% Fixed Carbon	51.07	52.62
	<u>100.00</u>	<u>100.00</u>
Btu/lb.	13373	13777
% Sulfur	1.68	1.73

FUSION TEMPERATURE OF ASH

	<u>Reducing</u>		<u>Oxidizing</u>	
Initial Deformation	xxx °F		xxx °F	
Softening (H = W)	xxx °F		xxx °F	
Softening (H = 1/2 W)	xxx °F		xxx °F	
Fluid	xx °F		xxx °F	

H = Cone Height
W = Cone Width

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

96

R. A. Houser
R. A. HOUSER, Manager, Midwest Division



Original Copy Watermarked
For Your Protection

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/dh

field

COMMERCIAL TESTING & ENGINEERING CO.
 GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 · AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
 16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
 OFFICE TEL. (312) 264-1173

► **KVB, INC.**
 6176 Olson Memorial Highway
 Minneapolis, MN 55422

July 17, 1979

Sample identification
 by **KVB, Inc.**

Kind of sample reported to us	Kentucky Coal	Test No. 8
Sample taken at	Test site J	
Sample taken by	KVB, Inc.	
Date sampled	6/15/79	
Date received	7/12/79	

Analysis report no. 71- 35628

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	1.94	xxxxx
% Ash	5.31	5.42
% Volatile	40.35	41.15
% Fixed Carbon	52.40	53.43
	<u>100.00</u>	<u>100.00</u>
Btu/lb.	13995	14272
% Sulfur	1.40	1.43

FUSION TEMPERATURE OF ASH

	<u>Reducing</u>	<u>Oxidizing</u>	
Initial Deformation	xxx °F	xxx °F	H = Cone Height W = Cone Width
Softening (H = W)	xxx °F	xxx °F	
Softening (H = 1/2 W)	xxx °F	xxx °F	
Fluid	xxx °F	xxx °F	

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

97

R. A. Houser
 R. A. HOUSER, Manager, Midwest Division



Charter Member

Original Copy Watermarked
 For Your Protection

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

KVB, INC.
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 17, 1979

Sample identification
by KVB, Inc.

Kind of sample reported to us Kentucky Coal Test No. 9

Sample taken at Test site J

Sample taken by KVB, Inc.

Date sampled 6/16/79

Date received 7/12/79

Analysis report no. 71- 35629

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	2.91	xxxxx
% Ash	11.76	12.11
% Volatile	35.85	36.92
% Fixed Carbon	49.48	50.97
	<u>100.00</u>	<u>100.00</u>
Btu/lb.	12511	12886
% Sulfur	2.57	2.65

FUSION TEMPERATURE OF ASH

	<u>Reducing</u>		<u>Oxidizing</u>	
Initial Deformation	xxx °F		xxx °F	
Softening (H = W)	xxx °F		xxx °F	
Softening (H = 1/2 W)	xxx °F		xxx °F	
Fluid	xxx °F		xxx °F	

H -- Cone Height
W -- Cone Width

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

R. A. Houser
R. A. HOUSER, Manager, Midwest Division



Charter Member

98

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

► KVB, INC.
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 17, 1979

Sample identification
by KVB, Inc.

Kind of sample reported to us	Ohio Coal	Test No. 13
Sample taken at	Test site J	
Sample taken by	KVB, Inc.	
Date sampled	6/19/79	
Date received	7/12/79	

Analysis report no. 71- 35631

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	4.85	xxxxx
% Ash	8.23	8.65
% Volatile	36.71	38.58
% Fixed Carbon	50.21	52.77
	<u>100.00</u>	<u>100.00</u>
Btu/lb.	12810	13463
% Sulfur	1.64	1.72

FUSION TEMPERATURE OF ASH

	<u>Reducing</u>		<u>Oxidizing</u>	
Initial Deformation	xxx °F		xxx °F	
Softening (H=W)	xxx °F		xxx °F	
Softening (H= 1/2 W)	xxx °F		xxx °F	
Fluid	xxx °F		xxx °F	

H = Cone Height
W = Cone Width

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

R. A. House
R. A. HOUSER, Manager, Midwest Division



Charter Member

99

Original Copy Watermarked
For Your Protection

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/dh

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 284-1173

KVB, INC.
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 17, 1979

Sample identification
by KVB, Inc.

Kind of sample reported to us Ohio Coal

Test No. 14

Sample taken at Test site J

Sample taken by KVB, Inc.

Date sampled 6/20/79

Date received 7/12/79

Analysis report no. 71- 35625

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
% Moisture	3.18	XXXXX
% Ash	8.23	8.50
% Volatile	38.91	40.19
% Fixed Carbon	49.68	51.31
	<u>100.00</u>	<u>100.00</u>
Btu/lb.	13101	13531
% Sulfur	1.82	1.88

FUSION TEMPERATURE OF ASH

	<u>Reducing</u>		<u>Oxidizing</u>	
Initial Deformation	XXX °F		XXX °F	
Softening (H = W)	XXX °F		XXX °F	
Softening (H = 1/2 W)	XXX °F		XXX °F	
Fluid	XXX °F		XXX °F	

H = Cone Height
W = Cone Width

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

100

R. A. Houser
R. A. HOUSER, Manager, Midwest Division



Charter Member

Original Copy Watermarked
For Your Protection

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/dh

filed

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 • AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

► KVB
A Research-Cottrell Co.
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 25, 1979

Sample identification
by KVB

Kind of sample reported to us Kent. Coal

Test #15
Test Site: J

Sample taken at -----

Sample taken by KVB

Date sampled 6/28/79

Date received 7/12/79

Analysis report no. 71-35627

PROXIMATE ANALYSIS

	As Received	Dry Basis
%Moisture.....	2.09	xxxxx
%Ash.....	5.02	5.13
%Volatile.....	39.58	40.42
%Fixed Carbon.....	53.31	54.45
	<u>100.00</u>	<u>100.00</u>
Btu/lb.....	13954	14252
%Sulfur.....	1.03	1.05

	%Weight	
	As Received	Dry Basis
%Pyritic Sulfur.....	0.26	0.27
%Sulfate Sulfur.....	0.02	0.02
%Organic Sulfur(dif)...	0.75	0.76

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

101

R. A. Houser

R. A. HOUSER, Manager, Midwest Division



Charter Member

Original Copy Watermarked
For Your Protection

RAH/br

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

Field

KVB
A Research-Cottrell Co.
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 21, 1979

Sample identification
by KVB

Kind of sample reported to us Coal
Sample taken at ----
Sample taken by KVB
Date sampled 6/30/79
Date received 7/12/79

Sample: Ohio coal
Test No. 16
Test site: J

Analysis report no. 71-35633

PROXIMATE ANALYSIS

	<u>As Received</u>	<u>Dry Basis</u>
%Moisture	3.73	xxxxx
%Ash	7.77	8.07
%Volatile	38.06	39.53
%Fixed carbon	50.44	52.40
	<u>100.00</u>	<u>100.00</u>
Btu/lb.	12990	13493
%Sulfur	2.02	2.10
%Pyritic sulfur	1.39	1.44
%Sulfate sulfur	0.10	0.11
%Organic sulfur	0.53	0.55

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

102

R. A. HOUSER, Manager, Midwest Division



Charter Member

Original Copy Watermarked
For Your Protection

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/br

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

July 25, 1979

KVB
A Research-Cottrell Co.
6176 Olson Memorial Highway
Minneapolis, MN 55422

Kind of sample reported to us **Ohio Coal**

Sample taken at **---**

Sample taken by **KVB**

Date sampled **---**

Date received **7/12/79**

Sample identification by **KVB**

Test No.: **Composite**
Test Site: **J**

Analysis report no. 71-35635			% Weight		
PROXIMATE ANALYSIS	As received	Dry basis	ULTIMATE ANALYSIS	As received	Dry basis
% Moisture	3.05	xxxxx	Moisture	3.05	xxxxx
% Ash	7.05	7.27	Carbon	74.74	77.09
% Volatile	37.93	39.12	Hydrogen	5.13	5.29
% Fixed Carbon	51.97	53.61	Nitrogen	1.66	1.71
	<u>100.00</u>	<u>100.00</u>	Chlorine	0.19	0.20
Btu/lb.	13368	13789	Sulfur	1.75	1.80
% Sulfur	1.75	1.80	Ash	7.05	7.27
% Alk. as Na ₂ O	xxxxx	0.12	Oxygen (diff)	6.43	6.64
				<u>100.00</u>	<u>100.00</u>
<u>SULFUR FORMS</u>			<u>MINERAL ANALYSIS OF ASH</u>		
% Pyritic Sulfur	0.97	1.00	% Weight Ignited Basis		
% Sulfate Sulfur	0.05	0.05	Silica, SiO ₂	42.48	
% Organic Sulfur	0.73	0.75	Alumina, Al ₂ O ₃	26.60	
			Titania, TiO ₂	1.29	
<u>WATER SOLUBLE ALKALIES</u>			Ferric oxide, Fe ₂ O ₃	22.09	
% Na ₂ O =	xxxxx	xxxxx	Lime, CaO	2.11	
% K ₂ O =	xxxxx	xxxxx	Magnesia, MgO	0.83	
			Potassium oxide, K ₂ O	1.91	
<u>FUSION TEMPERATURE OF ASH</u>			Sodium oxide, Na ₂ O	0.35	
Initial Deformation	2100 °F	xxxxx °F	Sulfur trioxide, SO ₃	1.43	
H is Cone Height Softening (H = W)	2250 °F	xxxxx °F	Phos. pentoxide, P ₂ O ₅	0.40	
W is Cone Width Softening (H = 1/2 W)	2400 °F	xxxxx °F	Undetermined	0.38*	
Fluid	2535 °F	xxxxx °F		<u>100.00</u>	
% EQUILIBRIUM MOISTURE =	2.94		SILICA VALUE =	62.92	
HARDGROVE GRINDABILITY INDEX =	53		BASE: ACID RATIO	0.39	
FREE SWELLING INDEX =	4		T ₂₅₀ Temperature =	2425 °F	

*These ignited basis results were used to calculate undetermined value above
 ‡Strontium oxide, SrO 0.00
 ‡Barium oxide, BaO 0.08
 ‡Manganese oxide, Mn₃O₄ 0.05

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

R. A. Houser

R. A. HOUSER, Manager, Midwest Division



Charter Member

103

Original Copy Watermarked For Your Protection

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
 HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/br

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434

field



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

July 26, 1979

KVB
A Research-Cottrell Co.
6176 Olson Memorial Highway
Minneapolis, MN 55422

Sample identification
by KVB

Kind of sample reported to us **Coal**
Sample taken at **---**
Sample taken by **KVB**
Date sampled **---**
Date received **7/12/79**

Test No. **Composite**
Sample: **Kent Coal**
Test Site: **J**

PROXIMATE ANALYSIS	Analysis report no. 71-35634		ULTIMATE ANALYSIS	% Weight	
	As received	Dry basis		As received	Dry basis
% Moisture	1.96	xxxxx	Moisture	1.96	xxxxx
% Ash	6.14	6.26	Carbon	76.77	78.31
% Volatile	39.08	39.86	Hydrogen	5.09	5.19
% Fixed Carbon	52.82	53.88	Nitrogen	1.23	1.25
	<u>100.00</u>	<u>100.00</u>	Chlorine	0.13	0.13
Btu/lb.	13624	13897	Sulfur	1.43	1.46
% Sulfur	1.43	1.46	Ash	6.14	6.26
% Alk. as Na ₂ O	xxxxx	0.12	Oxygen (diff)	7.25	7.40
			<u>100.00</u>	<u>100.00</u>	
SULFUR FORMS			MINERAL ANALYSIS OF ASH	% Weight Ignited Basis	
% Pyritic Sulfur	0.68	0.69	Silica, SiO ₂	44.08	
% Sulfate Sulfur	0.02	0.02	Alumina, Al ₂ O ₃	26.46	
% Organic Sulfur	0.73	0.75	Titania, TiO ₂	1.51	
WATER SOLUBLE ALKALIES			Ferric oxide, Fe ₂ O ₃	17.80	
% Na ₂ O =	xxxxx	xxxxx	Lime, CaO	2.28	
% K ₂ O =	xxxxx	xxxxx	Magnesia, MgO	0.78	
			Potassium oxide, K ₂ O	1.78	
FUSION TEMPERATURE OF ASH	Reducing	Oxidizing	Sodium oxide, Na ₂ O	0.80	
Initial Deformation	2205 °F	°F	Sulfur trioxide, SO ₃	1.85	
H is Cone Height Softening (H=W)	2335 °F	°F	Phos. pentoxide, P ₂ O ₅	0.31	
W is Cone Width Softening (H=1/2W)	2465 °F	°F	Undetermined	1.89	
Fluid	2580 °F	°F		<u>100.00</u>	
% EQUILIBRIUM MOISTURE =	2.07		SILICA VALUE =	67.88	
HARDGROVE GRINDABILITY INDEX =	49		BASE: ACID RATIO	0.33	
FREE SWELLING INDEX =	6		T ₂₅₀ Temperature =	2515 °F	

*These ignited basis results were used to calculate undetermined value above

- %Strontium oxide, SrO 0.14
- %Barium oxide, BaO 0.30
- %Manganese oxide, Mn₃O₄ 0.02
- Fouling index 0.26
- Slagging index 0.48

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

R. A. Houser
R. A. HOUSER, Manager, Midwest Division



Original Copy Watermarked
For Your Protection

104

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 - AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

► KVB
A Research-Cottrell Company
6176 Olson Memorial Highway
Minneapolis, MN 55422

June 28, 1979

Sample identification
by KVB

Kind of sample reported to us	Ash
Sample taken at	----
Sample taken by	KVB
Date sampled	----
Date received	6/23/79

Test No. 1
Sample: Bottom Ash
Site: J

Analysis report no. 71-34527

Dry Basis

%Ash.....	79.83
%Combustible.....	20.17

Original Copy Watermarked
For Your Protection

105

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

R. A. House
R. A. HOUSE, Manager, Midwest Division



Charter Member

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/ br

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

► KVB
A Research-Cottrell Company
6176 Olson Memorial Highway
Minneapolis, MN 55422

June 28, 1979

Sample identification
by KVB

Kind of sample reported to us Ash
Sample taken at ----
Sample taken by KVB
Date sampled ----
Date received 6/23/79

Test No. 2
Sample: Bottom Ash
Site: J

Analysis report no. 71-34531

Dry Basis

%Ash..... 84.53
%Combustible..... 15.47

Original Copy Watermarked
For Your Protection

106

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

R. A. Houser
R. A. HOUSER, Manager, Midwest Division



Charter Member

RAH/ br

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 · AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

July 17, 1979

▶ KVB, INC.
6176 Olson Memorial Highway
Minneapolis, MN 55422

Sample identification
by KVB, Inc.

Test No. 6

Kind of sample reported to us	Bottom Ash
Sample taken at	Test site J
Sample taken by	KVB, Inc.
Date sampled	6/13/79
Date received	7/12/79

Analysis report no. 71- 35638

‡ Combustible, dry basis 20.26

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

R. A. Houser

R. A. HOUSER, Manager, Midwest Division

107



Charter Member

Original Copy Watermarked
For Your Protection

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/dh

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

July 17, 1979

Sample identification
by KVB, Inc.

▶ KVB, INC.
6176 Olson Memorial Highway
Minneapolis, MN 55422

Test No. 7

Kind of sample reported to us Bottom Ash

Sample taken at Test site J

Sample taken by KVB, Inc.

Date sampled 6/14/79

Date received 7/12/79

Analysis report no. 71- 35641

% Combustible, dry basis 19.57

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

108

R. A. House
R. A. HOUSE, Manager, Midwest Division



SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

Original Copy Watermarked
For Your Protection

RAH/dh

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

▶ KVB, INC.
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 17, 1979

Sample Identification
by KVB, Inc.

Kind of sample reported to us Bottom Ash
Sample taken at Test site J
Sample taken by KVB, Inc.
Date sampled 6/15/79
Date received 7/12/79

Test No. 8

Analysis report no. 71- 35640

% Combustible, dry basis 30.75

Original Copy Watermarked
For Your Protection

109

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

R. A. HOUSER, Manager, Midwest Division



Charter Member

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/dh

Field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

▶ KVB, INC.
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 17, 1979

Sample identification
by KVB, Inc.

Kind of sample reported to us Bottom Ash

Test No. 9

Sample taken at Test site J

Sample taken by KVB, Inc.

Date sampled 6/16/79

Date received 7/12/79

Analysis report no. 71- 35637

% Combustible, dry basis 7.23

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

110

R. A. HOUSER, Manager, Midwest Division



Charter Member

Original Copy Watermarked
For Your Protection

SD. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/dh

Handwritten mark

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 80601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

▶ KVB, INC.
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 17, 1979

Sample identification
by KVB, Inc.

Kind of sample reported to us Bottom Ash

Test No. 13

Sample taken at Test site J

Sample taken by KVB, Inc.

Date sampled 6/19/79

Date received 7/12/79

Analysis report no. 71- 35639

% Combustible, dry basis 18.58

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

R. A. Houser

R. A. HOUSER, Manager, Midwest Division



Charter Member

111

Original Copy Watermarked
For Your Protection

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/dh

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

▶ **KVB, INC.**
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 17, 1979

Sample identification
by **KVB, Inc.**

Kind of sample reported to us **Bottom Ash**

Test No. 14

Sample taken at **Test site J**

Sample taken by **KVB, Inc.**

Date sampled **6/20/79**

Date received **7/12/79**

Analysis report no. 71- 35636

% Combustible, dry basis 30.93

Original Copy Watermarked
For Your Protection

112

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

R. A. Houser
R. A. HOUSER, Manager, Midwest Division



SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/dh

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

▶ KVB, INC.
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 17, 1979

Sample identification
by KVB, Inc.

Kind of sample reported to us Bottom Ash

Test No. 15

Sample taken at Test site J

Sample taken by KVB, Inc.

Date sampled 6/28/79

Date received 7/12/79

Analysis report no. 71- 35643

% Combustible, dry basis 24.09

% Sulfur, dry basis 0.51

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

113

R. A. Houser

R. A. HOUSER, Manager, Midwest Division



Charter Member

Original Copy Watermarked
For Your Protection

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/dh

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

▶ KVB, INC.
6176 Olson Memorial Highway
Minneapolis, MN 55422

July 17, 1979

Sample identification
by KVB, Inc.

Kind of sample reported to us	Bottom Ash	Test No. 16
Sample taken at	Test site J	
Sample taken by	KVB, Inc.	
Date sampled	6/30/79	
Date received	7/12/79	

Analysis report no. 71- 35642

% Combustible, dry basis	18.97
% Sulfur, dry basis	0.31

Original Copy Watermarked
For Your Protection

114

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

R. A. Houser
R. A. HOUSER, Manager, Midwest Division



RAH/dh

filed

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 · AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 264-1173

► **KVB**
A Research-Cottrell Company
6176 Olson Memorial Highway
Minneapolis, MN 55422

June 28, 1979

Sample identification
by KVB

Kind of sample reported to us Ash
Sample taken at ----
Sample taken by KVB
Date sampled ----
Date received 6/23/79

Test No. 1
Sample: Multclone Ash
Test Site: J

Analysis report no. 71-34548

Dry Basis

%Ash..... 70.14
%Combustible..... 29.86

Original Copy Watermarked
For Your Protection

115

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

R. A. Houser
R. A. HOUSER, Manager, Midwest Division



Charter Member

SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/ br

field

COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 AREA CODE 312 726-8434



PLEASE ADDRESS ALL CORRESPONDENCE TO:
16130 VAN DRUNEN RD., SOUTH HOLLAND, IL 60473
OFFICE TEL. (312) 284-1173

▶ KVB
A Research-Cottrell Company
6176 Olson Memorial Highway
Minneapolis, MN 55422

June 28, 1979

Sample identification
by KVB

Kind of sample reported to us Ash
Sample taken at -----
Sample taken by KVB
Date sampled -----
Date received 6/23/79

Test No. 2
Sample: Multclone Ash
Site: J

Analysis report no. 71-34532

Dry Basis

%Ash..... 87.91
%Combustible..... 12.09

Original Copy Watermarked
For Your Protection

116

Respectfully submitted,
COMMERCIAL TESTING & ENGINEERING CO.

R. A. Houser
R. A. HOUSER, Manager, Midwest Division



SO. HOLLAND, IL • BILLINGS, MT • BIRMINGHAM, AL • CHARLESTON, WV • CLARKSBURG, WV • CLEVELAND, OH • DENVER, CO • GOLDEN, CO
HENDERSON, KY • MIDDLESBORO, KY • MOBILE, AL • NEW ORLEANS, LA • NORFOLK, VA • PIKEVILLE, KY • VANCOUVER, B.C. CAN.

RAH/ br

COMBUSTIBLES DATA SHEET

SITE J

Crucible Number	Sample Origin	Crucible Weight grams	Crucible & Sample Weight Post 110°C gms	Sample Weight grams	Post 750°C grams	Δ Weight grams	% Combustibles
25	TEST #1 Site J BLR OUT AVG.	9.6889	9.8850	0.1961	9.8325	0.525	26.7
		9.6889	9.8850		9.8326		
		9.6891	—		—		
		9.6889	9.8850		9.8325		
26	TEST #2 BLR OUT AVG.	10.2368	10.9110	0.6750	10.7432	0.1686	24.9
		10.2370	10.9120		10.7434		
		10.2369	—		—		
		10.2369	10.9119		10.7433		
27	TEST #3 BLR OUT AVG.	9.4131	9.6644	0.2511	10.5777	0.0577	23.7
		9.4132	9.6643		9.6045		
		9.4132	—		9.6047		
		9.4132	9.6643		9.6046		
29	TEST #6 BLR OUT AVG.	10.2774	11.5592	1.2820	11.2150	0.3442	26.8
		10.2772	11.5594		11.2152		
		10.2773	—		—		
		10.2773	11.5593		11.2151		
33	TEST #7 BLR OUT AVG.	10.2320	10.5351	0.3031	10.4604	0.0749	24.7
		10.2321	10.5353		10.4602		
		10.2323	—		—		
		10.2321	10.5352		10.4603		
37	TEST #8 BLR OUT AVG.	10.2072	10.4690	0.2618	10.3747	0.0945	36.0
		10.2073	10.4692		10.3746		
		10.2073	—		—		
		10.2073	10.4691		10.3746		
40	TEST #9 BLR OUT AVG.	9.2519	9.4155	0.1636	9.3661	0.0493	30.1
		9.2521	9.4157		9.3664		
		9.2521	—		—		
		9.2520	9.4156		9.3663		
	AVG.						
	AVG.						
	AVG.						
	AVG.						

KVB

SIEVE ANALYSIS TEST REPORT

TEST NO. 1


DATE SAMPLE TAKEN 6-3-79

TEST SITE J

TEST PERFORMED BY JCS

SAMPLE IDENTIFICATION Ohio

Screen Size Passing	Tare Weight (gm)	Gross Weight (gm)	Net Weight (gm)	Percent (%)	Cumulative Weight Passing (gm)	Cumulative Percent Passing (%)	Sieve Shaker Duration (min)
Top	109.3	559.2 770.7	1111.3	22.5	4944.7	100.0	5
1"	↓	1155.2 1124.0	2060.6	41.7	3833.4	77.5	5
1/2"		748.4 707.2	1237.0	25.0	1772.8	35.8	5
3/4"		387.9	278.6	5.6	535.8	10.8	5
#8		150.0	40.7	0.8	257.2	5.2	5
#16		325.8	216.5	4.4	216.5	4.4	5



KVB

SIEVE ANALYSIS TEST REPORT

TEST NO. 2


DATE SAMPLE TAKEN 6-4-79

TEST SITE J

TEST PERFORMED BY LOB

SAMPLE IDENTIFICATION Ohio

Screen Size Passing	Tare Weight (gm)	Gross Weight (gm)	Net Weight (gm)	Percent (%)	Cumulative Weight Passing (gm)	Cumulative Percent Passing (%)	Sieve Shaker Duration (min)
TOP	109.8	594.3 538.1	912.8	16.4	5553.5	100.0	5
1"	↓	1131.4 1274.0	2135.8	38.5	4644.7	83.5	5
2"		819.8 907.4	1507.6	27.1	2504.9	45.0	5
4"		345.7 406.5	532.6	9.6	997.3	17.9	5
#8		250.2	140.4	2.5	464.7	8.3	5
#16		434.1	324.3	5.8	324.3	5.8	5



KVB

SIEVE ANALYSIS TEST REPORT

TEST NO. 5


DATE SAMPLE TAKEN 6-12-79

TEST SITE J

TEST PERFORMED BY JOB

SAMPLE IDENTIFICATION Ohio

Screen Size Passing	Tare Weight (gm)	Gross Weight (gm)	Net Weight (gm)	Percent (%)	Cumulative Weight Passing (gm)	Cumulative Percent Passing (%)	Sieve Shaker Duration (min)
TOP	109.0	448.2	339.2	5.9	5710.7	100.0	5
1"	↓	764.5 990.2	1536.7	26.9	5371.5	94.2	5
1" 2"		778.8 1167.0	1727.8	30.3	3834.8	67.3	5
1" 4"		1123.0	1014.0	17.8	2107.0	37.0	5
#8		548.0	439.0	7.7	1093.0	19.2	5
#16		763.0	654.0	11.5	654.0	11.5	5



KVB

SIEVE ANALYSIS TEST REPORT

TEST NO. 6


DATE SAMPLE TAKEN 6-13-75

TEST SITE J

TEST PERFORMED BY JLB

SAMPLE IDENTIFICATION Kentucky Coal

Screen Size Passing	Tare Weight (gm)	Gross Weight (gm)	Net Weight (gm)	Percent (%)	Cumulative Weight Passing (gm)	Cumulative Percent Passing (%)	Sieve Shaker Duration (min)
TOP	109.6	262.2 520.6	563.6	9.4	5994.5	100.0	5
1"	↓	1817.4 1232.5	4185.6	69.8	5430.9	90.6	5
1/2"		804.8 373.0	958.6	16.0	1245.3	20.8	5
1/4"		199.0	89.4	1.5	296.7	4.8	5
#8		133.1	23.5	0.4	197.3	3.3	5
#16		283.4	173.8	2.9	173.8	2.9	5



KVB

SIEVE ANALYSIS TEST REPORT

TEST NO. 7


DATE SAMPLE TAKEN 6-14-79

TEST SITE J

TEST PERFORMED BY JOB

SAMPLE IDENTIFICATION Ohio

Screen Size Passing	Tare Weight (gm)	Gross Weight (gm)	Net Weight (gm)	Percent (%)	Cumulative Weight Passing (gm)	Cumulative Percent Passing (%)	Sieve Shaker Duration (min)
Top	109.0	818.7 600.0	1200.7	22.6	5324.0	100.0	5
1"	↓	1385.1 1309.9	378.3 2855.3	53.6	4123.3	77.4	5
1/2"		695.5 405.3	872.8	16.4	1268.0	23.8	5
3/4"		295.0	186.0	3.5	395.2	7.4	5
#8		142.9	33.9	0.6	209.2	3.9	5
#16		284.3	175.3	3.3	175.3	3.3	5



KVB

SIEVE ANALYSIS TEST REPORT

TEST NO. 8


DATE SAMPLE TAKEN 6-15-79

TEST SITE J

TEST PERFORMED BY JOB

SAMPLE IDENTIFICATION Kentucky

Screen Size Passing	Tare Weight (gm)	Gross Weight (gm)	Net Weight (gm)	Percent (%)	Cumulative Weight Passing (gm)	Cumulative Percent Passing (%)	Sieve Shaker Duration (min)
TOP	1092	208.0 174.7	164.3	3.0	5452.0	100.0	5
1"	↓	1826.7 1248.4	2856.7	52.4	5287.7	97.0	5
1/2"		1141.8 914.3	1837.7	33.7	2431.0	44.6	5
3/4"		423.4	314.2	5.8	593.3	10.9	5
#8		160.8	51.6	0.9	279.1	5.1	5
#16		336.7	227.5	4.2	277.5	4.2	5



KVB

SIEVE ANALYSIS TEST REPORT

TEST NO. 9


DATE SAMPLE TAKEN 6-16-79

TEST SITE J

TEST PERFORMED BY J.B.

SAMPLE IDENTIFICATION Kentucky Coal

Screen Size Passing	Tare Weight (gm)	Gross Weight (gm)	Net Weight (gm)	Percent (%)	Cumulative Weight Passing (gm)	Cumulative Percent Passing (%)	Sieve Shaker Duration (min)
Top	109.7	191.4 379.1	311.1	5.9	5245.7	100.0	5
1"	↓	1304.4 1061.9	2146.9	40.9	4934.6	94.0	5
½"		1259.6 801.9	1842.1	35.1	2787.7	53.1	5
¾"		557.4	447.7	8.5	945.6	18.0	5
#8		221.7	112.0	2.1	497.9	9.5	5
#16		495.6	385.9	7.4	385.9	7.4	5



KVB

SIEVE ANALYSIS TEST REPORT

TEST NO. 13


DATE SAMPLE TAKEN 6-19-79

TEST SITE J

TEST PERFORMED BY JLB

SAMPLE IDENTIFICATION Ohio

Screen Size Passing	Tare Weight (gm)	Gross Weight (gm)	Net Weight (gm)	Percent (%)	Cumulative Weight Passing (gm)	Cumulative Percent Passing (%)	Sieve Shaker Duration (min)
TOP	109.3	497.7 276.6	555.7	10.5	5216.0	100.0	5
1"	↓	1102.6 1581.4	2465.4	46.7	4720.3	89.5	5
1/2"	↓	733.0 776.3	1289.7	24.4	2254.9	42.8	5
1/4"	↓	382.2	272.9	5.2	965.2	18.4	5
*8	↓	280.9	171.6	3.3	692.3	13.2	5
*16	↓	630.0	520.7	9.9	520.7	9.9	5



KVB

SIEVE ANALYSIS TEST REPORT

TEST NO. 14


DATE SAMPLE TAKEN 6-20-79

TEST SITE

TEST PERFORMED BY JB

SAMPLE IDENTIFICATION Okc

Screen Size Passing	Tare Weight (gm)	Gross Weight (gm)	Net Weight (gm)	Percent (%)	Cumulative Weight Passing (gm)	Cumulative Percent Passing (%)	Sieve Shaker Duration (min)
Top	109.4	329.2 540.0	650.4	15.6	4171.8	100.0	5
1"		1048.2 1222.2	2051.6	49.2	3521.4	84.4	5
1/2"		635.9 594.7	1011.8	24.3	1469.8	35.2	5
3/4"		285.7	176.3	4.2	458.0	10.9	5
#8		169.3	59.9	1.4	281.7	6.7	5
#16		331.2	221.8	5.3	221.8	5.3	5



KVB

SIEVE ANALYSIS TEST REPORT

TEST NO. 15


DATE SAMPLE TAKEN 6-28-79

TEST SITE ✓

TEST PERFORMED BY JOE

SAMPLE IDENTIFICATION Kentucky

Screen Size Passing	Tare Weight (gm)	Gross Weight (gm)	Net Weight (gm)	Percent (%)	Cumulative Weight Passing (gm)	Cumulative Percent Passing (%)	Sieve Shaker Duration (min)
TOP	109.5	185.4 427.7	397.4	6.0	650.1	100.0	5
1"	↓	1696.5 1235.1 1362.0 728.6	4592.2	70.1	6156.0	94.0	5
2"		608.1 863.9	1253.0	19.1	1563.8	23.9	5
4"		208.5	79.0	1.5	310.8	4.8	5
8"		131.5	22.0	0.3	211.8	3.3	5
16"		259.3	129.8	2.9	189.8	3.0	5



KVB

SIEVE ANALYSIS TEST REPORT

TEST NO. Composite


DATE SAMPLE TAKEN

TEST SITE J

TEST PERFORMED BY JOB

SAMPLE IDENTIFICATION Ohio Coal

Screen Size Passing	Tare Weight (gm)	Gross Weight (gm)	Net Weight (gm)	Percent (%)	Cumulative Weight Passing (gm)	Cumulative Percent Passing (%)	Sieve Shaker Duration (min)	
TOP	110.3	756.2 894.1	1429.7	15.1	9452.8	100.0	5	
11"	↓	1650.4 1514.3	3915.7	41.4	8023.1	84.9	5	
2"		994.2 1471.5	2245.1	23.8	4107.4	43.5	5	
4"		501.1 482.8	763.3	8.1	1862.3	19.7	5	
#8		392.5	282.2	3.0	1099.0	11.6	5	
#16			97.1	816.8	8.6	816.8	8.6	5



KVB

SIEVE ANALYSIS TEST REPORT

TEST NO. Composite


DATE SAMPLE TAKEN _____

TEST SITE J

TEST PERFORMED BY JSP

SAMPLE IDENTIFICATION Kentucky Coal

Screen Size Passing	Tare Weight (gm)	Gross Weight (gm)	Net Weight (gm)	Percent (%)	Cumulative Weight Passing (gm)	Cumulative Percent Passing (%)	Sieve Shaker Duration (min)
TOP	1095	190.8 339.2	311.0	5.5	5666.1	100.0	5
1"	↓	1507.2 1268.7	3413.3	60.2	5355.1	94.5	5
1/2"		594.4 997.6	1373.0	24.2	1941.8	34.3	5
1/4"		358.4	248.9	4.4	568.8	10.1	5
#8		176.0	66.5	1.2	319.9	5.7	5
#16		362.9	253.4	4.5	253.4	4.5	5




SECTION 6.0
OVERFIRE AND TRAVERSES

	<u>PAGE</u>
6.1 OVERFIRE AIR DATA SHEETS	132

**OVERFIRE AIR TRAVERSE
SMOKESTACK FLOW PROFILE**

TEST NO. 10
 LOCATION NO. MAIN DUCT
 DATE 6-17-79
 SAMPLING LOCATION FRONT OFA
 INSIDE OF FAR WALL TO 19 3/4"
 OUTSIDE OF NIPPLE, (DISTANCE A) _____ BAROMETRIC PRESS, in.Hg 29.36
 INSIDE OF NEAR WALL TO 3 1/8"
 OUTSIDE OF NIPPLE, (DISTANCE B) _____ STACK PRESS., Ps, iwg _____
 STACK I.D. (DISTANCE A - DISTANCE B) 16 5/8" STK. GAS SP. GRAVITY, G_S _____
 NEAREST UPSTREAM DISTURBANCE _____
 NEAREST DOWNSTREAM DISTURBANCE _____




OFA setting 30
 OFA tap - 1/2" H₂O
 static
 RH = 33%

TRAVERSE POINT NUMBER	% OF STACK DIAMETER	DISTANCE FROM INSIDE WALL	VELOCITY HEAD (ΔP _S), in. H ₂ O	STACK TEMPERATURE (T _S , °F)	OXYGEN %	STACK GAS SPEED, V _S ft/min
1.	3.2	0.541" + 3 1/8" = 3 11/16"	ΔP ₁ 0.03 ΔP ₂ 0.03	110		
2.	10.5	1.745" + 3 1/8" = 4 7/8"	0.03 0.04			
3.	19.4	3.225" + 3 1/8" = 6 3/8"	0.03 0.04			
4.	32.3	5.370" + 3 1/8" = 8 1/2"	0.04 0.04			
5.	67.7	11.255" + 3 1/8" = 14 3/8"	0.04 0.005 *			
6.	80.6	13.40" + 3 1/8" = 16 1/2"	0.03 0.008 *			
7.	87.5	14.879" + 3 1/8" = 18"	0.04 0.008 *			
8.	96.8	16.076" + 3 1/8" = 19 3/8"	0.01 0.008 *			
9.						
10.						
11.						
12.						
13.						
14.						
15.						
16.						
17.						
18.						
Average						

STACK GAS, V_S = 174 F_S $\sqrt{\frac{\text{Average } \Delta P (T_s + 460)}{P_s} \left(\frac{407}{P_s}\right) \left(\frac{1.00}{G_s}\right)}$
 SPEED

* standard pitot tube used otherwise S type (C = 0.837)

OVERFIRE AIR TRAVERSES
SMOKESTACK FLOW PROFILE



TEST NO. 11
 LOCATION NO. MAIN DUCT
 DATE 6-17-79
 SAMPLING LOCATION FRONT OF A
 INSIDE OF FAR WALL TO 19 3/4"
 OUTSIDE OF NIPPLE, (DISTANCE A) _____ BAROMETRIC PRESS, in. Hg 29.36
 INSIDE OF NEAR WALL TO 3 1/8"
 OUTSIDE OF NIPPLE, (DISTANCE B) _____ STACK PRESS., Ps, iwg _____
 STACK I.D. (DISTANCE A - DISTANCE B) 16 5/8" STK. GAS SP. GRAVITY, G_S _____
 NEAREST UPSTREAM DISTURBANCE _____
 NEAREST DOWNSTREAM DISTURBANCE _____

OFA setting - 60
 OFA static 2 1/2" H₂O
 RH = 33%

TRAVERSE POINT NUMBER	% OF STACK DIAMETER	DISTANCE FROM INSIDE WALL	VELOCITY HEAD (ΔP _S), in. H ₂ O	STACK TEMPERATURE (T _S), °F	OXYGEN %	STACK GAS SPEED, V _S ft/min
1.	3.2	3 1/16"	DP ₁ 0.15 DP ₂ 0.11	110		
2.	10.5	4 7/8"	0.16 0.12			
3.	19.4	6 3/8"	0.17 0.11			
4.	32.3	8 1/2"	0.17 0.11			
5.	61.7	14 7/8"	0.12 0.05 +			
6.	80.6	16 1/2"	0.10 0.05 +			
7.	89.5	18"	0.09 0.03 +			
8.	96.5	19 3/16"	0.08 0.02 +			
9.						
10.						
11.						
12.						
13.						
14.						
15.						
16.						
17.						
18.						
Average						


$$\text{STACK GAS, } V_s = 174 F_s \sqrt{\frac{\text{Average } \Delta P (T_s + 460)}{(P_s) (G_s)}}$$

SPEED

* standard pitot tube used otherwise Stype (C = 0.837)

**OVERFIRE AIR TRAVERSE
SMOKESTACK FLOW PROFILE**

TEST NO. 12
 LOCATION NO. MAIN DUCT
 DATE 6-17-79
 SAMPLING LOCATION FRONT OFA
 INSIDE OF FAR WALL TO 19 3/4"
 OUTSIDE OF NIPPLE, (DISTANCE A) _____ BAROMETRIC PRESS, in.Hg 29.36
 INSIDE OF NEAR WALL TO 3/8"
 OUTSIDE OF NIPPLE, (DISTANCE B) _____ STACK PRESS., Ps, iwg _____
 STACK I.D. (DISTANCE A - DISTANCE B) 16 5/8" STK. GAS SP. GRAVITY, G_S _____
 NEAREST UPSTREAM DISTURBANCE _____
 NEAREST DOWNSTREAM DISTURBANCE _____



OFA setting 100
 OFA static - 8 1/2" H₂O
 RH = 33%

TRAVERSE POINT NUMBER	% OF STACK DIAMETER	DISTANCE FROM INSIDE WALL	VELOCITY HEAD (ΔP _S), in. H ₂ O	STACK TEMPERATURE (T _S , °F)	OXYGEN %	STACK GAS SPEED, V _S ft/min
1.	3.2	3 1/16"	ΔP ₁ 0.32 ΔP ₂ 0.28	108		
2.	10.5	4 7/8"	0.36 0.27			
3.	19.4	6 3/8"	0.44 0.30			
4.	32.3	8 1/2"	0.47 0.33			
5.	67.7	14 3/8"	0.39 0.14 *			
6.	80.6	16 1/2"	0.39 0.14 *			
7.	89.5	18"	0.37 0.10 *			
8.	96.8	19 3/16"	0.30 0.08 +			
9.						
10.						
11.						
12.						
13.						
14.						
15.						
16.						
17.						
18.						
Average						

STACK GAS, V_S = 174 F_S $\sqrt{\frac{\text{Average } \Delta P (T_s + 460)}{P_s} \left(\frac{1.00}{G_s}\right)}$
 SPEED

* standard pitot tube used otherwise S type (C = 0.837)

TECHNICAL REPORT DATA
(Please read instructions on the reverse before completing)

1. REPORT NO. EPA-600/7-80-137b		2.		3. RECIPIENT'S ACCESSION NO.	
4. TITLE AND SUBTITLE Field Tests of Industrial Stoker Coal-fired Boilers for Emissions Control and Efficiency Improvement-- Site J (Data Supplement)				5. REPORT DATE May 1980	
7. AUTHOR(S) J. O. Burlingame, R. A. Parker, W. M. Jackson, and J. D. Demont				6. PERFORMING ORGANIZATION CODE	
9. PERFORMING ORGANIZATION NAME AND ADDRESS KVB, Inc. 6176 Olson Memorial Highway Minneapolis, Minnesota 55422				8. PERFORMING ORGANIZATION REPORT NO.	
12. SPONSORING AGENCY NAME AND ADDRESS EPA, Office of Research and Development * Industrial Environmental Research Laboratory Research Triangle Park, NC 27711				10. PROGRAM ELEMENT NO. EHE-624	
				11. CONTRACT/GRANT NO. EPA- IAG-D7-E681 and DoE-EF-77-C-01-2609	
15. SUPPLEMENTARY NOTES (*)Cosponsors are DoE and the American Boiler Manufacturers Assn. Project officers are R. Hall (EPA) and W. Harvey Jr. (DoE). The final technical report is "a" of this same series.				13. TYPE OF REPORT AND PERIOD COVERED Supplement; 6/79	
				14. SPONSORING AGENCY CODE EPA/600/13	
16. ABSTRACT The Data Supplement is a compilation of test data presented in greater detail than was practical in the final technical report. It is intended to provide the necessary details to other researchers who are interested in performing their own analysis. Readers are referred to the contract final report for information as to objectives, description of facility tested and coals fired, test equipment and procedures, interpretations, and conclusions. The final technical report also contains data summaries not found in this Supplement. The Supplement contains panel board data for each test, detailed particulate, O ₂ , CO ₂ , NO, SO ₂ , and SO ₃ data, particle size distribution data, chemical analysis of the coal, coal size consistency data, and combustible analysis and overfire air traverse data.					
17. KEY WORDS AND DOCUMENT ANALYSIS					
a. DESCRIPTORS		b. IDENTIFIERS/OPEN ENDED TERMS		c. COSATI Field/Group	
Air Pollution	Improvement	Air Pollution Control	13B		
Boilers	Efficiency	Stationary Sources	13A		
Combustion	Flue Gases	Combustion Modification	21B		
Coal	Fly Ash	Spreader Stokers	21D		
Field Tests	Particle Size	Particulate	14B		
Dust	Nitrogen Oxides	Overfire Air	11G	07B	
Stokers	Sulfur Oxides				
18. DISTRIBUTION STATEMENT Release to Public		19. SECURITY CLASS (This Report) Unclassified		21. NO. OF PAGES 143	
		20. SECURITY CLASS (This page) Unclassified		22. PRICE	