



# Research and Development

ENVIRONMENTAL ASSESSMENT  
OF A WOOD-WASTE-FIRED  
INDUSTRIAL FIRETUBE BOILER  
Volume II. Data Supplement

## Prepared for

Office of Air Quality Planning and Standards

## Prepared by

Air and Energy Engineering Research  
Laboratory  
Research Triangle Park NC 27711

## **RESEARCH REPORTING SERIES**

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into nine series. These nine broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and a maximum interface in related fields. The nine series are:

- 1. Environmental Health Effects Research**
- 2. Environmental Protection Technology**
- 3. Ecological Research**
- 4. Environmental Monitoring**
- 5. Socioeconomic Environmental Studies**
- 6. Scientific and Technical Assessment Reports (STAR)**
- 7. Interagency Energy-Environment Research and Development**
- 8. "Special" Reports**
- 9. Miscellaneous Reports**

This report has been assigned to the INTERAGENCY ENERGY-ENVIRONMENT RESEARCH AND DEVELOPMENT series. Reports in this series result from the effort funded under the 17-agency Federal Energy/Environment Research and Development Program. These studies relate to EPA's mission to protect the public health and welfare from adverse effects of pollutants associated with energy systems. The goal of the Program is to assure the rapid development of domestic energy supplies in an environmentally-compatible manner by providing the necessary environmental data and control technology. Investigations include analyses of the transport of energy-related pollutants and their health and ecological effects; assessments of, and development of, control technologies for energy systems; and integrated assessments of a wide range of energy-related environmental issues.

## **EPA REVIEW NOTICE**

This report has been reviewed by the participating Federal Agencies, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the Government, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

This document is available to the public through the National Technical Information Service, Springfield, Virginia 22161.

EPA-600/7-87-010b  
March 1987

ENVIRONMENTAL ASSESSMENT OF A  
WOODWASTE-FIRED INDUSTRIAL FIRETUBE BOILER

Volume II. Data Supplement

by

R. DeRosier and L. R. Waterland  
Acurex Corporation  
Environmental Systems Division  
485 Clyde Avenue  
P.O. Box 7444  
Mountain View, California 94039

EPA Contract No. 68-02-3188

Project Officer: R. E. Hall  
Air and Energy Engineering Research Laboratory  
Research Triangle Park, North Carolina 27711

for

OFFICE OF RESEARCH AND DEVELOPMENT  
U.S. ENVIRONMENTAL PROTECTION AGENCY  
WASHINGTON, DC 20460

## **ACKNOWLEDGMENTS**

The authors wish to extend their gratitude to P. B. Wainright of the North Carolina Department of Natural Resources and Community Development. The cooperation of D. B. Harris and J. Montgomery of EPA/AEERL was also instrumental to the success of the test program. Special recognition is also extended to the Acurex field test team under the supervision of B. C. DaRos, assisted by P. Kaufman, R. Best, and J. Holm.

## TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1 INTRODUCTION . . . . .	1-1
2 PRELIMINARY TESTS . . . . .	2-1
3 BOILER OPERATING DATA . . . . .	3-1
3.1 OPERATING DATA . . . . .	3-3
3.2 BOILER THERMAL EFFICIENCY CALCULATION . . . . .	3-5
4 SAMPLING DATA SHEETS . . . . .	4-1
4.1 CONTINUOUS EMISSIONS MONITORING DATA . . . . .	4-3
4.2 FIELD DATA SHEETS FOR EPA METHOD 5, SASS, AND CONTROLLED CONDENSATION . . . . .	4-7
5 ANALYTICAL RESULTS . . . . .	5-1
5.1 FUEL ANALYSIS . . . . .	5-3
5.2 SASS PARTICULATE EMISSIONS . . . . .	5-5
5.3 EPA METHOD 5 PARTICULATE EMISSIONS . . . . .	5-11
5.4 SULFUR OXIDES EMISSIONS FROM CONTROLLED CONDENSATION SAMPLES . . . . .	5-19
5.5 TRACE ELEMENT ANALYSIS . . . . .	5-23
5.6 C <sub>1</sub> TO C <sub>6</sub> HYDROCARBONS BY GAS CHROMATOGRAPHY . . . . .	5-35
5.7 TOTAL CHROMOTOGRAFPHABLE ORGANICS (TCO), GRAVIMETRIC ORGANICS (GRAV), IR SPECTRA, AND GAS CHROMATOGRAPHY/MASS SPECTROMETRY (GC/MS) . . . . .	5-71
5.8 RADIOMETRIC ANALYSIS RESULTS . . . . .	5-81
5.9 BIOASSAY REPORTS . . . . .	5-85

## SECTION 1

### INTRODUCTION

The purpose of this data supplement is to document data in greater detail than was possible in Volume I (Technical Results) of this report. It is intended to provide sufficient detail for researchers to perform their own analysis of the data obtained. Readers are referred to the technical volume for objectives, description of source emission results, interpretation, and conclusions.

The remaining sections of this data supplement contain the following information:

Section 2 -- Preliminary Tests: stack velocity traverse and gas composition tests

Section 3 -- Boiler Operating Data: steam flow, drum pressure, feedwater pressure, furnace pressure, outlet pressure, collector pressure, stack temperature, and boiler efficiency calculations

Section 4 -- Sampling Data Sheets: continuous emission monitoring data, operating data tables for EPA Method 5 (for particulate mass emissions), controlled condensation (for SO<sub>2</sub> and SO<sub>3</sub> sampling), and SASS (for trace element and organic sampling)

Section 5 -- Analytical Laboratory Results: fuel analysis, Method 5 particulate emissions, SASS particulate emissions, sulfur oxides emissions from controlled condensation samples, trace element

emissions by spark source mass spectrometry (SSMS) analysis and atomic absorption spectroscopy (AAS) analysis; C<sub>1</sub> to C<sub>6</sub> hydrocarbons by gas chromatography; total chromatographable organic (TCO) and gravimetric (GRAV) results; infrared (IR) spectra; determination of organic compounds by gas chromatography/mass spectrometry (GC/MS); radiometric analysis results, and biological assay reports on the SASS train samples.

**SECTION 2**  
**PRELIMINARY TESTS**

# TRAVERSE POINT LOCATION FOR CIRCULAR DUCTS

PLANT Burnett, Phil Pot, Lexington, NC

DATE 7-29-81

SAMPLING LOCATION STACK

INSIDE OF FAR WALL TO

OUTSIDE OF NIPPLE, (DISTANCE A) 27.75 "

INSIDE OF NEAR WALL TO


OUTSIDE OF NIPPLE, (DISTANCE B) 1.75 "

STACK I.D., (DISTANCE A - DISTANCE B) 36 "

NEAREST UPSTREAM DISTURBANCE 2

NEAREST DOWNSTREAM DISTURBANCE 1

CALCULATOR BEST



SCHEMATIC OF SAMPLING LOCATION

TRAVERSE POINT NUMBER	FRACTION OF STACK I.D.	STACK I.D.	PRODUCT OF COLUMNS 2 AND 3 (TO NEAREST 1/8 INCH)	DISTANCE B	TRAVERSE POINT LOCATION FROM OUTSIDE OF NIPPLE (SUM OF COLUMNS 4 & 5)
1	.011	36	0.40 (1.0)	1.75	2.75
2	.032		1.15		2.90
3	.055		2.00		3.75
4	.079		2.84		4.59
5	.105		3.78		5.53
6	.132		4.75		6.50
7	.161		5.80		7.55
8	.194		7.00		8.75
9	.23		8.28		10.03
10	.272		9.80		11.55
11	.313		11.63		13.38
12	.398		14.33		16.08
13	.402		21.07		23.42
14	.477		24.37		26.12
15	.528		26.21		27.96
16	.57		27.72		29.47
17	.606		29.02		30.77
18	.639		30.20		31.95
19	.668		31.25		33.00
20	.695		32.22		33.97
21	.721		33.16		34.91
22	.745		34.0		35.75
23	.768		34.85		36.6
24	.789		35.00 (35.0)		36.75

# PRELIMINARY VELOCITY TRAVERSE

PLANT BURLINGTON - PHILL POT, LEXINGTON N.C.

DATE 4-29-81


LOCATION SPACK

STACK I.D. 36

BAROMETRIC PRESSURE, in. Hg 28.98

STACK GAUGE PRESSURE, in. H<sub>2</sub>O   

OPERATORS Bent / Farver



SCHEMATIC OF TRAVERSE POINT LAYOUT

West

TRAVERSE POINT NUMBER	VELOCITY HEAD ( $\Delta p_s$ ), in. H <sub>2</sub> O	STACK TEMPERATURE ( $T_s$ ), °F
1	.38	204
2	.37	2
3	.40	460
4	.43	460
5	.52	460
6	.53	460
7	.55	460
8	.70	506
9	.75	521
10	.75	525
11	.75	529
12	.75	532
13	.75	538
14	.80	542
15	.75	542
16	.80	542
17	.72	540
18	.75	534
19	.75	530
20	.75	527
21	.70	523
22	.70	519
23	.75	511
24	.75	511
AVERAGE		

TRAVERSE POINT NUMBER	VELOCITY HEAD ( $\Delta p_s$ ), in. H <sub>2</sub> O	STACK TEMPERATURE ( $T_s$ ), °F
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
AVERAGE		

## ISOKINETIC SAMPLING WORKSHEET

Plant Burlington Industries Performed by Best  
 Date 4-29-81  
 Sample Location Outlet  
 Test No./Type M/S #1

static = -40

Barom = 28.99

$$K = \frac{782.687 (C_p)^2 (1-B_{w0})^2 P_s M_d}{K_o^2 M_s P_m}$$

where: K = Contant of fixed and assumed parameters (dimensionless)

Pitot coefficient (dimensionless)	$C_p$	.806
Water vapor in the gas stream (proportion by volume)	$B_{w0}$	,08 <i>assume</i>
Absolute stack gas pressure (in. Hg)	$P_s$	28.90
Molecular weight, stack gas dry (1b/1b-mole)	$M_d$	29.2 <i>assume</i>
Orifice coefficient (dimensionless)	$K_o$	.718
Molecular weight, stack gas wet (1b/1b-mole) $M_d(1-B_{w0}) + 18(B_{w0})$	$M_s$	28.2 <i>assume</i>
Absolute meter pressure (in. Hg)	$P_m$	29.10
$\frac{782.687 (.806)^2 (1-.08)^2 (28.90) (29.2)}{(.718)^2 (28.2) (29.10)}$	K	860.249

ISOKINETIC NOZZLE CALCULATION  
AND  
SAMPLING RATE CALCULATION

Plant Burlington Industries

Performed by Best

Date 4-29-81

Sample Location Outlet

Test No./Type M5 / #1

$$N_d = \left( \frac{\Delta H}{K T_m \Delta P} \right)^{.25}$$

where:  $N_d$  = Nozzel diameter (inches)

Average pressure differential across the orifice meter (in. H <sub>2</sub> O)	$\Delta H$	1.2
Temperature stack gas, average (°F)	$T_s$	520
Temperature of gas meter, average (°F)	$T_m$	85
Stack gas velocity pressure (in H <sub>2</sub> O)	$\Delta P$	.70
$\left( \frac{(\underline{\quad}) (\underline{\quad} + 460)}{(\underline{\quad}) (\underline{\quad} + 460)(\underline{\quad})} \right)^{.25}$	$N_d$	271

$$\Delta H = K (N_d)^4 \frac{T_m}{T_s} (\Delta P)$$

where:  $\Delta H$  = Pressure differential across the orifice meter (in H<sub>2</sub>O)

Nozzel diameter, actual (inches)	$N_d$	3086
Temperature of gas meter (°F)	$T_m$	
Temperature of stack gas (°F)	$T_s$	
Stack gas velocity pressure (in H <sub>2</sub> O)	$\Delta P$	
$\left( (\underline{\quad}) (\underline{\quad})^4 \left\{ \frac{\underline{\quad} + 460}{\underline{\quad} + 460} \right\} (\underline{\quad}) \right)$	$\Delta H$	
Magic number _____ ( ) <sup>4</sup>	$K(N_d)^4$	7.802

ISOKINETIC SAMPLING WORKSHEET

Plant Industrial - F-1

Performed by P. Kuehn

Date 4-28-77

Sample Location Stack

Test No./Type 1-2415

$$K = \frac{782.687 (C_p)^2 (1-B_{w0})^2 P_s M_d}{K_o^2 M_s P_m}$$

where: K = Constant of fixed and assumed parameters (dimensionless)

Pitot coefficient (dimensionless)	$C_p$	1.00
Water vapor in the gas stream (proportion by volume)	$B_{w0}$	0.50
Absolute stack gas pressure (in. Hg)	$P_s$	28.78
Molecular weight, stack gas dry (lb/lb-mole)	$M_d$	28.77
Orifice coefficient (dimensionless)	$K_o$	1.0
Molecular weight, stack gas wet (lb/lb-mole) $M_d(1-B_{w0}) + 18(B_{w0})$	$M_s$	28.24
Absolute meter pressure (in. Hg)	$P_m$	28.78
$\frac{782.687 (\underline{\hspace{1cm}})^2 (1-\underline{\hspace{1cm}})^2 (\underline{\hspace{1cm}}) (\underline{\hspace{1cm}})}{(\underline{\hspace{1cm}})^2 (\underline{\hspace{1cm}}) (\underline{\hspace{1cm}})}$	K	30.929

ISOKINETIC NOZZLE CALCULATION  
AND  
SAMPLING RATE CALCULATION

Plant P-1000-1000-1000

Performed by P. K. Sengupta

Date 4-24-81

Sample Location STACK

Test No./Type - SIASS

$$N_d = \left( \frac{\Delta H \ T_s}{K \ T_m \ \Delta P} \right)^{.25}$$

where:  $N_d$  = Nozzle diameter (inches)

Average pressure differential across the orifice meter (in. H <sub>2</sub> O)	$\Delta H$	2.3
Temperature stack gas, average (°F)	$T_s$	520
Temperature of gas meter, average (°F)	$T_m$	100
Stack gas velocity pressure (in H <sub>2</sub> O)	$\Delta P$	.7
$\left( \frac{(\_) (\_) + 460}{(\_) (\_) + 460 (\_) } \right)^{.25}$	$N_d$	.650

P-15  
.611

$$\Delta H = K (N_d)^4 \frac{T_m}{T_s} (\Delta P)$$

where:  $\Delta H$  = Pressure differential across the orifice meter (in H<sub>2</sub>O)

Nozzle diameter, actual (inches)	$N_d$	
Temperature of gas meter (°F)	$T_m$	
Temperature of stack gas (°F)	$T_s$	
Stack gas velocity pressure (in H <sub>2</sub> O)	$\Delta P$	
$\left( (\_) (\_)^4 \frac{(\_) + 460}{(\_) + 460} (\_) \right)$	$\Delta H$	
Magic number _____ ( ) <sup>4</sup>	$K(N_d)^4$	

**SECTION 3**  
**BOILER OPERATING DATA**

### 3.1 OPERATING DATA

Time:	9:30	10:00	10:30	11:00	11:30	12:00	12:30	1:00	1:30	2:00	2:30	3:00	3:30	4:00	4:30	5:00	Average
Steam flow (1000lb/hr)	9.5	11.2	13.0	13.0	13.7	13.6	13.5	14.5	14.5	14.2	14.6	15.0	14.8	14.8	14.5	14.0	13.6
Drum pressure (psig)	120	120	122	124	122	122	120	124	124	124	121	126	121	122	122	122	122
Feedwater pressure (psig)	162	157	162	165	160	165	155	165	163	162	162	122	165	162	155	160	158
Furnace pressure (in. H <sub>2</sub> O)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Outlet pressure (in. H <sub>2</sub> O)	1.1	1.0	0.9	1.25	1.0	1.0	0.9	0.9	1.2	1.2	1.0	1.0	1.0	0.8	0.9	1.0	1.0
Collector pressure (in. H <sub>2</sub> O)	2.25	2.2	2.2	2.2	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1
Stack temperature (°F)	650	650	650	650	650	650	620	670	600	680	670	620	690	700	630	620	650

### **3.2 BOILER THERMAL EFFICIENCY CALCULATION**

## SUMMARY SHEET

ASME TEST FORM  
FOR ABBREVIATED EFFICIENCY TEST

PTC 4.1-a(1964)

OWNER OF PLANT	<i>Burnhamton</i>		TEST NO.	1	BOILER NO.	1	DATE	<i>6-29-61</i>
TEST CONDUCTED BY	<i>Auxiliary / Castelloiai</i>		LOCATION	<i>Lexington, NC</i>		OBJECTIVE OF TEST	<i>Emissions Meas.</i>	
BOILER MAKE & TYPE	<i>H&amp;T Firetube</i>		DURATION	<i>6 hr</i>		RATED CAPACITY	<i>26,000 lb/hr</i>	
STOKER, TYPE & SIZE	<i>McBurnay</i>							
PULVERIZER, TYPE & SIZE	<i>None</i>							
FUEL USED	<i>Wood waste</i>	MINE	COUNTY	STATE	BURNER, TYPE & SIZE			SIZE AS FIRED
PRESSURES & TEMPERATURES								
1 STEAM PRESSURE IN BOILER DRUM	psia	<i>137</i>	COAL AS FIRED PROX. ANALYSIS	% wt	OIL			
2 STEAM PRESSURE AT S. H. OUTLET	psia		37 MOISTURE	<i>5.66</i>	51 FLASH POINT F°			
3 STEAM PRESSURE AT R. H. INLET	psia		38 VOL MATTER		52 Sp. Gravity Deg. API			
4 STEAM PRESSURE AT R. H. OUTLET	psia		39 FIXED CARBON		53 VISCOSITY AT SSU <sup>a</sup> BURNER SSF			
5 STEAM TEMPERATURE AT S. H. OUTLET	F		40 ASH	<i>0.47</i>	44 TOTAL HYDROGEN % wt			
6 STEAM TEMPERATURE AT R. H. INLET	F		TOTAL			45 Btu per lb		
7 STEAM TEMPERATURE AT R. H. OUTLET	F		41 Btu per lb AS FIRED	<i>814.8</i>				
8 WATER TEMP. ENTERING (ECON.) (BOILER)	F	<i>125</i>	42 ASH SOFT TEMP. <sup>b</sup> ASTM METHOD		GAS			% VOL
9 STEAM QUALITY % MOISTURE OR P. P. M.			COAL OR OIL AS FIRED ULTIMATE ANALYSIS		54 CO			
10 AIR TEMP. AROUND BOILER (AMBIENT)	F	<i>77</i>	43 CARBON	<i>44.71</i>	55 CH <sub>4</sub> METHANE			
11 TEMP. AIR FOR COMBUSTION (This Is Reference Temperature) <sup>c</sup>	F	<i>77</i>	44 HYDROGEN	<i>5.42</i>	56 C <sub>2</sub> H <sub>2</sub> ACETYLENE			
12 TEMPERATURE OF FUEL	F		45 OXYGEN	<i>12.33</i>	57 C <sub>2</sub> H <sub>4</sub> ETHYLENE			
13 GAS TEMP. LEAVING (Boiler) (Econ.) (Air Mfr.)	F	<i>650</i>	46 NITROGEN	<i>0.17</i>	58 C <sub>3</sub> H <sub>8</sub> ETHANE			
14 GAS TEMP. ENTERING AM (If conditions to be corrected to average)	F		47 SULPHUR	<i>0.04</i>	59 H <sub>2</sub> S			
UNIT QUANTITIES								
15 ENTHALPY OF SAT. LIQUID (TOTAL HEAT)	Btu/lb	<i>319</i>	37 MOISTURE	<i>5.61</i>	60 CO <sub>2</sub>			
16 ENTHALPY OF (SATURATED) (SUPERHEATED) STM.	Btu/lb	<i>193</i>	TOTAL			61 H <sub>2</sub> HYDROGEN	TOTAL	
17 ENTHALPY OF SAT. FEED TO (BOILER) (ECON.)	Btu/lb	<i>93</i>	COAL PULVERIZATION			TOTAL HYDROGEN % wt		
18 ENTHALPY OF REHEATED STEAM R. H. INLET	Btu/lb		48 GRINDABILITY INDEX <sup>d</sup>		62 DENSITY 68 F ATM. PRESS.			
19 ENTHALPY OF REHEATED STEAM R. H. OUTLET	Btu/lb		49 FINENESS % THRU 50 M <sup>e</sup>		63 Btu PER CU FT			
20 HEAT ABS/LB OF STEAM (ITEM 16-ITEM 17)	Btu/lb	<i>1100</i>	50 FINENESS % THRU 200 M <sup>e</sup>		64 Btu PER LB			
21 HEAT ABS/LB R. H. STEAM (ITEM 19-ITEM 18)	Btu/lb		64 INPUT-OUTPUT EFFICIENCY OF UNIT %		ITEM 31 = 100 ITEM 29	<i>45.1</i>		
22 DRY REFUSE (ASH PIT + FLY ASH) PER LB AS FIRED FUEL	lb/lb		HEAT LOSS EFFICIENCY			Btu/lb	% of A. F. FUEL	
23 Btu PER LB IN REFUSE (WEIGHTED AVERAGE)	Btu/lb		65 HEAT LOSS DUE TO DRY GAS		65 HEAT LOSS DUE TO DRY GAS	<i>197.0</i>	<i>24.2</i>	
24 CARBON BURNED PER LB AS FIRED FUEL	lb/lb	<i>0.95</i>	66 HEAT LOSS DUE TO MOISTURE IN FUEL		66 HEAT LOSS DUE TO MOISTURE IN FUEL	<i>74.4</i>	<i>9.9</i>	
25 DRY GAS PER LB AS FIRED FUEL BURNED	lb/lb	<i>14.34</i>	67 HEAT LOSS DUE TO H <sub>2</sub> O FROM COMB. OF H <sub>2</sub>		67 HEAT LOSS DUE TO H <sub>2</sub> O FROM COMB. OF H <sub>2</sub>	<i>64.1</i>	<i>7.9</i>	
HOURLY QUANTITIES								
26 ACTUAL WATER EVAPORATED	lb/hr	<i>13,600</i>	68 HEAT LOSS DUE TO COMBUST. IN REFUSE		68 HEAT LOSS DUE TO COMBUST. IN REFUSE			
27 REHEAT STEAM FLOW	lb/hr		69 HEAT LOSS DUE TO RADIATION		69 HEAT LOSS DUE TO RADIATION		<i>1.0</i>	
28 RATE OF FUEL FIRING (AS FIRED wt)	lb/hr	<i>9071</i>	70 UNMEASURED LOSSES		70 UNMEASURED LOSSES		<i>1.5</i>	
29 TOTAL HEAT INPUT (Item 28 x Item 4)	lb/hr	<i>33140</i>	71 TOTAL		71 TOTAL		<i>35.5</i>	
30 HEAT OUTPUT IN BLOW-DOWN WATER	lb/hr		72 EFFICIENCY = (100 - Item 71)		72 EFFICIENCY = (100 - Item 71)		<i>64.5</i>	
31 TOTAL HEAT (Item 26+Item 20)+(Item 27+Item 21)+Item 30 OUTPUT 1000	lb/hr	<i>14960</i>						
FLUE GAS ANAL. (BOILER) (ECON) (AIR HTR) OUTLET								
32 CO <sub>2</sub>	% VOL	<i>7.7</i>						
33 O <sub>2</sub>	% VOL	<i>13.1</i>						
34 CO	% VOL	<i>0.1</i>						
35 N <sub>2</sub> (BY DIFFERENCE)	% VOL	<i>79.1</i>						
36 EXCESS AIR	%	<i>11.0</i>						

<sup>a</sup> Assumed<sup>b</sup> Average of meter reading over test<sup>c</sup> Carbon balance<sup>d</sup> 8630 Btu/lb dry basis<sup>e</sup> Not Required for Efficiency Testing<sup>f</sup> For Point of Measurement See Par. 7.2.B.1-PTC 4.1-1964

ASME TEST FORM  
FOR ABBREVIATED EFFICIENCY TEST      Revised September, 1965

OWNER OF PLANT <u>Burlington</u>		TEST NO. /	BOILER NO. /	DATE <u>4-27-81</u>
30	HEAT OUTPUT IN BOILER BLOW-DOWN WATER = LB OF WATER BLOW-DOWN PER HR X	<span style="border: 1px solid black; padding: 2px;">ITEM 15</span> <span style="border: 1px solid black; padding: 2px;">ITEM 17</span> lb/hr <span style="border: 1px solid black; padding: 2px;">1000</span>		
24	If impractical to weigh refuse, this item can be estimated as follows  DRY REFUSE PER LB OF AS FIRED FUEL = $\frac{\% \text{ASH IN AS FIRED COAL}}{100 - \% \text{COMB. IN REFUSE SAMPLE}}$	NOTE: IF FLUE DUST & ASH PIT REFUSE DIFFER MATERIALLY IN COMBUSTIBLE CONTENT, THEY SHOULD BE ESTIMATED SEPARATELY. SEE SECTION 7, COMPUTATIONS.		
25	CARBON BURNED PER LB AS FIRED FUEL = $\frac{44.81}{100}$ - $\left[ \frac{\text{ITEM 22} \times \text{ITEM 23}}{14,500} \right] = 0.95$			
25	DRY GAS PER LB AS FIRED FUEL = $\frac{11(\text{CO}_2 + \text{SO}_2 + 7(\text{N}_2 + \text{CO}))}{3(\text{CO}_2 + \text{CO})} \times (\text{LB CARBON BURNED PER LB AS FIRED FUEL} + \frac{3}{8})$ $\times \frac{11 \times \text{ITEM 12} + 8 \times \text{ITEM 33}}{(\text{ITEM 32} + \text{ITEM 34})} + 7(\frac{\text{ITEM 35} + \text{ITEM 34}}{267}) \times \left[ \frac{\text{ITEM 24} + \text{ITEM 47}}{267} \right] = 19.3$			
36	EXCESS AIR = $100 \times \frac{\text{O}_2 - \frac{\text{CO}}{2}}{.2682\text{N}_2 - (\text{O}_2 - \frac{\text{CO}}{2})} = 100 \times \frac{\text{ITEM 33} - \frac{\text{ITEM 34}}{2}}{.2682(\text{ITEM 35}) - (\text{ITEM 33} - \frac{\text{ITEM 34}}{2})} = 160$			
HEAT LOSS EFFICIENCY				
65	HEAT LOSS DUE TO DRY GAS PER LB AS FIRED FUEL = $\frac{\text{ITEM 25} \times \text{ITEM 25} ((\text{ITEM 13}) - (\text{ITEM 11}))}{14.3 \times 650 \times .77} = 1970$	Btu/lb AS FIRED FUEL	LOSS $\frac{\text{HHV}}{100} \times 100$	LOSS %
66	HEAT LOSS DUE TO MOISTURE IN FUEL AS FIRED FUEL = $\frac{\text{ITEM 37} \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA & T GAS LVG}) - (\text{ENTHALPY OF LIQUID AT T AIR})]}{100 \times 546 \times 6/360 - 47} = 74.4$			
67	HEAT LOSS DUE TO H <sub>2</sub> O FROM COMB. OF H <sub>2</sub> = $9\text{H}_2 \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA & T GAS LVG}) - (\text{ENTHALPY OF LIQUID AT T AIR})]$ $= 9 \times \frac{\text{ITEM 44}}{100} \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA & T ITEM 13}) - (\text{ENTHALPY OF LIQUID AT T ITEM 11})] = 641$			
68	HEAT LOSS DUE TO COMBUSTIBLE IN REFUSE = $\text{ITEM 22} \times \text{ITEM 23} = \dots$	—	$\frac{68}{41} \times 100 =$	0...
69	HEAT LOSS DUE TO RADIATION = $\frac{\text{ITEM 22} \times \text{ITEM 28}}{\text{ITEM 22} - \text{ITEM 28}} = \dots$		$\frac{69}{41} \times 100 =$	1.0
70	UNMEASURED LOSSES ** = $\dots$		$\frac{70}{41} \times 100 =$	1.5
71	TOTAL = $\dots$			35.5
72	EFFICIENCY = $(100 - \text{ITEM 71}) = \dots$			64.5

\* For rigorous determination of excess air see Appendix 9.2 - PTC 4.1-1964

\* If losses are not measured, use ABMA Standard Radiation Loss Chart, Fig. 8, PTC 4.1-1964

\*\* Unmeasured losses listed in PTC 4.1 but not tabulated above may be provided for by assigning a mutually agreed upon value for Item 70.

**SECTION 4**  
**SAMPLING DATA SHEETS**

#### 4.1 CONTINUOUS EMISSIONS MONITORING DATA

Time	Dry, Uncorrected			Corrected to 3% O <sub>2</sub>		Comments
	O <sub>2</sub> (%)	CO (ppm)	NO (ppm)	CO (ppm)	NO (ppm)	
10:00	12.8	148	145	324	317	
10:03	13.5	118	143	284	343	
10:06	13.3	1,545	143	3,611	332	
10:09	12.0	118	178	236	356	
10:12	11.8	79	148	155	288	
10:15	13.8	216	120	540	299	
10:18	12.8	177	138	388	302	
10:21	13.0	118	144	266	293	
10:24	12.3	235	159	487	327	
10:27	12.3	138	162	285	332	
10:30	12.5	118	154	250	326	
10:33	12.3	89	142	184	291	
10:36	13.0	167	122	375	274	
10:39	16.6	2,248	83	9,196	339	
10:42	14.5	1,105	134	3,059	371	
10:45	12.8	69	124	152	270	
10:48	14.3	274	104	737	277	
10:51	12.5	196	144	415	304	
10:54	14.5	294	106	814	294	
10:57	12.0	89	163	177	326	
11:00	13.5	98	138	236	332	
11:03	11.0	79	173	142	311	
11:06	14.8	304	136	881	392	
11:09	11.8	59	141	116	273	
11:12	12.3	333	158	689	325	
11:15	13.3	118	130	275	303	CM down for repairs
11:18	13.5	323	130	775	313	CM down for repairs
11:21	12.8	79	130	173	284	CM down for repairs
11:24	12.5	128	157	270	333	CM down for repairs
11:29	14.0	196	116	504	297	CM down for repairs
11:30	16.8	479	142	2,054	603	CM down for repairs
11:33	19.5	108	2.7	1,296	33	CM down for repairs
11:36	12.8	313	140	687	305	
11:39	15.0	743	118	2,229	353	
11:42	13.3	274	140	641	324	
11:45	13.3	98	132	229	307	
11:48	15.3	1,798	105	5,678	329	
11:51	13.5	684	139	1,642	334	
11:54	12.5	69	134	146	285	
11:57	14.5	235	129	650	358	
12:00	13.5	127	125	306	299	
12:03	13.0	69	132	155	296	
12:06	15.3	2,257	93	7,128	290	

## 4.1 CONTINUED

Time	Dry, Uncorrected			Corrected to 3% O <sub>2</sub>		Comments
	O <sub>2</sub> (%)	CO (ppm)	NO (ppm)	CO (ppm)	NO (ppm)	
12:09	12.3	78	124	162	256	
12:12	13.5	332	136	798	327	
12:15	143	723	100	1,943	266	
12:18	12.0	176	139	352	277	
12:21	15.0	1,115	93	3,345	277	
12:24	12.0	88	114	176	228	
12:27	14.0	381	112	980	287	
12:30	12.5	59	112	125	236	
12:33	14.0	303	124	779	318	
12:36	11.8	49	121	96	236	
12:39	12.5	108	143	228	302	
12:42	14.5	440	92	1,218	255	
12:45	11.8	117	140	230	273	
12:48	13.8	469	126	1,173	312	
12:51	14.0	196	109	503	280	
12:54	11.5	59	128	111	242	
12:57	13.0	156	142	352	320	
13:00	15.0	1,104	85	3,312	234	
13:03	11.5	59	154	111	292	
13:06	13.0	117	171	264	384	
13:09	15.3	1,544	125	4,875	392	
13:12	12.0	59	139	117	279	
13:15	11.3	225	178	417	328	
13:18	16.0	1,270	99	4,572	355	
13:21	11.5	59	144	111	273	
13:24	12.0	156	182	313	364	
13:27	16.3	1,710	84	6,548	319	
13:30	11.3	0	120	0	221	
13:33	12.3	117	151	242	310	
13:36	14.3	156	108	420	287	
13:39	15.3	674	0.6	2,128	2	
13:42	14.3	146	103	393	274	
13:45	11.0	78	143	140	258	
13:48	14.3	205	141	551	375	
13:51	12.5	58	138	124	292	
13:54	12.6	78	136	167	292	
13:57	13.5	78	122	187	292	
14:00	12.2	137	121	279	249	
14:03	14.0	117	117	301	300	
14:06	11.5	68	169	129	320	
14:09	13.5	68	135	164	325	
14:12	14.5	205	140	567	388	

## 4.1 CONTINUED

Time	Dry, Uncorrected			Corrected to 3% O <sub>2</sub>		Comments
	O <sub>2</sub> (%)	CO (ppm)	NO (ppm)	CO (ppm)	NO (ppm)	
14:15	9.8	58	171	94	274	
14:18	14.0	68	131	175	336	
14:21	11.5	68	178	129	336	
14:24	13.3	68	133	159	308	
14:27	12.5	107	189	227	400	
14:30	12.5	58	142	123	300	
14:33	15.0	351	123	1,054	369	
14:36	11.0	48	144	87	259	
14:39	14.5	146	135	405	373	
14:42	10.8	48	167	85	294	
14:45	14.4	87	125	239	338	
14:48	9.3	127	174	195	267	
14:51	14.0	78	120	200	310	
14:54	15.0	488	118	1,464	353	
14:57	11.3	48	134	90	248	
15:00	14.3	166	148	445	395	
15:03	12.3	58	125	120	257	
15:06	14.8	136	122	396	352	
15:09	11.4	48	141	91	262	
15:12	14.8	175	122	509	351	
15:15	10.0	38	155	63	253	
15:18	14.3	78	130	208	347	
15:21	10.8	58	164	102	287	
15:24	11.5	78	164	147	310	
15:27	14.8	146	117	424	337	
15:30	11.0	87	177	157	319	
15:33	14.0	77	117	199	300	
15:36	12.0	87	161	174	321	
15:39	13.3	97	114	227	266	
15:42	14.5	234	110	647	304	
15:45	11.8	68	107	132	209	
15:48	14.8	234	91	679	262	
15:51	11.0	97	121	174	218	
15:54	14.5	107	107	295	297	
15:57	10.0	38	142	63	232	
16:00	14.0	77	132	199	340	
16:03	11.3	85	174	158	321	
16:06	14.3	107	116	286	309	
16:09	10.0	97	173	158	284	
16:12	13.3	77	130	181	301	
16:15	13.8	97	157	242	390	
16:18	12.6	68	136	145	292	
16:21	13.8	77	143	193	355	

4.1 CONCLUDED

Time	Dry, Uncorrected			Corrected to 3% O <sub>2</sub>		Comments
	O <sub>2</sub> (%)	CO (ppm)	NO (ppm)	CO (ppm)	NO (ppm)	
16:24	13.5	146	166	350	398	
16:27	13.0	67	134	152	301	
16:30	15.0	263	120	789	360	
16:33	10.3	77	168	130	281	
16:36	14.5	136	127	376	351	End of SASS train

**4.2 FIELD DATA SHEETS FOR EPA METHOD 5, SASS, AND CONTROLLED CONDENSATION**

$$M.N. = 1.80L + \frac{T_s}{T_f} \times AP = 411$$

FIELD DATA

Page 1 of 4

Plant Burlington Industries  
 Date 4-29-81  
 Sample Location Boiler Duct  
 Sample Type Methanol  
 Run Number #1  
 Operator Best  
 Ambient Temperature -  
 Barometric Pressure 28.98  
 Static Pressure,  $(H_2O)$  -40" H<sub>2</sub>O  
 Filter Number(s) MV-140  
206

Leak Check; Initial at 10 \* Hg., .004 CFM Pilot O.H., (55;.804)  
 Final at 11 \* Hg., .004 CFM

Impinger Volumes

Initial	Final
100	165
100	118
0	11

94 ml

Silica Gel  
 $574.2 - 549.5 \rightarrow 35.4$  gr. gain

Probe Length and Type 5' glass  
 Nozzle I.D. (No.) .3086 P-90  
 Assumed Moisture 8%  
 Molecular Weight, Dry, ( $M_d$ ) 718  
 Meter Box Number 038  
 Meter Coefficient .718  
 a Factor .992  
 $K = \frac{860.249}{(N_d)^4}$   
 $K(N_d)^4 = \frac{1}{(N_d)^4} \times \frac{(860.249)^4}{(206)^4} = 1.802$   
 $\Delta H = K(N_d)^4 \left( \frac{T_m}{T_s} \right) (\Delta P)$

Traverse Point Number	Clock Time (24-hr) Clock Sampling Time, min	Gas Meter Reading ( $V_m$ ), ft <sup>3</sup>	Velocity Head ( $\Delta P_s$ ), in. H <sub>2</sub> O	Temperature of						Pump Vacuum in. Hg	Avg. $\sqrt{\Delta P}$			
				Orifice Pressure Differential ( $\Delta H$ ), in. H <sub>2</sub> O		Stack	Probe	Impinger	Organic Module	Oven	Gas Meter			
				Desired	Actual						In	Out		
1	6.0	425.666	.75	3.20	534	247				272	84	83	4	.866
2	2.5	428.1	.75	3.17	545	267				248	85	84	4	.866
3	5.0	430.5	.80	3.50	512	273				231	86	84	5	.874
4	7.5	433.1	.80	3.50	521	274				229	87	84	5	.874
5	10.0	435.6	.85	3.13	538	275				241	87	84	5	.922
6	12.5	438.2	.90	3.84	532	274				260	88	85	5	.99
7	15.0	440.9	.90	3.86	540	272				274	88	84	5	.949
8	17.5	443.6	.85	3.65	546	275				277	88	85	5	.922
9	20.0	446.2	.85	3.65	538	275				262	88	85	5	.922

Comments:

L-4  
 North  
 Start at  
 furthest  
 point

4-8

Traverse Point Number	Sampling Time, min	Clock Time (24-hr) Clock	Gas Meter Reading ( $V_m$ ), ft <sup>3</sup>	Velocity Head ( $\Delta P_s$ ), in. H <sub>2</sub> O	Orifice Pressure Differential ( $\Delta H$ ), in. H <sub>2</sub> O	Temperature of					Pump Vacuum in. Hg	Avg. $\bar{V}_P$				
						Desired	Actual	Stack	Probe	Impinger	Organic Module	Oven	In	Out		
10	22.5	448.8	.80	2.82	539	274						243	88	85	5	.874
11	25.0	451.3	.65	2.79	536	273						227	88	85	8	.806
12	27.5	453.5	.65	2.92	491	276						227	88	86	9	.806
13	30.0	455.9	.55	2.36	476	274						23	88	86	8	.742
14	32.5	458.1	.55	2.36	506	275						258	88	86	7	.742
15	35.0	460.2	.50	2.14	528	275						271	58	84	6	.707
16	37.5	462.2	.45	1.93	506	275						277	88	86	5	.671
17	40.0	464.1	.50	2.15	495	275						266	87	86	6	.707
18	42.5	466.1	.45	1.93	542	275						251	88	86	6	.671
19	45.0	468.0	.50	2.15	502	275						239	57	86	6	.707
20	47.5	470.0	.45	1.93	539	275						227	87	86	6	.671
21	50.0	471.9	.45	1.93	514	275						226	87	86	6	.671
22	52.5	473.8	.35	1.50	529	275						243	87	86	5	.572
23	55.0	475.5	.35	1.56	497	275						263	87	86	5	.572
24	57.5	477.3	.35	1.60	425	275						272	87	86	6	.572
	End of slope	479.015														

Run No. 1

Date 4-29-81

Sampling Location Outlet

Comments:

Wet  
Start of  
farther  
point  
of

6-4

Traverse Point Number	Clock Time (24-hr) Clock		Gas Meter Reading ( $V_m$ ), ft <sup>3</sup>	Velocity Head ( $\Delta P_s$ ), in. H <sub>2</sub> O	Orifice Pressure Differential ( $\Delta H$ ), in. H <sub>2</sub> O		Temperature OF				Gas Meter		Pump Vacuum in. Hg	Avg. $\Delta P$		
	Sampling Time, min				Desired	Actual	Stack	Probe	Impinger	Organic Module	Oven	In	Out			
	-	Init.														
1	60.0	479.015	.65		2.82	576	268				235	87	86	.8	.801	
2	62.5	481.3	.65		2.82	534	267				224	86	86	9	.806	
3	65.0	483.6	.75		3.26	518	274				220	86	87	11	.806	
4	67.5	486.0	.75		3.26	535	274				240	87	86	11	.806	
5	70.0	488.5	.70		3.04	522	275				253	87	87	11	.837	
6	72.5	490.8	.70		3.04	531	275				273	87	86	11	.837	
7	75.0	493.3	.70		3.04	533	275				275	88	87	11	.837	
8	77.5	495.7	.75		3.26	511	275				259	89	86	11	.866	
9	80.0	498.2	.70		3.04	529	275	.			241	88	87	11	.837	
10	82.5	500.5	.70		3.04	516	262				224	88	87	11	.837	
11	85.0	502.9	.70		3.04	527	263				231	98	87	11	.837	
12	87.5	505.4	.70		3.04	522	263				240	88	87	11	.837	
13	90.0	507.8	.70		3.04	522	262				250	87	87	11	.837	
14	92.5	510.2	.75		3.26	510	263				269	89	87	11	.866	
15	95.0	512.6	.70		3.04	528	262				276	90	87	11	.837	
16	97.5	515.0	.65		2.82	527	263				263	90	87	11	.806	
17	100.0	517.3	.65		2.82	576	263				242	90	87	10	.806	

Run No. /

Date 4-27-81

Sampling Location \_\_\_\_\_

Comments:



## FIELD DATA

Page 1 of 2

Plant Burlington PhilpotDate 4-29-81Sample Location STACKSample Type SASSRun Number 1Operator KAUFMANNAmbient Temperature -Barometric Pressure 28.98Static Pressure,  $(H_2O)$  -0.4Filter Number(s) Pitot  $O_2$ , .769Leak Check: Initial at 25 ' Hg, .02 CFM through organic mod.Final at        ' Hg,        CFM

ph 5

condensate, 909 ml.

## Impinger Volumes

Initial      Final

500      530

500      875

500            

Silica Gel

909.0      1168.6

10" Hg .051 entire train

TOTAL MOISTURE GAIN = 1073.6 1173.6Probe Length and Type 03 ft ① GlassNozzle I.D. (No.) .06Assumed Moisture .06Molecular Weight, Dry,  $(M_d)$        Meter Box Number 088Meter Coefficient 3.619 $\alpha$  Factor .992K =        $K(N_d)^4 = \frac{1}{      } \times \left( \frac{1}{      } \right)^4 = \frac{1}{      }$  $\Delta H = K(N_d)^4 \left( \frac{T_m}{T_s} \right) (\Delta P)$ 

Traverse Point Number	Clock Time (24-hr) Clock	Sampling Time, min	Gas Meter Reading (V <sub>m</sub> ), ft <sup>3</sup>	Velocity Head ( $A_P$ ), in. $H_2O$	Orifice Pressure Differential ( $\Delta H$ ), in. $H_2O$	Temperature of						Pump Vacuum in. Hg	Avg. VAP		
						Desired	Actual	Stack	Probe	Impinger	Organic Module	Oven	In	Out	
10	1050	Init. 127.100	168.8	0.7	2.2	323	420	64	386	8787	1515	837			
stop	20	208.05	208.05	0.6	1.8	347	426	62	390	9428	2050	775			
stop	33	260.8	260.8	0.5	2.2	324	420	68	400	8939	1515	707			
stop	45	306.30	306.30	0.5	1.8	333	425	65	402	9593	2050	767			
stop	60	367.9	367.9	0.6	2.2	519	417	66	47	7492	1515	725			
stop	75	425.48	425.48	0.6	2.0	522	421	68	401	9994	2050	775			
stop	91	491.0	491.0	0.7	2.2	523	429	64	404	9277	1515	837			
stop	105	541.93	541.93	0.65	1.6	524	416	65	402	9722	2050	806			
	116	594.5	594.5	0.7	2.2	523	433	67	411	9294	1515	837			

Comments: Sampling was done 12" into stack

Traverse Point Number	Sampling Time, min	Clock Time (24-hr) Clock	Gas Meter Reading ( $V_m$ ), ft <sup>3</sup>	Velocity Head ( $\Delta P_s$ ), in. H <sub>2</sub> O	Orifice Pressure Differential ( $\Delta H$ ), in. H <sub>2</sub> O	Temperature of				Gas Meter	Pump Vacuum in. Hg	Avg. $\Delta P$	
						Desired	Actual	Stack	Probe	Impinger	Organic Module	Oven	
charge F #7	stop	130	639.85	0.65	1.7	536	425				63	410	97 94 20/20 .806
		145	700.0	0.85	2.2	517	413				67	444	92 94 15/15 .592
charge F #8	stop	155	737.95	0.3	1.7	528	422				67	398	97 94 20/20 .548
		165	780.0	0.6	2.2	494	418				68	409	93 93 15/15 .775
charge F #9	stop	175	818.21	0.6	1.8	489	417				60	437	96 93 20/20 .775
		190	897.1	0.6	2.2	497	418				62	407	91 92 15/15 .775
charge F #10	stop	205	932.81	0.6	1.5	523	417				62	451	95 93 20/20 .775
		220	996.0	0.6	2.2	524	413				67	405	90 92 15/15 .775
charge F #11	stop	235	1031.01	0.5	1.5	494	422				63	408	96 93 20/20 .707
		241	1077.1	0.3	2.2	534	433				63	405	91 92 15/15 .548
charge F #12	stop	255	1130.12	0.6	1.5	535	411				59	342	95 92 20/20 .775
		265	1172.4	0.65	2.2	503	411				60	405	91 91 15/15 .806
4-12	stop	275	1212.197	0.6	1.8	518	409				57	413	97 93 20/20 .775
average		275	1085.097		1.95	522.3					93.6	92.0	.749

Run No. SASS - 1

Date 4/29/81

Sampling Location Buxton Project

Comments:

**CONTROLLED CONDENSATION SYSTEM (CCS)**  
**FIELD DATA SHEET**

Plant Buinington, Phil Pot  
 Date 4-29-81  
 Sample Location STACK  
 Run No. /  
 Operator DuPex

Ambient Temperature ~75-80°F  
 Barometric Pressure 28.98  
 Meter Box Number 082  
 Meter Orifice Coefficient .712  
 Meter α Factor .988

Clock Time (24-hr) clock  Sam- pling Time, min 0	Gas Meter Reading (V <sub>m</sub> ), ft <sup>3</sup>  Init. 202.175	Temperature (°F)							
		Stack	Probe	Filter		Recirc Water	Exit Coil	Dry Gas Meter	
				Skin	Out			In	Out
10 1255	206.400	530	550	1343	606	140	124	71	91
20 1305	209.900	{	591	1343	606	140	124	91	91
30 1315	213.075	{	578	1498	680	140	120	91	91
40 1325	216.300	{	591	1378	678	140	122	92	92
50 1335	219.100	{	587	1228	611	140	122	92	92
60 1345	221.830	530	588	1281	620	140	122	92	93
Average	19.655	530	580.8	1344.5	633.5	140	122.3	91.5	91.7

CURLINGTON, PHILPOTT, CCS R-1

CONTROLLED CONDENSATION SYSTEM (CCS)  
FIELD CHECKPOINT SHEET

Checkpoint	Initials		Remarks
	Supervisor	QA Inspector	
LABORATORY PREPARATION			
• Inspect and clean CCC. Both filter holder and CCC are cleaned with hot chromic acid solution and D.I. H <sub>2</sub> O.	✓		
• Rinse with acetone and air dry CCC.	✓		
• Place Tissuequartz filter in filter housing.	✓		
• Check seal between end of joint and filter.	✓		
• Do not use grease on joints.	✓		
• Inspect and clean all glass joints.	✓		
SITE SETUP			
• Rinse the inside of probe prior to run.	✓		
• Rinse probe with acetone until rinse solution is clear.	✓		
• Perform leak test.	✓		.0015 atm 1 min
• Leak rate must be less than 80 ml/min (0.003 cfm).	✓		
• Thermocouple leads attached to probe and filter.	✓		
• CCC water bath held at 60°C (140°F) <u>±1°C</u> .	✓		
• Leak test train.	✓		
• Probe temperature maintained at 316°C (600°F) <u>±17°C</u> .	✓	NO ~590°F	
• Gas temperature out of filter holder held at 228°C (550°F).	✓		
• Fresh solutions placed in impingers.	✓		
• Fresh absorbent replaced in final impinger.	✓		
• Adjust flowrate in system to 8 lpm.	✓		

BURLINGTON, PHILPOT R-1 CCS

CONTROLLED CONDENSATION SYSTEM (CCS)  
FIELD CHECKPOINT SHEET -- Continued

Checkpoint	Initials		Remarks
	Supervisor	QA Inspector	
SAMPLING RUN			
• Turn vacuum pump on just before inserting probe in stack.	✓		
• Check seal between probe and port to prevent any outside air from entering stack.	✓		
• Run test for 1 hour or until coils are frosted to 1/2 or 2/3 their length.	✓		
• After run, cap both ends of probe and lay in horizontal position.	✓		
• Rinse the CCC coils into the modified Erlenmeyer flask with a maximum of 40 ml D.I. H <sub>2</sub> O.	✓		
• Was any of the solution lost (✓ ml estimated)?	✓		
• After probe has cooled, it is rinsed with a maximum of 40 ml D.I. H <sub>2</sub> O into a 25-ml Erlenmeyer flask.	✓		
- Was any solution lost (✓ ml estimated)?	✓		
- Clean support equipment prior to next run.	✓		
- Save filter for titration.	✓		

Comments:

**SECTION 5**  
**ANALYTICAL RESULTS**

**CURTIS & TOMPKINS, LTD.**

ESTABLISHED 1878

**ANALYTICAL - CHEMISTS - CONSULTING****SAMPLERS - INSPECTORS**

MEMBERS OFFICIAL CHEMISTS  
AND/OR SAMPLERS FOR MANY  
COMMODITY AND TRADE ORGANIZATIONS

CORPORATE OR STAFF MEMBERSHIP IN  
PRINCIPAL SCIENTIFIC SOCIETIES

290 DIVISION STREET  
SAN FRANCISCO, CALIF. 94103  
U.S.A.

Telephone (415) 861-1863

CABLE ADDRESS ANALYST  
REFEREE ANALYSES  
RESEARCH - INVESTIGATIONS  
VITAMIN ASSAYS - BIOCHEMISTRY  
SPECIALISTS IN BULK COMMODITIES

**Laboratory No.** 81hh00  
**Preliminary No.** 6487

**Reported** 8/13/81  
**Sampled** -----  
**Received** 7/07/81

For ACUREX CORPORATION

Report on 5 samples of Fuel Product

**Mark** Project No. 7734.12, 7/06/81, Blanket Subcontract RB59186A,  
Release No. 2.

DRY BASIS EXCEPT AS NOTED

	813690		
	1st Test	2nd Test	3rd Test
Carbon (C), % -----	47.60	----	----
Hydrogen (H), % -----	5.75	----	----
Oxygen (O), (by difference), %-----	45.93	----	----
Nitrogen (N), % -----	0.18	0.22	0.15
Sulfur (S), % -----	0.04	0.04	0.03
Heating Value: BTU/Pound -----	8,630	----	----
Specific Gravity, 75°F (as rec'd) -----	16.25	----	----
Ash, % -----	0.50	----	----
Moisture, % (as rec'd) -----	5.66	----	----

SAMPLES DISCARDED 30 DAYS AFTER RECEIPT UNLESS OTHERWISE REQUESTED

## **5.2 SASS PARTICULATE EMISSIONS**

## ISOKINETIC PERFORMANCE WORKSHEET &amp; PARTICULATE CALCULATIONS

 Plant Burlington Philpott

Performed by \_\_\_\_\_

 Date 4-29-81

 Sample Location STACK

 Test No./Type SASS

Barometric Pressure (in. Hg)	$P_b$	28.98
Meter volume (std), $17.64 \left( \frac{V_m}{\alpha} \right) \left( P_b + \frac{\Delta H}{13.6} \right)$ $17.64 \left( \frac{(1085.07)}{0.992} \right) \left( \frac{(28.98)}{22.9} + \frac{(1.95)}{460} \right)$	$V_m$ std	1016.367
Volume of liquid collected (grams)	$V_l_c$	1073.6
Volume of liquid at standard condition (scf) $V_l_c \times 0.04707$	$V_w$ std	50.534
Stack gas proportion of water vapor $\frac{V_w \text{ std}}{V_w \text{ std} + V_m \text{ std}}, \frac{(\quad)}{(\quad) + (\quad)}$	$B_{w0}$	0.0474
Molecular weight, stack gas dry * $(1b/1b\text{-mole})$ $(\% CO_2 \times 0.44) + (\% O_2 \times 0.32) + (\% N_2 + \% CO \times 0.28)$ $(7.9 \times 0.44) + (13.09 \times 0.32) + (77.01 + \quad \times 0.28)$	$M_d$	29.79
Molecular weight, stack gas wet $(1b/1b\text{-mole})$ $M_d(1-B_{w0}) + 18(B_{w0}), (29.79)(1-0.0474) + 18(0.0474)$	$M_s$	29.23
Absolute stack pressure (in. Hg) $P_b + \frac{P_{stack} \text{ (in. H}_2\text{O)}}{13.6}, (28.98) + \frac{(-0.4)}{13.6}$	$P_s$	28.95

 \* Calculated from fuel analysis & stack  $O_2$ 

7602/5/81/Rev 1

Temperature stack gas, average ( $^{\circ}$ F)	$T_s$	522.3
Stack velocity (fps) 85.49 ( $C_p$ ) ( $\sqrt{4P_s}$ avg) $\sqrt{\frac{T_s \text{ avg} + 460}{P_s M_s}}$ 85.49 ( $0.767$ ) ( $\frac{1}{0.749}$ ) $\sqrt{\frac{(522.3) + 460}{(28.95)(29.23)}}$	$v_s(\text{avg})$	53.053
Total sample time (minutes)	$\theta$	275
Nozzle diameter, actual (inches)	$N_d$	0.6118
Percent isokinetic (%) 17.33 ( $T_s + 460$ ) ( $V_w$ std + $V_m$ std)	$\%I$	114.9
$\theta$ $v_s$ $P_s$ $N_d^2$ 17.33 ( $522.3 + 460$ ) (( <u>50.534</u> ) + ( <u>106.367</u> )) <u>(275)</u> ( <u>53.053</u> ) ( <u>28.95</u> ) ( <u>0.6118</u> )		
Area of stack ( $\text{ft}^2$ ) $\pi = 3.1416$ $\pi r^2 \div 144$ , $\pi (\frac{18}{2})^2 \div 144$	$A_s$	7.069
Stack gas volume at standard conditions (dscfm) 60 ( $1 - B_{w0}$ ) $v_s$ avg $A_s$ $\left( \frac{528}{T_s \text{ avg} + 460} \right) \left( \frac{P_s}{29.92} \right)$ 60 ( $1 - 0.0474$ ) ( <u>53.05</u> ) ( <u>7.069</u> ) $\left( \frac{528}{522.3 + 460} \right) \left( \frac{(28.95)}{(29.92)} \right)$	$Q_s$	11148
Particulate matter concentration, dry (gr/dscf) 15.432 $\frac{M_p \text{ (grams)}}{V_m \text{ std}}$ ,    15.432 $\frac{(5.458)}{(106.367)}$	$C_s(\text{std})$	0.083
Emission rate of particulate matter (lb/hr) 0.00857 ( $Q_s$ ) $C_s(\text{std})$ , 0.00857 (_____)(_____)	$E_p$	

7602/5/81/Rev 1



## DATA REPORTING FORM

CUSTOMER CMEA DATE July 13, 1981  
CUSTOMER CONTRACT NO. 307736.22 ACUREX CONTRACT NO. A81-05-031  
RESULTS REPORT TO L. Waterland TELEPHONE \_\_\_\_\_  
ADDRESS \_\_\_\_\_  
Burlington

SAMPLE ID (CUSTOMER)	Probe	1u	3u	10u	Filter	XAD					
SAMPLE ID (LAB)	<u>761</u>	<u>768</u>	<u>767</u>	<u>766</u>	<u>770</u>	<u>760</u>					
PARAMETER											UNITS
Weight	<u>0.9750</u>	<u>0.5720</u>	<u>0.8459</u>	<u>0.2846</u>	<u>2.7803</u>	<u>130</u>					gram

ANALYST J. Labash  
REVIEWER G. Nicoll

### **5.3 EPA METHOD 5 PARTICULATE EMISSIONS**

## ISOKINETIC PERFORMANCE WORKSHEET &amp; PARTICULATE CALCULATIONS

 Plant Burlington Philpot

 Performed by R. Best

 Date 4-29-81

 Sample Location Stack

 Test No./Type 1/M5

Barometric Pressure (in. Hg)	$P_b$	28.98
Meter volume (std), $17.64 \left( \frac{V_m}{\alpha} \right) \left( P_b + \frac{\Delta H}{13.6} \right)$ $17.64 \left( \frac{109.404}{1.552} \right) \left( \frac{28.98}{13.6} + \frac{2.52}{460} \right)$	$V_m \text{ std}$	103.783
Volume of liquid collected (grams) $V_l_c$	$V_l_c$	129.4
Volume of liquid at standard condition (scf) $V_l_c \times 0.04707$	$V_w \text{ std}$	6.091
Stack gas proportion of water vapor $\frac{V_w \text{ std}}{V_w \text{ std} + V_m \text{ std}} = \frac{(6.091)}{(6.091) + 103.783}$	$B_{wo}$	0.054
Molecular weight, stack gas dry (lb/lb-mole) $(\% CO_2 \times 0.44) + (\% O_2 \times 0.32) + (\% N_2 + \% CO \times 0.28)$ $(7 \times 0.44) + (13 \times 0.32) + (80 + \text{blank} \times 0.28)$	$M_d$	29.64
Molecular weight, stack gas wet (lb/lb-mole) $M_d(1-B_{wo}) + 18(B_{wo})$ , $(29.64)(1-0.054) + 18(0.054)$	$M_s$	28.99
Absolute stack pressure (in. Hg) $P_b + \frac{P_{stack} \text{ (in. H}_2\text{O)}}{13.6} = \frac{(-40)}{13.6}$	$P_s$	28.95

7602/5/81/Rev 1

Temperature stack gas, average ( $^{\circ}$ F)	$T_s$	516.8
Stack velocity (fps) 85.49 ( $C_p$ ) ( $\sqrt{AP_s}$ avg)	$v_s(\text{avg})$	55.10
$85.49 \left( \frac{T_s \text{ avg} + 460}{P_s \text{ std} \cdot M_s} \right) \sqrt{\frac{(516.8) + 460}{(29.92)(28.99)}}$		
Total sample time (minutes)	$\theta$	120
Nozzle diameter, actual (inches)	$N_d$	0.3086
Percent isokinetic (%) 17.33 ( $T_s$ + 460) ( $V_w$ std + $V_m$ std)	$\%I$	-
$17.33 \left( \frac{516.8 + 460}{(1.078)^2 + (1.074)^2} \right) \frac{1.078^2}{(1.078^2 + 1.074^2)} \frac{1.074^2}{(1.078^2 + 1.074^2)} \frac{1.078^2}{(1.078^2 + 1.074^2)} \frac{1.074^2}{(1.078^2 + 1.074^2)}$		95.12
Area of stack ( $\text{ft}^2$ ) $\approx 3.1416$ $\pi r^2 \div 144$ , $\pi (\frac{1}{8})^2 \div 144$	$A_s$	7.069
Stack gas volume at standard conditions (dscfm) 60 (1 - $B_{WD}$ ) $V_s$ avg $A_s$ $\left( \frac{528}{T_s \text{ avg} + 460} \right) \left( \frac{P_s}{29.92} \right)$	$Q_s$	12382
$60 \left( 1 - \frac{0.034}{0.034} \right) \left( \frac{528}{516.8 + 460} \right) \left( \frac{29.55}{29.92} \right)$		
Particulate matter concentration, dry (gr/dscf) 15.432 $\frac{M_p \text{ (grams)}}{V_m \text{ std}}$ , 15.432 $\frac{(5172) .0057}{(423.783)}$	$C_s(\text{std})$ Front: 0.07690 Back: 0.00085 Total: 0.07775	
Emission rate of particulate matter (lb/hr) 0.00857 ( $Q_s$ ) $C_s(\text{std})$ , 0.00857 (12382) (0.07690) $\div 0.000857$	$E_p$ Front: 8.160 Back: 0.090 Total: 8.250	

7602/5/B1/Rev 1

7735.22

B.F. Drasco

CMEA: BURLINGTON  
CENTRALTON, N.C.

TEST I.D.	V <sub>M</sub> (STD)	FRONT HALF		BACK HALF		IMPIINGER RINSE (bottom) mg	IMPIINGER CONTENTS			
		PROBE # NOZZLE CATCH (mg)	M-5 FILTER (mg)	AQUEOUS PHASE (mg)	ORGANIC PHASE (mg)					
M-5 Test No 1	103.783	96.29	420.91	21	.72	5.00				

1) BLURRY CORROBORATED

2) LAB APPARENTLY MIXED IMP. RINSE + PRYCE RINSE - TO FORM ONE (1) SAMPLE

**ACUREX**  
**ANALYTICAL REPORT**

Sample of: Buslington

Sample Date: April 29, 1981

Requested By: Bruce Davis

I.D. Number: 7735.22 /CMEA

Analytical Method: EPA Method 5 Protocol - Ether/Chloroform Extractions  
Date of Analysis: September 3, 1981 of Impinger Liquids

Lab I.D. Number	Component	Analytical Result	Unit
813753 - Test 1 - Aqueous Phase - Organic Phase	481 mls	0.72 5.00	Net Gain milligrams

Analysis By J. Dwyer / G. L. Hartmer

5-11 Date September 15, 1981

# ACUREX ANALYTICAL REPORT

Sample of: Burlington

Sample Date: April 29, 1981

Requested By: Bruce Davis

I.D. Number: 7735.22 / CMER

Analytical Method: Densimetric Analysis of Acetone Probe Wash

Date of Analysis: September 1 and 2, 1981

Lab I.D. Number	Component	Analytical Result	Unit
813752 - Test 1	120 mls	96.29 -.24 = 96.05	Net Gain milligrams
813787 - Acetone Blank	330 mls	0.67 .0020 mg/ml	

Analysis By J. Mayer / G. Whitmer

5-12 Date September 16, 1981

**ACUREX**  
**ANALYTICAL REPORT**

Sample of: Burlington

Sample Date: April 29, 1981

Requested By: Bruce Davis

I.D. Number: 7735.22 / CMER

Analytical Method: Gravimetric Analysis of Filter

Date of Analysis: July 30, 1981

Lab I.D. Number	Component	Analytical Result	Unit
813805 - Test 1	MV-142-206	1.41326 - 1.01335 =.39991	Final Filter Weight
813788 - Blank	B-21	1.00995	

Note: Due to unavailability of filter tare weight,  
actual filter final weight is reported  
rather than Net Weight GAIN.

Analysis By J. Davis / J. Whitman

5-13 Date September 15, 1981

**5.4 SULFUR OXIDES EMISSIONS FROM CONTROLLED CONDENSATION SAMPLES**

**CONTROLLED CONDENSATION SYSTEM (CCS)**  
**LABORATORY DATA SHEET**

Plant Burlington Philpot  
 Date \_\_\_\_\_  
 Sample Location STACK  
 Run No. 1

Analyst DAROS  
 Date Lab Analysis Completed 7-20-81

Method \_\_\_\_\_ Titrant \_\_\_\_\_ Titration Data  
 Normality \_\_\_\_\_ Indicator \_\_\_\_\_

Sample Description	Probe, Nozzle and Filter Rinse	G/R Coil Rinse	Impinger Contents and Rinse	H <sub>2</sub> O Blank	3% H <sub>2</sub> O <sub>2</sub> Blank
Sample No.	813746	813745	813802		813692 <del>81389</del>
Vol. of Sample	87	70	314	inc. 0.05 ml 0.02N H <sub>2</sub> SO <sub>4</sub>	inc. 0.50 ml 0.02N H <sub>2</sub> SO <sub>4</sub>
Vol. of Aliquot	5	5	5	✓ 5	5
Vol. of Titrant Used	1.65 1.55 1.60	0.40 0.45 0.40	1.0 1.0 1.0	.25 .50	0.10 0.10 0.10
Average Vol. of Titrant Used	1.60	0.42	1.0	inc. 0.10 ml ↑ 0.02 N H <sub>2</sub> SO <sub>4</sub>	

Calculations

Vol. of Gas Sampled ( $V_M$ ) 19.45 ft<sup>3</sup>, Avg. Meter Temp ( $T_M$ ) 71.6 °F,  
 Meter Pressure ( $P_M$ ) "Hg, Meter  $\alpha$  Factor C.188 dimensionless

$\text{PPM } \text{SO}_4 = \frac{48.15 (\text{_____, MgSO}_4)(\text{_____, } T_M + 460)}{96 (\text{_____, } V_M)(\text{_____, } P_M) (\text{_____, } \alpha)}$
ppm SO <sub>4</sub> =
$\text{PPM } \text{SO}_2 = \frac{48.15 (\text{_____, MgSO}_2)(\text{_____, } T_M + 460)}{64 (\text{_____, } V_M)(\text{_____, } P_M) (\text{_____, } \alpha)}$
ppm SO <sub>2</sub> =

**CONTROLLED CONDENSATION SYSTEM (CCS)**  
**LABORATORY DATA SHEET**

Plant Burlington Philpott  
 Date \_\_\_\_\_  
 Sample Location S  
 Run No. 1

Analyst DAROS  
 Date Lab Analysis Completed 10-20-81

Method \_\_\_\_\_ Titrant \_\_\_\_\_ Normality \_\_\_\_\_ Indicator BARIUM THORIN

Sample Description	Probe, Nozzle and Filter Rinse		G/R Coil Rinse	Impinger Contents and Rinse	H <sub>2</sub> O Blank	3% H <sub>2</sub> O <sub>2</sub> Blank
Sample No.	813746		813745	813802	813693	813692
Vol. of Sample	87		70	314		
Vol. of Aliquot						
Vol. of Titrant Used	.05	.05	0.05	0.05	.05	.05
Average Vol. of Titrant Used						

Calculations

Vol. of Gas Sampled ( $V_M$ ) 18.451 ft<sup>3</sup>, Avg. Meter Temp ( $T_M$ ) 91.6 °F,  
 Meter Pressure ( $P_M$ ) 100 "Hg, Meter α Factor 0.988 dimensionless

$\text{PPM } \text{SO}_4 = \frac{48.15 (\text{_____, MgSO}_4)(\text{_____, } T_M + 460)}{96 (\text{_____, } V_M)(\text{_____, } P_M) (\text{_____, } \alpha)}$
$\text{ppm SO}_4 =$
$\text{PPM } \text{SO}_2 = \frac{48.15 (\text{_____, MgSO}_2)(\text{_____, } T_M + 460)}{64 (\text{_____, } V_M)(\text{_____, } P_M) (\text{_____, } \alpha)}$
$\text{ppm SO}_2 =$

## **5.5 TRACE ELEMENT ANALYSIS**

**COMMERCIAL TESTING & ENGINEERING CO.**

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 · AREA CODE 312 728-8434  
INSTRUMENTAL ANALYSIS DIVISION: 14035 WEST 44TH AVENUE GOLDEN, COLORADO 80401. PHONE 303-278-9521

Reply to

To: Mr. Roy A. Belletto  
Acurex Corporation  
485 Clyde Avenue  
Mountain View, CA 94942



Date August 24, 1981

Release No. 5  
P. O. No.: Subcontract SW59159A

Analyst: J. Oldham

Sample No. A81-05-031-759 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS IAD No. 97-G852-116-25  
Lexington Filter Blank CONCENTRATION IN  $\mu\text{g}/\text{cm}^2$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.002
Thorium		Gadolinium		Molybdenum	<0.001	Titanium	0.3
Bismuth		Europium		Niobium	0.001	Scandium	<0.001
Lead	0.002	Samarium		Zirconium	0.007	Calcium	6
Thallium		Neodymium		Yttrium	<0.001	Potassium	0.2
Mercury	NR	Praseodymium	<0.001	Strontium	0.008	Chlorine	0.06
Gold		Cerium	0.001	Rubidium	<0.001	Sulfur	0.2
Platinum		Lanthanum	0.001	Bromine	0.04	Phosphorus	0.2
Iridium		Barium	0.03	Selenium		Silicon	>8
Osmium		Cesium		Arsenic	NR	Aluminum	>0.1
Rhenium		Iodine	<0.001	Germanium		Magnesium	5
Tungsten		Tellurium		Gallium	0.002	Sodium	>0.3
Tantalum		Antimony	NR	Zinc	0.007	Fluorine	=0.2
Hafnium		Tin		Copper	0.002	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.004	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	<0.001	Carbon	NR
Thulium	<i>RECEIVED</i>	Silver	0.005	Iron	0.07	Boron	0.7
Erbium	<i>... U.S REC'D</i>	Palladium		Manganese	0.003	Beryllium	<0.001
Holmium	<i>ACUREX</i>	Rhodium		Chromium	0.001	Lithium	<0.001
Dysprosium						Hydrogen	NR

STD — Internal Standard  
NR — Not Reported  
All elements not detected <  $0.001 \mu\text{g}/\text{cm}^2$   
MC — Major Component >  $10 \mu\text{g}/\text{cm}^2$   
INT — Interference

Approved:

**COMMERCIAL TESTING & ENGINEERING CO.**

GENERAL OFFICES 226 NORTH LA SALLE STREET, CHICAGO ILLINOIS 60601 AREA CODE 312 726-8434  
INSTRUMENTAL ANALYSIS DIVISION 14035 WEST 44TH AVENUE GOLDEN, COLORADO 80401 PHONE 303-278-9521

Reply to

To: Mr. Roy A. Belletto  
Acurex Corporation  
485 Clyde Avenue  
Mountain View, CA 94942



Date August 25, 1981

Release No. 5  
P. O. No.: Subcontract SW59159A

Analyst J. Oldham

Sample No.: A81-05-031-784 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS IAD No 97-G852-116-25  
Lexington XAD blank CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.1
Thorium		Gadolinium		Molybdenum	0.9	Titanium	2
Bismuth		Europium		Niobium		Scandium	<0.1
Lead	0.3	Samarium		Zirconium	1	Calcium	15
Thallium		Neodymium	0.2	Yttrium	0.3	Potassium	21
Mercury	NR	Praseodymium	0.3	Strontium	0.1	Chlorine	2
Gold		Cerium	1	Rubidium		Sulfur	1
Platinum	4	Lanthanum	2	Bromine	0.7	Phosphorus	0.4
Iridium		Barium	2	Selenium		Silicon	12
Osmium		Cesium		Arsenic	NR	Aluminum	1
Rhenium		Iodine	<0.1	Germanium		Magnesium	7
Tungsten		Tellurium		Gallium	<0.1	Sodium	10
Tantalum		Antimony	NR	Zinc	4	Fluorine	=0.3
Hafnium		Tin		Copper	3	Oxygen	NR
Lutetium		Indium	STD	Nickel	13	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	<0.1	Carbon	NR
Thulium		Silver		Iron	5	Boron	*0.5
Erbium		Palladium		Manganese	1	Beryllium	
Holmium		Rhodium	RECEIVED	Chromium	*3	Lithium	*<0.1
Dysprosium			SEP 08 1981			Hydrogen	NR

STD - Internal Standard

NR - Not Reported

All elements not detected < 0.1 ppm

MC - Major Component

INT - Interference

*ACUREX*

Approved:

\*Heterogeneous

**COMMERCIAL TESTING & ENGINEERING CO.**

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 • AREA CODE 312 728-8434  
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE 303-278-9521

Reply to



To: Mr. Roy A. Belletto  
Acurex Corporation  
485 Clyde Avenue  
Mountain View, CA 94942

Date August 20, 1981

Release No. 5  
P. O. No.: Subcontract SW59159A

Analyst: J. Oldham

Sample No.: A81-05-031-754 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS  
Lexington Imp 1 Blank CONCENTRATION IN  $\mu\text{g}/\text{ml}$  IAD No.: 97-G852-116-25

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	<0.001
Thorium		Gadolinium		Molybdenum	0.01	Titanium	0.09
Bismuth		Europium		Niobium		Scandium	<0.001
Lead	0.008	Samarium		Zirconium	0.03	Calcium	MC
Thallium		Neodymium		Yttrium		Potassium	1
Mercury	NR	Praseodymium		Strontium	0.02	Chlorine	0.05
Gold		Cerium	0.001	Rubidium		Sulfur	*0.07
Platinum		Lanthanum		Bromine	0.02	Phosphorus	0.4
Iridium		Barium	3	Selenium		Silicon	1
Osmium		Cesium		Arsenic	NR	Aluminum	0.1
Rhenium		Iodine	0.002	Germanium		Magnesium	0.04
Tungsten		Tellurium		Gallium		Sodium	>2
Tantalum		Antimony	NR	Zinc	0.02	Fluorine	=3
Hafnium		Tin	0.4	Copper	0.003	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.02	Nitrogen	NR
Ytterbium		Cadmium	0.02	Cobalt	0.002	Carbon	NR
Thulium		Silver		Iron	0.2	Boron	0.004
Erbium		Palladium		Manganese	0.04	Beryllium	
Holmium		Rhodium		Chromium	0.005	Lithium	0.003
Dysprosium		*Heterogeneous				Hydrogen	NR

STD - Internal Standard

NR - Not Reported

All elements not detected < 0.001  $\mu\text{g}/\text{ml}$

MC - Major Component > 10  $\mu\text{g}/\text{ml}$

INT - Interference

Approved: M.L. Jacobs by P.J. Ziegler  
24 Aug 81

**COMMERCIAL TESTING & ENGINEERING CO.**

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO ILLINOIS 60601 AREA CODE 312 726-8434  
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE GOLDEN COLORADO 80401 PHONE 303-278-9521

Reply to

To: Mr. Roy A. Belletto  
Acurex Corporation  
485 Clyde Avenue  
Mountain View, CA 94942

Date August 25, 1981

Release No. 5  
P. O. No.: Subcontract SW59159A

Analyst: J. Oldham

Sample No.: A81-05-030-690 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS  
Lexington fuel IAD No 97-G852-116-25

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium	<0.01	Ruthenium		Vanadium	0.04
Thorium		Gadolinium	0.01	Molybdenum	0.02	Titanium	3
Bismuth		Europium	<0.01	Niobium	0.01	Scandium	<0.01
Lead	0.2	Samarium	0.05	Zirconium	0.3	Calcium	MC
Thallium		Neodymium	0.02	Yttrium	0.07	Potassium	>62
Mercury	NR	Praseodymium	0.06	Strontium	3	Chlorine	22
Gold		Cerium	0.6	Rubidium	0.4	Sulfur	6
Platinum		Lanthanum	0.5	Bromine	0.2	Phosphorus	57
Iridium		Barium	21	Selenium	0.06	Silicon	17
Osmium		Cesium	<0.01	Arsenic	NR	Aluminum	2
Rhenium		Iodine	0.03	Germanium	0.01	Magnesium	MC
Tungsten		Tellurium	<0.01	Gallium	0.04	Sodium	>13
Tantalum		Antimony	NR	Zinc	3	Fluorine	=0.4
Hafnium		Tin	0.02	Copper	2	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.2	Nitrogen	NR
Ytterbium		Cadmium	0.09	Cobalt	0.09	Carbon	NR
Thulium		Silver	<0.01	Iron	12	Boron	0.2
<i>RECEIVED</i>		Palladium		Manganese	17	Beryllium	<0.01
<i>Holmium U-34</i>		Rhodium		Chromium	0.03	Lithium	0.07
<i>Dysprosium</i>		Note: Sample low temperature oxygen plasma ashed prior to analysis				Hydrogen	NR

STD - Internal Standard

NR - Not Reported

All elements not detected < 0.01ppm

MC - Major Component >100ppm

INT - Interference

Approved:

# COMMERCIAL TESTING & ENGINEERING CO.

GENERAL OFFICES 228 NORTH LA SALLE STREET, CHICAGO ILLINOIS 60601 AREA CODE 312 726-8434  
INSTRUMENTAL ANALYSIS DIVISION, 14305 WEST 44TH AVENUE GOLDEN, COLORADO 80401 PHONE 303-278-9521

Reply to

To: Mr. Roy A. Belletto  
Acurex Corporation  
485 Clyde Avenue  
Mountain View, CA 94942

Date August 25, 1981



Release No. 5  
P. O. No.: Subcontract SW59159A

Analyst J. Oldham

Sample No.: A81-05-031-765  
Lexington bottom ash SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS IAD No. 97-G852-116-25  
CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	0.4	Terbium	0.9	Ruthenium		Vanadium	15
Thorium	0.9	Gadolinium	2	Molybdenum	13	Titanium	MC
Bismuth		Europium	1	Niobium	1	Scandium	1
Lead	82	Samarium	9	Zirconium	7	Calcium	MC
Thallium		Neodymium	22	Yttrium	15	Potassium	MC
Mercury	NR	Praseodymium	10	Strontium	MC	Chlorine	110
Gold		Cerium	66	Rubidium	260	Sulfur	MC
Platinum		Lanthanum	120	Bromine	4	Phosphorus	MC
Iridium		Barium	MC	Selenium	2	Silicon	MC
Osmium		Cesium	0.7	Arsenic	NR	Aluminum	MC
Rhenium		Iodine	0.5	Germanium	0.3	Magnesium	MC
Tungsten	25	Tellurium	0.3	Gallium	7	Sodium	MC
Tantalum		Antimony	NR	Zinc	240	Fluorine	=160
Hafnium	0.3	Tin	2	Copper	61	Oxygen	NR
Lutetium	<0.1	Indium	STD	Nickel	75	Nitrogen	NR
Ytterbium	0.5	Cadmium	0.8	Cobalt	3	Carbon	NR
Thulium	<0.1	Silver		Iron	MC	Boron	280
Erbium	0.4	Palladium		Manganese	>460	Beryllium	0.2
Holmium	1	Rhodium		Chromium	52	Lithium	65
Dysprosium	2					Hydrogen	NR

**RECEIVED**

Ser 06 REC'D

STD - Internal Standard

NR - Not Reported

All elements not detected < 0.1ppm ACUREX

MC - Major Component > 1000

INT - Interference

Approved:

**COMMERCIAL TESTING & ENGINEERING CO.**

Reply to

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO ILLINOIS 60601 - AREA CODE 312 726-8434  
INSTRUMENTAL ANALYSIS DIVISION: 14035 WEST 44TH AVENUE, GOLDEN, COLORADO 80401, PHONE 303-278-9521

To: Mr. Roy A. Belletto  
Acurex Corporation  
485 Clyde Avenue  
Mountain View, CA 94942



Date: August 25, 1981

Release No. 5  
P. O. No.: Subcontract SW59159A

Analyst: J. Oldham

Sample No.: A81-05-031-761 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS IAD No 97-G852-116-25  
Lexington Probe Wash CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	<0.9	Terbium	1	Ruthenium		Vanadium	25
Thorium	1	Gadolinium	4	Molybdenum	15	Titanium	MC
Bismuth	0.1	Europium	3	Niobium	2	Scandium	0.8
Lead	240	Samarium	12	Zirconium	8	Calcium	MC
Thallium	31	Neodymium	14	Yttrium	19	Potassium	MC
Mercury	NR	Praseodymium	27	Strontium	930	Chlorine	MC
Gold		Cerium	170	Rubidium	110	Sulfur	MC
Platinum		Lanthanum	140	Bromine	11	Phosphorus	MC
Iridium		Barium	MC	Selenium	7	Silicon	MC
Osmium		Cesium	0.9	Arsenic	NR	Aluminum	MC
Rhenium		Iodine	2	Germanium	1	Magnesium	MC
Tungsten	4	Tellurium		Gallium	4	Sodium	MC
Tantalum	≤1	Antimony	NR	Zinc	MC	Fluorine	MC
Hafnium	0.8	Tin	5	Copper	78	Oxygen	NR
Lutetium	0.3	Indium	STD	Nickel	120	Nitrogen	NR
Ytterbium	1	Cadmium	10	Cobalt	10	Carbon	NR
Thulium	0.4	Silver	24	Iron	MC	Boron	310
Erbium	1	Palladium		Manganese	MC	Beryllium	<0.1
Holmium	2	Rhodium		Chromium	120	Lithium	1
Dysprosium	6	<b>RECEIVED</b>		Hydrogen			NR

STD - Internal Standard

NR - Not Reported

All elements not detected < 0.1 ppm

MC - Major Component > 1000

INT - Interference

5-11 08 RECD

Approved:

**COMMERCIAL TESTING & ENGINEERING CO.**

Reply to

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO ILLINOIS 60601 · AREA CODE 312 728-8434  
INSTRUMENTAL ANALYSIS DIVISION 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401 PHONE 303-278-9521



To: Mr. Roy A. Belletto  
Acurex Corporation  
485 Clyde Avenue  
Mountain View, CA 94942

Date August 25, 1981

Release No. 5  
P. O. No.: Subcontract SW59159A

Analyst: J. Oldham

Sample No.: A81-05-031-766 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS IAD No.: 97-G852-116-25  
Lexington 10 $\mu$  + 3 $\mu$

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium	<0.6	Terbium	2	Ruthenium		Vanadium	9
Thorium	1	Gadolinium	5	Molybdenum	20	Titanium	MC
Bismuth	0.6	Europium	2	Niobium	2	Scandium	<0.1
Lead	170	Samarium	19	Zirconium	15	Calcium	MC
Thallium	0.6	Neodymium	25	Yttrium	40	Potassium	MC
Mercury	NR	Praseodymium	21	Strontium	MC	Chlorine	MC
Gold		Cerium	240	Rubidium	520	Sulfur	MC
Platinum		Lanthanum	240	Bromine	21	Phosphorus	MC
Iridium		Barium	MC	Selenium	28	Silicon	MC
Osmium		Cesium	1	Arsenic	NR	Aluminum	MC
Rhenium		Iodine	3	Germanium	2	Magnesium	MC
Tungsten	89	Tellurium	0.7	Gallium	7	Sodium	MC
Tantalum	3	Antimony	NR	Zinc	MC	Fluorine	~140
Hafnium		Tin	8	Copper	170	Oxygen	NR
Lutetium	0.4	Indium	STD	Nickel	300	Nitrogen	NR
Ytterbium	2	Cadmium	17	Cobalt	17	Carbon	NR
Thulium	0.3	Silver	17	Iron	MC	Boron	570
Erbium	2	Palladium		Manganese	>920	Beryllium	0.2
Holmium	3	Rhodium		Chromium	100	Lithium	3
Dysprosium	4	<b>RECEIVED</b>				Hydrogen	NR

STD - Internal Standard

NR - Not Reported

All elements not detected < 0.1 ppm **ACUREX**

MC - Major Component > 1000

INT - Interference

SPL 08 RECD

Approved:

*M. Y. Jacobs*

**COMMERCIAL TESTING & ENGINEERING CO.**

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO ILLINOIS 60601 AREA CODE 312 726-8434  
INSTRUMENTAL ANALYSIS DIVISION, 14305 WEST 44TH AVENUE GOLDEN, COLORADO 80401 PHONE 303-278-9521

Reply to

To: Mr. Roy A. Belletto  
Acurex Corporation  
485 Clyde Avenue  
Mountain View, CA 94942

Date August 25, 1981

Release No. 5  
P. O. No.: Subcontract SW59159A

Analyst J. Oldham

Sample No.: A81-05-031-768 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS      IAD No 97-G852-116-25  
Lexington 1  $\mu$  + filter      CONCENTRATION IN  $\mu\text{g}/\text{cm}^2$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC	ELEMENT	CONC
Uranium	<0.001	Terbium	<0.001	Ruthenium		Vanadium	0.002
Thorium	<0.001	Gadolinium	<0.001	Molybdenum	0.006	Titanium	0.1
Bismuth	<0.001	Europium	<0.001	Niobium	0.003	Scandium	<0.001
Lead	0.5	Samarium	0.001	Zirconium	0.007	Calcium	MC
Thallium		Neodymium	0.003	Yttrium	0.002	Potassium	>0.3
Mercury	NR	Praseodymium	0.001	Strontium	0.1	Chlorine	3
Gold		Cerium	0.01	Rubidium	0.1	Sulfur	>0.2
Platinum		Lanthanum	0.01	Bromine	0.02	Phosphorus	>0.8
Iridium		Barium	2	Selenium	0.001	Silicon	>2
Osmium		Cesium	<0.001	Arsenic	NR	Aluminum	>0.02
Rhenium		Iodine	0.001	Germanium	0.001	Magnesium	>2
Tungsten	0.04	Tellurium	<0.001	Gallium	0.002	Sodium	>0.06
Tantalum	<0.001	Antimony	NR	Zinc	1	Fluorine	=0.6
Hafnium	<0.001	Tin	0.002	Copper	0.03	Oxygen	NR
Lutetium	<0.001	Indium	STD	Nickel	0.03	Nitrogen	NR
Ytterbium	<0.001	Cadmium	0.002	Cobalt	0.002	Carbon	NR
Thulium	<0.001	Silver	0.01	Iron	0.2	Boron	0.5
Erbium	<0.001	Palladium		Manganese	>0.3	Beryllium	
Holmium	<0.001	Rhodium	RECEIVED	Chromium	0.01	Lithium	0.003
Dysprosium	<0.001		REC'D			Hydrogen	NR

STD - Internal Standard

NR - Not Reported

All elements not detected < 0.001  $\mu\text{g}/\text{cm}^2$

ACUREX MC - Major Component > 10  $\mu\text{g}/\text{cm}^2$

INT - Interference

Approved:

*M. Jacobs*

**COMMERCIAL TESTING & ENGINEERING CO.**

GENERAL OFFICES 228 NORTH LA SALLE STREET, CHICAGO ILLINOIS 60601 · AREA CODE 312 726-8434  
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE GOLDEN COLORADO 80401. PHONE 303-278-9521

Reply to

To: Mr. Roy A. Belletto  
Acurex Corporation  
485 Clyde Avenue  
Mountain View, CA 94942

Date: August 25, 1981

Release No. 5  
P. O. No.: Subcontract SW59159A

Analyst: J. Oldham

Sample No.: A81-05-031-760 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS      IAD No.: 97-G852-116-25  
Lexington XAD

CONCENTRATION IN PPM WEIGHT

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	<0.1
Thorium		Gadolinium		Molybdenum	0.4	Titanium	<0.9
Bismuth		Europium		Niobium		Scandium	<0.1
Lead		Samarium		Zirconium	2	Calcium	76
Thallium		Neodymium		Yttrium		Potassium	93
Mercury	NR	Praseodymium		Strontium	0.1	Chlorine	34
Gold		Cerium		Rubidium		Sulfur	*6
Platinum	0.3	Lanthanum		Bromine	0.3	Phosphorus	*3
Iridium		Barium	0.8	Selenium		Silicon	57
Osmium		Cesium		Arsenic	NR	Aluminum	2
Rhenium		Iodine	<0.1	Germanium		Magnesium	3
Tungsten		Tellurium		Gallium	<0.1	Sodium	4
Tantalum		Antimony	NR	Zinc	2	Fluorine	=0.7
Hafnium		Tin		Copper	5	Oxygen	NR
Lutetium		Indium	STD	Nickel	48	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	<0.1	Carbon	NR
Thulium		Silver		Iron	18	Boron	0.3
Erbium		Palladium		Manganese	0.4	Beryllium	
Holmium		Rhodium	RECEIVED	Chromium	*4	Lithium	*0.1
Dysprosium			SEP 08 RECD			Hydrogen	NR

STD — Internal Standard

NR — Not Reported

All elements not detected < 0.1 ppm

MC — Major Component      G-1000

INT — Interference

ACUREX

Approved:

\*Heterogeneous

*M. Speciale*

**COMMERCIAL TESTING & ENGINEERING CO.**

GENERAL OFFICES: 228 NORTH LA SALLE STREET, CHICAGO, ILLINOIS 60601 - AREA CODE 312 726-8434  
INSTRUMENTAL ANALYSIS DIVISION, 14335 WEST 44TH AVENUE, GOLDEN, COLORADO 80401 PHONE 303-278-9521

Reply to



To: Mr. Roy A. Belletto  
Acurex Corporation  
485 Clyde Avenue  
Mountain View, CA 94942

Date August 25, 1981

Release No. 5

Analyst J. Oldham

P. O. No.: Subcontract SW59159A

Sample No.: A81-05-031-762 SPARK SOURCE MASS SPECTROGRAPHIC ANALYSIS  
Lexington Imp 1

CONCENTRATION IN  $\mu\text{g}/\text{ml}$

ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.	ELEMENT	CONC.
Uranium		Terbium		Ruthenium		Vanadium	0.002
Thorium		Gadolinium		Molybdenum	0.01	Titanium	0.04
Bismuth		Europium		Niobium	0.002	Scandium	
Lead	0.01	Samarium		Zirconium	0.003	Calcium	0.4
Thallium		Neodymium		Yttrium		Potassium	0.6
Mercury	NR	Praseodymium		Strontium	0.002	Chlorine	0.3
Gold		Cerium		Rubidium	0.003	Sulfur	>8
Platinum		Lanthanum		Bromine	0.01	Phosphorus	0.02
Iridium		Barium	0.01	Selenium	<0.03	Silicon	0.2
Osmium		Cesium	<0.001	Arsenic	NR	Aluminum	0.03
Rhenium		Iodine	0.003	Germanium		Magnesium	0.06
Tungsten		Tellurium	0.004	Gallium	0.02	Sodium	>3
Tantalum		Antimony	NR	Zinc	0.8	Fluorine	=0.1
Hafnium		Tin	0.03	Copper	0.2	Oxygen	NR
Lutetium		Indium	STD	Nickel	0.2	Nitrogen	NR
Ytterbium		Cadmium		Cobalt	<0.001	Carbon	NR
Thulium		Silver	0.002	Iron	0.2	Boron	0.001
Erbium		Palladium		Manganese	0.05	Beryllium	
Holmium		Rhodium		Chromium	0.03	Lithium	<0.001
Dysprosium		<b>RECEIVED</b>				Hydrogen	NR

STD - Internal Standard

NR - Not Reported

All elements not detected < 0.001  $\mu\text{g}/\text{ml}$  ACUREX

MC - Major Component >10  $\mu\text{g}/\text{ml}$

INT - Interference

Approved:

5.6 C<sub>1</sub> TO C<sub>6</sub> HYDROCARBONS BY GAS CHROMATOGRAPHY

C<sub>1</sub> TO C<sub>6</sub> GC SUMMARY

Run No.	Bulb I.D.	Sample Time	Approximate Bulb Temperature (°F)	Recorder/Print-Out Reference No.	C <sub>1</sub>	C <sub>2</sub>	C <sub>3</sub>	C <sub>4</sub>	C <sub>5</sub>	C <sub>6</sub>
1	A	1225	518	10	3.1	0.6	2.3	1.2	ND	--
1	A	1225	518	11	4.8	2.0	ND	ND	ND	--
1	B	1235	518	13	4.1	2.0	2.0	0.8	ND	--
2	A	1402	520	14	ND	ND	1.8	ND	ND	--
2	B	1408	520	15	ND	ND	1.6	ND	ND	--
2	A	1402	520	16	ND	ND	1.6	ND	ND	--
2	B	1408	520	17	ND	ND	1.8	ND	ND	--
3	A	1630	517	19	1.9	ND	1.0	ND	ND	--
3	B	1640	508	20	2.1	ND	1.0	ND	ND	--
3	A	1630	517	21	2.0	ND	1.5	ND	ND	--

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CMEA, Location Lexington, N.C., Job No. 7725.2

Injection Date 4-28-81, Time 19:39:42, Instrument ID VAC141  
Recorder/Printout Reference No. 6, Recorder ID AP237APurpose of Run DETERMINATION OF C<sub>2</sub> RETENTION TIMESample Description SCOTTY T 1000PPM IN ETHANOL  
±10 in BAL N<sub>2</sub>

## GC CONDITIONS

Amount Injected 1 μl, Inj. Port or Sample Loop Used 1μl loop

Detector Used: FID , ECD , FPD , TCD  (Current \_\_\_\_\_)Detector Attenuation , Amplifier or Range  $10^{-11}$ Column: Liquid Phase , Solid Phase  PREPAPALLength 6', O.D.  $\frac{1}{8}$ " , I.D. , Material 

Temperature: Injector 120 °C, Oven 120 °C, Detector 150 °C


Temperature Program ISOTHERMAL

## SAMPLE RUN

Sampling Method 

RT min	Area	Peak Height	Amount (ppm)	Component
0.58	481420		104	C <sub>2</sub> -C <sub>2</sub>

Name of Operator  Tom Hearn, Date  10-1 1981



RUN # 6 APR/28/81 19:38:42  
ID 1 NO CALIB PEAKS FOUND

AREA%	RT	AREA	TYPE	AR/HT	AREA%
	0.21	12333	D BP	0.081	2.814
	0.56	481420	D PB	0.086	74.964
	1.46	3444	BB	0.270	0.536
	3.41	144410	BB	0.373	22.486

TOTAL AREA= 642200  
MUL FACTOR= 1.0000E+00

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CMAA, Location (Exeter), N.J. Job No. 27352

Injection Date 4-28-81, Time 20:04:22, Instrument ID VARIAN 3100  
 Recorder/Printout Reference No. 7, Recorder ID HP 331A  
 Purpose of Run DETERMINATION OF C<sub>4</sub> RETENTION TIME

Sample Description Scotix T ~ 106 ppm in BUTANE  
± 10% in BAL. N<sub>2</sub>

## GC CONDITIONS

Amount Injected 2μl, Inj. Port or Sample Loop Used 2ml/loop  
 Detector Used: FID X, ECD  , FPD  , TCD   (Current  )  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase  , Solid Phase PORAPAK Q,  
 Length 6', O.D. 1/8", I.D.  , Material  .  
 Temperature: Injector 120 °C, Oven 130 °C, Detector 250 °C  
 Temperature Program ISOTHERMAL


## SAMPLE RUN

Sampling Method N/A

RT min.	Area	Peak Height	Amount (ppm)	Component
4.20	951690		106	C <sub>4</sub>

Name of Operator Tom Hahn, Date 10-21-81 19 81

Operator: J. HOLM ..... Date: 4-28-81  
 Column No. .... Length: 6' .... Dia. 1/4"  
 Coating: ..... Concn.: .....  
 Support: P.D.R.E.P.A.K. Q ..... Mesh: 80% 100%  
 TEMP: Col: Init. 120 °C Final 120 °C  
 Rate: °C/min. Det. 250 °C Inl. °C  
 CARRIER GAS: H<sub>2</sub> ..... Rate: 24.4 ml/min.  
 Pressures: Inlet: 40 PSI, min. Outlet: 40 PSI, min.  
 Hydrogen: 40 PSI, min. Air: 0. PSI, min/min.  
 DETECTOR E.C. .... T.C. .... F.I.D. & XID = " "  
 Scavenger: ..... Rate: ..... ml/min.  
 Sens. .... Rec. Range: ..... mv.  
 SAMPLE CAL. GAS: C<sub>4</sub> ..... Size: 2 mL .....  
 Solvent: ..... Concn.: 1.06, RPM



RUN #: 7      APR/28/81 20:04:22  
 ID: 1  
 NO CALIB PEAKS FOUND

AREA%	RT	AREA	TYPE	AR/HT	AREA%
	0.22	2669	D	BP	0.260
	0.49	33716	D	PB	3.281
	1.46	22487	PR	0.162	2.189
	3.42	11456	BV	0.345	1.115
	4.20	951690	BV	0.431	92.628
	7.26	5501	BV	0.917	0.535

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CMEA, Location LEXINGTON, NC, Job No. 7735.2

Injection Date 4-29-81, Time 20:30:06, Instrument ID 3700  
 Recorder/Printout Reference No. X, Recorder ID HPS330A  
 Purpose of Run CALIBRATION (INITIAL)

Sample Description SOLVENT I multi-component mixture  
C<sub>1</sub>-C<sub>6</sub> PARAFFINS ~15 ppm ± 10% b.p. N.

## GC CONDITIONS


Amount Injected 2 ml, Inj. Port or Sample Loop Used 2 ml L.P.D.  
 Detector Used: FID X, ECD  , FPD  , TCD   (Current  )  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase  , Solid Phase P-PADICOL,  
 Length 6', O.D. 1/8", I.D.  , Material >  
 Temperature: Injector 120 °C, Oven 130 °C, Detector 150 °C  
 Temperature Program ISOTHERMAL

## SAMPLE RUN

Sampling Method N/A

RT min.	Area	Peak Height	Amount (ppm)	Component
0.27	41404		15.1	C <sub>1</sub>
0.57	71370		14.6	C <sub>2</sub>
1.46	124170		15.6	C <sub>3</sub>
4.19	145150		15.2	C <sub>4</sub>
12.40	180700		15.1	C <sub>5</sub>

Name of Operator TOM HALEY, Date 10-21 1981



RUN #: 8                    APR/28/81 20:30:06  
 ID: 1  
 NO CALIB PEAKS FOUND

AREA%		RT	AREA	TYPE	AR/HT	AREA%
0.27	41484	D	BP	0.886	7.176	
0.59	71398	D	PB	0.885	12.373	
1.46	124170	PB		0.177	21.528	
4.19	145150	VV		0.432	25.157	
7.73	5714	VV		0.343	0.990	
7.90	8386	VV		0.436	1.454	
12.46	186768	VV		1.207	31.329	

TOTAL AREA= 576979  
 MUL FACTOR= 1.0000E+00

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CORE, Location LEXINGTON, NC, Job No. 7755.21

Injection Date 4-28-81, Time 21:05:51, Instrument ID VARIAN 3700  
 Recorder/Printout Reference No. 9, Recorder ID HP 339-A  
 Purpose of Run Calibration (INITIAL)

Sample Description Scotxy I Multi-Component Mixture  
C<sub>1</sub>-C<sub>6</sub> un-purified ~15ppm ±10% (each)

## GC CONDITIONS


Amount Injected 2μL, Inj. Port or Sample Loop Used 2mL  
 Detector Used: FID X, ECD  , FPD  , TCD   (Current  )  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase  , Solid Phase PORAPAK Q,  
 Length 6', O.D. 1/8", I.D.  , Material SS  
 Temperature: Injector 120 °C, Oven 120 °C, Detector 250 °C  
 Temperature Program ISOTHERMAL

## SAMPLE RUN

Sampling Method #1/A

RT min.	Area	Peak Height	Amount (ppm)	Component
0.24	45013		15.1	C <sub>1</sub>
0.57	74852		14.6	C <sub>2</sub>
1.43	123540		15.6	C <sub>3</sub>
4.16	142600		15.2	C <sub>4</sub>
12.45	170670		15.6	C <sub>5</sub>

Name of Operator Tom Hines, Date 10-21 1981



RUN # 9 APR/28/81 21:05:59  
 ID 1  
 NO CALIB PEAKS FOUND

AREA%		AREA	TYPE	AR/HT	AREA%
0.24	45613	BV	0.077		7.845
0.57	74852	VV	0.067		12.875
1.43	123540	PB	0.166		21.248
4.16	142668	PB	0.424		24.538
7.80	16938	VP	0.867		2.757
12.45	176648	PV	1.211		39.382
14.80	742	PG	0.177		0.128
22.79	1328	BB	0.286		0.227

TOTAL AREA= 561488  
 MUL FACTOR= 1.0000E+00

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CHEMEX, Location Exxon, Job No. 7135-81Injection Date 4-27-81, Time 12:57:48, Instrument ID UT-21-A  
3100Recorder/Printout Reference No. 10, Recorder ID HPS31-APurpose of Run C, -C<sub>2</sub> HYDROCARBON ANALYSISSample Description STABE NO 1 BULB A 1225

## GC CONDITIONS

Amount Injected 2 μl, Inj. Port or Sample Loop Used 1Detector Used: FID x, ECD  , FPD  , TCD   (Current  )Detector Attenuation 0, Amplifier or Range 10<sup>-1</sup>Column: Liquid Phase  , Solid Phase PORAPAK Q,Length 6', O.D. 1/8", I.D.  , Material SS.Temperature: Injector 120 °C, Oven 120 °C, Detector 150 °CTemperature Program THERMAL


## SAMPLE RUN

Sampling Method GRAB 3.7 ml (5180E)

RT	Area	Peak Height	Amount ( $\mu\text{g}$ )	Component
1.26	8256		3.1	-
1.47	2615		0.6	-
1.51	11410 827		2.3	-
1.55	4005 5517		1.2	-
3.80	1458		-	1
7.88	742840		-	CONTAMINANT

Name of Operator J. HIGGINS, Date 11-21-81

Operator J. HAGM Date 4-29-81  
 Column No. Length 6' Dia.  $\frac{1}{8}$ "  
 Coating Concn.  
 Support PORAPAK Q Mesh 80/100  
 TEMP: Col: Init. 120 °C Final. 120 °C  
 Rate ..... °C/min. Det. 250 °C Inj. 120 °C  
 CARRIER GAS H<sub>2</sub> Rate 84.4 ml/min.  
 Pressures: Inlet Outlet  
 Hydrogen 4.0 atm. Air 6.0 atm. FID  $8 \times 10^{-11}$  ml/min.  
 DETECTOR E.C. T.C.  
 Scavenger Rate ..... ml/min.  
 SENS. Rec. Range mv.  
 SAMPLE I BULB A 12.25 Size 2.0 ml  
 Solvent Concn.



RUN # 18 APR/29/81 12:57:49  
 ID 1

ESTD	RT	RTFA	TYPE	CAL#	AMOUNT
	0.19	1385	BV		0.000
	0.26	8256	VV	1R	4183E+00
	0.49	2615	V8		0.000
	0.68	11418	BB		0.000
	1.32	850	PV		0.000
	1.56	4005	VP		0.000
	2.23	5510	PP		0.000
	3.86	1458	PV		0.000
	7.88	742890	VV		0.000
	14.96	892	PV		0.000
	15.13	1183	VP		0.000
	15.36	764	PV		0.000
	15.56	1419	VV		0.000
	15.98	1386	VV		0.000
	16.21	1216	VV		0.000
	16.42	1289	VV		0.000
	16.68	1092	VV		0.000
	16.96	1321	VV		0.000
	17.21	1075	VV		0.000
	17.43	1174	VV		0.000
	17.68	1374	VV		0.000
	17.84	1178	VV		0.000
	18.89	1447	PV		0.000
	18.34	1287	VV		0.000
	18.57	861	PV		0.000
	24.56	901	VP		0.000
	24.75	1096	PP		0.000

TOTAL AREA= 799840  
 MUL. FACTOR= 1 8000E+00

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CMEA, Location Lexington, N.C., Job No. 7735.21

Injection Date 4-29-81, Time 13:30:57, Instrument ID VARIAN 3700  
 Recorder/Printout Reference No. 11, Recorder ID HP 3390A  
 Purpose of Run C<sub>1</sub>-C<sub>6</sub> HYDROCARBON ANALYSIS

Sample Description Sample No 1 BULB 1225

## GC CONDITIONS


Amount Injected 2 mL, Inj. Port or Sample Loop Used 2mL Loop  
 Detector Used: FID X, ECD  , FPD  , TCD   (Current  )  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase  , Solid Phase PORAPAK Q,  
 Length 6', O.D. 1/8", I.D.  , Material S.S.  
 Temperature: Injector 120 °C, Oven 120 °C, Detector 150 °C  
 Temperature Program ISOTHERMAL

## SAMPLE RUN

Sampling Method GRAB 300ML (5.4°F)

RT	Area	Peak Height	Amount (ppm)	Component
.25	1215Y		4.8	C <sub>1</sub>
.68	10057		2.0	C <sub>2</sub>
7.88	714460		—	CONTAMINANT

Name of Operator John Holm, Date 10-21 1981



Operator.....	HORN.....	Date.....	4-29-81.....
Column No.....	6.....	Length.....	6'.....
Coating.....	PORAPAK Q.....	Dia.....	1/8"
Support.....	PORAPAK Q.....	Concn.....	Mesh 80/100.....
TEMP: Col:	Init.....120.....°C	Final.....120.....°C	
Rate.....	°C/min.	Det. 2.5R.....°C	Inj. 120.....°C
CARRIER GAS.....	N <sub>2</sub> .....	Rate.....84.....ml./min.	
Pressures: Inlet.....		Outlet.....	
Hydrogen.....	4.0.....PSI.....ml/min.	Air.....6.0.....PSI.....ml/min.	
DETECTOR E.C.....	T.C.....	FID & X10 <sup>-1</sup> .....	
Scavenger.....	Rate.....	ml./min.	
Sens.....	Rec.Range.....	mv.	
SAMPLE.....	BOLB A.....1.25.....Size 2.0mm		
Solvent.....	Concn.....		

RUN # 11                    APR/29/81 13:38:57  
ID : 1

ESTD		RT	AREA	TYPE	CALC	AMOUNT
		0.25	12758	PB	1R	5 2823E+00
		0.68	10059	PB		0.000
		7.98	776660	BB		0.000

TOTAL AREA= 799470  
MUL FACTOR= 1.0000E+00

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CMEA, Location LEXINGTON, N.C., Job No. 7135.21

Injection Date 4-29-81, Time 14:07:53, Instrument ID VARIAN 3700  
 Recorder/Printout Reference No. 13, Recorder ID HP 3390A  
 Purpose of Run C<sub>1</sub>-C<sub>6</sub> HYDROCARBON ANALYSIS

Sample Description CAN. 2, E. 1 HOUR 12 123-

## GC CONDITIONS

Amount Injected 2 ml, Inj. Port or Sample Loop Used 2ml Loop  
 Detector Used: FID X, ECD  , FPD  , TCD   (Current  )  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase  , Solid Phase PORAPAK Q,  
 Length 6', O.D. 1/8", I.D.  , Material S.S.  
 Temperature: Injector 120 °C, Oven 120 °C, Detector 150 °C  
 Temperature Program ISO THERMAL


## SAMPLE RUN

Sampling Method GRAB 300ML (51.8°F)

RT	Area	Peak Height	Amount (ppm)	Component
0.27	1074		4.1	C <sub>1</sub>
0.51	2221		2.0	C <sub>2</sub>
0.59	2221			
1.07	10437		2.0	C <sub>3</sub>
1.53	2100			
2.25	4740		0.8	C <sub>4</sub>
7.7	792140			contaminant
				1

Name of Operator John Holm, Date 10-21 1981

TOTAL AREA= 491620  
MUL FACTOR= 1.0000E+00



Operator...J. HOLM.	Date...4-29-81
Column No.....	Length...6'
	Dia...1/8"
Coating.....	Concn.....
Support...P.D.R.A.P.A.K.	Mesh...20/40
TEMP: Col: Init...1.R.D.	°C Final...12.0...°C
Rate.....°C/min.	Det. 2.5D °C Inj. 12.0 °C
CARRIER GAS He.....	Rate 84.4 ml/min.
Pressures: Inlet.....	Outlet.....
Hydrogen...40PSI mt/mm.	Air...60 PSI mt/mm.
DETECTOR E.C. T.C. F.I.D. & X.I.D.	Size 2.0m
Scavenger.....	Rate.....ml/min.
Sens.....	Rec. Range.....mV.
SAMPLE N.o. 1 BULLS R.	Concn.....

RUN # 13 APR/29/81 14:07:53  
ID 1

ESTD  
RT AREA TYPE CALB AMOUNT  
0.59 6208 VV 2 4 4319E+00

TOTAL AREA= 6208  
MUL FACTOR= 1.0000E+00

RUN # 13 APR/29/81 14:07:53  
ID 1

AREA%	RT	AREA	TYPE	AR/HT	AREAX
	0.21	1253	PV	0.035	0.159
	0.27	10741	VB	0.055	1.285
	0.51	3031	PV	0.056	0.363
	0.59	6208	VV	0.056	0.743
	0.69	16439	VB	0.136	1.249
	1.58	2998	VP	0.186	0.347
	2.25	4748	PB	0.221	0.567
	2.51	792148	BY	0.786	94.748
	12.24	2409	PV	0.224	0.268
	18.43	2185	PV	0.309	0.261

TOTAL AREA= 836958  
MUL FACTOR= 1.0000E+00

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CMEA, Location Lexington, N.C., Job No. 7735.21

Injection Date 4-29-81, Time 14:31:36, Instrument ID VARIAN 3700  
 Recorder/Printout Reference No. 14, Recorder ID HP 3390A  
 Purpose of Run C<sub>1</sub>-C<sub>6</sub> HYDROCARBON ANALYSIS

Sample Description SAMPLE NO. 2 BOTTLE 47

## GC CONDITIONS

Amount Injected 2 ml, Inj. Port or Sample Loop Used 2ml Loop  
 Detector Used: FID X, ECD  , FPD  , TCD   (Current  )  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase  , Solid Phase PORAPAK Q,  
 Length 6', O.D. 1/8", I.D.  , Material S.S.  
 Temperature: Injector 120 °C, Oven 120 °C, Detector 150 °C  
 Temperature Program ISO THERMAL

## SAMPLE RUN

Sampling Method GRAB 300ML (520 °F)

RT	Area	Peak Height	Amount (ppm)	Component
..	9177		1.8	C <sub>2</sub>

Name of Operator John Holm, Date 10-21 1981

Operator: J. HOLM Date: 4-29-81  
 Column No. 6 Length 6' Dia.  $\frac{1}{8}$ "  
 Coating Support: PORAPAK Q Concn. Mesh: 80/200  
 TEMP: Col: Init 130 °C Final 120 °C  
 Rate °C/min. Det 250 °C Inj. 120 °C  
 CARRIER GAS: H<sub>2</sub> Rate 84.4 ml/min.  
 Pressure: Inlet Outlet  
 Hydrogen 40 P.S.I. ml/min. Air 60 P.S.L. ml/min.  
 DETECTOR E.C. T.C. F.I.D. X.I.D. -  
 Sens. Rate ml/min.  
 Scavenger: Rec. Range 0.01-1000  
 SAMPLE 2 RULG A 1% O<sub>2</sub> Size 2.0 mm  
 Solvent: Concn.



STOP

RUN # 14 APR/29/81 14:31:36  
 IN 1 NO CALIB PEAKS FOUND

AREA%	RT	AREA TYPE	AR/HT	AREA%
	6.20	2684 PV	0.052	19.583
	0.68	9179 PB	0.122	81.45

TOTAL AREA= 11263  
 MUL FACTOR= 1.0000E+00

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CMEA, Location Lexington, N.C., Job No. 7135.21

Injection Date 4-29-81, Time 15:02:30, Instrument ID VARIAN 3700  
 Recorder/Printout Reference No. 15, Recorder ID HP 3390A  
 Purpose of Run C<sub>1</sub>-C<sub>6</sub> HYDROCARBON ANALYSIS

Sample Description SAMPLE NO. 2 BULK P 141

## GC CONDITIONS

Amount Injected 2 mL, Inj. Port or Sample Loop Used 2mL Loop  
 Detector Used: FID X, ECD  , FPD  , TCD   (Current  )  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase  , Solid Phase PORAPAK Q,  
 Length 6', O.D. 1/8", I.D.  , Material S.S.  
 Temperature: Injector 120 °C, Oven 120 °C, Detector 150 °C  
 Temperature Program ISO THERMAL


## SAMPLE RUN

Sampling Method GRAB 300ML (520°F)

RT	Area	Peak Height	Amount (ppm)	Component
167	5536		104	13

Name of Operator John Holm, Date 10-21 1981

Operator J. HOLM Date 4-29-81  
 Column No. Length 6' Dia.  $\frac{1}{8}$ "  
 Coating Support P.R.R.A.P.A.K. Q. Concn.  
 TEMP: Col. Init. 120 °C Final. 120 °C  
 Rate... °C/min. Det. 250 °C Inj. 120 °C  
 CARRIER GAS He Rate 84 ml./min.  
 Pressures: Inlet Outlet  
 Hydrogen 40 PSI ml/min. Air 60 PSI ml/min.  
 DETECTOR E.C. T.C. F.I.D. & X.I.D. 11"  
 Scavenger Rate ml/min.  
 Sens. Rec. Range 1000000  
 SAMPLE 2 BULK G. Size 2 mm  
 Solvent. Concn.



RUN # 15 APR/29/81 15:02:30  
 ID 1 NO CALIB PEAKS FOUND

AREA%		RT	AREA TYPE	AR/HT	AREA%
8.19		99	PB	0.006	1.217
0.67		8036	PB	0.115	98.783

TOTAL AREA= 8135  
 MUL. FACTOR= 1.0000E+00

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CMEA, Location Lexington, N.C., Job No. 7135.21

Injection Date 4-29-81, Time .410, Instrument ID VARIAN  
3700  
 Recorder/Printout Reference No. 1, Recorder ID HP 3390A  
 Purpose of Run C, -C<sub>6</sub> HYDROCARBON ANALYSIS

Sample Description SAMPLE NO 2 BULB A 150°

## GC CONDITIONS


Amount Injected 2 mL, Inj. Port or Sample Loop Used 2mL Loop  
 Detector Used: FID X, ECD \_\_, FPD \_\_, TCD \_\_ (Current \_\_)  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase \_\_, Solid Phase PORAPAK Q,  
 Length 6', O.D. 1/8", I.D. \_\_, Material S.S.  
 Temperature: Injector 120 °C, Oven 120 °C, Detector 150 °C  
 Temperature Program ISOTHERMAL

## SAMPLE RUN

Sampling Method GRAB 300ML (520°F)

RT	Area	Peak Height	Amount (ppm)	Component
0.66	8176		1.6	C <sub>2</sub>

Name of Operator John Holm, Date 10-21 1981



STOP

RUN # 16                    APR/29/81 15:22:18  
ID 1  
NO CALIB PEAKS FOUND

AREA%			AREA%	
RT	AREA	TYPE	AR/HT	AREA%
0.17	943	PB	0.042	1.269
0.66	8176	PB	0.115	18.959
4.66	65213	PB	0.200	87.732

TOTAL AREA= 74332  
MUL FACTOR= 1.0000E+00

Operator...T. HOLLM	Date...4-29-81
Column No.....	Length...6'
Coating.....	Dia.... $\frac{1}{8}$ "
Support...P.P.R.A.K. Q.	Concn...Mesh. 40/100
TEMP: Col: Init...120 °C	Final.120 °C
Rate..... °C/min.	Inj.120 °C
CARRIER GAS...He	Rate...8.0 ml./min.
Pressures: Inlet	Outlet.....
Hydrogen: 40. PSI	Air.6.0. PSI..... ml/min.
DETECTOR E.C.	T.C. F.I.D. & $\times 10^{-11}$ mv.
Scavenger.....	Rate..... ml./min.
Sens...14.02	Rec.Range..... mv.
SAMPLE 2 BULB A	Size.2.0ML
Solvent.....	Concn.....

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CMEA, Location Lexington, N.C., Job No. 7135.21

Injection Date 4-29-81, Time 15:10:35, Instrument ID VARIAN 3700  
 Recorder/Printout Reference No. 17, Recorder ID HP 3390A  
 Purpose of Run C<sub>1</sub>-C<sub>6</sub> HYDROCARBON ANALYSIS

Sample Description Sample No. 2 2123 1408

## GC CONDITIONS

Amount Injected 2 mL, Inj. Port or Sample Loop Used 2mL Loop  
 Detector Used: FID X, ECD  , FPD  , TCD   (Current  )  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase  , Solid Phase PORAPAK Q,  
 Length 6', O.D. 1/8", I.D.  , Material S.S.  
 Temperature: Injector 120 °C, Oven 120 °C, Detector 250 °C  
 Temperature Program ISO THERMAL

## SAMPLE RUN

Sampling Method GRAB 300mL (520°F)

RT	Area	Peak Height	Amount (ppm)	Component
.68	7050		1.8	C <sub>2</sub>

Name of Operator John Holm, Date 10-21 1981

Operator: T. HOLM ..... Date: 4-29-81  
 Column No. ..... Length: 6' ..... Dia.: 1/8"  
 Coating ..... Conc. ....  
 Support: P.R.R.A.P.A.K. Q. .... Mesh: 80/100  
 TEMP: Col: Init. 120 °C Final. 120 °C  
 Rate: °C/min. Det. 250 °C Inj. 120 °C  
 CARRIER GAS: He ..... Rate: 24.4 ml./min.  
 Pressures: Inlet ..... Outlet .....  
 Hydrogen: 4.0 PSI ..... Air: 6.0 PSI ..... ml/min.  
 DETECTOR E.C. ..... T.C. ..... FID, R.K.I.D.  
 Scavenger: ..... Rate: ..... ml/min.  
 Sens. ..... Rec. Range: ..... mV  
 SAMPLE: 2 ..... KULB.A. (408) Size: 2.0 M.L.  
 Solvent: ..... Concn. ....

RUN #: 17 APR/29/81 15:43:05  
 ID: 1  
 NO CALIB PEAKS FOUND

AREA%	RT	AREA TYPE	AR/HT	AREA%
	0.68	9050 D PB	0.143	100.000

TOTAL AREA= 9050  
 MULT. FACTOR= 1.0000E+00

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CMEA, Location LEXINGTON, N.C., Job No. 7135.21

Injection Date 4-29-81, Time 17:54:50, Instrument ID VARIAN 3700  
 Recorder/Printout Reference No. 17, Recorder ID HP 3390A.  
 Purpose of Run C<sub>1</sub>-C<sub>6</sub> HYDROCARBON ANALYSIS

Sample Description SAMPLE NO. 13 BULB A 1.50

## GC CONDITIONS

Amount Injected 2 mL, Inj. Port or Sample Loop Used 2mL Loop  
 Detector Used: FID X, ECD  , FPD  , TCD   (Current  )  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase  , Solid Phase PORAPAK Q,  
 Length 6', O.D. 1/8", I.D.  , Material S.S.  
 Temperature: Injector 120 °C, Oven 120 °C, Detector 150 °C  
 Temperature Program ISO THERMAL

## SAMPLE RUN

Sampling Method GRAB 300ML (≤17 °F)

RT min	Area	Peak Height	Amount (ppm)	Component
.24	4944		1.4	C <sub>1</sub>
.69	5376		1.0	C <sub>2</sub>

Name of Operator Torsten Holm, Date 10-21 1981

Operator: J. Holm Date: 4-29-81  
 Column No. .... Length: 6' Dia.: 1/8" Concn. ....  
 Coating .....  
 Support: PEEK Q. .... Mesh: 80/100  
 TEMP: Col: Int. 120 °C Final. 120 °C  
 Rate: °C/min. Det. 250 °C Inj. 120 °C  
 CARRIER GAS: H<sub>2</sub> .... Rate: 24 ml./min.  
 Pressures: Inlet ..... Outlet .....  
 Hydrogen: 40 psi ... ml/min. Air: 60 psi ... ml/min.  
 DETECTOR E.C. .... I.C. .... FID & K. ID = 1"  
 Scavenger: .... Rate: .... ml/min.  
 Sens. .... Rec.Range: .... Inv.  
 SAMPLE: 3 BULK 16.30 Size: 2.0 ml  
 Solvent: .... Concn. ....

24  
 69  
 PY . 6 48  
 12'78  
 S1

RUN #: 19 APR/29/81 17:04:58  
ID: 1

ESTD	RT	AREA	TYPE	CALS	AMOUNT
	0.24	4994	PB	1R	2.0677E+08

TOTAL AREA= 4994  
MUL FACTOR= 1.0000E+00

RUN #: 19 APR/29/81 17:04:58  
ID: 1

AREA%	RT	AREA	TYPE	AR/HT	AREA%
	0.24	4994	PB	0.120	48.158
	0.69	5376	PB	0.139	51.842

TOTAL AREA= 10370  
MUL FACTOR= 1.0000E+00

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CMFA, Location Lexington, N.C., Job No. 7735.21

Injection Date 4-29-81, Time 11:45:50, Instrument ID VARIAN 3700  
 Recorder/Printout Reference No. 40, Recorder ID HP 3390A  
 Purpose of Run C<sub>1</sub>-C<sub>6</sub> HYDROCARBON ANALYSIS

Sample Description Sample No. 2 Blue 100 ml

## GC CONDITIONS

Amount Injected 2 mL, Inj. Port or Sample Loop Used 2mL Loop  
 Detector Used: FID X, ECD  , FPD  , TCD   (Current  )  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase  , Solid Phase PORAPAK Q,  
 Length 6', O.D. 1/8", I.D.  , Material S.S.  
 Temperature: Injector 120 °C, Oven 120 °C, Detector 250 °C  
 Temperature Program ISOTHERMAL


## SAMPLE RUN

Sampling Method GRAB 300ML (57 °F)

RT	Area	Peak Height	Amount (ppm)	Component
•36	5612		2.1	C <sub>1</sub>
.68	4881		1.0	C <sub>2</sub>

Name of Operator John Holm, Date 10-21 1981

Operator J. Holm Date 4-21-81  
 Column No. Length 6' Dia.  $\frac{1}{8}$ "  
 Coating Support P.D.R.A.R.A.K. Q. Concn.  
 Mesh 80/100  
 TEMP: Col. Init. 120. °C Final. 120. °C  
 Rate ..... °C/min. Det. R.S.D. °C Inl. 120. °C  
 CARRIER GAS H<sub>2</sub> Rate 8 x 10<sup>-4</sup> ml/min.  
 Pressures: Inlet Outlet  
 Hydrogen 40. PSI ml/min. Air 60. PSI ml/min.  
 DETECTOR E.C. T.C. F.I.D. 8 x 10<sup>-4</sup>  
 Scavenger Rate ml/min.  
 Sens. Rec. Range MV.  
 SAMPLE 3 B.W.L.B. G. 1640. SIZE 2.0 ML  
 Solvent. Concen.



STOP

RUN # 20 APR/29  
ID 1  
NO CALIB PEAKS FOUND

AREA%	RT	AREA	TYPE	AR/HT	AREA%
	8.26	5612	BB	0.105	53.483
	8.68	4881	PB	0.103	46.517

TOTAL AREA= 18493  
MUL FACTOR= 1.0000E+00

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client IMFA, Location LEXINGTON, NC, Job No. 7735.3

Injection Date 4-29-71, Time 17:45:45, Instrument ID VARIAN 3700  
 Recorder/Printout Reference No. 31, Recorder ID HP 3317A  
 Purpose of Run C<sub>1</sub>-C<sub>8</sub> HYDROCARBON ANALYSIS

Sample Description SAMPLE NO. 3 FILE A 1.31

## GC CONDITIONS

Amount Injected 2 μl, Inj. Port or Sample Loop Used 2 ml loop  
 Detector Used: FID X, ECD  , FPD  , TCD   (Current  )  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase  , Solid Phase PREGELATIN,  
 Length 6', O.D. 1/8", I.D.  , Material  .  
 Temperature: Injector 120 °C, Oven 120 °C, Detector 250 °C  
 Temperature Program ISOTHERMAL

## SAMPLE RUN

Sampling Method GRAB 20 ml (511 °F)

RT	Area	Peak Height	Amount (ppm)	Component
1.24	5322		2.0	C <sub>1</sub>
1.67	7818		1.5	C <sub>2</sub>

Name of Operator TOM STRAIN, Date 5-21 1971



Operator... <b>T. HOLM</b>	Date... <b>4-29-81</b>
Column No.....	Length... <b>6'</b>
Coating.....	Dia. <b>1/8"</b>
Support... <b>PORARAK</b>	Concn.....
TEMP: Col:	Init. .... <b>120</b> °C
	Final.... <b>120</b> °C
Rate.....	<b>°C/min.</b>
CARRIER GAS... <b>H2</b>	Rate. <b>.24 ml./min.</b>
Pressures: Inlet.....	Outlet.....
Hydrogen... <b>40 psi</b>	<b>mm/min.</b>
DETECTOR E.C.....	Air/ <b>60</b> P.S.I. .... <b>mm/min.</b>
Sens.....	<b>FID. 10^-11</b>
Scavenger.....	Rate. .... <b>mv.</b>
SAMPLE... <b>3 RUBB</b>	Rec.Range. .... <b>mv.</b>
Solvent.....	Concn.....

RUN # **21**                    APR/29/81 17:45:45  
ID **1**

ESTD	RT	AREA	TYPE	CALC	AMOUNT
	<b>6.24</b>	<b>5322</b>	<b>BB</b>	<b>1R</b>	<b>2.2835E+08</b>

TOTAL AREA= **5322**  
MUL FACTOR= **1.0000E+00**

RUN # **21**                    APR/29/81 17:45:45  
ID **1**

AREA%	RT	AREA	TYPE	AR/Ht	AREA%
	<b>8.24</b>	<b>5322</b>	<b>BB</b>	<b>0.119</b>	<b>49.582</b>
	<b>8.69</b>	<b>7818</b>	<b>BB</b>	<b>0.144</b>	<b>59.498</b>

TOTAL AREA= **13140**  
MUL FACTOR= **1.0000E+00**

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CNAEA, Location Englewood, NJ, Job No. 1735.21

Injection Date 4-29-81, Time 12:04:30, Instrument ID UAR100  
 Recorder/Printout Reference No. 22, Recorder ID HP 3370A  
 Purpose of Run CALIBRATION (FINAL)

Sample Description SANTY I MULTI-COMPONENT MIXTURE  
C<sub>1</sub>-C<sub>6</sub> IN PARAFIN ~15 ppm ± 10% in N<sub>2</sub>

## GC CONDITIONS


Amount Injected 2μl, Inj. Port or Sample Loop Used 2m LNP  
 Detector Used: FID X, ECD  , FPD  , TCD   (Current  )  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase  , Solid Phase POROSIL C,  
 Length 6', O.D. 1/8", I.D.  , Material Si  
 Temperature: Injector 120 °C, Oven 120 °C, Detector 250 °C  
 Temperature Program ISOTHERMAL

## SAMPLE RUN

Sampling Method N/A

RT min.	Area	Peak Height	Amount (μg)	Component
0.26	37575		15.1	C <sub>1</sub>
0.58	68114		14.0	C <sub>2</sub>
1.45	116060		15.6	C <sub>3</sub>
4.20	138750		15.2	C <sub>4</sub>
12.52	171960		15.6	C <sub>5</sub>

Name of Operator John Hagan, Date 10-21 1981



RUN #: 22 APR/29/81 18:04:30  
 ID: 1  
 ESTD  

RT	AREA TYPE	CAL#	AMOUNT
0.58	68114 D PB	2	4.8627E+09
1.45	116060 PB	3	1.4412E+10
4.20	138750 BB	4	2.0139E+10

TOTAL AREA= 322930  
 MUL FACTOR= 1.0000E+00

## GAS CHROMATOGRAPH OPERATING CONDITIONS AND FIELD LOG

Client CMA, Location LEXINGTON, N.C., Job No. 7735.21

Injection Date 4-29-81, Time 14:24:50, Instrument ID VARIAN 3700  
 Recorder/Printout Reference No. 23, Recorder ID HP3370A  
 Purpose of Run CALIBRATION (FINAL)

Sample Description Scotny I. multi-component mixture  
C<sub>1</sub>-C<sub>5</sub> in paraffine 0.15 ppm ± 10% by wt.

## GC CONDITIONS


Amount Injected 2 μl, Inj. Port or Sample Loop Used 25 (TR)  
 Detector Used: FID X, ECD  , FPD  , TCD   (Current  )  
 Detector Attenuation 8, Amplifier or Range 10<sup>-11</sup>  
 Column: Liquid Phase  , Solid Phase P-PAPACK Q,  
 Length 6', O.D. 1/8", I.D.  , Material SS  
 Temperature: Injector 120 °C, Oven 120 °C, Detector 150 °C  
 Temperature Program ISOTHERMAL

## SAMPLE RUN

Sampling Method N/A

RT min.	Area	Peak Height	Amount (ppm)	Component
0.36	345.4		15.1	C <sub>1</sub>
0.59	68146		14.6	C <sub>2</sub>
1.46	115630		15.6	C <sub>3</sub>
4.21	138910		15.2	C <sub>4</sub>
			15.6	C <sub>5</sub>

Name of Operator J. H. L., Date 4-21-81, 1981



RUN # 23 APR/29/81 18:24:58  
 ID 1

ESTD	RT	AREA	TYPE	CALB	AMOUNT
	0.59	68146	PB	2	4.8649E+09
	1.46	115636	PB	3	1.4358E+10

TOTAL AREA= 183770  
 MUL FACTOR= 1.0000E+00

RUN # 23 APR/29/81 18:24:58  
 ID 1

AREAN	RT	AREA	TYPE	AR/HT	AREAX
	0.25	39514	BB	0.871	18.989
	0.59	68146	PB	0.865	18.815
	1.46	115636	PB	0.166	21.924
	4.21	138918	I PB	0.427	38.352

TOTAL AREA= 362200  
 MUL FACTOR= 1.0000E+00

5.7 TOTAL CHROMOTOGRAFABLE ORGANICS (TCO), GRAVIMETRIC ORGANICS (GRAV),  
IR SPECTRA, AND GAS CHROMATOGRAPHY/MASS SPECTROMETRY (GC/MS)



## DATA REPORTING FORM

CUSTOMER CMEA DATE July 31, 1981  
 CUSTOMER CONTRACT NO. 307736.22 ACUREX CONTRACT NO. A81-05-031  
 RESULTS REPORT TO L. Waterland TELEPHONE \_\_\_\_\_  
 ADDRESS \_\_\_\_\_  
Burlington 28.78 dscm

SAMPLE ID (CUSTOMER)	Probe	10u + 3u	1u+Filter	XAD	OMC	Imp I	Imp 2+3	Bottom Ash	Fuel	
SAMPLE ID (LAB)	761	766	768	760	780	762	763	765	690	
PARAMETER										UNITS
GRAV Aliquot	< 4	< 4	6	7	< 4	-	-	-	-	mg
GRAV (Blank)	< 4	< 4	< 4	< 4	< 4	-	-	-	-	mg
GRAV	< 0.2	< 0.2	0.4	0.3	< 0.1	-	-	-	-	mg/dscm
TCO Aliquot	-	-	-	(120) 1.7*	< 0.1	-	-	-	-	mg
TCO (Blank)	-	-	-	(120) 1.4*	< 0.1	-	-	-	-	mg
TCO	-	-	-	< 0.01	< 0.003	-	-	-	-	mg/dscm
Mercury Aliquot	< 1	< 1	< 1	< 1	-	< 1	< 1	< 1	< 1	ug/l
Mercury (Blank)	< 1	< 1	< 1	< 1	-	< 1	< 1	< 1	< 1	mg/dscm
Mercury	<0.00003	<0.00004	<0.00005	<0.0002	-	<0.00006	<0.00004	<0.05mg/kg	<0.05mg/kg	ug/l
Antimony Aliquot	-	-	-	-	-	-	< 10	-	-	ug/l
Antimony	-	-	-	-	-	-	< 0.0004	-	-	mg/dscm
Arsenic Aliquot	-	-	-	-	-	-	< 10	-	-	ug/l
Arsenic	-	-	-	-	-	-	< 0.0004	-	-	mg/dscm

\*Corrected for resin contamination -- uncorrected value in parentheses

ANALYST \_\_\_\_\_

REVIEWER \_\_\_\_\_



## IR REPORT

SAMPLE: 766 Burlington 10u &amp; 3u

Wave Number ( $\text{cm}^{-1}$ )	Intensity	Assignment	Comments
		No Peaks	



## IR REPORT

SAMPLE: 759 Burlington Filter Blank

Wave Number ( $\text{cm}^{-1}$ )	Intensity	Assignment	Comments
		No Peaks	



## IR REPORT

SAMPLE: 780 Burlington OMC

Wave Number (cm <sup>-1</sup> )	Intensity	Assignment	Comments
		No Peaks	



## DATA REPORTING FORM

CUSTOMER CMEA DATE July 31, 1981  
CUSTOMER CONTRACT NO. 307736.22 ACUREX CONTRACT NO. A81-05-031  
RESULTS REPORT TO L. Waterland TELEPHONE \_\_\_\_\_  
ADDRESS \_\_\_\_\_  
Burlington 28.78 dscm


SAMPLE ID (CUSTOMER)	Probe	10u + 3u	1u+Filter	XAD	OMC						
SAMPLE ID (LAB)	761	766	768	760	780						
PARAMETER											UNITS
Naphthalene Aliquot	< 1	< 1	< 1	87	< 1						ng
Acenaphthylene Aliquot	< 1	< 1	< 1	8	< 1						ng
Phenanthrene Aliquot	< 1	< 1	< 1	7	< 1						ng
Fluoranthene Aliquot	< 1	< 1	< 1	2	< 1						ng
Pyrene Aliquot	< 1	< 1	< 1	4	< 1						ng
Phenol Aliquot	< 1	< 1	< 1	10	15						ng
Napthalene :	< 40	< 60	< 70	3300	< 30						ng/dscm
Acenaphthylene	< 40	< 60	< 70	300	< 30						ng/dscm
Phenanthrene	< 40	< 60	< 70	300	< 30						ng/dscm
Fluoranthene	< 40	< 60	< 70	80	< 30						ng/dscm
Pyrene	< 40	< 60	< 70	200	< 30						ng/dscm
Phenol	< 40	< 60	< 70	380	520						ng/dscm
Others with a detection < 40	< 60	< 70	< 40	< 30							ng.

Limit of 1 ng

ANALYST \_\_\_\_\_

REVIEWER \_\_\_\_\_

## **5.8 RADIOMETRIC ANALYSIS RESULTS**



## SAFETY SPECIALISTS, Inc.

3284 F Edward Avenue, Santa Clara, California 95050 • Telephone (408) 988-1111

### ASSAY REPORT

Acurex Corporation  
Attn: Mr. Larry Waterland  
485 Clyde Avenue  
Mountain View, California 94042

Date: August 13, 1981

Date Samples Received: 6/29/81

Customer Order No.: RB59185A, Rel. 15

<u>SSI No.</u>	<u>Client Description</u>	<u>Activity*</u>	
		Gross Alpha pCi/g	Gross Beta pCi/g
81228H	A81-05-030-766	53.3 ± 37.2	328.1 ± 98.3

Pamela S. Shreve


Analyst: Pamela S. Shreve

J. Noble

Approved: T. C. Noble, Director  
Safety and Health Services Division

\*The ± values are the two sigma Poisson standard deviation of the counting error.

The ≤ values are equal to or less than three sigma of the counting error.



## SAFETY SPECIALISTS, Inc.

3284 F Edward Avenue, Santa Clara, California 95050 • Telephone (408) 988-1111

### ASSAY REPORT

Acurex Corporation  
Attn: Mr. Larry Waterland  
485 Clyde Avenue  
Mountain View, California 94042

Date: August 13, 1981

Date Samples Received: 6/29/81

Customer Order No.: RB59185A, Rel. 15

<u>SSI No.</u>	<u>Client Description</u>	Activity*	
		Gross Gamma <u>pCi/L</u>	Gross Gamma <u>pCi/g</u>
81228H	A81-05-030-766	530	± 1761

Pamela S. Shreve

Analyst: Pamela S. Shreve

T. C. Noble

Approved: T. C. Noble, Director  
Safety and Health Services Division

\*The ± values are the two sigma Poisson standard deviation of the counting error.

The ≤ values are equal to or less than three sigma of the counting error.

**5.9 BIOASSAY REPORTS**



BIONETICS

5516 Nicholson Lane, Kensington, Maryland 20795 301 881-5600 • Telex 29-2369

November 20, 1981

Mr. Roy Belletto  
Acurex Corporation  
485 Clyde Avenue  
Mountain View, CA 94042

Dear Mr. Belletto:

Enclosed are five copies each of the final reports for the three samples from the "Burl" sampling site submitted for testing and evaluation in IERL-EPA Level 1 environmental assessment bioassays. All studies were conducted and evaluated under IERL-EPA Level 1 guidelines. Reports for the "EA-1" and "EA-2" sampling sites will be sent the week of November 23, 1981.

No technical or interpretative problems were encountered with these samples except for an insufficient amount of the XAD extract sample to assay up to the recommended maximum applicable dose (MAD) based upon weight of organics per plate. Ames testing was modified by eliminating less responsive tester strains. Adequate evaluations were achieved using this modified testing strategy.

If you have any questions or comments concerning the reports, please feel free to contact me at (301)881-5600, extension 536.

Sincerely,

Robert R. Young  
Environmental Assessment Section  
Department of Molecular Toxicology

RRY/mg

Enclosures: Reports:

Ames	5881, 5885, 5888
CHO	5881
RAM	5885, 5888
Rodent	5888

**BIOASSAY SUMMARY TABLE**

Technical Directive or Project No. LBI PROJECT NUMBER 22064

Contract No. ACUREX SUBCONTRACT RB59178A, RELEASE NUMBER 3, 'BURL' SITE

Sample Identification	Health Effects Tests					Ecological Effects Tests							
	AMES Salmonella*	RAM Cytotoxicity	CHO Cytotoxicity	Rodent Toxicity	Fish	Fresh Water	Marine	Aquatic	Terrestrial	Plant Stress Ethylene	Root Elongation	Insect Toxicity	Notes
A81-05-031-760  (BURL XAD EXTRACT)	M		M										
A81-05-031-766  (BURL 10+3+1+FILTER)	ND	L											
A81-05-031-765  (BURL FLYASH)	ND	L/ND		ND									

ND = No Detectable Toxicity

L = Low Toxicity

M = Moderate Toxicity

H = High Toxicity

\* Evaluation of Ames Salmonella test is based upon mutagenicity and not toxicity.

LBI-0468 R 11/80

DEFINITION OF TOXICITY CATEGORIES FOR HEALTH EFFECTS ASSAYS

Assay <sup>a</sup>	Activity Measured <sup>b</sup>	Sample Type <sup>c</sup>	MAD <sup>d</sup>	Units	Range of Concentration or Dosage			
					High	Moderate	Low	Not Detectable (ND)
Ames	MEC (mutagenesis)	S AL, NAL E	5 200 5000	mg/plate $\mu$ l/plate L/plate	<0.05 <2 <50	0.05-0.5 2-20 50-500	0.5-5 20-200 500-5000	ND at >5 ND at >200 ND at >5000
RAM	EC <sub>50</sub> (lethality)	S AL NAL E	1 600 20 1000	mg/ml $\mu$ l/ml $\mu$ l/ml L/ml	<0.01 <6 <0.2 <10	0.01-0.1 6-60 0.2-2 10-100	0.1-1 60-600 2-20 100-1000	ND at >1 ND at >600 ND at >20 ND at >1000
CHO	EC <sub>50</sub> (lethality)	S AL NAL E	1 600 20 1000	mg/ml $\mu$ l/ml $\mu$ l/ml L/ml	<0.01 <6 <0.2 <10	0.01-0.1 6-60 0.2-2 10-100	0.1-1 60-600 2-20 100-1000	ND at >1 ND at >600 ND at >20 ND at >1000
WAT	LD <sub>50</sub> (lethality and toxic signs)	S AL, NAL	5 5	gm/kg ml/kg	<0.05 <0.05	0.05-0.5 0.05-0.5	0.5-5 0.5-5	ND at >5 ND at >5

<sup>a</sup>Standard test abbreviations are as follows:

Ames: Ames Salmonella/microsome mutagenesis assay

RAM: Rabbit alveolar macrophage cytotoxicity assay

CHO: Rodent cell clonal toxicity assay

WAT: Acute in vivo test in rodents (whole animal test)

<sup>b</sup>Standard abbreviations for measured endpoints are as follows:

MEC: Minimum effective concentration

EC<sub>50</sub>: Calculated concentration expected to produce effect in 50 percent of population

LD<sub>50</sub>: Calculated dose expected to kill 50 percent of population

<sup>c</sup>S = Solid, AL = Aqueous liquid, NAL = Nonaqueous liquid, E = Extract and/or concentrate of unknown organic content (use equivalent volume of SASS train gas)

<sup>d</sup>MAD = Maximum applicable dose

TABLE

HEALTH EFFECTS CRITICAL DATA SUMMARY FORM<sup>a</sup>

Contract No. ACUREX SUBCONTRACT Technical Directive or Project No. LBI PROJECT NO. 22064 Site Sampled BURL  
 RB59178A, RELEASE 3

Sample Identification	Ames Mutagenicity [MEC] <sup>b</sup>	CHO Clonal Toxicity [EC50] <sup>c</sup>	RAM Cytotoxicity [EC50] <sup>c</sup>			Rodent Toxicity	
			Viability	Viability Index	ATP	ATP/Per 10 <sup>6</sup> Cells	LD50 <sup>d</sup>
A81-05-031-760  (BURL XAD EXTRACT)	80 µg	18.4 µg					
A81-05-031-766  (BURL 10+3+1+FILTER)	> 5 mg		>1000 µg	500 µg	360 µg	~1000 µg	
A81-05-031-765  (BURL FLYASH)	> 5 mg		>1000 µg	>1000 µg	~1000 µg	>1000 µg	>5 g

<sup>a</sup>The assays, observed parameters and evaluation criteria are presented in IERL-RTP Procedures Manual; Level 1 Environmental Assessment Biological Tests, [EPA Contract No. 68-02-2681, Litton Bionetics, Inc., Kensington, Md., September 1980, in press.]

<sup>b</sup>MEC: Minimum Effective Concentration - Lowest concentration for any tester strain giving a mutagenic response.

<sup>c</sup>EC<sub>50</sub>: Effective concentration that reduces the observed parameter to 50 percent of the appropriate negative control.

<sup>d</sup>LD<sub>50</sub>: The dose lethal to 50 percent of treated animals.

<sup>e</sup>Toxic signs are identified in a numbered list in the Level 1 manual. Only the number is reported here.

NOTE:Doses reported as per plate for the Ames assay, per ml for the CHO and RAM assays, and per kg for the Rodent Toxicity assay.



EG&G BIOMICS, 790 MAIN STREET, WAREHAM, MASSACHUSETTS 02571 • TEL. (617) 295-2550

RECEIVED SEP 3 1981

September 2, 1981

Ms. Teri Lannon  
Acurex Corporation  
485 Clyde Avenue  
Mountain View, CA 94042

Dear Ms. Lannon:

Enclosed please find three (3) copies of our report:

"The Acute Toxicity of Five Samples To Freshwater Organisms" - Report #BW-81-7-966

I trust you shall find this report both complete and satisfactory. If you should have any questions or comments, please contact me.

Sincerely,

A handwritten signature in black ink, appearing to read "Gerald A. LeBlanc".

Gerald A. LeBlanc  
Aquatic Toxicologist

GAL:jeb

Enclosure

Estimated LC50 values, confidence intervals and no discernible effect concentrations for D. magna and P. promelas exposed to Acurex samples.

Sample	Species	LC50 (95% confidence interval) <sup>a</sup>				No discernible effect concentration (mg/l)
		24 hour	48 hour	72 hour	96 hour	
A81-05-031-765 (bottom ash)	<u>D. magna</u>	>1000	740 <sup>b</sup> (620-940)	-	-	220
	<u>P. promelas</u>	>1000	>1000	>1000	>1000	1000

a  
mg/l.

b  
Estimated by the moving average angle method.

Calculated 5-day EC50's and EC95's for Selenastrum capricornutum exposed to the five samples provided by the Acurex Corporation. The EC values were based on decrease of cell numbers on exposed cultures as compared to the control. (The 95% confidence limits are in parentheses). Concentrations were based on microliters of A80-09-023-24 per liter of algal growth medium and milligrams of the other samples per liter of algal growth medium.

Sample	EC50	EC95
A81-05-031-765	169(118-242)	314(195-506)

**TECHNICAL REPORT DATA**  
*(Please read Instructions on the reverse before completing)*

1. REPORT NO. EPA-600/7-87-010b	2.	3. RECIPIENT'S ACCESSION NO.	
4. TITLE AND SUBTITLE Environmental Assessment of a Wood-Waste-Fired Industrial Firetube Boiler; Volume II. Data Supplement		5. REPORT DATE March 1987	
7. AUTHOR(S) R. DeRosier and L. R. Waterland		6. PERFORMING ORGANIZATION CODE	
9. PERFORMING ORGANIZATION NAME AND ADDRESS Acurex Corporation P. O. Box 7555 Mountain View, California 94039		8. PERFORMING ORGANIZATION REPORT NO. TR-83-123/ESD	
12. SPONSORING AGENCY NAME AND ADDRESS EPA, Office of Research and Development Air and Energy Engineering Research Laboratory Research Triangle Park, NC 27711		10. PROGRAM ELEMENT NO.	
		11. CONTRACT/GANT NO. 68-02-3188	
13. TYPE OF REPORT AND PERIOD COVERED Final; 1/81 - 3/84		14. SPONSORING AGENCY CODE EPA/600/13	
15. SUPPLEMENTARY NOTES AEERL project officer is Robert E. Hall, Mail Drop 65, 919/541-2477. Volume I contains the technical results of the study.			
16. ABSTRACT The report gives emission results from field tests of a wood-waste-fired industrial firetube boiler. Emission measurements included: continuous monitoring of flue gas emissions; source assessment sampling system (SASS) sampling of the flue gas with subsequent laboratory analysis of samples to give total flue gas organics in two boiling point ranges, compound category information within these ranges, specific quantitation of the semivolatile organic priority pollutants, and flue gas concentrations of 65 trace elements; Method 5 sampling for particulates; controlled condensation system (CSS) sampling for SO <sub>2</sub> and SO <sub>3</sub> ; and grab sampling of boiler bottom ash for trace element content determinations. Flue gas CO emissions were quite variable during the tests, and often quite high (attributed to the high excess air level at which the unit operated). NO <sub>x</sub> emissions were relatively high for a wood-fired boiler, although the fuel nitrogen content was relatively high for a wood fuel. SO <sub>2</sub> and SO <sub>3</sub> emissions were less than 10 ppm, in keeping with the low sulfur content of the wood-waste fuel. Total organic emissions from the boiler were 5.7 mg/dscm, about 90% of which consisted of volatile compounds. Emission levels of five polycyclic organic matter species and phenol were quantitated: except for naphthalene, all were emitted at less than 0.4 microgram/dscm.			
17. KEY WORDS AND DOCUMENT ANALYSIS			
a. DESCRIPTORS	b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group	
Pollution Wood Wastes Fire Tube Boilers Flue Gases Assessments Particles	Sulfur Oxides Nitrogen Oxides Trace Elements Carbon Monoxide Organic Compounds Polycyclic Compounds Phenols	Pollution Control Stationary Sources Environmental Assessment Particulate	13B    07B 11L 13A    06A 21B 14B    07C 14G
18. DISTRIBUTION STATEMENT Release to Public		19. SECURITY CLASS ( <i>This Report</i> ) Unclassified	21. NO. OF PAGES 114
		20. SECURITY CLASS ( <i>This page</i> ) Unclassified	22. PRICE