


Research and Development



Performance Evaluation of Existing Aerated Lagoon System at Bixby, Oklahoma



RESEARCH REPORTING SERIES

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into nine series. These nine broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and a maximum interface in related fields. The nine series are:

1. Environmental Health Effects Research
2. Environmental Protection Technology
3. Ecological Research
4. Environmental Monitoring
5. Socioeconomic Environmental Studies
6. Scientific and Technical Assessment Reports (STAR)
7. Interagency Energy-Environment Research and Development
8. "Special" Reports
9. Miscellaneous Reports

This report has been assigned to the ENVIRONMENTAL PROTECTION TECHNOLOGY series. This series describes research performed to develop and demonstrate instrumentation, equipment, and methodology to repair or prevent environmental degradation from point and non-point sources of pollution. This work provides the new or improved technology required for the control and treatment of pollution sources to meet environmental quality standards.

EPA-600/2-79-014
March 1979

PERFORMANCE EVALUATION OF
EXISTING AERATED LAGOON SYSTEM
AT BIXBY, OKLAHOMA

by

George W. Reid
Bureau of Water and Environmental Resources Research
and
Leale Streebin
School of Civil Engineering and Environmental Science
University of Oklahoma
Norman, Oklahoma 73019

Grant No. R803916

Project Officer

Ronald F. Lewis
Wastewater Research Division
Municipal Environmental Research Laboratory
Cincinnati, Ohio 45268

MUNICIPAL ENVIRONMENTAL RESEARCH LABORATORY
OFFICE OF RESEARCH AND DEVELOPMENT
U.S. ENVIRONMENTAL PROTECTION AGENCY
CINCINNATI, OHIO 45268

DISCLAIMER

This report has been reviewed by the Municipal Environmental Research Laboratory, U. S. Environmental Protection Agency, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the U. S. Environmental Protection Agency, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

FOREWORD

The Environmental Protection Agency was created because of increasing public and government concern about the dangers of pollution to the health and welfare of the American people. The complexity of the environment and the interplay between its components require a concentrated and integrated attack on the problem.

Research and development is that necessary first step in problem solution and it involves defining the problem, measuring its impact, and searching for solutions. The Municipal Environmental Research Laboratory develops new and improved technology and systems for the prevention, treatment, and management of wastewater and solid and hazardous waste pollutant discharges from municipal and community sources, for the preservation and treatment of public drinking water supplies, and to minimize the adverse economic, social, health, and aesthetic effects of pollution. This publication is one of the products of that research; a most vital communications link between the researcher and the user community.

As part of these activities, this case history report was prepared to make available to the sanitary engineering community a full year of operating and measured performance data for a two-celled, aerated wastewater treatment lagoon system.

Francis T. Mayo, Director
Municipal Environmental Research
Laboratory

ABSTRACT

The University of Oklahoma School of Civil Engineering and Environmental Science research group in collaboration with INCOG & BIXBY, have studied a well designed, well operated two cell aerated wastewater treatment lagoon system. The study involved four seasons and nineteen study parameters. The data was treated to statistical analysis, using a SPSS multiple regression, and to normative analytical expression.

The lagoon exhibited an overall BOD₅ removal efficiency of 92%, but was only totally in compliance for 7 months of the year. The use of several kinetic models and regression models were not very satisfactory though the temperature coefficient (θ) were in substantial agreement with Adams and Eckenfelder and other reputed values.

This report was submitted in fulfillment of Grant No. R803-916 by the University of Oklahoma under the partial sponsorship of the U.S. Environmental Protection Agency. This report covers the Bixby lagoon operating period of January 1976 through December 1976.

CONTENTS

Disclaimer	ii
Foreword	iii
Abstract	iv
Figures	vi
Tables	viii
Acknowledgements	xi
1. Introduction	1
Background	1
Significance of project	1
2. Conclusions	5
3. Recommendations	6
4. Approach	7
Primary objective	7
Secondary objective	7
Scope	8
5. Project Description	10
Description of the city of Bixby and its lagoon system	10
Description of the experimental investigation	12
Description of statistical analysis techniques	15
6. Project Generated Data	17
Data generated on a year-round basis	17
Data generated on a seasonal basis	17
Data generated on a monthly basis	17
7. Project Data Evaluation and Analysis	44
Results and analysis	46
References	56
Appendices	
A. Summary of a Comparative Study of Parameters Used for Measuring Waste Treatment Lagoon Performance	58
B. Results of Regression Analysis	61
C. Operational Problems	92
D. Daily Data	93

FIGURES

<u>Number</u>	<u>Page</u>
1	Flow schematic of Bixby lagoon system 13
2	Seasonal mid-point water temperature change at Bixby lagoon, 1976 21
3	Seasonal influent flow rate change at Bixby lagoon, 1976 22
4	Seasonal influent BOD ₅ change at Bixby lagoon, 1976 . 23
5	Seasonal mid-point BOD ₅ change at Bixby lagoon, 1976 24
6	Seasonal effluent BOD ₅ change at Bixby lagoon, 1976 . 25
7	Seasonal change of mid-point volatile suspended solids at Bixby lagoon, 1976 26
8	Seasonal change of effluent volatile suspended solids at Bixby lagoon, 1976 27
9	Monthly average pH value at Bixby lagoon, 1976 . . . 31
10	Monthly average water temperature at Bixby lagoon, 1976 32
11	Monthly average alkalinity at Bixby lagoon, 1976 . . 33
12	Monthly average dissolved oxygen at Bixby lagoon, 1976 34
13	Monthly average total BOD ₅ at Bixby lagoon, 1976 . . 35
14	Monthly average soluble BOD ₅ at Bixby lagoon, 1976 . 36

15	Monthly average total suspended solids at Bixby lagoon, 1976	37
16	Monthly average volatile suspended solids at Bixby lagoon, 1976	38
17	Monthly average total COD at Bixby lagoon, 1976 . . .	39
18	Monthly average soluble COD at Bixby lagoon, 1976 . .	40
19	Monthly average total Kjeldahl nitrogen at Bixby lagoon, 1976	41
20	Monthly average ammonia nitrogen at Bixby lagoon, 1976	42

TABLES

<u>Number</u>		<u>Page</u>
1	Sampling and Analytical Guide	9
2	Process Data	11
3	Statistical Description of Influent Water Quality at Bixby Lagoon, 1976	18
4	Statistical Description of Mid-Point Water Quality at Bixby Lagoon, 1976	18
5	Statistical Description of Effluent Water Quality at Bixby Lagoon, 1976	19
6	Summary of Bixby Lagoon Efficiencies, 1976	19
7	Seasonal Average Influent, Mid-Point, and Effluent Water Quality at Bixby Lagoon, 1976	20
8	Monthly Average Influent Water Quality at Bixby Lagoon, 1976	28
9	Monthly Average Mid-Point Water Quality at Bixby Lagoon, 1976	29
10	Monthly Average Effluent Water Quality at Bixby Lagoon, 1976	30
11	Algal Genus Identified at Bixby Lagoon	43
12	Evaluation of Temperature Coefficient	53
13	Summary of Model Testing, Bixby Cell 1	55
14	Summary of model Testing, Bixby Cell 2	55

A-1	Comparison of Parameters Measured at Five Lagoon Systems	59
A-2	Preliminary Identification of Tests Necessary for the Performance Evaluation of Each Type of Lagoon . .	60
B-1	Summary of Preliminary Regression Data, Jan.-Dec. 1976	61
B-2	Results of Regression of Variables Selected after Stepwise Regression, Jan.-Dec. 1976	62
B-3	Results of Regression of Variables Selected after Stepwise Regression, Jan., Feb., Dec. 1976	63
B-4	Results of Regression of Variables Selected after Stepwise Regression, March-May 1976	64
B-5	Results of Regression of Variables Selected after Stepwise Regression, June-Aug. 1976	65
B-6	Results of Regression of Variables Selected after Stepwise Regression, Sept.-Nov. 1976	66
B-7	Summary of Stepwise Regression Data, Jan.-Dec. 1976 . .	67
B-8	Results of Regression of Variables Selected after Stepwise Regression, Jan.-Dec. 1976	69
B-9	Results of Regression of Variables Selected after Stepwise Regression, Jan., Feb., Dec. 1976	71
B-10	Results of Regression of Variables Selected after Stepwise Regression, March-May 1976	73
B-11	Results of Regression of Variables Selected after Stepwise Regression, June-Aug. 1976	75
B-12	Results of Regression of Variables Selected after Stepwise Regression, Sept.-Nov. 1976	77
B-13	Summary of Stepwise Regression Data, Jan.-Dec. 1976 . .	79
B-14	Results of Regression of Variables Selected after Stepwise Regression, Jan.-Dec. 1976	80

B-15	Results of Regression of Variables Selected after Stepwise Regression, Jan., Feb., Dec. 1976	81
B-16	Results of Regression of Variables Selected after Stepwise Regression, March-May 1976	82
B-17	Results of Regression of Variables Selected after Stepwise Regression, June-Aug. 1976	83
B-18	Results of Regression of Variables Selected after Stepwise Regression, Sept.-Nov. 1976	84
B-19	Summary of Stepwise Regression Data, Jan.-Dec. 1976 . .	85
B-20	Results of Regression of Variables Selected after Stepwise Regression, Jan.-Dec. 1976	87
B-21	Results of Regression of Variables Selected after Stepwise Regression, Jan., Feb., Dec. 1976	88
B-22	Results of Regression of Variables Selected after Stepwise Regression, March-May 1976	89
B-23	Results of Regression of Variables Selected after Stepwise Regression, June-Aug. 1976	90
B-24	Results of Regression of Variables Selected after Stepwise Regression, Sept.-Nov. 1976	91
D-1	Influent Test Data of Bixby Lagoon, 1976	93
D-2	Mid-Point Test Data of Bixby Lagoon, 1976	97
D-3	Effluent Test Data of Bixby Lagoon, 1976	101

ACKNOWLEDGEMENTS

The authors acknowledge with gratitude the following individuals for their contribution to this report.

Anil Mathur for his diligent and conscientious pursuit of the data required to perform the analysis of the aerated lagoon system.

Joseph L. Norton, Chief of Laboratory Services, Division of the Tulsa City County Health Department, for his assistance in reviewing the project plans and laboratory analysis performed in his laboratory.

Jerry G. Cleveland, Chief of Planning & Research, Division of the Tulsa City County Health Department, for his assistance in reviewing the project plans.

Fred Keas, City of Bixby, Oklahoma, for his assistance in sampling and analysis during his tenure as Superintendent of the Water Pollution Control Facilities.

Bobby J. Tollette, Superintendent of Water Pollution Control Facilities, for his assistance in sampling and analysis.

Gene-Pai, Chou, for his assistance in graphical work.

Andy Law, Research Assistant, the Bureau of Water & Environmental Resources Research, for his assistance in writing the final report.

SECTION 1

INTRODUCTION

BACKGROUND

Biological waste treatment by means of waste stabilization lagoon system can be considered as a major wastewater treatment alternative for small communities (especially those with less than 50,000 population) and rural areas and some industries. Waste stabilization lagoon system are chosen not only for the reason of low initial capital cost, but also because of their relative stability and simplicity, as well as minimum cost of operation and maintenance. The low initial capital cost is particularly true in the rural areas where more openland is available and at lower costs. For these reasons, today there are thousands of wastewater treatment lagoons in use for domestic wastewater treatment in the United States.

The use of lagoon systems to treat wastewater is wide-spread and there are great variations in the design of these systems: from simple anaerobic, facultative, aerobic and maturation lagoons to modified lagoons of various designs (for example - the use of aeration systems or devices to maintain aerobic conditions), from single to multiple cell systems, and so forth. Although a large number of these different systems of lagoons have been studied, there is a common lack of carefully collected data in sufficient depth -- in terms of realistic, long-term performance data which would be indispensable for producing sound design criteria for future use. Partly this is due to very little on-site capability and facility to determine operational test results.

SIGNIFICANCE OF PROJECT

In the October of 1972, Congress passed the Federal Water Pollution Control Act Amendments. The Act has three major targets:

- (a) All municipal treatment facilities must achieve secondary treatment effluent limitations, and all industries must implement the Best Practicable Treatment technology

(BPT) for treatment of the wastewater discharged into all surface waters. The Act requires that these effluent criteria be met by 1977. The Environmental Protection Agency (EPA) has defined municipal secondary treatment standards and also Best Practicable Treatment technology effluent standards for each category of industry and type of manufacturing process used.

- (b) By 1983, municipalities must achieve BPT in their treatment facilities. (BPT has been defined by EPA as secondary treatment for municipalities). Industries will have to implement Best Available Technology (BAT), as defined by EPA by 1983, for each kind of industry class.
- (c) By 1985, all polluttional discharges must be eliminated from the nation's waters.

The Congress mandated that these steps be taken to enable the water quality goals of fishable and swimmable waters to be achieved by 1983. The spirit and overall purpose of the Act is to restore and maintain the chemical, physical and biological integrity of the nation's waters.

The law also established the National Pollution Discharge Elimination System (NPDES). Under NPDES, all point source (municipal and industrial) are issued permits specifying the nature and quality of pollution they may discharge. These permits, at a minimum, reflect the appropriate technology based BPT or BAT standards.

The secondary treatment effluent limitations or the minimum performance requirements for publicly owned treatment works as established in the Act of 1972 specify that the BOD₅ and suspended solids arithmetic mean values of the effluent samples for 30 days consecutive sampling shall not exceed 30 milligrams per liter or 45 milligrams per liter for samples collected in seven consecutive days. They further specify that the arithmetic mean values for the 30 day consecutive sampling shall not exceed 15% of arithmetic mean of the influent samples collected at approximately the same time during the same period. Finally, they specify that the geometric mean of the fecal coliform bacteria and the effluents shall not exceed 200 for the 30 day period or 400 for the seven consecutive day period.*

These regulations and EPA's definition of secondary treatment seems to emphasize the installation of activated sludge units.

*This has been deleted. See new standards at end of this section.

On the other hand, it is precisely because small communities cannot afford the high costs involved in the construction, operation and maintenance of activated sludge or other sophisticated units that they had to resort to treatment by means of lagoons. There also exists a strong possibility that many of the present operating lagoon will not meet EPA secondary treatment effluent standards without modifications. (2,3,4) Thus, in order to meet treatment standards, many of the presently operating lagoons would have to be modified or upgraded.

Among the numerous alternatives for upgrading lagoon treatment, functionally serialized lagoons (anaerobic, facultative and maturation) present a possible solution. Other possible solutions for upgrading the treatment are addition of air, recycling, controlled discharge, possibility of final sedimentation, filtration, and even the possibility of harvesting algae through natural methods such as culturing carp or milk-fish, or passing through a natural aquatic habitat. However, before a decision can be made on what methods of upgrading are sufficient in improving effluent quality to meet the standards, it becomes necessary to gather additional pertinent data on existing lagoon systems. At the present, there are very limited published data on performance of lagoons on a seasonal basis for the most important water quality parameters (including nutrients). It is most important to have such data in order to do a rigorous performance evaluation. Therefore, it is important to determine how an existing well-designed aerated lagoon treats wastewater. Well designed, well operated lagoon must have been operated sufficiently long and at different climatic conditions to be able to ascertain their performance in order to determine whether there are existing continuous discharge aerated lagoons that can meet the 1977 secondary treatment standards. This project will document and evaluate carefully collected operating performance data from one such lagoon system.

* Since the beginning of this project, the federal Secondary Treatment Effluent Standards have been amended. As published in the July 26, 1976 Federal Register, the limitations on fecal coliform bacteria were deleted in the 1976 revision of the standard. It is now felt that it is environmentally sound to establish disinfection requirements for domestic wastewater discharges in accordance with water quality standards promulgated pursuant to Section 302 and 303 of the Act and associated public health needs. On October 7, 1977, suspended solids limitations were amended to permit less stringent limitations for publicly owned wastewater treatment ponds with a design capacity of two million gallons per

day or less. Either the Regional EPA Administrator or the State Director for Environmental Control, subjected to EPA approval, may establish less stringent limitations based on the actual performance of waste stabilization ponds in the geographic area which are meeting effluent quality limitations for biochemical oxygen demand.

SECTION 2

CONCLUSIONS

Although the Bixby lagoon system exhibits an overall BOD₅ removal efficiency of 92%, it is only in compliance with EPA's BOD₅ standard for about 7 months out of the year. Winter and early Spring months are the non-complying months.

Total suspended solid levels in the effluent remained fairly high for 11 months of the year. The average TSS level for those months was 52 mg/l, which may be attributed to algal growth.

Fecal coliform density in the wastewater entering the Bixby lagoon system was high, in the order of 10^5 /100 ml. Even if the lagoon system had coliform removal efficiency as high as 98%, it still would not be able to reduce the coliform bacteria to less than 200/100 ml. Additional treatment would be necessary if there were a bacterial limitation for the receiving stream.

The use of linear regressions to characterize the influent, mid-point and effluent parameter and correlate lagoon efficiencies all fall short of being satisfactory. Additional parameters not clear at the present will have to be included in the regression analysis for it to be meaningful.

The attempt to depict the performance of Bixby lagoon system in terms of kinetic models was unsuccessful. The wide variations in experimental data which were being fitted to the models could not be satisfactorily explained. One possible explanation was that it may be due to algal growths which affected the fraction of the biologically active volatile suspended solids.

SECTION 3

RECOMMENDATIONS

For the numerous small communities and rural areas, wastewater treatment by means of lagoons is a significant and economically feasible alternative. However, few existing lagoons were able to perform to more desirable treatment levels as that obtained from conventional secondary treatment systems. It is obvious that lagoons as a viable means of wastewater treatment need to be further studied and monitored so that from such actions meaningful knowledge may be acquired and better design criteria may be formulated.

At the present, lagoon effluent standards are less stringent as a result of subsequent revisions of the 1972 Act. However, should a need arise in the future for the improvement of the Bixby lagoon system the addition of one or a combination of the followings is recommended: anaerobic lagoon for pretreatment, maturation lagoon for polishing and/or chlorination prior to discharge. However, feasibility study should be conducted prior to any such action.

The effect of the relative abundance of algae on the biologically active portion of the volatile suspended solids should be investigated.

The retention time in each lagoon at Bixby based on plug flow is 40 days. A method of accounting for this time lag in the correlation and regression analysis should be developed.

SECTION 4

APPROACH

PRIMARY OBJECTIVE

The primary objective of this project was to generate reliable year round performance data for a typical multi-cell aerated lagoon waste disposal system. Bixby, Oklahoma is a case in point. This lagoon system, which consists of two cells in series using an Air Aqua* system, is located in the town of Bixby, Oklahoma, which is part of the INCOG Multi-County Planning System. This aerated lagoon was selected for study by EPA with the concurrence of others.

SECONDARY OBJECTIVE

The secondary objective was to utilize these data to evaluate the effectiveness of the multi-cell lagoon system to perform in accordance with its design criteria and its ability to meet the secondary treatment standards as established by the Federal Water Pollution Control Act Amendments of 1972.

Data generated and evaluated in this lagoon system were to be similar to data from other types and locations of well-designed well-operated multi-cell aerated or a combined aerated and facultative lagoon system. These data could be used not only to assist design engineers and regulatory officials, but also assist EPA in its stated objective of defining lagoon capabilities and lagoon grading needs. A great number of parameters were studied in considerable depth. Out of the parameter study two significantly useful things were sought: 1) the more meaningful parameters conceivably could be used as routine operational tests, and 2) the parameters could be interrelated to provide predictive equations for future design.

*Tradename of Hinde Engineering aeration system.

SCOPE

From the existing Bixby lagoon system at Bixby, Oklahoma, one full year of lagoon performance data were collected. Within this period, data collection was divided into four temporal phases coinciding with the four seasons: Spring, Summer, Fall and Winter. In each period, data were collected daily for one month while samples of one week (7 consecutive days) per month were taken during the remaining two months.

Sampling was done with a flow proportional type compositing device, and sampling points were the influent (before entering the lagoon system), the mid-point (exit of first cell) and the effluent (exit from the lagoon system). Nineteen parameters were attempted: flow data, pH, temperature, dissolved oxygen, alkalinity, total BOD₅, soluble BOD₅, total suspended solids, volatile suspended solids, total COD, soluble COD, phosphorus (dissolved orthophosphate), total Kjeldahl nitrogen, ammonia nitrogen, nitrate and nitrite nitrogen, fecal and total coliform. Nitrate and nitrite nitrogen tests were subsequently discarded after tests performed at the start of project consistently showed near zero values. The remaining parameters were measured in depth with the exception of algal determination which was performed qualitatively only. Table 1 is a sampling and analytical guide.

Four tests were performed at the site, namely: pH, temperature, alkalinity and dissolved oxygen. Total suspended solids, volatile suspended solids, total and soluble COD, total and soluble BOD₅ tests were performed at the University of Oklahoma's mobile laboratory parked by the lagoon. Remaining tests were conducted by Laboratory Services, Division of the Tulsa City County Health Department.

This report in addition to containing the tabulation of the performance data, detailed information concerning the lagoon design, operational parameters, inlet and outlet configurations and flow pattern, also included an interpretation of the data as to its significance in relation to the objectives of the project. Statistically, data were analysed in the form of correlation matrices to assist in the identification of appropriate and redundant tests, and hopefully to develop through regression analysis technique and equations representing the performance of this type of lagoon. These equations, if developed, would be useful in design and evaluation of performance, including both efficiency and cost of treatment.

TABLE 1. SAMPLING AND ANALYTICAL GUIDE

PARAMETER	INFLUENT	SAMPLING POINTS	
		MID-POINT	EFFLUENT
WW Flow	X		
pH	X	X	X
WW Temperature		X	X
Dissolved Oxygen		X	X
Alkalinity	X	X	X
Total BOD ₅	X	X	X
Soluble BOD ₅	X	X	X
Total Suspended Solids	X	X	X
Volatile Suspended Solids	X	X	X
Total COD	X	X	X
Soluble COD	X	X	X
Phosphorus*	X	X	X
Total Kjeldahl Nitrogen	X		X
Ammonia Nitrogen	X		X
Nitrate Nitrogen ⁺	X		X
Nitrite Nitrogen ⁺	X		X
Fecal Coliform	X	X	X
Total Coliform		X	X
Algal Determination		X	X

*Actual test performed was dissolved ortho-phosphate. For convenience, dissolved ortho-phosphate was identified by phosphorus.

⁺Nitrate and nitrite tests were discontinued after numerous tests performed at the start of the project yield zero or near zero values consistently.

SECTION 5

PROJECT DESCRIPTION

DESCRIPTION OF THE CITY OF BIXBY AND ITS LAGOON SYSTEM

The site selected for this segment of the oxygen-supplied multiple lagoon system was that of the city of Bixby, Oklahoma. The city of Bixby is situated in the Indian Nation Council of governments (INCOG) and is adjacent to south Tulsa City. The current population of Bixby is 3,000 and is projected to grow to 6,000 in the year 2,000. The present population produces an effluent BOD_5 averaging 350 milligram per liter. Currently, Bixby has no manufacturing or process industries discharging industrial waste into the sanitary sewers. This greatly increased the desirability of the Bixby lagoon system as a site for intensive study because the wastewater concentration entering the lagoon system will be relatively stable and practically free of toxic substances which may disrupt treatment continuity. All variabilities in the wastewater which enters the Bixby lagoon system can thus be attributed to normal small town domestic and commercial sources.

Bixby Lagoon System

Bixby lagoon system is a dual-cell system, with total surface area of $23.5 \times 10^{-3} \text{ km}^2$, an average depth of 3.2 m, and an overall volume of $5.6 \times 10^4 \text{ m}^3$. Each cell is 167 m long and 38 m wide. The cells are not cemented and are supported on the sides by a dike of slope 3:1. It has 20 h.p., $9.8 \text{ m}^3/\text{min.}$, Hinde/Air-Aqua system with 84 laterals in the primary and 48 laterals in the secondary, designed to supply all the oxygen requirements for loading of 276 kg of BOD_5 per day, a population of 4,500 people and 0.4 MGD (1 GPD = $0.003785 \text{ m}^3/\text{d}$). The present plant is operating at about 90% efficiency, and a retention time of about 67.5 days. The flow is continuous, the inlet and outlet system is designed against short-circuiting. The plant is well operated, and is always accessible. It does not have final clarification nor does it have chlorination, nor are there available long-term records. These data are summarized in Table 2 and a sketch of the

TABLE 2. PROCESS DATA

Two Lagoons -	5.6x10 ⁴ m ³ volume 23.5x10 ⁻³ km ² surface area 3.2 m depth designed for either serial or parallel operation. (See sketch, Figure 1)
Aeration -	20 h.p.- Air Aqua System/Hinde Engineering 84 laterals in primary 48 laterals in secondary % oxygen demand supplied - 100%
Design -	Q = 0.45 MGD (1 GPD = 0.003785 m ³ /d) Population = 4,500 BOD ₅ /DAY = 335 kg Retention Time = 31.6 days BOD ₅ /100 m ³ = 0.6 kg BOD ₅ /HPH = 0.7 kg BOD ₅ /m ² /DAY = 0.015 kg
Actual -	Q = 0.21 ± 0.04 MGD (1 GPD = 0.003785 m ³ /d) Population = 3,000 Influent BOD ₅ = 240 (200 - 350) mg/l Effluent BOD ₅ = 11 mg/l Efficiency = 90.5% BOD ₅ /m ² /DAY = 0.008 kg Retention Time = 67.5 days
Operation -	Continuous flow Off set inlet, air lift, over under baffle No Cl ₂ Effluent V notch weir No cover, cell depth constant Maintenance good, always acessible
Other -	Built in 1970 Engineering - HTD (Tulsa/Okla. City) Operator - Fred Keas

facility in Figure 1.

DESCRIPTION OF THE EXPERIMENTAL INVESTIGATION

Sampling was simplified with the use of automatic-samplers which were setup at the lagoon influent, the mid-point and the lagoon effluent. The sampler set at the mid-point allowed analysis of each cell's performance individually.

Each sampler collected 50 ml of sample every fifteen minutes and approximately 4 liters of sample was collected in a 24 hour period.

The samples were stored in ice boxes at 4 degrees Celsius. This inhibited biological activity in the composite samples. All the experimental parameters used in the correlation were measured within 1 day of sample collection. pH, temperature, dissolved oxygen and alkalinity tests were conducted on-site immediately after samples were collected.

In the experimental analysis, 462 samples were collected and analyzed between January and December 1976. January, April, July and November were months of intensive testing and approximately 75 samples were analyzed in each of these months. This close study of the behavior of the lagoons was essential to get data to predict the seasonal variation of the performance of the lagoons. During each of the remaining months, testing was not equally rigorous and about 21 daily samples were analyzed in each month.

DESCRIPTION OF EXPERIMENTAL ANALYSIS AND PROCEDURES

All analysis were performed in accord to either the 13th Edition of Standard Methods for the Examination of Water and Wastewater (7) or EPA's Manual of Methods for Chemical Analysis of Water and Wastes (17). In the following, they will be abbreviated as Standard Method and EPA Manual respectively. The analytical procedures chosen for the parameters included in this project are briefly outlined as follows:

Tests conducted on-site:

pH - direct measurement by pH meter.

Temperature - measured by thermometer in Celsius.

Dissolved Oxygen - measured by D.O. probe.

Alkalinity - titrimetrically determined by mixed bromocresol green - methyl red double indicator method.




Figure 1. Flow schematic of Bixby lagoon system.

(Standard Method)

Tests conducted in laboratories*:

Phosphorus - determined in terms of dissolved ortho-phosphate by direct colorimetric analysis procedure.
(EPA Manual, storet no. 00671)

Ammonia Nitrogen - determined by Automated Colorimetric Phenate Method using Technicon Autoanalyser Unit AAII. (EPA Manual, storet no. 00610)

Total Kjeldahl Nitrogen - determined by titration of ammonia after distillation. (EPA Manual, storet no. 00625)

Nitrate Nitrogen - measured by spectrophotometer. (EPA Manual, storet no. 00630)

Nitrite Nitrogen - measured by spectrophotometer. (EPA Manual, storet no. 00615)

Total BOD₅ - determined by Azide Modification of the Winkler Method. (Standard Method)

Soluble BOD₅ - samples were first filtered through 0.45 μ filter with subsequent determination by the Azide Modification of the Winkler Method.
(Standard Method)

Total COD - determined by titrimetric method after reflux.
(EPA Manual, storet no. 00335, Low Level)

Soluble COD - samples were first filtered through 0.45 μ filter with subsequent determination by titrimetric method after reflux. (EPA Manual, storet no. 00335, Low Level)

Total Suspended Solids - complete evaporation of the water portion with residue dried at oven temperature of 103 °C. Determined by weight difference. (Standard Method)

Volatile Suspended Solids - complete evaporation and ashed at 550 °C. Determined by weight difference. (Standard Method)

Total Coliform - determined by membrane filter technique.
(Standard Method)

Fecal Coliform - determined by membrane filter technique.
(Standard Method)

Flow Rate - determined by measurement of water level over weir with a portable water level recorder.

Algal determination - qualitatively determined.

*Six tests were performed in O.U. Mobile Laboratory. See page 8.

DESCRIPTION OF STATISTICAL ANALYSIS TECHNIQUES

Because of the extremely large amount of performance data collected over the project period, statistical analysis would be impractical as well as not feasible without the use of high-speed computers. All the analysis conducted in this project were done with the use of a "canned" statistical analysis package -SPSS. (6) SPSS is a highly flexible, user oriented tool with output data printed out in very neat and readable manner.

Analysis of experimental data to obtain continuous variable descriptive statistics such as maximum, minimum, mean values, and standard deviation, etc. was executed with the use of a sub-program in the SPSS.

For studies related to characterization of wastewater entering the facility, efficiency correlations and design method verification, the principal tool used was multiple regression analysis.

In all correlation work, where all the variable interdependencies are not immediately obvious, stepwise regression analysis is probably the most useful and versatile tool (6).

Stepwise regression enables the identification of the most significant variables, which "explain" a given dependent variable, in the relative order of their importance. The initial task, therefore, is to identify all possible independent variables which may be related to a given dependent variable. The stepwise regression procedure introduces each variable, in order of its importance, into the regression equation and shows the effect of this introduction on the overall correlation coefficient (r^2), the F ratio, the standard error, and the beta weights for each variable in the equation. No variables would be added to the regression equation if the addition of a variable does not increase the r^2 value.

Once the pertinent variables are identified by the stepwise regression, a very close examination of all the possible underlying theoretical explanations is necessary. This is simply to avoid the problems caused by an exclusive reliance on statistical analysis. There are, sometimes, unexpected indications of variable interdependencies. These need very careful substantiation. Alternatively, variables thought to be extremely significant may not appear in the final equation resulting from the stepwise procedure. This can happen easily especially when there is considerable scatter in the original data for that variable because

of low experimental reproducibility (7). This problem occurs often in biochemical tests.

One common decision whenever this problem arises is to force the excluded variable(s) into the regression equation by abandoning the stepwise procedure. This also enables dropping of non-significant variables from the equation with a corresponding increase in the total number of valid cases. The final regression then, shows the best relationship between the independent variables and the dependent variables.

The output from such a final regression includes a tabulation of all regression parameters, a case by case listing of observed versus predicted values for the dependent variable, and a plot of the standardized error in predicted variable values. An analysis of such a plot can reveal whether or not there is reason to suspect systematic violations of the assumption that the regression is linear. In such cases, non-linear transformations of the independent variables may be indicated and the entire regression exercise repeated. However, the regression statistics produced after such variable transformations cannot be compared against the original statistics except in a very general, qualitative way. This is especially true if logarithmic transformations are used.

The fitting of observed lagoon data to a general design equation can be done by rearrangement of the design equation, identification of "synthetic" new variables and regression of these variables using least squares methods. Should it be necessary to force such regressions through a fixed point (for theoretical reasons), the usual unconstrained regression procedure is no longer useful. A similar situation would arise, for example, if a particular regression coefficient were to be held fixed. Such problems are best handled by a basic reformulation of the least squares technique which forces such constraints to be met at the beginning. Examples of such modifications are discussed later in the report.

SECTION 6

PROJECT GENERATED DATA

The primary objective of this report on Bixby lagoon system was to generate the much needed performance data for a typical multi-cell aerated lagoon waste disposal system on a year-round basis. For this reason, Section 6 is entirely devoted to the tabulation and presentation of data generated during the course of this project. For clarity purpose, data are organized into three levels: year-round, seasonal, and monthly.

DATA GENERATED ON A YEAR-ROUND BASIS

Data generated in this group is an attempt to create an overall view of the parameter characteristics measured at the Bixby lagoon system. Tables 3 to 5 are statistical descriptions of the water quality parameters at the influent, mid-point and effluent of the Bixby lagoon system. Table 6 summarizes lagoon efficiency of individual cells and the lagoon system as a whole.

DATA GENERATED ON A SEASONAL BASIS

Seasonal average water quality of wastewater at various treatment stages of the Bixby lagoon are computed and tabulated in Table 7. Data generated in this manner allow observation and comparison of wastewater treatment efficiency on a seasonal basis. Figure 2 to 8 are computer interpretations of parameter level vs time (these parameters are the ones involved in the kinetic modeling.)

DATA GENERATED ON A MONTHLY BASIS

Tables 8 to 10 contain data computed to monthly averages. Their significance lie in the fact that they revealed the trend of parameter level variation throughout the year when data were collected. Figure 9 to 20 are graphical presentations of data so computed. These graphs besides visually showing trends of parameter variation, also permit comparison of treatment efficiencies

TABLE 3. STATISTICAL DESCRIPTION OF INFLUENT WATER
QUALITY AT BIXBY LAGOON, 1976

TEST	AVE. VALUE ⁺	MIN.	MAX.	STD. DEV.
pH		4.3	7.6	
Alkalinity*	154.0	94.0	198.0	18.9
Total BOD ₅	368	210	740	90
Soluble BOD ₅	154	53	350	56
Total S.S.	268	92	772	138
Volatile S.S.	201	40	631	116
Total COD	641	233	1,148	147
Soluble COD	262	115	545	69
TKN	45.7	21.0	115.0	11.8
Ammonia-N	29.3	9.0	48.9	6.7
Flow, GPD**	1.4x10 ⁵	617	17.6x10 ⁵	1.8x10 ⁵

⁺All values were computed from one year period data. Unless indicated, all units are mg/l except for pH.

*As CaCO₃

**1 GPD = 0.003785 m³/d

TABLE 4. STATISTICAL DESCRIPTION OF MID-POINT WATER
QUALITY AT BIXBY LAGOON, 1976

TEST	AVE. VALUE ⁺	MIN.	MAX.	STD. DEV.
pH		5.5	8.0	
Alkalinity*	85.7	26.0	194.0	41.7
Temperature, °C	17.8	1.0	30.0	8.6
DO	7.6	2.2	13.6	2.6
Total BOD ₅	84	26	183	37
Soluble BOD ₅	25	3	132	28
Total S.S.	90	19	232	46
Volatile S.S.	70	12	196	39
Total COD	195	88	498	67
Soluble COD	71	17	246	35

⁺All values were computed from one year period data. Unless indicated, all units are mg/l except for pH.

*As CaCO₃

TABLE 5. STATISTICAL DESCRIPTION OF EFFLUENT WATER
QUALITY AT BIXBY LAGOON, 1976

TEST	AVE. VALUE ⁺	MIN.	MAX.	STD. DEV.
pH		6.3	9.8	
Alkalinity*	74.4	24.0	180.0	24.1
Temperature, °C	17.3	1.0	31.0	9.1
DO	8.8	2.0	19.0	4.0
Total BOD ₅	30	7	131	21
Soluble BOD ₅	16	1	128	19
Total S.S.	56	11	186	33
Volatile S.S.	35	4	146	23
Total COD	103	20	330	45
Soluble COD	55	6	250	32
TKN	7.8	1.0	23.0	4.7
Ammonia-N	3.3	0.1	23.8	4.6

⁺All values were computed from one year period data. Unless indicated, all units are mg/l except for pH.

*As CaCO₃

TABLE 6. SUMMARY OF BIXBY LAGOON EFFICIENCIES, 1976

TEST	AVE. VALUE ⁺	MIN.	MAX.	STD. DEV.
BOD ₅ Cell 1	77	48	94	9
BOD ₅ Cell 2	61	-17*	92	24
BOD ₅ Overall	92	68	97	5
Total S.S. Cell 1	61	-22	93	24
Total S.S. Cell 2	16	-392	94	76
Total S.S. Overall	76	29	96	14
COD Cell 1	69	18	89	12
COD Cell 2	45	-15	95	21
COD Overall	84	55	97	7
TKN Overall	83	34	98	10

⁺All values were computed from one year period data. Values are removal efficiencies in percentages.

*Negative sign indicates increase in waste concentration.

TABLE 7. SEASONAL AVERAGE INFLUENT, MID-POINT, AND EFFLUENT
WATER QUALITY AT BIXBY LAGOON, 1976

TESTS	SPRING			SUMMER			AUTUMN			WINTER		
	INF.	MID.	EFF.	INF.	MID.	EFF.	INF.	MID.	EFF.	INF.	MID.	EFF.
pH	6.5	6.8	7.2	6.2	6.7	6.8	6.2	6.2	7.6	6.7	6.9	7.9
Alkalinity*	160	109	85	151	78	72	149	71	60	157	113	79
Temperature, °C	-	19.3	19.1	-	28.0	28.4	-	12.7	11.8	-	6.6	5.7
DO	-	6.6	7.1	-	6.4	5.2	-	8.2	11.6	-	9.8	13.2
Total BOD ₅	394	88	35	355	64	20	366	111	25	357	80	40
Soluble BOD ₅	148	24	16	129	13	9	144	7	10	199	52	28
Total S.S.	301	79	58	258	72	66	258	133	52	253	78	46
Volatile S.S.	221	61	41	214	58	33	192	108	35	178	52	28
Total COD	606	206	131	594	156	84	757	263	102	630	165	94
Soluble COD	240	77	74	248	62	49	257	67	47	302	78	46
Phosphorus**	37.7	44.0	48.2	-	-	38.0	-	-	-	36.9	40.7	32.0
TKN	49.1	-	10.4	43.5	-	4.7	46.9	-	5.3	43.6	-	10.1
Ammonia-N	24.1	-	5.0	31.1	-	0.8	33.9	-	0.1	29.8	-	6.1
Fecal Coli.+	199	147	73	-	-	-	-	-	-	-	-	-
Total Coli.+	-	303	166	-	-	-	-	-	-	-	-	-
Flow, x10 ³ gpd#	150	-	-	151	-	-	132	-	-	118	-	-

Unless otherwise indicated, all units are mg/l except for pH.

*Alkalinity as CaCO₃.

**Actual tests performed were dissolved ortho-phosphate. For convenience, dissolved ortho-phosphate was identified as phosphorus.

+Values are x100/100ml.

#1 gpd = 0.003785 m³/d.




Figure 2. Seasonal mid-point water temperature change at Bixby lagoon, 1976




Figure 3. Seasonal influent flow rate change at Bixby lagoon, 1976




Figure 4. Seasonal influent BOD₅ change at Bixby lagoon, 1976




Figure 5. Seasonal mid-point BOD₅ change at Bixby lagoon, 1976




Figure 6. Seasonal effluent BOD₅ change at Bixby lagoon, 1976




Figure 7. Seasonal change of mid-point volatile suspended solids at Bixby lagoon, 1976




Figure 8. Seasonal change of effluent volatile suspended solids at Bixby lagoon, 1976

TABLE 8. MONTHLY AVERAGE INFLUENT WATER QUALITY AT BIXBY LAGOON, 1976

TESTS	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.
pH	6.9	-	7.1	6.7	6.5	6.5	6.1	6.4	6.2	6.3	6.5	6.3
Alkalinity*	165	-	162	169	159	157	152	144	142	163	154	143
Total BOD ₅	368	422	414	430	379	413	355	213	330	388	383	283
Soluble BOD ₅	222	244	227	132	136	122	140	105	142	136	156	119
Total S.S.	323	228	236	347	271	230	253	282	213	230	289	134
Volatile S.S.	230	177	107	288	207	187	200	255	82	180	229	96
Total COD	664	523	671	619	552	606	594	589	646	773	815	619
Soluble COD	312	368	319	225	240	267	254	223	259	278	262	224
Phosphorus**	36.5	-	37.3	-	-	-	-	-	-	-	-	-
TKN	42.9	44.4	63.6	42.3	40.2	40.8	47.5	36.3	44.2	47.1	50.2	44.3
Ammonia-N	31.0	27.9	25.1	24.7	24.4	26.5	36.3	22.3	33.5	40.4	32.6	28.5
Fecal Coli., x100/100 ml	-	-	133	225	-	-	-	-	-	-	-	-
Flow, x10 ³ gpd#	111	109	123	168	141	111	124	222	140	124	148	148

Unless otherwise indicated, all units are mg/l except for pH.

*Alkalinity as CaCO₃.

**Actual tests performed were dissolved ortho-phosphate. For convenience, dissolved ortho-phosphate was identified as phosphorus.

#1 gpd = 0.003785 m³/d.

TABLE 9. MONTHLY AVERAGE MID-POINT WATER QUALITY AT BIXBY LAGOON, 1976

TESTS	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.
pH	7.3	-	7.7	6.8	6.6	6.5	6.6	6.8	6.7	6.4	6.6	6.4
Alkalinity*	142	-	157	111	72	71	81	74	52	45	38	74
Temperature, °C	5.7	-	16.6	19.3	21.0	25.9	28.7	27.4	25.0	14.0	9.5	7.4
DO	10.6	-	6.7	7.3	4.4	3.5	6.9	7.7	7.1	8.4	8.4	7.9
Total BOD ₅	68	150	60	99	71	87	56	79	87	105	110	52
Soluble BOD ₅	55	87	40	37	9	13	14	8	5	8	9	12
Total S.S.	93	63	101	73	80	61	66	102	109	166	120	51
Volatile S.S.	64	40	63	59	74	53	50	87	78	140	98	40
Total COD	147	186	191	216	183	175	139	204	185	268	248	173
Soluble COD	65	133	111	84	64	104	53	69	68	57	68	66
Phosphorus**	38.6	-	43.6	-	-	-	-	-	-	-	-	-
Fecal Coli., x100/100 ml	-	-	113	162	-	-	-	-	-	-	-	-
Total Coli., x100/100 ml	-	-	213	328	-	-	-	-	-	-	-	-

Unless otherwise indicated, all units are mg/l except for pH.

*Alkalinity as CaCO₃.

**Actual tests performed were dissolved ortho-phosphate. For convenience, dissolved ortho-phosphate was identified as phosphorus.

TABLE 10. MONTHLY AVERAGE EFFLUENT WATER QUALITY AT BIXBY LAGOON, 1976

TESTS	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.
pH	7.6	-	9.2	6.9	6.9	6.7	6.7	7.1	8.1	7.7	7.1	6.7
Alkalinity*	91	-	149	80	59	69	75	69	63	62	59	49
Temperature, °C	5.2	-	16.0	19.2	20.3	26.1	29.3	28.2	24.3	12.8	8.6	6.6
DO	13.5	-	9.0	5.7	8.3	3.9	4.3	6.4	9.5	10.6	11.7	11.5
Total BOD ₅	48	41	39	36	27	26	20	14	40	19	24	21
Soluble BOD ₅	36	32	36	13	6	9	10	5	4	6	7	5
Total S.S.	51	-	59	67	44	97	71	38	28	51	56	36
Volatile S.S.	31	-	43	41	39	52	33	25	16	34	39	21
Total COD	85	-	154	128	119	146	75	60	61	85	116	110
Soluble COD	41	-	107	70	59	60	48	44	30	39	52	55
Phosphorus**	32.9	-	39.9	-	104	-	38	-	-	-	-	-
TKN	7.7	19.2	22.2	7.5	5.6	6.3	5.0	2.7	3.9	4.3	5.9	8.4
Ammonia-N	4.6	13.9	14.8	3.0	1.2	1.3	0.6	0.5	0.1	0.2	0.1	1.0
Fecal Coli., x100/100 ml	-	-	53	80	-	-	-	-	-	-	-	-
Total Coli., x100/100 ml	-	-	129	178	-	-	-	-	-	-	-	-

Unless otherwise indicated, all units are mg/l except for pH.

*Alkalinity as CaCO₃.

**Actual tests performed were dissolved ortho-phosphate. For convenience, dissolved ortho-phosphate was identified as phosphorus.




Figure 9. Monthly average pH value at Bixby lagoon, 1976.




Figure 10. Monthly average water temperature at Bixby lagoon, 1976.




Figure 11. Monthly average alkalinity at Bixby lagoon, 1976.




Figure 12. Monthly average dissolved oxygen at Bixby lagoon, 1976.




Figure 13. Monthly average total BOD₅ at Bixby lagoon, 1976.




Figure 14. Monthly average soluble BOD₅ at Bixby lagoon, 1976.




Figure 15. Monthly average total suspended solids at Bixby lagoon, 1976.




Figure 16. Monthly average volatile suspended solids at Bixby lagoon, 1976.




Figure 17. Monthly average total COD at Bixby lagoon, 1976.




Figure 18. Monthly average soluble COD at Bixby Lagoon, 1976.




Figure 19. Monthly average total Kjeldahl nitrogen at Bixby lagoon, 1976




Figure 20. Monthly average ammonia nitrogen at Bixby lagoon, 1976.

at any month of the year.

The analysis of algae was performed qualitatively only and analysis was made to the genus level. Based on comparative observation, the population density of the different algae are referred to as very abundant (VA) or rare (R). Algal analysis performed at the Bixby lagoon are tabulated in Table 11.

TABLE 11. ALGAL GENUS IDENTIFIED* AT BIXBY LAGOON

ALGAL GENUS	POPULATION DENSITY
(From mid-point of lagoon system)	
Ankistrodesmus	VA
Euglena	R
Golenkinia	R
Oocystis	R
Scenedesmas	R
(From effluent of lagoon system)	
Ankistrodesmus	VA
Chlorella	R
Euglena	R
Golenkinia	R
Pediastrum	R

*Identification was performed by Bill Cox, Pollution Control Section, Tulsa City-County Health Dept., Tulsa, Oklahoma; on single sample.

SECTION 7

PROJECT DATA EVALUATION AND ANALYSIS

The stated secondary objective in the proposal is to utilize the generated data to evaluate the effectiveness of the multi-system lagoon to perform in accordance with its design criteria and the ability to meet the secondary treatment standards as established by the Federal Water Pollution Control Act Amendments of 1972.

This section of the report will discuss, in relation to the stated secondary objectives, the results of analysis of data collected. However, before the discussion of the results, a brief literature review will perhaps be helpful to readers who are unfamiliar with the modelling aspects of biological waste treatment.

BRIEF LITERATURE REVIEW IN BIOLOGICAL WASTE TREATMENT MODELLING

Literatures reviewed indicated that there exists a proliferation of design methods for biological treatment facilities. There are, however, precious few articles on the analysis of existing biological treatment facilities. A study of operational parameters in facultative lagoons is essential if one is to compare the performance efficiencies against design values.

Horsfall (8) points out that little is understood of the biochemical reactions that take place in facultative lagoons. Enzymatic processes do not necessarily occur in the same environment as the bulk of water. Also, if cells encounter food sources at low concentration, they develop a mechanism for concentrating food around the cell in a separate layer. These cells are thus able to consume food that cannot be transported directly through the cell walls. The cells excrete enzymes that break up the food, thereby enabling transport across the cell wall.

A variety of life forms degrade organic wastes. It is impossible to predict which of the several steps these organisms use to consume the waste is rate-controlling. The problem is compli-

cated by the fact that domestic and industrial wastes are practically impossible to classify at a level of detail essential for theoretical biochemical degradation studies. Horsfall suggests that lagoon design procedures are simplistic and that the fact that biochemical facilities operate efficiently is surprising in view of the uncertainties in design methods.

Shastri, Fan and Erickson (9) have developed a non-linear least squares method for estimating the parameters in a nine parameter stream water quality model. However, as Brown and Berthouex (10) have pointed out, the model is not convincing because the fundamental premises on which the model is built are themselves questionable. They argue that using highly non-linear kinetic models for BOD removal studies is questionable if numerous parameters are arbitrarily hypothesized as being relevant. In fact, practically any data set could be forced to fit a nine-parameter, non-linear model. Therefore, a mere parameter estimation exercise does not validate the model per se. This is simply because innumerable "counter-models" could be proposed and shown to fit the same data equally well, regardless of the theoretical validity of the models themselves. This issue lies at the heart of the question of model calibration versus model testing and validation against observed data which was not included in model calibration originally. As a result, complex models require very extensive field data collection. A corollary of this statement would be that, in the absence of extensive field data, models should be constructed to be as simple as possible. The real problem therefore, is not the lack of theoretical models but rather the shortage of consistent and reliable experimental data drawn from long term water quality monitoring studies of operating facilities. In fact, an even more fundamental problem often is the lack of good waste characterization studies.

Viraraghavan (11) attempted such a waste characterization study between BOD_5 , COD and TOC for a raw sewage, septic tank effluent and polluted groundwater. Viraraghavan made the following conclusions:

- (a) For raw sewage the correlation coefficients between BOD_5 , COD and soluble organic carbon were not significant at the 5 percent level.
- (b) For polluted groundwater the correlation coefficient between COD and soluble organic carbon was significant at the 1 percent level.

However, these conclusions may be entirely premature since

Viraraghavan used only ten raw sewage, 20 septic tank effluent and 28 polluted groundwater samples in the statistical analysis. Besides, other essential parameters such as suspended, dissolved, settleable, and total solids as well as nutrients and their degradation by-products were completely ignored in the characterization. A final point in such an exercise is simply that there is no logical necessity for different waste waters and surface or groundwaters to have similar statistical profiles for various pollutants. It is obvious that each kind of wastewater has unique characteristics and that any extrapolation to other kinds of wastewater is not logical.

Thus, studies which report field data for the major water quality constituents on a seasonal basis are useful. They make it possible to confirm or deny the reliability of the design procedure which was used to build the facility in the first place. In a stream water quality modeling effort, field data would be similarly essential to enable model calibration. Additional data, not used in the model calibration, would be necessary for model validation exercises.

This study shows in the succeeding sections that influent characterization, treatment process efficiency correlations, and effluent characterization and correlation against influent data are all possible using simple multi-parameter linear models.

A final effort in the study addresses the important problem of attempting to derive characteristic design parameters from operational information. The complications caused by seasonal temperature variations are, specifically, addressed in an attempt to see how well the standard lagoon design method formulas fit observed performance data.

RESULTS AND ANALYSES

The discussion on results and analyses, will be divided into seven sections as follows: (results from regression analysis are summarized in Appendix B).

- (i) Computing statistical averages and standard deviations.
- (ii) Characterization of the wastewater entering the lagoon system (influent).
- (iii) Calculation of removal efficiencies for pollutants listed on the NPDES permit and also for other parameters. (These removal efficiencies were computed for each cell as well as for the total system). Correlation of pollutant removal efficiencies against influent

- properties and parameters for each cell and for the total system.
- (iv) Correlation of lagoon mid-point properties (between cell 1 and cell 2) with influent properties.
 - (v) Correlation of effluent parameters with influent parameters.
 - (vi) Fitting the standard aerated lagoon design equations to actual performance data for biochemical oxygen demand (BOD), with temperature dependency of the reaction rate constant included.
 - (vii) Fitting the CSTR and Plug Flow Models for different rate mechanism to a set of data which has a constant temperature.

(i) Computing statistical averages and standard deviations:

Descriptive statistics of the experimentally determined parameters are summarized in Tables 3-5. The statistics of the parameters at the influent are presented in Table 3, the mid-point and effluent statistics are presented in Tables 4 and 5, respectively.

Examination of these tables indicate the wide variation of the experimentally determined water quality data.

As shown in Table 3, the average value of the influent BOD₅ is 368 mg/l and has a standard deviation of 90. The volatile suspended solids have an average value of 201 mg/l and a standard deviation of 116. At the outset, a close study of these standard deviations indicates that a waste characterization attempt would have dubious success. This hypothesis is confirmed in subsequent sections.

Tables 4 and 5 indicate similar wide variations. For instance, the effluent BOD₅ has an average value of 30 mg/l and a standard deviation of 21. An attempt to predict the mid-point and effluent parameters was ambiguous at best. In the linear regression equations the constant term was always high, indicating that the correlating parameters only partially "explain" the dependent variable.

(ii) Characterization of wastewater entering the lagoon system:

Raw wastewater properties dictate the lagoon performance. Influent wastewater properties at a lagoon system can vary on an hourly, daily, monthly and seasonal basis. Hourly fluctuations can be very different because total flow and pollutant

loadings are particularly high after morning and evening hours. Mid-afternoon and night-time conditions are usually less severe. In the Bixby study, it was decided to take samples composited throughout the day so that the effect of hourly fluctuations could be smoothened out.

Despite such daily averaging, there remains a high degree of variation in raw wastewater properties by season. This, along with climatic considerations, causes the performance to vary considerably between the seasons.

The federal NPDES permit does not specifically require raw wastewater analysis. The apparent emphasis in the permit system is on the quality of the treated wastewater. Due to this, some communities do not feel that influent monitoring is necessary on a routine basis. However, for design calculations, or for performance grading studies, influent characteristics data are equally important as those of the effluent.

An examination of Tables B-1 to B-6 (in Appendix B) shows the several significant correlations attempted between various influent parameters for different seasons. Table B-1 shows the stepwise regression which led to the identification of significant variables for explaining selected dependent variables. The low correlation coefficients indicate that the regression equations are a poor substitute for experimental data, and most likely are excluding significant parameters from variables considered in the regression analysis.

(iii) Correlation of pollutant removal efficiencies:

As may be expected, the lagoon efficiencies for BOD removal are consistently high except possibly during winter. From the one year data period of this project, the overall BOD removal efficiency averaged about 92%. This, in conjunction with the annual average effluent BOD₅ concentration of 29 mg/l, shows the Bixby lagoon to be substantially in compliance with the federal requirements of secondary treatment for BOD₅.

The overall removal efficiency for BOD was found to correlate primarily only with the temperature of the wastewater. on a monthly basis, effluent BOD₅ concentration was below 30 mg/l in seven months out of the year. Low BOD values seemed to coincide with the warm temperature of summer months while lagging into the late autumn months. Further explanation is difficult because of the uncertainties involved in the experimental determination of influent BOD caused by floccular dispersion of organic material.

BOD removal efficiency correlation for cell 2 is quite good with BOD at the end of cell 1. This reinforces the suspicion that raw influent BOD fluctuations are quite large; the high standard deviation of 89 mg/l again points in the same direction.

Total suspended solids (TSS) removal efficiency averaged at 76%, while the average effluent TSS was 54 mg/l on an annual basis. This shows that the lagoon fails to meet federal secondary treatment limitations for suspended solids. Examination of the monthly average effluent water quality (see Table 10) revealed that for TSS only one month out of the year did the effluent TSS level meet the standard.

The fecal coliform density data of raw wastewater at the Bixby lagoon system are in the range of 10^5 /100 ml. With this concentration of coliform bacteria in the wastewater, even a reduction efficiency as high as 98% may still result in an effluent with fecal coliform exceeding the 200/100 ml secondary effluent standard. Data of effluent total and fecal coliform collected at Bixby are in the range of 10^4 and 10^3 /100 ml respectively, indicating non-compliance with the federal secondary treatment requirement. In view of this inadequacy in bacteriological treatment, it is suggested here that perhaps a maturation pond added will greatly improve the bacterial removal efficiency of the Bixby lagoon system or disinfection should be used if the water quality standards required meeting effluent numbers less than 200/100 ml.

(iv) Correlation of lagoon mid-point properties:

At the mid-point of the lagoon (between cell 1 and cell 2) system, the annual average BOD₅ and TSS were found to be 84 mg/l and 89 mg/l respectively. This shows that the bulk of the BOD and TSS removal occurred in cell 1. This is in keeping with theoretical considerations which predict a BOD removal rate proportional to the average concentration of BOD in the cell. Similarly, the bulk of the TSS in the influent settle down rather quickly in cell 1. Cell 1 is also more vigorously aerated than cell 2 and this surely complicated the analysis. Above all, the growth of algae in cell 2 also contributed significantly to TSS.

(v) Correlation of effluent properties with influent properties:

As discussed under (ii) above, the Bixby lagoon meets the EPA criteria for BOD₅ but not for TSS, or fecal coliform density.

Correlations were attempted for total and soluble BOD₅ and COD, total and volatile suspended solids and total Kjeldahl nitrogen in the lagoon effluent. In general, it was not found feasible to correlate effluent properties with influent data with any high degree of reliability, for in cases where correlation did exist, they were found to be erratic in nature. This is perhaps partly because of the inscrutable random scattering in the influent and effluent properties and the fact that the effect of algae has not been considered.

A further complication is the fact that the lagoons' average residence time (based on plug flow) is nearly eighty-two days. This time lag is very significant and an attempt to correlate influent and effluent properties has proved this to be true. On the other hand, an attempt to correlate influent and effluent data taken eighty-two days apart would ignore the effect of intervening parameters like climatic and other cumulative factors during those eighty-two days. It can be said, therefore, that at this time there is no satisfactory method for correlating effluent parameters with influent values for a high retention time aerated lagoon unless during the entire retention period all intervening factors could be controlled. This fact also casts some doubt on one's ability to accurately compare the design calculations against actual operating data. Ignoring the time lag or considering the average values seems to be the only viable alternatives at the moment.

(vi) Curve-fitting of design equation to operating data:
The standard design equation for aerated lagoons (11) is:

$$(S_0 - S_e)/(X_v t) = k S_e \text{ ----- (1)}$$

S_0 = influent BOD₅ concentration, mg/l.

S_e = effluent BOD₅ concentration, mg/l.

X_v = average or equilibrium concentration of volatile solids
(active bio-mass) in lagoon, mg/l.

t = detention time = V/Q , days.

k = specific organic removal rate coefficient l/mg-day.

In the above design equation it is a normal practice to plot $(S_0 - S_e)/t$ versus S_e . A linear regression is then carried out to obtain the slope (kX_v). The reason why k and X_v are lumped together in most studies is that prediction of X_v in an aerated

lagoon which has zero recycle is often impossible. The intercept from this plot (which theoretically should be zero) is labeled as a "residual term". The alternative to having a residual is forcing the line through the origin and decreasing the degrees of freedom of the regression equation for y by 1.

The real problem with the above mentioned plot is that the term, S_e , appears in the numerator of both the x and the y-axis term. This, as discussed by Sherwood and Reed (12), is a cardinal error since highly erroneous values of S_e would be disguised under such a plot.

The correct procedure for plotting the design equation is really:

$$(S_o - S_e)/S_e = k X_v t \dots\dots\dots(2)$$

and to do a least squares fit which forces the line to pass through the origin. Such a plot of $(S_o/S_e - 1)$ versus t would show two independent variables on either axis and would not suffer from the above mentioned deficiencies.

Before such a plot is made the temperature effect on the specific organic removal rate constant must be considered. The standard approach (9) is:

$$k = k_o \theta^{(T-20)} \dots\dots\dots(3)$$

where

k_o = specific organic removal rate at 20°C; 1/mg-day.

θ = temperature coefficient (dimensionless)

T = temperature of the waste °C

Substituting (3) in (1) and taking logarithms yields \ln

$$\ln(k_o X_v V) - 20(\ln \theta) + (T \ln \theta - \ln Q) \dots\dots\dots(4)$$

a plot of these synthesized variables $\ln((S_o - S_e)/S_e)$ versus $(T \ln \theta - \ln Q)$ should be forced through a slope of 1.0. The intercept is then $\ln(k_o X_v V)$.

There is no really definitive recommendation in the literature as to whether or not one should treat X_v as an independent design parameter in aerated lagoon design. For this reason, an

attempt was made in this study to determine whether extensive operating data gathered over a period of one year could be used to elucidate the problem.

The methodology used to segregate the effect of X_v , assuming it to be statistically significant, was to rewrite equation (4) as:

$$\ln((S_o - S_e)/S_o) = \ln(k_o V) - 20 (\ln \theta) + (T \ln \theta - \ln Q + \ln X_v) \text{ ----- (5)}$$

where X_v has been combined with the synthetic independent variable term.

It should be recognized that X_v reduced very rapidly from the entrance to the first cell to the exit of the first cell. The variation in the second cell is not so marked because of the rapid growth of algae which interfere with the measurement of the volatile suspended solids (VSS). In other words, the fraction of the VSS which is biologically active, x , varies inversely with the relative abundance of algae. There was no attempt to isolate the value of x from the measured VSS value in this study. Such a determination would have to be based on extensive pilot plant experiments in which all other operating conditions could be carefully controlled. Such control was not possible in the Bixby lagoon system.

The X_v term, as used in the above equations, therefore should be thought to include the multiplier x . The net effect of using X_v without x in the regression exercise would be to bias the value of the intercept term $(\ln k_o V - 20 \ln \theta)$ in equation (5).

If the basic data variables in equation (5) were "noisy", this could easily conceal the true significance of x in the regression. The Bixby study has shown that these data items do in fact contain a great deal of random spread and hence the error involved in ignoring x is probably not significant.

Equation (5) was regressed for two alternatives:

- (a) Cell 1, with S_o measured at raw influent, S_e , T , X_v measured at cell 1 exit.
- (b) Cell 2, with S_o measured at cell 1 exit, S_e , T , X_v measured at cell 2 exit (i.e. at lagoon system exit).

Eckenfelder reported the temperature coefficient, θ for a pulp and paper mill waste and for a board-mill waste to be

varying from 1.07 to 1.09 for filtered and settled samples. (13) Herman and Gloyna using municipal wastewater for a temperature range of 25°C to 35°C found the optimum rate constant K_{35} to be 0.60, with θ value equal to 1.085. (14) Mancini and Barnhart reported that for aerated lagoons, θ varies from 1.06 to 1.18. (15)

Because the value of the temperature coefficient θ is not known with certainty, it would have to be varied until the best least squares lines could be obtained. Seventeen values of θ between 1.0 and 1.2 were attempted in each of the two alternatives. The value of θ which gave the best fit in terms of the lowest residual sum of squares of the errors and/or the best correlation coefficient (r) was chosen.

The regression exercise was repeated for equation (4) which, as explained earlier, helped produce an average value for the product $k_0 X_v$ rather than k_0 alone.

Results of these regression exercises for both equation (4) and (5) are tabulated in Table 12. All regressions were found to have F values which were statistically insignificant at the confidence level of 95%. Correlation coefficients were also found to be rather low, probably due to noisy data and ignoring of the effect of algae.

The most impressive result obtained from these regressions was that the temperature coefficient values θ were 1.01 and 1.035 for equation (4) and 1.05 and 1.035 for equation (5) for cell 1 and cell 2 respectively. This is in strong agreement with Adams and Eckenfelder's (16) reported general value of 1.035.

TABLE 12. EVALUATION OF TEMPERATURE COEFFICIENT

CELL	REACTOR MODEL	X_v VARIABLE?	SS_r	SS_y	r^2	VALID CASES	θ
1	CSTR	Yes	49.42	22.4	0.062	72	1.050
1	CSTR	No	16.74	22.4	0.269	72	1.035
1	Plug Flow	No	6.02	5.9	0.239	72	1.020
2	CSTR	Yes	130.70	62.2	0.068	75	1.035
2	CSTR	No	76.20	62.2	0.072	75	1.010
2	CSTR	No	38.20	27.6	0.062	75	1.000

(vii) Fitting the CSTR and Plug Flow Models for different rate mechanisms to a set of data which has a constant temperature:

As can be observed from data tabulated previously, the temperature of the wastewater remained fairly constant for the months June through September. Average temperature was 28 °C, with a standard deviation of 1.2. Since the average retention time in each of the two cells is 40 days (based on plug flow), it is necessary to choose data for model fitting which has the same temperature over an extended period of time. Accordingly, the data for July to September were used in the following models.

The basic design equations for a plug flow reactor and a CSTR under steady state conditions are respectively:

$$\int_0^V dv/Q = \int_{S_0}^{S_e} ds/(-r) \quad \text{and} \quad Q(S_0 - S_e)/V = -r$$

In the above equations: V = volume of reactor (m^3)
 Q = flow rate (m^3/day)
 S = concentration of BOD_5 mg/l .
 r = rate of reaction mg/l/day .

Both these design equations represent ideal extremes between which the lagoons perform. Different kinetic models for the rate of reaction were substituted in these design equations. These equations were simplified and linearized by taking logarithms. The possibility of treating the volatile suspended solids as a variable was also considered.

Table 13 summarizes the results for cell 1 and Table 14 for cell 2. In these tables the first column represents the reactor model, the second column the rate equation that was used. The third column, SS_r , is the residual sum of the squares - a measure of the deviation of the observed values from the values predicted by the regression equation. Column 4, SS_y , is a measure of the deviation of the observed value from the average value of the dependent variable.

An examination of Tables 13 & 14 show that none of the models are "better" than just predicting an average value for the lagoon performance, that is, none of the models explain the data sufficiently. This can be explained partly because the kinetic models do not account for algae growth. Actually, the poor results in this modeling exercise are in keeping with Horsfall's (8)

contention that existing design equations are simplistic and do not reflect the complexity of the biochemical reactions.

TABLE 13. SUMMARY OF MODEL TESTING, BIXBY CELL 1

REACTOR MODEL	RATE EQUATION	SS _r	SS _y	r ²
Plug Flow	$r = K$	2.14	0.75	0.159
Plug Flow	$r = K S$	2.18	0.89	0.159
Plug Flow	$r = (K S)/S_0$	3.30	1.39	0.023
CSTR	$r = K$	2.14	0.75	0.159
CSTR	$r = K S$	3.95	3.86	0.150
CSTR	$r = (K S)/S_0$	4.08	4.61	0.198
CSTR	$r = k X_v$	6.41	0.75	0.019
CSTR	$r = k X_v S$	12.55	3.86	0.163
CSTR	$r = (k X_v S)/S_0$	13.20	4.62	0.128

$K = k X_v$

25 DATA POINTS, AVE. TEMP. = 28 °C, STD. DEV. = 1.8

TABLE 14. SUMMARY OF MODEL TESTING, BIXBY CELL 2

REACTOR MODEL	RATE EQUATION	SS _r	SS _y	r ²
Plug Flow	$r = K$	12.11	7.36	0.068
Plug Flow	$r = K S$	10.05	5.59	0.067
Plug Flow	$r = (K S)/S_0$	7.23	5.94	0.015
CSTR	$r = K$	12.11	7.36	0.068
CSTR	$r = K S$	20.32	14.53	0.073
CSTR	$r = (K S)/S_0$	31.74	24.78	0.080
CSTR	$r = k X_v$	26.72	7.36	0.052
CSTR	$r = k X_v S$	31.95	14.53	0.092
CSTR	$r = (k X_v S)/S_0$	46.39	24.78	0.034

$K = k X_v$

25 DATA POINTS, AVE. TEMP. = 28 °C, STD. DEV. = 1.5

REFERENCES

1. Marais, G. V. R. New Factors in the Design, Operation and Performance of Waste Stabilization Ponds. Bull. Wld. Hlth. Org., 34:737-763, 1966.
2. Barsom, G. M., and Rychman, D. W. Evaluation of Lagoon Performance in Light of 1965 Water Quality Act. In: Second International Symposium for Waste Treatment Lagoons, Kansas City, Missouri, June 1970.
3. Barsom, George. Lagoon Performance and the State of Lagoon Technology. U.S.E.P.A., Wash. D.C., June 1973.
4. Coleman, M. S., Henderson, J. P., Chichester, H. G., and Carpenter, R. L. Agriculture as a Means to Achieve Effluent Standards. Env. Prot. Tech. Series EPA-660/2-74-041.
5. Eckley, L. E., Canter, L., and Reid, G. Operation of Stabilization Ponds in Tropical Area. U.S. Army Medical Research and Development Command, Office of the Surgeon General, Wash. D.C., 1974.
6. Nie, N. H., Hull, C. H., Jenkins, J. G., Steinbrenner, K., and Bent, D. H. Statistical Packet for the Social Sciences. 2nd. Edition, McGraw-Hill, Inc., 1975.
7. Standard Methods for the Examination of Water and Wastewater. 13th. Edition. American Public Health Association, American Water Works Association and Water Pollution Control Federation. 1971.
8. Horsfall, F. L., III. Biochemical Augmentation of Wastewater Treatment. Water Pollution Control Federation Highlights, 14 (2), February 1977.
9. Shastri, J. S., Fan, L. T., and Erickson, L. E. Nonlinear Parameter Estimation in Water Quality Modeling. Journal of the Environmental Engineering Division, ASCE, 99(EE3):315-331, June 1973.

10. Brown, L. C., and Berthouex, P. M. Discussion on Nonlinear Parameter Estimation in Water Quality Modeling. Journal of the Environmental Engineering Division, ASCE, 100(##1):226-227, February 1974.
11. Viraraghavan, T. Correlation of BOD, COD, and Soluble Organic Carbons. Jour. Water Poll. Con. Fed., 48:2213-2214, Sept. 1976.
12. Sherwood, T. K., and Reed, C. E. Applied Mathematics in Chemical Engineering. 1st. Edition. McGraw-Hill Book Co., Inc., 1939. pp. 295-299.
13. Eckenfelder, W. W., Jr. Industrial Water Pollution Control. McGraw-Hill, New York.
14. Herman, E. R., and Gloyna, E. F. Waste Stabilization Ponds. I. Experimental investigations. II. Field practices. III. Formulation of design equations. Sewage Ind. Wastes. pp. 30, 511, 646, 963.
15. Mancini, J. L., and Barnhart, E. L. Industrial Waste Treatment in Aerated Lagoons. Advances in Water Quality Improvement, (Ed. by Gloyna, E. F., and Eckenfelder, W. W., Jr.) University of Texas Press, Austin, Texas, 1968.
16. Adams, C. E., Jr., and Eckenfelder, W. W., Jr. Process Design Techniques for Industrial Waste Treatment. 1974. pp.181.
17. Methods for Chemical Analysis of Water and Wastes. Methods Development and Quality Assurance Research Laboratory, U.S. E.P.A., Wash. D.C., EPA-625/6-74-003.
18. Aguire, J., and Gloyna, E. F. Design Guides for Biological Wastewater Treatment Process: Waste Stabilization Pond Performance. University of Texas, Austin, Texas, 1970.
19. Neel, J. D., McDermott, J. H., and Monday, C. A. Experimental Lagooning of Raw Sewage at Fayette, Missouri. Jour. of Water Poll. Cont. Fed., 33(6):603-641, 1961.
20. Sewage Stabilization Ponds in the Dakota: An evaluation of the use of stabilization ponds as a method of sewage disposal in cold climates. Vol. 1&2, Joint Report: N & S Dakotas Dept. of Health, Robert A. Taft Sanitary Engineering Center, Cincinnati, Ohio, 1975.

APPENDIX A

SUMMARY OF A COMPARATIVE STUDY OF PARAMETERS USED FOR MEASURING WASTE TREATMENT LAGOON PERFORMANCE

Appendix A is a summary of the determination of meaningful parameters that the author proposed to be used as routine operational tests. Table A-1 is a tabulation of the parameters that were measured at five lagoon systems. Panama Lagoons are U.S. Army lagoons in the Canal Zone. (5) Austin Lagoons are experimental lagoons. (18) Fayette and South Dakota lagoons are both municipal lagoons. (19, 20)

Table A-2 is the result of determination of tests necessary for the evaluation of performance of the various type of lagoons. This table is developed as a result of information gathered from other lagoon studies and this project. In Table A-2, the most important test as indicated are also the tests proposed to be used as routine operational tests. These tests are important to both design evaluation and routine operational control. The second group of tests, rated as important are pertinent to design evaluation considerations. The third group or the less important tests are the ones that are not apparent in their effect on design evaluation, but their overall important should not be entirely neglected.

In Table A-2, the noticeable absence of the nutrient tests among the important tests is due to the fact that in waste treatment lagoons treating primarily domestic waste, nutrients are not limiting factors in regard to lagoon performance. The exclusion of the dissolved oxygen test from the most important test group is that dissolved oxygen is usually at a reasonably high level and therefore it is not necessary to test it routinely.

TABLE A-1. COMPARISON OF PARAMETERS MEASURED AT FIVE LAGOON SYSTEMS

PARAMETERS	BIXBY LAGOON	PANAMA LAGOON	AUSTIN LAGOON	FAYETTE LAGOON	SO. DAKOTA LAGOON
pH	X	X	X	X	X
Acidity		X*			
Alkalinity	X	X		X	X
Temperature	X	X	X	X	X
DO	X	X	X	X	X
Total BOD ₅	X	X	X	X	X
Soluble BOD ₅	X				
Total S.S.	X	X*	X		X
Volatile S.S.	X	X*			
Settleable S.		X*			
Total COD	X	X	X		
Soluble COD	X				
Phosphorus	X	X		X	X
TKN	X				
Ammonia-N	X	X		X	X
Nitrate-N	X*	X		X	
Nitrite-N	X*	X*		X	X
Organic-N		X		X	
Algal Count		X			
Fecal Coli.	X	X	X		
Total Coli.	X	X	X	X	X
Flow, Influent	X				X
Flow, Effluent					
Other	a		TOC	b	c

*Tests were discontinued later.

a - Algal determination.

b - Chloride, detergent.

c - Turbidity, chloride, sulfide.

TABLE A-2. PRELIMINARY IDENTIFICATION OF TESTS NECESSARY FOR THE
PERFORMANCE EVALUATION OF EACH TYPE OF LAGOON.

TESTS	NON-AERATED LAGOONS				AERATED LAGOONS		
	ANAEROBIC	AEROBIC	FACULTATIVE	MATURATION	AEROBIC	FACULTATIVE	EXT-AERATION
pH	X	X	X	X	X	X	X
Acidity	*	*	*		*	*	*
Alkalinity		*	*		*	*	*
Temperature	X	X	X	X	X	X	X
DO, Effluent		X	X	*	*	*	*
Total BOD ₅	X	X	X	X	X	X	X
Soluble BOD ₅	X	X	X	X	X	X	X
Total S.S.	*	X	X	X	X	X	X
Volatile S.S.	*	X	X		X	X	X
Total COD		X	X		X	X	X
Soluble COD		X	X		X	X	X
Phosphorus			X				
Ammonia-N							
TKN							
Nitrate-N							
Nitrite-N							
TOC							
Sulfide	X		*				
Turbidity			*	*			
Algal Count		X	X		X	X	X
Fecal Coli.		*	*	*	*	*	*
Total Coli.		X	X	X	X	X	X
Flow		X	X	X	X	X	X
Odor	X						

Unless indicated, tests should be performed at both influent and effluent points.
X - Most important tests. X - Important tests. * - Less important tests.

APPENDIX B

RESULTS OF REGRESSION ANALYSIS

TABLE B-1. SUMMARY OF PRELIMINARY REGRESSION DATA, JAN.-DEC. 1976.

Characterization of Waste

Dependent Variable	Variables Attempted In Regression	Variables Selected In Regression	1	2	F.value	Confidence Level	Standard Error
VO11, COD IN	VO07 TKN IN VO09 TOTAL BOD IN VO10 SOL BOD IN VO13 TSS IN VO15 FLOW;GPD	VO13 TSS IN VO09 TOTAL BOD IN VO07 TKN IN	3	74	6.75979	99.95	121.88
VO13 TSS IN	VO07 TKN IN VO09 TOTAL BOD IN VO15 FLOW;GPD	VO07 TKN IN	1	76	2.80299	90.18	139.3
VO14 VSS IN	VO13 TSS IN	VO13 TSS IN	1	76	213.6694	99.99	54.67
VO07 TKN IN	VO06 AMMONIA IN	VO06 AMMONIA IN	1	76	4.73048	96.72	10.77
VO07 TKN IN	VO09 TOTAL BOD IN VO13 TSS IN VO15 FLOW;GPD	VO15 FLOW;GPD	1	76	4.46520	96.21	10.79

TABLE B-2. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, JAN.-DEC. 1976.

<u>Characterization of Waste</u>					
Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
VO11 TOTAL COD IN	VO07 TKN IN VC09 TOTAL BOD IN VO13 TSS IN	2.371184 0.2984597 0.3044201 356.9879	99.99	0.204	125.70
VO13 TSS IN	VO07 TKN IN	2.750073 143.9223	98.18	0.046	139.34
2 VO11 TOTAL COD IN	VO09 TOTAL BOD IN	0.2992710 545.3842	95.65	0.033	140.23
VC07 TKN	VO15 FLOW GPD	-7.6671401E-05 56.58597	99.98	0.102	11.5
VO14 VSS IN	VO13 TSS IN	0.7334903 -2.483477	99.99	0.777	55.45
VO07 TKN IN	VO06 AMMONIA IN	0.4309353 33.3799	99.37	0.061	11.97
VO10 SOL BOD IN	VO09 TOTAL BOD IN	0.2463666 63.27534	99.99	0.155	52.04
VO12 SOL COD IN	VO11 TOTAL COD IN	0.1488168 166.5253	99.97	0.094	67.02

TABLE B-3. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, JAN., FEB., DEC. 1976

<u>Characterization of Waste</u>		Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
Dependent Variables	Independent Variables				
VO11 TOTAL COD IN	VO07 TKN IN	2.493559	64.02	0.145	144.99
	VO09 TOTAL BOD IN	3.613323E-02			
	VO13 TSS IN	0.5352311 388.1805			
VO13 TSS IN	VO07 TKN IN	1.719844 178.1662	32.51	0.006	131.1
VO11 TOTAL COD IN	VO09 TOTAL BOD IN	-----NO	CORRELATION-----		
VO07 TKN IN	VO15 FLOW; GPD	-----NO	CORRELATION-----		
VO14 VSS IN	VO13 TSS IN	0.7976157 -21.15965	99.99	0.888	37.88
VO07 TKN IN	VO06 AMMONIA IN	0.3753874 32.51137	85.24	0.061	5.97
VO10 SOL BOD IN	VO09 TOTAL BOD IN	0.2987844 91.34779	99.74	0.280	55.67
VO12 SOL COD IN	VO11 TOTAL COD IN	7.9981E-02 253.0131	68.78	0.03	71.74

TABLE B-4. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, MARCH-MAY 1976.

<u>Characterization of Waste</u>					
Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
VO11 TOTAL COD IN	VO07 TKN IN VO09 TOTAL BOD IN VO13 TSS IN	0.3534145 -1.9700766E-02 0.4801225 469.8646	97.8	0.361	100.21
VO13 TSS IN	VO07 TKN IN	2.106279 210.7788	86.7	0.076	136.1
64 VO11 TOTAL COD IN	VO09 TOTAL BOD IN	-0.5635178 852.4	92.83	0.104	119.5
VO07 TKN IN	VO15 FLOW;GPD	-1.1796518E-04 67.06766	98.6	0.162	18.1
VO14 VSS IN	VO13 TSS IN	0.6834089 0.8095333	99.99	0.666	68.9
VO07 TKN IN	VO06 AMMONIA IN	0.9821723 25.34194	90.2	0.083	19.66
VO10 SOL BOD IN	VO09 TOTAL BOD IN	0.2342563 59.14523	91.32	0.098	50.09
VO12 SOL COD IN	VO11 TOTAL COD IN	0.2247963 102.9625	98.78	0.162	72.63

TABLE B-5. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, JUNE-AUG. 1976.

<u>Characterization of Waste</u>		Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
Dependent Variables	Independent Variables				
VO11 TOTAL COD IN	VO07 TKN IN VO09 TOTAL BOD IN VO13 TSS IN	-0.2361691 0.6596316 0.1671231 334.56	99.29	0.377	80.53
VO13 TSS IN	VO07 TKN IN	-1.534388 323.6429	34.9	0.007	149.37
VO11 TOTAL COD IN	VO09 TOTAL BOD IN	0.7103718 349.699	99.97	0.351	85.23
VO07 TKN IN	VO15 FLOW;GPD	-8.72784E-05 57.06159	99.96	0.352	6.63
VO14 VSS IN	VO13 TSS IN	0.8745831 -30.27953	99.99	0.884	46.43
VO07 TKN IN	VO06 AMMONIA IN	0.8588041 17.36009	99.98	0.465	6.37
VO10 SOL BOD IN	VO09 TOTAL BOD IN	0.2835594 28.11254	99.97	0.327	39.76
VO12 SOL COD IN	VO11 TOTAL COD IN	0.3404716 45.43303	99.92	0.284	55.62

TABLE B-6. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, SEPT.-NOV. 1976.

Characterization of Waste					
Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	r^2	Standard Error
VO11 TOTAL COD IN	VO07 TKN IN	10.23053	99.99	0.778	72.21
	VO09 TOTAL BOD IN	0.5929619			
	VO13 TSS IN	0.2321051			
		10.07128			
VO13 TSS IN	VO07 TKN IN	13.85392 -398.6944	99.91	0.376	119.2
VO11 TOTAL COD IN	VO09 TOTAL BOD IN	1.698052 147.4821	99.99	0.573	92.1
VO07 TKN IN	VO15 FLOW;GPD	-9.51804E-05 59.70244	91.53	0.114	6.45
VO14 VSS IN	VO13 TSS IN	0.5878145 40.49858	99.99	0.674	57.96
VO07 TKN IN	VO06 AMMONIA IN	0.6176733 26.20884	99.87	0.355	5.59
VO10 SOL BOD IN	VO09 TOTAL BOD IN	9.628862E-02 109.1254	77.85	0.055	28.07
VO12 SOL COD IN	VO11 TOTAL COD IN	9.641165E-02 184.2956	95.31	0.144	30.22

TABLE B-7. SUMMARY OF STEPWISE REGRESSION DATA, JAN.-DEC. 1976

Lagoon Efficiencies

Dependent Variable	Variables Attempted In Regression	Variables Selected In Regression	1	2	F.value	Confidence Level	Standard Error
V046 BOD EFFICIENCY CELL 1	V019 TEMP MP V009 TOTAL BOD IN V013 TSS IN	V019 TEMP MP V009 TOTAL BOD IN V011 TOTAL COD IN	3	64	3.61696	98.2	8.1
V047 BOD EFFICIENCY CELL 2	V025 TSS MP V031 TEMP EFF V023 TOTAL COD MP V021 TOTAL BOD MP	V025 TSS MP V031 TEMP EFF V023 TOTAL COD MP V021 TOTAL BOD MP	4	63	9.81592	99.99	20.45
V048 BOD EFFICIENCY TOTAL	V009 TOTAL BOD IN V019 TEMP MP V011 TOTAL COD V031 TEMP EFF	V031 TEMP EFF V011 TOTAL COD IN V009 TOTAL BOD IN	3	64	3.05528	96.53	5.05
V049 COD EFFICIENCY CELL 1	V011 TOTAL COD IN V009 TOTAL BOD IN V019 TEMP MP V013 TSS IN	V011 TOTAL COD IN	1	66	2.54154	88.43	10.35
V050 COD EFFICIENCY CELL 2	V025 TSS MP V023 TOTAL COD MP V031 TEMP EFF V021 TOTAL BOD MP	V025 TSS MP V023 TOTAL COD MP	2	65	7.23842	99.85	20.11

TABLE B-7. Cont'd.

<u>Lagoon Efficiencies</u>							
Dependent Variable	Variables Attempted In Regression	Variables Selected In Regression	1	2	F.value	Confidence Level	Standard Error
VO51 COD EFFICIENCY TOTAL	VO13 TSS IN VO11 TOTAL COD IN VO19 TEMP MP VO31 TEMP EFF VO09 TOTAL BOD IN	VO13 TSS IN	1	66	1.19143	72.09	7.04
VO52 TSS EFFICIENCY CELL 1	VO13 TSS IN VO11 TOTAL COD IN VO09 TOTAL BOD IN VO19 TEMP MP	VO09 TOTAL BOD IN VO11 TOTAL COD IN VO13 TSS IN	3	64	15.01452	99.99	18.66
VO53 TSS EFFICIENCY CELL 2	VO25 TSS MP VO31 TEMP EFF VO23 TOTAL COD MP VO21 TOTAL BOD MP	VO23 TOTAL COD MP VO31 TEMP EFF VO25 TSS MP	3	64	13.09213	99.99	69.67
VO54 TSS EFFICIENCY TOTAL	VO13 TSS IN VO31 TEMP EFF VO11 TOTAL COD IN VO19 TEMP MP VO09 TOTAL BOD IN	VO13 TSS IN VO31 TEMP EFF VO11 TOTAL COD IN	3	64	9.39776	99.99	11.76
VO55 TKN EFFICIENCY TOTAL	VO19 TEMP MP VO11 TOTAL COD IN VO09 TOTAL BOD IN VO13 TSS IN VO07 TKN IN	VO09 TOTAL BOD IN VO11 TOTAL COD IN VO13 TSS IN VO19 TEMP MP	4	63	4.97705	99.85	5.31

TABLE B-8. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, JAN.-DEC. 1976.

<u>Lagoon Efficiencies</u>					
Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
V046 BOD EFFICIENCY CELL 1	V019 TEMP MP V057 AMT. BOD IN	0.3096749 -6.367396E-08 75.04213	98.94	0.085	9.04
V047 BOD EFFICIENCY CELL 2	V031 TEMP EFF V063 AMT BOD MP V067 AMT TSS MP	0.3956547 4.723639E-07 1.0786696E-06 37.13798	99.96	0.192	21.77
3 V048 BOD EFFICIENCY TOTAL	V031 TEMP EFF	0.1714976 89.1727	99.79	0.089	4.93
V050 COD EFFICIENCY CELL 2	V065 AMT COD MP V067 AMT TSS MP V031 TEMP EFF	6.239130E-07 2.380887E-07 0.23101231 22.23239	99.99	0.198	19.40
V052 TSS EFFICIENCY CELL 1	V057 AMT BOD IN V061 AMT TSS IN V019 TEMP MP	-2.123962E-07 4.116586E-07 0.6153472 44.33618	99.99	0.235	21.90
V053 TSS EFFICIENCY CELL 2	V065 AMT COD IN V067 AMT TSS MP V031 TEMP EFF	3.19013E-08 5.131307E-06 -2.895973 -0.4622752	99.99	0.366	64.41

TABLE B-8. Cont'd.

<u>Lagoon Efficiencies</u>					
Dependent	Independent	Coefficient In	Confidence	2	Standard
Variables	Variables	Regression	Level	r	Error
		Equation			
VO54 TSS	VO31 TEMP EFF	-0.2610138	99.99	0.217	11.914
EFFICIENCY	VO61 AMT TSS IN	2.30723E-07			
TOTAL	VO59 AMT COD IN	-4.51608E-09			
		72.50847			
VO55 TKN	VO19 TEMP MP	0.2649953	97.36	0.094	7.719
EFFICIENCY	VO57 AMT BOD IN	-6.801801E-08			
TOTAL	VO56 AMT TKN IN	2.844735E-07			
		81.26784			

TABLE B-9. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, JAN., FEB., DEC. 1976

<u>Lagoon Efficiencies</u>					
Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
V046 BOD EFFICIENCY CELL 1	V019 TEMP MP V057 AMT BOD IN	1.804974 1.1025123E-07 63.10404	87.93	0.232	8.05
V047 BOD EFFICIENCY CELL 2	V031 TEMP EFF V063 AMT BOD MP V067 AMT TSS MP	14.01739 3.0296144E-06 9.103946E-07 -66.25088	96.44	0.560	18.83
V048 BOD EFFICIENCY TOTAL	V031 TEMP EFF	0.5952108 85.31143	69.36	0.055	7.40
V050 COD EFFICIENCY CELL 2	V065 AMT COD MP V067 AMT TSS MP V031 TEMP EFF	8.2201986E-07 1.1222128E-06 -1.238537 19.16636	97.57	0.456	9.91
V052 TSS EFFICIENCY CELL 1	V057 AMT BOD IN V061 AMT TSS IN V019 TEMP MP	-2.28154E-07 5.0686795E-07 -3.336686 81.92313	70.41	0.324	14.76
V053 TSS EFFICIENCY CELL 2	V065 AMT COD MP	-----NO CORRELATION-----			
V054 TSS EFFICIENCY TOTAL	V031 TEMP EFF V061 AMT TSS IN V059 AMT COD IN	-.6839095 3.565298E-07 -5.358666E-08 75.07638	97.7	0.483	7.88

TABLE B-9. Cont'd.

Lagoon Efficiencies

Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
V055 TKN EFFICIENCY TOTAL	V019 TEMP MP	-0.721412	93.6	0.395	5.44
	V057 AMT BOD IN	4.394689E-08			
	V056 AMT TKN IN	-1.449E-06			
		91.88497			

TABLE B-10. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, MARCH-MAY 1976.

<u>Lagoon Efficiencies</u>					
Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
V046 BOD EFFICIENCY CELL 1	V019 TEMP MP V057 AMT BOD IN	-1.521782 -1.42388E-07 115.2151	99.16	0.289	6.08
V047 BOD EFFICIENCY CELL 2	V031 TEMP EFF V063 AMT BOD MP V067 AMT TSS MP	4.286493 3.7664E-07 2.14875E-06 -52.31941	99.10	0.377	21.95
73 V048 BOD EFFICIENCY TOTAL	V031 TEMP EFF	1.388996 65.21324	98.99	0.221	3.87
V050 COD EFFICIENCY CELL 2	V065 AMT COD MP V067 AMT TSS MP V031 TEMP EFF	7.691299E-07 -5.05891E-07 -0.239462 25.29951	51.28	0.098	22.22
V052 TSS EFFICIENCY CELL 1	V057 AMT BOD IN V061 AMT TSS IN V019 TEMP MP	-3.86296E-07 4.993186E-07 2.306771 26.59588	99.62	0.450	13.66
V053 TSS EFFICIENCY CELL 2	V065 AMT COD MP V067 AMT TSS MP V031 TEMP EFF	-2.403267E-07 1.53379E-06 2.756489 -11.84721	76.68	0.267	14.49

TABLE B-10. Cont'd.

<u>Lagoon Efficiencies</u>					
Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	² r	Standard Error
VO54 TSS EFFICIENCY TOTAL	VO31 TEMP EFF	0.931586	88.01	0.205	13.97
	VO61 AMT TSS IN	2.738169E-07			
	VO59 AMT COD IN	-5.508731E-09 48.461			
VO55 TKN EFFICIENCY TOTAL	VO19 TEMP MP	3.829024	99.99	0.553	6.59
	VO57 AMT BOD IN	-1.2462157E-07			
	VO56 AMT TKN IN	1.154889E-06 3.188585			

TABLE B-11. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, JUNE-AUG. 1976.

<u>Lagoon Efficiencies</u>					
Dependent Variable	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
VO46 BOD EFFICIENCY CELL 1	VO19 TEMP MP VO57 AMT BOD IN	3.088944 -5.1052676E-08 -3.332165	98.21	0.250	6.88
VO47 BOD EFFICIENCY CELL 2	VO31 TEMP EFF VO63 AMT BOD MP VO67 AMT TSS MP	2.961521 1.561813E-06 -30.45803	94.7	0.301	11.86
75 VO48 BOD EFFICIENCY TOTAL	VO31 TEMP EFF	0.2634126 86.67577	69.51	0.038	1.99
VO50 COD EFFICIENCY CELL 2	VO65 AMT COD MP VO67 AMT TSS MP VO31 TEMP EFF	8.776925E-07 -1.046776E-07 3.98633 -85.51623	98.17	0.348	17.5
VO52 TSS EFFICIENCY CELL 1	VO57 AMT BOD IN VO61 AMT TSS IN VO19 TEMP MP	-4.82136E-08 1.803818E-07 -3.558946 165.5479	62.11	0.128	20.47
VO53 TSS EFFICIENCY CELL 2	VO65 AMT COD MP VO67 AMT TSS MP VO31 TEMP EFF	-3.37821E-07 2.252324E-06 -18.84411 549.2112	99.47	0.741	17.61

TABLE B-11. Cont'd.

<u>Lagoon Efficiencies</u>					
Dependent Variable	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
VO54 TSS EFFICIENCY TOTAL	VO31 TEMP EFF	-2.323927	96.80	0.336	13.54
	VO61 AMT TSS IN	7.79934E-08			
	VO59 AMT COD IN	1.476833E-07			
		123.4936			
VO55 TKN EFFICIENCY TOTAL	VO19 TEMP MP	0.3588631	96.21	0.282	1.88
	VO57 AMT BOD IN	7.952106E-09			
	VO56 AMT TKN IN	6.066973E-07			
		75.50454			

TABLE B-12. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, SEPT.-NOV. 1976.

Lagoon Efficiencies					
Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
VO46 BOD EFFICIENCY CELL 1	VO19 TEMP MP VO57 AMT BOD IN	0.2872387 2.56492E-07 52.57227	84.0	0.160	3.85
VO47 BOD EFFICIENCY CELL 2	VO31 TEMP EFF VO63 AMT BOD MP BO67 AMT TSS MP	-----NO CORRELATION-----			
77 VO48 BOD EFFICIENCY TOTAL	VO31 TEMP EFF	-0.3122703 96.53475	88.93	0.107	4.85
VO50 COD EFFICIENCY CELL 2	VO65 AMT COD MP VO67 AMT TSS MP VO31 TEMP EFF	5.844505E-07 -4.5638265E-07 1.262185 31.74012	99.99	0.709	7.54
VO52 TSS EFFICIENCY CELL 1	VO51 AMT BOD IN VO61 AMT TSS IN VO19 TEMP MP	-1.007704E-06 9.188986E-07 -0.4569783 63.36416	99.62	0.517	16.39
VO53 TSS EFFICIENCY CELL 2	VO65 AMT COD MP VO67 AMT TSS MP VO31 TEMP EFF	8.667412E-08 6.226111E-07 0.7175017 37.84197	82.81	0.226	15.60

TABLE B-12. Cont'd.

Lagoon Efficiencies

Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	² r	Standard Error
V054 TSS EFFICIENCY TOTAL	V031 TEMP EFF	9.849385E-03	99.96	0.623	6.84
	V061 AMT TSS IN	5.643182E-07			
	V059 AMT COD IN	-4.011315E-07			
		98.28307			
V055 TKN EFFICIENCY TOTAL	V019 TEMP MP	0.1740435	68.45	0.183	2.40
	V057 AMT BOD IN	-1.292232E-08			
	V056 AMT TKN IN	3.34404E-07			
		84.82043			

TABLE B-13. SUMMARY OF STEPWISE REGRESSION DATA, JAN.-DEC. 1976

Predicting Mid-Point Properties

Dependent Variable	Variables Attempted In Regression	Variables Selected In Regression	1	2	F.value	Confidence Level	Standard Error
VO21 TOTAL BOD MP	VO09 TOTAL BOD IN VO11 TOTAL COD IN VO13 TSS IN VO19 TEMP MP	VO09 TOTAL BOD IN VO11 TOTAL COD IN VO13 TSS IN	3	56	8.18624	99.98	30.35
VO23 TOTAL COD MP	VO09 TOTAL BOD IN VO11 TOTAL COD IN VO13 TSS IN VO19 TEMP MP	VO11 TOTAL COD IN	1	58	4.56314	96.31	73.07
VO25 TSS MP	VO09 TOTAL BOD IN VO11 TOTAL COD IN VO13 TSS IN VO19 TEMP MP	VO11 TOTAL COD IN VO19 TEMP MP	2	57	6.60485	99.73	43.74
VO22 SOL BOD MP	VO09 TOTAL BOD IN VO11 TOTAL COD IN VO13 TSS IN VO14 VSS IN VO19 TEMP MP	VO09 TOTAL BOD IN VO11 TOTAL COD IN VO19 TEMP MP VO13 TSS IN	4	55	12.84829	99.99	18.89
VO24 SOL COD MP	VO09 TOTAL BOD IN VO11 TOTAL COD IN VO13 TSS IN VO14 VSS IN VO19 TEMP MP	VO09 TOTAL BOD IN	1	58	1.11408	70.44	41.3

TABLE B-14. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, JAN.-DEC. 1976.

<u>Predicting Mid-point Properties</u>					
Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
V021 TOTAL BOD MP	V061 AMT TSS IN V057 AMT BOD IN V019 TEMP MP	-2.431649E-07 9.5585035E-07 -1.479171 69.74489	99.99	0.305	29.67
V023 TOTAL COD MP	V061 AMT TSS IN V059 AMT COD IN	-4.88751E-07 7.7177165E-07 149.7909	98.70	0.073	67.46
V025 TSS MP	V019 TEMP MP V059 AMT COD IN V058 AMT SOL BOD IN V061 AMT TSS IN	-2.177494 4.681205E-07 -9.369269E-07 6.6979104E-08 101.0664	99.96	0.220	41.47
V022 SOL BOD MP	V019 TEMP MP V058 AMT SOL BOD IN	-0.7011226 1.55455E-06 2.16999	99.99	0.308	20.67
V024 SOL COD MP	V060 AMT SOL COD IN	4.882489E-07 51.99619	90.89	0.024	33.61

TABLE B-15. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, JAN., FEB., DEC. 1976.

Predicting Mid-point Properties					
Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
VO21 TOTAL BOD MP	VO61 AMT TSS IN VO57 AMT BOD IN VO19 TEMP MP	-9.40834E-07 6.278336E-07 -11.27744 149.7123	99.5	0.707	24.8
VO23 TOTAL COD MP	VO61 AMT TSS IN VO59 AMT COD IN	-----NO CORRELATION-----			
VO25 TSS MP	VO19 TEMP MP VO59 AMT COD IN VO58 AMT SOL BOD IN VO61 AMT TSS IN	5.253647 -2.828018E-07 -1.082674E-06 1.8908713E-06 38.67576	92.0	0.610	24.23
VO22 SOL BOD MP	VO19 TEMP MP VO58 AMT SOL BOD IN	-7.858441 2.230613E-06 45.75013	99.99	0.717	21.71
VO24 SOL COD MP	VO60 AMT SOL COD IN	9.633473E-07 42.25974	94.15	0.107	27.65

TABLE B-16. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, MARCH-MAY 1976.

Predicting Mid-point properties

Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
V021 TOTAL BOD MP	V061 AMT TSS IN V057 AMT BOD IN V019 TEMP MP	-2.679179E-07 9.8079974E-07 7.244122 -96.22798	99.54	0.426	25.23
V023 TOTAL COD MP	V061 AMT TSS IN V059 AMT COD IN	-4.1396E-07 4.450183E-07 189.0472	23.3	0.025	59.60
V025 TSS MP	V019 TEMP MP V059 AMT COD IN V058 AMT SOL BOD IN V061 AMT TSS IN	-----NO CORRELATION-----			
V022 SOL BOD MP	V019 TEMP MP V058 AMT SOL BOD IN	-3.470565 8.7329E-07 73.15219	97.74	0.253	16.01
V024 SOL COD MP	V060 AMT SOL COD IN	-----NO CORRELATION-----			

TABLE B-17. RESULTS OF REGRESSION VARIABLES SELECTED
AFTER STEPWISE REGRESSION, JUNE-AUG. 1976.

Predicting Mid-point Properties

Dependent Variable	Independent Variables	Coefficient In Regression Equation	Confidence Level	r^2	Standard. Error
V021 TOTAL BOD MP	V061 AMT TSS IN V057 AMT BOD IN V019 TEMP MP	-8.867321E-08 4.688706E-07 -10.35434 333.7117	99.68	0.419	20.06
V023 TOTAL COD MP	V061 AMT TSS IN V059 AMT COD IN	-6.804419E-08 6.89286E-07 96.34911	99.04	0.291	38.7
V025 TSS MP	V019 TEMP MP V059 AMT COD IN V058 AMT SOL BOD IN V061 AMT TSS IN	2.851196 5.24489E-08 9.819212E-07 2.515837E-07 -48.87567	77.87	0.229	31.39
V022 SOL BOD MP	V019 TEMP MP V058 AMT SOL BOD IN	0.3077798 5.2027359E-07 -5.515419	73.74	0.105	11.69
V024 SOL COD MP	V060 AMT SOL COD IN	4.8975877E-07 38.53497	99.26	0.229	12.87

TABLE B-18. RESULTS OF REGRESSION VARIABLES SELECTED
AFTER STEPWISE REGRESSION, SEPT.-NOV. 1976.

Predicting Mid-point Properties

Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
V021 TOTAL BOD MP	V061 AMT TSS IN V057 AMT BOD IN V019 TEMP MP	-----NO CORRELATION-----			
V023 TOTAL COD MP	V061 AMT TSS IN V059 AMT COD IN	-----NO CORRELATION-----			
V025 TSS MP	V019 TEMP MP V059 AMT COD IN V058 AMT SOL BOD IN V061 AMT TSS IN	1.121863 1.386452E-06 -4.707157E-06 9.352955E-07 45.16838	99.21	0.592	33.28
V022 SOL BOD MP	V019 TEMP MP V058 AMT SOL BOD IN	4.5705377E-02 2.30846E-07 0.8368860	67.33	0.130	3.31
V024 SOL COD MP	V060 AMT SOL COD IN	-----NO CORRELATION-----			

TABLE B-19. SUMMARY OF STEPWISE REGRESSION DATA, JAN.-DEC. 1976.

Predicting Effluent Properties

Dependent Variable	Variables Attempted In Regression	Variables Selected In Regression	1	2	F. value	Confidence Level	Standard Error
V037 TOTAL BOD EFF	V009 TOTAL BOD IN V011 TOTAL COD IN V013 TSS IN V019 TEMP MP V031 TEMP EFF	V009 TOTAL BOD IN V019 TEMP MP	2	48	8.96151	99.95	21.49
V038 SOL BOD EFF	V010 SOL BOD IN V012 SOL COD IN V014 VSS IN V019 TEMP MP V031 TEMP EFF	V010 SOL BOD IN	1	49	27.85733	99.99	19.83
V039 TOTAL COD EFF	V009 TOTAL BOD IN V011 TOTAL COD IN V013 TSS IN V019 TEMP MP V031 TEMP EFF	V011 TOTAL COD IN	1	49	2.75074	89.64	48.62
V040 SOL COD EFF	V010 SOL BOD IN V012 SOL COD IN V014 VSS IN V019 TEMP MP V031 TEMP EFF	V010 SOL BOD IN V012 SOL COD IN V019 TEMP MP V031 TEMP EFF	4	46	4.39372	99.15	28.57

TABLE B-19. Cont'd.

Predicting Effluent Properties

Dependent Variable	Variables Attempted In Regression	Variables Selected In Regression	1	2	F. value	Confidence Level	Standard Error
VO41 TSS EFF	VO09 TOTAL BOD IN VO11 TOTAL COD IN VO13 TSS IN VO19 TEMP MP VO31 TEMP EFF	VO13 TSS IN	1	49	5.69229	97.91	29.55
VO42 VSS EFF	VO09 TOTAL BOD IN VO11 TOTAL COD IN VO13 TSS IN VO14 VSS IN	VO11 TOTAL COD IN VO14 VSS IN	2	48	6.57962	99.7	15.93
VO35 TKN EFF	VO07 TKN IN VO09 TOTAL BOD IN VO11 TOTAL COD IN VO13 TSS IN VO19 TEMP MP VO31 TEMP EFF	VO07 TKN IN VO09 TOTAL BOD IN VO11 TOTAL COD IN VO19 TEMP MP	4	46	8.34508	99.99	2.58

TABLE B-20. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, JAN.-DEC. 1976.

<u>Predicting Effluent Properties</u>					
Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
V037 TOTAL BOD EFFLUENT	V019 TEMP MP V057 AMT BOD IN V061 AMT TSS IN	-0.6373126 3.0022921E-07 -1.0223558E-08 27.60717	98.36	0.113	20.3
V038 SOL. BOD EFFLUENT	V019 TEMP MP V058 AMT SOL BOD IN V062 AMT VSS IN	-0.1601284 1.4907674E-06 -1.58528E-07 -8.426982	99.99	0.274	18.03
V041 TSS EFFLUENT	V019 TEMP MP V057 AMT BOD IN V061 AMT TSS IN	0.2934921 -6.75198E-07 3.69532E-07 69.96406	99.35	0.137	29.97

NO CONFIDENCE IN PREDICTING EFFLUENT COD'S AND VSS.

TABLE B-21. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, JAN., FEB., DEC. 1976.

<u>Predicting Effluent Properties</u>					
Dependent Variables	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
VC37 TOTAL BOD EFFLUENT	V019 TEMP MP	-15.19848	99.85	0.772	20.89
	V057 AMT BOD IN	-3.177845E-08			
	V061 AMT TSS IN	6.432184E-08			
		147.6917			
V038 SOL BOD EFFLUENT	V019 TEMP MP	-9.064955	99.99	0.869	16.44
	V058 AMT SOL BOD IN	2.341592E-06			
	V062 AMT VSS IN	-2.0301668E-07			
		44.96168			
V040 SOL COD EFFLUENT	V031 TEMP EFF		-----NO CORRELATION-----		
	V060 AMT SOL COD IN				
	V062 AMT VSS IN				
V041 TSS EFFLUENT	V019 TEMP MP	-1.733782	49.98	0.221	21.37
	V057 AMT BOD IN	-7.007306E-07			
	V061 AMT TSS IN	5.268625E-07			
		74.12917			
V042 VSS EFFLUENT	V062 AMT VSS IN	2.4052816E-07	60.38	0.098	15.53
	V059 AMT COD IN	1.098939E-07			
		14.66022			
V035 TKN EFFLUENT	V019 TEMP MP	0.4897082	99.95	0.685	1.83
	V056 AMT TKN IN	9.46846E-07			
	V061 AMT TSS IN	3.23372E-08			
		-1.645129			

TABLE B-22. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, MARCH-MAY 1976.

Predicting Effluent Properties					
Dependent Variables	Independent Variables	Coefficient In Regression Equation	Cofindence Level	2 r	Standard Error
V037 TOTAL BOD EFFLUENT	V019 TEMP MP	-5.0066	71.1	0.160	17.67
	V057 AMT BOD IN	-1.4400566E-07			
	V061 AMT TSS IN	8.4209674E-08 134.0367			
V038 SOL BOD EFFLUENT	V019 TEMP MP	-5.571941	99.62	0.515	8.78
	V058 AMT SOL BOD IN	1.045895E-08			
	V062 AMT VSS IN	-6.901865E-08 125.1794			
68 V040 SOL COD EFFLUENT	V031 TEMP EFF	-3.680056	75.48	0.223	41.74
	V060 AMT SOL COD IN	1.41637E-06			
	V062 AMT VSS IN	-6.485565E-07 126.06			
V041 TSS EFFLUENT	V019 TEMP MP	-4.181593	90.06	0.234	34.8
	V057 AMT BOD IN	-1.08493E-06			
	V061 AMT TSS IN	5.7175E-07 176.1793			
V042 VSS EFFLUENT	V062 AMT VSS IN	6.708066E-07	70.86	0.135	30.62
	V059 AMT COD IN	-4.754626E-07 68.58951			
V035 TKN EFFLUENT	V019 TEMP MP	-2.640331	99.99	0.734	2.80
	V056 AMT TKN IN	7.37957E-07			
	V061 AMT TSS IN	-3.9730322E-08 58.83446			

TABLE B-23. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, JUNE-AUG. 1976.

<u>Predicting Effluent Properties</u>					
Dependent Variable	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
V037 TOTAL BOD EFFLUENT	V019 TEMP MP	-1.129164	53.55	0.103	9.86
	V057 AMT BOD IN	7.621986E-08			
	V061 AMT TSS IN	-8.121767E-08			
		51.02819			
V038 SOL BOD EFFLUENT	V019 TEMP MP	-0.9311389	88.43	0.251	8.82
	V058 AMT SOL BOD IN	5.251931E-07			
	V062 AMT VSS IN	-1.1085798E-07			
		29.93009			
V040 SOL COD EFFLUENT	V031 TEMP EFF	-4.839794	57.06	0.146	24.43
	V060 AMT SOL COD IN	2.76011E-07			
	V062 AMT VSS IN	-2.149446E-07			
		188.377			
V041 TSS EFFLUENT	V019 TEMP MP	3.524894	86.99	0.222	34.65
	V057 AMT BOD IN	-9.85267E-07			
	V061 AMT TSS IN	2.857604E-07			
		-2.68606			
V042 VSS EFFLUENT	V062 AMT VSS IN	-2.1265245E-07	70.4	0.120	26.38
	V059 AMT COD IN	3.6231892E-07			
		6.616256			
V035 TKN EFFLUENT	V019 TEMP MP	0.150057	95.79	0.275	1.031
	V056 AMT TKN IN	-1.2929168E-07			
	V061 AMT TSS IN	-1.168428E-08			
		1.25442			

TABLE B-24. RESULTS OF REGRESSION OF VARIABLES SELECTED
AFTER STEPWISE REGRESSION, SEPT.-NOV. 1976.

Predicting Effluent Properties

Dependent Variable	Independent Variables	Coefficient In Regression Equation	Confidence Level	2 r	Standard Error
V037 TOTAL BOD EFFLUENT	V019 TEMP MP V057 AMT BOD IN V061 AMT TSS IN	1.170972 -4.832518E-08 -4.97638E-07 26.07699	91.7	0.290	14.32
V038 SOL BOD EFFLUENT	V019 TEMP MP V058 AMT SOL BOD IN V062 AMT VSS IN	2.003566 1.55971E-06 -4.129796E-07 -37.4667	98.52	0.472	13.72
V040 SOL COD EFFLUENT	V031 TEMP EFF V060 AMT SOL COD IN V062 AMT VSS IN	-1.03349 -1.098727E-07 3.1701628E-07 55.64379	75.28	0.183	16.92
V041 TSS EFFLUENT	V019 TEMP MP V057 AMT BOD IN V061 AMT TSS IN	-1.836766 3.67628E-07 2.345345E-07 46.46516	99.22	0.475	15.66
V042 VSS EFFLUENT	V062 AMT VSS IN V059 AMT COD IN	-----NO CORRELATION-----			
V035 TKN EFFLUENT	V019 TEMP MP V056 AMT TKN IN V061 AMT TSS IN	-.133172 1.035E-07 -4.2646E-09 6.564393	98.70	0.442	1.00

APPENDIX C

OPERATIONAL PROBLEMS

During the study, several operational problems became evident. The two major problems associated with the lagoon system itself were loss of one of the dikes due to burrowing by muskrats and plugging of the air diffuser system. In one month muskrats completely drained cell number two and one other time the cell level was dropped significantly by someone who inadvertently turned on the irrigation pump used for applying the effluent to adjacent lands. The aerators were not functioning properly for a significant portion of the time. Based on periodic site visits approximately twenty-five percent of the system was not functioning properly about fifty percent of the time. The problems were usually associated with plugging of the aeration tubes.

Other problems associated with the project include:

- a) Freezing of the samplers.
- b) Loss of power to the mobile laboratory and concomitant freezing and breaking of important glassware and loss of chemicals.

APPENDIX D

DAILY DATA

TABLE D-1. INFLUENT TEST DATA OF BIXBY LAGOON, 1976.

S.NO	DATA	PH	ALKALINITY	TOTAL	AMMONIA	KJELDAHL	BOD	BOD	COD	COD	TOTAL	VOLATILE	FLOW	FECAL
	YR MO DT			PHOSPHOROUS	NITROGEN	NITROGEN	TOTAL	SOL.	TOTAL	SOL.	SUSPENDED	SUSPENDED	RATE	COLI
											SOLIDS	SOLIDS	GPD	
A01	76 1 6	7.5	178	31	27.5	48.9	0	0	552	348	694	631	120400	0
A02	76 1 7	6.5	197	37	33.7	48.8	0	0	374	305	181	157	125600	0
A03	76 1 8	6.0	155	31	32.3	48.5	740	232	846	439	392	278	140500	0
A04	76 1 9	6.4	163	35	30.0	44.5	337	253	586	259	0	0	76300	0
A05	76 1 10	6.4	160	33	31.0	42.6	440	253	563	341	0	0	120600	0
A06	76 1 11	6.8	140	38	24.5	43.0	0	0	652	308	234	176	126600	0
A07	76 1 12	7.0	136	30	33.3	45.8	357	248	442	244	157	121	133800	0
A08	76 1 13	6.5	159	35	33.1	46.2	431	229	603	324	304	240	105000	0
A09	76 1 14	6.5	162	33	33.3	45.1	463	233	554	325	0	0	105000	0
A10	76 1 15	6.0	153	34	27.6	43.9	430	260	522	271	190	90	116000	0
A11	76 1 16	6.0	0	31	33.0	48.4	438	228	519	332	380	208	121100	0
A12	76 1 17	7.6	181	36	33.8	53.4	315	220	528	318	0	0	132600	0
A13	76 1 18	7.0	0	34	33.5	48.0	315	170	632	265	357	159	61700	0
A14	76 1 19	7.1	0	33	33.5	47.9	270	205	555	271	404	278	110400	0
A15	76 1 20	7.1	160	33	33.5	47.9	270	175	517	311	420	308	133200	0
A16	76 1 21	7.0	0	32	33.5	47.9	277	173	560	302	387	265	113000	0
A17	76 1 22	6.9	180	32	33.5	47.9	300	194	637	338	185	121	103000	0
A18	76 1 23	7.2	0	31	33.5	47.9	0	0	0	0	0	0	138100	0
A19	76 1 24	7.0	0	35	33.5	47.9	0	0	0	0	0	0	69600	0
A20	76 1 25	7.0	0	40	33.5	47.9	0	0	0	0	0	0	106600	0
A21	76 1 26	7.3	150	34	25.5	33.7	320	238	516	244	285	230	98900	0
A22	76 1 27	6.8	146	34	24.2	33.7	240	156	512	413	275	190	106600	0
A23	76 1 28	6.9	186	40	29.0	30.7	510	189	530	313	328	230	94200	0
A24	76 1 29	6.8	158	40	30.0	30.0	342	252	567	333	0	0	109000	0
B01	76 2 01	6.0	0	0	23.9	46.8	0	0	542	374	336	220	123600	0
B02	76 2 02	6.0	0	0	27.2	42.9	445	282	645	450	210	142	109700	0
B03	76 2 03	6.0	0	0	29.0	41.8	315	237	543	357	232	208	121600	0
B04	76 2 04	6.0	0	0	30.5	42.0	332	185	485	364	156	136	98600	0
B05	76 2 05	6.0	0	0	30.5	42.0	0	0	0	0	0	0	93600	0
B06	76 2 06	6.0	0	0	26.6	54.0	363	255	415	347	208	0	103200	0
B07	76 2 07	6.0	0	0	24.4	51.0	397	262	500	314	0	0	100600	0
C01	76 3 22	6.0	0	36	23.1	97.0	0	0	736	339	357	80	109400	400
C02	76 3 23	7.1	132	40	27.7	51.0	390	273	616	275	119	90	114400	9000
C03	76 3 25	7.2	164	43	24.7	56.5	405	245	636	302	273	140	108000	13000
C04	76 3 26	7.3	192	38	24.0	58.5	540	295	617	466	290	170	120700	19000
C05	76 3 27	6.9	158	25	23.1	56.0	293	224	718	197	240	160	110300	25000
C06	76 3 28	6.0	0	49	25.9	56.0	455	165	0	323	180	90	121600	18000
C07	76 3 29	6.0	0	30	24.9	56.0	400	161	700	328	190	120	175200	5000

Data except for pH, Flow Rate and Fecal Coliform are in mg/l. Fecal Coliform count as /100 ml.

Alkalinity as CaCO₃. Total Phosphorus is measured in terms of Dissolved Ortho-phosphate.

For Flow Rate, 1 GPD = 0.003785 m³/d.

TABLE D-1. Cont'd.

[illegible]

TABLE D-1. Cont'd.

S.NO	DATA	PH	ALKALINITY	TOTAL PHOSPHOROUS	AMMONIA NITROGEN	KJELDMAL NITROGEN	BOD TOTAL	BOD SOL.	CCC TOTAL	COD SOL.	TOTAL SUSPENDED SOLIDS	VOLATILE SUSPENDED SOLIDS	FLOW RATE GPD	FECAL COLI
001	76 7 5	6.4	144	0	48.0	47.0	380	150	475	188	0	0	103500	0
002	76 7 6	6.1	150	0	40.5	40.5	330	190	555	222	216	48	123000	0
003	76 7 7	6.1	140	0	34.5	33.5	330	140	555	208	196	120	140200	0
004	76 7 8	6.5	160	0	0.0	39.5	500	170	848	455	0	0	126700	0
005	76 7 9	6.5	152	0	0.0	41.0	350	350	657	314	228	88	109300	0
006	76 7 10	6.8	133	0	0.0	40.5	340	90	650	300	95	0	115900	0
007	76 7 11	6.8	140	0	0.0	40.5	340	140	650	270	132	0	105900	0
008	76 7 12	6.8	133	0	0.0	40.5	340	140	650	267	363	53	123100	0
009	76 7 13	6.8	133	0	0.0	40.5	340	150	650	267	184	35	125700	0
010	76 7 14	6.8	133	0	0.0	40.5	340	110	650	267	268	166	118700	0
011	76 7 15	6.8	133	0	0.0	40.5	340	160	650	267	464	316	155000	0
012	76 7 16	6.8	133	0	0.0	40.5	340	130	650	267	328	166	127700	0
013	76 7 17	6.8	133	0	0.0	40.5	340	120	650	267	107	40	125800	0
014	76 7 18	6.8	133	0	0.0	40.5	340	130	650	267	184	0	107300	0
015	76 7 19	6.8	133	0	0.0	40.5	340	180	650	267	215	24	123500	0
016	76 7 20	6.8	133	0	0.0	40.5	340	110	650	267	234	22	122400	0
017	76 7 21	6.8	133	0	0.0	40.5	340	130	650	267	208	20	116100	0
018	76 7 22	6.8	133	0	0.0	40.5	340	140	650	267	192	25	170500	0
019	76 7 23	6.8	133	0	0.0	40.5	340	110	650	267	280	25	67100	0
020	76 7 24	6.8	133	0	0.0	40.5	340	0	650	267	0	0	100400	0
021	76 7 25	6.8	133	0	0.0	40.5	340	0	650	267	0	0	122600	0
022	76 7 26	6.8	133	0	0.0	40.5	340	120	650	267	188	16	121900	0
023	76 7 27	6.8	133	0	0.0	40.5	340	80	650	267	488	42	174800	0
024	76 7 28	6.8	133	0	0.0	40.5	340	90	650	267	332	188	227700	0
025	76 7 29	6.8	133	0	0.0	40.5	340	130	650	267	160	116	158200	0
026	76 7 30	6.8	133	0	0.0	40.5	340	90	650	267	215	215	124500	0
027	76 7 31	6.8	133	0	0.0	40.5	340	0	650	267	240	168	233800	0
028	76 7 32	6.8	133	0	0.0	40.5	340	100	650	267	304	296	238800	0
029	76 7 33	6.8	133	0	0.0	40.5	340	100	650	267	772	623	246700	0
030	76 7 34	6.8	133	0	0.0	40.5	340	120	650	267	328	283	247500	0
031	76 7 35	6.8	133	0	0.0	40.5	340	120	650	267	224	189	250400	0
032	76 7 36	6.8	133	0	0.0	40.5	340	90	650	267	96	32	254800	0
033	76 7 37	6.8	133	0	0.0	40.5	340	0	650	267	148	24	234400	0
034	76 7 38	6.8	133	0	0.0	40.5	340	0	650	267	156	48	126900	0
035	76 7 39	6.8	133	0	0.0	40.5	340	140	650	267	124	100	163300	0
036	76 7 40	6.8	133	0	0.0	40.5	340	170	650	267	92	60	126100	0
037	76 7 41	6.8	133	0	0.0	40.5	340	115	650	267	480	120	143400	0

TABLE D-1. Cont'd.

S.NO	DATA YR MO DT	PH	ALKALINITY	TOTAL PHOSPHOROUS	AMMONIA NITROGEN	KJELDHAL NITROGEN	BOD TOTAL	BOD SOL.	CCC TOTAL	COD SOL.	TOTAL SUSPENDED SOLIDS	VOLATILE SUSPENDED SOLIDS	FLOW RATE GPD	FECAL COLI
L001	76 10 23	6.0	156	0	36.0	38.1	410	170	704	268	0	0	116100	0
L002	76 10 24	6.0	156	0	36.4	45.7	370	145	815	260	280	239	118800	0
L003	76 10 25	6.0	156	0	37.0	48.7	385	155	833	274	155	93	123500	0
L004	76 10 26	6.0	156	0	37.3	44.9	350	140	717	307	208	153	137400	0
L005	76 10 27	6.0	156	0	38.8	50.4	365	150	771	264	178	138	112200	0
L006	76 10 28	6.0	156	0	48.9	54.9	360	160	797	288	232	216	128500	0
L007	76 10 29	6.0	156	0	0	0	355	135	750	285	327	239	132900	0
L008	76 10 30	6.0	156	0	0	0	340	140	730	275	197	183	123400	0
L009	76 11 01	6.0	156	0	33.2	0	390	140	855	277	277	213	139000	0
L010	76 11 02	6.0	144	0	24.8	39.6	350	110	632	169	181	171	0	0
L011	76 11 03	6.0	150	0	39.4	47.4	430	120	755	225	243	219	142600	0
L012	76 11 04	6.0	134	0	41.6	44.6	270	120	664	284	246	205	133100	0
L013	76 11 05	6.0	162	0	40.2	50.8	430	130	0	221	561	462	150900	0
L014	76 11 06	6.0	162	0	45.0	54.1	360	160	789	284	177	138	146600	0
L015	76 11 07	6.0	156	0	30.7	44.1	350	150	664	260	160	147	148700	0
L016	76 11 08	6.0	140	0	36.5	45.6	330	130	640	269	146	124	136800	0
L017	76 11 09	6.0	0	0	0	0	350	130	553	250	170	117	148700	0
L018	76 11 10	6.0	0	0	28.1	43.0	310	140	666	236	186	152	152100	0
L019	76 11 11	6.0	0	0	27.5	42.3	360	150	772	241	192	132	153200	0
L020	76 11 12	6.0	112	0	26.7	45.6	0	0	872	242	258	206	108300	0
L021	76 11 13	6.0	112	0	34.0	55.6	410	170	1038	272	327	257	75700	0
L022	76 11 14	6.0	142	0	29.1	44.6	350	140	724	238	184	161	150400	0
L023	76 11 15	6.0	140	0	31.1	46.0	310	180	758	249	272	230	145100	0
L024	76 11 16	6.0	156	0	23.4	35.7	360	160	662	267	134	113	163300	0
L025	76 11 17	6.0	116	0	25.7	38.7	280	190	644	205	0	0	144100	0
L026	76 11 18	6.0	160	0	40.9	55.7	430	0	1040	0	564	456	92700	0
L027	76 11 19	6.0	144	0	31.0	49.4	350	110	700	260	364	344	72000	0
L028	76 11 20	6.0	168	0	26.1	66.6	580	210	1148	314	651	321	151600	0
L029	76 11 21	6.0	166	0	26.2	46.5	310	110	651	232	118	85	134500	0
L030	76 11 22	6.0	156	0	28.1	41.2	330	140	867	241	124	112	134400	0
L031	76 11 23	6.0	148	0	0	38.4	0	0	430	207	119	88	141000	0
L032	76 11 24	6.0	140	0	27.7	43.9	310	135	542	236	130	88	132700	0
L033	76 11 25	6.0	136	0	32.9	55.5	230	110	742	233	163	112	78300	0
L034	76 11 26	6.0	136	0	32.8	40.5	0	0	633	207	118	88	171900	0
L035	76 11 27	6.0	146	0	25.1	50.0	230	90	584	194	206	161	259900	0
L036	76 11 28	6.0	136	0	27.0	44.6	210	60	507	225	132	58	0	0
L037	76 11 29	6.0	156	0	26.4	43.2	0	230	0	208	74	88	134500	0
L038	76 11 30	6.0	150	0	29.3	45.3	310	80	614	196	152	80	0	0

TABLE D-2. MID-POINT TEST DATA OF BIXBY LAGOON, 1976.
(Effluent Cell 1)

S.NO	DATE	ALKALINITY	PH	TEMP.	DISS.	BOD	BOD	COO	CCO	TOTAL	VOLATILE	TOTAL	FECAL	TOTAL
YR	MO	DT		DEG C	OXYGEN	TOTAL	SOLUBLE	TOTAL	SOLUBLE	SUSPENDED	SUSPENDED	PHOSPHOROUS	COLI	COLI
A01	76	66	6	132	6.9	2.0	10.7	0	0	150	85	101	79	40
A02	76	66	7	132	7.0	1.0	13.6	0	0	164	36	63	19	40
A03	76	66	8	132	7.0	1.0	12.6	138	132	150	36	69	19	40
A04	76	66	9	129	6.9	3.0	11.8	95	88	128	73	0	0	40
A05	76	66	10	132	6.8	2.0	12.8	110	88	121	73	0	0	40
A06	76	66	11	132	6.9	4.0	11.1	0	0	2+3	99	54	63	40
A07	76	66	12	136	7.3	5.0	12.2	138	115	143	99	54	63	40
A08	76	66	13	136	7.0	7.0	12.2	138	115	143	99	54	63	40
A09	76	66	14	136	7.0	7.0	12.2	138	115	143	99	54	63	40
A10	76	66	15	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A11	76	66	16	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A12	76	66	17	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A13	76	66	18	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A14	76	66	19	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A15	76	66	20	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A16	76	66	21	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A17	76	66	22	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A18	76	66	23	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A19	76	66	24	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A20	76	66	25	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A21	76	66	26	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A22	76	66	27	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A23	76	66	28	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A24	76	66	29	137	7.3	6.0	11.1	0	0	111	111	0	0	40
A25	76	66	30	137	7.3	6.0	11.1	0	0	111	111	0	0	40
B001	76	66	31	137	7.3	6.0	11.1	0	0	111	111	0	0	40
B002	76	66	32	137	7.3	6.0	11.1	0	0	111	111	0	0	40
B003	76	66	33	137	7.3	6.0	11.1	0	0	111	111	0	0	40
B004	76	66	34	137	7.3	6.0	11.1	0	0	111	111	0	0	40
B005	76	66	35	137	7.3	6.0	11.1	0	0	111	111	0	0	40
B006	76	66	36	137	7.3	6.0	11.1	0	0	111	111	0	0	40
B007	76	66	37	137	7.3	6.0	11.1	0	0	111	111	0	0	40
C001	76	66	38	137	7.3	6.0	11.1	0	0	111	111	0	0	40
C002	76	66	39	137	7.3	6.0	11.1	0	0	111	111	0	0	40
C003	76	66	40	137	7.3	6.0	11.1	0	0	111	111	0	0	40
C004	76	66	41	137	7.3	6.0	11.1	0	0	111	111	0	0	40
C005	76	66	42	137	7.3	6.0	11.1	0	0	111	111	0	0	40
C006	76	66	43	137	7.3	6.0	11.1	0	0	111	111	0	0	40
C007	76	66	44	137	7.3	6.0	11.1	0	0	111	111	0	0	40

TABLE D-2. Cont'd.

S.NO	DATE YR MO DT	ALKALINITY	PH	TEMP. DEG C	DISS. OXYGEN	BOD TOTAL	BOD SOLUBLE	COD TOTAL	COD SOLUBLE	TOTAL SUSPENDED SOLIDS	VOLATILE SUSPENDED SOLIDS	TOTAL PHOSPHOROUS	FECAL COLI	TOTAL COLI
001	76 66 5	182	7.5	18.0	8.6	60	0	236	38	0	0	0	7000	18000
002	76 66 6	98	7.3	19.0	9.5	74	53	262	70	44	0	0	14000	26000
003	76 66 7	144	7.5	18.0	9.1	63	51	246	76	44	0	0	9000	21000
004	76 66 8	160	7.2	20.0	9.0	74	38	174	34	24	0	0	11000	21000
005	76 66 9	160	7.4	19.0	9.3	72	60	157	35	52	24	0	19000	21000
006	76 66 10	0	7.0	19.3	9.3	76	34	327	0	48	28	0	11000	21000
007	76 66 11	0	7.0	20.0	9.4	58	24	287	154	81	69	0	9000	19000
008	76 66 12	158	7.1	19.0	8.2	58	24	283	246	40	0	0	9000	19000
009	76 66 13	172	6.9	20.0	8.9	54	21	153	0	47	37	0	0	0
010	76 66 14	160	6.9	21.0	8.9	150	6	200	64	119	74	0	9000	17000
011	76 66 15	160	6.8	20.0	8.8	82	15	182	0	67	22	0	15000	23000
012	76 66 16	66	7.0	20.0	8.5	96	22	228	61	103	81	0	25000	0
013	76 66 17	140	6.9	20.0	8.2	132	6	193	0	111	69	0	0	57000
014	76 66 18	130	6.9	20.0	8.2	110	6	207	0	76	69	0	1800	36000
015	76 66 19	0	6.0	20.0	8.0	99	10	210	158	51	69	0	0	54000
016	76 66 20	0	6.0	20.0	8.0	0	0	190	44	110	78	0	2900	56000
017	76 66 21	130	6.7	21.0	8.1	128	0	183	0	88	0	0	10000	19000
018	76 66 22	88	6.5	20.0	7.9	88	36	217	0	88	0	0	40000	52000
019	76 66 23	90	6.5	20.0	7.9	123	0	198	0	0	0	0	16000	41000
020	76 66 24	72	6.4	20.0	6.6	111	0	214	60	50	0	0	20000	52000
021	76 66 25	54	6.7	19.0	7.2	90	27	148	14	118	74	0	20000	48000
022	76 66 26	70	6.4	19.0	7.2	129	6	393	145	84	0	0	11000	40000
023	76 66 27	74	6.4	19.0	8.0	104	24	173	98	70	0	0	11000	40000
024	76 66 28	60	6.2	17.0	8.0	156	0	173	0	78	34	0	17000	32000
025	76 66 29	60	6.4	17.0	8.0	163	0	173	0	78	34	0	0	0
026	76 66 30	54	6.3	18.0	8.6	132	0	212	115	26	0	0	0	0
027	76 66 31	55	6.3	19.0	8.6	0	0	327	33	92	0	0	0	0
028	76 66 32	20	6.7	22.0	8.4	93	0	163	158	72	0	0	0	0
029	76 66 33	72	6.7	22.0	8.4	69	6	202	158	0	0	0	0	0
030	76 66 34	76	6.9	21.0	8.5	90	15	163	0	92	0	0	0	0
031	76 66 35	64	6.6	21.0	8.5	0	0	154	18	0	0	0	0	0
032	76 66 36	74	6.6	19.0	8.4	47	6	243	45	34	36	0	0	0
033	76 66 37	70	6.6	21.0	8.5	57	0	162	0	68	0	0	0	0
034	76 66 38	66	6.6	22.0	8.5	0	0	144	49	128	112	0	0	0
035	76 66 39	72	6.8	23.0	8.5	60	0	181	188	76	71	0	0	0
036	76 66 40	66	6.5	26.0	8.5	75	0	107	33	70	50	0	0	0
037	76 66 41	70	6.6	26.0	8.6	128	12	274	0	44	44	0	0	0
038	76 66 42	70	6.6	27.0	8.6	86	21	232	200	52	46	0	0	0
039	76 66 43	80	6.7	26.0	8.7	6	0	126	63	88	0	0	0	0
040	76 66 44	74	6.8	25.0	8.7	87	10	101	0	36	0	0	0	0
041	76 66 45	68	6.2	26.0	8.1	90	12	0	0	0	0	0	0	0

TABLE D-2. Cont'd.

S.NO	DATE			ALKALINITY	PH	TEMP.	DISS.	BOD	BOD	COD	COD	TOTAL	VOLATILE	TOTAL	FECAL	TOTAL
	YR	MO	DT			DEG C	OXYGEN	TOTAL	SOLUBLE	TOTAL	SOLUBLE	SUSPENDED	SUSPENDED	PHOSPHOROUS	COLI	COLI
												SOLIDS	SOLIDS			
G01	76	66	5	70	6.7	28.0	2.0	3.4	21	29	40	0	0	0	0	0
G02	76	66	6	72	6.7	28.0	2.5	2.4	22	101	0	150	102	0	0	0
G03	76	66	7	73	6.7	28.0	4.1	1.5	25	208	59	61	41	0	0	0
G04	76	66	8	74	6.4	28.0	4.1	1.1	19	192	69	0	0	0	0	0
G05	76	66	9	75	6.4	29.0	4.1	1.1	33	98	99	32	12	0	0	0
G06	76	66	10	76	6.4	28.0	4.9	1.7	15	88	60	19	19	0	0	0
G07	76	66	11	76	6.4	28.0	6.6	1.6	13	150	0	65	35	0	0	0
G08	76	66	12	76	6.6	28.0	4.5	1.5	12	129	0	0	0	0	0	0
G09	76	66	13	76	6.7	28.0	4.5	1.5	13	136	0	5	3	0	0	0
G10	76	66	14	77	6.2	28.0	4.3	1.2	1	107	0	51	3	0	0	0
G11	76	66	15	77	6.6	28.0	4.3	1.2	1	127	0	0	3	0	0	0
G12	76	66	16	77	6.6	28.0	4.3	1.4	1	127	0	40	3	0	0	0
G13	76	66	17	77	6.6	28.0	4.3	1.4	1	127	0	4	3	0	0	0
G14	76	66	18	78	6.6	28.0	4.3	1.1	1	150	56	61	4	0	0	0
G15	76	66	19	78	6.6	28.0	4.3	1.1	1	153	6	200	50	0	0	0
G16	76	66	20	78	6.6	28.0	4.3	1.1	1	167	6	48	4	0	0	0
G17	76	66	21	78	6.6	28.0	4.3	1.1	1	143	6	48	4	0	0	0
G18	76	66	22	78	6.6	28.0	4.3	1.1	1	165	6	8	8	0	0	0
G19	76	66	23	78	6.6	28.0	4.3	1.1	1	151	7	28	6	0	0	0
G20	76	66	24	78	6.6	28.0	4.3	1.1	1	167	6	7	7	0	0	0
G21	76	66	25	78	6.6	28.0	4.3	1.1	1	151	6	102	4	0	0	0
G22	76	66	26	78	6.6	28.0	4.3	1.1	1	120	17	62	62	0	0	0
G23	76	66	27	78	6.6	28.0	4.3	1.1	1	106	6	6	6	0	0	0
G24	76	66	28	78	6.6	28.0	4.3	1.1	1	117	5	46	46	0	0	0
G25	76	66	29	78	6.6	28.0	4.3	1.1	1	125	8	62	60	0	0	0
G26	76	66	30	78	6.6	28.0	4.3	1.1	1	125	8	50	50	0	0	0
G27	76	66	31	78	6.6	28.0	4.3	1.1	1	122	8	126	10	0	0	0
G28	76	66	32	78	6.6	28.0	4.3	1.1	1	122	8	64	64	0	0	0
G29	76	66	33	78	6.6	28.0	4.3	1.1	1	122	8	138	11	0	0	0
G30	76	66	34	78	6.6	28.0	4.3	1.1	1	122	8	96	66	0	0	0
G31	76	66	35	78	6.6	28.0	4.3	1.1	1	122	8	180	188	0	0	0
G32	76	66	36	78	6.6	28.0	4.3	1.1	1	122	8	75	66	0	0	0
G33	76	66	37	78	6.6	28.0	4.3	1.1	1	122	8	0	70	0	0	0
G34	76	66	38	78	6.6	28.0	4.3	1.1	1	122	8	0	70	0	0	0
G35	76	66	39	78	6.6	28.0	4.3	1.1	1	122	8	230	146	0	0	0

TABLE D-2. Cont'd.

S.NO	DATE	ALKALINITY	PH	TEMP.	DISS.	BOD	BOD	COD	COD	TOTAL	VOLATILE	TOTAL	FECAL TOTAL
YR	MO	DT		DEG C	OXYGEN	TOTAL	SOLUBLE	TOTAL	SOLUBLE	SUSPENDED SOLIDS	SUSPENDED SOLIDS	PHOSPHOROUS	COLI COLI
L001	75					141	11	261	3	138	110	0	0
L002	76					105	11	10		232	156		
L003	76					111		109		150	160		
L004	76					105		100		108	136		
L005	76					105		100		100	150		
L006	76					105		100		100	150		
L007	76					105		100		100	150		
L008	76					105		100		100	150		
L009	76					105		100		100	150		
L010	76					105		100		100	150		
L011	76					105		100		100	150		
L012	76					105		100		100	150		
L013	76					105		100		100	150		
L014	76					105		100		100	150		
L015	76					105		100		100	150		
L016	76					105		100		100	150		
L017	76					105		100		100	150		
L018	76					105		100		100	150		
L019	76					105		100		100	150		
L020	76					105		100		100	150		
L021	76					105		100		100	150		
L022	76					105		100		100	150		
L023	76					105		100		100	150		
L024	76					105		100		100	150		
L025	76					105		100		100	150		
L026	76					105		100		100	150		
L027	76					105		100		100	150		
L028	76					105		100		100	150		
L029	76					105		100		100	150		
L030	76					105		100		100	150		
L031	76					105		100		100	150		
L032	76					105		100		100	150		
L033	76					105		100		100	150		
L034	76					105		100		100	150		
L035	76					105		100		100	150		
L036	76					105		100		100	150		
L037	76					105		100		100	150		

TABLE D-3. EFFLUENT TEST DATA OF BIXBY LAGOON, 1976.
(Effluent Cell 2)

S-NO	DATE	PH	TEMP.	ALKAL.	DISS.	AMMONIA	KJELDAHL	BOD	BOD	COD	COD	TOTAL	VOLATILE	PHOSPHOROUS	FECAL	TOTAL
YR	MO	DT	DEG C	MG/L	OXYGEN	NITROGEN	NITROGEN	TOTAL	SOL.	TOTAL	SCL	SCL	SUSPENDED	SUSPENDED	COLI	COLI
													SOLIDS	SOLIDS		
A01	76	1	6	6.7	2.4	93	12	2.0	6.9	0	0	85	52	52	45	32
A02	76	1	7	6.6	1.0	93	14	11.3	6.9	0	0	98	39	39	14	33
A03	76	1	8	6.0	1.0	93	15	6.4	6.4	131	1	98	33	33	13	33
A04	76	1	9	7.3	2.0	91	14	7.1	7.1	69	500	82	0	0	0	0
A05	76	1	10	7.3	1.0	87	15	2.5	7.4	78	58	79	0	0	0	32
A06	76	1	11	7.5	2.0	91	13	5.6	7.8	0	0	111	22	22	12	32
A07	76	1	12	8.5	3.5	91	14	7.3	7.3	115	110	73	20	20	17	31
A08	76	1	13	7.8	5.0	83	11	3.8	7.0	25	23	72	8	8	29	31
A09	76	1	14	7.9	6.0	83	15	3.8	5.3	26	45	67	0	0	0	32
A10	76	1	15	8.0	3.0	85	13	3.9	9.1	62	33	94	45	45	40	32
A11	76	1	16	8.0	0.0	60	0	5.2	10.5	39	24	76	42	42	27	32
A12	76	1	17	8.0	1.0	0	14	4.6	11.3	75	34	85	0	0	49	32
A13	76	1	18	8.0	0.0	0	0	4.5	7.8	77	23	54	68	68	37	33
A14	76	1	19	8.0	0.0	0	0	5.1	7.1	31	27	75	74	75	33	33
A15	76	1	20	8.0	7.0	104	11	4.7	6.8	14	13	93	66	66	37	34
A16	76	1	21	8.0	0.0	0	0	4.3	7.5	19	10	44	43	43	19	34
A17	76	1	22	8.0	0.0	0	15	6.5	8.0	0	0	93	43	43	23	39
A18	76	1	23	8.0	0.0	0	0	0.0	0.0	0	0	0	0	0	0	30
A19	76	1	24	8.0	0.0	0	0	0.0	0.0	0	0	0	0	0	0	31
A20	76	1	25	8.0	0.0	0	0	0.0	0.0	0	0	0	0	0	0	30
A21	76	1	26	9.2	7.0	106	13	5.5	9.4	20	15	111	104	104	36	30
A22	76	1	27	9.3	7.0	108	13	5.8	9.0	21	13	111	42	42	18	28
A23	76	1	28	9.4	7.0	114	14	5.3	7.1	18	10	103	57	57	32	29
A24	76	1	29	9.8	8.0	118	13	0.0	0.0	27	14	71	0	0	0	0
B01	76	2	22	8.0	0.0	0	0	13.2	20.9	35	41	0	0	0	0	0
B02	76	2	23	8.0	0.0	0	0	14.1	20.7	35	40	0	0	0	0	0
B03	76	2	24	8.0	0.0	0	0	13.4	20.0	32	40	0	0	0	0	0
B04	76	2	25	8.0	0.0	0	0	13.5	21.1	41	38	0	0	0	0	0
B05	76	2	26	8.0	0.0	0	0	14.7	21.8	41	38	0	0	0	0	0
B06	76	2	27	8.0	0.0	0	0	14.8	21.9	40	37	0	0	0	0	0
B07	76	2	28	8.0	0.0	0	0	13.4	22.0	40	37	0	0	0	0	0
C01	76	3	23	17.0	14	160	0	23.8	0.0	47	46	13	63	63	44	3000
C02	76	3	24	17.0	14	160	0	23.8	0.0	47	46	13	63	63	44	3000
C03	76	3	25	17.0	14	160	0	23.8	0.0	47	46	13	63	63	44	3000
C04	76	3	26	17.0	14	160	0	23.8	0.0	47	46	13	63	63	44	3000
C05	76	3	27	16.0	14	160	0	23.8	0.0	47	46	13	63	63	44	3000
C06	76	3	28	16.0	14	160	0	23.8	0.0	47	46	13	63	63	44	3000
C07	76	3	29	16.0	14	160	0	23.8	0.0	47	46	13	63	63	44	3000

TABLE D-3. Cont'd.

S-NO	DATE	PH	TEMP	ALKAL	DISS	AMMONIA	KJELDAHL	BCD	BOD	COD	CCD	TOTAL	VOLATILE	PHOSPHOROUS	FECAL	TOTAL
YR	MO	DT	DEG C	INIIY	OXYGEN	NITROGEN	NITROGEN	TOTAL	SCL	TOTAL	SCL	SUSPENDED	SUSPENDED	SOLIDS	COLI	COLI
1	76														2000	7000
2	76														7000	7000
3	76														12000	12000
4	76														12000	12000
5	76														7000	7000
6	76														7000	7000
7	76														7000	7000
8	76														7000	7000
9	76														7000	7000
10	76														7000	7000
11	76														7000	7000
12	76														7000	7000
13	76														7000	7000
14	76														7000	7000
15	76														7000	7000
16	76														7000	7000
17	76														7000	7000
18	76														7000	7000
19	76														7000	7000
20	76														7000	7000
21	76														7000	7000
22	76														7000	7000
23	76														7000	7000
24	76														7000	7000
25	76														7000	7000
26	76														7000	7000
27	76														7000	7000
28	76														7000	7000
29	76														7000	7000
30	76														7000	7000
31	76														7000	7000
32	76														7000	7000
33	76														7000	7000
34	76														7000	7000
35	76														7000	7000
36	76														7000	7000
37	76														7000	7000
38	76														7000	7000
39	76														7000	7000
40	76														7000	7000
41	76														7000	7000
42	76														7000	7000
43	76														7000	7000
44	76														7000	7000
45	76														7000	7000
46	76														7000	7000
47	76														7000	7000
48	76														7000	7000
49	76														7000	7000
50	76														7000	7000
51	76														7000	7000
52	76														7000	7000
53	76														7000	7000
54	76														7000	7000
55	76														7000	7000
56	76														7000	7000
57	76														7000	7000
58	76														7000	7000
59	76														7000	7000
60	76														7000	7000
61	76														7000	7000
62	76														7000	7000
63	76														7000	7000
64	76														7000	7000
65	76														7000	7000
66	76														7000	7000
67	76														7000	7000
68	76														7000	7000
69	76														7000	7000
70	76														7000	7000
71	76														7000	7000
72	76														7000	7000
73	76														7000	7000
74	76														7000	7000
75	76														7000	7000
76	76														7000	7000
77	76														7000	7000
78	76														7000	7000
79	76														7000	7000
80	76														7000	7000
81	76														7000	7000
82	76														7000	7000
83	76														7000	7000
84	76														7000	7000
85	76														7000	7000
86	76														7000	7000
87	76														7000	7000
88	76														7000	7000
89	76														7000	7000
90	76														7000	7000
91	76														7000	7000
92	76														7000	7000
93	76														7000	7000
94	76														7000	7000
95	76														7000	7000
96	76														7000	7000
97	76														7000	7000
98	76														7000	7000
99	76														7000	7000
100	76														7000	7000

TABLE D-3. Cont'd.

SANO	DATE	PH	TEMP.	ALKALY	DIMS.	AMMONIA	KJELDAHL	BOD	BCD	COD	CCD	TOTAL	VOLATILE	PHOSPHOROUS	FECAL	TOTAL
YR	MO	DT	DEG C	1-117	OXYGEN	NITROGEN	NITROGEN	TOTAL	SOL.	TOTAL	SCL	SUSPENDED	SUSPENDED	SOLIDS	COLI	COLI
801	76	7	5	6.7	28.0	100	3	1.6	5.0	27	10	89	30	0	0	0
802	76	7	6	6.5	28.0	69	4	1.1	5.7	31	9	91	30	0	0	0
803	76	7	7	6.8	28.0	69	5	0.0	5.3	20	4	93	30	0	0	0
804	76	7	8	6.6	29.0	70	5	0.0	6.6	24	10	101	30	0	0	0
805	76	7	9	6.6	29.0	64	3	0.0	6.6	20	3	92	30	0	0	0
806	76	7	10	6.6	29.0	48	3	0.0	6.6	20	6	96	30	0	0	0
807	76	7	12	6.5	29.0	70	5	1.1	6.3	22	10	100	30	0	0	0
808	76	7	13	6.7	29.0	64	5	0.9	6.8	27	8	100	30	0	0	0
809	76	7	14	6.8	30.0	64	5	0.0	6.8	27	8	99	30	0	0	0
810	76	7	15	6.7	30.0	70	5	0.0	6.7	27	8	98	30	0	0	0
811	76	7	16	6.7	30.0	88	5	1.3	6.9	20	9	87	30	0	0	0
812	76	7	17	6.4	30.0	64	5	0.0	6.4	15	9	88	30	0	0	0
813	76	7	18	6.6	30.0	70	5	0.0	6.6	18	8	88	30	0	0	0
814	76	7	19	6.6	30.0	72	5	0.7	6.6	18	8	85	30	0	0	0
815	76	7	20	6.6	30.0	80	5	0.0	6.6	18	8	85	30	0	0	0
816	76	7	21	6.6	30.0	72	5	0.0	6.6	21	7	86	30	0	0	0
817	76	7	22	6.6	30.0	80	5	1.0	6.6	21	7	84	30	0	0	0
818	76	7	23	6.5	30.0	70	5	0.6	6.8	22	6	85	30	0	0	0
819	76	7	24	6.5	30.0	72	5	0.3	6.8	16	5	84	30	0	0	0
820	76	7	25	6.5	30.0	78	5	0.3	6.8	15	4	84	30	0	0	0
821	76	7	27	7.1	31.0	70	5	0.3	6.8	21	5	84	30	0	0	0
822	76	7	28	6.8	31.0	72	5	0.7	6.7	9	5	73	30	0	0	0
823	76	7	30	6.7	31.0	82	5	0.7	6.9	12	5	72	30	0	0	0
824	76	8	2	6.7	30.0	62	5	0.0	6.7	15	5	60	30	0	0	0
825	76	8	3	6.8	30.0	70	5	0.0	6.8	15	5	67	30	0	0	0
826	76	8	4	6.7	30.0	68	5	0.2	6.8	15	5	71	30	0	0	0
827	76	8	5	6.7	30.0	70	5	0.7	6.8	15	5	72	30	0	0	0
828	76	8	6	6.7	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
829	76	8	7	7.1	30.0	70	5	0.7	6.8	15	5	72	30	0	0	0
830	76	8	8	7.4	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
831	76	8	9	7.3	30.0	66	5	0.6	6.8	15	5	72	30	0	0	0
832	76	8	10	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
833	76	8	11	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
834	76	8	12	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
835	76	8	13	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
836	76	8	14	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
837	76	8	15	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
838	76	8	16	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
839	76	8	17	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
840	76	8	18	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
841	76	8	19	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
842	76	8	20	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
843	76	8	21	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
844	76	8	22	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
845	76	8	23	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
846	76	8	24	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
847	76	8	25	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
848	76	8	26	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
849	76	8	27	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
850	76	8	28	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
851	76	8	29	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
852	76	8	30	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
853	76	8	31	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
854	76	8	32	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
855	76	8	33	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
856	76	8	34	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
857	76	8	35	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
858	76	8	36	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
859	76	8	37	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
860	76	8	38	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
861	76	8	39	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
862	76	8	40	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
863	76	8	41	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
864	76	8	42	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
865	76	8	43	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
866	76	8	44	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
867	76	8	45	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
868	76	8	46	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
869	76	8	47	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
870	76	8	48	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
871	76	8	49	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
872	76	8	50	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
873	76	8	51	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
874	76	8	52	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
875	76	8	53	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
876	76	8	54	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
877	76	8	55	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
878	76	8	56	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
879	76	8	57	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
880	76	8	58	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
881	76	8	59	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
882	76	8	60	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
883	76	8	61	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
884	76	8	62	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
885	76	8	63	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
886	76	8	64	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
887	76	8	65	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
888	76	8	66	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
889	76	8	67	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
890	76	8	68	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
891	76	8	69	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
892	76	8	70	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
893	76	8	71	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
894	76	8	72	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
895	76	8	73	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
896	76	8	74	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
897	76	8	75	7.3	30.0	70	5	0.6	6.8	15	5	72	30	0	0	0
898	76	8	76	7.3	30.0											

TABLE D-3. Cont'd.

S.NO	DATE			PH	TEMP.	ALKAL.	DISS.	AMMONIA	KJELDAHL	COD	BOD	COD	CCD	TOTAL	VOLATILE	PHOSPHOROUS	FECAL	TOTAL
	YR	MO	DT															
101	76	10	23	7.0	13.0	0.0	0.0	0.0	0.3	35	8	105	24	126	0	0	0	0
102	76	10	24	7.0	13.0	0.0	0.0	0.2	0.3	20	7	58	42	14	0	0	0	0
103	76	10	25	7.0	13.0	0.0	0.0	0.1	0.3	17	9	80	22	14	0	0	0	0
104	76	10	26	7.0	13.0	0.0	0.0	0.1	0.8	16	4	86	55	58	0	0	0	0
105	76	10	27	7.0	13.0	0.0	0.0	0.1	0.7	14	5	98	11	51	0	0	0	0
106	76	10	28	7.0	13.0	0.0	0.0	0.2	0.8	18	0	98	53	11	0	0	0	0
107	76	10	29	7.0	13.0	0.0	0.0	0.0	0.0	15	3	98	46	55	0	0	0	0
108	76	11	01	7.0	12.0	0.0	0.0	0.0	0.0	24	3	95	21	35	0	0	0	0
109	76	11	02	7.0	12.0	0.0	0.0	0.2	0.0	23	1	34	73	0	0	0	0	0
110	76	11	03	7.0	12.0	0.0	0.0	0.1	0.2	19	11	113	63	0	0	0	0	0
111	76	11	04	7.0	12.0	0.0	0.0	0.1	0.6	25	8	118	57	37	0	0	0	0
112	76	11	05	7.0	12.0	0.0	0.0	0.1	0.8	24	2	121	74	62	0	0	0	0
113	76	11	06	7.0	12.0	0.0	0.0	0.1	0.9	32	9	131	51	60	0	0	0	0
114	76	11	07	7.0	12.0	0.0	0.0	0.0	0.1	17	4	123	40	93	0	0	0	0
115	76	11	08	7.0	12.0	0.0	0.0	0.1	0.5	20	11	104	48	40	0	0	0	0
116	76	11	09	7.0	12.0	0.0	0.0	0.1	0.1	21	5	108	51	56	0	0	0	0
117	76	11	10	7.0	12.0	0.0	0.0	0.1	0.9	21	1	107	47	73	0	0	0	0
118	76	11	11	7.0	12.0	0.0	0.0	0.1	0.6	27	1	110	56	52	0	0	0	0
119	76	11	12	7.0	12.0	0.0	0.0	0.0	0.2	25	8	120	49	56	0	0	0	0
120	76	11	13	7.0	12.0	0.0	0.0	0.1	0.7	24	0	109	76	56	0	0	0	0
121	76	11	14	7.0	12.0	0.0	0.0	0.1	0.9	30	6	116	52	46	0	0	0	0
122	76	11	15	7.0	12.0	0.0	0.0	0.0	0.8	11	1	108	66	62	0	0	0	0
123	76	11	16	7.0	12.0	0.0	0.0	0.0	0.9	11	1	130	49	66	0	0	0	0
124	76	11	17	7.0	12.0	0.0	0.0	0.0	0.9	23	1	130	46	66	0	0	0	0
125	76	11	18	7.0	12.0	0.0	0.0	0.0	0.3	27	0	125	0	0	0	0	0	0
126	76	11	19	7.0	12.0	0.0	0.0	0.0	0.2	11	1	99	34	3	0	0	0	0
127	76	11	20	7.0	12.0	0.0	0.0	0.0	0.7	6	1	102	42	1	0	0	0	0
128	76	11	21	7.0	12.0	0.0	0.0	0.0	0.4	15	0	103	46	0	0	0	0	0
129	76	11	22	7.0	12.0	0.0	0.0	0.0	0.4	12	0	106	67	0	0	0	0	0
130	76	11	23	7.0	12.0	0.0	0.0	0.0	0.4	0	0	106	52	0	0	0	0	0
131	76	11	24	7.0	12.0	0.0	0.0	0.0	0.8	24	1	130	51	3	0	0	0	0
132	76	11	25	7.0	12.0	0.0	0.0	0.0	0.8	0	0	116	41	5	0	0	0	0
133	76	11	26	7.0	12.0	0.0	0.0	0.9	0.8	0	0	120	41	5	0	0	0	0
134	76	11	27	7.0	12.0	0.0	0.0	1.0	0.8	1	0	89	45	26	0	0	0	0
135	76	11	28	7.0	12.0	0.0	0.0	1.0	0.8	1	0	108	45	36	0	0	0	0
136	76	11	29	7.0	12.0	0.0	0.0	1.2	0.8	1	0	127	75	14	0	0	0	0
137	76	11	30	7.0	12.0	0.0	0.0	0.0	1.1	35	0	110	51	40	0	0	0	0

TECHNICAL REPORT DATA <i>(Please read instructions on the reverse before completing)</i>		
1. REPORT NO. EPA-600/2-79-014	2.	3. RECIPIENT'S ACCESSION NO.
4. TITLE AND SUBTITLE PERFORMANCE EVALUATION OF EXISTING AERATED LAGOON SYSTEM AT BIXBY, OKLAHOMA	5. REPORT DATE March 1979 (Issuing Date)	6. PERFORMING ORGANIZATION CODE
7. AUTHOR(S) George W. Reid, Leale Streebin	8. PERFORMING ORGANIZATION REPORT NO.	
9. PERFORMING ORGANIZATION NAME AND ADDRESS University of Oklahoma Bureau of Water and Environmental Resources Research Norman, Oklahoma 73019	10. PROGRAM ELEMENT NO. IBC822 SOS #3 Task D-1/26	11. CONTRACT/GRANT NO. R-803916
12. SPONSORING AGENCY NAME AND ADDRESS Municipal Environmental Research Laboratory--Cin., OH Office of Research and Development U.S. Environmental Protection Agency Cincinnati, Ohio 45268	13. TYPE OF REPORT AND PERIOD COVERED Final 1/6/76-12/22/76	14. SPONSORING AGENCY CODE EPA/600/14
15. SUPPLEMENTARY NOTES Project Officer: Ronald F. Lewis, (513) 684-7644		
16. ABSTRACT <p>The University of Oklahoma School of Civil Engineering and Environmental Science research group in collaboration with INCOG & BIXBY, have studied a well designed, well operated two cell aerated wastewater treatment lagoon system. The study involved four seasons and nineteen study parameters. The data was treated to statistical analysis, using a SPSS multiple regression, and to normative analytical expression. This report covers the BIXBY lagoon system operation period of January 1976 through December 1976.</p> <p>The lagoon exhibited an overall BOD₅ removal efficiency of 92%, but was only totally in compliance for 7 months of the year. The use of several kinetic models and regression models were not very satisfactory though the temperature coefficient were in substantial agreement with Adams and Eckenfelders and other reputed values.</p>		
17. KEY WORDS AND DOCUMENT ANALYSIS		
a. DESCRIPTORS	b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group
Waste treatment *Lagoons (ponds) *Performance evaluation *Design criteria Chemical analysis Physical tests	Aerated	13B
18. DISTRIBUTION STATEMENT Release to Public	19. SECURITY CLASS (This Report) Unclassified	21. NO. OF PAGES 117
	20. SECURITY CLASS (This page) Unclassified	22. PRICE