

EPA-650/2-73-005-b

August 1975

Environmental Protection Technology Series

**PROGRAM FOR REDUCTION  
OF NO<sub>x</sub> FROM TANGENTIAL  
COAL-FIRED BOILERS  
PHASE IIa**

**NO<sub>x</sub> CONTROL TECHNOLOGY APPLICATION STUDY**



U.S. Environmental Protection Agency  
Office of Research and Development  
Washington, D. C. 20460



# **PROGRAM FOR REDUCTION OF NO<sub>x</sub> FROM TANGENTIAL COAL-FIRED BOILERS PHASE IIa**

## **NO<sub>x</sub> CONTROL TECHNOLOGY APPLICATION STUDY**

by

Ambrose P Selker

Combustion Engineering, Inc.  
1000 Prospect Hill Road  
Windsor, Connecticut 06095

Contract No. 68-02-1367  
ROAP No. 21ADG-080  
Program Element No. 1AB014

EPA Project Officer: David G. Lachapelle

Industrial Environmental Research Laboratory  
Office of Energy, Minerals, and Industry  
Research Triangle Park, North Carolina 27711

Prepared for

U. S. ENVIRONMENTAL PROTECTION AGENCY  
Office of Research and Development  
Washington, D. C. 20460

August 1975



## **EPA REVIEW NOTICE**

This report has been reviewed by the National Environmental Research Center - Research Triangle Park, Office of Research and Development, EPA, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the Environmental Protection Agency, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

## **RESEARCH REPORTING SERIES**

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into series. These broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and maximum interface in related fields. These series are:

1. ENVIRONMENTAL HEALTH EFFECTS RESEARCH
2. ENVIRONMENTAL PROTECTION TECHNOLOGY
3. ECOLOGICAL RESEARCH
4. ENVIRONMENTAL MONITORING
5. SOCIOECONOMIC ENVIRONMENTAL STUDIES
6. SCIENTIFIC AND TECHNICAL ASSESSMENT REPORTS
9. MISCELLANEOUS

This report has been assigned to the ENVIRONMENTAL PROTECTION TECHNOLOGY series. This series describes research performed to develop and demonstrate instrumentation, equipment and methodology to repair or prevent environmental degradation from point and non-point sources of pollution. This work provides the new or improved technology required for the control and treatment of pollution sources to meet environmental quality standards.

This document is available to the public for sale through the National Technical Information Service, Springfield, Virginia 22161.

Publication No. EPA-650/2-73-005-b



## ABSTRACT

This report presents the results of Task IX of the Phase II - "Program for Reduction of NO<sub>x</sub> from Tangential Coal Fired Boilers" performed under the sponsorship of the Office of Research and Development of the Environmental Protection Agency (Contract 68-02-1367).

The results presented are based on both field performance tests performed at Alabama Power Corporation, Barry #2 and current contractor experience.

The utilization of overfire air as an NO<sub>x</sub> control technique is discussed relative to the following areas of interest:

1. Necessary equipment modifications and costs (as of March, 1975) associated with applying this technology to existing steam generators.
2. Specific limitations to the general applications of the technology developed.
3. Emission control and cost effectiveness of applying the developed technology to new steam generator designs.



## DISCLAIMER

"This report was prepared by Combustion Engineering, Inc. as an account of work sponsored by the Office of Research and Development, U.S. Environmental Protection Agency (EPA). Combustion Engineering, Inc. nor any person acting on behalf of Combustion Engineering, Inc.:

- "a. Makes any warranty or representation, expressed or implied including the warranties of fitness for a particular purpose or merchantability, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or
- b. Assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method or process disclosed in this report."



## CONTENTS

	<u>Page No.</u>
Abstract	iii
Disclaimer	iv
Contents	v
Figures, Tables, and Data Sheets	vi
Acknowledgments	vii
Conclusions	1
Recommendations	2
Introduction	3
Design and Description of OFA System	7
Discussion	10
Field Test Program	10
Exploratory Study	12
Effect on Unit Performance	13
Economic Evaluation	15
Applicability	19
References	21



## FIGURES, TABLES, AND DATA SHEETS

<u>Figure</u>	<u>Description</u>	<u>Page No.</u>
1	Gross MW Loading VS Time-Baseline Study	4
2	Gross MW Loading VS Time-OFA Study	5
3	Waterwall Corrosion Probe Locations	6
4	OFA System - New Units	8
5	OFA System - Existing Units	9
6	Overfire Air System Costs	16

### Table

1	Cost of Electricity Generated 500 MW Plant	18
---	--	----

### Data

<u>Sheet</u>	<u>Description</u>	
1	NO <sub>x</sub> Test Data Summary - Baseline Study	22
2	NO <sub>x</sub> Test Data Summary - Biased Firing Study	23
3	NO <sub>x</sub> Test Data Summary - Baseline after Modification Study	24
4A,4B	NO <sub>x</sub> Test Data Summary - OFA Study	25,26
5A	Waterwall Corrosion Coupon Data Summary - Baseline Study	27
5B	Waterwall Corrosion Coupon Data Summary - Biased Firing Study	28
5C	Waterwall Corrosion Coupon Data Summary - OFA Study	29



## ACKNOWLEDGMENTS

The author wishes to acknowledge the constructive participation of Mr. D. G. Lachapelle, EPA Project Officer in providing the program direction necessary to its successful completion.

The cooperation and active participation of Alabama Power Company and in particular, the personnel of the Barry Steam Plant, were essential to successful completion of this program.

The results presented in this report represent the effort of many Combustion Engineering, Inc. personnel whose participation was required for its successful completion and in particular, the technical contributions made by Messrs: M. J. Hargrove and R. W. Robinson.



## CONCLUSIONS

1. Prior to incorporating overfire air as an NO<sub>x</sub> control system on existing unit designs, an exploratory test program must be performed to determine the acceptability of the unit for modification.
2. The costs of installing an overfire air system on an existing unit could range between 2 to 4 times the cost as included on a new unit design. Based on March, 1975 estimates existing unit modification costs could range from 0.2 to 1.5 \$/kw, depending on unit size.
3. Approximately 40% of the existing coal fired units in the United States are of tangential design and could conceivably be modified to incorporate overfire air systems.
4. Unit size, heat rate and expected life must be considered in deciding whether modifications are justified.
5. Incorporation of an overfire air system will generally not significantly affect unit performance.
6. A large percentage of the existing tangentially coal fired units in the United States can meet current EPA standards for NO<sub>x</sub> emission levels. The necessity of applying the overfire air technique for NO<sub>x</sub> control should therefore be established prior to committing a unit for modification.



## RECOMMENDATIONS

### Existing Steam Generating Units

The applicability of the technology developed in the course of this project should be qualified by the following conditions:

1. Any unit under consideration should be subjected to an exploratory test program to determine the necessity of modification with respect to applicable NO<sub>x</sub> compliance limits. The minimum test requirements recommended for such a study would consist of studying the effect of available process variables such as excess air level. The minimum test data would consist of NO<sub>x</sub>, CO for combustion efficiency and sufficient board or test data to identify changes in unit operating characteristics.
2. A review should be made of the unit and turbine useful life expectancy, unit size versus modification costs, and unit heat rate.

### New Steam Generating Units

All tangentially coal fired units since approximately 1970 have included OFA in the original unit design. The OFA system is therefore not considered as an additional NO<sub>x</sub> control device.



## INTRODUCTION

The effectiveness of overfire air operation in reducing  $\text{NO}_x$  emissions from existing utility steam generators was evaluated by selecting and modifying a test unit and studying the effects of this modification on unit performance and emission control. The test unit was a natural circulation, balanced draft design, firing coal through four elevations of tilting tangential fuel nozzles. Unit capacity at maximum continuous rating (MCR) is 408,000 kg/hr main steam flow with a superheat outlet temperature and pressure of 538°C and 131.8 kg/cm<sup>2</sup>. Superheat and reheat temperatures were controlled by fuel nozzle tilt and spray desuperheating.

In order to evaluate unit performance during the study, necessary steam, water, air and gas temperature and pressure measurements were performed as well as  $\text{NO}_x$ ,  $\text{CO}$ ,  $\text{O}_2$ ,  $\text{HC}$ ,  $\text{SO}_2$  and carbon loss determinations to assess emission performance. The specific results of the test program are included in Final Report EPA-650/2-73-005a and are therefore not presented herein. The test program was conducted in three phases consisting of baseline and biased firing portions conducted prior to modification and baseline and overfire air portions conducted after unit modification. The effect of the modification on unit performance was found to be insignificant and the test data summaries for each phase are shown on Sheets 1, 2, 3 and 4. Short term comparative corrosion tests were run over thirty day periods using corrosion coupons. During this evaluation normal operation with OFA was achieved. The unit load schedules for the baseline and biased firing and overfire air evaluations are shown on Figures 1 and 2 and the respective data summaries are shown on Sheets 5A, 5B and 5C. Corrosion coupon locations are shown on Figure 3.






Figure 1: Gross MW Loading Vs. Time - Baseline Corrosion Probe Study






Figure 2: Gross MW Loading Vs. Time - Overfire Air Corrosion Probe Study






Figure 3: Waterwall Corrosion Probe Locations, Barry No. 4



### Design and Description of OFA Systems

The overfire air system as incorporated in tangential coal fired furnaces consists of air compartments and nozzles, ductwork, flow control dampers and nozzle tilting mechanisms. A typical arrangement of this system is shown on Figure 4. The overfire air compartments and nozzles are designed as vertical extensions of the corner windboxes unless as in the case of some existing units, modification at that location is not possible due to structural considerations.

In the latter case, as was the situation with the test unit, the separate compartments and nozzles were installed within three meters of the top of the existing windbox. As shown on Figure 5, this arrangement requires additional ductwork for supplying air to the OFA system.

Control dampers for regulating the OFA flow rate should be coordinated with the windbox fuel and auxiliary air compartment dampers to correctly proportion air flow as required for various operating modes.

An independent OFA nozzle tilt mechanism should also be provided on retrofits of existing units to permit coordinating these nozzles with the fuel and air nozzle tilts.

The overfire air nozzles and ducts should be sized for 15% of the full load secondary<sup>\*</sup> air flow using the same nozzle and duct velocities as the windbox. Each overfire air port consists of two nozzles above each windbox, usually as an extension of the windbox.

---

\* Secondary air does not include coal pulverizer transport air.






Figure 4: Typical Overfire Air Windbox Extension Coal Firing






Figure 5: Schematic Overfire Air System, Barry No. 2



## DISCUSSION

### Field Test Program

The field performance tests conducted at Barry No. 2 firing eastern bituminous coal showed that an overfire air system on a tangential coal fired furnace can reduce  $\text{NO}_x$  emissions with no detriment to unit operation or maintenance.  $\text{NO}_x$  reductions of 20 to 30% were obtained with 15 to 20 percent overfire air when operating at a total unit excess air of approximately 15 to 20 percent as measured at the economizer outlet. This condition provided an average fuel firing zone stoichiometry of 95 to 100 percent of theoretical air. Stoichiometries below this level did not result in large enough decreases in  $\text{NO}_x$  levels to justify their use. Biased firing (removing the top burner elevation from service), while potentially as effective, necessitated a reduction in unit loading and is therefore less desirable a method of  $\text{NO}_x$  control. In essence, this method uses the uppermost fuel and air compartment as a windbox extension.

When using overfire air as a means of decreasing the theoretical air (TA) to the fuel firing zone the percent carbon in the fly ash and CO emission levels were less affected than when operating with low excess air.\* This is due to the ability to maintain acceptable total excess air levels as measured at the economizer outlet during overfire air operation while the theoretical air (TA) to the fuel firing zone is reduced.

---

\* A minimum of 20 percent excess air was established for the Barry No. 2 tests.



Furnace performance as indicated by waterwall slag accumulations, visual observations and absorption rates was not significantly affected by overfire air operation.

On existing units where, for structural reasons, an overfire air port might not be installed as a windbox extension, test results indicate that the centerline of the overfire air port be kept within 3 meters of the centerline of the top fuel elevation. Distances greater than 3 meters did not result in decreased  $\text{NO}_x$  levels. Changes within the 3 meters limit did affect  $\text{NO}_x$  levels slightly with the  $\text{NO}_x$  levels increasing as the distance decreased.

The overfire air nozzles should tilt in unison with the fuel nozzles where possible. Tilting the overfire air and fuel nozzles towards each other directs the overfire air into the fuel admission zone thereby negating the original intent, while tilting the nozzles away from each other may result in decreased flame stability. If the overfire air nozzle tilt is fixed in a horizontal position  $\text{NO}_x$  levels would probably then vary to a limited extent with fuel nozzle position. In other words, the  $\text{NO}_x$  levels may increase or decrease as the total included angle between the fuel and OFA nozzles is decreased or increased respectively.

The results of the 30 day baseline, biased firing and overfire air corrosion coupon runs indicate that the overfire air operation for low  $\text{NO}_x$  optimization did not result in significant increases in corrosion coupon degradation. The results of this study are shown on Sheets 5A, 5B and 5C. Potential long term corrosion effects were not evaluated as part of this program.



### Exploratory Field Test Program - Existing Units

To determine both the necessity and acceptability of applying the OFA technique for NO<sub>x</sub> emissions control on existing tangentially fired units, an evaluation should be performed prior to committing the unit to modification.

This evaluation should include the study of existing process variables such as excess air as an NO<sub>x</sub> control method. If these techniques should prove unsatisfactory, the program should then be expanded to evaluate the effect of biased firing on NO<sub>x</sub> emissions. This technique consists of removing the top fuel elevations from service and using the upper air and fuel compartments for the introduction of overfire air. This evaluation should be conducted at the maximum possible unit loading with one pulverizer out of service and otherwise normal operation.

During biased firing operation, changes in total excess air required to maintain acceptable CO levels, the amount of carryover from the furnace outlet and furnace slagging tendencies should be observed. Carryover could be visually observed while increased slagging might be evaluated both visually and in terms of bottom ash handling system performance. Outlet steam temperatures and air heater exit gas temperatures should also be observed for comparison to normal operation.

The minimum instrumentation necessary for a comprehensive evaluation is as follows:



### Unit Performance

Superheat (S.H.) Outlet Temp.	Calibrated Board Data*
Reheat (R.H.) Outlet Temp.	Calibrated Board Data*
R.H. & S.H. Spray Flows	Calibrated Board Data*
Gas Temp. Lvg. Air Heater (A.H.)	Thermocouple Grid in A.H. Outlet Duct
Excess Air Lvg. A.H.	Gas Sampling Grid in A.H. Outlet Duct
Furnace Carryover	Visual Observation
Furnace Slagging	Visual Observation and Ash System Performance, Noz- zle Tilt Changes & De- superheating sprays
Unit Gas Side Pressure Drop	Calibrated Board Readings*

### Emissions Performance

NO <sub>x</sub> , CO & O <sub>2</sub>	Gas Sampling Grid in A.H. Inlet Duct
---------------------------------------	---

### Effect on Unit Performance

The application of OFA as an NO<sub>x</sub> control device spreads out the furnace fire which reduces flame intensity and temperature and the initial oxygen concentration. These effects combine to limit the formation of NO compounds with the reduced oxygen apparently affecting the fuel bound nitrogen NO formation.

---

\* If not available, test instrumentation should be considered.



In the case of coal firing, the  $\text{NO}_x$  emissions originate from two sources, fuel bound and atmospheric nitrogen  $(\text{NO})_{\text{Total}} = (\text{NO})_{\text{Fuel N}} + (\text{NO})_{\text{N}_2}$  in air.

The Barry 2 test results indicated that as long as the total excess oxygen (fuel compartment  $\text{O}_2$  + OFA  $\text{O}_2$ ) as measured at the economizer remains unchanged from the baseline condition, unit performance would remain unaffected. In some cases, however, a slightly increased total oxygen may be required to prevent an increase in CO and unburned carbon emission levels. This situation could be simulated with a biased firing test (top fuel elevation out of service) conducted during the exploratory program to determine the necessity of unit modification. While this approach will necessitate a reduction in unit loading, testing should be conducted at the highest possible loading obtainable for comparison to normal unit operation.

Otherwise, overall steam generator performance, including fan power, final steam temperatures, furnace wall tube temperatures and corrosion, and unit efficiency remain essentially unchanged.

The effect on furnace slagging has been found to be minimal with the coal used in this program and the coals studied in parallel programs conducted at the Barry Station.<sup>1</sup> However, since coal types vary widely the effect of changing firing zone stoichiometries on slagging tendencies should be evaluated during the exploratory program, again by using the biased firing technique. Where evaluating units with spare coal pulverizer capacity, this check should, if at all possible, be made at or close to full unit rating, particularly from the standpoint of evaluating unit slagging tendencies. A minimum evaluation period of one week is recommended for studying slagging tendencies.

On some units, the spreading out of the furnace fire might result in some combustible carryover from the unit furnace to the superheat sec-



tions. The tendency toward this condition can also be evaluated during the exploratory program by visual observation and watching for changes in unit performance.

### Economic Evaluation

The cost of incorporating overfire air systems on existing and new unit designs was evaluated for steam generating units from 125 to 1000 MW capacity. The results of this study are shown on Figure 6.

The cost estimates for the revision of existing units are based on studies performed on units within this size range including the actual costs for modification of the Barry 2 unit. The cost estimates presented for including the overfire air system in new unit designs are based on current experience with these systems.

The accuracy of the March, 1975 cost estimates is plus or minus ten percent. Because the overfire air system is included as an integral part of new unit design, it is not therefore, considered as an optional or additional emissions control device. The costs for existing units could be from 0.2 to 1.5 \$/kw, due to variations in existing unit design and construction which might make modifications more complicated. These costs may also vary and escalate with the prevailing economic climate.

The largest four windbox (single cell) furnaces manufactured to date have been of a 625 MW size at which point eight windbox furnaces (generally divided into two cells) have been selected. Since an eight windbox tangentially fired furnace has double the firing corners of a four windbox furnace, the costs of windboxes and ducts increase significantly.

The resulting increase in the cost of electricity generated is approxi-







Figure 6: Overfire Air System Costs - Tangential Coal Fired Steam Generators - March, 1975 Equipment Costs



mately 0.03% for a typical new 500 MW plant\* costing 500 \$/kw using coal costing 0.70 \$/10<sup>6</sup> BTU, as illustrated in Table 1. The overfire air system increases capital costs by 0.2 \$/kw, and all other costs are unchanged. The mills/kwhr increase is 0.006.

An existing 500 MW plant has overfire air system costs up to 0.7 \$/kw. Generation costs for a 500 \$/kw plant increase by up to 0.10% or 0.021 mills/kwhr. An existing 500 MW plant which was installed for 250 \$/kw and receives coal costing 0.35 \$/10<sup>6</sup> BTU has much lower operating costs than the previous example. The cost increase percentage is 0.17%, but the increase in mills/kwhr remains unchanged at 0.021, as shown in the last column of Table 1.

---

\* March, 1975 equipment costs for 500 MW Coal Fired Power Plant with Limestone SO<sub>2</sub> Scrubbing System.

	<u>\$/KW</u>
Coal Handling, Storage, Pulverizing, Ash Handling	44
SO <sub>2</sub> Scrubber System	75
Boiler, Air Heaters, Fans, Stack	62
Steam Turbine-Generator, Piping, Heaters, Water Treatment, Condenser, Cooling Towers	92
Structures, Sitework Foundations, Offices, Land, Workshops, Controls, Switchgear, Transformers	<u>63</u>
Subtotal	336
Engineering, Construction	44
Contingency	37
Interest During Construction	<u>83</u>
Total	500



TABLE 1. COST OF ELECTRICITY GENERATED - 500 MW PLANTS

Net Heat Rate 9500 Btu/Kwhr

March, 1975 Equipment Costs

	New plant without overfire air	New plant with overfire air	Recent existing with added overfire air	Older existing without overfire air	Older existing with added overfire air
Capital Costs \$/kw	500.00	500.20	500.70	250.00	250.70
Annual Cap. Cost \$	40,000,000 (1)	40,016,000	40,056,000	20,000,000 (2)	20,056,000
Annual Fuel Cost \$	18,000,000 (3)	18,000,000	18,000,000	9,000,000 (4)	9,000,000
Labor & Maint. (5) \$	8,100,000	8,100,000	8,100,000	8,100,000	8,100,000
Total Annual Cost (6) \$	66,100,000	66,116,000	66,156,000	37,100,000	37,156,000
Electricity Cost (7) Mills/kwhr	24.481	24.487	24.502	13.741	13.762
Increase - %	---	0.024	0.086	---	0.153
Increase - Mills/kwhr	---	0.006	0.021	---	0.021

Based on: (1) Annual Fixed Charge Rate of 16% x 500 \$/kw x 500,000 kw.  
 (2) 16% x 250 \$/kw x 500,000 kw.  
 (3) 0.70 \$/10<sup>6</sup> BTU coal cost x 5400 hr/yr x 500,000 kw x 9500 BTU/kwhr.  
 (4) 0.35 \$/10<sup>6</sup> BTU coal cost x 5400 hr/yr x 500,000 kw x 9500 BTU/kwhr.  
 (5) Labor and maintenance cost of 3.0 mills/kwhr.  
 (6) 5400 hr/yr at 500 MW - 2700 gwhr/yr.  
 (7) Cost at plant bus bar; transmission and distribution not included.



The increases in generating costs (mills/kwhr) for typical 100 MW plants are approximately double the increases for 500 MW plants. The increases for 600 MW plants with divided furnaces are 25% to 35% higher; and the increases for 1000 MW plants are the same as for 500 MW plants.

Transmission and distribution costs are not included in these comparisons. These examples are only typical; a specific plant has to be evaluated on its particular economic criteria.

### Applicability

#### Existing Steam Generating Units

In a specific existing plant, the exploratory field test program will provide the data to determine whether an overfire air system is needed to meet NO<sub>x</sub> limits. If so, the biased firing tests will show operating effects such as combustible loss, corrosion, or furnace slagging. Favorable results from the field tests should be followed by an evaluation as shown in Table 1 to determine whether modification costs are economically justified.

Economic considerations include plant age and efficiency. Will the plant continue to operate long enough to pay off the investment? The annual capital cost is inversely proportional to the number of years. Steam generator size also has an effect on the relative economics of overfire air system modifications. For example, the minimum modification cost is about \$100,000, which is 4\$/kw for a 25 MW unit. With complications, 10\$/kw is possible for a 25 MW unit.

Approximately 40% of the existing coal fired units in the United States are of tangential design and could conceivably be modified to incorporate overfire air systems, if the field test and economic evaluation



results are favorable. Since 1949, approximately 320 tangential units have been put into service without overfire air systems.

#### New Steam Generating Units

At the current levels of  $\text{NO}_x$  limits, an overfire air system should be included as a standard design feature of a new unit. The technology is proven, and the cost is minimal when included in the original design.





## REFERENCES

1. Crawford, A. P., Manny, E. H. and Bartok, W., "Field Testing: Application of Combustion Modifications to Control NO<sub>x</sub> Emissions From Utility Boilers"




BASELINE STUDY  
NO<sub>x</sub> TEST DATA SUMMARY


TEST NO		1	2	3	4	5	6	7
PURPOSE OF TEST		EXCESS AIR VAR - CLEAN FURN COND.						
		1/2 LOAD	1/2 LOAD	3/4 LOAD	3/4 LOAD	FULL LOAD	FULL LOAD	
DATL		11-30-73	11-30-73	11-30-73	1-18-74	11-14-73	11-28-73	11-28-73
LOAD	MW <sub>3</sub>	66	65	67	93	124	123	123
MAIN STEAM FLOW	10 <sup>3</sup> KG/HR	219	224	214	316	404	407	405
EXCESS AIR ECON OUTLET	%	35.5	17.5	58.9	12.6	22.7	11.7	30.8
THEO AIR TO FUEL FIRING ZONE	%	130.6	117.1	151.3	109.2	117.9	107.2	125.3
FUEL FLEV IN SERV.		ABC	ABC	ABC	ABC	ALL	ALL	ALL
FUEL NOZZLE TILT	DEG	+3	+7	+3	+8	+3	0	0
	AUX	20	0	50	30	60	100	100
	FUEL	30	30	30	20	20	30	30
	AUX	20	0	50	60	100	100	100
	FUEL	30	30	30	20	20	30	30
	AUX /AUX	20/20	20/10	50/50	80/80	100/100	100/100	100/100
	FUEL	30	30	30	20	20	30	30
	AUX	20	10	50	50	100	100	100
	FUEL	0	0	0	0	20	30	30
	AUX	0	0	0	0	100	100	100
SHO TEMPERATURE	°C	529	498	548	500	539	539	538
RHO TEMPERATURE	°C	488	446	517	499	514	524	524
UNIT EFFICIENCY	%	88.3	88.2	87.6	89.3	89.0	89.1	89.5
GAS WEIGHT FNT A.H	10 <sup>3</sup> KG/HR	352	360	412	386	554	578	592
NO	PPM - O <sub>2</sub>	631	489	718	429	494	357	664
NO <sub>2</sub>	GR/10 <sup>6</sup> CAL	1.337	1.030	1.519	900	1.041	761	1.403
SO <sub>2</sub>	PPM - O <sub>2</sub>	2298	2318	1644	1635	1641	1434	1455
SO <sub>3</sub>	GR/10 <sup>6</sup> CAL	6.770	6.794	4.841	4.769	4.815	4.254	4.278
CO	PPM - O <sub>2</sub>	24.51	142.26	8.05	39.09	31.16	152.88	32.91
CO <sub>2</sub>	GR/10 <sup>6</sup> CAL	.0316	.182	.0104	.0499	.0400	.198	.0423
HC	PPM - O <sub>2</sub>	144	.160	0.0	0.0	509	0.0	0.0
O <sub>2</sub>	% A.H. IN	5.59	3.20	7.89	2.40	3.96	2.26	5.02
O <sub>3</sub>	% A.H. OUT	7.28	5.61	9.09	5.14	6.24	4.63	6.87
CARBON LOSS IN FLYASH	%	29	.97	17	.96	.48	57	20
DUST LOADING	GR/SCM					4.19		

TEST NO		8	9	10	11	12	13	14
PURPOSE OF TEST		E.A. VAR. MOD DIRTY FURN.			E.A. VAR. DIRTY FURN			
		FULL LOAD	FULL LOAD	FULL LOAD	1/2 LOAD	FULL LOAD	FULL LOAD	
DATL		11-15-73	11-19-73	11-19-73	12-5-73	12-4-73	11-16-73	11-16-73
LOAD	MW <sub>3</sub>	126	122	124	66	74	125	125
MAIN STEAM FLOW	10 <sup>3</sup> KG/HR	411	403	405	211	206	412	406
EXCESS AIR ECON OUTLET	%	21.5	13.0	26.0	32.7	51.2	20.7	24.3
THEO AIR TO FUEL FIRING ZONE	%	116.9	108.5	120.8	128.0	144.1	115.7	119.2
FUEL FLEV IN SERV		ALL	ALL	ALL	ABC	ABC	ALL	ALL
FUEL NOZZLE TILT	DEG	+8	-22	-22	0	0	-22	-22
	AUX	60	100	100	20	50	100	100
	FUEL	30	30	30	30	30	30	30
	AUX	100	100	100	20	50	100	100
	FUEL	30	30	30	30	30	30	30
	AUX /AUX	100/100	100/100	100/100	20/20	50/50	100/100	100/100
	FUEL	30	30	30	30	30	30	30
	AUX	100	100	100	20	50	100	100
	FUEL	30	30	30	0	0	30	30
	AUX	100	100	100	0	0	100	100
SHO TEMPERATURE	°C	548	533	544	518	548	539	543
RHO TEMPERATURE	°C	533	510	531	476	508	522	529
UNIT EFFICIENCY	%	89.6	89.6	89.6	88.3	87.9	89.2	89.3
GAS WEIGHT FNT A.H	10 <sup>3</sup> KG/HR	567	502	565	222	269	556	567
NO	PPM - O <sub>2</sub>	421	361	581	536	658	499	506
NO <sub>2</sub>	GR/10 <sup>6</sup> CAL	.894	.748	1.198	1.118	1.370	1.037	1.221
SO <sub>2</sub>	PPM - O <sub>2</sub>	1171	2052	2179	2348	2164	1917	1370
SO <sub>3</sub>	GR/10 <sup>6</sup> CAL	3.458	5.922	6.251	6.821	6.267	5.538	3.985
CO	PPM - O <sub>2</sub>	45.75	431.8	5.48	297.59	220.56	40.85	22.61
CO <sub>2</sub>	GR/10 <sup>6</sup> CAL	.0591	.545	.0069	.378	.280	.052	.042
HC	PPM - O <sub>2</sub>	61	128	1.54	0.0	0.0	.512	.227
O <sub>2</sub>	% A.H. IN	3.78	2.47	4.41	5.26	7.20	3.66	4.18
O <sub>3</sub>	% A.H. OUT	5.31	4.00	6.64	6.99	8.63	6.01	6.47
CARBON LOSS IN FLYASH	%	.16	.27	.05	.58	.20	.17	.10



# BIASED FIRING STUDY NO<sub>x</sub> TEST DATA SUMMARY

Test No.		15	16	17	18	19
		Biased Firing - 1 Fuel Elev. Out of Service - Air Dampers Open				
Purpose of Test		1/2 Load	3/4 Load	Max Load		
Date		1-19-74	1-18-74	12-3-73	12-4-73	12-5-73
Load	MW <sub>3</sub>	66	96	100	103	99
Main Steam Flow	10 <sup>3</sup> Kg/HR	199	297	315	321	321
Excess Air Econ Outlet	%	50.1	26.7	21.1	22.2	21.8
Theo Air to Fuel Firing Zone	%	105.8	121.7	116.5	117.5	117.2
Fuel Elev In Serv.		ABC	ABC	ABC	ABD	ACD
Fuel Nozzle Tilt	Deg	-9	0	-15	-15	-10
	Aux.	50	50	50	50	50
	Fuel	20	20	30	30	30
	Aux	50	50	50	50	100
	Fuel	20	20	30	30	100
	Aux /Aux.	50/50	50/50	50/50	50/100	50/50
	Fuel	20	20	30	100	30
	Aux.	50	50	50	50	50
	Fuel	100	100	100	30	30
	Aux.	100	100	100	50	50
SHO Temperature	°C	546	539	529	543	523
RHO Temperature	°C	496	506	501	520	486
Unit Efficiency	% <sup>3</sup>	87.9	89.3	89.1	89.3	88.9
Gas Weight Ent A H	10 <sup>3</sup> Kg/HR	341	430	439	455	428
NO	PPM - % O <sub>2</sub>	594	543	397	373	387
NO <sub>x</sub>	GR/10 <sup>6</sup> CAL <sup>2</sup>	1.206	1.142	840	792	.795
SO <sub>2</sub>	PPM - % O <sub>2</sub>	1721	1682	2422	2553	2292
SO <sub>2</sub>	GR/10 <sup>6</sup> CAL <sup>2</sup>	4.861	4.922	7.137	7.536	6.543
CO <sub>2</sub>	PPM - % O <sub>2</sub>	33.38	29.10	45.63	38.51	35.48
CO	GR/10 <sup>6</sup> CAL <sup>2</sup>	.0412	.0372	.0588	.0497	.0443
HC	PPM - % O <sub>2</sub>	0.0	0.0	0.0	.012	.012
O <sub>2</sub>	% A H. In	7.10	4.55	3.72	3.885	3.825
O <sub>2</sub>	% A H. Out	8.54	7.19	6.08	5.80	6.30
Carbon Loss in Flyash	%	32	34	.46	.37	.42

Test No.		20	21	22	23	24
		Biased Firing - 1 Fuel Elev Out of Service - Air Dampers Open				
Purpose of Test		Max Load	3/4 Load	1/2 Load		
Date		12-6-73	1-18-74	1-19-74	1-19-74	1-19-74
Load	MW <sub>3</sub>	102	94	64	64	66
Main Steam Flow	10 <sup>3</sup> Kg/HR	314	308	208	211	202
Excess Air Econ Outlet	%	24.2	29.0	48.0	47.0	47.0
Theo. Air to Fuel Firing Zone	%	94.7	97.3	112.5	141.4	141.3
Fuel Elev in Service.		BCD	BCD	BCD	ACD	ABD
Fuel Nozzle Tilt	Deg.	-5	+10	0	0	-15
	Aux.	100	100	100	50	50
	Fuel	100	100	100	20	20
	Aux	50	50	50	100	50
	Fuel	30	20	20	100	20
	Aux /Aux	50/50	50/50	50/50	50/50	50/100
	Fuel	30	20	20	20	100
	Aux	50	50	50	50	50
	Fuel	30	20	20	20	20
	Aux	50	50	50	50	50
SHO Temperature	°C	544	512	501	507	544
RHO Temperature	°C	515	469	448	454	513
Unit Efficiency	% <sup>3</sup>	88.8	89.6	87.8	87.9	87.7
Gas Weight Ent A H	10 <sup>3</sup> Kg/HR	451	435	360	361	356
NO	PPM - % O <sub>2</sub>	285	331	520	485	609
NO <sub>x</sub>	GR/10 <sup>6</sup> CAL <sup>2</sup>	599	696	1.124	1.043	1.282
SO <sub>2</sub>	PPM - % O <sub>2</sub>	2277	1566	1861	2245	1807
SO <sub>2</sub>	GR/10 <sup>6</sup> CAL <sup>2</sup>	6.661	4.578	5.593	6.710	5.288
CO <sub>2</sub>	PPM - % O <sub>2</sub>	26.61	31.28	29.10	22.41	27.54
CO	GR/10 <sup>6</sup> CAL <sup>2</sup>	.0341	.0400	.0382	.0293	.0353
HC	PPM - % O <sub>2</sub>	0.0	0.0	0.0	0.0	0.0
O <sub>2</sub>	% A H. In	4.165	4.76	6.93	6.85	6.79
O <sub>2</sub>	% A.H. Out	7.31	8.37	8.40	8.58	6.87
Carbon Loss in Flyash	%	25	30	20	11	.21
Dust Loading	GR/SCM	8.65				



# NO<sub>x</sub> TEST DATA SUMMARY

## BASELINE STUDY AFTER MODIFICATION


TEST NO.	1	2	3	4	5	6	7
Purpose of Test	Excess Air Var. - Clean Furnace Cond.						
	1/2 Load		3/4 Load		Maximum Load		
Date	6/25/74	6/25/74	6/25/74	6/27/74	6/19/74	6/27/74	6/27/74
Load MW	62	62	64	92	131	127	125
Main Steam Flow 10 <sup>3</sup> KG/HR	219	213	217	315	450	441	423
Excess Air Econ Outlet %	33.5	16.0	64.7	15.5	21.0	12.4	25.4
Theo Air to Fuel Firing Zone %	127.1	113.4	155.4	111.0	115.3	107.1	119.5
Fuel Elev In Serv	ABC	ABC	ABC	ABC	ALL	ALL	ALL
OFA Nozzle Tilt DEG	0	0	0	0	0	0	0
Fuel Nozzle Tilt DEG	3	6	-14	2	-13	-3	-22
	0	0	0	0	0	0	0
	0	0	0	0	0	0	0
	20	0	50	30	80	100	100
	30	30	30	20	30	30	35
	20	0	50	60	100	100	100
	30	30	30	20	30	30	35
	20/20	10/10	50/50	80/80	100/100	100/100	100/100
	30	30	30	20	30	30	35
	20	10	50	50	100	100	100
	0	0	0	0	30	30	35
	0	0	0	0	100	100	100
SHO Temperature °C	492	468	536	504	528	524	518
RHO Temperature °C	435	402	499	466	488	487	480
Unit Efficiency %	88.4	88.8	87.4	89.8	88.4	89.2	89.5
Gas Weight Ent A.H 10 <sup>3</sup> KG/HR	335	270	413	398	593	546	559
NO <sub>x</sub> PPM - 0% O <sub>2</sub>	444	335	640	327	404	330	477
NO <sub>2</sub> GR/10 <sup>6</sup> CAL	929	701	1 339	684	846	692	1 000
SO <sub>2</sub> PPM - 0% O <sub>2</sub>	3678	3621	2611	2634	2251	2677	2707
SO <sub>2</sub> GR/10 <sup>6</sup> CAL	10.718	10.551	7 606	7 674	6 559	7 800	7 889
CO PPM - 0% O <sub>2</sub>	27.54	375.77	34.66	109.70	26.37	127.2	21.74
CO GR/10 <sup>6</sup> CAL	0351	4790	0442	1398	0336	1622	0277
HC PPM - 0% O <sub>2</sub>	0	0	0	0	0	0	0
O <sub>2</sub> % A.H In	5.36	2.95	8.36	2.87	3.71	2.36	4.34
O <sub>2</sub> % A.H Out	7.35	5.52	9.70	5.5	7.36	5.75	7.02
Carbon Loss In Flyash %	29	23	1.06	11	75	51	74


TEST NO.	8	9	10	11	12	13	14
Purpose of Test	E A Var - Mod Dirty Furnace			E A Var - Dirty Furnace			
	Maximum Load			1/2 Load	Maximum Load		
Date	6/20/74	6/20/74	6/28/74	6/26/74	6/26/74	6/28/74	6/28/74
Load MW	130	129	125	55	68	126	125
Main Steam Flow 10 <sup>3</sup> KG/HR	440	446	428	246	218	432	425
Excess Air Econ Outlet %	17.8	12.1	26.6	30.9	63.1	22.0	25.9
Theo Air to Fuel Firing Zone %	112.3	106.9	120.5	124.6	154.0	116.2	119.9
Fuel Elev In Serv	ALL	ALL	ALL	ABC	ABC	ALL	ALL
OFA Nozzle Tilt DEG	0	0	0	0	0	0	0
Fuel Nozzle Tilt DEG	-21	-17	-6	-16	-16	-6	-6
	0	0	0	0	0	0	0
	0	0	0	0	0	0	0
	80	80	100	20	50	100	100
	30	30	30	30	30	30	30
	100	100	100	20	50	100	100
	30	30	30	30	30	30	30
	100/100	100/100	100/100	20/20	50/50	100/100	100/100
	30	30	30	30	30	30	30
	100	100	100	20	50	100	100
	30	30	30	0	0	30	30
	100	100	100	0	0	100	100
SHO Temperature °C	526	528	524	507	531	524	529
RHO Temperature °C	486	483	480	457	498	496	499
Unit Efficiency %	89.0	88.9	89.5	89.3	88.0	89.0	89.4
Gas Weight Ent A.H 10 <sup>3</sup> KG/HR	565	542	584	363	419	575	583
NO <sub>x</sub> PPM - 0% O <sub>2</sub>	470	334	431	373	626	391	431
NO <sub>2</sub> GR/10 <sup>6</sup> CAL	985	699	902	782	1 310	819	902
SO <sub>2</sub> PPM - 0% O <sub>2</sub>	1941	2482	2500	2558	2461	2564	2629
SO <sub>2</sub> GR/10 <sup>6</sup> CAL	5 655	7 232	7 283	7 453	7 171	7 470	7 661
CO PPM - 0% O <sub>2</sub>	24.31	97.16	23.55	26.28	23.85	23.4	22.92
CO GR/10 <sup>6</sup> CAL	0310	1239	0300	0335	0304	0298	0292
HC PPM - 0% O <sub>2</sub>	0	0	0	0	0	0	0
O <sub>2</sub> % A.H In	3.24	2.31	4.5	5.04	8.23	3.86	4.4
O <sub>2</sub> % A.H Out	6.8	6.19	7.48	7.55	10.75	7.3	7.15
Carbon Loss in Flyash %	22	42	61	17	05	36	25



# NO<sub>x</sub> TEST DATA SUMMARY

## OVERFIRE AIR LOCATION, RATE & VELOCITY VARIATION


TEST NO	15	16	17	18A	19
Purpose of Test	OFA Damper Position Variation				
	← 3/4 Load →				
Date	7/10/74	7/10/74	7/10/74	7/12/74	7/11/74
Load MW	97	98	100	100	100
Main Steam Flow 10 <sup>3</sup> KG/HR	336	340	338	344	338
Excess Air Econ Outlet %	28.5	27.1	25.6	26.6	24.8
Theo Air to Fuel Firing Zone %	114.5	96.7	95.8	84.8	89.3
Fuel Elev In Serv	BCD	BCD	BCD	BCD	BCD
OFA Nozzle Tilt DEG	0	0	0	0	0
Fuel Nozzle Tilt DEG	-5	-5	-5	-4	-4
	OFA	100	0	100	50
	OFA	0	0	100	50
	Aux	0	0	0	0
	Fuel	0	0	0	0
	Aux	50	50	50	50
	Fuel	30	30	30	30
	Aux /Aux	50/50	50/50	50/50	50/50
	Fuel	30	30	30	30
	Aux	50	50	50	50
	Fuel	30	30	30	30
	Aux	50	50	50	50
SHO Temperature °C	518	510	514	524	521
RHO Temperature °C	457	452	457	476	486
Unit Efficiency %	90.0	89.8	89.7	89.6	89.3
Gas Weight Ent A H 10 <sup>3</sup> KG/HR	458	447	442	466	468
NO <sub>x</sub> PPM - 0% O <sub>2</sub>	345	254	254	229	232
NO <sub>2</sub> GR/10 <sup>6</sup> CAL	723	533	533	479	486
SO <sub>2</sub> PPM - 0% O <sub>2</sub>	1892	1973	2092	2397	2684
SO <sub>2</sub> GR/10 <sup>6</sup> CAL	5.512	5.750	6.097	6.984	7.821
CO PPM - 0% O <sub>2</sub>	28.10	29.96	32.4	48.08	39.20
CO GR/10 <sup>6</sup> CAL	0358	.0382	0413	.0613	0500
HC PPM - 0% O <sub>2</sub>	0	0	0	0	0
O <sub>2</sub> % A H In	4.74	4.55	4.36	4.5	4.25
O <sub>2</sub> % A H Out	6.51	6.49	6.08	6.32	6.05
Carbon Loss in Flyash %	51	59	63	.54	.32

TEST NO	20	21	22	23
Purpose of Test	OFA Damper Position Variation			
	← 3/4 Load →			
Date	7/11/74	7/12/74	7/12/74	7/12/74
Load MW	100	102	102	102
Main Steam Flow 10 <sup>3</sup> KG/HR	344	342	341	346
Excess Air Econ Outlet %	25.4	25.4	27.9	28.1
Theo Air to Fuel Firing Zone %	100.5	117.4	90.4	96.9
Fuel Elev In Serv	BCD	ABC	ABC	ABC
OFA Nozzle Tilt DEG.	0	0	0	0
Fuel Nozzle Tilt DEG	-4	-4	-4	-4
	OFA	0	100	50
	OFA	0	100	50
	Aux	100	100	50
	Fuel	0	100	50
	Aux	50	50	50
	Fuel	30	30	30
	Aux /Aux	50/50	50/50	50/50
	Fuel	30	30	30
	Aux	50	50	50
	Fuel	30	0	0
	Aux	50	0	0
SHO Temperature °C	524	532	524	521
RHO Temperature °C	479	498	491	485
Unit Efficiency %	90.2	90.1	89.0	89.1
Gas Weight Ent A H 10 <sup>3</sup> KG/HR	468	476	494	492
NO <sub>x</sub> PPM - 0% O <sub>2</sub>	323	483	329	336
NO <sub>2</sub> GR/10 <sup>6</sup> CAL	677	1.012	689	704
SO <sub>2</sub> PPM - 0% O <sub>2</sub>	1821	1814	2259	2417
SO <sub>2</sub> GR/10 <sup>6</sup> CAL	5.308	5.284	6.583	7.042
CO PPM - 0% O <sub>2</sub>	28.79	25.16	25.79	25.28
CO GR/10 <sup>6</sup> CAL	0367	0321	0329	0322
HC PPM - 0% O <sub>2</sub>	0	0	0	0
O <sub>2</sub> % A H In	4.33	4.33	4.67	4.69
O <sub>2</sub> % A H Out	6.14	6.05	6.46	6.72
Carbon Loss in Flyash %	49	46	54	60




## NO<sub>x</sub> TEST DATA SUMMARY

### OFA TILT VARIATION

TEST NO	24	25	26	27	28	29
Purpose of Test	OFA & Fuel Nozzle Tilt Variation ← Full Load →					
Date	7/29/74	7/29/74	7/29/74	7/29/74	7/29/74	7/29/74
Load MW	124	124	124	125	125	124
Main Steam Flow 10 <sup>3</sup> KG/HR	407	418	412	407	414	418
Excess Air Econ Outlet %	25.9	23.7	25.1	22.3	20.2	23.7
Theo Air to Fuel Firing Zone %	94.2	92.4	93.2	91.5	89.6	92.6
Fuel Elev In Serv	ALL	ALL	ALL	ALL	ALL	ALL
OFA Nozzle Tilt DEG.	0	0	0	-30	-30	+30
Fuel Nozzle Tilt DEG.	-5	-23	+19	-5	+22	-21
	OFA	100	100	100	100	100
	OFA	100	100	100	100	100
	Aux	100	100	100	100	100
	"A" Fuel	100	100	100	100	100
	Aux	50	50	50	50	50
	"B" Fuel	30	30	30	30	30
	Aux./Aux	50/50	50/50	50/50	50/50	50/50
	"C" Fuel	30	30	30	30	30
	Aux	50	50	50	50	50
	"D" Fuel	30	30	30	30	30
	Aux	50	50	50	50	50
	Aux	50	50	50	50	50
SHO Temperature °C	538	521	524	527	524	521
RHO Temperature °C	532	508	527	533	535	505
Unit Efficiency %	89.6	89.3	88.9	89.3	88.6	89.4
Gas Weight Ent A H 10 <sup>3</sup> KG/HR	548	566	585	557	586	544
NO <sub>x</sub> PPM - 0% O <sub>2</sub>	339	290	368	344	404	285
NO <sub>2</sub> GR/10 <sup>6</sup> CAL	710	609	770	721	846	596
SO <sub>2</sub> PPM - 0% O <sub>2</sub>	2450	2920	3310	3160	3370	3240
SO <sub>2</sub> GR/10 <sup>6</sup> CAL	7.140	8.511	9.647	9.208	9.820	9.443
CO PPM - 0% O <sub>2</sub>	25.4	27.1	31.8	22.1	28.2	49.4
CO GR/10 <sup>6</sup> CAL	0324	0346	0406	0282	0360	0630
HC PPM - 0% O <sub>2</sub>	0	0	0	0	0	0
O <sub>2</sub> % A H In	4.4	4.1	4.3	3.9	3.6	4.1
O <sub>2</sub> % A H Out	5.9	6.0	6.2	6.0	5.8	6.4
Carbon Loss In Flyash %	37	.37	40	29	29	49

## LOAD VARIATION AT OPTIMUM CONDITIONS

TEST NO	30	31	32	33	34	35
Purpose of Test	Load Variation at Optimum Conditions					
	Max Load	3/4 Load	1/2 Load	Max. Load	3/4 Load	1/2 Load
Date	7/30/74	7/31/74	7/31/74	7/31/74	7/31/74	8/1/74
Load MW	125	97	65	122	95	64
Main Steam Flow 10 <sup>3</sup> KG/HR	416	314	204	409	310	204
Excess Air Econ Outlet %	21.6	25.2	46.9	27.4	27.4	45.9
Theo Air to Fuel Firing Zone %	90.7	89.4	88.5	94.6	90.6	88.5
Fuel Elev In Serv	ALL	ABC	AB	ALL	ABC	AB
OFA Nozzle Tilt DEG	0	-12	0	-22	-22	-10
Fuel Nozzle Tilt DEG	-4	-16	-5	-22	-22	-15
	OFA	100	100	100	100	100
	OFA	100	100	100	100	100
	Aux	100	100	100	100	100
	"A" Fuel	100	100	100	100	100
	Aux	50	50	50	50	50
	"B" Fuel	30	30	30	30	30
	Aux./Aux	50/50	50/50	50/50	50/50	50/50
	"C" Fuel	30	30	30	30	30
	Aux	50	50	50	50	50
	"D" Fuel	30	0	30	0	0
	Aux	50	0	50	0	0
	Aux	50	0	50	0	0
SHO Temperature °C	538	525	535	521	506	512
RHO Temperature °C	536	514	514	521	493	493
Unit Efficiency %	89.0	89.1	89.2	89.0	88.2	89.0
Gas Weight Ent A H 10 <sup>3</sup> KG/HR	574	456	341	584	472	329
NO <sub>x</sub> PPM - 0% O <sub>2</sub>	339	338	396	333	291	313
NO <sub>2</sub> GR/10 <sup>6</sup> CAL	710	708	828	697	608	655
SO <sub>2</sub> PPM - 0% O <sub>2</sub>	1680	1730	1740	2430	2490	2420
SO <sub>2</sub> GR/10 <sup>6</sup> CAL	4.896	5.043	5.070	7.083	7.256	6.960
CO PPM - 0% O <sub>2</sub>	26.1	26.1	24.4	24.8	26.4	25.0
CO GR/10 <sup>6</sup> CAL	0333	0333	0311	0316	0337	0319
HC PPM - 0% O <sub>2</sub>	0	0	0	0	0	0
O <sub>2</sub> % A H In	3.8	4.3	6.8	4.6	4.6	6.7
O <sub>2</sub> % A H Out	5.3	5.7	8.2	6.3	6.8	8.4
Carbon Loss In Flyash %	61	39	.32	24	33	15
Dust Loading GR/SCM	8.64					



## WATERWALL CORROSION COUPON DATA SUMMARY

### WEIGHT LOSS EVALUATION

#### BASELINE TEST

<u>Probe Loc.</u>	<u>Probe No.</u>	<u>Coupon No.</u>	<u>Initial Wt. GR.</u>	<u>Final Wt. GR.</u>	<u>Wt. Loss GR.</u>	<u>Wt. Loss/ Coupon MG/CM<sup>2</sup></u>	<u>Avg. Wt. Loss/ Probe MG/CM<sup>2</sup></u>
1	I	1	199.2937	199.1341	.1596	3.1643	2.9392
		2	201.3871	201.2135	.1736	3.4418	
		3	198.3883	198.2384	.1499	2.9719	
		4	195.8045	195.6946	.1099	2.1789	
2	J	1	199.1977	199.0534	.1443	2.8609	2.8088
		2	199.6807	199.5009	.1798	3.5647	
		3	202.8649	202.7226	.1423	2.8213	
		4	202.3445	202.2442	.1003	1.9885	
3	E	1	199.0122	198.8632	.1490	2.9541	2.13475
		2	202.2508	202.1171	.1337	2.6507	
		3	201.9826	201.8976	.0850	1.6852	
		4	199.6584	199.5954	.0630	1.249	
4	L	1	202.5778	202.5080	.0698	1.3838	1.91965
		2	200.8579	200.7484	.1095	2.1769	
		3	202.7075	202.5924	.1151	2.282	
		4	197.7676	197.6750	.0926	1.8359	
5	K	1	199.5913	---	---	---	3.38826
		2	197.4684	197.2730	.1954	3.874	
		3	194.9513	194.7783	.1730	3.4299	
		4	202.0694	201.9251	.1443	2.8609	

Avg. Wt. Loss/Test 2.6381 MG/CM<sup>2</sup>



## WATERWALL CORROSION COUPON DATA SUMMARY

### WEIGHT LOSS EVALUATION

#### BIASED FIRING TEST

<u>Probe Loc.</u>	<u>Probe No.</u>	<u>Coupon No.</u>	<u>Initial Wt. GR.</u>	<u>Final Wt. GR.</u>	<u>Wt. Loss GR.</u>	<u>Wt. Loss/ Coupon MG/CM<sup>2</sup></u>	<u>Avg. Wt. Loss/ Probe MG/CM<sup>2</sup></u>
1	B	1	197.9531	197.6484	.3047	6.0411	5.8795
		2	202.1660	201.8659	.3001	5.9499	
		3	198.3393	198.0383	.3010	5.9678	
		4	200.5603	200.2799	.2804	5.5593	
2	Q	1	199.3158	199.1437	.1721	3.4121	4.3777
		2	196.2751	196.0480	.2271	4.5026	
		3	202.8709	202.5541	.3168	6.2810	
		4	200.2327	200.0655	.1672	3.3150	
3	R	1	198.8940	198.7626	.1314	2.6051	3.4081
		2	199.8790	199.6842	.1948	3.8622	
		3	196.0683	195.8721	.1962	3.8899	
		4	199.3342	199.1690	.1652	3.2753	
4	M	1	199.5078	199.3628	.1450	2.8748	3.8201
		2	198.7039	198.4853	.2186	4.3341	
		3	198.3125	198.1121	.2004	3.9732	
		4	200.8838	200.6771	.2067	4.0981	
5	D	1	197.9655	197.7001	.2654	5.2619	5.7289
		2	202.9412	202.5809	.3603	7.1435	
		3	199.1306	198.7976	.3330	6.6022	
		4	198.2205	198.0234	.1971	3.9078	

Avg. Wt. Loss/Test 4.6429 MG/CM<sup>2</sup>



## WATERWALL CORROSION COUPON DATA SUMMARY

### WEIGHT LOSS EVALUATION

#### OVERFIRE AIR TEST

<u>Probe Loc.</u>	<u>Probe No.</u>	<u>Coupon No.</u>	<u>Initial Wt. GR.</u>	<u>Final Wt. GR.</u>	<u>Wt. Loss GR.</u>	<u>Wt. Loss/ Coupon MG/CM<sup>2</sup></u>	<u>Avg. Wt. Loss/ Probe MG/CM<sup>2</sup></u>
1	S	1	200.7678	200.5465	.2213	4.3876	4.5244
		2	196.0684	195.8121	.2563	5.0815	
		3	199.6433	199.3849	.2584	5.1235	
		4	197.8187	197.6419	.1768	3.5053	
2	T	1	200.7026	199.1437	.2802	5.5554	3.9044
		2	---	---	---	3.3540	
		3	593.7075	593.2000	.5075	3.3540	
		4	---	---	---	3.3540	
3	F	1	199.1897	198.9156	.2741	5.4344	6.0401
		2	199.4476	199.1351	.3125	6.1958	
		3	199.3119	198.9858	.3261	6.4654	
		4	199.0463	198.7404	.3059	6.0649	
4	N	1	202.8354	202.6125	.2234	4.4292	3.7656
		2	201.2249	200.9784	.2465	4.8872	
		3	---	---	---	2.8729	
		4	397.4898	397.2000	.2898	2.8729	
5	2	1	---	---	---	---	3.9752
		2	191.8528	191.6484	.2044	4.0525	
		3	192.7875	192.5909	.1966	3.8979	
		4	---	---	---	---	

Avg. Wt. Loss/Test 4.4419 MG/CM<sup>2</sup>



**TECHNICAL REPORT DATA**  
(Please read instructions on the reverse before completing)

1 REPORT NO EPA-650/2-73-005-b		2		3 RECIPIENT'S ACCESSION NO	
4 TITLE AND SUBTITLE Program for Reduction of NO <sub>x</sub> from Tangential Coal-Fired Boilers, Phase IIa--NO <sub>x</sub> Control Technology Application Study				5 REPORT DATE August 1975	
				6 PERFORMING ORGANIZATION CODE	
7 AUTHOR(S) Ambrose P. Selker				8 PERFORMING ORGANIZATION REPORT NO	
9 PERFORMING ORGANIZATION NAME AND ADDRESS Combustion Engineering, Inc. 1000 Prospect Hill Road Windsor, Connecticut 06095				10 PROGRAM ELEMENT NO 1AB014; ROAP 21ADG-080	
				11 CONTRACT/GRANT NO 68-02-1367	
12 SPONSORING AGENCY NAME AND ADDRESS EPA, Office of Research and Development Industrial Environmental Research Laboratory Research Triangle Park, NC 27711				13 TYPE OF REPORT AND PERIOD COVERED Task IX Final; 7/73 - 3/75	
				14 SPONSORING AGENCY CODE	
15 SUPPLEMENTARY NOTES					
16 ABSTRACT The report gives results of Task IX of a program to reduce NO <sub>x</sub> from tangential coal-fired boilers. Results are based on current contractor experience, as well as on field performance tests performed at Alabama Power Corporation's Barry Unit No. 2. Use of overfire air as an NO <sub>x</sub> control technique is discussed relative to: equipment modifications and costs (as of March 1975) associated with applying this technology to existing steam generators; limitations to the general application of developed technology; and emission control and cost effectiveness of applying developed technology to new steam generator designs.					
17 KEY WORDS AND DOCUMENT ANALYSIS					
a. DESCRIPTORS		b. IDENTIFIERS/OPEN ENDED TERMS		c. COSATI Field/Group	
Air Pollution Nitrogen Oxides Boilers Coal Combustion Control Cost Effectiveness		Air Pollution Control Stationary Sources Tangential Firing Overfire Air Combustion Modification		13B 07B 13A 21D 21B 14A	
18 DISTRIBUTION STATEMENT  Unlimited		19 SECURITY CLASS (This Report) Unclassified		21 NO OF PAGES 37	
		20 SECURITY CLASS (This page) Unclassified		22 PRICE	