

EPA-650/2-75-057-f

September 1975

Environmental Protection Technology Series

**SURVEY
OF FLUE GAS
DESULFURIZATION SYSTEMS
EDDYSTONE STATION, PHILADELPHIA ELECTRIC CO.**



U.S. Environmental Protection Agency
Office of Research and Development
Washington, D. C. 20460

**SURVEY
OF FLUE GAS
DESULFURIZATION SYSTEMS
EDDYSTONE STATION, PHILADELPHIA ELECTRIC CO.**

by

Gerald A. Isaacs

PEDCo-Environmental Specialists, Inc.
Suite 13
Atkinson Square
Cincinnati, Ohio 45246

Contract No. 68-02-1321, Task 6f
ROAP No. 21ACX-130
Program Element No. 1AB013

EPA Project Officer: Norman Kaplan

Industrial Environmental Research Laboratory
Office of Energy, Minerals, and Industry
Research Triangle Park, North Carolina 27711

Prepared for

U.S. ENVIRONMENTAL PROTECTION AGENCY
Office of Research and Development
Washington, D. C. 20460

September 1975

EPA REVIEW NOTICE

This report has been reviewed by the U.S. Environmental Protection Agency and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the Environmental Protection Agency, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

RESEARCH REPORTING SERIES

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into series. These broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and maximum interface in related fields. These series are:

1. ENVIRONMENTAL HEALTH EFFECTS RESEARCH
2. ENVIRONMENTAL PROTECTION TECHNOLOGY
3. ECOLOGICAL RESEARCH
4. ENVIRONMENTAL MONITORING
5. SOCIOECONOMIC ENVIRONMENTAL STUDIES
6. SCIENTIFIC AND TECHNICAL ASSESSMENT REPORTS
9. MISCELLANEOUS

This report has been assigned to the ENVIRONMENTAL PROTECTION TECHNOLOGY series. This series describes research performed to develop and demonstrate instrumentation, equipment and methodology to repair or prevent environmental degradation from point and non-point sources of pollution. This work provides the new or improved technology required for the control and treatment of pollution sources to meet environmental quality standards.

This document is available to the public for sale through the National Technical Information Service, Springfield, Virginia 22161.

Publication No. EPA-650/2-75-057-f

ACKNOWLEDGMENT

This report was prepared under the direction of Mr. Timothy W. Devitt. The principal author was Dr. Gerald A. Isaacs. Mr. Charles D. Fleming was responsible for editorial review and preparation of graphic materials.

Mr. Wade H. Ponder, former EPA Project Officer, had primary responsibility within EPA for this project report. Information and data on the plant operation were supplied by Mr. George Kotnick, Philadelphia Electric Company, and by Dr. J. T. Pinkston, United Engineers and Constructors, Inc., during and subsequent to the plant survey visit.

The author appreciates the efforts and cooperation of everyone who participated in the preparation of this report.

TABLE OF CONTENTS

	<u>Page</u>
ACKNOWLEDGMENT	iii
LIST OF FIGURES	vi
LIST OF TABLES	vi
SUMMARY	vii
1.0 INTRODUCTION	1-1
2.0 FACILITY DESCRIPTION	2-1
2.1 Plant Location	2-1
2.2 Boiler Data	2-1
2.3 Pollution Controls	2-1
3.0 FLUE GAS DESULFURIZATION SYSTEM	3-1
3.1 Process Description	3-1
3.2 Design Parameters	3-3
3.3 Installation Schedule	3-5
3.4 Cost Data	3-5
APPENDIX A PLANT SURVEY FORM	A-1
APPENDIX B PLANT PHOTOGRAPHS	B-1

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
3.1 General Flow Diagram of the FGD System on Eddystone No. 1 - PECO	3-2

LIST OF TABLES

<u>Tables</u>	<u>Page</u>
2.1 Pertinent Data on Plant Design, Operation and Atmospheric Emissions	2-3

SUMMARY

The magnesium oxide based flue gas desulfurization (FGD) system on Boiler No. 1 at the Eddystone Station of Philadelphia Electric Company (PECO) was designed and installed by United Engineers and Constructors, Inc. The system consists of three first-stage scrubber modules in parallel for particulate control (two are Environeering Ventri-Rod Units; one is a Peabody-Lurgi Venturi Unit) and a second-stage Environeering absorber module with two ventri-rod beds for SO₂ removal.

The three first-stage scrubbers together are sized to handle all the exhaust gas from Unit 1 which has a net electric generating capacity of 316 MW. The second-stage absorber is sized to handle one-third of the gas flow, equivalent to about 105 MW (net). The system is designed to remove 90 percent of the SO₂ from boiler stack gas.

As of April 1, 1975 the second-stage module had not yet been operated. This report therefore necessarily emphasizes design parameters rather than operating parameters and experience.

Pertinent data on the facility and the FGD system are presented in the following table.

SUMMARY OF FGD DATA, GENERATING UNIT NO. 1

EDDYSTONE STATION

Generator rating, MW (net)	308 ^a
Fuel:	Coal
Gross heating value, BTU/lb	12,100
Ash, percent	12
Sulfur, percent	2.3
FGD vendor:	United Engineers
Process:	Magnesium oxide scrubbing
New or retrofit:	Retrofit
Start-up date:	1975
FGD modules:	1 (105 MW)
Efficiency, percent overall:	
Particulates	99.9
SO ₂	90
Make-up water, gpm/MW	1.1
Unit cost: \$/KW (net)	193 ^b

^a 316 MW net rating minus 8 MW auxiliary power for this FGD System.

^b This cost is not representative since it includes the installed cost of three first-stage particulate scrubbers to handle the exhaust gases from the complete 308 MW unit. The FGD module size of 105 MW is the basis for this calculation.

1.0 INTRODUCTION

The Industrial Environmental Research Laboratory (formerly Control Systems Laboratory) of the U.S. Environmental Protection Agency (EPA) has initiated a study to evaluate the performance characteristics and degree of reliability of flue gas desulfurization (FGD) systems on coal-fired utility boilers in the United States. This report on the Eddystone Station of Philadelphia Electric Company (PECO) is one of a series of reports on such systems. It presents values of key process design and operating parameters and describes the major system problems encountered at the facility. The report also discusses the measures taken to alleviate such problems and identifies available capital and operating costs.

This report is based upon information obtained during a plant inspection on February 11, 1975, and on subsequent data provided by PECO and United Engineers and Constructors, Inc. (UE) personnel.

Section 2.0 presents pertinent data on facility design and operation, including actual and allowable particulate and SO₂ emission rates. Section 3.0 describes the flue gas desulfurization system. Appendices present details of plant and system operation and photos of the installation.

2.0 FACILITY DESCRIPTION

2.1 PLANT LOCATION

The Eddystone Station of PECO is located on the Delaware River in Eddystone, Pennsylvania, about 11 miles southwest of the center of Philadelphia. The plant is about five miles west of one of the main runways of Philadelphia International Airport.

2.2 BOILER DATA

The station has four generators with a total net capacity of 1370 MW. Units 1 and 2 burn coal with an average gross heating value of 12,100 BTU/lb and ash and sulfur contents of 12 percent and 2.3 percent, respectively. Steam conditions are 5000 psi and 1150°F. These are the highest utility plant operating pressure and temperature conditions in the United States. Units 1 and 2, base-load units, operated at 68 percent capacity in 1974. Units 3 and 4, peak-load generators, burn No. 6 oil.

2.3 POLLUTION CONTROLS

At the present time an FGD system has been installed to handle about one-third of the exhaust gas from Unit 1. The

unit will have an estimated net generating capacity of about 308 MW with the three particulate scrubbers and the SO₂ absorber operating.

There are two furnaces on the Unit 1 boiler. Each furnace was installed with particulate controls consisting of mechanical collectors and an electrostatic precipitator.

The wet particulate and SO₂ system, designed and installed by UE, consists of three, first-stage water scrubbers for particulate control and a single, 105 MW second-stage magnesium oxide absorber for SO₂ removal. The particulate scrubber system was started up for initial shakedown purposes in February 1975. Table 2.1 gives pertinent data on plant design parameters.

Table 2.1 PERTINENT DATA ON PLANT DESIGN,
OPERATION AND ATMOSPHERIC EMISSIONS

Boiler data - Eddystone No. 1 - PECO		
Maximum generating capacity, MW (net)		308 ^a
Average capacity factor (1974), %		68
Boiler manufacturer		C-E Sulzer
Year placed in service		1959
Unit heat rate, BTU/KWH		9455
Maximum coal consumption, ton/hr		120
Maximum heat input, MM BTU/hr		2912
Stack height above grade, ft		249
Flue gas rate - maximum, acfm		927,000
Flue gas temperature, °F		294
Emission controls:		
Particulate		Mechanical and ESP and ventri-rod scrubber
SO ₂		Ventri-rod magnesium oxide absorber on one-third of the gas flow
Particulate emission rates:		
Allowable, lb/MM BTU		0.1
Design, lb/MM BTU		0.04
SO ₂ emission rates:		
Allowable, lb/MM BTU		0.6
Design, lb/MM BTU		0.3

^a Existing particulate scrubbers and FGD absorber in operation.

3.0 FLUE GAS DESULFURIZATION SYSTEM

3.1 PROCESS DESCRIPTION^a


Figure 3.1 is a schematic flow diagram for this magnesium oxide scrubbing system installed to handle approximately one-third (309,000 acfm at 294°F) of the exhaust gas from Unit 1. The maximum continuous net generating capacity for the unit was 316 MW before the scrubbing system was installed. The particulate scrubbers and the SO₂ absorber consume about 8 MW to derate the unit to about 308 MW. If additional second-stage SO₂ absorber capacity is installed on the rest of the unit it will derate the unit by an additional 2 MW.

Two of the three first-stage particulate scrubbers were manufactured by Environeering, Inc., and are venturi-rod units. The third unit is a Peabody-Lurgi venturi scrubber.

A portion of the particulate scrubber liquid circulating stream is diverted to on-site ash ponds. Make-up water from the river is pumped into the surge tanks for the three particulate scrubbers at the rate of 351 gpm (total).

Exhaust gas is drawn from the two boiler furnaces by four induced-draft fans. It then passes through the particulate

^a Adapted from "Design and Installation of a Prototype Magnesia Scrubbing Installation", B. M. Anz et al, United Engineers and Constructors Inc., May 15, 1973, and supplemented with data from field visit.




STREAM NO.		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
DRY GAS	lb/min.	15,560	15,560	15,560	23,119	16,162				24,243							
H ₂ O VAPOR	lb/min.	947	1,657	1,620	1,255	1,658				2,481							
SO ₂	lb/min.	55.3	55.3	5.5	83	5.5				8.25							
H ₂ O LIQUID	lb/min.						2,922	186	974		10,811		252		264	3,476	
ASH	lb/min.	3.33	0.67	0.67	5	0.67					1	109			2.66		
MgO	lb/min.											93.9	31.3				
MgSO ₃	lb/min.												6*			72.2*	
MgSO ₃ ·6H ₂ O	lb/min.															131.2	
AIR	lb/min.																
FUEL OIL	lb/min.																
MgSO ₄	lb/min.												17*			613*	
Mg(HSO ₃) ₂ *	lb/min.												3.0*			47.4*	
	lb/min.																
	lb/min.																
TOTAL	lb/min.	16,565.6	17,273	17,186	24,462	17,826	2,922	186	974	26,733	10,920	93.9	372.1		266.67	4,339.8	
gpm OR acfm		309,000	268,000	276,000	475,000	339,000	351	22.3	117	468,000	1,300		35.8		32	445	
SPECIFIC GRAVITY OR MOLECULAR WEIGHT		29.4	28.7	28.7	29.4	28.7	1.0	1.0	1.0	28.7	1.01		1.25		1.01	1.17	
DESIGN FLOW (3" S OR 355MM)		321,000	280,000	287,000	492,000	351,000				487,000		122	46.5				
MAX. FLOW acfm		345,000	301,000	311,000	535,000	380,000				530,000	1,600			512,000			351,000

*DISSOLVED SOLIDS.

BASIS: AVERAGE CONDITION OF 2.3% S COAL.

Figure 3.1. General flow diagram of the FGD system on Eddystone No. 1 - PECO.



17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34
													1,105	1,505			
												2.7	59	388		7.85	
													4	4			
100,800	1,156	1,486	25	845	3,749	3,302	1,897	553	4,594								4,726
2,140*	25*	32*	0.54*	17.5*	77.5*	71*	39.5*	12*	95*	122							QR*
11,200	195.3	165.1	247.6				71.8										
												206				503	
18,300*	210*	270*	4.55*	147*	653*	600*	335*	100*	800*	4.55	14.85				29.0		830.5*
1,400*	16*	21*	0.35*	11.4*	50.6*	47*	25.9*	7.6*	62*								64.3*
133,840	1,902.3	1,974.1	278	1,021	4,530	4,020	2,369.2	672.6	5,551	126.55	14.85	208.7	1,168	1,897	29.0	610.85	5,250
13,384	179	197		106	469	415	243	70	575		1.96	2,730	21,500	47,000	3.82	8,000	600
1.20	1.28	1.20		1.16	1.16	1.16	1.17	1.16	1.16		0.91	29	29.5	26.6	0.91	29	1.17
	232	256	256	138	612	540		90	750		2.55	3,550	28,000	61,000			

Figure 3.1 (continued). General flow diagram of the FGD system on Eddystone No. 1 - PECO.

scrubber and through the SO₂ absorber. From there it is reheated and drawn through a booster fan before it is discharged through the stack. Dampers in the system permit gas to bypass the SO₂ absorber or any of the particulate scrubbers.



The second-stage SO₂ absorber was designed by Enviro-neering, Inc. The ventri-rod unit contains two absorber sections in series, each consisting of an adjustable set of cylindrical rods that are sprayed underneath with magnesium sulfite slurry. A louvered, continuous-waterwash demister is installed at the scrubber exit. Slurry flows through the unit and into an agitated absorber surge tank. Slurry make-up is also added to this tank from an MgO slaking tank. The slurry is recirculated to the scrubber from the surge tank. A portion of the recirculating slurry is bled from the scrubber circulation pump discharge to the thickener. Thickener underflow is pumped to a centrifuge. Solid MgSO₃ from the centrifuge is then dried in a direct-fired, cocurrent rotary dryer.

Thickener tank overflow and mother liquor from the centrifuge flow into a mother liquor tank. The liquid is then pumped back to the MgO slaking tank and a mist eliminator spray tank. A portion of the liquid stream can be bled into the wastewater treatment system, so that the possible buildup of iron or other impurities can be purged. Make-up water is added to the first stage demister system from the mother liquor tank.

3.2 DESIGN PARAMETERS

Each of the three particulate scrubbers is designed to cool 309,000 acfm of exhaust gas from 294°F to 127°F and to remove about 150 pounds of ash per hour from the exhaust gas stream. The design water recirculation rate through each particulate scrubber is 1300 gpm. The liquid-to-gas ratio (L/G) through each scrubber is therefore calculated to be about 5.4 gallons of water per 1000 actual cubic feet of air at 127°F. Approximately 32 gpm are bled from the recirculation pump discharge to the wastewater treatment system. The particulate scrubber recirculation stream carries about one percent solids by weight. River water make-up to each scrubber, about 117 gallons per minute, is supplied to the scrubber surge tank.

The SO₂ absorber is designed to receive 268,000 acfm of essentially particulate-free exhaust gas at 127°F. Design pressure drop through the absorber is 12 inches of H₂O. Evaporative heat transfer through the scrubber is negligible. Slurry is circulated from the SO₂ scrubber surge tank at 13,400 gpm. L/G is 50 gallons per 1000 actual cubic feet of gas at 127°F for this stage. The design SO₂ removal efficiency for the absorber is 90 percent. It is reported that magnesium sulfite is precipitated in the absorber surge tank per the following equations:



Slurry pH is controlled at 6 by regulating the rate of addition of slaked $\text{Mg}(\text{OH})_2$ slurry. The scrubber surge tank with a capacity of 60,000 gallons, provides a slurry residence time of about four minutes in order to minimize plugging problems in the recirculating pipes and scrubber.

The thickener receives 197 gpm of slurry recirculation bleed. With an approximate capacity of 120,000 gallons, residence time is close to ten hours. Underflow from the thickener contains about 25 percent solids ($\text{MgSO}_3 \cdot 6 \text{H}_2\text{O}$ and $\text{MgSO}_3 \cdot 3 \text{H}_2\text{O}$).

Wet solids from the stainless steel, solid bowl centrifuge are conveyed directly into a rotary-kiln, oil-fired, direct-heat, concurrent-flow dryer. MgSO_3 crystals are conveyed from the dryer to storage silos.

The MgSO_3 will be trucked to a sulfuric acid plant about twenty miles away. There it will be decomposed in an oil-fired, fluidized-bed reactor to form MgO and SO_2 . The SO_2 will be converted to sulfuric acid, and the regenerated MgO will be trucked back to the Eddystone Station.

3.3 INSTALLATION SCHEDULE

On-site construction for this plant began in April 1972. Construction was essentially completed in late 1974, and the particulate scrubber was started up in December of that year. As of June 1, 1975 the SO_2 absorber had not been put on line, mainly because of corrosion problems encountered in the particulate system. These problems are now being

ameliorated by neutralization, increased blowdown of scrubber fluid and start-up procedure revisions. Defective polyurethane-coated tanks will be repaired before operation of the SO₂ system will be attempted.

3.4 COST DATA

The particulate and FGD system, consisting of three first-stage particulate scrubbers and one second-stage SO₂ absorber, was installed at a total cost of \$20,273,000 or \$193/KW (net). About two-thirds of this amount is for the particulate scrubbers and the SO₂ absorption and recovery equipment with the remaining one-third for site improvements, land, access roads, engineering and contractor's fees and interest on capital during construction. The figure does not include magnesium oxide regenerating facilities. A considerably lower figure would be realized if the costs for two-thirds of the 308 MW particulate scrubbing system were separated out. Since the FGD system has not yet been operated, actual operating costs cannot be reported at the present time.

APPENDIX A
PLANT SURVEY FORM

PLANT SURVEY FORM^a
 REGENERABLE FGD PROCESSES

A. COMPANY AND PLANT INFORMATION

1. COMPANY NAME	<u>Philadelphia Electric Company</u>
2. MAIN OFFICE	<u>2301 Market Street, Phila., Pa. 19101</u>
3. PLANT SUPERINTENDENT	<u>Henry J. Wylie, Jr.</u>
4. PLANT NAME	<u>Eddystone Station</u>
5. PLANT LOCATION	<u>#1 Industrial Highway, Chester, Pa. 19013</u>
6. PERSON TO CONTACT FOR FURTHER INFORMATION	<u>George Kotnick</u>
7. POSITION	<u>Supervising Engineer</u>
8. TELEPHONE NUMBER	<u>215/841-4540</u>
9. DATE INFORMATION GATHERED	<u>February 11, 1975</u>
	Supplemented - <u>February 28, 1975, March 18, 1975</u>
10. PARTICIPANTS IN MEETING	AFFILIATION
<u>Wade H. Ponder</u>	<u>EPA - Research Triangle Park</u>
<u>John Busik</u>	<u>EPA - Washington, D. C.</u>
<u>Gerald A. Isaacs</u>	<u>PEDCo</u>
<u>Larry Yerino</u>	<u>PEDCo</u>
<u>Bertrand M. Anz</u>	<u>United Engineers & Const., Inc.</u>
<u>Henry F. Scheck</u>	<u>Philadelphia Electric Co.</u>
<u>Matthew M. Troyan</u>	<u>Philadelphia Electric Co.</u>
<u>James A. Gille</u>	<u>Philadelphia Electric Co.</u>

^a These data were obtained on February 11, 1975. Some of the data have been updated in the text of the report.

B. PLANT DATA. (APPLIES TO ALL BOILERS AT THE PLANT) .

	BOILER NO.			
	1	2	3	4
CAPACITY, MW (net)	316	334	360	360
SERVICE (BASE, PEAK, ETC.)	base	base	peak	under construction
FGD SYSTEM USED	MgO	none	none	none

C. BOILER DATA. COMPLETE SECTIONS (C) THROUGH (R) FOR EACH BOILER HAVING AN FGD SYSTEM.

1. BOILER IDENTIFICATION NO. 1
2. MAXIMUM CONTINUOUS HEAT INPUT 2912 MM BTU/HR
3. MAXIMUM CONTINUOUS GENERATING CAPACITY 316 MW (net)
4. MAXIMUM CONTINUOUS FLUE GAS RATE, 927,000 ACFM @ 294 °F
5. BOILER MANUFACTURER Combustion Engineering-Sulzer
6. YEAR BOILER PLACED IN SERVICE 1959
7. BOILER SERVICE (BASE LOAD, PEAK, ETC.) base load
8. STACK HEIGHT 249 ft.
9. BOILER OPERATION HOURS/YEAR (197) 6549 hours
10. BOILER CAPACITY FACTOR * 67.65%
11. RATIO OF FLY ASH/BOTTOM ASH 80/20

* DEFINED AS: $\frac{\text{KWH GENERATED IN YEAR } \underline{1,872,648 \text{ (net)}}}{\text{MAX. CONT. GENERATED CAPACITY IN KW} \times 8760 \text{ HR/YR}}$
316 MW (net)

D. FUEL DATA

1. COAL ANALYSIS (as received)

GHV (BTU/LB.)

S %

ASH %

MAX.	MIN.	AVG.
12,490	11,444	12,131
3.49	1.14	2.34
21.54	7.79	11.83

2. FUEL OIL ANALYSIS (exclude start-up fuel) (not applicable)

GRADE

S %

ASH %

E. ATMOSPHERIC EMISSIONS

1. APPLICABLE EMISSION REGULATIONS

- a) CURRENT REQUIREMENTS
Metro Phila. III 6/8/73 FR
AQCR PRIORITY CLASSIFICATION

REGULATION & SECTION NO. Pa.DER

MAX. ALLOWABLE EMISSIONS
LBS/MM BTU

PARTICULATES	SO ₂
--	--
III	III
Title 25 Part 1 Chapt. 123.11	Article III Chapt. 123.22B
0.1	0.6

- b) FUTURE REQUIREMENTS,
COMPLIANCE DATE

REGULATION & SECTION NO.

MAXIMUM ALLOWABLE EMISSIONS
LBS/MM BTU

2. PLANT PROGRAM FOR PARTICULATES COMPLIANCE

Program is presented in consent orders signed with EPA and DER

on September 25, 1974.

3. PLANT PROGRAM FOR SO₂ COMPLIANCE

Program is prepared in consent orders signed with EPA and DER

on September 25, 1974.

F. PARTICULATE REMOVAL

1. TYPE	MECH.	E.S.P.	FGD
MANUFACTURER	American Standard	Western Precipitation	1 - Peabody 1 - Environeering
EFFICIENCY: DESIGN/ACTUAL	72/70	95/92	90/not avail.
MAX. EMISSION RATE* LB/HR	7500	600	60
GR/SCF			
LB/MMBTU			
DESIGN BASIS, SULFUR CONTENT	2.3% by wt.		

G. DESULFURIZATION SYSTEM DATA

1. PROCESS NAME Magnesium Base Wet Scrubbing
2. LICENSOR/DESIGNER NAME: United Engineers & Constructors, Inc.
ADDRESS: 1401 Arch Street
PERSON TO CONTACT: J. T. Pinkston
TELEPHONE NO.: 215/422-4812
3. ARCHITECTURAL/ENGINEERS, NAME: United Engineers & Constructors, Inc.
ADDRESS: 1401 Arch Street, Phila. 19105
PERSON TO CONTACT: J. T. Pinkston
TELEPHONE NO.: 215/422-4812
4. PROJECT CONSTRUCTION SCHEDULE: DATE
 - a) DATE OF PREPARATION OF BIDS SPECS. Not Applicable
 - b) DATE OF REQUEST FOR BIDS Not Applicable
 - c) DATE OF CONTRACT AWARD Not Applicable
 - d) DATE ON SITE CONSTRUCTION BEGAN 4/72
 - e) DATE ON SITE CONSTRUCTION COMPLETED 11/74
 - f) DATE OF INITIAL STARTUP 12/74
 - g) DATE OF COMPLETION OF SHAKEDOWN Not Available

*At Max. Continuous Capacity

5. LIST MAJOR DELAYS IN CONSTRUCTION SCHEDULE AND CAUSES:


6. NUMBER OF SO₂ SCRUBBER TRAINS USED Three

7. DESIGN THROUGHPUT PER TRAIN, ACFM @ 127 °F 300,000

8. DRAWINGS: 1) PROCESS FLOW DIAGRAM AND MATERIAL BALANCE
2) EQUIPMENT LAYOUT

H. SO₂ SCRUBBING AGENT

1. TYPE	<u>Magnesium Oxide</u>
2. SOURCES OF SUPPLY	<u>Basic Chemical, Martin Marietta Chemicals</u>
3. CHEMICAL COMPOSITION (for each source)	<u>97.5% MgO</u>
4. EXCESS SCRUBBING AGENT USED ABOVE STOICHIOMETRIC REQUIREMENTS	<u>None</u>
5. MAKE-UP WATER POINT OF ADDITION	<u>Mother Liquor Tank</u>
6. MAKE-UP ALKALI POINT OF ADDITION	<u>Scrubber Surge Tanks</u>



A-7

	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)
RATE lb/min	16,600	2,922	265						133,890		133,840		131,916	1974
ACFM	309,000			268,000	268,000		276,000							
GPM		351	32						13,384		13,384		13,187	197
PARTICULATES lb/hr														
SO ₂ lb/min	165		2.66											
H ₂ S lb/hr														
SULFUR lb/min														
SULFATES lb/min									N.A.		N.A.			N.A.
TEMPERATURE °F	294	80	127	127	127		127		127		127			127

	(15)	(16)	(17)	(18)	(19)	(20)	(21)	(22)	(23)	(24)	(25)	(26)	(27)	(28)
RATE lb/hr		1788							31.3	85				
SCFM														
GPM		214												
PARTICULATES lb/hr														
SO ₂ lb/hr														
H ₂ S lb/hr														
SULFUR lb/hr														
SULFATES lb/hr														
TEMPERATURE °F		127							100	400				

1. Representative flow rates based on operating data at maximum continuous load

J. SCRUBBER TRAIN SPECIFICATIONS

1. SCRUBBER NO. 1 (a)

TYPE (TOWER/VENTURI)	<u>Ventri-Rod</u>
LIQUID/GAS RATIO, G/MCF @ °F	<u>4-5</u>
GAS VELOCITY THROUGH SCRUBBER, FT/SEC	<u>Not Applicable</u>
MATERIAL OF CONSTRUCTION	<u>316L S/S</u>
TYPE OF LINING	<u></u>
INTERNALS:	
TYPE (FLOATING BED, MARBLE BED, ETC.)	<u>Adjustable ventri-rod</u>
NUMBER OF STAGES	<u>One</u>
TYPE AND SIZE OF PACKING MATERIAL	<u>Not Applicable</u>
PACKING THICKNESS PER STAGE ^(b)	<u></u>
MATERIAL OF CONSTRUCTION, PACKING:	<u>Not Applicable</u>
SUPPORTS:	<u>Not Applicable</u>

2. SCRUBBER NO. 2 (a)

TYPE (TOWER/VENTURI)	<u>Ventri-Rod</u>
LIQUID/GAS RATIO, G/MCF @ °F	<u>40-50</u>
GAS VELOCITY THROUGH SCRUBBER, FT/SEC	<u>Not Applicable</u>
MATERIAL OF CONSTRUCTION	<u>Lined Carbon Steel</u>
TYPE OF LINING	<u>Polyurethane</u>
INTERNALS:	
TYPE (FLOATING BED, MARBLE BED, ETC.)	<u>Adjustable Ventri-rod</u>
NUMBER OF STAGES	<u>Two</u>
TYPE AND SIZE OF PACKING MATERIAL	<u>Not Applicable</u>

- a) Scrubber No. 1 is the scrubber that the flue gases first enter. Scrubber 2 (if applicable) follows Scrubber No. 1.
- b) For floating bed, packing thickness at rest.

PACKING THICKNESS PER STAGE^(b) Not Applicable

MATERIAL OF CONSTRUCTION, PACKING: Not Applicable

SUPPORTS: Not Applicable

3. CLEAR WATER TRAY (AT TOP OF SCRUBBER)

TYPE Not Applicable

L/G RATIO Not Applicable

SOURCE OF WATER Not Applicable

4. DEMISTER

TYPE (CHEVRON, ETC.) Chevron

NUMBER OF PASSES (STAGES) Two

SPACE BETWEEN VANES Proprietary Vendor Information

ANGLE OF VANES Proprietary Vendor Information

TOTAL DEPTH OF DEMISTER Proprietary Vendor Information

DIAMETER OF DEMISTER Proprietary Vendor Information

DISTANCE BETWEEN TOP OF PACKING AND BOTTOM OF DEMISTER Proprietary Vendor Information

POSITION (HORIZONTAL, VERTICAL) Vertical

MATERIAL OF CONSTRUCTION FRP

METHOD OF CLEANING Clean liquor and water sprays

SOURCE OF WATER AND PRESSURE River, 50 PSIG

FLOW RATE DURING CLEANINGS, GPM 1st stage - 600 GPM Liquor

2nd stage - 400 GPM Water

FREQUENCY AND DURATION OF CLEANING 1st stage - Continuous

2nd stage - As Required

REMARKS _____

5. REHEATER

TYPE (DIRECT, INDIRECT) Direct

b) For floating bed, packing thickness at rest.

DUTY, MMBTU/HR	<u>40 MM BTU/hr. Max.</u>
HEAT TRANSFER SURFACE AREA SQ.FT	<u>Not Applicable</u>
TEMPERATURE OF GAS: IN <u>127°F</u>	OUT <u>230°F Max.</u>
HEATING MEDIUM SOURCE	<u>Fuel oil</u>
TEMPERATURE & PRESSURE	<u>200°F & 75 PSIG</u>
FLOW RATE	<u>1800</u> LB/HR
REHEATER TUBES, TYPE AND MATERIAL OF CONSTRUCTION	<u>Not Applicable</u>
REHEATER LOCATION WITH RESPECT TO DEMISTER	<u>75' downstream of SO₂ Scrubber Demister</u> <u>40' downstream of Particulate Scrubber Demister</u>
METHOD OF CLEANING	<u>Not Applicable</u>
FREQUENCY AND DURATION OF CLEANING	<u>Not Applicable</u>
FLOW RATE OF CLEANING MEDIUM	<u>Not Applicable</u> LB/HR
REMARKS	<u></u>

6. SCRUBBER TRAIN PRESSURE DROP DATA	<u>INCHES OF WATER</u>
PARTICULATE SCRUBBER	<u>12" - 17" W.C.</u>
SO ₂ SCRUBBER	<u>12" W.C.</u>
CLEAR WATER TRAY	<u>Not Applicable</u>
DEMISTER	<u>1" W.C.</u>
REHEATER	<u>None</u>
DUCTWORK	<u>4.2" W.C.</u>
TOTAL FGD SYSTEM	<u>29.2 - 34.2" W.C.</u>

7. FRESH WATER MAKE UP FLOW RATES AND POINTS OF ADDITION

TO: DEMISTER Water added separated from SO₂ System
 QUENCH CHAMBER Not Applicable
 ALKALI SLURRYING Not Applicable
 PUMP SEALS 25 - 30 GPM
 OTHER Water input based on liquor inventory control
 TOTAL Not Available

FRESH WATER ADDED PER MOLE OF SULFUR REMOVED Not Available

8. BYPASS SYSTEM

CAN FLUE GAS BE BYPASSED AROUND FGD SYSTEMS Yes
 GAS LEAKAGE THROUGH BYPASS VALVE, ACFM Essentially Zero

K. TANK DATA

ALKALI SLURRY MAKEUP TANK

PARTICULATE SCRUBBER EFFLUENT
HOLD TANK (a)

SO₂ SCRUBBER EFFLUENT HOLD
TANK (a)

pH	% Solids	Capacity (gal)	Hold up time
10	8-10	12,000	5 Hrs. Phase
1-3	1	4,000	2.5 Min.
6-7	8-10	60,000	4 Min.

L. SO₂ RECOVERY

NAME OF PROCESS MgSO₃ Roasting
 LICENSOR/DESIGNER Copeland Systems, Inc.
 SYSTEM'S CAPACITY 3.5 Solids T/HR
 RAW MATERIAL REQUIRED Not Applicable

M. DISPOSAL OF CONTAMINANTS

PURGE STREAM, gpm	<u>Not Available</u>
AMOUNT OF CONTAMINANTS IN STREAM	<u>Not Available</u>
DESCRIBE METHOD OF CONCENTRATION AND DISPOSAL OF CONTAMINANTS	<u>Not Available</u>

N. COST DATA

1. TOTAL INSTALLED CAPITAL COST	<u>\$20,273,000</u>
2. ANNUALIZED OPERATING COST	<u>Not Available</u>

3. COST BREAKDOWN

COST ELEMENTS	INCLUDED IN ABOVE COST ESTIMATE		ESTIMATED AMOUNT OR % OF TOTAL INSTALLED CAPITAL COST
	YES	NO	
A. CAPITAL COSTS			
SO ₂ ABSORPTION/DESORPTION SYSTEM	<input checked="" type="checkbox"/>	<input type="checkbox"/>	50%
SO ₂ RECOVERY SYSTEM INCLUDING H ₂ S GENERATOR	<input checked="" type="checkbox"/>	<input type="checkbox"/>	7%
GAS QUENCHING & CLEANING	<input checked="" type="checkbox"/>	<input type="checkbox"/>	10%
SITE IMPROVEMENTS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2%
LAND, ROADS, TRACKS, SUBSTATION	<input checked="" type="checkbox"/>	<input type="checkbox"/>	12%
ENGINEERING COSTS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1%
CONTRACTORS FEE	<input checked="" type="checkbox"/>	<input type="checkbox"/>	8%
INTEREST ON CAPITAL DURING CONSTRUCTION	<input checked="" type="checkbox"/>	<input type="checkbox"/>	10%
B. ANNUALIZED OPERATING COST			
FIXED COSTS			
INTEREST ON CAPITAL	<input type="checkbox"/>	<input type="checkbox"/>	Not for Publication
DEPRECIATION	<input type="checkbox"/>	<input type="checkbox"/>	Not for Publication
INSURANCE & TAXES	<input type="checkbox"/>	<input type="checkbox"/>	Not for Publication
LABOR COST INCLUDING OVERHEAD	<input type="checkbox"/>	<input type="checkbox"/>	Not for Publication
VARIABLE COSTS			
RAW MATERIAL	<input type="checkbox"/>	<input type="checkbox"/>	Not Available
UTILITIES	<input type="checkbox"/>	<input type="checkbox"/>	Not Available
MAINTENANCE	<input type="checkbox"/>	<input type="checkbox"/>	Not Available

4. COST FACTORS

a. ELECTRICITY	<u>Not for Publication</u>	
b. WATER	<u>Not Available</u>	
c. STEAM (OR FUEL FOR REHEATING)	<u>Not Available</u>	
d. SULFUR/SULFURIC ACID SELLING COST	<u>Not for Publication</u>	<u>\$/TON</u>
e. RAW MATERIAL PURCHASING COST	<u>Not for Publication</u>	<u>\$/TON OF DRY SLUDGE</u>
f. LABOR: SUPERVISOR	<u>Not for Publication</u>	<u>HOUS/WEK <u>Not for Publi-</u></u>
	<u>Not for Publication</u>	<u>cation WAGE</u>
OPERATOR	<u>Not for Publication</u>	<u>_____</u>
OPERATOR HELPER	<u>Not for Publication</u>	<u>_____</u>
MAINTENANCE	<u>Not for Publication</u>	<u>_____</u>

O. MAJOR PROBLEM AREAS: (CORROSION, PLUGGING, ETC.)

1. SO₂ SCRUBBER, CIRCULATION TANK AND PUMPS.

a. PROBLEM/SOLUTION Not available at this time.

2. DEMISTER

PROBLEM/SOLUTION Not available at this time.

3. REHEATER

PROBLEM/SOLUTION Not available at this time.

4. VENTURI SCRUBBER, CIRCULATION TANKS AND PUMPS

PROBLEM/SOLUTION Not applicable

5. I.D. BOOSTER FAN AND DUCT WORK

PROBLEM/SOLUTION Not available at this time.

6. SO₂ RECOVERY AND CONVERSION

PROBLEM/SOLUTION Not available at this time.

7. GAS QUENCHING AND CLEANING

PROBLEM/SOLUTION Not available at this time.

5/17/74

8. MISCELLANEOUS AREA INCLUDING BYPASS AND
PURGE STREAM SYSTEM

PROBLEM/SOLUTION Not available at this time.

P. DESCRIBE FACTORS WHICH MAY NOT MAKE THIS A REPRESENTATIVE
INSTALLATION

1. Cost figures misleading, since full scale particulate removal
installed but only 1/3 SO₂ scrubbing.

Q. DESCRIBE METHODS OF SCRUBBER CONTROL UNDER FLUCTUATING
LOAD. IDENTIFY PROBLEMS WITH THIS METHOD AND SOLUTIONS.
IDENTIFY METHOD OF pH CONTROL AND LOCATION OF pH PROBES.

1. Scrubber Control Under Fluctuating Load

- a. Scrubber liquor flow rate is held constant.
- b. Adjustable rod deck is automatically controlled to maintain
a constant pressure drop at varying gas flow rate.

2. pH Control

The pH of the SO₂ scrubber surge tank is maintained by the
automatic addition of magnesium hydroxide slurry from the
slaking tank. Either of two pH probe locations may be
selected for control. One in the surge tank and one in slurry
recirculating line to the scrubber.

5/17/74

A-17

BOILER RATING OR MAXIMUM CONTINUOUS CAPACITY, MW _____

[illegible]

Availability factor computation:

1. Divide boiler capacity by the number of modules and obtain MW/module = χ
2. Multiply boiler capacity by number of hours during period = a
3. Add all down times due to module trouble for all modules during period = b
4. Add all down times due to boiler trouble or reduction in electricity demand for all modules during period = c
5. Availability factor =
$$\frac{[a - \chi (b + c)]100}{a - \chi c} = \%$$

5/17/74

APPENDIX B
PLANT PHOTOGRAPHS




Photo No. 1 Construction photo showing installation of MgO silo at Eddystone. Boiler house appears in background.

(Courtesy Philadelphia Electric Co.)




Photo No. 2 General view of Eddystone scrubber area. Supply ducts to three particulate scrubbers are visible, but scrubbers are obscured by structural steel. FGD module is in foreground at left. Boiler 1 stack and boiler house are behind scrubbers.

(Courtesy Philadelphia Electric Co.)




Photo No. 3 View of thickener tank, centrifuge foundations and MgSO_3 dryer. Overhead pipe rack carries coal to bunkers from coal handling building in background. Note empty coal cars behind thickener.

(Courtesy Philadelphia Electric Co.)




Photo No. 4 Construction photo showing installation of ductwork to Peabody scrubber from supply duct in foreground. Coal conveyor, FGD module, and coal pile are visible in background.

(Courtesy Philadelphia Electric Co.)

TECHNICAL REPORT DATA <i>(Please read Instructions on the reverse before completing)</i>			
1. REPORT NO. EPA-650/2-75-057-f		2. 	
4. TITLE AND SUBTITLE Survey of Flue Gas Desulfurization Systems Eddystone Station, Philadelphia Electric Company		3. RECIPIENT'S ACCESSION NO. 	
		5. REPORT DATE September 1975	
		6. PERFORMING ORGANIZATION CODE 	
7. AUTHOR(S) Gerald A. Isaacs		8. PERFORMING ORGANIZATION REPORT NO. 	
9. PERFORMING ORGANIZATION NAME AND ADDRESS PEDCo-Environmental Specialists, Inc. Suite 13, Atkinson Square Cincinnati, Ohio 45246		10. PROGRAM ELEMENT NO. LAB013; 2IACX-130	
		11. CONTRACT/GRANT NO. 68-02-1321, Task 6f	
12. SPONSORING AGENCY NAME AND ADDRESS EPA, Office of Research and Development Industrial Environmental Research Laboratory Research Triangle Park, NC 27711		13. TYPE OF REPORT AND PERIOD COVERED Subtask Final: 2/75-9/75	
		14. SPONSORING AGENCY CODE 	
15. SUPPLEMENTARY NOTES 			
16. ABSTRACT The report gives results of a survey of the magnesium-oxide-based flue gas desulfurization system on boiler 1 at Philadelphia Electric Co.'s Eddystone Station. The system, designed and installed by United Engineers and Constructors, Inc., consists of three first stage scrubber modules in parallel for particulate control (two are Enviroengineering venturi-rod units; the third is a Peabody-Lurgi venturi unit) and a second stage Enviroengineering absorber module with two venturi-rod beds for SO2 removal. The three first stage scrubbers, combined, are sized to handle all the exhaust gas from unit 1 which has a net electric generating capacity of 314 MW. The second stage absorber is sized to handle one-third of the gas flow, equivalent to about 105 MW (net). As of April 1, 1975, the second stage module had not yet been operated; therefore, this report necessarily emphasizes design, rather than operating, parameters and experience. The system is designed to remove 90 percent of the SO2 from boiler stack gas.			
17. KEY WORDS AND DOCUMENT ANALYSIS			
a. DESCRIPTORS		b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group
Air Pollution Coal Flue Gases Combustion Desulfurization Sulfur Dioxide Magnesium Oxides Scrubbers		Air Pollution Control Stationary Sources Particulates Venturi-Rod Units Venturi Units	13B 21D 21B 07A, 07D 07B
18. DISTRIBUTION STATEMENT Unlimited		19. SECURITY CLASS (This Report) Unclassified	21. NO. OF PAGES 42
		20. SECURITY CLASS (This page) Unclassified	22. PRICE