

EPA-450/3-76-018-a

April 1977

**DETERMINING
INPUT VARIABLES
FOR CALCULATION
OF IMPACT OF NEW
SOURCE PERFORMANCE
STANDARDS: WORKSHEETS
FOR STATIONARY
COMBUSTION SOURCES**

U.S. ENVIRONMENTAL PROTECTION AGENCY

Office of Air and Waste Management

Office of Air Quality Planning and Standards

Research Triangle Park, North Carolina 27711

**DETERMINING INPUT VARIABLES
FOR CALCULATION OF IMPACT OF NEW
SOURCE PERFORMANCE STANDARDS:
WORKSHEETS FOR STATIONARY
COMBUSTION SOURCES**

by

**The Research Corporation of New England
129 Silas Deane Highway
Weathersfield, Connecticut 06109**

Contract No. 68-02-1382

EPA Project Officer: Gary D. McCutchen

Prepared for

**U.S. ENVIRONMENTAL PROTECTION AGENCY
Office of Air and Waste Management
Office of Air Quality Planning and Standards
Research Triangle Park, North Carolina 27711**

April 1977

This report is issued by the Environmental Protection Agency to report technical data of interest to a limited number of readers. Copies are available free of charge to Federal employees, current contractors and grantees, and nonprofit organizations - in limited quantities - from the Library Services Office (MD-35), Research Triangle Park, North Carolina 27711; or, for a fee, from the National Technical Information Service, 5285 Port Royal Road, Springfield, Virginia 22161.

This report was furnished to the Environmental Protection Agency by The Research Corporation of New England, Weathersfield, Connecticut 06109, in fulfillment of Contract No.68-02-1382. The contents of this report are reproduced herein as received from The Research Corporation of New England. The opinions, findings, and conclusions expressed are those of the author and not necessarily those of the Environmental Protection Agency. Mention of company or product names is not to be considered as an endorsement by the Environmental Protection Agency.

Publication No. EPA-450/3-76-018-a

FOREWORD

During 1974, two studies were initiated that ultimately resulted in the establishment of priorities for developing and promulgating New Source Performance Standards (NSPS). The procedures used to determine these priorities produced a great deal of information that is believed to be useful in the industries involved and, accordingly, is being published in this series of reports (EPA-450/3-76-017, EPA-450/3-76-018, EPA-450/3-76-019, and EPA-450/3-76-020). This information is organized as follows:

EPA-450/3-76-017 discusses (1) the mathematical model (Model IV) used to determine NSPS impacts over a 10-year period; (2) the methods used to attain input variables; and (3) the summary tables which are the heart of this study. Included in the summary tables are data related to (1) emission, growth, and replacement rates; (2) present and future production and capacity; (3) nationwide emissions; and (4) NSPS impact. These tables include information on 13 pollutants and nearly 200 stationary source categories.

EPA-450/3-3-76-018-a, -b, -c, -d, -e, and -f are the calculation sheets, showing how the input variables reported in EPA-450/3-76-017 were derived. All information sources, assumptions, and calculations are documented and explained. The appropriate worksheets are arranged alphabetically in the following volumes:

018-a - Stationary Combustion Sources

018-b - Chemical Processing Industries

018-c - Food and Agricultural Industries

018-d - Mineral Products Industries

018-e - Metallurgical Industries

018-f - Miscellaneous Sources (Evaporation Losses, Petroleum

Industry, Wood Products Industry, and Assembly Plants

The 018-a -f series is of interest only to those concerned with the detailed calculations used to determine the Model IV input variables.

EPA-450/3-76-019-a provides additional results and information produced during the priority study. Its major purpose is to describe the computer program used to rank all the Model IV input and output variables by pollutant (these rankings are reported in 019-b and -c). In addition, it contains (1) summaries of the control systems considered "best" for each source, (2) equipment retirement ages, and (3) emission trends for each source category.

EPA-450/3-76-019-b and c present the computer-generated ranked data for each pollutant. Ranking is from highest to lowest for each of the 21 variables, e.g., A (nationwide capacity) and Eu (uncontrolled emission rate). Volume 019-b contains ranked data for particulate, nitrogen oxide (NO_x), and sulfur oxide (SO_x) sources. In Volume 019-c, the remaining pollutant sources are ranked: hydrocarbons, carbon monoxide (CO), fluorides, hazardous material, acid mist, lead, ammonia, sulfides, chlorine, and trace metals.

EPA-450/3-76-020, the final document in this series, takes the objective impact values from EPA-450/3-76-017, adds subjective judgements, and uses these combined criteria to produce a priority list for NSPS development. The report then calculates nationwide emission trends over the next 15 years for each criteria pollutant (particulate, SO_x , NO_x , hydrocarbons, and CO) based on a series of scenarios (e.g., no NSPS, 20 NSPS per year, etc.)

In summary, documents EPA-450/3-76-017 and 020 present the results of this study. Each stands alone, but they also complement each other, with 020 building on the results of 017. The remaining documents (018-a -f and 019-a -c) present additional and/or more detailed information derived from the impact and priority studies.

DETERMINATION OF INPUT VARIABLES
FOR
STATIONARY COMBUSTION SOURCES

TRC -- The Research Corporation of New England
 125 Silias Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hopper Date 9/19/74

Source Fossil Fuel Boilers

Boiler Type	Typical Rated Capacity Range #STEAM/HR	Source Class 10^6 BTU	TOTAL CAPACITY 10^6 #STEAM/HR		
			1967	1975	1985
Residential		<0.3	2117	2877	3849
Cast Iron	650 - 8000 ⁽³⁾	0.3 - 10.0	757	985	1330
Fierluse	420 - 25000 ⁽³⁾	0.3 - 10.0	813	1365	2255
Warehouse-1	10,000 - 100,000 ⁽²⁾	10 - 250	921	1045	1201
Warehouse-2	100,001 - 250,000 ⁽²⁾	10 - 250	658	700	810
Warehouse-3	250,001 - 500,000 ⁽²⁾	>250	259	286	276
Warehouse-4	>500,000 ⁽²⁾	0	?	2564	4663

① Ref 73 p 16 TAB 1-5.

② Ref 73 p 16 TAB 1-5

③ Ref 22 p 1-1

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Haze Date 9/19/74

Source Fossil Fuel Boilers

Determination Of K

"K" will be defined as follows

$$K = \frac{\text{various fuels}}{\left(\frac{\text{BTU}}{\# \text{STEAM}} \right)} \times \frac{1}{[\text{Capacity}] \frac{\text{BTU}}{\text{HR}} \times [8760 \frac{\text{HR}}{\text{YR}}]}$$

for each boiler type

$$\left(\frac{\text{BTU}}{\# \text{STEAM}} \right) = \frac{975 \frac{\text{BTU}}{\#}}{\eta_{\text{BOILER}}}$$

- ① The value of BTU/#steam will differ for each fuel type within a given boiler category.
- ② Ref 73 pA-4, A-5 for 975 value

RESIDENTIAL

Ref 73 p 5 TAB 1-1 gives 1967 Capacity & Fuel Usage data. Capacity is presented on p. 6 of this analysis.

355×10^6 BTU DISTILLATE OIL
 3.15×10^{12} FT³ GAS

$\eta_{\text{RESIDENTIAL}} = 100\%$ BECAUSE CAPACITY DATA IS BASED ON INPUT, NOT OUTPUT REF 73 PA-15

Heating VALUES - Ref 22 p4-2 TAB 4-1

DISTILLATE OIL - 5.817×10^6 BTU/BBL

GAS - 1040 BTU/FT³

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hause Date 9/17/74

Source Fossil Fuel Boilers

$$K_{RES} = \frac{(355 \times 10^6)(5.817 \times 10^6) + (3.15 \times 10^{12})(1040)}{(2117 \times 10^6)(975)(8760)} = \frac{(20.65 + 32.76) \times 10^{14}}{(2117 \times 10^6)(975)(8760)}$$

$$K = 0.30$$

RESI-
-DENTAL

CAST IRON

REF(73) p 5 TAB 1-1 gives 1967 capacity & fuel usage data. Capacity is presented on p1 of this analysis.

11×10^6 TONS COAL

56×10^6 BBL'S RES. OIL

37×10^6 BBL'S DISTOIL

1.03×10^{12} FT³ GAS

EFFICIENCIES PER REF(73) p A-16	
COAL	70%
RO	80%
DO	80%
GAS	77%

Heating Values - REF(22) p 4-2 TAB 4-1

DISTOIL & GAS have already been stated

RES. OIL - 6.384×10^6 BTU/BBL

COAL - 26.2×10^6 BTU/TON

$$K_{IRON} = \frac{\frac{(11 \times 10^6)(26.2 \times 10^6)}{0.7} + \frac{(56 \times 10^6)(6.384 \times 10^6)}{0.8} + \frac{(37 \times 10^6)(5.817 \times 10^6)}{0.80} + \frac{(1.03 \times 10^{12})(1040)}{0.77}}{(757 \times 10^6)(8760)}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hoyer Date 9/19/74

Source Fossil Fuel Boilers

$$K = \frac{2.069 \times 10^6 + 2.933 \times 10^6 + 1.766 \times 10^6 + 8.460 \times 10^6}{(757 \times 10^6)(8760)} = 0.23$$

$$K_{\text{CAST IRON}} = 0.23$$

Firetube

From Ref 73 p5 TAB 1-1

11×10^6 TONS COAL

98×10^6 BBL'S RO

69×10^6 BBL'S DO

1.12×10^2 FT³ GAS

Efficiencies per Ref 73
 PA-Ko, TAB A-3

COAL - 70%

RO - 77%

DO - 77%

GAS - 75%

$$\frac{(11 \times 10^6)(26.2 \times 10^6)}{(975)} + \frac{(98 \times 10^6)(6.384 \times 10^6)}{0.77} + \frac{(69 \times 10^6)(5.817 \times 10^6)}{0.77} + \frac{(1.12 \times 10^2)(1040)}{0.75}$$

$$K = \frac{(813 \times 10^6)(8760)}{(813 \times 10^6)(8760)}$$

$$= \frac{2.069 \times 10^6 + 4.941 \times 10^6 + 3.170 \times 10^6 + 8.96 \times 10^6}{(813 \times 10^6)(8760)} = 0.27$$

$$K_{\text{FIRE TUBE}} = 0.27$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hagge Date 7/20/74
 Source Boilers

UNITS - TYPES 1, 2, 3

From Ref (73) p 5 TAB A-1

132×10^6 TONS COAL
 194×10^6 GALLS RO
 14×10^6 GALLS DO
 1.72×10^{12} FT³ GAS

Efficiencies per Ref (73) TAB A-16 TAB A-3

	(1)	(2)	(3)
COAL -	77%	83%	89%
RO -	75%	80%	87%
DO -	75%	80%	87%
GAS -	70%	76%	81%

IF ALL UNITS WERE TYPE 1, THEN

$$K_{WT} = \frac{\frac{(132 \times 10^6)(26.2 \times 10^6)}{(975)} + \frac{(194 \times 10^6)(6.384 \times 10^6)}{(975)} + \frac{(14 \times 10^6)(5.817 \times 10^6)}{(975)} + \frac{(1.72 \times 10^{12})(1040)}{(975)}}{(1838 \times 10^6)(8760)}$$

$$K_{WT} = \frac{2.731 \times 10^{12} + .9527 \times 10^{12} + 6.264 \times 10^{10} + 1.28 \times 10^{12}}{(1838) \times 10^6 (8760)} = 0.31$$

$$K_{WT_1} = 0.31$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hoppe Date 9/20/74

Source Boilers

IF ALL UNITS WERE TYPE 2, THEN

$$K_{WT}^2 = \frac{\frac{(132 \times 10^4)(26.2 \times 10^4)}{(975)} + \frac{(194 \times 10^4)(6.384 \times 10^4)}{(975)} + \frac{(14 \times 10^4)(5.817 \times 10^4)}{(975)} + \frac{(1.72 \times 10^2)(1040)}{(975)}}{(1838 \times 10^4)(8760)}$$

$$= \frac{2.944 \times 10^{12} + 1.016 \times 10^{12} + 6.682 \times 10^{10} + 1.394 \times 10^{12}}{(1838 \times 10^4)(8760)} = 0.34$$

$$K_{WT}^2 = 0.34$$

IF ALL UNITS WERE TYPE 3, THEN

$$\frac{(132 \times 10^4)(26.2 \times 10^4)}{(975)(.89)} + \frac{(194 \times 10^4)(6.384 \times 10^4)}{(975)(.87)} + \frac{(14 \times 10^4)(5.817 \times 10^4)}{(975)(.87)} + \frac{(1.72 \times 10^2)(1040)}{(975)(.81)}$$

$$K_{WT}^3 = \frac{(1838 \times 10^4)(8760)}{}$$

$$= \frac{3.157 \times 10^{12} + 1.105 \times 10^{12} + 7.267 \times 10^{10} + 1.486 \times 10^{12}}{(1838 \times 10^4)(8760)} = 0.36$$

$$K_{WT}^3 = .36$$

TRC --- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hegge Date 9/20/74
 Source Boilers

To determine K for type 4 units, use data from ref (73) p 5
 TAB 1-1 FOR UTILITY BOILERS, WHICH, AS A GENERAL RULE, ARE IN THIS
 SIZE CATEGORY

COAL - 271×10^6 TONS

RO - 156×10^6 GALS

DO - 2×10^6 GALS

GAS - 2.76×10^{12} FT³

CAP 1967 = 1800×10^6 LBH
 STEAM

EFFECTIVENESS FOR REF (73) PA-16 TAB A-3

COAL - 90%

RO - 88%

DO - 88%

GAS - 81%

$$\frac{(271 \times 10^6)(26.2 \times 10^6)}{(975) .90} + \frac{(156 \times 10^6)(6.384 \times 10^6)}{(975) .88} + \frac{(2 \times 10^6)(5.817 \times 10^6)}{(975) .88} + \frac{(2.76 \times 10^{12})(1040)}{(975) .81}$$

$$K_{WT} = \frac{(1800 \times 10^6)(8760)}{6.55 \times 10^{12} + (8.989 \times 10^{10}) + 1.050 \times 10^{10} + 2.385 \times 10^{12}} = 0.62$$

$$(1800 \times 10^6)(8760)$$

$$K_{WT} = 0.62$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Harrer Date 7/20/74

Source Fossil Fuel Boilers

$$K_{<0.3} = 0.30$$

$$K_{0.3-10.0} = \left(\frac{757}{757+813} \right) (0.23) + \left(\frac{813}{757+813} \right) (0.27)$$

$$= 0.1109 + 0.1398 = 0.251$$

$$K_{0.3-10.0} = 0.25$$

$$K_{10-250} = \frac{(921)}{(921+658)} (0.31) + \frac{(658)}{(658+921)} (0.34)$$

$$= 0.1808 + 0.1417 = 0.3225$$

$$K_{10-250} = 0.32$$

$$K_{>250} = \frac{(259)}{(259+1248)} (0.36) + \frac{(1248)}{(259+1248)} (0.62)$$

$$= 0.0619 + 0.5134 = 0.575$$

$$K_{>250} = 0.58$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hopper Date 9/23/74

Source Fossil Fuel Boilers

We have 1975 capacity (P_1 OF THESE CAKES) IN $\frac{\text{BTU}}{\text{HR}}$
 STREAM. SINCE EMISSION FACTORS WILL BE ON A PER BTU BASIS,
 IT IS NECESSARY TO CONVERT.

$$1975 \text{ CAP. } (10^{12} \text{ BTU}) = 1975 \text{ CAP } \left(\frac{\text{#}}{\text{HR STREAM}} \right) \left(8760 \frac{\text{HR}}{\text{YR}} \right) \left(\frac{\text{BTU}}{\text{# STREAM}} \right)$$

$$\frac{\text{BTU}}{\text{# STREAM}} = \frac{975 \frac{\text{BTU}}{\text{#}}}{N_{BLOCKS}} \quad (\text{SEE P2 OF THESE CAKES})$$

FOR THE SAKE OF MINIMIZING EXTENSIVE CALCULATIONS TO WEIGHT
 EFFICIENCIES, WE WILL ASSUME A LINEAR AV'S

RESIDENTIAL

$$A = \frac{(2877 \times 10^6)(8760)(975)}{1.0} = 24,572 \times 10^{12} \frac{\text{BTU}}{\text{YR}}$$

$$A_{\text{RESIDENTIAL}} = 24,572 \times 10^{12} \frac{\text{BTU}}{\text{YR}}$$

CAST IRON

70
80
80
77
77

= AVG

$$A = \frac{(985)(8760)(975)(10^6)}{277} = 10,926 \times 10^{12}$$

$$A_{\text{CAST IRON}} = 10,926 \times 10^{12} \frac{\text{BTU}}{\text{YR}}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Homer

Date 9/23/74

Source Fossil Fuel Boilers

Factors

70	77
77	75
75	75
75	75
<hr/>	
75	= AVG

$$A = \frac{(1365 \times 10^6)(8760)(975)}{0.75} = 15,545 \times 10^{12} \text{ BTU}$$

$$A_{\text{Fossil Fuel}} = 15,545 \times 10^{12} \text{ BTU/yr}$$

Wateruse - Type #1

$$A = \frac{(1045 \times 10^6)(8760)(975)}{0.74} = 12,061 \times 10^{12} \text{ BTU} \quad \begin{array}{r} .77 \\ .75 \\ .75 \\ .70 \\ \hline .74 = \text{AVG} \end{array}$$

$$A_{\text{WT.1}} = 12,061 \times 10^{12} \text{ BTU/yr}$$

Wateruse - Type #2

$$A = \frac{(700 \times 10^6)(8760)(975)}{.80} = 3,473 \times 10^{12} \text{ BTU} \quad \begin{array}{r} .83 \\ .80 \\ .80 \\ .76 \\ \hline .80 = \text{AVG} \end{array}$$

$$A_{\text{WT.2}} = 3,473 \times 10^{12} \text{ BTU/yr}$$

Wateruse - Type #3

$$A = \frac{(286 \times 10^6)(8760)(975)}{.86} = 2840 \times 10^{12} \text{ BTU/yr} \quad \begin{array}{r} .89 \\ .87 \\ .87 \\ .81 \\ \hline .86 = \text{AVG} \end{array}$$

$$A_{\text{WT.3}} = 2840 \times 10^{12} \text{ BTU/yr}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Herr Date 9/23/74

Source Fossil Fuel Boilers

Warehouse - Type #4

$$A = \frac{(9564 \times 10^6)(8700)(775)}{0.87} = 25,171 \times 10^{12}$$

70	88
88	77
81	87

Avg

$$A_{w-4} = 25,171 \times 10^{12} \text{ BTU/YR}$$

$$A_{<0.3} = 24,572 \times 10^{12} \text{ BTU/YR}$$

$$A_{0.3-10.0} = (10,926 + 15,545) 10^{12} = 26,471 \times 10^{12}$$

$$A_{0.3-10.0} = 26,471 \times 10^{12} \text{ BTU/YR}$$

$$A_{10.0-250} = (12,061 + 7,473)(10^{12}) = 19,534 \times 10^{12} \text{ BTU/YR}$$

$$A_{10.0-250} = 19,534 \times 10^{12} \text{ BTU/YR}$$

$$A_{>250} = (2840 \times 10^{12} + 25,171 \times 10^{12}) = 28,011 \times 10^{12}$$

$$A_{>250} = 28,011 \times 10^{12} \text{ BTU/YR}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Homer Date 9/23/74

Source Fossil Fuel Boilers

P_B determination

Cast Iron Ref (22) p 2-1 Life = 50 years

$$\frac{100\%}{50 \text{ years}} = 2\% \text{ / year}$$

$$P_{B_{\text{cast}}} = 2\% \text{ simple}$$

Firetube

Ref (22) p-2-1 Life = 20 yrs

$$\frac{100\%}{20 \text{ years}} = 5\% \text{ / year}$$

$$P_{B_{\text{firetube}}} = 5\% \text{ simple}$$

Water tube

Ref (22) p 2-3

".... longevity may be comparable to firetube units

$$P_{B_{\text{wt}}} = 5\% \text{ simple}$$

} REF 73

Assume Residencetime equal to the av's of cast iron } P 50

$$P_{B_{<0.3}} = 2\% \text{ simple}$$

$$P_{B_{0.3-10.0}} = (2\%) \left(\frac{985}{985+1365} \right) + (5\%) \left(\frac{1365}{985+1365} \right) = 0.838 + 2.901 = 3.74\%$$

1975 CAPACITIES (SEE P1 OF THESE CIRCLES)

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Haze Date 9/23/74
 Source Fossil Fuel Boilers

$$P_{B_{0.3-10.0}} = 3.7\% \text{ simple}$$

$$P_{B_{10-250}} = P_{B_{WT}} = 5\%$$

$$P_{B_{10-250}} = 5\% \text{ simple}$$

$$P_{B_{>250}} = P_{B_{WF}} = 5\%$$

$$P_{B_{>250}} = 5\% \text{ simple}$$

Pc determination

Ref 73 p 16 tab 1-5 gives 1975-1985 Capacities
 Assume compo growth

$$P_{C_{RES.}} = \sqrt[10]{\frac{3844}{2877}} - 1.0 = 2.9\%$$

$$P_{C_{CE}} = \sqrt[10]{\frac{1330}{985}} - 1.0 = 3.05\%$$

$$P_{C_{FT}} = \sqrt[10]{\frac{2255}{1365}} - 1.0 = 5.15\%$$

$$P_{C_{WT-1}} = \sqrt[10]{\frac{1201}{1045}} - 1.0 = 1.40\%$$

$$P_{C_{WT-2}} = \sqrt[10]{\frac{810}{700}} - 1.0 = 1.47\%$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hagan Date 9/23/74

Source Boilers

$$P_{C_{WT-3}} = \sqrt[10]{\frac{276}{286}} - 1.0 = -0.36\%$$

$$P_{C_{WT-4}} = \sqrt[10]{\frac{4663}{2564}} - 1.0 = 6.16\%$$

$$P_{C_{<0.3}} = 2.9\% \text{ ampd}$$

$$P_{C_{0.3-10.0}} = \left(\frac{985}{985+1365} \right) (3.05) + \left(\frac{1365}{985+1365} \right) (5.15) = 1.278 - 2.991 \\ = 4.27$$

1975 CAPACITIES (see p. OF THIS calc)

$$P_{C_{0.3-10.0}} = 4.3\% \text{ ampd}$$

$$P_{C_{10-250}} = 1.4\%$$

$$P_{C_{10-250}} = 1.4\% \text{ ampd}$$

$$P_{C_{>250}} = (-.36) \left(\frac{286}{286+2564} \right) + 6.16 \left(\frac{2564}{286+2564} \right) = -.36 - 5.54\%$$

$$P_{C_{>250}} = 5.52\% \text{ ampd}$$

1975 CAPACITIES (see p. of this calc)

TRG -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hegner

Date 7/23/74

Source Boilers

Summary Of Industrial Factors

K	A(10^2)	Pc(%)	Pg
< 0.3	0.3	24,572	2.9 _c
0.3-10.0	0.25	26,471	4.3 _c
100-250	0.32	19,534	1.4 _c
> 250	0.58	28,011	5.5 _c

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 9/23/78

Source Fossil Fuel Boilers

RESIDENTIAL

Proj. Ref. 75 p 1.3-2 TAB 1.3-1

$$E_{UP} = \frac{10^4}{1000 \text{ gal}}$$

$$\frac{0.010 \times \frac{42 \text{ gal}}{\text{gal}}} {3.817 \times 10^6 \text{ BTU/gal}} = 0.0722 \frac{\#}{10^6 \text{ BTU}} (\text{oil})$$

Ref 75 p 1.4-2 TAB 1.4-1

$$E_{UP, \text{gas}} = \frac{19}{10^6 \text{ ft}^3}$$

$$\frac{(19 \times 10^{-6} \frac{\#}{\text{ft}^3})}{1090 \frac{\text{BTU}}{\text{ft}^3}} \times 10^6 = 0.0183 \frac{\#}{10^6 \text{ BTU}} (\text{gas})$$

$$\frac{(355 \times 10^6) (5.817 \times 10^6)}{(355 \times 10^6) (5.817 \times 10^6) + (3.15 \times 10^{12}) (1010)} = 38.7 \% \text{ dist. oil}$$

$$\therefore 7. \text{ gas} = 61.3 \%$$

$$(0.387)(0.0722) + (0.613)(0.0183) = .0279 + .0112 = .0391$$

$$E_{UP, \text{res}} = 0.0391 \frac{\#}{10^6 \text{ BTU}}$$

CONVERSION FACTORS,
FUEL USAGE RATES &
CAPACITIES HAVE ALL
BEEN PRESENTED IN
"INDUSTRIAL FACTORS"
CALC'N SHEETS

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 9/23/74
 Source Fossil Fuel Boilers

NO_x

Ref(75) P1.3-2 ~~gas~~ 1.3-1

$$EU_{NO_x} = \frac{12}{1000 \text{ gal}} \text{ do}$$

Ref(75) P1.4-2 ~~gas~~ 1.4-1

$$EU_{NO_x} = \frac{80}{10^6 \text{ ft}^3} \text{ do}$$

$$\frac{(0.012)(42)}{5.817} = 0.0866 \%_{10^6 \text{ BTU}} (\text{D.O.})$$

$$\frac{(80 \times 10^{-6})(10^6)}{1040} = 0.0769 \%_{10^6 \text{ BTU}} (\text{D.S.})$$

$$(0.0866)(.387) + (0.0769)(.613) = .0335 + .0471 = .0806$$

$$EU_{NO_x} = 0.0806 \%_{10^6 \text{ BTU}}$$

*

HC

Same refs, & pp as above

$$EU_{HC} = \frac{3+2}{1000 \text{ gal}} = 5 \text{ do}$$

$$EU_{HC} = \frac{8}{10^6 \text{ ft}^3} \text{ do}$$

$$\frac{(0.005)(42)}{5.817} = .0361 \%_{10^6 \text{ BTU}} (\text{D.O.}) \quad \frac{(8 \times 10^{-6})(10^6)}{1040} = .0077$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 9/23/74

Source _____

$$.0361(.387) + .0077(.613) = .0140 + .0047 = 0.0187$$

$$E_{U_{SO_3}} = 0.0187 \frac{\text{#}}{10^6 \text{BTU}}$$

*

SO_x

Ref 97 P19 TAB 49 % S in #2 FUEL = 0.265%
 (Arithmetic Av's of TAB 49)

Ref 75 → $E_{U_{SO_x}} = (142+2) 5 = (144)(.265) = 38.16 \frac{\text{#}}{1000 \text{BTU}}$
 $\rho_{1.3-2}$
 $TAB 1.3-1$

$$\frac{(0.3816)(12)}{3.817} = 0.2755 \frac{\text{#}}{10^6 \text{BTU}} (\text{DO})$$

Ref 75 $\rho_{1.4-2}$
 $TAB 1.4-1$

$$\frac{(0.6 \times 10^{-6})(10^4)}{1000} = 0.00058 \frac{\text{#}}{10^6 \text{BTU}} (\text{GAS})$$

$$(2755)(.387) + (.00058)(.613) = .1066 + .00036 = 0.1070$$

$$E_{U_{SO_x}} = 0.1070 \frac{\text{#}}{10^6 \text{BTU}}$$

*

CO

Same as above

$$E_{U_{CO}} = 5 \frac{\text{#}}{1000 \text{gas}}$$

$$E_{U_{CO}} = 30 \frac{\text{#}}{10^6 \text{FT}^3}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 9/23/74
 Source Boilers

$$\frac{(.005)(42)}{(5.817)} = 0.0361 \frac{\text{#}/10^6 \text{ BTU}}{(\text{DO})} \quad \frac{(30 \times 10^{-6})(10^6)}{1010} = 0.0192 \frac{\text{#}/10^6 \text{ BTU}}{(\text{GAS})}$$

$$(.0361)(.387) + (0.0192)(.613) = .0140 + .0118 = 0.0258$$

$$E_{URSS} = 0.0258 \frac{\text{#}/10^6 \text{ BTU}}{(\text{DO})}$$

*

FIRETUBE

PARTICULATES

% BREAKDOWN OF FUEL USAGE TYPES ARE NECESSARY TO
 SYNTHESIZE EMISSION FACTORS SINCE THESE FACTORS ARE DIFFERENT
 FOR DIFFERENT FUELS. DATA FOR THE FOLLOWING METHODS HAS BEEN
 PREVIOUSLY PRESENTED IN THE "INDUSTRIAL FACTORS" COMPUT SHEETS.

$$\begin{aligned} \text{TOTAL HEAT USED} &= (11 \times 10^6)(28.2 \times 10^6) + (18 \times 10^6)(8.384 \times 10^6) + (6 \times 10^6)(5.87 \times 10^6) \\ &\quad + (1.12 \times 10^{12})(1010) \\ &= (2.882 \times 10^{14} + 6.256 \times 10^{14} + 4.014 \times 10^{14} + 11.648 \times 10^{14}) \\ &= 21.8 \times 10^{14} \text{ BTU/YR} \end{aligned}$$

$$\% \text{ COAL} = \frac{2.882}{21.8} = 11.6\%$$

$$\% \text{ GAS} = \frac{11.648}{21.8} = 52.7\%$$

$$\% \text{ DO} = \frac{6.256}{21.8} = 28.2\%$$

$$\% \text{ DD} = \frac{4.014}{21.8} = 16.2\%$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Heggen Date 9/23/74
 Source Baileys

Ref(22) p 4-2 and 4-1 gives emission factors

$$E_{UFT} = \left(\frac{18}{.1040 \times 10^{10}} \right) \times 10^6 = 0.0173 \text{ gao}$$

$$E_{UFT} = \left(\frac{966}{.4380 \times 10^{10}} \right) (10^6) = 0.1029 \text{ RO}$$

$$E_{UFT} = \left(\frac{630}{.5817 \times 10^{10}} \right) (10^6) = 0.1083 \text{ OO}$$

$$E_{UFT} = \frac{(5000)(8.1)(10^6)}{2.62 \times 10^{10}} = 1.5458 \text{ COAL}$$

{ REF(22) p 4-1 gives ash content of = 8.1%
 COAL
 Ref(73) p A-14 states all cast iron
 units are underfired stone type

$$\begin{aligned}
 E_{UFT} &= (.0173)(.47) + (.1029)(.252) + (.1083)(.18) + (1.5458)(.116) \\
 &= 0.0081 + .0259 + .0175 + .1793 = 0.2308
 \end{aligned}$$

$$E_U = 0.2308$$

*

NO_x

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 9/23/74
 Source Boilers

Ref(2) p4-2 TAG 4-1 gives emission factors

$\frac{\#}{10^6 \text{ BTU}}$

$$EV_{NO_x} = \left(\frac{118}{1000 \times 10^{10}} \right) (10^6) = 0.1135 \quad \text{gas}$$

$$= \left(\frac{1529}{6384 \times 10^{10}} \right) (10^6) = 0.2395 \quad \text{RO}$$

$$= \left(\frac{1391}{5817 \times 10^{10}} \right) (10^6) = 0.2391 \quad \text{DO}$$

$$= \left(\frac{10,000}{2.62 \times 10^{10}} \right) (10^6) = 0.3817 \quad \text{COAL}$$

$$EV_{NO_x} = (.1135)(.47) + (.2395)(.252) + (.2391)(.162) + (.3817)(.116)$$

$$= .0533 + .0604 + .0387 + .0443 = 0.1967$$

$$EV_{NO_x} = 0.1967 \frac{\#}{10^6 \text{ BTU}} \quad *$$

H/C Same as above

$$EV_{H/C} = \left(\frac{40}{1000 \times 10^{10}} \right) (10^6) = 0.0385 \quad \text{gas}$$

$$= \left(\frac{126}{6384 \times 10^{10}} \right) (10^6) = 0.0197 \quad \text{RO}$$

$$= \left(\frac{126}{5817 \times 10^{10}} \right) (10^6) = 0.0217 \quad \text{DO}$$

$$= \left(\frac{3000}{2.62 \times 10^{10}} \right) (10^6) = 0.1145 \quad \text{COAL}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 9/23/74
 Source Smokes

$$(.0385)(.47) + (.0197)(.252) + (.0217)(.162) + (.1145)(.116) = \\ .0181 + .00496 + .0035 + .0133 = .0399$$

$$EV_{\text{HC}} = 0.0399 \text{ #}/10^6 \text{ BTU}$$

*

CO same Refs as above

$$EV_{\text{CO}} = \left(\frac{.4}{.1090 \times 10^{-6}} \right) (10^6) = .00038 \text{ gas}$$

$$= \left(\frac{8.4}{.6384 \times 10^{-6}} \right) (10^6) = .0013 \text{ RO}$$

$$= \left(\frac{8.4}{.5817 \times 10^{-6}} \right) (10^6) = .0014 \text{ DO}$$

$$= \left(\frac{10,000}{2.62 \times 10^{-6}} \right) (10^6) = 0.3817 \text{ COAL}$$

$$(.00038)(.47) + (.0013)(.252) + (.0014)(.162) + (.3817)(.116) = \\ .00018 + .00023 + .00023 + .0443 = .0449$$

$$EV_{\text{CO}} = 0.0449 \text{ #}/10^6 \text{ BTU}$$

*

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 . New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hamer Date 9/23/74
 Source Boilers

SO₂

Same sets as above for emission factors

$$\% S_{\text{gas}} = .0006 \text{ %} \quad \text{REF } \textcircled{22} \text{ p4-4 TAB 4-2}$$

$$\% S_{\text{RO}} = 1.5 \% \quad " \quad " \quad "$$

$$\% S_{\text{DO}} = 0.265 \% \text{ (PREVIOUSLY QUOTED)}$$

$$\% S_{\text{COAL}} = 2.00 \% \quad \text{REF } \textcircled{22} \text{ p4-4 TAB 4-2}$$

$$\frac{E_{\text{U}_{\text{SO}_2}}}{\text{FT}} = \frac{(0.6)(.0006)(10^6)}{(.1040 \times 10^{-6})} \approx 0.0 \quad \text{gas}$$

$$= \frac{(6804)(1.5)(10^6)}{(.6384 \times 10^{-6})} = 1.5987 \quad \text{RO}$$

$$= \frac{(5838)(.265)(10^6)}{(.5817 \times 10^{-6})} = 0.2660 \quad \text{DO}$$

$$= \frac{(38,000)/(2.0)(10^6)}{(2.62 \times 10^{-6})} = 2.9008 \quad \text{COAL}$$

$$(0.0)(.47) + (1.5987)(.252) + (.266)(.162) + (2.9008)(.116) =$$

$$0 + .4029 + .0431 + .3365 = 0.7825$$

$$\frac{E_{\text{U}_{\text{SO}_2}}}{\text{FT}} = 0.7825 \quad *$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Heger Date 9/23/74
 Source Boilers

Cast Iron

Emission factors for each fuel are the same as for firetube boilers. However, the distribution is different. Data for following fuels previously presented on "INDUSTRIAL FUELS" chart sheet.

$$\begin{aligned} \text{TOTAL HFCR}_{\text{INPUT}} &= (11.1 \times 10^6)(28.2 \times 10^6) + (56 \times 10^6)(6.384 \times 10^6) + (37 \times 10^6)(5.817 \times 10^6) \\ &\quad + (103 \times 10^6)(1040) \\ &= 2.882 \times 10^{14} + 3.5750 \times 10^{14} + 2.1523 \times 10^{14} + 10.712 \times 10^{14} \\ &\approx 19.321 \times 10^{14} \text{ BTU} \end{aligned}$$

$$\% \text{ COAL} = \frac{2.882}{19.321} = 14.9\%$$

$$\% \text{ DO} = \frac{2.152}{19.321} = 11.1\%$$

$$\% \text{ AD} = \frac{3.575}{19.321} = 18.5\%$$

$$\% \text{ GFC} = \frac{10.712}{19.321} = 55.4\%$$

Particulates

$$\begin{aligned} EU_{GFC} &= (0.173)(.554) + (.1029)(.185) + (.1083)(.111) + (1.5458)(.149) \\ &= .00958 + .0190 + .0120 + .2303 = .2709 \end{aligned}$$

$$EU_{GFC} = 0.2709 \text{ #/10}^6 \text{ BTU}$$

*

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 9/23/74
 Source Boilers

NO_x

$$(.1135)(.554) + (.2395)(.185) + (.2391)(.111) + (.3817)(.149) = \\ .0629 + .0443 + .0265 + .0569 = .1906$$

$$EV_{NO_x} = 0.1906 \text{ #/10^6 BTU} *$$

H/C

$$(.0385)(.554) + (.0197)(.185) + (.0217)(.111) + (.1145)(.149) = \\ .0213 + .0036 + .0024 + .0171 = 0.0444$$

$$EV_{HC} = 0.0444 \text{ #/10^6 BTU} *$$

CO

$$(.00038)(.554) + (.0013)(.185) + (.0014)(.111) + (.3817)(.149) = \\ 0.00021 + .00024 + .00016 + .0569 = .0575$$

$$EV_{CO} = 0.0575 \text{ #/10^6 BTU} *$$

SO₂

$$(0) + (1.5987)(.185) + (.266)(.111) + (2.901)(.149) = \\ = 0.2958 + .0295 + .4322 = .7575$$

$$EV_{SO_2} = 0.7575 \text{ #/10^6 BTU} *$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 9/23/74
 Source Bolton

WATERBURY - 1

Particulate

Emission factors for RO, DO & Gas are the same.
 Coal must be broken down dependent upon fuel mechanism.

REF(13) pA-14 inc A-2 gives fuel breakdown & def's

$$\begin{array}{lll} PV = .194 & OF = .474 & UF = .129 \\ CY = 0.0 & SS = .203 & \end{array}$$

$$\begin{aligned} Eu_{vg} &= .0173 \text{ gas} \\ &= .1029 \text{ RO} \\ &= .1083 \text{ DO} \end{aligned}$$

For coal, ref(12) pA-2 inc A-1

$$\begin{aligned} (.194)(16000) + (.474)(13000) + (.129)(5000) + (.203)(5000) = \\ 3104 + 6162 + 645 + 1015 = 10,926 \text{ A} \end{aligned}$$

$$\frac{(10,926)(8.1)(10^6)}{2.62 \times 10^{10}} = 3.378 \% \text{ on coal}$$

Fuel usage breakdown has been previously presented for WT-1
 BOLTONS

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 9/23/74
 Source Boilers

$$\begin{aligned} \text{TOTAL HEAT} &= \frac{(132 \times 10^6)(26.2 \times 10^6) + (194 \times 10^6)(6.384 \times 10^6) + (14 \times 10^6)(5.817 \times 10^6)}{\text{INPUT}} + \\ &\quad + \frac{(1.72 \times 10^{12})(1090)}{=} = 34.584 \times 10^{14} + 12.385 \times 10^{14} + 0.814 \times 10^{14} + 17.888 \times 10^{14} \\ &= 65.671 \times 10^{14} \end{aligned}$$

$$\% \text{ COAL} = \frac{34.584}{65.671} = 52.7\% \quad \% \text{ DO} = \frac{3.14}{65.671} = 1.2\%$$

$$\% \text{ RO} = \frac{12.385}{65.671} = 18.9\% \quad \% \text{ GAS} = \frac{17.888}{65.671} = 27.2\%$$

$$\begin{aligned} Eu_{WT-1} &= \frac{(3.378)(.527) + (.1029)(.189) + (.1083)(.012) + (.0173)(.272)}{1000} \\ &= 1.780 + .0194 + .0013 + .0047 = 1.8054 \end{aligned}$$

$$Eu_{WT-1} = 1.8054 \text{ #/10^6 Btu} \quad *$$

NO_x Ref(22) p 4-2 tabs 4-1 gives emission factors

$$Eu_{WT-1} \text{ gas} = \frac{(167.6)(10^6)}{.1040 \times 10^{10}} = 0.1612 \text{ gas}$$

$$Eu_{WT-1} \text{ RO} = \frac{(218)(10^6)}{0.6384 \times 10^{10}} = .0341 \text{ RO}$$

$$Eu_{WT-1} \text{ DO} = \frac{(2017)(10^6)}{.5817 \times 10^{10}} + .3467 \text{ DO}$$

Using the coal feed breakdowns previously presented for WT-1 boilers,

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 9/23/74
 Source Boilers

$$\frac{EU_{WT-1}}{COAL} = (.194)(20,000) + (.474)(15,000) + (.129)(10,000) + (.203)(10,000)$$

$$= 3880 + 7110 + 1290 + 2030 = 14,310$$

$$\frac{EU_{WT-1}}{COAL} = \frac{(14,310)(10^6)}{2.62 \times 10^{10}} = .5462$$

$$(.5462)(.527) + (.189)(.0341) + (.012)(.3467) + (.272)(.1612) =$$

$$.2878 + .0064 + .0042 + .0438 = .3422$$

$$\frac{EU_{WT-1}}{NOX} = 0.3422 \text{ #/10^6 BTU}$$

H/C

Ref (22) p 4-2 tab 4-1 gives emission factors

$$\frac{EUNC_{WT-1}}{gas} = \frac{(20)(10^6)}{.1040 \times 10^{10}} = .0192$$

$$\frac{EU_{WT-1}}{DO} = \frac{(126)(10^6)}{.6384 \times 10^{10}} = .0197$$

$$\frac{EU_{WT-1}}{RO} = \frac{(26)(10^6)}{.5817 \times 10^{10}} = .0217$$

Using coal feed breakdowns as previously presented

$$\frac{EU_{WT-1}}{COAL} = (.194)(300) + (.474 + .129 + .203)(3000) = 58.2 + 2418 = 2476$$

$$= (2476)(10^6) / (2.62 \times 10^{10}) = .0945$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hager Date 9/23/74
 Source Boilers

$$(.0192)(.272) + (.0197)(.012) + (.0217)(.189) + (.0945)(.527) = \\ .00522 + .00024 + .0041 + .0498 = .0594$$

$$EU_{WT-1} = .0594 \frac{\%}{10^6 Btu} *$$

SOx Emission factors for gas, RO, DO, same as ^{fossil} coal
 gas - 0.0
 RO - 1.5987
 DO - .2660
 coal - 2.901

$$(.012)(.2660) + (.189)(1.5987) + (.527)(2.901) = .0032 + .3022 + 1.5288 \\ = 1.8342$$

$$EU_{WT-1} = 1.8342 \frac{\%}{10^6 Btu} *$$

CO Ref (22) p 4-2 mo 4-1 for emission factors

$$EU_{WT-1} = \frac{(8)(10^6)}{.1040 \times 10^{10}} = .0077 \quad \text{gas}$$

$$EU_{WT-1} = \frac{(8.4)(10^6)}{.6384 \times 10^{10}} = .0013 \quad \text{RO}$$

$$EU_{WT-1} = \frac{(8.4)(10^6)}{.5817 \times 10^{10}} = .0014 \quad \text{DO}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Happer Date 9/27/74
 Source Boilers

$$EV_{WT-1} = (.194)(1000) + (.474 + .129 + .203)(10,000) = 194 + 8060 = \frac{8254}{8254}$$

$$EV_{WT-1} = \frac{(8254)(10^6)}{2.62 \times 10^6} = .3150$$

$$(.012)(.0014) + (.189)(.0013) + (.527)(.3150) + (.273)(.0077) = \\ 0 + .00025 + .1660 + .0021 = .1684$$

$$EV_{WT-1} = 0.1684 \frac{\text{t}}{10^6 \text{Btu}} *$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 9/27/74
 Source Boilers

WTEUSE - 2

Precursors

Emission factors ref(22) p 4-27A8 t-1

$$EU_{WT-2} = \frac{(15)(10^6)}{.1090 \times 10^{10}} = .0144 \text{ gas}$$

$$EU_{WT-2} = \frac{(420)(10^6)}{.63842 \times 10^{10}} = .0658 \text{ RO}$$

$$EU_{WT-2} = \frac{(630)(10^6)}{.58172 \times 10^{10}} = .1083 \text{ DO}$$

Coke Feed breakdowns per ref(73) p A-14 TMA A-2

$$\begin{array}{lll} PY = .593 & OF = .293 & UF = .021 \\ CY = .016 & SS = .077 & \end{array}$$

$$\begin{aligned} (.593)(16000) + (.016)(20,000) + (.293)(13000) + (.077)(5000) + (.021)(5000) = \\ 9488 + 320 + 3809 + 385 + 105 = 14,107 \text{ A} \end{aligned}$$

$$EU_{WT-2} = \frac{(14,107)(0.1)(10^6)}{2.62 \times 10^{10}} = 4.3613 \text{ coal}$$

Fuel usage distribution is same as WT-1

$$\text{gas} = 27.2\%$$

$$RO = 18.9\%$$

$$DO = 1.2\%$$

$$COAL = 52.7\%$$

$$\begin{aligned} EU_{WT-2} = (.0144)(.272) + (.0658)(.189) + (.1083)(.012) + (4.3613)(.527) = \\ .0039 + .0124 + .0013 + 2.2984 = 2.316 \end{aligned}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoyer Date 9/22/74
 Source Baileys

$$EU_{WT-Z} = 2.316 \frac{\text{#}/10^6 \text{ BTU}}{\text{P}}$$

*

NO_x

$$EU_{WT-Z} = \frac{(228)(10^6)}{1.040 \times 10^{10}} = .2192 \quad \text{gas}$$

$$EU_{WT-Z} = \frac{(3072)(10^6)}{6.384 \times 10^{10}} = .4812 \quad \text{RO}$$

$$EU_{WT-Z} = \frac{(2794)(10^6)}{5.817 \times 10^{10}} = .4803 \quad \text{OO}$$

COAL

$$(.593)(20,000) + (.013)(60,000) + (.293)(15,000) + (.077+.021)(10,000) =$$

$$11,860 + 960 + 4375 + 980 = 18,195$$

$$EU_{WT-Z} = \frac{(18,195)(10^6)}{2.62 \times 10^{10}} = 0.6945$$

$$EU_{WT-Z} = \frac{(.2192)(.2192) + (.189)(.4812) + (.012)(.4803) + (.527)(.6945)}{NO_x} = \\ = .0596 + .0909 + .0058 + .3660 = 0.5223$$

$$EU_{WT-Z} = 0.5223 \frac{\text{#}/10^6 \text{ BTU}}{NO_x}$$

*

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 9/27/74
 Source Boilers

HC Ref(22) p 4-2 ~~TABLE-1~~: emission factors

$$EU_{W_{T-Z}} = \frac{(10)(10^6)}{104 \times 10^{10}} = .0385 \quad \text{gas}$$

$$EU_{W_{T-Z}} = \frac{(26)(10^6)}{6384 \times 10^{10}} = .0197 \quad RO$$

$$EU_{W_{T-Z}} = \frac{(26)(10^6)}{5817 \times 10^{10}} = .0217 \quad DO$$

$$\text{COAL} \\ (.593)(300) + (.016)(300) + (.293 + .077 + .021)(1000) = 182.7 + 391 = 574$$

$$EU_{W_{T-Z}} = \frac{(574)(10^6)}{2.62 \times 10^{10}} = .0219$$

$$(.0385)(.272) + (.0197)(.189) + (.0217)(.012) + (.0219)(.527) = \\ .0105 + .0037 + .00026 + .0115 = 0.026$$

$$EU_{W_{T-Z}} = 0.026 \% / 10^6 BTU \quad *$$

SO_x Emission factors same as for firetube

$$\text{gas} \approx 0.0$$

$$RO = 1.5987$$

$$DO = .2660$$

$$COAL = 2.901$$

$$34 \quad EU_{W_{T-Z}} = \frac{(1.5987)(.189) + (.2660)(.012) + (2.901)(.527)}{.3022 + .0032 + 1.5288} =$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 9/27/74
 Source Boiler

$$E_{UWT-2} = 1.8342 \times 10^6 \text{ BTU}$$

*

CO

Emissions factor Ref(22) p 42 tab 1-1

$$E_{UWCO} = \frac{(6.4)(10^6)}{1.04 \times 10^{10}} = 0 \quad \text{gas}$$

$$E_{UWCO} = \frac{(3.4)(10^6)}{6.384 \times 10^{10}} = .0013 \quad \text{CO}$$

$$E_{UWCO} = \frac{(2.4)(10^6)}{5.817 \times 10^{10}} = .0014 \quad \text{CO}$$

COAL

$$(593 + 0.08)(1000) + (293 + 0.22 + 0.02)(2000) = 609 + 782 = 1391$$

$$E_{UWT-2} = \frac{(1391)(10^6)}{2.68 \times 10^{10}} = .0531$$

$$\begin{aligned} E_{UWT-2} &= (189)(.0013) + (.012)(.0014) + (.527)(.0531) \\ &= .00025 + 0 + .0280 = .0283 \end{aligned}$$

$$E_{UWT-2} = 0.0283 \times 10^6 \text{ BTU}$$

*

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 9/27/74
 Source Boilers

Wt-3

Procedure

Ref (22) p 4-2 tabs 4-1 for emissions

Assuming a misprint for CY coal
 emissions (2000 instead of 20,000), emission
 factors are the same as for wt-2 boilers.
 coal emission factors must be redefined since the feed
 mechanism is different than wt-2

Ref (23) p A-14 tabs A-2 states 92.1% PV & the remaining
 % being distributed between the other feed mechanisms. We
 will assume 100% PV.

$$E_{U\text{wt-3}} = .0144 \quad \text{gas}$$

$$E_{U\text{wt-3}} = .0658 \quad \text{RO}$$

$$E_{U\text{wt-3}} = .1083 \quad \text{DO}$$

$$E_{U\text{wt-3}} = \frac{(16,000)(.81)(10^6)}{2.62 \times 10^{10}} = 4.9466 \quad \text{coal}$$

use usage & distribution same as wt-1

$$\begin{aligned} E_{U\text{wt-3}} &= (.0144)(.272) + (.0658)(.189) + (.1083)(.012) + (4.9466)(.527) \\ &= .0039 + .0124 + .0013 + 2.6069 = 2.6245 \end{aligned}$$

$$E_{U\text{wt-3}} = 2.6245 * 10^6 \text{ lb}$$

*

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoyer Date 9/27/74
 Source Boilers

NO_x Ref ② p 4-2 nos 4-1 for emission factors

$$EU_{WT-3} = \frac{(239)(10^6)}{.104 \times 10^{10}} = .2394 \quad \text{gas}$$

$$\frac{EU_{WT-3}}{RD} = \frac{(3372)(10^6)}{.6384 \times 10^{10}} = .5282 \quad RD$$

$$\frac{EU_{WT-3}}{DO} = \frac{(3067)(10^6)}{.5817 \times 10^{10}} = .5272 \quad DO$$

$$\frac{REAL}{COAL} EU_{WT-3} = \frac{(29,000)(10^6)}{2.62 \times 10^{10}} = .7634 \quad COAL$$

$$EU_{NO_x}_{WT-3} = (.2394)(.272) + (.5282)(.189) + (.5272)(.012) + (.7634)(.527) \\ = .0651 + .0998 + .0063 + .4023 = .5735$$

$$EU_{WT-3} = 0.5735 \times 10^6 \text{ lbu}$$

*

H/C Emission factors for gas, DO, RD same as WT-2

$$EU_{WT-3} = .0285$$

$$\frac{EU_{WT-3}}{RD} = .0197$$

$$\frac{EU_{WT-3}}{DO} = .0217$$

$$\frac{EU_{WT-3}}{COAL} = \frac{(300)(10^6)}{2.62 \times 10^{10}} = .0115$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 7/27/74
 Source Baileys

$$EU_{WT-3}^{HC} = (.0385)(.272) + (.0197)(.189) + (.0217)(.012) + (.005)(.527)$$

$$= .0105 + .0037 + .00026 + .0061 = .0206$$

$$EU_{WT-3}^{HC} = .0206 \text{ #/10^6 Btu} *$$

SO_x same emission factors as for WT-2

$$gas \approx 0.0$$

$$R0 = 1.5987$$

$$DO = .2660$$

$$COFC = 2.901$$

$$EU_{WT-3}^{SO_x} = (.5987)(.189) + (.2660)(.012) + (2.901)(.527) =$$

$$= .3022 + .0032 + 1.5288 = 1.8342$$

$$EU_{WT-3}^{SO_x} = 1.8342 \text{ #/10^6 Btu} *$$

CO EU for Gas, R0, DO same as WT-2

$$EU_{WT-3}^{CO} = 0$$

$$EU_{WT-3}^{CO} = .0013$$

$$EU_{WT-3}^{CO} = .0014$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoyer Date 9/28/74
 Source Boilers

$$\text{air} \quad EU_{WT-3} = \frac{(1000)(10^6)}{2.62 \times 10^{10}} = .0382$$

$$EU_{WT-3} = (.0013)(.189) + (.0004)(.012) + (.0382)(.527) \\ = 0.00025 + 0 + .02013 = .0204$$

$$EU_{WT-3} = 0.0204 \text{ } \% \text{ } \text{SO}_2 \text{ BRU}$$

**

WT-4

Assume emission factors for Gas, RO, DO to be the same as for WT-3 units. coal is 100% PR (Ref 73 p-A14 TAA1-2)
 i.e. Emission factor for coal is same also. Fuel usage for WT-4 units has been previously presented as:

$$\begin{aligned} \text{TOTAL FUEL} &= (271 \times 10^6)(28.2 \times 10^6) + (156 \times 10^6)(6.384 \times 10^6) + (2 \times 10^6)(5.87) \\ &\quad + (2.76 \times 10^6)(1000) \\ &= 7.100 \times 10^{15} + .996 \times 10^{15} + .0116 \times 10^{15} + 2.870 \times 10^{15} \\ &= 10.978 \times 10^{15} \end{aligned}$$

$$\% \text{ COAL} = \frac{7.100}{10.978} = 64.7\%$$

$$\% \text{ RO} = \frac{.996}{10.978} = 9.1\%$$

$$\% \text{ DO} = \frac{.0116}{10.978} = 0.1\% \approx 0.0\%$$

$$\% \text{ Gas} = \frac{2.870}{10.978} = 26.1\%$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 9/27/74
 Source Bailees

Particulates

$$(0.154)(.26) + (.0658)(.091) + 0 + (4.9466)(.647) = Eu_{wrt-4}$$

$$Eu_{wrt-4} = .0038 + .0060 + 3.2004 = 3.2102$$

$$Eu_{wrt-4} = 3.2102 \text{ %/10^6 GRU}$$

*

NOx

$$(0.2391)(.261) + (.5282)(.091) + (.5272)(0) + (.7634)(.647)$$

$$= .0625 + .0481 + .4939 = .6045$$

$$Eu_{wrt-3} = .6045$$

*

H/C

$$(0.225)(.261) + (.0197)(.091) + (.0115)(.647) = .0100 + .0018 + .0074$$

$$Eu_{wrt-3} = 0.0192 \text { %/10^6 GRU}$$

*

SOx

$$(1.5987)(.091) + (2.901)(.647) = .1455 + 1.8769 = 2.0224$$

$$Eu_{wrt-3} = 2.0224 \text { %/10^6 GRU}$$

*

CO

$$(0.013)(.091) + (.0382)(.647) = .00012 + .0247 = .0248$$

$$Eu_{wrt-3} = .0248 \text { %/10^6 GRU}$$

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 9/27/74

Source Boilers

Intermediate Summary

RESIDENTIAL
.5178 Fireuse
.4822 Gasfurn
.5833 WT-1
.4167 WT-2
.1718 WT-3
.8282 WT-4

PART	NOX	NC	SOX	CD	
.0391	.0806	.0187	.1070	.0258	< 0.3
.2308	.1967	.0399	.7825	.0449	0.3-10.0
.2709	.1906	.0444	.7575	.0575	
1.8054	.3422	.0594	1.8342	.1684	10-250
2.316	.5223	.0260	1.8342	.0283	
2.6245	.5735	.0206	1.8342	.0204	
3.2102	.6045	.0192	2.0229	.0248	> 250

These values will be weighted for each category based upon data from TABLE 1-5 p16 Ref 73

0.3-10.0

$$EU_{0.3-10} = \left(\frac{757}{757+813} \right) (.2709) + \left(\frac{713}{757+813} \right) (.2308)$$

$$= (0.4822)(.2709) + (0.5178)(.2308)$$

$$= 0.1306 + .1195$$

$$EU_{0.3-10.0} = 0.2501 \text{ #}/10^6 \text{ BTU}$$

$$EU_{NOX 0.3-10.0} = (0.4822)(.1906) + (.5178)(.1967) = .0919 + .1019$$

$$EU_{NOX 0.3-10.0} = 0.1938 \text{ #}/10^6 \text{ BTU}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hager Date 7/27/77
 Source Boilers

$$EU_{HC} = (0.4822)(0.4444) + (.5178)(.0399) = .0214 + .0207$$

$$EU_{HC} = 0.0421 \frac{\#}{10^6 \text{ BRU}} \\ 0.3-10.0$$

$$EU_{SO_2} = (.4822)(.7575) + (.5178)(.7825) = .3653 + .4052$$

$$EU_{SO_2} = 0.7705 \frac{\#}{10^6 \text{ BRU}} \\ 0.3-10.0$$

$$EU_{CO} = (.4822)(.0575) + (.5178)(.0449) = .0277 + .0232$$

$$EU_{CO} = 0.0509 \frac{\#}{10^6 \text{ BRU}} \\ 0.3-10.0$$

DO-250

1579

$$WT-1 = \frac{921}{921+658} = .5833$$

$$WT-2 = \frac{658}{921+658} = 0.4167$$

$$EU_p = (1.8054)(.5833) + (2.31)(.4167) = 1.0531 + .9651$$

$$EU_p = 2.0182 \frac{\#}{10^6 \text{ BRU}} \\ 10-250$$

$$EU_{NO_x} = (.5833)(.3422) + (.4167)(.5223) = .1996 + .2176$$

$$(EU_{NO_x} = 0.4172 \frac{\#}{10^6 \text{ BRU}})$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 9/27/74
 Source Poiless

$$E_{U_{HC}} = (0.5833)(.0594) + (.4167)(.0260) = .0346 + .0108 =$$

$$E_{U_{HC}} = 0.0454 \text{ #/10}^6 \text{ BTU}$$

$$E_{U_{SOX}} = (5833)(1.8342) + (.4167)(1.8342)$$

$$E_{U_{SOX}} = 1.8342 \text{ #/10}^6 \text{ BTU}$$

$$E_{U_{CO}} = (.5833)(.1684) + (.4167)(.0283) = .0982 + .0118$$

$$E_{U_{CO}} = 0.11 \text{ #/10}^6 \text{ BTU}$$

> 250

$$WT-3 = \frac{159}{299+1248} = .1718$$

$$WT-4 = \frac{1248+}{1248+259} = .8282$$

$$E_{UP} = (.1718)(2.6245) + (.8282)(3.2102) = .4509 + 2.6589$$

$$E_{UP,>250} = 3.1098 \text{ #/10}^6 \text{ BTU}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 9/22/74
 Source Boilers

$$EU_{NO_x} = (.1718)(.5735) + (.8282)(.6045) = 0.0985 + .5006$$

$$EU_{NO_x} = 0.5991 \frac{\#}{10^6 \text{ BTU}} \\ > 250$$

$$EU_{HC} = (.1718)(.0205) + (.8282)(.0192) = .0035 + .0159$$

$$EU_{HC} = 0.0194 \frac{\#}{10^6 \text{ BTU}} \\ > 250$$

$$EU_{SO_x} = (.1718)(1.8342) + (.8282)(2.0224) = .3151 + 1.6750$$

$$EU_{SO_x} = 1.9901 \frac{\#}{10^6 \text{ BTU}} \\ > 250$$

$$EU_{CO} = (.1718)(.0204) + (.8282)(.0248) = .0035 + .0205$$

$$EU_{CO} = 0.0240 \frac{\#}{10^6 \text{ BTU}} \\ > 250$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoyer Date 9/27/74
 Source Boilers

Summary Of Eu:

	PART	NO _x	H/C	SO _x	CO
RESIDENTIAL	.039	.081	.019	.107	.026
0.3-10.0	.250	.194	.042	.771	.051
10.0-250	2.018	.417	.045	1.834	.110
>250	3.110	.599	.019	1.990	.024

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper

Date 10/2/74

Source Boilers

Determination Of EN

RESIDENTIAL UNITS

Nothing could be found in the literature regarding specific control methods for residential units. Some mention was made of work being done but no concrete values [REF (73) P196].

IT WOULD APPEAR @ THE PRESENT TIME THAT RESIDENTIAL UNITS ARE NOT AMENABLE TO CONTROL.

IN ORDER TO DETERMINE THE EXTENT OF UNCONTROLLED EMISSIONS & TO ASCERTAIN MAXIMUM IMPACT, WE WILL USE THE METHODOLOGY USED PREVIOUSLY IN OUR STUDY WHICH SETS $EN = 0.0$ SO THAT MAX IMPACT CAN BE QUANTIFIED. IF THE RESULT IS EXTREMELY HIGH, WE WILL HAVE "FLAGGED" AN "INDUSTRY" WHICH REQUIRES A SUBSTANTIAL R&D EFFORT ON CONTROL TECHNOLOGY BEFORE NSPS COULD BE SET.

$$\text{EN}_{\text{ALL POLLUTANTS RES}} = 0.0$$

2/5/75 Ref(202) p 7-13 indicates the potential for a 50% NO_x reduction.

So, instead of $EN = 0.0$, we will use $EN_{NOx} = (0.5)(EN) = (0.5)(0.0) = 0.04$

$$EN_{NOx} = 0.04$$

FIRETUBE & CAST IRON

REF (28) p 4-19 "FUEL SWITCHING IS THE MOST COST-EFFECTIVE STRATEGY FOR REDUCING EMISSIONS FROM INTERMEDIATE BOILERS."

REF (28) p 4-19 "HOWEVER, FOR STEAM-ELECTRIC PLANTS, [>50 MW] A COMPLETE SWITCH FROM HIGH SULFUR COAL AND OIL TO LOW SULFUR OIL IS NOT FEASIBLE. . . ."

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 10/2/74
 Source Boilers

REF (73) p 214 TAC 6-3 & p 225 TAC 6-9

Particulates

0.549×10^6 tons/yr (uncontrolled)

REDUCTION DUE TO FUEL SWITCHING = 0.349×10^6 T.P.Y
 REDUCTION DUE TO FUEL ADDITIVES = 0.094×10^6 T.P.Y
 TOTAL REDUCTION = 0.443×10^6 T.P.Y

$$R_{\text{REDUCTION}} = \frac{0.443}{0.549} = 80.7\% \quad *$$

PART.
FT +
CI

SO_x

1.983×10^6 T.P.Y (uncontrolled)

REDUCTION DUE TO FUEL SWITCHING = 1.452×10^6 T.P.Y
 NO REDUCTION BY SUPPLEMENTAL MEANS

$$\frac{1.452}{1.983} = 73.2\%$$

$$R_{\text{REDUCTION}} = 73.2\% \quad *$$

SO_x
FT +
CI

NO_x

0.574×10^6 T.P.Y (uncontrolled)

0.057×10^6 T.P.Y REDUCTION DUE TO FUEL SWITCHING

$$R = .057/.574 = 9.9\%$$

NO REDUCTION BY
SUPPLEMENTAL MEANS

$$R_{\text{REDUCTION, NO}_x} = 9.9\% \quad *$$

FT + CI

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 10/2/74

Source Bailees

Wardrobe - I

Ref (73) p 214 TAB 6-3 & p 225 TAB 6-9

Procedures

$1.421 \times 10^6 \text{ TPy}$ (uncontrolled)

$1.287 \times 10^6 \text{ TPy}$ REDUCTION DUE TO FUEL SWAPPING

$0.057 \times 10^6 \text{ TPy}$ REDUCTION DUE TO FUEL ADDITIVES
 & COMBUSTION MODIFICATION

1.344 TPy - TOTAL REDUCTION

$$\eta = \frac{1.334}{1.421} = 94.6\%$$

η REDUCTION = 94.6%
 PART
 WT-1

*

SO_x

$2.410 \times 10^6 \text{ TPy}$ (UNCONTROLLED)

$2.023 \times 10^6 \text{ TPy}$ REDUCTION DUE TO FUEL SWAPPING

NO REDUCTION BY SUPPLEMENTAL METHODS

$$\eta = \frac{2.023}{2.410} = 83.9\%$$

η REDUCTION = 83.9%
 SOX
 WT-1

*

NO_x

$0.620 \times 10^6 \text{ TPy}$ UNCONTROLLED

$0.133 \times 10^6 \text{ TPy}$ REDUCTION BY FUEL SWAPPING

$0.268 \times 10^6 \text{ TPy}$ REDUCTION DUE TO COMBUSTION MODIFICATION

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 10/2/74

Source Boilers

TOTAL REDUCTION = 0.401×10^6 TPY

$$\eta = \frac{.401}{.620} = 64.7\%$$

$\eta_{REDUCTION} = 64.7\%$

NOx
WT-1

*

WATERTUBE 2 & 3

PARTICULATE

0.561×10^6 TPY (UNCONTROLLED)

0.496×10^6 TPY BY FUEL SWITCHING

0.023×10^6 TPY BY FUEL ADDITIVES & COMBUSTION MODIFICATION

TOTAL REDUCTION = 0.519×10^6 TPY

$$\eta = \frac{.519}{.561} = 92.5\%$$

$\eta_{REDUCTION} = 92.5\%$

PART
WT-2,3

*

SOx

3.239×10^6 TPY (UNCONTROLLED)

2.876×10^6 TPY REDUCTION BY FUEL SWITCHING

NO REDUCTION BY SUPPLEMENTAL METHODS

$$\eta = \frac{2.876}{3.239} = 88.8\%$$

$\eta_{REDUCTION} = 88.8\%$

SOx
WT2,3

*

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Kepner Date 10/2/74
 Source Boilers

NO_x

0.885×10^6 TPY (UNCONTROLLED)
 0.271×10^6 TPY BY FUEL SWITCHING
 0.350×10^6 TPY BY COMBUSTION MODIFICATION
 REDUCTION

$$\text{TOTAL REDUCTION} = 0.621 \times 10^6 \text{ TPY}$$

$$R = \frac{621}{885} = 70.2\%$$

$$R_{\text{REDUCTION}} = 70.2\% \quad * \\ \text{NO}_x \\ \text{WT 2,3}$$

WT-4 As mentioned on p 30 of these facts, FUEL SWITCHING IN THE LARGE UNITS IS NOT FEASIBLE. REF (73) p 28 STATES "ONLY SIMPLE ALKALINE SCRUBBING WAS CONSIDERED AS PRACTICALLY FEASIBLE FOR INTERMEDIATE SIZE BOILERS."

REF (73) p 212 TAB 6-2 gives control from wet scrubbing employing a sodium carbonate solution

Assume data for WT-2,3 size

Particulate

0.561×10^6 TPY (UNCONTROLLED)
 0.539×10^6 TPY BY SCRUBBING
 $R = \frac{.539}{.561} = 96.1\% = R_{\text{REDUCTION}} \text{PART WT-4}$

SO_x

3.239×10^6 TPY (UNCONTROLLED)
 3.072×10^6 TPY REDUCTION BY SCRUBBING

$$R = \frac{3.072}{3.239} = 94.8\%$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 10/12/74
 Source Boilers

$$\text{R}_\text{Reduction} = 99.8\% \\ \text{SO}_x \\ \text{WT-4}$$

NO_x

$0.885 \times 10^6 \text{ TPR}$ (UNCONTROLLED)

$0.177 \times 10^6 \text{ TPR}$ REDUCTION FROM WET SCRUBBING

$$R = \frac{.177}{.885} = 20\%$$

$$\text{R}_\text{Reduction} = 20\% \\ \text{NO}_x \\ \text{WT-4}$$

Summary Of Efficiencies:

CASE I DOWN

FLEETWISE

WT-1

WT-2

WT-3

WT-4

PART	SO _x	NO _x
80.7	73.2	9.9
80.7	73.2	9.9
94.6	83.9	64.7
92.5	88.8	70.2
92.5	88.8	70.2
96.1	94.8	20.0

No information could be found regarding control of CO & H/C

We will weight these efficiencies by the fraction of capacity of that type (REF 13 pg TAB 1-5) to set'n the avg R for each source category. This avg efficiency will then be applied to E_u to derive E_n.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 10/12/74
 Source Boilers

RESIDENTIAL

$$E_N = 0.0 \frac{\#}{10^6 \text{ BTU}}$$

ALL
POLLUTANTS
CO₂

REASONING HAS BEEN
PREVIOUSLY DISCUSSED *

0.3 - 10.0

$$R_{part} = 80.7\%$$

$$E_N = (1 - .807)(.250) =$$

$$E_N = 0.3 - 10.0 = 0.048 \frac{\#}{10^6 \text{ BTU}}$$

PART *

$$R_{SOX} = 73.2\%$$

$$E_N = (1 - .732)(.771) = 0.207$$

$$E_N = 0.3 - 10.0 = 0.207 \frac{\#}{10^6 \text{ BTU}}$$

SOX *

$$R_{NOX} = 9.9\%$$

$$E_N = (1 - .099)(.194) = 0.175$$

$$E_N = 0.3 - 10.0 = 0.175 \frac{\#}{10^6 \text{ BTU}}$$

NOX *

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 10/4/74

Source Boilers

IN A EFFORT TO
 DET'N THE MAX
 $(T_S - T_H)$ FOR
 REASONS PREVIOUSLY
 DISCUSSED:

$$E_N = 0.0 \text{ #}/10^6 \text{ BTU}$$

H/C

$$E_N = 0.0 \text{ #}/10^6 \text{ BTU}$$

CO

10.0 - 250 ($WT_1 + WT_2$)

PART $WT_1 = \frac{921}{921+658} = 0.5833$

$$WT_2 = \frac{658}{921+658} = 0.4167$$

$$\bar{R}_P = (94.6)(.5833) + (92.5)(.4167) = 55.18 + 38.54$$

$$\bar{R}_P = 93.7\%$$

$$E_N_{10-250} = (1 - .937)(2.018) = 0.127$$

PART

$$E_N_{10-250} = 0.127 \text{ #}/10^6 \text{ BTU}$$

PART

SO_x

$$\bar{R}_{SO_x} = (.5833)(83.9) + (.4167)(88.8) = 48.94 + 37.00 = 85.94$$

$$E_N_{SO_x} = (1 - .859)(1.834) = 0.259 \text{ #}/10^6 \text{ BTU}$$

$$E_N_{SO_x} = 0.259 \text{ #}/10^6 \text{ BTU}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 10/2/74
 Source Bailees

NO_x

$$\bar{R}_{NO_x} = (.5853)(69.7) + (.4167)(70.2) = 37.74 + 29.25$$

$$\bar{R}_{NO_x} = 67.0\%$$

$$E_{NO_x}^{10-250} = (1 - .67)(0.417) \approx 0.138$$

$$E_{NO_x}^{10-250} = 0.138 * 10^6 BTU$$

for reasons previously discussed

$$E_{CO}^{10-250} = 0.0 * 10^6 BTU$$

$$E_{HC}^{10-250} = 0.0 * 10^6 BTU$$

> 250 (WT-3, 4)

The reg'd NSPS for particulate is 0.1 * 10⁶ BTU (Ref 273). Ref 147 p9 states that new full-scale scrubbers are being installed @ large steam generators which have been designed to meet the std's.

Particulate However, Ref 279 indicates that 5/8/75 a level of 0.05 would be attained using an ESP. If we assume that the cost is not prohibitive.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 10/2/74
 Source Boilers

$$E_{N_P > 250} = 0.05 \text{ lb}/10^6 \text{ BTU}$$

SOx

$$\bar{R}_{SO_x} = (.1718)(83.8) + (.8282)(94.8) = 15.26 + 78.51 \\ \bar{R}_{SO_x} = 93.87$$

$$E_N = (1 - .938)(1.990) = 0.123 \text{ #}/10^6 \text{ BTU}$$

$$\bar{E}_{N > 250} = 0.123 \text{ #}/10^6 \text{ BTU}$$

NO_x

$$\bar{R}_{NO_x} = (70.2)(.1718) + (20.0)(.8282) = 12.06 + 16.56$$

$$\bar{R}_{NO_x} = 28.67$$

$$E_N = (1 - .286)(.599) = 0.428$$

$$E_{N > 250} = 0.428 \text{ #}/10^6 \text{ BTU}$$

For reasons previously discussed,

$$\bar{E}_{N > 250} = 0.0 \text{ #}/10^6 \text{ BTU}$$

$$(E_{N > 250} = 0.0 \text{ #}/10^6 \text{ BTU})$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hegge Date 10/2/74

Source Boilers

SUMMARY OF EN:

(EU SUMMARY ON pg 9)

RESIDENTIAL

0.3 - 10.0

10.0 - 250

> 250

PART	NO _x	H/C	SO _x	CO
0.0	0.0	0.0	0.0	0.0
.048	.175	0.0	.207	0.0
.127	.138	0.0	.259	0.0
.05	.428	0.0	.123	0.0

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoyer Date 10/3/74

Source Boilers

Es DETERMINATION

PARTICULATE

THERE ARE ONLY THREE STATES (ONE IS D.C.) WITH ES FOR BOILERS LESS THAN 1×10^6 BTU/HR. THEREFORE ASSUME

$$E_{S<0.3} = E_{U<0.3} = 0.039 \frac{\#}{10^6 \text{ BTU}}$$

Ref (84)

P 20-23 incl. TAB 1 & THE ENVIRONMENTAL RPTR (UP TO & INCLUDING AUGUST '74 ADDITIONS) WERE USED AS THE REFERENCES.

SINCE VALUES OF ES FOR EACH SIZE CATEGORY WERE OF THE SAME GENERAL ORDER OF MAGNITUDE, A STRAIGHT LINEAR AVERAGE WAS ASSUMED AS OPPOSED TO AN AVERAGE WEIGHTED BY THERM. USAGE.

THE ATTACHED TABLES GIVE THE SPECIFIC STATE AVGS FOR EACH SIZE CATEGORY + THE METHODOLOGY USED IN THEIR DETERMINATION IF UNIQUE.

IT WAS NECESSARY TO DETERMINE AN ES FOR BOTH NEW & EXISTING SOURCES.

$$E_{S_{0.3-10.0}} = 0.48 \frac{\#}{10^6 \text{ BTU}}$$

PART
EXISTING

HOWEVER,

$$E_{U_{0.3-10.0}} = 0.250 \frac{\#}{10^6 \text{ BTU}}$$

PART



TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 10/13/74
 Source Boilers

$$E_S_{0.3-10.0} = 0.428 \text{ #/10}^6 \text{ BTU}$$

PART
NEW

$$E_U = .250 \frac{\#}{\text{10}^6 \text{ BTU}}$$

$$E_S_{10-250} = 0.383 \text{ #/10}^6 \text{ BTU}$$

PART
EXIST

$$E_S_{10-250} = 0.334 \text{ #/10}^6 \text{ BTU}$$

PART
NEW

$$E_S_{>250} = 0.277 \text{ #/10}^6 \text{ BTU}$$

PART
EXIST

$$E_S_{>250} = 0.100 \text{ #/10}^6 \text{ BTU}$$

PART
NEW

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 10/4/74
 Source Boilers

SO₂

REF(31) PS8-63 TAB IV
 & THE ENVIRONMENTAL REPORTER

REF(48) (UP TO & INCLUDING
 AUGUST '74 ADDITIONS)

$$\frac{5.817 \times 10^6 \text{ BTU}}{42 \frac{\text{gAC}}{\text{BTU}} \times 7.309 \frac{\text{#SO}_2}{\text{gAC}}} = 18,949 \text{ BTU/#}$$

REF(101) P 9.6 AVG OF DATA
 FOR #2 OIL, TAB 9-9

$$\frac{(0.005 \frac{\text{#SO}_2}{\text{gAC}})(2 \frac{\text{#SO}_2}{\text{#S}})(10^6)}{18,949 \frac{\text{BTU}}{\text{gAC}}} = 0.53 \frac{\text{#SO}_2}{10^6 \text{ BTU}}$$

1.06 %/BTU PER %

$$\frac{26.2 \times 10^6 \text{ BTU}}{2000 \frac{\text{#SO}_2}{\text{TON}}} = 13,100 \text{ BTU/#}$$

$$\frac{(.0200 \frac{\text{#SO}_2}{\text{gAC}})(2 \frac{\text{#SO}_2}{\text{#S}})(10^6)}{13,100} = 3.05 \frac{\text{#SO}_2}{10^6 \text{ BTU}} \quad 1.53 \%/\text{BTU PER \%}$$

Results were broken down into the following categories

Existing & New

>250 x 10⁶ & <250 x 10⁶

COAL & OIL

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 10/4/74
 Source Boilers

INDIVIDUAL WORK IS FOUND ON ATTACHED TABLES

For existing sources

Coal 1.971 #/ 10^6 BTU
 Oil 1.589 #/ 10^6 BTU } < 250

Coal 1.845 #/ 10^6 BTU
 Oil 1.451 #/ 10^6 BTU } > 250

For new sources

Coal 1.722 #/ 10^6 BTU
 Oil 1.303 #/ 10^6 BTU } < 250

Coal 1.013 #/ 10^6 BTU
 Oil 0.662 #/ 10^6 BTU } > 250

Because of NSPS, THE REGULATIONS OF THOSE STATES WHICH
 WERE GREATER THAN 1.2 (COAL) & 0.8 (OIL) WERE CONSIDERED
 TO BE 1.2 & 0.8, NOT THE STATED VALUES

IT IS NECESSARY TO SYNTHESIZE THE ES VALUES FOR COAL &
 OIL USING FUEL DISTRIBUTION

REF(73) p 5 TAB 1-1

ASSUME DATA FOR COMMERCIAL & INDUSTRIAL TO REPRESENT
 BOILER CAPACITIES < 250×10^6 & UTILITY TO REPRESENT BOILER
 CAPACITIES > 250×10^6

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 10/4/74
 Source Boilers

Heating values have been previously presented.

for $< 250 \times 10^6 \text{ BTU/HR}$

$$\begin{aligned} \text{TOTAL HEAT} &= (\text{COAL}) + (\text{RO}) \\ \text{VALUE} &= (26+84)(28.2 \times 10^6)(10^6) + (106+192)(10^6)(6.384 \times 10^6) \\ &\quad + (58+60)(10^6)(5.817 \times 10^6) + \text{GAS NOT TO BE INCLUDED} \\ &\quad \text{DO} \\ &= 2.882 \times 10^{15} + 1.902 \times 10^{15} + .686 \times 10^{15} = 5.47 \times 10^{15} \end{aligned}$$

% COAL = 53%
 % OIL = 47% } For boilers $< 250 \times 10^6$ using coal or oil

$$E_{S_{<250}} = (1.971)(.53) + (1.589)(.47) = 1.0446 + .7463$$

SOX
EXIST.

$$E_{S_{SOX\<250}} = 1.791 \frac{\text{#}}{10^6 \text{BTU}}$$

$$E_U_{<250} = .771$$

$$E_U_{>250} = 1.834$$

$$E_{S_{SOX\<250}} = (1.722)(.53) + (1.305)(.47) = .9127 + .6124$$

SOX
EXIST

$$E_{S_{SOX\<250}} = 1.525 \frac{\text{#}}{10^6 \text{BTU}}$$

$$E_U_{<250} = .771$$

$$E_U_{>250} = 1.834$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Huppel Date 10/7/74
 Source Boilers

For $>250 \times 10^6$ Btu/hr

$$\text{Total} = (971 \times 10^6)(26.2 \times 10^6) + (156 \times 10^6)(6.384 \times 10^6) + (2 \times 10^6)(5.817 \times 10^6)$$

SO₂ NO_x VAPOR

+ GAS NOT INCLUDED

$$= 7.100 \times 10^{15} + .9959 \times 10^{15} + .0116 \times 10^{15} = 8.108 \times 10^{15}$$

SO₂ NO_x VAPOR

$$\% \text{ SO}_2 = 87.6\%$$

$$\% \text{ NO}_x = 12.4\%$$

$$E_{S, >250} = 1.845(.876) + 1.451(.124) = 1.6162 + .1799$$

SO₂ NO_x EXIST

$$E_{S, >250} = 1.796 \times 10^6 \text{ Btu}$$

SO₂ NO_x EXIST

$$E_{S, >250} = (1.013)(.876) + (.662)(.124) = .8874 + .0821 = .9695$$

SO₂ NO_x NEW

$$E_{S, >250} = 0.970 \times 10^6 \text{ Btu}$$

SO₂ NO_x NEW

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hayes

Date 10/7/74

Source Boilers

NO_x

Ref 84 p 64-65 TAB xx

↓
Ref 148 (upto & including August '74 additions)

SEE ATTACHED TABLE FOR SUMMARY

NOT ALL STATES HAVE NO_x REGS FOR ALL FUELS FOR ALL SIZES FOR BOTH NEW & EXISTING

REGS FOR THOSE THAT DO HAVE BEEN SYNTHESIZED USING FUEL DISTRIBUTION DATA FROM REF 73 PS TAB 1-1. THESE IN TURN ARE ADDED TO THE PREVIOUSLY DET'D VALUE OF EU BY WEIGHTING ON A STRAIGHT LINE BASIS AS A FUNCTION OF # OF STATES W/ W/O REGS

FOR <250X10⁶ BTU/HR

$$\begin{aligned}
 \text{TOTAL} \\
 \text{HEAT} \\
 \text{VALUE} \\
 = & (26+84)(10^6)(26.2 \times 10^{-6}) + (106+92)(10^6)(6.384 \times 10^{-6}) + (58+80)(10^6)(5.817 \times 10^{-6}) \\
 & + (1.33+1.99)(10^{12})(1040) \\
 = & 2.882 \times 10^{15} + 1.902 \times 10^{15} + .686 \times 10^{15} + 3.453 \times 10^{15} = 8.923 \times 10^{15}
 \end{aligned}$$

COAL RO DO gns

% Coal = 32 %

% Oil = 29 %

% Gas = 39 %

FOR EXISTING <250 $E'_x = (.39)(.2182) + (.29)(.3) + (.32)(.7333)$

\downarrow
 $E'_x = .0251 + .0871 + .2347 = .3469$

$E'_{NO_x} = 0.4069 \% / 10^6 \text{ BTU}$ (28 CATEGORIES OUT OF 153) 63

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hager Date 10/7/74
 Source Boilers

VALUES OF EU FOR EACH SIZE CLASS HAVE PREVIOUSLY BEEN
 DET'D & SUMMARIZED ON P 29 OF THESE CALCS

$$(0.3 - 10) \times 10^6 \text{ BTU/HR}$$

$$E_{S_{NOX}} = \frac{(0.194)(153-28)}{153} + \frac{(0.4069)(28)}{153} = 0.1585 + .0745 = .233$$

0.3-10

$$E_{S_{NOX}} = 0.233 \text{ } \frac{\text{#}}{10^6 \text{ BTU}}$$

0.3-10
EXISTING

$$EU = 0.194 \frac{\text{#}}{10^6 \text{ BTU}}$$

$$E_{S_{NOX}} = \frac{(0.17)(153-28)}{153} + \frac{(0.4069)(28)}{153} = .3907 + .0745 = .4152$$

10-250

$$E_{S_{NOX}} = 0.415 \text{ } \frac{\text{#}}{10^6 \text{ BTU}}$$

10-250
EXISTING

FOR EXISTING > 250 X 10⁶

$$\begin{aligned} \text{Total Hour Value} &= (271 \times 10^6) / (26.2 \times 10^6) + ((56 \times 10^6) / (6.38 \times 10^6)) + (2 \times 10^6) / (5.817 \times 10^6) \\ &\quad + (2.76 \times 10^{12}) / (1040) \end{aligned}$$

$$\begin{aligned} &= 7.100 \times 10^{-5} + .9959 \times 10^{-5} + .016 \times 10^{-5} + 2.8701 \times 10^{-5} = 10.9779 \times 10^{-5} \end{aligned}$$

TRC - The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe
 Source Poilecs

Date 10/7/74

% Coal = 65%

% OIL = 9%

% GAS = 26%

For existing > 250

$$E_{S_{NOx}}' = (.2333)(.26) + (.3158)(.09) + (.7)(.65)$$

$$= .0607 + .0284 + .455 = .5441$$

$$E_{S_{NOx}}' = .5441 \quad (49 \text{ out of } 153 \text{ categories})$$

$$E_{S_{NOx}}' = (.5441)\left(\frac{49}{153}\right) + (.599)\left(\frac{153-49}{153}\right) = .1743 + .4072 = .5815$$

$$E_{S_{NOx}}' = 0.582 \text{ #/10^6 Btu}$$

> 250

84ST

For new < 250

$$E_{S_{NOx}}' = (.2133)(.39) + (.3000)(.29) + (.6950)(.32)$$

$$= .0832 + .087 + .2224 = .3926$$

$$E_{S_{NOx}}' = .3926 \quad (40 \text{ out of } 153 \text{ categories})$$

NEW

$$E_{S_{NOx}}' = (.3926)\left(\frac{40}{153}\right) + (.194)\left(\frac{153-40}{153}\right) = .1026 + .1433 = .2459$$

$$E_{S_{NOx}}' = 0.246 \text{ #/10^6 Btu}$$

.3-10.0
NEW

$$EU = .194 \text{ #/10^6 Btu}$$

65

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hegner Date 10/7/74

Source Boilers

$$\frac{E_{S_{NO_x}}}{10-250} = (0.3926) \left(\frac{40}{153} \right) + (.417) \left(\frac{153-40}{153} \right) = .1026 + .3079 = .4106$$

$$\frac{E_{S_{NO_x}}}{10-250} = 0.411 \text{ #/10^6 Btu}$$

NEW

In all cases, for new units greater than $250 \times 10^6 \text{ Btu/hr}$,
 NSPS will be in effect.

From Ref (147) p 4

$$E_{S_{gas}} = 0.2$$

$$E_{S_{oil}} = 0.3$$

$$E_{S_{coal}} = 0.7$$

From p 49 of these notes

$$\% \text{ Coal} = 65$$

$$\% \text{ oil} = 9$$

$$\% \text{ gas} = 26$$

$$\begin{aligned} E_{S_{NO_x}} &= (.65)(.7) + (.09)(.3) + (.26)(.2) = .455 + .027 + .052 \\ &> 250 \text{ NO}_x &= .534 \end{aligned}$$

$$\frac{E_{S_{NO_x}}}{> 250} = 0.534 \text{ #/10^6 Btu}$$

NEW

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Kappa Date 10/7/74
 Source Boilers

There are no SMRI reg's applicable to boilers for CO & H/C.

Assume, therefore, that $E_S = E_U$

	PARTICULATES		NO _X		H/C		SO _X		CO	
	EXIST	NEW	EXIST	NEW	EXIST	NEW	EXIST	NEW	EXIST	NEW
Resid.	.039	.039	.081	.081	.019	.019	.107	.107	.026	.026
0.3-10.0	.480*	.428*	.233*	.246*	.042	.042	1.791*	1.525*	.051	.051
10-250	.383	.334	.415	.411	.045	.045	1.791	1.525	.110	.110
>250	.277	.100	.582	.534	.019	.019	1.796	.970	.024	.024

* These values of E_S are greater than the values of E_U . This difference is probably due to the relative breakdowns of fuel types.

This size category uses a substantial percentage of natural gas which generally results in lower uncontrolled emissions of part., NO_X & SO_X than do oil & coal. It is oil & coal that most fuel burning reg's apply to.

Therefore, the summary below will replace the values within the 0.3-10.0 MBTU/HR category. They are the E_U values.

PART.	NO _X	H/C	SO _X	CO
0.3-10.0	.250	.194	.194	.042

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoyer Date 1/22/75
 Source Boilers

Fluorides - EU

Although coal contains only 0.01% (wt) Fluorine (Ref 234)
 p 3-30, its use in large quantities results in an appreciable annual
 emission.

Ref 234 p 3-131 gives an emission factor of $0.16 \text{ lb}/\text{ton}_{\text{coal}}$

For a heating value of $26.2 \times 10^6 \text{ BTU}/\text{ton}$

$$\text{EU}_{F^-} = \frac{0.16 \text{ lb/ton}}{26.2 \times 10^6 \text{ BTU}/\text{ton}} = 0.00611 \text{ lb}/10^6 \text{ BTU}$$

For small units $< 0.3 \times 10^6 \text{ BTU/hr}$, no coal is used; \therefore no F⁻ emissions
 From p 4 of these tables, the % coal for firetube boilers is 11.6%

$$\text{EU}_{F^-_{FT}} = (.116)(.00611) = 0.000709 \text{ lb}/10^6 \text{ BTU} *$$

From p 9, the % coal for cast iron boilers = 14.9%

$$\text{EU}_{F^-_{CI}} = (.149)(.00611) = 0.000910 \text{ lb}/10^6 \text{ BTU} *$$

From p 12, 16, 20, 23 the following % coal were shown

WT-1, 2, 3, - 52.7%

WT-4 — 64.7%

$$\text{EU}_{F^-_{WT-1,2,3}} = (.527)(.00611) = 0.00322 \text{ lb}/10^6 \text{ BTU} *$$

$$\text{EU}_{F^-_{WT-4}} = (.647)(.00611) = 0.00395 \text{ lb}/10^6 \text{ BTU} *$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 1/22/75
 Source Boilers

The breakdown of boiler types & heat input ranges are from pages 25-27 of these cat's.

$$\begin{aligned} EU_{F^-} &= (.4822)(.000910) + (.5178)(.000709) \\ &= .0004388 + .0003671 = 0.000806 \end{aligned}$$

$$EU_{F^-} = 0.000806 \frac{\text{lb}}{10^6 \text{ BTU}}$$

$$EU_{F^-} = (.5833)(.00322) + (.4167)(.00322)$$

$$EU_{F^-} = 0.00322 \frac{\text{lb}}{10^6 \text{ BTU}}$$

$$\begin{aligned} EU_{F^-} &= (.1718)(.00322) + (.8282)(.00395) \\ &= .0005531 + .0032713 = 0.00382 \end{aligned}$$

$$EU_{F^-} = 0.00382 \frac{\text{lb}}{10^6 \text{ BTU}}$$

EN From pages 36-39 of these cat's, the synthesized "η" for control for each boiler size is given for SOx control from fuel switching (<250) & alkaline scrubbing (>250). We will use these same η's for HF(gaseous) control, since the fluoride

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoyer Date 1/22/75
 Source Boilers

emission is gaseous.

$$\text{ENF}^- = \frac{(1 - .732)(0.000806)}{.3-10} = 0.000216$$

$$\text{ENF}^- = 0.000216 \text{ lb}/10^6 \text{ BTU}$$

$$\text{ENF}^- = \frac{(1 - .859)(.00322)}{10-250} = 0.000454$$

$$\text{ENF}^- = 0.000454 \text{ lb}/10^6 \text{ BTU}$$

$$\text{ENF}^- = \frac{(1 - .938)(0.00382)}{>250} = 0.000237$$

$$\text{ENF}^- = 0.000237 \text{ lb}/10^6 \text{ BTU}$$

E_s

Since there are no regs for fluorine emissions from boilers
 $E_s = E_u$.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 1/22/75
 Source Boilers

Summary Of Thoride Emission Factors

	<u>Eu</u>	<u>En</u>	<u>Es</u>
0.3-10	.000806	.000216	.000806
10-250	.00322	.000454	.00322
>250	.00382	.000237	.00382

Trace Metals

TRACE METALS will include

Arsenic, Beryllium, Cadmium, Manganese, Mercury, Nickel & Vanadium
 All emission factors (Eu) are from Ref(23). They are summarized as follows:

	<u>Coal (#/1000tons)</u>	<u>Oil (#/1000gals)</u>
Arsenic	3.0	.001
Beryllium	.03	.2
Cadmium	1.0	.03
Manganese	80.0	.001
Mercury	.40	.0004
Nickel	3.0	.3
Vanadium	.50	.2
<hr/>		
TOTAL	87.93 #/1000tons	0.7324 #/1000gals

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By _____ Date _____
 Source _____

For 1 GALL NV = $26.2 \times 10^6 \text{ BTU/ton}$ & on oil (avg of 40 & 60) of

$$\frac{\left(6.384 \times 10^6 \frac{\text{BTU}}{\text{gal}} + 5.817 \times 10^6 \frac{\text{BTU}}{\text{gal}} \right)}{(2)(42 \text{ gal/sec})} = 145,250 \frac{\text{BTU}}{\text{gal}}$$

$$E_{UTM} = \frac{87.93 \times 10^{-3}}{26.2 \times 10^6} = 0.00336 \frac{\text{lb}}{10^6 \text{ BTU}} *$$

$$E_{UTM} = \frac{0.7324 \times 10^{-3}}{145,250} = 0.00504 \frac{\text{lb}}{10^6 \text{ BTU}} *$$

We will go thru an analysis similar to that for fluorides using info previously developed in these calc's.

Residential ($<.3 \times 10^6 \text{ BTU/AC}$)

38.7% oil

$$E_{UTM} = (.387)(.00504) = .00195$$

$$E_{UTM} = 0.00195 \frac{\text{lb}}{10^6 \text{ BTU}}$$

FIRETUBE

11.6% COAL
 41.4% OIL

$$E_{UTM} = (.116)(.00336) + (.414)(.00504) = .00039 + .00209$$

$$E_{UTM} = 0.00248 *$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 1/22/75

Source Boilers

Cast Iron

14.9% coke

29.6% oil

$$E_{UTM} = (.149)(.00336) + (.296)(.00504) = .000501 + .00149$$

$$E_{UTM} = 0.00199 \text{ lb}/10^6 \text{ Btu}$$

*

WT-1,2,3

% COKE = 52.7%

% OIL = 30.1%

$$E_{UTM} = (.527)(.00336) + (.301)(.00504)$$

$$= .00177 + .00101 =$$

$$E_{UTM} = .00278 \text{ lb}/10^6 \text{ Btu}$$

*

WT-4

64.9% coal

9.2% oil

$$E_{UTM} = (.647)(.00336) + (.092)(.00504) = .002174 + .000464$$

$$E_{UTM} = 0.00264 \text{ lb}/10^6 \text{ Btu}$$

*

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hamer Date 1/22/75

Source Boilers

$$E_{UTM} = (.4122)(.00199) + (.5178)(.00248) = .00096 + .00128$$

$$E_{UTM} = 0.00224 \text{ lb}/10^6 \text{ BTU}$$

$$E_{UTM} = 0.00278 \text{ lb}/10^6 \text{ BTU}$$

$$E_{UTM} = (.1718)(.00278) + (.8282)(.00264) = .000478 + .00219$$

$$E_{UTM} = 0.00267 \text{ lb}/10^6 \text{ BTU}$$

EN

for Since there are no particulate control methods demonstrated
 residential units, we will assume (as for particulates)

$$E_{NTM} = 0.0$$

For units 0.3-10.0, fuel switching was the control method.
 The effective control "n" for units this size (part.), is 80.7%

$$E_{NTM} = (1 - .807)(.00224) = 0.00043 \text{ lb}/10^6 \text{ BTU}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 1/22/75

Source Bikes

$$E_{N_{TM}} = 0.00043 \text{ lb/10}^6 \text{ BTU}$$

$$E_{N_{10-250}} = (1 - .937)(.00278) = 0.000175 \quad (\text{fuel switching})$$

$$E_{N_{TM}} = 0.00018 \text{ lb/10}^6 \text{ BTU}$$

For units > 250, an ESP was used to control particulate which would also control trace metals.

$$\left(\frac{.05}{3.11}\right)(.00267) = .00004$$

$$E_{N_{TM}} = 0.00004$$

E_S

Although there are no regs for trace metals, the control of particulate will control TM's defacts. We will, ∴, use the E_S for particulate & its relationship to EU to get an E_S for TM's.

Since there are essentially no regs for residential units, $E_S = EU$

$$E_{S_{TM}} = 0.00195 \text{ lb/10}^6 \text{ BTU}$$

For units 0.3-10, E_S was greater than EU; ∴, $E_S = EU$

$$E_{S_{TM}} = 0.00224 \text{ lb/10}^6 \text{ BTU}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 1/22/75

Source Boilers

$$\frac{E_{sp}}{10-250 \text{ EXIT}} = .383$$

$$\frac{.383}{2.018} = \frac{x}{.00278} \quad x = 0.00053$$

$$E_{up} = 2.018$$

$$E_{STM} = 0.00053 \text{ lb}/10^6 \text{ Btu}$$

$$\frac{E_{sp}}{10-250 \text{ NEW}} = .334$$

$$\frac{.334}{2.018} = \frac{x}{.00278} \quad x = 0.00046$$

$$E_{STM} = 0.00046 \text{ lb}/10^6 \text{ Btu}$$

$$\frac{E_{sp}}{>250 \text{ EXIT}} = 0.277$$

$$\frac{.277}{3.110} = \frac{x}{.00267} \quad x = 0.00024$$

$$E_{up} = 3.110$$

$$E_{STM} = 0.00024 \text{ lb}/10^6 \text{ Btu}$$

$$\frac{E_{sp}}{>250 \text{ NEW}} = 0.144$$

$$\frac{.144}{3.11} = \frac{x}{.00267} \quad x = 0.00009$$

$$E_{STM} = 0.00009 \text{ lb}/10^6 \text{ Btu}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 1/22/75

Source Boilers

Summary Of Trace Metal Emission Factors

	<u>E_u</u>	<u>E_N</u>	<u>$E_{S_{GALT}}$</u>	<u>$E_{S_{NEW}}$</u>
<0.3	.00195	0.0	.00195	—
.3 - 10.0	.00224	.00043	.00224	—
10.0 - 250	.00278	.00018	.00053	.00046
> 250	.00267	.00004	.00024	.00009

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Harper Date 1/22/75
 Source Boilers

$E_{III(d)}$

For units $< 250 \times 10^6 \text{ Btu/hr}$, the control technique was fuel switching which can be accomplished for existing sources.
 THEREFORE, $E_{III(d)}$ for TM's & Fluorides is equal to E_N .

$$E_{III(d)}_{TM} = E_N_{TM} \quad \text{for } < 250 \times 10^6$$

However, for units $> 250 \times 10^6 \text{ Btu}$, Alkaline scrubbing was the control technique. THIS IS NON-AMENABLE TO RETROFIT ON EXISTING INSTALLATIONS. Therefore, $E_{III(d)}$ for Fluorides is equal to $E_{existing}$

$$E_{III(d)}_{F^-} = E_{existing} \quad > 250 \times 10^6$$

An ESP could conceivably be retrofitted to an existing installation; ∴ $E_{III(d)}$ for TM's is equal to E_N for TM

$$E_{III(d)}_{TM} = E_N_{TM} \quad \text{for } > 250 \times 10^6$$

Particulate Regs. - Fuel Burning

^{100c Btu}

	0.3-10.0 mg/ft ³	For 100 mmole/hr	>250 mg Btu/ft ³
Alabama	0.5 (avg)	.27 (avg); .21 (avg)	.12
Alaska	0.1 (avg, burning)	.1 (avg)	.10
Arizona	0.6	.2 (avg)	.28 (avg)
Arkansas	0.25 (avg); no avg	2.0 (avg)	3.1 (avg) no avg
Colorado			
California	0.32 (avg)	.15	.10
Conn.	0.20 (avg); 0.1 (new)	.17 (avg); 0.1 (new)	.20 (avg); .10 (new)
Dakota	0.30	.25	.30
D.C.	0.12	.07	.08
Florida	burned oil (avg)	no avg	.10
Georgia	0.7 (avg); 0.5 (new)	0.7 (avg)	.21 (avg); .10 (new)
Hawaii	0.6	.6	.6
Idaho	0.6	no avg (burning)	.12
Illinois	0.1 (burning)	.1	.1
Iowa	0.6	.8 (avg); .1 (new)	.2
Kansas	0.6	.2 (avg)	.8 (avg); .6 (new)
Kentucky	0.75 (avg); 0.45 (new)	.44 (avg); .21 (new)	.15 (avg); .10 (new)
Louisiana	0.6	.6	.6
Maine	0.6	.2	.3
Maryland	0.6	.25	.15 (avg)
Mass.	0.15 (avg); 0.17 (new)	.16 (avg); .10 (new)	.21 (avg); .1 (new)
Michigan	0.10 (avg); 0.12 (new)		
Miss.,	0.6	.6 (avg); .4 (new)	.6 (avg); .4 (new)
Miss.	0.6	.21	.21 (avg)
Missouri	0.6	.38 (avg)	.16 (avg)
Montana	0.6	.10 (avg); .25 (new)	.22 (avg); .2 (new)
Nebraska	0.6	.25	.15 (avg)
Nevada	0.6	.25	.11 (avg)
N. Dakota	0.6	.13 (avg); .37 (avg, new)	.23 (avg)
N.J.	0.6	.24 (avg)	.10
N.J.	0.6	.40 (avg)	.15
New York	.35 (avg); 0.1 (new)	.03 (avg); .10 (new)	.10
S. Carolina	0.6	.33	.13
S. Dakota	0.3 (avg); 0.3 (new)	.46	.25
Ohio	.5 (avg)	.2	.10

PART

Oklahoma	.6	.35	.13
Dregon	.33(exist); .17(new)	.33(exist); .17(new)	.33(exist); .17(new)
Penn.	0.4	.25(Avg)	.18(Avg)
R.I.	Conserve not replaceable	Save conserv.	Same comment
S. Carolina	.6	.6	not applicable
S. Dakota	.3	.3	.3
Tennessee	.6	.34(exist); .2 (new)	.18(funding); .1 (new)
Texas	.2 (avg)	.2 (avg)	.2 avg
Utah	Conserve not waste	Same comment	Same comment
Vermont	.5	.3	.1
Virginia	.4	.4	.1
Washington	.33(exist); .17(new)	.33(exist); .17(new)	.33(exist); .17(new)
W. Virginia	.10 (avg)	.10 avg	.10 (avg)
Wisconsin	.35(exist,new); .5 (new)	.15	.10
W. Virgin	.6 (exist); .1 (new)	.11 (exist); .1 (new)	.21 (exist); .1 (new)
	.420 (exist); .428 (new)	.383 (exist); .339 (new)	.277 (exist); .248 (new)

- ① Where new installations are not specifically noted, max rate is the same as existing.
- ② Many states have $E_s > 0.20$. Therefore, E_{avg} must be calculated assuming that 0.2 (new) will exist for those states whose present avg is > 0.2 . Those which are < 0.20 will remain in effect. $6.53/10 = 0.101 \text{ /m}^2 \text{ sec}$.
- ③ $E_{avg} = \text{Avg of Pct. within } E_s \text{ size category}$
- ④ Arkansas has no avg - a unique controller

**Summary of
NDx Rigs - Fuel Burning
*10⁶ BTU**

	Estimate						Actual		
	<250	250-500	500-1000	1000-2000	2000-3000	>3000	<250	250-500	500-1000
Ala									
Alask									
Ansg	.2	.3	.7	.7	.3	.7	.2	.3	.7
AK									
Color.									
CAL									
CA.	.2	.3	.9	.2	.3	.7	.2	.3	.7
CO									
DC									
FLA									
GA									
Hawa									
Tex									
IL									
IN									
Iowa									
Kans									
KY									
LA									
Maine									
Md									
Mass									
Mich									
Minn									
Miss									
Mo									
Mont									
Nev									
NH									
NJ									
NY	.3	.3	.7	.2	.3	.7	.2	.3	.7
PA	.2	.3	.7	.2	.3	.7	.2	.3	.7
NC									
ND									
Ohio									

10x

	F				M				N			
	100	200	300	400	100	200	300	400	100	200	300	400
Ordn.	6	0	C	G	0	C	G	0	C	G	0	C
Oreg.	.2	.3	.7	.2	.3	.7	.2	.3	.7	.2	.3	.7
Penn	.3	.5		.3	.5		.3	.5		.3	.5	
RI	.2	.3		.2	.3		.2	.3		.2	.3	
S.C												
SD	.2	.5		.2	.5		.2	.5		.2	.5	
Tenn	.2	.3	.7	.2	.3	.7	.2	.3	.7	.2	.3	.7
Tex												
W.L												
Vt												
VA												
Wash.												
W. Va												
Wisc												
Wyo.	.2	0		.2	0		.2	0		.2	0	
	<u>2.4</u>	<u>3.2</u>	<u>4.4</u>	<u>4.2</u>	<u>3.2</u>	<u>5.4</u>	<u>4.2</u>	<u>5.4</u>	<u>4.5</u>	<u>5.75</u>	<u>6.1</u>	<u>6.7</u>
	<u>11</u>	<u>11</u>	<u>10</u>	<u>13</u>	<u>11</u>	<u>12</u>	<u>11</u>	<u>12</u>	<u>10</u>	<u>10</u>	<u>12</u>	<u>11</u>
	<u>B</u>	<u>B</u>	<u>"</u>	<u>"</u>	<u>"</u>							
	2182	2201	2232	2233	2234	2235	2236	2237	2238	2239	2240	2241

~~summa~~
Regs - Fuel Burning
/ 10⁶ STU

	Estimate US				New US			
	<25'	>25'	<25'	>25'	Gas	Oil	Gas	Oil
COAL								
Ala	1.35	1.35	1.35	1.35	1.2	1.2	1.2	1.2
Akron	1.0						0	
Ariz								
Ark								
Colar.	0.3							
Cal								
Ct	.77	.53	.77	.53	.77	.53	.77	.53
Del	.46	.32	.46	.32	.46	.32	.46	.32
DC	.77	.53	.77	.53	.77	.53	.77	.53
Fla	1.00	1.77	1.5	1.1	1.00	1.77	1.2	.8
GA	3.82	2.65	4.59	3.18	1.2	.8	1.2	.8
Haw	3.05	3.05	.53	.43	3.05	3.05	.53	.53
Id							0	
IL	1.8	.65	1.8	.65	1.8	.65	1.2	.55
Incl.							0	
Iowa	5.0	1.5	6.0	1.5	6.0	1.5	5.0	1.5
Kans.	1.99	1.87	1.5	1.5	1.97	1.87	1.5	1.5
Ky	3.2	2.05	2.37	1.56	3.2	2.05	2.37	1.56
LA								
Maine	3.52	2.00	3.52	2.00	3.52	2.00	3.52	2.00
Md	1.53	.43	1.53	.43	1.53	.43	1.53	.43
MASS.	.77	.38	.77	.38	.77	.38	.77	.38
Mich	2.8	1.95	2.8	1.95	2.8	1.95	2.8	1.95
Minn	3.05	2.12	3.05	2.12	2.75	2.12	3.05	2.12
Miss	4.8				2.4		4	0
No.	2.15				1.41		4	0
Mont	2.0						2	0
NJcb								
Nev	1.06	→ 2.5	→ 1.06	→ 2.5	1	0	0	
NH	2.0	.83	2.0	.83	1.0	.83	1.0	.83
NJ	0.3							
NM	1.99	1.07	.34	.34	1.07	1.07	.34	.34
NY	.4	.11	.4	.11	.4	.11	.4	.11
NC	2.3				1.6		2	0
ND	3.0						2	0

Ground level
Ground level

New York, publication

Incl.

Due to NSPS

* 1.2

0 0.8

Ground level

SiO_2

	Existing Es				New Es			
	<250		>250		<250		>250	
	Gas	Oil	Gas	Oil	Gas	Oil	Gas	Oil
Ohio	2.0	2.7	1.0	1.0	1.0			
OKL					2.0	2.3	2.0	2.0
Orng	1.16	1.11	1.2	.8	1.0	1.0	1.2	.8
Penn	.46	.27	.16	.27	.16	.21	.16	.27
RI	1.53	1.06	1.53	1.06	1.53	1.06	1.53	1.06
SC	2.0							
SD	3.0							
Tenn								
Tex								
Utah	1.53	1.07	1.53	1.07	1.53	1.50	1.53*	1.57*
WV	1.53	1.06	1.53	1.06	1.53	1.06	1.53	1.06
VA								
Wash	1.5							
Wisc	1.53	.53	1.53	.53	1.53	.53	1.53*	.53
Wyoming	1.99				1.7	.58	1.2	.5
	1.99						*	*
R&R3	25.16	75.45	52.07		72.32	51.73	42.56	11.82
41	41	41	41		42	42	42	42
"	"	"	"		"	"	"	"
	1.971	1.577	1.845	1.451	1.722	1.203	1.013	0.662

Doktorate

外 1.2
内 0.8

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 · New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hopper Date 1/3/75

Source MIXED FUEL BOILERS

For the purpose of this study, we will define mixed fuel boilers as those which simultaneously burn fossil fuel & municipal refuse for the purpose of generating steam. This decision is made for the following reasons:

- (1) THIS "INDUSTRY" HAS THE POTENTIAL FOR RAPID GROWTH IN THE IMMEDIATE FUTURE
- (2) THE ANALYSIS OF "FOSSIL FUELED BOILERS" WAS BASED ON FUEL USAGE &, THEREFORE, CONDENS EMISSIONS FROM ANY COMBINATION OF THESE.
- (3) THE COMBUSTION OF PROCESS GAS WAS COVERED UNDER PETROLEUM REFINERIES & ANY COMBINATION WITH NATURAL GAS WOULD HAVE BEEN COVERED UNDER NOTE (2) ABOVE.
- (4) ANY COMBINATION OF WOOD WASTE AND AN AUXILIARY FUEL IS COVERED UNDER WOOD WASTE BOILERS & NOTE (2) ABOVE.

REF (349) p 7ff tab 1 Gives Existing & Projected 1980 capacity. Summarizing in TPD

<u>COAL + OIL</u>	<u>Oil + Ref</u>
3000	300
1500	300
900	1500
1000	3000
1400	17
1500	1150
1400	1000
1000	1000
(600)	700
2000	1400
6000	1000
750	1350
950	200
1000	1250
640	1100
	1750
	1100
<hr/>	
$\Sigma = 10,051$	
	$\Sigma = 11,810$

where COAL OR OIL WERE OPTIONAL, COAL WAS CHOSEN

() = EXISTING

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 1/3/75

Source Mixed Fuel Boilers

Presently, there is only one combined - fired unit - St Louis (Mechanick)
 This is rated @ 600 TPD. The values are to be considered as
 "speculation only" (ref (249) p 7)

$$40,057 + 11,810 = 51,867 \text{ TPD in 1980}$$

Assuming simple growth between 1975 & 1980

$$\frac{51,867}{5} = 10,373 \text{ TPD/yr}$$

If 1975 Capacity is assumed to be 600 TPD, then

$$P_c = \frac{10,373}{600} = 17.29 !$$

The emission factors phenomenal value is due to the low baseline
 YEAR CAPACITY.

$$P_c = 17.29 \quad \text{simple}$$

$$A = (600)(5)(52) = 156,000 \text{ TPY}$$

Assumes that refuse is
 collected 5 days per week

$$A = 0.156 \times 10^6 \text{ tons refuse burned}$$

SEE PAGE 3

Since these will all be new units, it is assumed that replacement
 will not occur before 1985.

$$P_B = 0$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hopper Date 1/3/75

Source Mixed Fuel Boilers

We will assume a K equal to that for boilers. Since most new units will exceed $1000 \times 10^6 \text{ BRU/HR}$, we will use the K developed for boilers $> 250 \times 10^6 \text{ BRU/HR}$. (see "INDUSTRIAL FACTORS - FOSSIL-FUELED BOILERS")

$$K = 0.58$$

Since emissions/contract/args differ for coal & oil, A must be broken down

$$\% \text{ Coal} = \frac{40,057}{51867} = 77\%$$

$$\% \text{ oil} = \frac{11,810}{51867} = 23\%$$

Assuming that this same breakdown holds in 1985

$$A_{\text{Coal Refuse}} = (.77)(.156 \times 10^6) = 0.120 \times 10^6$$

$$A_{\text{Coal Refuse}} = 0.120 \times 10^6 \text{ tons Refuse}$$

$$A_{\text{oil Refuse}} = (.23)(.156 \times 10^6) = 0.036 \times 10^6$$

$$A_{\text{oil Refuse}} = 0.036 \times 10^6 \text{ tons Refuse}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By HORRER Date 1/3/75

Source Mixed Fuel Boilers

For the purpose of developing emission factors, we will assume that 20% of the heat input is supplied by refuse & the remaining 80% either coal or oil.

PARTICULARE

COAL + REFUSE

$$EU = f(7.32 \times 10^{-6} \text{ BTU})$$

Ref (249) p 79 TAB 13

We must now convert this to $\text{lb}/\text{TON}_{\text{REFUSE}}$

Ref (249) p 24

$$5000 \text{ BTU}/\text{lb}_{\text{REFUSE}}$$

$$\left(\frac{\text{LB}}{\text{BTU TOTAL}} \right) \left(\frac{\text{BTU TOTAL}}{\text{TON WASTE}} \right) = \text{lb/TON WASTE}$$

$$\left(\frac{\text{BTU TOTAL}}{\text{TON WASTE}} \right) =$$

$$5000 \frac{\text{BTU}}{\text{lb}} \times 2000 \frac{\text{BTU}}{\text{TON REF}} = 10 \times 10^6 \frac{\text{BTU}}{\text{TON REF}}$$

$$\frac{10 \times 10^6}{0.2} = \frac{\text{TOTAL BTU}}{\text{TON REF}} = 50 \times 10^6 \frac{\text{BTU TOTAL}}{\text{TON REF}}$$

$$(7.32 \times 10^{-6})(50 \times 10^6) =$$

$$EUP_{\text{COAL}} = 366 \frac{\text{lb}}{\text{TON}_{\text{REFUSE}}}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 1/3/75
 Source Mixed Fuel Boilers

Ref 249 p 94-112 indicates that ESP efficiencies = 99%
 are possible by adding surface area to existing designs.
 With this assumption

$$E_{N_p} = \frac{(1-.99)(366)}{coal} = 3.66 \text{ lb/ton refuse}$$

$$E_{N_p} = 3.66 \text{ lb/ton refuse}$$

Since all units will be new units & assuming that NSPS
 reqs for boilers > 250 kton/hr apply (& NOT NSPS for incinerators)

$$E_s = f(0.1 \text{ %})$$

Converting

$$E_{S_p} = \frac{(0.1 \times 10^{-6})(50 \times 10^6)}{coal} = 5.0$$

$$E_{S_p} = 5.0 \text{ lb/ton refuse}$$

Oil & Refuse

Ref 249 p 88 tab 1B

$$E_U = f(2.03 \text{ %})$$

Converting,

$$E_U = \frac{(2.03 \times 10^{-6})(50 \times 10^6)}{oil} = 101.5$$

$$E_{U_p} = 101.5 \text{ lb/ton refuse}$$

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 1/6/75

Source Mixed Fuel Boilers

Using the same ESP efficiency as for coal & refuse,

$$E_N = (1 - .99) / (101.5) = 1.02$$

$$E_{N_{\text{oil}}} = 1.02 \text{ lb/ton refuse}$$

The Es for oil from new boiler units $> 250 \times 10^6 \text{ Btu/hr}$ is

$$E_s = f(.1 * 10^6 \text{ Btu}) \quad (\text{Same as coal})$$

$$E_{s_{\text{oil}}} = 5.0 \text{ lb/ton refuse}$$

NO_x

Coal & Refuse

From Ref (249) p 79 TAB 13

$$E_U = f(.75 \text{ lb}/10^6 \text{ Btu})$$

Converting

$$E_U = (.75 \times 10^{-6}) / (50 \times 10^6) = 37.5 \text{ lb/ton refuse}$$

$$E_{U_{NO_x}} = 37.5 \text{ lb/ton refuse}$$

Ref (249) p 115 TAB 24

$E_{N_{NO_x}} = f(\eta = 60\%)$ Using flue gas recirculation
& off stoichiometric (oil + refuse) combustion

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 1/6/75

Source Mixed Fuel Boilers

Assuming that a similar reduction can be realized for coal & refuse,

$$E_N = 37.5(1-.6) = 15.0$$

$$E_{N_{NO_x}} = 15.0 \text{ lb/ton refuse}$$

The NSPS, NO_x reg for coal = 0.7 lb/ton oil

Converting

$$E_S = (.7)(50) = 35.0$$

$$E_{S_{NO_x}} = 35.0 \text{ lb/ton refuse}$$

Oil & Refuse

Ref 249 pgs TAB 18

$$E_U = f(.69 \text{ lb/ton oil})$$

Converting

$$E_U = (.69)(50) = 34.5$$

$$E_{U_{NO_x}} = 34.5 \text{ lb/ton refuse}$$

As mentioned on pg 3 of these calc's, $f = 60\%$

$$E_N = (1-.6)(34.5) = 13.8$$

$$E_{N_{NO_x}} = 13.8 \text{ lb/ton refuse}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 1/6/75
 Source Mixed Fuel Boilers

The NO_x NSPS for oil is 0.3 $\text{LB}/10^6 \text{ BTU}$

Converting

$$E_S = (.3)(50) = 15.0$$

$$E_{S_{NO_x}} = 15.0 \text{ LB/Ton refuse}$$

SO_x

Coal & Refuse

Ref (249) p 79 TAB 13

$$E_U = f(4.48 \text{ LB}/10^6 \text{ BTU})$$

Converting

$$E_U = (4.48)(50) = 224$$

$$E_{U_{SO_x}} = 224 \text{ LB/Ton refuse}$$

If a lime/limestone scrubbing system is employed, efficiencies between 70% & 90% can be expected (Ref (249) p 106)

Assuming the avg of 80%

$$E_{NSO_x} = (1-.20)(224) = 179.2$$

$$E_{NSO_x} = 179.2 \text{ LB/Ton refuse}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hager Date 1/6/75

Source Mixed Fuel Boilers

The NSPS reg for SO_x from coal-fired boilers = 1.2 %/ton

Converting

$$E_S = 1.2(50) = 60$$

$$E_{SO_x} = 60 \text{ lb/ton}$$

coal refuse

Oil & Refuse

Ref 247 P 23 TAB 13

$$E_U = f(.41 \% \text{ SRV})$$

Converting,

$$E_U = (.41)(50) = 20.5$$

$$E_{SO_x} = 20.5 \text{ lb/ton}$$

oil refuse

The use of low sulfur oil will certainly reduce SO_x emissions. However, it is technically feasible to employ a lime/limestone scrubber. We will assume the same % as the one chosen for the coal analysis, 80%.

$$E_{SO_x} = 20.5(1-.2) = 4.1$$

$$E_{SO_x} = 4.1 \text{ lb/ton}$$

oil refuse

The NSPS reg for SO_x for oil-fired units = 0.8 %/ton

Converting, Since this is greater than EU, $E_S = E_U$

$$(0.8)(50) = 40$$

$$E_{SO_x} = 40 \text{ lb/ton}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 1/6/74
 Source Mixed Fuel Boilers

<u>Summary</u>	<u>COAL & REFUSE</u>			<u>oil & refuse</u>		
	<u>E_U</u>	<u>E_N</u>	<u>E_S</u>	<u>E_U</u>	<u>E_N</u>	<u>E_S</u>
P _T	3660.0	3.66	5.0	101.5	1.02	5.0
NO _x	37.5	15.0	35.0	34.5	13.8	15.0
SO _x	224.0	44.8	60.0	20.5	4.1	20.5

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By K. Tower Date 1/29/75

Source Wood Boilers

Wood boilers are used for wood waste which is mainly associated with the pulp + paper industry where refuse results from the separation of bark from the logs and the lumber industry where it appears mainly as shavings, sawdust and bark. (Ref 236, p II-60).

From ref. 043, p. 321 we make the assumption that the average bark boiler size is 300,000 lb/hr steam. Ref 073, p A-4,5 states there are 975 BTU/lb steam/efficiency of boiler. From ref 073, p. A-16, Table A-3 we assume the average efficiency of a wood boiler is 80%.

From these data we can calculate the capacity of an average wood waste boiler as follows:

$$\text{Capacity} = \frac{(975 \frac{\text{BTU}}{\text{lb}})(300,000 \frac{\text{lb}}{\text{hr}})}{.8} = 365.6 \frac{\text{BTU}}{\text{HR}}$$

From the Boiler Industrial Factors data sheets, p. 15 we find that this size boiler will have a fractional utilization rate of 0.58 and a $P_B = .05$ simple.

$$K = .58$$

$$P_B = .05$$

simple

We make the assumption that the growth rate of wood boilers to be the same as that of the wood pulping industry, which is .012 compound. However, it should be noted that this number may be slightly low since more industries may find it economically feasible to use wood wastes as a fuel source.

$$P_C = .012$$

compound

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By K.Tower Date 1/29/75

Source Wood Boilers

Ref 048, p. 280 gives the total process emissions from bark boilers of the pulp mill industry to be 734,400 TONS/YR. Ref 075, p. 1.6-2, Table 1.6-1 gives an emission factor of 25-30 $\frac{\text{lbs}}{\text{TON}}$ for bark boilers. We will assume 27.5 $\frac{\text{lbs}}{\text{TON}}$. We will also assume that the pulp mill industry operates 60% of all wood boilers. Therefore production in 1970 can be calculated as follows:

$$\text{Production}_{1970} = \frac{(734,400 \frac{\text{TONS}}{\text{YR}}) (2000 \frac{\text{lbs}}{\text{TON}})}{(27.5 \frac{\text{lbs}}{\text{TON}})(0.60)} = 89.0 \times 10^6 \frac{\text{TONS}}{\text{YR}}$$

From this information we can calculate 1975 Production as follows:

$$\begin{aligned} P_{1975} &= P_{1970} (1 + P_c) \\ &= (89.0 \times 10^6 \frac{\text{TONS}}{\text{YR}}) (1 + .012)^5 \end{aligned}$$

$$P_{1975} = 94.5 \times 10^6 \frac{\text{TONS}}{\text{YR}}$$

$$A = \frac{\text{Prod}_{1975}}{K} = \frac{94.5 \times 10^6 \frac{\text{TONS}}{\text{YR}}}{.58} = 162.9 \times 10^6 \frac{\text{TONS}}{\text{YR}}$$

$$A = 162.9 \times 10^6 \frac{\text{TONS}}{\text{YR}}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By K.Tower Date 1/29/75
 Source Wood Boilers

As previously mentioned ref 075, p. I.6-2, Table I.6-1 gives an uncontrolled emission factor of 25 to 30 lbs/TON . We assume a $27.5 \text{ lbs}/\text{TON}$ factor.

$$E_u = 27.5 \frac{\text{lbs}}{\text{TON}}$$

The best method of controlling these emissions would be with a baghouse filter (Ref 236, p. II-60) We will assume a 99% efficiency.

$$E_N = 27.5 \frac{\text{lbs}}{\text{TON}} \times .01 = .275 \frac{\text{lbs}}{\text{TON}}$$

$$E_N = 0.28 \frac{\text{lbs}}{\text{TON}}$$

Since we could not obtain an accurate geographical distribution of wood boiler we obtain E_s from the general process weight curve. (Ref 084, Ref 148) Assuming an average process weight rate of $300,000 \text{ lbs}/\text{hr}$ (as previously referenced) the allowable emissions $= 52 \text{ lbs}/\text{HR}$.

Ref 043, p.34) gives a process weight bark feed lb/hr wet (45% moisture) for a $300,000 \text{ lbs}/\text{hr}$ bark boiler as $63,000 \text{ lb}/\text{hr}$. This rating in units of $\frac{\text{TONS}}{\text{HR}}$ can be calculated as follows.

$$\frac{\text{TONS}}{\text{HR}} = \frac{(63,000 \frac{\text{lbs}}{\text{HR}})(.55)}{2000 \frac{\text{lbs}}{\text{TON}}} = 17.3 \frac{\text{TONS}}{\text{HR}}$$

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By K. Tower Date 1/29/75

Source Wood Boilers

E_s can now be calculated as follows

$$E_s = \frac{52 \frac{\text{lbs}}{\text{HR}}}{17.3 \frac{\text{TONS}}{\text{HR}}} = 3.01 \frac{\text{lbs}}{\text{TON}}$$

$$E_s = 3.01 \frac{\text{lbs RT.}}{\text{TON}}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By HOPPER Date 8/13/79

Source STATIONARY GAS TURBINES

STATIONARY GAS TURBINES ARE USED PREMINISLY IN TWO DISTINCT AREAS:

- ① GAS-Pipeline
- ② Electric Power Generation

They will be treated separately due to the potential for differing K, P_c, & emissions

I. Electric Power Generation

CAPACITY 1971 = 19,313 MW REF (105) p 185

GROWTH BETWEEN 1970 & 1980 ESTIMATED @

$$\begin{aligned} \text{5,250 MW/yr (STATIONARY)} &\quad \text{REF (109) p 175} \\ \frac{69,000 \text{ (1980)} - 16,500 \text{ (1970)}}{10} &= 5,250 \text{ MW/yr} \end{aligned}$$

IP

$$P_c = 1975 - 1971 (1 + 4P_c)$$

$$(5250)4 + 19,313 = 19313 (1 + 4P_c)$$

$$\frac{2.087 - 1.0}{4} = P_c = 27\% \text{ (simple)}$$

$$P_c = 27\% \text{ simple}$$

$$P_c = .27 \text{ simple}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Homer Date 8/13/74

Source Stationary Gas Turbines

$$A = 19,313 + 4(5250) = 40,313$$

$$A = 40,313 \text{ MW} \quad \frac{(40,313 \text{ MW}) \times 10^6 \frac{\text{WATTS}}{\text{MW}}}{745.7 \frac{\text{WATTS}}{\text{HP}}} \quad 54.1 \times 10^6 \text{ HP}$$

REF 105 p 185

$$A = 54.1 \times 10^6 \text{ HP}$$

① UTILIZATION VARIES from 10 hrs/yr to base load durations

REF 104 p 179

② DEMANDS ARE SUCH THAT THE UNITS MUST BE OPERATED MORE FREQUENTLY THAN ORIGINALLY INTENDED

(A) "1950 hrs/yr"

(B) "1970 hrs/yr"

(C) "WELL ABOVE THE 1500 hours per year level"

Assuming that this trend continues, assume

$$K = \frac{1950}{(365)(24)} = 22.3\%$$

$$K_{\text{ELEC POWER}} = 0.223$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Kippe Date 8/14/74

Source Stationary Gas Turbines

II. Gas Pipeline Service

REF (104) was found to contain the most recent compilation of information. However, the text tended to be a bit misleading due to the lack of detailed def'n between turbines & gas turbines. Also, some curves & figures are presented to show the growth of gas turbines in the industry relative to all turbines &, therefore, lack specific data. However, the following information was ascertained

REF(104) P 306 TAB 2

$$1970 \text{ Capacity (Gas Turbines)} = 2.540 \times 10^6 \text{ hp}$$

$$1970 \text{ Capacity (All Turbines)} = 8.7 \times 10^6 \text{ hp}$$

REF(104) P 207 TAB 2 shows growth of gas

turbines between 1964 & 1970 in terms of capacity added per year. The attached figure is the integral of this curve drawn to determine THE GROWTH TREND

BETWEEN 1968 & 1970, WE HAD $(1.325 - .585) \times 10^6$
 HP INCREASE

$$\therefore \frac{(1.325 - .585)(10^6)}{2} = 0.37 \times 10^6 \text{ HP/YR}$$

If we assume straight line growth

$$A = 2.54 \times 10^6 + (37 \times 10^6)(5) = 4.39 \times 10^6$$

$$A = 4.39 \times 10^6 \text{ HP}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hoppe Date 8/14/74

Source Stationary Gas Turbines

P_C :

$$(4.39 \times 10^4) = (2.54 \times 10^4)(1 + 5\%)$$

$$P_C = 14.5\% \text{ since}$$

- ① Very little info was found regarding K
- ② K would generally be high considering the increasing need for natural gas (or any other fuel for that matter)
- ③ K is not equal to 2.0 because demands change daily AND annually.

The following is an effort to define K & is subject to modification if new data become available:

REF (104) p 306

- (A) 1st g/t installation "late 1940's" (Assume 1949)
 has accumulated 148,000 hrs "to date"
 (Assume 1970)
- (B) REF (104) p 177 TBO = 1500 hrs

$$\frac{148,000}{21 \text{ yrs}} = 7048 \frac{\text{hrs}}{\text{yr}}$$

$7048/1500 \approx 4 \text{ overhauls/yr} @ 340 \text{ manhours}$

REF 104 p 208

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hopper Date 8/14/74
 Source Stationary Gas Turbines

(C) Assume 2 mwh OR $\frac{240}{3} = 120 \text{ hrs/overhour}$

$(365)(24) - 4(120) = 8280 \frac{\text{hrs}}{\text{yr}}$ when unit could be used


(D) Assume gas turbine to run at peak or not at all since it is a steady state device.
 Short term demand changes handled by RECPs.

(E) REF (75) P 3.3.1-1 SEC. 3.3.1.2 STATES

$$\frac{7048}{8280} = K = 0.85$$

K = 0.85

"most gas turbines do not run at the frequent rate of low power"



TRC -- The Research Corporation of New England

125 Silas Deane Highway
Wethersfield, Connecticut 06109Project Number - 32391 New Source Performance StandardsComputation Sheet For Industrial FactorsCalculations Done By HoyerDate 10/24/74Source Stationary Gas TurbinesDet'n of P_B

REF. 37 p 41

IRS GUIDELINE = 50 yrs for

"Hydrolic Production Plant"

FALLING DAMS, FLUMES, CANALS, WATERWAYS.
ALSO INCLUDES JET ENGINES AND OTHER INTERNAL COMBUSTION ENGINES USED TO OPERATE AUXILIARY FACILITIES FOR LOAD SHAVING PURPOSES OR IN CASE OF EMERGENCIES"

IRS GUIDELINE = 20 yrs for

"NUCLEAR PRODUCTION PLANT"

INCLUDES NUCLEAR ENGINES AND OTHER INTERNAL COMBUSTION ENGINES USED TO OPERATE AUXILIARY FACILITIES FOR LOAD SHAVING PURPOSES OR IN CASE OF EMERGENCIES"

IRS GUIDELINE = 28 yrs for

"STEAM PRODUCTION PLANTS"

SAME QUOTE AS NUCLEAR POWER STATIONS

IT IS OUR JUDGEMENT THAT 25 YEARS REPRESENTS A REALISTIC AVERAGE

IF WE DOUBLE THE ALLOWABLE DEPRECIATION TO BE MORE CONSISTENT WITH REALITY, THEN

$$P_B = \frac{100\%}{50 \text{ yrs}} = 2\%$$

$$P_B = 0.02 \text{ SIMPLE}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 8/14/74

Source Stationary Gas Turbines

I. Gas Pipeline Service

REF 104 pg. 1 Fig 5 gives breakdown of # of units in service for

- ① GAS PIPELINES
- ② LIQUID PIPELINES (ASSUME OIL)
- ③ REPROSUGGING SYSTEMS (ASSUME 50/50 GAS/OIL)

Assume that the avg HP rating for engines in EACH category is THE SAME

in 1970

780 ENG'S - PIPELINE
 160 ENG'S - LIQUID (EXTRAP)
 80 ENG'S - REPR. SYST. (EXTRAP)

1020 ← 1970ES WITH # ENGINES TOTAL REF 104 pg 11 tab 1

$$\frac{780}{1020} = 76\% \quad \text{Assume to use Natural Gas}$$

$$\frac{160}{1020} = 17\% \quad \text{Assume to use #2 oil}$$

$$\frac{80}{1020} = 7\% \quad \text{Assume to use 50/50 gas/oil}$$

EMISSION FACTURES:

FOR OIL (#2) $F_U = 8.4 \times 10^3 \text{ gals} @ 140,000 \frac{\text{BTU}}{\text{gal}}$ REF 75

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By HOPPER Date 8/14/74

Source Stationary Gas Turbines

\leftarrow Ref (220) p31 TAB 10

$$\frac{\left(\frac{8.4 *}{10^3 \text{ gal}} \right) \left(11000 \cdot \frac{\text{Btu}}{\text{HP} \cdot \text{HR}} \right) \left(8760 \frac{\text{hr}}{\text{yr}} \right)}{(140,500) \frac{\text{Btu}}{\text{gal}}} = \frac{5.76 *}{\frac{\text{HP} \cdot \text{YR}}{\text{EUP}_{\text{oil}}}}$$

\uparrow REF (75) p 3.3.1-1

$$\text{EUP}_{\text{gas}} = 0 \quad \text{REF (75) p 3.3.1-2 TAB 3.3.1-2}$$

$$\text{EUP} = (.76)(0) + .17(5.76) + (.17)(.5)(5.76) + (.0)(.5)(.07)$$

$$.979 + .202 = 1.18$$

$$\text{EUP}_{\text{gas}} = 1.18 \frac{*}{\text{HP} \cdot \text{YR}}$$

The only particulate control mechanism used on gas turbine eng's are "smoke fix cans." REF 104 p179 New engines, which are the subject of NSPS, should have this type of combustor &, therefore, E_P would be less.

Assume that E_N = 0 for the purpose of determining max impact (T_S-T_N). If the impact is insignificant, the assumption is valid. If the impact is significant, A reevaluation of E_N would be in order.

$$\text{EUP}_{\text{gas}} = 0$$

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hooper Date 8/15/74
Source Stationary Gas Turbines

NO_x

$$E_{NO_x} = 120 \text{ } \% / 10^3 \text{ gac} \quad \text{Ref (75)} \quad p. 3.3.1-1$$

$$EV_{NO_x} = 0.57 \text{ m}^3/\text{106 BTU} \quad Ref=75 \quad P\ 3.3.1-2$$

$$\frac{\left(\frac{120}{103} \text{ gec} \right) \left(11000 \frac{\text{BTU}}{\text{HP.yr}} \right) \left(8760 \frac{\text{hr}}{\text{yr}} \right)}{\left(140,500 \frac{\text{BTU}}{\text{gec}} \right)} = 82.3 \frac{\text{# NOx}}{\text{HP.yr}}$$

↑
REF 75 pg 3.1-1

for on/off
units

$$\left(\frac{0.57 \text{ # NOx}}{10^6 \text{ BTU}} \right) \left(11000 \frac{\text{BTU}}{\text{HP.Mile}} \right) \left(8760 \frac{\text{hr}}{\text{yr}} \right) = 54.9 \quad \frac{\text{# NOx}}{\text{HP.Mile}}$$

Refer to P_i of these rule's for % breakdown

$$(.76)(54.9) + .17(82.3) + (.07)(.5)(82.3) + (.07)(.5)(54.9) = \\ 41.7 + 14.0 + 2.9 + 1.9 = 60.5$$

$$EV_{Hg} = 60.5 \frac{\text{mV}}{\text{ppm}}$$

Ques 32 See II. To Reduction in NO_x by "wet methods" reported up to 85?

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Homer Date 8/15/74
 Source Stationary Gas Turbines

$$.85 = \frac{60.5 - E_N}{60.5} \quad E_N = 9.08$$

$$E_N = 9.08 \frac{\text{# SO}_x}{\text{HP-YR}}$$

SO_x

For oil-fired units

$$E_{U_{SO_x}} = 1.05$$

Ref (75) p 3.3.1-1
 TAB 3.3.1-1

From Ref (77) p 19 TAB 4.9

Avg Sulfur content
 of #2 oil in the U.S.
 is 0.265%

$$E_{oil} = 0.265 \frac{\text{# SO}_x}{10^6 \text{BTU}}$$

(BASED ON ARITHMETIC)
 (AVERAGE OF TAB 4.9)

$$\left(\frac{0.265}{10^6} \right) \left(\frac{1}{1000} \right) \left(\frac{8760}{1} \right) = 25.5 \frac{\text{# SO}_x}{\text{HP-YR}} \text{ for oil units}$$

From Ref (75) p 3.3.1-2 TAB 3.3.1-2

$$E_{gas} = 0.0006 \frac{\text{# SO}_x}{10^6 \text{BTU}}$$

$$(0.0006)(10^6) \left(\frac{1}{1000} \right) \left(\frac{8760}{1} \right) = 0.058 \frac{\text{# SO}_x}{\text{HP-YR}} \text{ for gas units}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hansen Date 8/16/74

Source Stationary Gas Turbines

Refer to p. 1 of these rate's for % breakdown

$$(0.76)(.058) + .17(25.5) + (.07)(.5)(0.58) + (.07)(.5)(25.5) = \\ .0441 + 4.335 + .0020 + .8925 = 5.27$$

$$E_{N_{SO_x}} = 5.27 \frac{\text{lb}}{\text{hr.yr}}$$

Comments:

- ① There is no demonstrated control technology for SO_x on gas turbine engines
- ② If there were, it would be quite #. ^{REF (32)} _{Sec III-10}
- ③ Assume (for the time being) that all dual fuel units run 100% on NG

$$.0441 + 4.335 + .0041 = 4.38 \quad 17\% \text{ reduction}$$

This would probably result in a (S-1) quite low on the priority list.

$$E_{N_{SO_x}} = 4.38 \frac{\text{lb}}{\text{hr.yr}}$$

^{REF (32)}
_{Sec III-3}

There is a trend to go to poorer, less refined fuels (higher S content). This could be in the form of holding 7.5% at its present level & not allowing any alteration in standard in the future.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 8/16/74
 Source Stationary Gas Turbines

CO

REF (32) 2165 9/10

ARITHMETIC AVG OF DATA POINTS broken down into
 oil fired units & gas fired units with no regard, to
 size or NO_x control

<u>GAS (ppm)</u>	<u>oil (ppm)</u>
205	420
140	345
110	180
30	145
345	120
100	80
80	50
10	30
Avg = 115 ppm	160
	100
	75
	35
	30
	10
	Avg = 132 ppm

In order to convert ppm to $\frac{\# \text{CO}}{\text{HP.yr}}$ (for oil & gas)
 we must enter into a series of computations.

$$\left(\frac{\text{FT}^3 \text{CO}}{\text{FT}^3 \text{gas}} \right) \times \left(\frac{\text{FT}^3 \text{gas}}{\# \text{gas}} \right) \times \left(\frac{\text{mole CO}}{\text{FT}^3 \text{CO}} \right) \times \left(\frac{\# \text{CO}}{\text{mole CO}} \right) \times \left(\frac{\# \text{gas}}{\# \text{fuel}} \right) \times \left(\frac{\text{ft fuel}}{\text{hr}} \right) \times \left(\frac{\text{ft}^3}{\text{HP.hr}} \right) \times \left(\frac{\text{HP}}{\text{yr}} \right)$$

$\frac{\# \text{CO}}{\text{HP.yr}}$
 ppm $\frac{1}{P}$ 359 28 A/F.
 = $\frac{\# \text{CO}}{\text{HP.yr}}$ RATIO $\frac{1}{H_2}$ 11.20 8760

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Homer Date 8/16/74

Source Stationary Gas Turbines

$$\text{Assume } \rho = .075 \text{ (air)} \quad HV = \frac{140,500}{7.309} \frac{\text{Btu}}{\#} \text{ ref (101)} \\ \text{TAB 9-9}$$

A/F RATIO

$$\textcircled{a} \text{ oil} = \frac{1}{.015} \\ \textcircled{b} \text{ gas} = \frac{1}{.018}$$

} PER TERCON 8/16/74 WITH
 N. SCHWARTZ - JR. DIR'R PART.
 & WHITNEY AGREEMENT - INDUSRIAL
 TURBINE DIVISION, SECTION OF
 COMBUSTION GROUP

For oil

$$\frac{\#CO}{HP.YR} = 45.8$$

For gas

$$\frac{\#CO}{HP.YR} = 25.1$$

$$\text{Assume} \\ HV = 25,500$$

$$Af (101) \\ \rho 9-8 TAB 9-9$$

$$\frac{\#CO}{HP.YR} \\ \text{ref (75)} \\ 3.3.1-2 \\ TAB 3.3.1-2$$

Remove Δp_1 at these cat's for breakdown

$$(.76)(25.1) + (.17)(45.8) + (.07)(.5)(25.1) + (.07)(.5)(45.8)$$

$$19.08 + 7.79 + .88 + 1.60 = 29.35$$

$$E_{CO} = 29.35 \frac{\#CO}{HP.YR}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By HOPPER Date 8/16/74
 Source STATIONARY GAS TURBINES

Ref (32) SEC III-3 states
 CO reduction by 67%

En_{CO}:

$$\frac{29.35 - Ed}{29.35} = .67$$

$$En_{CO} = 9.69 \quad \frac{\pm CO}{hr \cdot yr}$$

gas
fire

A CO std would be req'd to preclude
 excessive increases in NO_x which have been known
 to occur when NO_x control is added Ref (32)

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By HOPPER Date 8/16/74
 Source Stationary Gas Turbines

II. Electric Power Generation

REF (105) p 186 - 208 list MW ratings for each electric company's gas turbines & the type of fuel burned. Of the total listed, there exist:

- (A) 6714.87 MW using oil (#2)
- (B) 1262.1 MW using gas
- (C) 10,035.9 MW using oil/gas

The % age breakdown is

37% oil
 7% gas
 56% dual fuel (assume 50/50 gas/oil)

Particulates

From p2 of these calc's

$$EV_{P_{oil}} = 5.76 \frac{\#}{HP \cdot yr}$$

$$EV_{P_{gas}} = 0$$

$$EV_{P_{dual}} = (.37)(5.76) + (07)(0) + .56(0).5 + (.56)(.5)(5.76)$$

$$2.13 + 1.61$$

$$EV_{P_{dual}} = 3.74 \frac{\#}{HP \cdot yr}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hager Date 8/16/74
 Source Stationary Gas Turbines

Assume

$$E_{N_{P_{ELEC}}} = 0$$

for the same reasons
 stated @ the bottom
 of p2 of these calc's.

NO_x

$$E_{N_{O_x}}_{on} = 82.3$$

$$E_{N_{O_x}}_{gas} = 54.9$$

Using the same % breakdowns
 discussed on p9 of these calc's

$$(37)(82.3) + (07)(54.9) + (.56)(.5)(82.3) + (.56)(.5)(54.9) =$$

$$30.45 + 3.84 + 23.04 + 15.37$$

$$E_{N_{O_x}}_{ELEC} = 72.7 \frac{\#}{HP.YR}$$

REF 32 Sec III reports up to 85% reduction in NO_x
 by wet methods

$$\frac{72.7 - E_N}{72.7} = .85$$

$$E_{N_{O_x}}_{ELEC} = 10.9 \frac{\#}{HP.YR}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hager Date 8/16/74
 Source Stationary Gas Turbines

SO_x

$$E_{SO_x} = 25.5 \\ \text{oil}$$

$$E_{SO_x} = .058 \\ \text{gas}$$

Using, again, the same % reductions discussed on p 9 of these calc's

$$(.37)(25.5) + (.07)(.058) + (.56)(.5)(25.5) + (.56)(.5)(.058) = \\ 9.44 + .0041 + 7.14 + .016$$

$$E_{SO_x} = 16.6 \frac{\#}{\text{hr.yr}}$$

Assume all oil fuel units run 100% on gas

$$(.37)(25.5) + (.07)(.058) + (.56)(.058) = 9.44 + .004 + .032$$

$$9.48$$

% Reduction
"43%

$$E_{NO_x} = 9.48 \frac{\#}{\text{hr.yr}}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoyer Date 3/15/74
 Source Stationary Gas Turbines

CO

$$EV_{CO} = 45.8$$

$$EV_{CO} = 25.1$$

Assume same % breakdowns discussed on
 p 9 of those cat's.

$$(37)(45.8) + (.07)(25.1) + (.56)(.5)(45.8) + (.56)(.5)(25.1) =$$

$$16.95 + 1.76 + 12.82 + 7.03$$

$$EV_{CO} = 38.56 \frac{\#}{HP-YR}$$

Ref (32) SEC III-3 STATES
 CO reduction by 67%

$$EV_{CO} = 12.7 \frac{\#}{HP-YR}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hoppe Date 9/18/75

Source Sini. Gas Turbines

Es

From Ref (84) & (148), there are no specific STATE regulations for NO_x (except Conn.). Some states appear to rule out STATIONARY gas turbines from their fuel burning Regs entirely. With others, it appears to be a case of interpretation — with respect to any pollutant. For the purpose of this study, we will assume that . . .

- ① STATES generally do not enforce fuel burning Regs for gas turbine engines
- ② Connecticut's regulation will be disregarded since it will have an inconsequential effect on our results

So

$$E_S = E_U$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By HOPPER Date 9/18/75

Source STAT. GAS TURBINES

Summary

	GAS PIPELINE			ELECTRIC UTILITY		
	E _U	E _N	E _S	E _U	E _N	E _S
PARTICULATE	1.18	0.0	1.18	3.74	0.0	3.74
NO _X	60.5	9.08	60.5	72.7	10.9	72.7
SO _X	5.27	4.38	5.27	16.6	9.48	16.6
CO	29.4	9.69	29.4	38.6	12.7	38.6

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By HOPPER Date 9/12/75

Source Internal Combustion & Diesel Engines

Several references were consulted regarding capacity of all Refs differed substantially

Ref(50) STATES

$(30-20)\times 10^6$ installed HP in 1972

Ref(100) p 5-6 TAB 5-3 STATES

(70×10^6) installed HP in 1969

Ref (220) p 2 STATES

(34.7×10^6) installed HP in 1971

Ref(50) is unpublished & a relatively "quick" analysis
Ref(100) indicates that their value is estimated

Ref (220) is

- (a) More recent than Ref(100) or Ref(50)
- (b) more detailed than " " "
- (c) Based on published data & industry questionnaires

Although any Ref could be used, we choose
Ref (220) information. Category breakdowns are
 also included in this Ref

$$A_{1971} = 34.7 \times 10^6 \text{ BHP}$$

IIC+P
sug's

Ref (220) p 2

54% - SPARK Ignition Engines (natural Gas)
 34.2% - DIESEL
 11.8% - DUAL fuel

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Homer Date 9/12/75

Source IC & D ENGINES

$$A_{SIE} = \frac{(34.7 \times 10^6)}{315} (.54) = 18.74 \times 10^6 \text{ Bhp}$$

$$A_{D+DF} = (.342 + .118)(34.7 \times 10^6) = 15.96 \times 10^6 \text{ Bhp}$$

Ref (50) gives growth rates of
 $2.5 \times 10^6 \text{ hp for SIE}$

$0.50 \times 10^6 \text{ hp for D+DF}$

This gives

$$A_{SIE} = [18.74 + (4)(2.5)] \times 10^6 = 28.74$$

$$A_{SIE} = 28.74 \times 10^6 \text{ Bhp}$$

$$A_{D+DF} = [15.96 + (4)(.5)] \times 10^6 = 17.96 \times 10^6$$

$$A_{D+DF} = 17.96 \times 10^6 \text{ Bhp}$$

$$P_{c_{SIE}} = \frac{2.5 \times 10^6}{28.74 \times 10^6} = 0.087$$

$$P_{c_{SIE}} = 0.087$$

simple

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By HOMER Date 9/12/75

Source IC & D Engines

$$P_{D+DF} = \frac{0.5 \times 10^6}{17.96 \times 10^6} = 0.028$$

$$P_{D+DF} = 0.028 \text{ simple}$$

Depending upon future availability of natural gas, these values could change significantly!

Ref (220) p 3 gives

$$K = 0.58$$

We will use this for both SIE & D+DF

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hegar

Date

9/12/75

Source IC+D Engines

Def'n of P_B

REF. 37 p.41

IRS GUIDELINE = 50 yrs for

"Hydroelectric Production Plant"

INCLUDING DAMS, FLUMES, CANALS, WATERWAYS.
ALSO INCLUDES JET ENGINES AND OTHER INTERNAL
COMBUSTION ENGINES USED TO OPERATE AUXILIARY
FACILITIES FOR LOAD SHAVING PURPOSES OR IN
CASE OF EMERGENCIES"

IRS GUIDELINE = 20 yrs for

"NUCLEAR PRODUCTION PLANT"

INCLUDES JET ENGINES AND OTHER INTERNAL
COMBUSTION ENGINES USED TO OPERATE AUXILIARY
FACILITIES FOR LOAD SHAVING PURPOSES OR IN
CASE OF EMERGENCIES"

IRS GUIDELINE = 28 yrs for

"STEAM PRODUCTION PLANTS"

SAME GUIDE AS NUCLEAR POWER STATIONS

IT IS OUR JUDGEMENT THAT 25 years represents a realistic
AVERAGE

IF we double the allowable depreciation to be more
CONSISTENT WITH REALITY, THEN

$$P_B = \frac{100\%}{50 \text{ yrs}} = 2\%$$

$$P_B = 0.02 \text{ SIMPLE}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Homer Date 9/12/75

Source IC & D Engines

NO_x

REF (220) p 24 TAB 6 gNES EU IN GRAMS/BHP-HR
 for A VARIETY OF cycle/charging config's
 Using the computed averages . . .

$$EU_{SIE} = 11.9 \frac{\text{GRAMS}}{\text{Bhp-HR}}$$

$$EU_{SIE}_{NO_x} = \frac{(11.9)(8760)}{454} = 230$$

$$EU_{SIE} = 230 \frac{\#}{\text{Bhp-YR}}$$

$$EU_{D+DF}_{NO_x} = 9.3 \frac{\text{GRAMS}}{\text{Bhp-HR}}$$

$$EU_{D+DF}_{NO_x} = \frac{(9.3)(8760)}{454} = 179$$

$$EU_{D+DF} = 179 \frac{\#}{\text{Bhp-YR}}$$

REF (50) TAB 2 BEST %AGE REDUCTION of NO_x is 43%
 for SIE

$$EU_{SIE}_{NO_x} = 230(1-.43) = 131 \frac{\#}{\text{BHP-YR}} = EN_{SIE}_{NO_x}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391. New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoppe Date 9/12/75

Source IC & D

Also, Ref⁽⁵⁰⁾

Improvement for Diesel = 28%
Improvement for Dualfuel = 40%

From p1 of IND. FACTORS,

34.2% of TOTAL CAP. = DIESEL

11.8% of TOTAL CAP. = DUAL FUEL

$$\bar{n} = \left(\frac{34.2}{46} \right) (28\%) + \left(\frac{11.8}{46} \right) (40\%) = 31.1\%$$

$$179 (1 - .311) = 123$$

$$E_{NOx} = 123 \frac{\text{#}}{\text{Bhp-yr}}$$

All these improvements can be realized through a series of combustion design/operating modifications

CO

Ref⁽²²⁰⁾ p24 TAB CO (Using avg values)

$$E_{CO}^{SIE} = 2.22 \frac{\text{g/hr}}{\text{Bhp-hr}}$$

$$E_{CO}^{SIE} = \frac{(2.22)(8760)}{454} = 42.8$$

$$E_{CO}^{SIE} = 42.8 \frac{\text{lb}}{\text{Bhp-yr}}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By HOPPER Date 9/12/75

Source ICE & D ENGINES

Ref(50) shows that for combustion modifications used to decrease NO_x, CO increases

Ref(220) pg states that "over the long term, catalytic reduction...."

However, . . . "A significant amount of development work must be carried out...."

We will assume, therefore, the hypothetical case of E_N=0.0 for control ranking purposes

$$\frac{E_{N\text{SIE}}}{CO} = 0.0$$

Ref(220) p24 TAB 6 (using avg values)

$$EU_{D+DF} = 2.84 \frac{\text{grams}}{\text{Bhp-hr}}$$

$$\left(\frac{34.2}{46}\right)\left(3.14\right) + \left(\frac{1.8}{46}\right)\left(2.0\right)$$

$$2.33 + .513 = 2.84$$

$$EU_{D+DF} = \frac{(2.84)(8760)}{454} =$$

$$EU_{D+DF} = 54.8 \frac{\#}{\text{Bhp-yr}}$$

Since CO increases for those op's which decrease NO_x (Ref(50)) & catalytic reduction needs substantial development effort (Ref(220) pg), we will make the following assumptions:

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391. New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoyer Date 9/12/75

Source IC & D Engines

- ① All dual-fuel units to use NAT. GAS 100% of time
- ② No change to diesel units

Using capacity breakdown figures on p. of IND. FACTORS
 & emission factors for SIE in lieu of those for dual fuel
 ENGINES (since gas is the fuel)

$$\text{EN}_{\text{DIESEL}} = \frac{(34.2)}{46} (3.14) + \frac{(11.8)}{46} (2.22) = 2.90$$

↑
 Ref 220
 p 29 TAB6
 for DIESEL
 ONLY

$$\text{EN}_{\text{D+DF}} = \frac{(2.90)(8760)}{454} = 56 \quad \text{This approach is}$$

RESULTS IN HIGHER
 EMISSIONS. ASSUME

$$\text{EN}_{\text{D+DF}} = 56 \frac{\#}{\text{BHP-YR}}$$

$$\text{EN}_{\text{D+DF}} = 0.0$$

AS FOR SIE

NSPS for Diesel units could be in the form of MAINTAINING
 HIGH QUALITY OF OPERATION THRU INSPECTIONS, CO METERS TO
 INDICATE DETERIORATION FROM "BEST OPERATION." IF % CO INCREASES
 BEYOND A CERTAIN LEVEL, IT WILL BE NECESSARY TO RETURN
 THE UNIT TO ITS "ORIGINAL CONDITION."

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hansen Date 9/12/75

Source IC & D Engines

Hydrocarbons

Ref(220) part 7006 (using avg values)

$$E_{NSIE} = 2.9 \frac{gR}{Bhp-hr}$$

$$\frac{(2.9)(8760)}{454} = 56$$

$$E_{NSIE} = 56 \frac{\#}{Bhp-YR}$$

Similar arguments for HC control hold as for CO control.

$$E_{NSIE} = 0.0$$

Ref(220) part 7006 (avg values) $\left(\frac{34.2}{46}\right)\left(1.11\right) + \left(\frac{11.8}{46}\right)\left(3.1\right)$

$$E_{UDOF} = 1.62 \frac{gR}{Bhp-hr}$$

$$\begin{matrix} \uparrow \\ \text{DIESEL} \end{matrix} \quad \begin{matrix} \uparrow \\ \text{DF} \end{matrix}$$

$$.825 + .795 = 1.62$$

$$E_{UDOF} = \frac{(1.62)(8760)}{454} = 25.7$$

$$E_{UD+DF} = 31.3 \frac{\#}{Bhp-YR}$$

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By HOPPE

Date 9/12/75

Source IC + D Engines

FOR EN, Assume that all dual-fuel units burn nat.gas 100% of the time & diesel units are uncharged

$$E_{NDIE} = \left(\frac{34.2}{46} \right) (1.11) + \left(\frac{11.8}{46} \right) (2.9) = .825 + .799 = 1.57$$

↑
Ref 220
P24 TAB6
DIESEL
ONLY

$$\frac{(1.57)(8760)}{454} = 30.3$$

$$E_{NDDF} = 30.3 \frac{\text{LB}}{\text{Bhp-YR}}$$

This fuel switching approach was unacceptable for CO emissions but would have some for HC emissions. We will assume this practice to be used for HC reduction in spite of the slight increase in CO.

SOX

From Ref ⑨7 $E_{NSIE} = 0.4 \frac{\text{#}}{10^6 \text{ FT}^3 \text{ gns}}$

From Ref 220 P 31 TAB 10 $7000 \frac{\text{STU}}{\text{Bhp-hr}}$

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By HOPPER Date 7/12/75

Source IC+D Engines

$$\frac{\left[0.4 \frac{lb}{10^6 ft^3}\right] \left[7000 \frac{BTU}{Bhp-hr}\right] \left[8760 \frac{hrs}{yr}\right]}{1000 \frac{BTU}{ft^3}} = 0.025$$

$$EU_{SO_2} = 0.025 \frac{lb}{Bhp-yr}$$

Since this is negligible & NG. is the "CLEANEST" FUEL THAT CAN BE USED
Assume EU = EN = 0

∴ ELIMINATE FROM TABLES

From Ref (97) for diesel engines

$$40 \frac{lb SO_2}{10^3 gallons} \quad (BS = 0.3)$$

From Ref (220) p 31 TAB 10

$$0.4 \frac{lb FUEL}{Bhp-hr} \quad \text{Assuming HV} = 140,500 \frac{BTU}{gAL}$$

$$\frac{\left(40 \frac{lb SO_2}{10^3 gAL}\right) \left(0.4 \frac{lb FUEL}{Bhp-hr}\right) \left(8760 \frac{hrs}{yr}\right)}{\left(7.31 \frac{lb FUEL}{gAL FUEL}\right)}$$

REF 75
P 3.3.1-1 TAB
3.3.1-1

7.31 $\frac{lb}{gAL}$ (#201)
Ref (101) P 9-6
TAB 9-9 (AVG)

$$EU_{SO_2} = 19.2 \frac{lb}{Bhp-yr}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoyer Date 2/12/75
 Source IC & D Engines

Assume dual fuel engines 50/50 oil/gas

$$\text{EU}_{\text{DF}} = \frac{(.5)(19.2) + .5(0)}{50} = 9.6$$

$$\text{EU}_{\text{DF}} = 9.6 \frac{\#}{\text{Bhp-yr}}$$

$$\text{EU}_{\text{D+DF}} = \frac{(34.2)}{46} (19.2) + \frac{(11.8)}{46} (9.6) = 14.3 + 2.5 = 16.8$$

$$\text{EU}_{\text{D+DF}} = 16.8 \frac{\#}{\text{Bhp-yr}}$$

For control, assume that diesels still burn oil but dual fuel switches to all gas

$$\text{EU}_{\text{D+DF}} = \frac{(34.2)}{46} (19.2) + 0 = 14.3$$

$$\text{EU}_{\text{D+DF}} = 14.3 - \frac{\#}{\text{Bhp-yr}}$$

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By HOPPER Date 9/12/75
Source IC & D Engines

PARTICULATES

$$EU_{SIE} = ENSIE = 0$$

Ref 75 p. 3.1.6-1
for gaseous fueled
vehicles

For diesel

Ref 75 p 3.15-2 TAS 3.1.5-1

$$EU = 13 \frac{\#}{10^3 \text{ GAL}}$$

$$\frac{\left(13 \frac{\#}{10^3 \text{ GAL}}\right) \left(0.4 \frac{\#_{FUEL}}{\text{Bhp-hr}}\right) \left(8760\right)}{7.31 \frac{\#_{FUEL}}{\text{GAL FUEL}}} = 6.2 = EU_{DIESEL}$$

Assume dual fuel engines use 50/50 oil/gas

$$EU_{DF} = (.5)(0) + (.5)(6.2) = 3.1 = EU_{DF}$$

$$EU_{D+DF} = \left(\frac{34.2}{46}\right)(6.2) + \left(\frac{11.8}{46}\right)(3.1) = 4.61 + .8 = 5.41$$

$$EU_{D+DF} = 5.41 \frac{\#}{\text{Bhp-hr}}$$

For context, assume diesels still burn oil but dual-fuel switches to all gas

$$EU_{D+DF} = \left(\frac{34.2}{46}\right)(6.2) + 0 = 4.61$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 9/12/75
 Source IC+D Engines

$$E_{NDHDF} = 4.61 \frac{\#}{BHP \cdot YR}$$

Summary of EU & EN

	<u>SPARK Ign. Eng.</u>		<u>Diesel & Dual Fuel</u>	
	<u>EU</u>	<u>EN</u>	<u>EU</u>	<u>EN</u>
CO	42.8	0.0	54.8	0.0
HC	56.0	0.0	31.3	30.3
SO _x	0	0	16.8	14.3
PART	0	0	5.41	4.61
NO _x	230	131	179	123

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hopper Date 9/12/75

Source IC&D Engines

No states have regs pertaining specifically to STATIONARY INTERNAL COMBUSTION ENGINES & DIESEL ENGINES. MANY STATES SPECIFICALLY DO NOT INCLUDE THEM WITHIN THEIR FUEL BURNING REGS. IT IS A MATTER OF INTERPRETATION, HOWEVER, WITH OTHER STATES. WE WILL

ASSUME

$$\text{E}_S = \text{E}_U \text{ for all pollutants of engine types}$$

Ref(50) STATES, ALSO, THAT THERE ARE NO REGS FOR THIS FUEL BURNING EQUIPMENT.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Morcone Date 9-9-74

Source Autobody Incinerators

Ref D38 pg 137 states that "the great majority of autobody incinerators now operating or under construction are based on the Bureau of Mine Design.

Refractory-lined garage-type unit equipped with a natural gas afterburner. 6 car/hr or 12,500 car/yr

Two cars at a time charged

K:

Ref 038 pg 142-143

$$\text{operating schedule } \frac{8 \text{ hr}}{\text{d}} \times \frac{5 \text{ day}}{\text{wk}} \times \frac{52 \text{ wk}}{\text{yr}} = 2080 \text{ hr yr}$$

<u>Cap car/hr</u>	<u>Plant Burn Rate car/hr</u>	<u>Schedule hr/yr</u>
1.	10	1820
2.	6	N.A.
3.	6	2080
4.	7	N.A.
5.	10	2,080

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marrone Date 8-9-74

Source Auto body Incinerators

K: cont'd

Calculating utilization factors from these data

$$1. \frac{1820}{2080} \approx .875$$

2. Not calculable, however est at best as $\frac{3\text{cur}}{6\text{cur}} = .5$

$$3. \frac{2080}{2080} \approx 1$$

4. Not calculable, however est at best as $\frac{7}{7} \approx 1$

5. Not calculable, however est at best as $\frac{2080}{2080} \approx 1$

In light of the sketchy data above; (we see that the utilization seems to range between .5 and 1.0) We estimate a normal utilization factor as .90 to be representative of normal operating practice.

$$\therefore K = .90$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marone Date 9-9-74

Source Autobody Incinerators

A:

From Ref 038 pg 143

Estimated installations in 1973 = 15

Using 6 car/hr capacity and operating schedule of 2080 hr we calculate the average disposal rate capacity for each installation.

$$6 \times 2080 = 12,480 \text{ or } 12,500 \frac{\text{car}}{\text{yr}}$$

for each installation

$$15 \text{ installation} \times 12,500 \frac{\text{car}}{\text{inst yr}} = 187,500 \frac{\text{car}}{\text{yr}} \text{ in 1973}$$

Note! The above reference obtained 248,000 car/yr however this was based on error in calculating the average cars burned per installation. They obtained 16,500 $\frac{\text{car}}{\text{inst}}$ versus the true value of 12,500 $\frac{\text{car}}{\text{yr}}$.

We will use 12,500 $\frac{\text{car}}{\text{inst yr}}$ and

187,500 total car $\frac{\text{yr}}$ as our data points.

The above source assumes that between 1973 and 1978 the autobody incinerators will capture 50% of the present open-burning rate. It was estimated by them from EPA data to be 530,000 car/yr for open burning.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marrone Date 9-9-74

Source Autobody Incinerator


A: Cont'd

$$\text{Added Capacity by 1978} = .5 \times 530,000 = 265,000 \text{ car/yr}$$

$$\begin{array}{rcl} \text{Added 1973-1978} & & 1973 \\ 1978 \text{ Cap} = 265,000 + 187,500 & & \end{array}$$

$$1978 \text{ Cap} = 452,500 \text{ car/yr}$$

There is assumed no expected change in incinerator size during this period.



We have assumed straight-line growth between 1973 and 1978
 5 years

$$1978 = 1973 (1 + P_c \cdot 5)$$

$$452,500 = 187,500 (1 + P_c \cdot 5)$$

TRC --- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marrone Date 9-9-74

Source Autobody Incinerator

A: cont'd

$$\rho_c = \frac{\left(\frac{452,500}{187,500} - 1 \right)}{5}$$

$$\rho_{c,78} = .28 \text{ simple}$$

We estimate 1975 Cap using this growth rate
 and the 1973 Capacity value of 187,500 car/yr
 $n=2$ years

$$1975 \text{ Cap} = 187,500 (1 + .28^2)$$

$$1975 \text{ Cap} = 292,500 \text{ car/yr}$$

$$A = 292,500 \text{ car/yr}$$

ρ_c : We will assume that the above growth
 estimate is applicable for the remainder of the
 period 1978-1985

$$\therefore \rho_c = .28 \text{ simple}$$

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marrone Date 9-9-74

Source Autobody Incinerator

P_B : Ref 037 does not specify any category which would be applicable to autobody incinerators. We make the assumption that the obsolescence rate will be approximated by the P_B for municipal incinerators

$$\therefore P_B = .039 \text{ simple}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marrone Date 9-9-74

Source Autobody Incinerators

E_u , E_N : Emission data was taken from Ref 038 Table 46 pg 141

All new incinerator installations have afterburners for control.

	E_u uncontrolled lb/car	E_N afterburner controlled lb/car
Particulate	2	.54
Carbon Monoxide	2.5	neg
Nitrogen Oxides	.1	.02
Hydrocarbons (includes aldehydes and organic acids)	1.0	.46

Not Gas is generally used as combustion fuel ^{and afterburner fuel} which would imply a very low sulfur oxide emission level. For this reason we do not consider SO_x to be a major pollutant for this source.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By U.F. Russo Date 11/4/74
 Source Autobody Incinerators

Particulate Emissions, E_S :

No distribution for Autobody Incinerators has been found.

~~Ref. 038~~ Table 47 pg 142 list fine (5) incinerators by location. We assume the remainder 10 incinerators' E_S is determined by the 50 State Average Process Weight Rate:

State	Rate (cu yr)	Rate (cu hr)*	Input Process wt. (lb hr) ^{**} / hr	Allw. Emis.
Colorado	12,500	6.0	12000 lbs/hr	11.2 lbs/yr
N.C.	12,500	6.0	12000	13.5 lbs/yr
Utah	12,500	6.0	12000	10.2 lbs/yr
Texas	12,500	6.0	12000	17.0 lbs/yr
Iowa	12,500	6.0	12000	13.5 lbs/yr
10 Others	12,500	6.0	12000	13.0 lbs/yr

* Assuming 2080 hrs operation/YEAR

** Assuming 2000 lbs/cu

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By _____ Date _____

Source _____

Since the State of NC, Texas, Iowa, and "10 others" have greater emissions than E_u , replace allowable emissions by E_u for these states.

<u>State</u>	E_s^0 (lbs/wt)	A_i
Col.	1.87	.067
Utah	1.70	.067
Others.	2	.866

$$\therefore E_s = .239 + 1.732$$

$$E_s = 1.97 \text{ lbs/ton}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marrone Date 11-4-74

Source Autobody Incinerators

E_s : Hydrocarbons

Ref 084 § 148 - there are no hydrocarbon regulations applicable to autobody incinerators
 $\therefore E_s = E_u$

$$E_s = 1 \text{ lb/car}$$

Carbon Monoxide

Ref 084 § 148

Only Illinois has regulations for CO applicable to autobody incinerators.

We make the assumption that this would not effect the overall value of E_s $\therefore E_s = E_u$

$$E_s = 2.5 \text{ lb/car}$$

Nitrogen Oxide Ref 048 § 084

Only Illinois, Indiana, and Massachusetts have NO_x reg applicable to autobody incinerators however their contribution is assumed negligible to the total $\therefore E_s = E_u$

$$E_s = .1 \text{ lb/car}$$

TRC --- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W.J. Marcone Date 9-11-74

Source Conical Burners

Synonomous Names : Teepee and ^{Wigwam} Incinerators

Ref 038
 pg 74- 98

These incinerators are mostly used for the disposal of wood wastes from the manufacture of forest products (pg 74)

Majority located in ; Western States

Texas

Louisiana

Arkansas

Kentucky

Georgia

North Carolina

Ref 051 pg 1 , pg 14-15

These incinerators have been applied in limited cases to municipal waste, however, the refuse is limited to a great extent to wood, twig and brush waste. Garbage, rubber, plastics, asphalt prod, leather, etc cause serious emission conditions and control requirement.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marrone Date 9-11-74
 Source Conical Burners

K: The average burning rate is 85% of design capacity Ref 038 pg 83

$$\therefore K = .85$$

A:

Ref 038 Table 31 pg 90

Year	No of Teepees	Yearly Disposal Rate 10 ⁶ units*/yr
1968	3,330	46.7
1973	835	11.7
1978	490	6.9

We plot this data (see attached graph) and estimate the 1975 disposal rate as; $P_{75} = 9.5 \times 10^6$ ton/yr

using $K=.85$ we estimate the product capacity for 1975

$$A = \frac{9.5 \times 10^6}{.85}$$

$$\therefore A = 11.2 \times 10^6 \text{ T wastes yr}$$


*UNIT IS EQUIVALENT TO ABOUT 1 TON OF WOOD WASTES

Conical Burners
Disposal Rate

Data Abstracted from Ref 038 pg 86-92

46 1320

10 X 10 TO 11 INCH 7 X 10 INCHES
REUFFEL & ESSER CO. MADE IN U.S.A.



TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marrone Date 9-11-74

Source Conical Incinerators

P_c : The growth from 1968 - 1973 is estimated as -24.2%
 $P_c = -.242$ compound

The growth est. for 1973 - 1978 is -10.01%

$$P_c = -.1001 \text{ compound}$$

We assume that the growth rate from 1973-1978 will continue and therefore is applicable to the whole period 1975-1985

$$\therefore P_c \approx -.10 \text{ compound}$$

P_B : Ref 038 pg 89 states that the trend of disposing of wood waste by burning in teepees has rapidly declined in the last 5 years and is expected to continue to decline in the near future.

We assume this to be true for disposal of municipal wastes even more so.

Modification of existing equipment is done only to meet air pollution regulations. Replacement of existing capacity is not expected $\therefore P_B = 0$

$$\therefore P_B = 0$$

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marone Date 9-11-74

Source Conical Incinerator

Since $P_c = -.10$ decline in industry
growth rate

$P_B = 0$ no replacement or
obsolete capacity

This source is not a candidate
for NSPS!

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marrone Date 9-11-74
 Source Conical Incinerators

Emission factors were obtained from Ref 038 Table 26 pg 81
 with qualification on pg 89 and pg 92

400°F represent unmodified temperatures
 800°F " modified "

Modified lb/tow:	<u>Pt</u>	<u>HC</u>	<u>CO</u>
waste	4	.5	20

Unmodified lb/tow:	16	4.5	60
waste			

In 1968 disposal in unmodified only

In 1973 41% modified disposal
 59% unmodified disposal

In 1978 all modified disposal

We assume the following percentages for 1975 - 1978

1975	64% modified	36% unmodified
1976	76% modified	24% unmodified
1977	88% modified	12% unmodified

Weighting the emission factor in each year by the
 above breakdown and combining this with the
 modified emission factor for the period 1978 - 1985
 we may estimate (calculate) average emission factors 1975-1985

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marrone Date 9-11-74
 Source Conical Incinerators

<u>Year</u>	<u>% modified</u>	Emission Factor lb/TON waste		
		<u>Pt</u>	<u>HC</u>	<u>CO</u>
1975	64%	8.3	.9	34.4
1976	76%	6.9	1.5	29.6
1977	88%	5.4	1.0	24.8
1978	100%	4	.5	20
1979	"	4	.5	20
1980	"	4	.5	20
1981	"	4	.5	20
1982	"	4	.5	20
1983	"	4	.5	20
1984	"	4	.5	20
1985	"	4	.5	20
		<u>Avg</u>	<u>4.8</u>	<u>.76</u>
				<u>22.6</u>

$$\therefore E_u \text{ Part} = 4.8 \text{ lb/TON waste}$$

$$HC = .76 \text{ lb/TON waste}$$

$$CO = 22.6 \text{ lb/TON waste}$$

Controls were not applied since this source does not apparently come under NSPS! Best control is being met by redesign and use of "modified" configuration and burning conditions.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By K.Tower Date 1/30/75

Source Industrial/Commercial Incinerators

Ref 075, p.2.1-2 states that industrial/commercial incinerators have capacities which cover a wide range, generally between 50 and 4000 pounds per hour.

Ref 163, p.33 defines intermediate-size incinerators as those incinerators with a design capacity of from 50-4000^{lbs}/hour. This includes commercial, industrial, medical (pathological), high-rise and school incinerators. We define industrial/commercial incinerators as all these incinerators listed as intermediate-size with the exception of pathological incinerators which will be covered as a separate industry. Ref 163, p.36 states that 4% of intermediate size incinerators are pathological. This means that industrial/commercial incinerators as we define them, are equal to 96% of intermediate size incinerators as Ref 163 defines them.

Ref 163, p.35 states that the average intermediate size incinerator operates 3 hrs/day. We assume the average owner of an industrial/commercial incinerator could possibly operate 8 hrs/day. Therefore, $K = \frac{3}{8} = .375$.

$$\boxed{K = 0.38}$$

Ref 163, p.34-38 gives a statistical analysis of "intermediate size" incinerator growth trends, based on a survey of the Incinerator Institute of America (IIA) covering the years 1962-1972. From the information in this analysis we develop the growth rate for the industrial/commercial industry, according to the following equation:

$$P_c = \frac{\frac{1972-1962}{\text{Industrial Capacity 1972}}}{\text{Industrial Capacity 1962}} - 1.0$$

Compound

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By K. Tower Date 1/30/75

Source Industrial/Commercial Incinerators

Ref 163, p.35 states there were 101,755 operating intermediate incinerators in 1972 and that the average capacity is equal to $228 \frac{\text{lb}}{\text{hr}}$. It can then be stated:

$$\text{Industrial Capacity}_{1972} = (101,755)(.96)\left(228 \frac{\text{lb}}{\text{hr}}\right) = 22.3 \times 10^6 \frac{\text{lb}}{\text{hr}}$$

From Ref 163, p.36, Fig 4 it can be determined that 4600 intermediate incinerators were sold from 1962-1972 (IIA data)

Using the relationship described in ref 163, p.34 one can determine the Industrial Capacity₁₉₆₂ as follows:

$$\begin{aligned}\text{Industrial Capacity}_{1962} &= \left[10.697(8146 - 4600) + 10(1461.836) \right] (.96) \left(150 \frac{\text{lb}}{\text{hr}} \right) \\ &= 7.57 \times 10^6 \frac{\text{lb}}{\text{hr}}\end{aligned}$$

No data could be found giving the average capacity of an industrial/commercial incinerator so we assumed $150 \frac{\text{lb}}{\text{hr}}$.

$$P_c = \sqrt{\frac{22.3 \times 10^6}{7.57 \times 10^6}} - 1.0$$

$$= 1.11 - 1.0 = .11$$

$P_c = 0.11$

compound

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By K. Tower Date 1/31/75

Source Industrial/Commercial Incinerators

From Ref 163, p. 35 we find "intermediate-size" incinerators processed 9.04×10^6 TON/yr in 1972. From this information we can calculate the amount of solid waste processed by industrial/commercial boilers in 1975 as follows:

$$P_{1975} = P_{1972} (1 + P_c)$$

$$= (9.04 \times 10^6) (1 + .11)^3$$

$$P_{1975} = 12.4 \times 10^6 \frac{\text{TONS}}{\text{YR}}$$

$$A = \frac{P_{1975}}{K} = \frac{12.4 \times 10^6 \frac{\text{TONS}}{\text{YR}}}{0.38} = 32.6 \times 10^6 \frac{\text{TONS}}{\text{YR}}$$

$$A = 32.6 \times 10^6 \frac{\text{TONS}}{\text{YR}}$$

We were not able to obtain specific information regarding the replacement rate of obsolete production capacity (P_B) however we will assume it to be the same as that for pathological incinerators $\rightarrow .039$ simple (Pathological Incinerators, Industrial Factors, p. 6)

$$P_B = .039$$

simple

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By K. Tower Date 1/31/75
 Source Industrial/Commercial Incinerators

The following table found in Ref 075, p.2.13, Table 2.1-1 will be used to determine emissions factors for P_T , SO_x , CO , Hydrocarbons and NO_x .
 Incinerator % P_T Emissions SO_x CO HC NO_x
 Type lbs/Ton lbs/Ton lbs/Ton lbs/Ton

Multiple chamber	83	7	2.5	10	3	1.5
Single chamber	2	15	2.5	20	15	1
Controlled Air	12	1.4	1.5	Neg	Neg	5
Other	3	$E_{u_{P_T}}$	$E_{u_{SO_x}}$	$E_{u_{CO}}$	$E_{u_{HC}}$	$E_{u_{NO_x}}$

*These data are taken from Ref 163, p.35, Table 5

E_u :

$$E_{u_{P_T}} = (.02)(15) + (.83)(7) + (.12)(1.4) + (.03)(E_{u_{P_T}})$$

$$E_{u_{P_T}} = 6.47 \text{ lbs/TON}$$

$$E_{u_{SO_x}} = (.83)(2.5) + (.02)(2.5) + (.12)(1.5) + (.03)(E_{u_{SO_x}})$$

$$E_{u_{SO_x}} = 2.38 \text{ lbs/TON}$$

$$E_{u_{CO}} = (.83)(10) + (.02)(20) + (.03)(E_{u_{CO}})$$

$$E_{u_{CO}} = 8.97 \text{ lbs/TON}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By K.Tower Date 1/31/75
 Source Industrial/Commercial Incinerators

E_u con'd:

$$E_{u_{HC}} = (.83)(3) + (.02)(15) + (.03)(E_{u_{HC}})$$

$$\boxed{E_{u_{HC}} = 2.88 \frac{\text{lbs}}{\text{TON}}}$$

$$E_{u_{NO_x}} = (.83)(1.5) + (.02)(1.0) + (.12)(5.0) + (.03)(E_{u_{NO_x}})$$

$$\boxed{E_{u_{NO_x}} = 1.87 \frac{\text{lbs}}{\text{TON}}}$$

E_N

Ref 075, p.2.1-4, Table 2.1-2 indicates that collection efficiencies of up to 99% on particulate emissions can be expected by using a fabric filter.

$$E_{N_{PT}} = (.01)(6.47) = .065 \frac{\text{lbs}}{\text{TON}}$$

$$\boxed{E_{N_{PT}} = .065 \frac{\text{lbs}}{\text{TON}}}$$

Only wet scrubbing devices are shown to control to some extent nitrogen oxides. Table VI-1 Ref 085: Maximum efficiency was for medium energy wet scrubbers $\rightarrow 65\%$

$$E_{N_{NO_x}} = 0.35 \times E_{u_{NO_x}} = 0.35 \times 1.87 \frac{\text{lbs}}{\text{TON}} = 0.65 \frac{\text{lbs}}{\text{TON}}$$

$$\boxed{E_{N_{NO_x}} = 0.65 \frac{\text{lbs}}{\text{TON}}}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By K. Tower Date 2/7/75

Source Industrial/Commercial Incinerators

There is no technology available that is known for the control of SO_x, CO, HC emissions from industrial/commercial incinerators. In order to maximize the potential impact for these sources we assume $E_N = 0$.

$$E_{N_{SO_x}} = 0.00 \text{ lbs/Ton}$$

$$E_{N_{CO}} = 0.00 \text{ lbs/Ton}$$

$$E_{N_{HC}} = 0.00 \text{ lbs/Ton}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By K.Tower Date 2/3/75
 Source Industrial/Commercial Incinerators

E_s

Ref 163, p.33 Table 1 gives a distribution by state of IIA incinerator units. We assume this to be the same distribution as that for industrial/commercial incinerators. The following is a list of the top contributors and the individual states' allowable emissions (ref 084, ^{Ref} 148) based on an average process weight rate for industrial/commercial incinerators as 228 lbs/hr. → ref 163, p.35.

State	%	Allowable Emissions (lbs/hr)
Illinois	8.58	0.82
Indiana	8.0	0.94
Massachusetts	5.12	0.95
Michigan	5.61	0.94
Minnesota	6.21	0.94
New York	5.57	0.89
Ohio	10.62	0.94
Wisconsin	<u>11.94</u>	<u>0.95</u>
	<u>61.65</u>	

$$\begin{aligned} \text{Allowable Emissions} = & (.086)(0.82) + (.08)(0.94) + (.051)(0.95) + (.056)(0.94) + \\ & (.062)(0.94) + (.056)(0.89) + (.106)(0.94) + (.119)(0.95) + \\ & (1.00 - .6165) \times (\text{Allowable Emissions}) \end{aligned}$$

$$\begin{aligned} \text{Allowable Emissions} = & \frac{.071 + .075 + .048 + .053 + .058 + .050 + .100 + .113}{.616} \end{aligned}$$

$$\begin{aligned} \text{Allowable Emissions} = & .922 \text{ lbs/hr.} \end{aligned}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By K.Tower Date 2/3/75

Source Industrial/Commercial Incinerators

E_s (cont)

$$E_{s_{PT}} = \frac{(0.922 \text{ lbs/hr})(2000 \text{ lbs/TON})}{(228 \text{ lbs/hr})} = 8.09 \text{ lbs/TON}$$

Since this value is greater than $E_{u_{PT}}$ we will assume
 $E_{s_{PT}} = E_{u_{PT}}$.

$$E_{s_{PT}} = 6.47 \text{ lbs/TON}$$

Specific regulations applicable to incinerator emissions other than particulate do not exist and no general regulations were seen to apply $\therefore E_s = E_u$ Ref (84), (148)

$$E_{s_{SO_x}} = 2.38 \text{ lbs/TON}$$

$$E_{s_{NO_x}} = 1.87 \text{ lbs/TON}$$

$$E_{s_{CO}} = 8.97 \text{ lbs/TON}$$

$$E_{s_{HC}} = 2.88 \text{ lbs/TON}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By K. Tower Date 2/3/75

Source Industrial/Commercial Incinerators

Summary of Emission Factor

Pollutant	E_u (lb/ton)	E_N (lb/ $\frac{TON}{hr}$)	E_S (lb/ $\frac{TON}{hr}$)
Particulate	6.47	0.065	6.47
SO _x	2.38	0.00	2.38
NO _x	1.87	0.65	1.87
CO	8.97	0.00	8.97
Hydrocarbons	2.88	0.00	2.88

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marrone Date 9-12-74

Source Municipal Incinerators


K:

Ref 085 Fig III-8 pg III-24

Plant use factor 1968 = 50%

Plant use factor 2000 = 65%

Assuming a linear relationship of factor growth during this period we may establish the following graph.



We will use this average plant use factor for the period 1975 - 1980 as an estimate of plant utilization of capacity (K)

$$K = .56$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards


Computation Sheet For Industrial Factors

Calculations Done By W. Marvone Date 9-12-74

Source Municipal Incinerator

A: Ref. 085 Fig III-7 pg III-23

Projected total active incinerator capacity is presented which we have graphed below



We assume a plant schedule of 250 hr/yr , 24 hr/day
 and may estimate the 1975 annual cap as $A = 250 \text{ Day} \times (130 \times 10^3) \frac{\text{Ton}}{\text{Day}}$
 $A = 3.25 \times 10^7 \text{ T/yr}$

$\therefore A = 32.5 \times 10^6 \text{ T/yr}$ refuse burned

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Manrone Date 9-12-74

Source Municipal Incinerators

P_c :

An estimate of growth during the period 1975 to 1985 is obtained by referring to our graph of Incinerator Cap.

The growth is assumed linear

$$\frac{(190 \times 10^3) - (100 \times 10^3)}{15 \text{ year}} = 6 \times 10^3 \text{ TPD/yr}$$

$$P_c = \frac{6 \times 10^3 \text{ TPD/yr}}{130 \times 10^3 \text{ TPD}} = .046$$

based on 1975
base-line year
(simple growth)

$P_c = .046 \text{ simple}$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W.J. Massone Date 9-12-74

Source Municipal Incinerators

P_B :

Ref 062 pg I-40 (Appendix)

Average life of incinerator based on the replies of 87 operating plants gave a value of 25.73 yrs. Using this expected life to estimate P_B

$$\frac{100\% \text{ depreciation}}{25.73 \text{ year}} = 3.88\%/\text{yr simple}$$

$$P_B \cong .039 \text{ simple}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marone Date 9-12-74

Source Municipal Incinerators

E_u : The following uncontrolled emission factors were obtained from Table III-6 of Ref 085


E_u lb/TON refuse

Pt (total)	19.7 lb/TOW
HC	2.7
CO	34.8
NO _x	3.0
SO _x	3.9

In addition HCl has been cited as a growing emission due to increase plastic (PVC) disposal. Table III-5 pg III-20 of Ref 085 gives a tabulation of HCl uncontrolled emission factors as a function of year from 1961-2000. This factor increases due to a growth in the percentage of plastics in refuse burned. Attached graph plots the estimates of HCl emission factors.

The average emission factor between 1975-1985 developed from the straight-line ~~fitted~~ through the data will be used to approx. an uncontrolled HCl emission factor.

HCl Emission Factor lb/TON Refuse



TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marone Date 9-12-74
 Source Municipal Incinerator

E_u : cont'd

$$\therefore E_{u_{Hg}} = 2.75 \text{ lb/tow refuse}$$

Trace metals were discussed on pg III-18 of Ref-085
 Zinc, Lead, Cadmium, Selenium are identified however,
 data were not available.

We were not able to determine specific or total
 trace metal emission factors.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marone Date 9-12-74

Source Municipal Incinerators

E_N :

Table VI - 2 of Ref 085 suggests that the greatest share of the control market on municipal incinerators will be held by

- ① Dry Mechanical Cyclones
- ② Medium Energy Wet Scrubbers
- ③ Electrostatic Precipitators

Bag Fabric Filters do not appear attractive (although believed to be effective) to incinerator designers and/or operators.

The "proposed standards" (Ref 147 Tech Report No 2) state that a 90-95% eff would be required to meet the standard level. Electrostatic Prec, Bag Filters, and high energy scrubbers are being used and all may achieve this level.

Particulate

We assume that the attainable collection efficiency for total particulate (between the 99% of mineral and 90% for combustible in Ref 085 Table VI -1) will be achieved by best available technology and be about 95%.

$$E_N = .05 \times E_u = .05 \times 19.7 = .985$$

$\therefore E_N = .99 \text{ lb/ton refuse}$ Particulates

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marone Date 9-12-74
 Source Municipal Incinerator

E_N : cont'd

HCl

Due to the high solubility of HCl in water, we expect a good collection efficiency in a wet scrubber.

Ref 085 Table VII-1 Medium Energy Scrubber 95% eff
 for HCl

$$E_N = .05 \times E_u = .05 \times 2.75 = .138$$

$$E_N \approx .14$$

$\therefore E_N = .14 \text{ lb/Ton refuse}$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marrone Date 9-12-74
 Source Municipal Incinerators

E_N :

NO_x CO HC

Modifications in combustion design and/or operation are the prime options available to reduce NO_x emissions. Carbon Monoxide and hydrocarbons are suspected of being associated Ret 085 pg II-39

$$\text{CO:HC} = 13:1$$

Reduction of CO (known HC) is best handled by improved incinerator operation or design pg III-16 Ret 085. APC devices are inadequate or ineffective at controlling these emissions.

Only wet scrubbing devices are shown to control to some extent nitrogen oxides.
 Table II-1 Ret 085: Max eff was for Med-Energy Wet Scrubber 65%.

We will use 65% eff for NO_x and assume that CO, HC are only lightly controlled.

More data on incinerator design features may suggest the optimum operating parameters, which would result in the lowest NO_x, HC, CO relationship concurrent with acceptable incineration performance. We will refine this when such data appears.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marone Date 9-12-74
 Source Municipal Incinerators

E_N cont'd

NO_x, CO, HC

$$E_N(\text{NO}_x) = .35 \times E_u = .35 \times 3.0$$

$$E_N(\text{NO}_x) \approx 1.1 \text{ lb/TON refuse}$$

Since control for municipal incinerators do not apply to CO and HC then, $E_N = 0$ for maximum impact determination

$$E_N = 0 \text{ (HC)}$$

$$E_N = 0 \text{ (CO)}$$

SO_x

Ref 097 pg 93

states that sulfur oxide emission from municipal incinerators are not normally controlled.

E_N is assumed = 0 for maximum impact demonstrated control tech not available

$$E_N(\text{SO}_x) = 0$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Morrone Date 10-24-74
 Source Municipal Incinerators

E_S : Particulate

Ref 062 pg I-27 Average Plant Size 400 TPD

$$\frac{400 \text{ TPD} \times 2000 \text{ lb}}{24 \text{ hr}} \cong 33,300 \text{ lb/hr}$$

It is assumed that this average plant size is typical of ~~existing~~ and new plants

The attached tables of emission limitations was used to estimate a synthesized value for E_S for ~~existing~~ and new municipal incinerators.

The following conditions or assumptions were employed:

- (a) Alaska and Nevada have ^{and new} opacity req for existing incinerators
 We assume $E_{Si} = E_u$
- (b) California has no state-wide req - use $E_{Si} = E_{SAvg}$
 (Existing and New)
- (c) Delaware: (Existing & New) has no req above 3000 lb/hr cap
 therefore we assume $E_{Si} = E_u$
- (d) Illinois has no req for existing incin above 2000 lb/hr
 therefore we assume $E_{Si} = E_u$
- (e) New Mexico does not permit incineration after 1976
 Therefore it is not included in calculation.
- (f) Oklahoma emission equation gives $\approx .10 \text{ lb}/100\text{lb}$ for 33,300 lb/hr
 (Existing & New)

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marrone Date 10-24-74
 Source Municipal Incinerator

E_s : particulate cont'd

(g) North Dakota emission equation gives $\approx .08 \text{ lb}/100 \text{ lb}$ for $33,300 \text{ lb}/\text{hr}$
 (Existing & New)

(h) S. Carolina has reg based on heat input. We assume
 $E_{si} = E_{s\text{Avg}}$ (Existing & New)

(l) Texas has no gen regulation (assume $E_{si} = E_{s\text{Avg}}$)
 [Existing & New]

(j) Utah require 85% control (Existing & New) $\therefore E_{si} = .15 \times E_u$

*(k) In the end, since NSPS has been ~~suggested~~ proposed for Municipal Incinerator $> 50 \text{ TPD}$ then $E_s(\text{new})$ must be at least as good as NSPS

Ref 147 pg 19 $E_{allow} = 1.9 \text{ lb}/\text{TOW waste}$

or $.095 \text{ lb}/100 \text{ lb}$

Any state standard $< .095 \text{ lb}/100 \text{ lb}$ will be kept

Any state standard $> .095 \text{ lb}/100 \text{ lb}$ will be changed to $.095 \text{ lb}/100 \text{ lb}$

Note Promulgated standard is $.08 \text{ gr/sec}$ as opposed to $.1 \text{ gr/sec}$
 for proposed standard.

Ref 273
 pg 24880

$$\therefore \text{NSPS} = \frac{.08}{.10} \times .095 \text{ lb}/100 \text{ lb} = .076 \text{ lb}/100 \text{ lb}$$

This value of $.076 \text{ lb}/100 \text{ lb}$ will be used to replace the limit of $.095 \text{ lb}/100 \text{ lb}$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marone Date 10-24-74

Source Municipal Incinerator

E_s : particulate cont'd

"Existing Plants"

51 states - 1 (N.Dak) = 50 states to consider
 with each acting equally which is equivalent
 to taking the average

$$1. E_{sc} = E_u \quad 4 \times E_u = 4 \times (19.7 \frac{\text{lb}}{\text{ton}} \times \frac{\text{ton}}{2000 \text{lb}}) \times 100 = 4 \times .985 \frac{\text{lb}}{100 \text{lb}} \\ = 3.94 \text{ lb}/100 \text{lb}$$

$$2. \sum E_{sc} \quad 42 \text{ states} \quad \sum E_{sc} = 6.81$$

$$3. E_{sc} = E_{SAvg} \quad 3 \text{ state} \quad 3 E_{SAvg}$$

$$4. Utah \quad E_{sc} = .15 \times E_u = .15 \times 19.7 \frac{\text{lb}}{\text{ton}} \times \frac{\text{ton}}{2000 \text{lb}} \times 100 = .15 \text{ lb}/100 \text{ lb}$$

3.94

6.81

.15

$3 \times E_{SAvg}$

$$\text{or } \frac{10.9 + 3 E_{SAvg}}{50} = E_{SAvg} = \frac{10.9}{47}$$

$$E_{SA} \approx .23 \text{ lb}/100 \text{ lb} \text{ (Existing Incin)}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marzzone Date 5-8-75

Source Municipal Incinerator

E_s : cont'd

Particulate

"New Plants"

- ① 42 states have limit $> .076 \text{ lb/100lb}$
- ② 1 state has limit $< .076 \text{ lb/100lb}$ $E_{s_i}(\text{new}) = .02 \text{ lb/100lb}$
- ③ 1 state does not permit incineration $E_{s_i}(\text{new}) = 0$
- ④ 7 states have values for allowable emission which are unknown
we assume they represent $E_s \text{ Avg}$

Therefore

$$\frac{42}{44} (.076) + \frac{1}{44} (.02) + \frac{1}{44} (0) = E_s^{(\text{new})}$$

$$.073 + .00045 + 0 = .073 \text{ lb/100lb} \cdot \frac{20 \text{ (100)}}{78.5}$$

$$E_s^{(\text{new})} = 1.46 \text{ lb/TON waste}$$

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marrone Date 5-8-75

Source Municipal Incinerator

E_s : Particulate

Existing Incinerator

$$E_{sA} = .23 \frac{\text{lb}}{100\text{lb}} \times 20 \frac{(\text{100lb})}{\text{TON}} = 4.6 \text{ lb/TON}$$

$$E_s (\text{existing}) = 4.6 \text{ lb/ton waste}$$

$$E_s (\text{new}) = 1.46 \text{ lb/ton waste}$$

Incineration Sources
lb Part / 100 lb Refuse Charge.

17 of 22

Existing Sources

Capacity lb/hr

	1200	2200	22000	21000	44000	24000	240000	Other	All	COMMENT
Alabama	.20	.20	.20	.20	.20	.20	.20		.20	opacity only
Alaska										
Azores	.22	.22	.22	.22	.22	.22	.22		.22	
Kansas	.29	.19	.19	.19	.19	.19	.19			
Colorado	.15	.09	.09	.09	.09	.09	.09			only county reg
California										
Conn.	.23	.23	.23	.23	.23	.23	.23		.23	no reg above 3000 lb/hr
Delaware	.20	.20	.20	.18	.16	Eu	Eu			
D.C.	.08	.08	.08	.08	.08	.08	.08		.08	
Florida										
Georgia	.19	.19	.19	.19	.19	.19	.19		.19	
Hawaii	.20	.20	.20	.20	.20	.20	.20		.20	
Idaho	.20	.20	.20	.20	.20	.20	.20		.20	
Illinois	.19	.19	.19	—	Eu	—	Eu			no reg above 2000
Indiana	.39	.39	.39	.23	.23	.23	.23			
Iowa	.33	.33	.33	.19	.19	.19	.19			
Kansas	.29	.19	.19	.19	.19	.19	.19			
Kentucky	.19	.19	.19	.19	.19	.19	.19		.19	
Louisiana	.19	.19	.19	.19	.19	.19	.19		.19	
Maine	.19	.19	.19	.19	.19	.08	.08			
Maryland	.29	.19	.19	.19	.19	.19	.19			
Mass.	.09	.09	.09	.09	.09	.09	.09		.09	
Michigan	.30	.30	.30	.30	.30	.30	.30		.30	
Minn.	.30	.20	.20	.10	.10	.10	.10			
Miss.	.19	.19	.19	.19	.19	.19	.19		.19	
Missouri	.29	.19	.19	.19	.19	.19	.19			
Montana	.29	.19	.19	.19	.19	.19	.19			
Nebraska	.19	.19	.19	.09	.09	.09	.09			
Nevada										
N.H.	.29	.19	.19	.19	.19	.19	.19			
N.J.	.19	.19	.19	.09	.09	.09	.09			
N.M.	0	0	0	0	0	0	0		0	main not permitted
N.Y.	.35	.35	.35	.35	.35	.35	.35		.50	.2 for NYC
S.C.	.20	.20	.20	.02	.02	.02	.02			
S.D.										
Ohio	.10	.10	.10	.10	.10	.10	.10			emission operation

Existing Cont'd

	≤ 200	$200 < 250$	$250 < 3000$	$3000 \leq 20000$	$20000 < 40000$	$40000 \leq 240000$	≥ 240000	other	All	comment
Oklahoma				use avg						emission equation
Oregon	.29	.19	.19	.19	.19	.19	.19			
Tenn.	.09	.09	.09	.09	.09	.09	.09		.09	
R.I.	.15	.15	.15	.08	.08	.08	.08			
S. Carolina			use avg							reg based on heat input
S. Dakota	.20	.20	.20	.20	.20	.20	.20		.20	
Tennessee	.60	.40	.40	.40	.40	.40	.40			
Texas			use avg							
Utah			$\leftarrow .15 \times Eu \rightarrow$							
Vermont	.10	.10	.10	.10	.10	.10	.10		.10	
Virginia	.13	.13	.13	.13	.13	.13	.13		.13	
Washington	.09	.09	.09	.09	.09	.09	.09		.09	
W. Virginia	.41	.27	.27	.27	.27	.27	.13			
Wisconsin	.34	.27	.27	.27	.27	.27	.27			
Wyoming	.20	.20	.20	.20	.20	.20	.20		.20	

Incineration Sources

19 of 22

lb Port / 100 lb Refuse Charged

New Sources

	<u>Capacity lb/hr</u>							other	All	comment
	<200	2-200	200-3000	3000-4000	4000-24000	24000-210000	>210000			
Alabama	.20	.20	.20	.20	.20	.20	.20		.20	
Alaska	.29	.19	.19	.09	.09	.09	.09			
Arizona	.22	.22	.22	.22	.22	.22	.22		.22	
Oklahoma	.29	.19	.19	.19	.19	.19	.19			
Colorado	.15	.09	.09	.09	.09	.09	.09			
California			use avg.							city country reg
Conn.	.08	.08	.08	.08	.08	.08	.08		.08	
Delaware	.20	.20	.20	.18	.16	Eu	Eu			no reg above 3000 lb/hr
D.C.	.03	.03	.03	.03	.03	.03	.03		.03	
Florida	—	—	—	—	—	.08	.08			no reg below 4000 lb/hr
Georgia	.10	.10	.10	.10	.10	.08	.08			
Hawaii	.20	.20	.20	.20	.20	.20	.20		.20	
Idaho	.20	.20	.20	.20	.20	.20	.20		.20	
Illinois	.09	.09	.09	.08	.08	.08	.08		.05	
Indiana	.39	.39	.39	.23	.23	.23	.23			
Iowa	.33	.33	.33	.19	.19	.19	.19			
Kansas	.29	.19	.19	.19	.19	.19	.19			
Kentucky	.19	.19	.19	.19	.19	.08	.08			
Louisiana	.19	.19	.19	.19	.19	.19	.19			
Maine	.19	.19	.19	.19	.19	.08	.08			
Maryland	.09	.09	.09	.03	.03	.03	.03			
Mass.	.05	.05	.05	.05	.05	.05	.05		.05	
Michigan	.30	.30	.30	.30	.30	.30	.30		.30	
Minn.	.30	.20	.20	.10	.10	.10	.10			
Miss.	.09	.09	.09	.09	.09	.09	.09		.09	
Missouri	.29	.19	.19	.19	.19	.19	.19			
Montana	.29	.19	.19	.19	.19	.19	.19			
Nebaska	.19	.19	.19	.09	.09	.09	.09			
Vermont	—	use	Eu							opacity only
N.H.	.29	.19	.19	.19	.19	.19	.19			
N.J.	.19	.19	.19	.09	.09	.09	.09			
Mexico	0	0	0	0	0	0	0		0	Intra not permitted
New York	.25	.25	.35	.25	.25	.25	.22			.2 for NYC
S.C.	.20	.20	.20	.02	.02	.02	.02			
S.D.	use	Avg								- emission equation
Ohio	.10	.10	.10	.10	.10	.10	.10			

New cont'd

	1200	2200	42000	32000	44000	24000	310,000	other	All	COMMENT
Oklahoma				use avg						Emissions equation
Oregon	.09	.09	.09	.09	.09	.09	.09		.09	
Penn.	.09	.09	.09	.09	.09	.09	.09		.09	
R.I.	.15	.15	.15	.08	.08	.08	.08			
S. CAROLINA			use avg							
S. DAKOTA	.20	.20	.20	.20	.20	.20	.20		.20	
TENNESSEE	.20	.20	.20	.10	.10	.10	.10			
TEXAS			use avg							
Utah			$\leftarrow .15 \times \text{Eu} \rightarrow$							
Vermont	.10	.10	.10	.10	.10	.10	.10		.10	
Virginia	.13	.13	.13	.13	.13	.13	.13		.13	
Washington	.09	.09	.09	.09	.09	.09	.09		.09	
W. Virginia	.41	.27	.27	.27	.27	.27	.13			
Wisconsin	.17	.11	.11	.11	.11	.08	.08			
Wyoming	.20	.20	.20	.20	.20	.20	.20		.20	

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By D. Marzzone Date 10-24-74

Source Municipal Incinerators

E_s : cont'd.

Specific regulations applicable to incinerator emissions other than particulate do not exist and no general regulations were seen to apply $\therefore E_s = E_u$

$$E_s(\text{HC}) = 2.7 \text{ lb/ton refuse}$$

$$E_s(\text{CO}) = 34.8 \text{ lb/ton refuse}$$

$$E_s(\text{NO}_x) = 3.0 \text{ lb/ton refuse}$$

$$E_s(\text{SO}_x) = 3.9 \text{ lb/ton refuse}$$

$$E_s(\text{HCl}) = 2.75 \text{ lb/ton refuse}$$

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marzzone Date 10-31-74

Source Municipal Incinerator

$E_{III\alpha}$: HCl

Adoption of a wet scrubbing system to control HCl emissions was proposed as suitable for municipal incineration achieving about 75% efficiency. It does not appear impractical to expect this collection efficiency on a retro-fitted scrubber.

$$\therefore E_{III\alpha} = E_N$$

$$E_{III\alpha} = .14 \text{ lb/TON refuse}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W.J. Marrone Date 9-10-74

Source Pathological Incinerators (Animal Shelters; Crematories)

K:

Ref 038 Table 51 pg 153

For the five pathological incinerator installations listed we may estimate burning/capacity ratio for three of them.

$$\textcircled{1} \quad \frac{B}{C} = \frac{130}{300} = .433$$

$$\textcircled{4} \quad \frac{B}{C} = \frac{29}{85} = .341$$

$$\textcircled{5} \quad \frac{B}{C} = \frac{93}{400} = .233$$

Operating schedules vary widely from 830 hr/yr to 4730 hr/yr. Assuming 5 d/wk and 52 wk/yr (260 d/yr), the daily hr usage for the 5 installations are:

$$\textcircled{1} \quad \frac{3280}{260} = 12.6 \text{ hr/day}$$

$$\textcircled{2} \quad \frac{4730}{260} \approx 18.2 \text{ hr/day}$$

$$\textcircled{3} \quad \frac{1040}{260} = 4 \text{ hr/day}$$

$$\textcircled{4} \quad \frac{830}{260} \approx 3.2 \text{ hr/day}$$

$$\textcircled{5} \quad \frac{2340}{260} = 9 \text{ hr/day}$$

} Aug 9.4 hr/day
or
 $9.4 \times 260 = 2444 \text{ hr/yr}$

TRC --- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marrone Date 9-10-74

Source Pathological Incinerators (Animal shelters & Crematories)

K: contd

Our best estimate of a utilization factor for this source will be based on an average value for the ratio of B/C calculated above (3 installations)

We see that these estimates are based on three plants having time schedules spanning the full range of calculated values ; 3.2 hr/day for ④ low
 9 hr/day for ⑤ medium
 12.6 hr/day for ① high

$$\text{Average } \frac{B}{C} = \frac{.433 + .341 + .233}{3} = .336$$

$$\text{approx } K \equiv \frac{B}{C} \equiv .34$$

$$\therefore K = .34$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By 2). Mannone Date 9-10-74

Source Pathological Incinerators (Animal Shelters; Crematories)

A: Waste consumed in pathological incinerators was developed from data presented in Ref 038 pg 152-155

Animals Incinerated:	1968	26,000 T/yr
	1973	30,000 T/yr
	1978	34,500 T/yr

Cremations:	1968	83,977 bodies
	1973	94,500 bodies
	1978	105,000 bodies

We calculate the mass rate for cremation using the factor of 255 lb ^{cremation} for converting to ton/yr of human bodies. This figure was obtained from pg 155 of the above source.

$$\frac{\text{bodies}}{\text{yr}} \times \frac{255 \text{ lb}}{\text{body}} \times \frac{\text{Ton}}{2000 \text{ lb}} = \text{Ton/yr}$$

Cremation Mass Rate	1968	10,707 T/yr
	1973	12,049 T/yr
	1978	13,388 T/yr

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marone Date 9-10-74

Source Pathological Incinerators (Animal Shelters & Crematories)

A: cont'd

The process weights consumed for animal and crematory sources is plotted along with the totals for the period 1963 to 1978 (see attached graph).

From this graph and the curve of total wastes consumed we may estimate the figure for 1975. This is done by calculating a compound growth between 1973 and 1978

$$P_c = \sqrt[5]{\frac{47,888}{42,049}} - 1$$

$$P_c = \sqrt[5]{1.1388} - 1$$

$$P_c = .026 \text{ compound}$$

then

$$1975 = 1973 (1 + .026)^2$$

$$1975 = 42,049 (1.026)^2$$

$$1975 \approx 44,265 \text{ T/yr}$$

Using $K = .34$ we determine the 1975 Prod Cap as is


$$A = \frac{44,265}{.34} = 130,191 \text{ T/yr}$$

$$\therefore A = 130,191 \text{ T/yr}$$

Pathological Waste Rates (Animal Shelters & Crematories)

5 of 6

All Data from Ref 038 pg 152 - 155



TRC --- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marrone Date 9-10-74

Source Pathological Incinerators (Animal Shelters & Crematories)

P_c :

We will use the compound growth determined above for the period 1973 - 1978 and assume it applicable to 1975 - 1985

$$\therefore P_c = .026 \text{ compound}$$

P_B :

Ref 037 did not specify a category which would be applicable to pathological incinerators. We will assume that the obsolescence rate will be approximated by the P_B for municipal incinerators

$$P_B \approx .039 \text{ simple}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By 2). Marjorie Date 9-10-74

Source Pathological Incinerators (Animal Shelter & Crematory)

E_u : From Ref 038 Table 50 pg 151

	E_u
Particulate	12.8 lb/ton waste
NOx	25 lb/ton waste
HC	3.8 lb/TON waste
CO	4.1 lb/TON waste

From Ref 075 Table 2.1-1 pg 2.1-3

	E_u
Particulate	8 lb/ton
NOx	3 lb/TON
HC	Neg
SOx	Neg
CO	Neg

Ref 046 pg 485 Table 129

Avg NOx 8 Tests 11.5 lb/TON

Avg HC (Avg of Avg from 84 Tests) .93 lb/TON

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Manrone Date 9-10-74

Source Pathological Incinerator

E_u : cont'd

There is a wide variation in reported emission quantities in the literature. We are lead to use the values appearing in Ref 038 since this is derived from more recent data.

Therefore:

	<u>E_u</u> lb/TON waste
Particulate	12.8
Hydrocarbons	3.8
Carbon Monoxide	4.1
Nitrogen Oxides	25.0

Good equipment design and operating practices are cited by Ref 038 pg 149 and Ref 046 pg 485-486 as the best means of maintaining emission control. Minimum levels due to these practices were not found in the literature.

Wet scrubbers are indicated in Ref 038 pg 149 as useful in controlling smoke, odor, and particulates.

Ref 046 pg 486 states that an afterburner is applicable to pathological incinerator control.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marrone Date 9-10-74

Source Pathological Incinerators

E_N : cont'd.

Achievable control efficiency were not found in the literature for pathological incinerators

We assume: ① 85% control of Pt (wet scrubber or improved design & operation)

② 99% control of CO and HC in well designed incinerator - afterburner package

③ 50% reduction in NO_x emission due to improved incinerator design and operation

$$E_N \text{ Pt} = .15 \times E_u = .15 \times 12.8 = 1.9 \text{ lb/Ton}$$

$$E_N \text{ HC} = .01 \times E_u = .01 \times 3.8 \approx .04 \text{ lb/Ton}$$

$$E_N \text{ CO} = .01 \times E_u = .01 \times 4.1 \approx .04 \text{ lb/Ton}$$

$$E_N \text{ NO}_x = .5 \times E_u = .5 \times 25 \approx 12.5 \text{ lb/Ton}$$

* May Assum $E_N(\text{NO}_x) = 0$ for max impact

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By D. Marrone Date 9-10-74

Source Pathological Incinerators (Animal Shelters & Crematory)

From our survey of the literature in particular, Ref 075, 038, and 046 it appears that most if not all of the incinerators mentioned used natural gas as the fuel.

Due to the low sulfur content of gas we would not expect significant sulfur oxide emission.

SO_x is a negligible emission from pathological incinerators

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards


Computation Sheet For Emission Factors

Calculations Done By W. Marrone

Date 10-24-74

Source Pathological Incinerator

E_s :



Total installations = 399

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By 2) Mannone Date 10-24-74

Source Pathological Incinerators

E_s : cont'd

Taking the 1975 capacity of 130,191 T/yr
 and the 399 installation we estimate an
 average incinerator capacity

$$\frac{130,191 \text{ T/yr}}{399} = 326 \text{ T/yr capacity per incinerator}$$

$$\text{Assuming: } 8 \text{ hr/day} \times \frac{5 \text{ d}}{\text{wk}} \times \frac{52 \text{ wk}}{\text{yr}} = 2080 \frac{\text{hr}}{\text{yr}}$$

$$\begin{aligned} \text{Avg Process Weight} &= \frac{326 \text{ T/yr}}{\text{yr}} \times \frac{2000 \text{ lb}}{\text{T/yr}} \times \frac{\text{yr}}{2080 \text{ hr}} \\ &= 313 \text{ lb/hr} \end{aligned}$$

Emission regulations for incinerators is applied to pathological incinerators in this investigation. All state will be considered to have equivalent capacity so that an average limitation estimate would suffice. E_s is calculated for Existing and New Facilities. Ref to the Attached Tables under "Municipal Incinerators E_s " for pertinent State allowable levels.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marzzone Date 10-24-74
 Source Pathological Incinerator

E_s : cont'd

The following assumptions or conditions were employed :

(1) Alaska (Existing) has only opacity reg assume $E_{sc} = E_u$

(2) California (Existing & New) has no state-wide Reg.
 Use $E_{sc} = E_{sAvg}$

(3) Florida (Existing & New) has no reg applicable < 4000 lb/hr
 use $E_{sc} = E_u$

(4) Nevada (Existing & New) has only opacity regu. Assum $E_{sc} = E_u$

(5) New Mexico does not permit incineration after 1976
 Therefore it is not included in calculation

(6) North Dakota emission equation (Existing & New) yields .29 lb/100lb

(7) Oklahoma emission equation (Existing & New) yields .30 lb/100lb

(8) S. Carolina (Existing & New) based on heat input - use $E_{sc} = E_{sAvg}$

(9) Texas has no gen regulation - use $E_{sc} = E_{sAvg}$ (New < Existing)

(10) Utah (New & Existing) require 85% control $E_{sc} = .15 \times E_u$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marzzone Date 10-24-74

Source Pathological Incinerators

E_s : cont'd

Particulates

"Existing Incin" based on 50 states

$$\textcircled{1} \quad E_{si} = E_u ; \quad 3 \text{ states} \times E_u = 3 \times \left(12.8 \frac{\text{lb}}{\text{ton}} \times \frac{\text{ton}}{2000 \text{ lb}} \times 100 \right) = 3 \times .64 = 1.92 \frac{\text{lb}}{100 \text{ lb}}$$

$$\textcircled{2} \quad E_{si} = E_{SAvg} \quad 3 \text{ states} \times E_{SAvg}$$

$$\textcircled{3} \quad \text{Utah} \quad E_{si} = .15 \times E_u = .15 \times \left(12.8 \times \frac{1}{2000} \times 100 \right) = .096 \text{ lb}/100 \text{ lb}$$

$$\textcircled{4} \quad \sum E_{si} \quad 43 \text{ states} \quad \sum E_{si} = 8.72 \text{ lb}/100 \text{ lb}$$

$$\begin{array}{r} 1.92 \\ .096 \\ \hline 8.72 \end{array} \quad 10.74 + 3 E_{SAvg}$$

$$\frac{10.74 + 3 E_{SAvg}}{50} = E_{SAvg}$$

$$E_{SAvg} = \frac{10.74}{47}$$

$$E_{SAvg} = .23 \frac{\text{lb}}{100 \text{ lb}}$$

(Existing)

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marrone Date 10-24-74
 Source Pathological Incinerator

E_S : cont'd Particulates

"New Incin" based on 50 states

$$\textcircled{1} \quad E_{Sc} = E_u ; \quad 2 \text{ states} \times E_u \quad 2 \times (12.8 \times \frac{I}{2000} \times 100) = 2 \times .64 \\ = 1.28 \text{ lb/100 lb}$$

$$\textcircled{2} \quad E_{Sc} = E_{SAvg} \quad 3 \text{ states} \times E_{SAvg}$$

$$\textcircled{3} \quad \text{Utah} \quad E_{Sc} = .15 \times E_u = .15 (12.8 \times \frac{I}{2000} \times 100) = .096 \text{ lb/100 lb}$$

$$\textcircled{4} \quad \sum E_{Sc} \quad 44 \text{ states} \quad \sum E_{Sc} = 7.72 \text{ lb/100 lb}$$

$$\begin{array}{r} 7.72 \\ 1.28 \\ .096 \\ \hline 9.096 \end{array}$$

$$\frac{9.096 + 3E_{SAvg}}{50} = E_{SAvg}$$

$$E_{SAvg} = \frac{9.096}{47} = .19$$

$$E_{SAvg} = .19 \\ (\text{New})$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W.J. Marrone Date 10-24-74

Source Pathological Incinerators

E_s : cont'd Particulates

$$E_s(\text{Existing}) = \frac{.23 \text{ lb}}{100 \text{ lb}} \times \frac{1}{100} \times \frac{2000 \text{ lb}}{\text{TON}} = 4.6 \text{ lb/TON}$$

$$E_s(\text{New}) = \frac{.19 \text{ lb}}{100 \text{ lb}} \times \frac{1}{100} \times \frac{2000 \text{ lb}}{\text{TON}} = 3.8 \text{ lb/TON}$$

$$E_s(\text{Existing}) = 4.6 \text{ lb/TON}$$

$$E_s(\text{New}) = 3.8 \text{ lb/TON}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marrone Date 10-24-74

Source Pathological Incinerators

E_s : cont'd

Regulations specifically or generally applicable to pathological incinerators for HC, CO, NO_x pollutants were not found in state reg (Ref 084 & 148)

Therefore $E_s = E_u$

$$E_s(\text{HC}) = 3.8 \text{ lb/Ton waste}$$

$$E_s(\text{CO}) = 4.1 \text{ lb/Ton waste}$$

$$E_s(\text{NO}_x) = 25.0 \text{ lb/Ton waste}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marrone Date 1-29-75

Source Pathological Incinerators

Trace Metals:

E_u : Emission factors for trace metals was not obtained from the literature.

Ref 270 pg 69 Table 3.1 gives a breakdown of animal tissue by element

We will use the figures for the major metals identified. Although this composition is given for man, we make the assumption that animal tissue will not be significantly different

	<u>wt %</u>
Magnesium	.05
Iron	.004
Manganese	.0003
Copper	.0002
	<u>.0545 % by wt</u>

Other elements (metals) are identified but are not quantified. We believe that the above covers the majority of the trace metals.

$$\frac{.0545\%}{100\%} \times \frac{2000\text{ lb}}{\text{TON}} = 1.09 \text{ lb/TON waste}$$

TOTAL
TRACE
METALS
AVAILABLE

Judgment at this time leads us to assume that 50% of the trace metals are emitted from the incinerator along with particulates

$$E_u = .5 \times 1.09 = .545 \text{ lb/TON waste}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Morrone Date 1-29-75

Source Pathological Incinerator

Trace Metals cont'd

$$E_u \approx .545 \text{ lb/ton waste}$$

E_N :

We see that the trace metal to particulate emissions ratio for pathological incinerators is $\frac{.545 \text{ lb Tr Met}}{12.8 \text{ lb Pt}} \approx .0426 \frac{\text{lb Tr Met}}{\text{lb Pt}}$

It is assumed that particulate control will be as effective on trace metals so that

$$E_N(\text{TM}) = .15 \times .545 \text{ lb/ton} \approx .082 \text{ lb/ton waste}$$

$$E_N = .082 \text{ lb/ton waste}$$

We assume $E_{\text{IId}} = E_N$

controls can be applied to existing plants as effectively as new plants

$$E_{\text{IId}} = .082 \text{ lb/ton waste}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marrone Date 1-29-75
 Source Pathological Incinerators

Trace Metals, cont'd

E_S :

Although there are no regulations applicable to trace metals we assume that particulate emission regulation will by "de facto" impose limits on trace metals.

$$E_S(TM) = E_S(PI) \times .0426 \frac{lb\ Tr\ met}{lb\ PI}$$

$$E_{S(Exit)}(Trace\ Met) = 4.6 \times .0426 = .196 \frac{lb}{TON} \text{ waste}$$

$$E_{S(New)}(Trace\ Met) = 3.8 \times .0426 = .162 \frac{lb}{TON} \text{ waste}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marrone Date 1-27-75

Source Sludge Incineration - Municipal

K:

Ref 266 pg 14

Most incinerators that have been built are reported to be operated at throughputs much less than designed for present municipality

Referring pg 15 Table 1 of the above ref we see that the units tested by EPA had operating rates ranging from 35% to 100% of capacity.

We suspect that most operating at >90% of design were doing so for the actual test and not as a representation of normal operating practice.

In light of little information regarding normal capacity operating rate we will make a judgement that 50% is a suitable value of K for Sludge incineration

$$K = .50$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marrone Date 1-27-75

Source Sludge Incineration - Municipal

A:

Ref 267 pg 75

Estimated 280 municipal sludge incineration sites,
 Report Oct 1974 - which we assume is close to 1975
 so that it may be used to estimate A.

Ref 044 describes a "typical" incinerator with a rated
 dry solids charging rate of .5 ton/hr and a gas flow
 of 3000 dscfm

Assuming an operating schedule of $24 \frac{\text{hr}}{\text{d}} \times 7 \frac{\text{d}}{\text{wk}} \times 50 \frac{\text{wk}}{\text{yr}} = 8400 \frac{\text{hr}}{\text{yr}}$

$$A = .5 \frac{\text{T}}{\text{hr}} \times 8400 \frac{\text{hr}}{\text{yr}} \times 280 \text{ plants}$$

$$A = 1.176 \times 10^6 \text{ TON/yr}$$

dry solids
feed
to incinerator

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By W. Marone Date 1-27-75

Source Sludge Incineration - Municipal

P_c :

Specific growth rate for sludge incineration was not given in the literature. Ref 044 pg 60 estimates that about 70 new sludge incinerators will be constructed annually. This is interpreted to be a simple growth. If we assume that generally the new plants do not change the average appreciably then we may estimate the growth by

280 plant 1975

70 plants/yr added

$$P_c = \frac{70}{280} \cong .25 \text{ simple}$$

P_B :

Replacement rate is estimated by assuming that the amortization of 30 years specified in Ref 268 pg 51 will equate well with the life of a unit.

$$\frac{100\%}{30 \text{ yrs}} = 3.3\%/\text{yr simple}$$

$$\therefore P_B = .033 \text{ simple}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marrone Date 1-27-75
 Source Sludge Incinerators - Municipal

Particulate

E_u : Ref 044 pg 57

Average uncontrolled emissions

Multiple Hearth 23 lb/hr

Fluid-Bed 205 lb/hr

Ref 268 pg viii 143 sludge incinerator plants
 pg 45 120 multiple hearth units

$$\frac{120}{143} \approx 100 \approx 84\% \text{ multiple hearth}$$

We assume that 80% multiple hearth and 20% fluid-bed will be representative in 1985. Fluid-bed may find faster growth, although this is not certain.

$$E'_u = .8(23) + .2(205) \text{ lb/hr}$$

$$E'_u \approx 59.4 \text{ lb/hr}$$

Using a typical plant size as stated on pg 2 of "Ind Factors" of .5 TON/hr dry solids feed we may estimate E_u in lb/TON dry solids feed.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marzzone Date 4-28-75

Source Sludge Incinerators - Municipal

Particulate cont'd

$$E_u = \frac{59.4 \text{ lb/hr}}{.5 \text{ TON/hr dry solid feed}} = 119 \text{ lb/TON dry solid feed}$$

E_N :

Ref 271 pg 9312

NSPS actually promulgated for Sewage Treatment Plant Sludge Incinerators specifies a standard of 1.3 lb/TON dry sludge input for particulate matter.

Ref 044 pg 57 describes the proposed standard for sludge incinerator of .031 gr/dsc which was mentioned in Ref 271 to be equivalent to the 1.3 lb/TON limit just stated in more meaningful units.

The standard was proposed after many performance tests on well-controlled plants. We will assume this value to be indicative of best control technology.

$$E_N = 1.3 \text{ lb/TON dry solid feed}$$

this represents an efficiency level of 98.9% based on the weighted uncontrolled value of 119 lb/TON

Controls generally used are wet scrubbers (impingement or venturi)

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By D. Marrone Date 4-28-75

Source Sludge Incineration - Municipal

Particulate: cont'd

E_s : A complete breakdown of sludge incineration by state was not obtained however, it was assumed that it would be dispersed uniformly enough to use the generalized process weight rate curve. Although this is a combustion source, the particulate is attributable to the solid content of the sludge.

For existing plant with avg AWR of .5 TON or 1000 lb/hr the allowable emission would be 2.5 lb/hr

$$E_s (\text{existing}) = \frac{2.5 \text{ lb/hr}}{.5 \text{ TON/hr}} = 5.0 \text{ lb/TON dry solid feed}$$

We equate $E_s (\text{new}) = E_{\text{promulgated}} = 1.3 \text{ lb/TON}$

$$E_s (\text{new}) = 1.3 \text{ lb/TON dry solid feed}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Moreno Date 1-28-75

Source Sludge Incineration - Municipal

Trace Metals

Ref 266 pg 28-36 discusses the tests run on several sludge incinerators plants to determine the metal content. Most of the determinations were for sludge and ash metal content. It is mentioned that there is great variability to metal content in sludge and that little conclusive data has been assembled to derive adequate metal emission factors.

E_u :

Our best estimate will be derived from Table 9 Ref 266 pg 33 by using the data for the Lake Tahoe, Calif Incinerator which was identified on pg 28 as largely a domestic sewage plant. We will total the metal content of sludge based on mg metal / g of fixed solids.

Ag	.6
Al	27.0
Ba	6.0
Ca	62.0
Cd	.37
Cr	2.0
Cu	2.6
Fe	18.0
Hg	neg
KJ	1.4
Mg	12.1
Mn	1.1
Na	1.8
P	81
Pb	5.8
Sb	neg

$$\begin{array}{l} \text{Se neg} \\ \text{Sr 1.0} \\ \text{Zn 1.6} \\ \hline \sum \approx 212 \text{ mg/g or } .212 \text{ g/g or } .212 \frac{\text{lb}}{\text{lb}} \end{array}$$

This implies that about 20% of solids is true metal.

We make the assumption that the trace metal content of the emitted particulate will be the same so that

$$E_{u,II} = .2 \times E_u(PT)$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By W. Marzzone Date 4-28-75

Source Sludge Incineration - Municipal

Trace Metals

$$E_u (\text{Trace Metal}) = .2 \times 119 = 24 \text{ lb/TON dry solid feed}$$

E_N : Trace metals will be assumed to be controlled as effectively as total particulate:

$$E_N (\text{TM}) = .011 \times 24 = .26 \text{ lb/TON dry solid feed}$$

↑
98.9% eff.

$E_{III,d}$:

$E_{III,d}$ is assumed equivalent to E_N for trace metals.

$$E_{III,d} (\text{TM}) = .26 \text{ lb/TON dry solid feed}$$

E_s : Trace metals will be controlled detracts along with particulate by PWR curve.

$$E_s (\text{TM}) = .2 E_s (\text{Part})$$

$$E_s (\text{exit TM}) = .2 \times 5 = 1.0 \text{ lb/TON dry solid feed}$$

$$E_s (\text{new TM}) = .2 \times 1.3 = .26 \text{ lb/TON dry solid feed}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By HOPPER Date 12/23/74

Source Open Burning

Open burning will be defined as the uncontrolled, outdoor combustion of the following classes of solid waste:

- (a) Residential & commercial
- (b) Construction & demolition waste
- (c) Institutional so houses
- (d) Industrial "
- (e) Agricultural "

This category will not include open burning as the result of accident

Ref (9) p26 estimates 5.3 #/person-day of solid waste are collected of which approx 64.5% (p29) resulted in some form of open burning (1968). However, since that time, the practice of open burning has been on the decline due to the enforcement of State & Local regulations.

Therefore PC 20

In fact, by the year 1985, it is conceivable that there will be no open burning permissible anywhere.

Also,

- (1) PB is not applicable to this situation
- (2) EN = 0.0 (If such a situation is to be defined)
- (3) A₁₉₇₅ is a highly questionable number & changing daily.

However, the practice of burning agricultural wastes still exists & could continue to exist for sometime. No information

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hopper Date 12/23/74

Source Open Burning

exists regarding the rate at which such a practice may increase.

One could assume a rate equal to the increase in population & consequently an increase in agricultural products. Offsetting this would be the effect of some local regulations & the use of alternate means of agricultural waste elimination.

Previous work on this project (see "Industrial Factors - Site Cleaning") indicated a population trend of 1.8% (compound). For the analysis stated above, we will assume a P_c equal to $\frac{1}{2}$ the value -0.09

$$P_c = -0.09 \text{ compound}$$

The term P_B is not applicable in this case

$$P_B = 0.0$$

this is necessary to use the model.

K is likewise, not applicable. In order to evaluate the impact of a national standard, we must set

$$K = 1.0$$

From Ref ④9 p 93 TAB 8-2. The tons of stubble burned in 1968 was 280×10^6 tons. Since $P_c = 0$ & $K = 1.0$

$$A = 280 \times 10^6 \text{ tons}$$

BURNED

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hoppe, Date 12/23/74

Source Open Burning

It must be noted that open burning is not an industry but a process associated with many industries. The use of NSPS under section III of the Clean Air Act should be studied to determine if this is the most effective path for control.

Our analysis is based on the fact that it is, if the input factors have been determined so as to fit the model, & yield meaningful results. Since P_C & P_B are zero, there is no new or modified capacity to which NSPS can be applied. Therefore, the value ($T_S - T_W$) really represents the impact of 100% control as would be applied by the States.

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hoyer Date 12/23/74

Source Open Burning

From Ref (75) p 2.4-1 TAB 2.4-1, the following emission factors are presented for Agricultural fields burning

$$EU_P = 17 \text{ #/TON BURNED}$$

$$EU_{SO_2} = 0.0$$

$$EU_{CO} = 100 \text{ #/TON BURNED}$$

$$EU_{HC} = 20 \text{ #/TON BURNED}$$

$$EU_{NO_x} = 2 \text{ #/TON BURNED}$$

Since the "best available control technology" would be to eliminate the practice of open burning, we will assume, for all pollutants

$$E_N = 0.0$$

ALL
POLLUTANTS

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hopper Date 12/23/74

Source Open Burning

Since the level & effect of local regulations cannot be
ascertained, we will let E_S equal E_U for all pollutants

$$E_S \underset{\text{EACH POLLUTANT}}{=} E_U \underset{\text{EACH POLLUTANT}}{}} \quad (\text{See p1})$$

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By K. Tower Date 1/23/75

Source Orchard Heaters

Orchard heaters are commonly used in various areas of the United States, primarily Florida and the Southwest, to prevent frost damage to fruit and fruit trees. The five common types of orchard heaters ^{are} pipeline, lazy flame, return stack, cone and solid fuel. From references 262 and 263 the current trend is with the use of the return stack type. We assume in our calculations that all orchard heaters are return stack type.

Since the emissions from orchard heaters come from their operation rather than from their production we define production (A) in units of Heater hrs/yr. It follows therefore that we define all emission factors in units of lbs/Heater hr.

In this case we are not concerned with fractional utilization of production capacity. K is equal to 1.0 for this industry because we assume orchard heaters operate at 100% capacity once fired.

$$K = 1.0$$

From ref 262 we find that the average life of an orchard heater is 30 years.

$$P_B = \frac{1}{30} = .033$$

$$P_B = .033$$

simple


Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By K. Tower Date 1/24/75

Source Orchard Heaters

The following graph shows the growth in production of citrus fruits which employ the use of orchard heaters. This includes production of nectarines, avocados, oranges, tangerines, grapefruit, lemons, limes, tangelos, and temples in the years 1968-1971 ref 247, p. 162.



TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By K.Tower Date 1/24/75

Source Orchard Heaters

Assuming a simple growth rate we can calculate the growth rate by the following formula:

$$P_c = \frac{\text{Production in 1971} - \text{Production in 1969}}{(1971 - 1969)(\text{Production in 1975})}$$

$$= \frac{11,920,000 \text{ TONS} - 11,180,000 \text{ TONS}}{(2)(13,400,000 \text{ TONS})}$$

$$= \frac{740,000}{26,800,000} = .0276$$

$$P_c = .028$$

simple

Ref 262 indicates there are approximately 10,000,000 orchard heaters in the US. Ref. 263 indicates that the average orchard heater operates 6 hrs./yr. "A" as defined earlier in units of heater hrs./yr can be determined as follows:

$$A = (10,000,000 \text{ heaters})(6 \text{ hrs./yr}) = 60 \times 10^6 \text{ heater hrs./yr}$$

$$A = 60 \times 10^6 \text{ heater hrs./yr}$$

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By K. Tower Date 1/24/75
Source Orchard Heaters

Ref 247, p.170, figure 9 presents a graph of the particulate emission rate for orchard heaters as a function of fuel usage rate (lb/heater-hr). Once again we assume the emission rate for the return stack type orchard heater to be representative of the entire industry.

Ref. 264 indicates that the average orchard heater ^{w/w} generate approximately 125,000 BTU's/hr. Ref 101, p.9-6 gives the density of #2 distillate oil as 7.13 lbs/gal. Ref 075, p.1.3-1 gives the heating value of distillate oil as 140,000 BTU/gal. Therefore the fuel usage rate of an average orchard heater can be calculated as follows:

$$\text{Fuel Usage Rate} = \frac{(125,000 \frac{\text{BTU}}{\text{Heater-hr}}) / 7.13 \frac{\text{lbs}}{\text{gal}}}{140,000 \frac{\text{BTU}}{\text{gal}}} = 6.37 \frac{\text{lb}}{\text{heater-hr}}$$

Referring once again to Ref 247, p.170, figure 9 , a 6.37 lb/heater-hr gives $\frac{7 \text{ lb Emissions}}{1000 \text{ heater-hrs}}$

$$E_{N_{PT}} = .007 \frac{\text{lbs}}{\text{heater-hr}}$$

There is no practical technique for ^{the} reduction of orchard heater particulate emissions so to determine the maximum potential impact of the reduction of these emissions we assume $E_{N_{PT}} = 0.00 \frac{\text{lbs}}{\text{heater-hr}}$.

$$E_{N_{PT}} = 0.00 \frac{\text{lbs}}{\text{heater-hr}}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By K. Tower Date 1/24/75
 Source Orchard Heaters

California & Florida have $.132 \text{ lbs/hr}$ & $.066 \text{ lbs/hr}$ (1 gm/min & $.5 \text{ gm/min}$) pt. limitations on orchard heaters. However these values are so much greater than $E_{u_{PT}}$ for an average size orchard heater we assume $E_{s_{PT}} = E_{u_{PT}}$, in order to demonstrate the true effect of potential new source performance standards.

$$E_{s_{PT}} = .007 \frac{\text{lbs}}{\text{heater-hr}}$$

Ref 097, p. 19, Table 4-9 gives the % S found in #2 distillate oil as .265%. This value represents an arithmetic average of the data in the table. Ref 247, p 169, Table 70 shows that SO_x emissions from a return stack orchard heater is equal to $0.145 \text{ lbs/heater-hr}$.

$$E_{u_{SO_x}} = (0.14)(.265) = .0371 \frac{\text{lbs}}{\text{heater-hr}}$$

$$E_u = .037 \frac{\text{lbs}}{\text{heater-hr}}$$

There is no practical technique for the reduction of orchard heater SO_x emissions so to determine the maximum potential impact of the reduction of these emissions we assume $E_n = 0.00 \frac{\text{lbs}}{\text{heater-hr}}$.

$$E_{n_{SO_x}} = 0.00 \frac{\text{lbs}}{\text{heater-hr}}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By K. Tower

Date 1/24/75

Source Orchard Heaters

California has a .5%S regulation for fuel burning sources and Florida has no S regulation for fuel burning sources with fuel usage rates as low as those for orchard heaters. We have previously referenced the average sulfur content for #2 distillate oil as .265%S. Therefore in order to accurately demonstrate the true effect of potential new source performance standards we assume $E_{S_{SO_x}} = E_{U_{SO_x}}$

$$E_{S_{SO_x}} = .037 \text{ lbs/heater-hr.}$$

Ref 075, p. I.3-2, Table I.3-1 gives a "CO emission factor of .004 lbs/gal of distillate oil for fuel combustion units. Ref 264 gives the average heating value of oil used with orchard heaters as 125 BTU/heater-hr. Ref. 075, p.I.3-1 states there are 140,000 BTU/gal of distillate oil. E_u for orchard heaters can therefore be calculated as follows:

$$E_{U_{CO}} = \frac{(125,000 \text{ BTU/heater-hr.})(.004 \text{ lbs/gal.})}{(140,000 \text{ BTU/gal.})} = .0036 \text{ lbs/heater-hr.}$$

$$E_{U_{CO}} = .004 \text{ lbs/heater-hr.}$$

There is no practical technique for the reduction of orchard heater CO emissions so to determine the maximum potential impact of the reduction of these emissions we assume $E_{N_{CO}} = 0.00 \text{ lbs/heater-hr.}$

$$E_{N_{CO}} = 0.00 \text{ lbs/heater-hr.}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By K. Tower Date 1/27/75

Source Orchard Heaters

There are no applicable CO regulations for orchard heaters in Florida or California. Therefore $E_{S_{CO}} = E_{U_{CO}}$

$$E_{S_{CO}} = .004 \text{ lbs/heater-hr.}$$

Ref 247, p. 169, Table 70 gives the emission factor for return stack type orchard heaters as $16 \frac{\text{lbs}}{\text{heater-hr.}}$ hydrocarbon.

$$E_{U_{HC}} = 16 \text{ lbs/heater-hr.}$$

Since there is no practical technique for the reduction of orchard heater hydrocarbon emissions we assume $E_N = 0.00 \frac{\text{lbs}}{\text{heater-hr.}}$ In order to determine maximum potential impact of the reduction of these emissions.

$$E_{N_{HC}} = 0.00 \frac{\text{lbs}}{\text{heater-hr.}}$$

There are no applicable regulations concerning orchard heaters so we will assume $E_{S_{HC}} = E_{U_{HC}}$

$$E_{S_{HC}} = 16 \frac{\text{lbs}}{\text{heater-hr.}}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By K. Tower Date 1/27/75
 Source Orchard Heaters

Ref 247, p. 169, Table 70 states that NO_x emissions from orchard heaters are negligible.

$$E_{u_{NO_x}} = 0.00 \text{ lbs/heater-hr.}$$

It follows therefore that $E_{N_{NO_x}}$ also = $0.00 \text{ lbs/heater-hr.}$

$$E_{N_{NO_x}} = 0.00 \text{ lbs/heater-hr}$$

In order to demonstrate the true effect of potential new source performance standards we assume $E_{S_{NO_x}} = E_{u_{NO_x}}$

$$E_{S_{NO_x}} = 0.00 \text{ lbs/heater-hr.}$$

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 : New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By K.Tower Date 1/27/75
 Source Orchard Heaters

Summary of Emission Factors

Pollutant	E_u ($\text{lbs}/\text{heater-hr}$)	E_N ($\text{lbs}/\text{heater-hr}$)	E_u ($\text{lbs}/\text{heater-hr}$)
Particulate	.007	0.00	.007-
SO_x	.037	0.00	.037-
CO	.004	0.00	,004'
HC	16	0.00	9.2
NO_x	0.00	0.00	0.00

TRC -- The Research Corporation of New England
 125 Silas Deane Highway
 Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hoppe Date 6/3/75

Source Conversion of Waste Crude Case Oil

Ref (27) App. A p 2 The national amt of waste oil is estimated to be 730×10^6 gallons in 1975.

From (27) App. B. "It is estimated that 50% of the oil is burned"

$$\text{Usage} = \frac{730 \times 10^6}{2} = 365 \times 10^6 \text{ gallons}$$

If we assume that the typical size range of boilers used is greater than $250 \times 10^6 \text{ gal/hr}$, the K is 0.58 (See, "INDUSTRIAL FACTORS - BOILERS")

$$\therefore A = \frac{365 \times 10^6}{.58} = 629 \times 10^6 \text{ gal}$$

$$A = 629 \times 10^6 \text{ gallons}$$

$$K = 0.58$$

From Ref (27) App A p 2 the 1967 amt of waste oil was 680×10^6 gals & the estimated 1975 amt is 730×10^6 . Assuming const growth

$$P_c = \sqrt[8]{\frac{730}{680}} - 1 = 0.009$$

$$P_c = 0.009 \text{ const}$$

TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Industrial Factors

Calculations Done By Hoppe Date 6/3/75

Source Comb. of Waste Concrete Oil

Obsolescence rate, P_B , is not applicable in this situation.

$$\therefore P_B = 0.0$$

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By HOPPER

Date 6/3/75

Source Comb. of Waste Gasoline Oil

From Ref (277) Apps

Sp. wt of oil is 7.5 lb/gal & 1% is loss.
If all the loss is vented thru the exhaust, then

$$E_{N_{10}} = 0.075 \text{ lb/gallon}$$

We will assume that the oil is burned in processes with efficient control systems & that the 12/6/73 regs for Pb are not in effect.

Ref (277) App(1) p 4 indicates 99% η with a baghouse

$$E_{N_{10}} = .075(1-.99) = 0.00075$$

$$E_{N_{10}} = 0.00075 \text{ lb/gallon}$$

For existing plants, we will assume an $\eta = 90\%$ using baghouses.

$$E_{N_{10}} = .075(1-.9) = 0.0075$$

$$E_{N_{10}} = 0.0075 \text{ lb/gallon}$$

There are no regs for lead; however,

$$E_{Sp,7250} = 0.277 \text{ lb/gal} \quad (\text{See "Emission Factors - Boilers})$$

$$Q = 5.817 \times 10^6 \text{ BTU/sec} \quad \& \quad 42 \text{ gal/sec} \quad (\text{Ref (22) pt-2 tab 1-1})$$

2012
TRC -- The Research Corporation of New England
125 Silas Deane Highway
Wethersfield, Connecticut 06109

Project Number - 32391 New Source Performance Standards

Computation Sheet For Emission Factors

Calculations Done By Hooper Date 6/3/75

Source Comb. of Wmiz Crankcase Oil

$$\frac{(277 \times 10^6)(5.817 \times 10^4)}{42} = 0.038$$

This would be the top limit
for particulate & lead

$$E_{S_{P_3}} = 0.038 \text{ lb/gallon}$$

TECHNICAL REPORT DATA
(Please read Instructions on the reverse before completing)

1. REPORT NO. EPA 450/3-76 - 018a	2.	3. RECIPIENT'S ACCESSION NO.
4. TITLE AND SUBTITLE Determining Input Variables for Calculation of Impact of New Source Performance Standards: Worksheets for Stationary Combustion Sources		5. REPORT DATE April 1977
7. AUTHOR(S) Thomas G. Hopper William A. Marrone		6. PERFORMING ORGANIZATION CODE
9. PERFORMING ORGANIZATION NAME AND ADDRESS TRC - The Research Corporation of New England 125 Silas Deane Highway Wethersfield, Connecticut 06109		8. PERFORMING ORGANIZATION REPORT NO.
		10. PROGRAM ELEMENT NO. 2AC129
		11. CONTRACT/GRANT NO. 68-02-1382
12. SPONSORING AGENCY NAME AND ADDRESS EPA-Office of Air Quality Planning and Standards Emission Standards and Engineering Division Research Triangle Park, NC 27711		13. TYPE OF REPORT AND PERIOD COVERED Task Final: 7/74 - 7/76
		14. SPONSORING AGENCY CODE EPA - OAQPS
15. SUPPLEMENTARY NOTES Project Officer for this Report is G. D. McCutchen, Mail Drop 13, Ext. 271		
16. ABSTRACT The purpose of this document is to present the results of a study to determine the impact of new source performance standards on nationwide emissions. The work presented covers 14 potential pollutants from approximately 200 source categories for the year 1985. The results are being used by EPA as input to the development of an overall standard setting strategy. The report contains information regarding controlled and uncontrolled emission factors, State emission limitations, industrial capacity, utilization, growth and retirement rates. The results of this study have been published as three volumes which encompass ten separate documents. This document contains Appendix 4A of Volume II - Calculation Sheets for Combustion Sources.		
17. KEY WORDS AND DOCUMENT ANALYSIS		
a. DESCRIPTORS	b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group
Air Pollution Air Pollution Control Industrial Processes Combustion Regulations Economic Factors	Priorities Chemical Industry Paper Industry Petroleum Industry	Metal Industry Agricultural Mineral Flyash Exhaust Gases
18. DISTRIBUTION STATEMENT Unlimited	19. SECURITY CLASS (This Report) Unclassified	21. NO. OF PAGES 235
	20. SECURITY CLASS (This page) Unclassified	22. PRICE

EPA Form 2220-1 (8-73)