




United States
Environmental Protection
Agency

Industrial Environmental Research
Laboratory
Research Triangle Park NC 27711

EPA-600/7-80-085c
April 1980

Thirty-day Field Tests of Industrial Boilers: Site 3 — Pulverized-coal-fired Boiler

Interagency Energy/Environment R&D Program Report



RESEARCH REPORTING SERIES

Research reports of the Office of Research and Development, U.S. Environmental Protection Agency, have been grouped into nine series. These nine broad categories were established to facilitate further development and application of environmental technology. Elimination of traditional grouping was consciously planned to foster technology transfer and a maximum interface in related fields. The nine series are:

- 1. Environmental Health Effects Research**
- 2. Environmental Protection Technology**
- 3. Ecological Research**
- 4. Environmental Monitoring**
- 5. Socioeconomic Environmental Studies**
- 6. Scientific and Technical Assessment Reports (STAR)**
- 7. Interagency Energy-Environment Research and Development**
- 8. "Special" Reports**
- 9. Miscellaneous Reports**

This report has been assigned to the INTERAGENCY ENERGY-ENVIRONMENT RESEARCH AND DEVELOPMENT series. Reports in this series result from the effort funded under the 17-agency Federal Energy/Environment Research and Development Program. These studies relate to EPA's mission to protect the public health and welfare from adverse effects of pollutants associated with energy systems. The goal of the Program is to assure the rapid development of domestic energy supplies in an environmentally-compatible manner by providing the necessary environmental data and control technology. Investigations include analyses of the transport of energy-related pollutants and their health and ecological effects; assessments of, and development of, control technologies for energy systems; and integrated assessments of a wide range of energy-related environmental issues.

EPA REVIEW NOTICE

This report has been reviewed by the participating Federal Agencies, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policies of the Government, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

This document is available to the public through the National Technical Information Service, Springfield, Virginia 22161.

EPA-600/7-80-085c

April 1980

Thirty-day Field Tests of Industrial Boilers: Site 3 — Pulverized-coal-fired Boiler

by

W.A Carter and H.J Buening

**KVB, Inc.
P.O. Box 19518
Irvine, California 92714**

**Contract No 68-02-2645
Task No. 4
Program Element No EHE624**

EPA Project Officer, Robert E. Hall

**Industrial Environmental Research Laboratory
Office of Environmental Engineering and Technology
Research Triangle Park, NC 27711**

Prepared for

**U S ENVIRONMENTAL PROTECTION AGENCY
Office of Research and Development
Washington, DC 20460**

ABSTRACT

This is a final report on a test program to evaluate the long-term effectiveness of combustion modifications for lowering emissions from industrial boilers. During previous programs short-term tests have been performed on industrial boilers to determine the effect of combustion modifications on air pollutant emissions such as NO_x , SO_x , CO, HC, and particulate. The objective of this program was to determine whether the combustion modification techniques which were effective for short-duration tests are feasible for a longer period. This report presents the results of a 30-day field test of a 76.2 MW (260,000 lb steam/hr) output, pulverized-coal-fired water tube boiler. The NO_x control technology employed on this unit was staged combustion air and low excess air. The results indicate that staged combustion air and low excess air can be effective techniques for NO_x control. However, additional operational problems such as flame stability can be encountered. The baseline NO measurement was 498 ng/J (815 ppm @ 3% O_2 , dry) with the unit operating at approximately 70% of capacity. At approximately the same load, low NO_x operation yielded an NO emission level of 422 ng/J (691 ppm @ 3% O_2 , dry) for a reduction of approximately 15%. The average NO emission level for 30 days, firing with staged combustion air and low excess air at loads varying from 15 MW to 63 MW, was 340 ng/J (557 ppm @ 3% O_2 , dry). Boiler efficiency showed an increase of approximately 1% under low NO_x firing condition.

CONTENTS

<u>SECTION</u>		<u>PAGE</u>
	ABSTRACT	ii
1.0	SUMMARY	1
	1.2 Results	2
	1.3 Conclusions	5
2.0	INSTRUMENTATION AND PROCEDURES	6
	2.1 Emissions Measurement Instrumentation	6
	2.2 Boiler Description and Characteristics	17
3.0	TEST RESULTS	19
	3.1 Continuous Monitor Certification Test 5	19
	3.2 Pulverized Coal-Fired Boiler Tests	22
4.0	REFERENCES	46
 APPENDICES:		
	A. EFFICIENCY MEASUREMENTS	49
	B. DATA RECORDING FORMATS	56
	C. CONTINUOUS MONITOR CERTIFICATION DATA SHEETS	74
	D. CONTINUOUS MONITOR PERFORMANCE SPECIFICATIONS	93
	E. TABULATION OF HOURLY EMISSIONS DATA	109
	F. SUMMARY OF PREVIOUS TEST DATA	153

FIGURES

<u>Section</u>		<u>Page</u>
1-1	NO emissions from Site 3 - Pulverized Coal-Fired-Boiler	4
2-1	Photograph of KVB Continuous Monitor for measuring gaseous emissions.	7
2-2	Schematic of continuous monitor sampling and conditioning system.	10
2-3	Mark III adsorbent sampling system.	14
2-4	Two-drum Stirling boiler for pulverized coal (Typ.)	17
2-5	Typical simple baghouse with mechanical shaking (Wheelabrator Corporation, Mishawaka, Indiana).	18
3-1	Boiler efficiency vs. excess O ₂ . Pulverized Coal-Fired-Boiler, Site 3.	36
3-2	NO emissions from Site 3 - Pulverized Coal-Fired-Boiler	40
3-3	NO emissions from Site 3, a Pulverized Coal-Fired-Boiler	43
3-4	NO emissions from Site 3, a Pulverized Coal Fired Boiler.	44
3-5	Daily average NO _x emissions for Site 3 - Pulverized Coal-Fired-Boiler.	45
3-6	Daily average O ₂ measurements for Site 3 - Pulverized Coal-Fired-Boiler.	46

TABLES

<u>Section</u>		<u>Page</u>
1-1	Summary of 24-hour Averages of Stack Emissions from a Pulverized-Coal-Fired Boiler	3
2-1	Analytical Instrumentation	8
3-1	Schedule of Certification Test Events	20
3-2	Instrument Specifications and Performance	21
3-3	Summary of Gaseous and Particulate Emissions at Site 3.	24
3-4	Particulate Data Summary - Site 3	30
3-5	Summary of POM Analyses for Site 3	32
3-6	Summary of Coal and Ash Analysis from Site 3	34
3-7	Summary of Boiler Efficiency Calculations for Site 3	35
3-8	Format of Hourly Emissions Data for Site 3	37
3-9	Summary of 24-Hour Averages of Stack Emissions from a Pulverized-Coal-Fired Boiler	38
3-10	NO Emission - Frequency Data Site 3	41
3-11	NO Emission - Frequency Data for Site 3	42

SECTION 1.0

SUMMARY

1.1 OBJECTIVE AND SCOPE

The objective of this field test was to determine whether combustion modification techniques which brought about reduction of air pollutant emissions during short-term tests are feasible for longer periods. In addition, boiler performance and reliability were monitored. The combustion modifications have previously been shown to be effective on industrial boilers (Refs. 1, 2, 3).

The program scope provides for 30-day field tests of a total of seven industrial boilers with design capacities ranging from 14.65 to 73.25 MW thermal output (50,000 to 250,000 lb steam/hr). Fuels to be burned include natural gas, light oil, residual oil, and coal. This final report is for a 76.2 MW thermal output (260,000 lb steam/hr) pulverized-coal-fired boiler using staged combustion air (SCA) and low excess air (LEA) as the emission control technology.

During the test period, continuous monitor certification tests were performed concurrently with low NO_x testing. Emissions measured were particulate, NO, CO₂, CO, and O₂. Boiler efficiency was calculated several times during the program to determine the effect of combustion modification on boiler efficiency.

This is a final report on the 30-day test, documenting test equipment, summarizing the test data, and discussing the data in relation to the control technology employed for this type of boiler.

1.2 RESULTS

A pulverized-coal-fired boiler using SCA and LEA as the NO_x control technology was selected for this field test. A survey was made of previous tests conducted on pulverized-coal-fired boilers with SCA as the NO_x control technology. It was desirable to select a boiler which had been tested previously in order to know its capability for low NO_x operation and to minimize setup time.

The boiler tested at Site 3 was selected on the basis that previous testing had been performed by KVB and the unit had shown a capability of operation under low NO_x conditions. Selection of a unit in this category was limited because the desired capacity is the lower end of the range for pulverized-coal-fired boilers.

A survey and analysis of the population of industrial boilers is presented in Reference 4. This study showed that pulverized-coal-fired boilers account nationally for only 12% of the total of coal-fired industrial boilers.

After permission to test was obtained, the continuous monitor was shipped to the site and installed. The next task was to perform the certification tasks outlined in Performance Specifications 2 and 3, 40 CFR60, Appendix B. (See Appendix D, this report.)

Following the monitor certification, the 30-day field test was conducted. The test was set up according to "Plan for Performing Source Evaluation Tests in Support of NSPS for Industrial Boilers." Emissions of NO, CO, CO₂, and O₂ were measured continuously. Particulate measurements were made in triplicate at the start and conclusion of the test period. In addition, triplicate particulate measurements were made with the boiler in the as-found (unmodified) condition. Measurements of polycyclic organic matter were made in both the low NO_x and unmodified condition.

Results of the 30-day test are discussed in detail in Section 3.0. Table 1-1 presents a summary of the 24-hour averages of the stack emissions. The result of the statistical analysis of the data is illustrated in Figure 1-1 where the 24-hour averages for all boiler load conditions are plotted on log-probability paper. These data indicate that the NO data are log-normally distributed and the mean value is 340 ng/J with a geometric dispersion of 1.13.

TABLE 1-1. SUMMARY OF 24-HOUR AVERAGES OF STACK EMISSIONS
FROM A PULVERIZED-COAL-FIRED BOILER

DATE	TIME	LOAD MWH	24 HOUR DATA DRY STACK GAS CONCENTRATION									
			O2 MEAS	CO2 MEAS	CU MEAS	NO PPMV MEAS	CO PPMV MEAS	NO PPMV MEAS	CO PPMV MEAS	NO NG/J	CO NG/J	
			VOL%	VOL%	PPHMV	PPHMV	PPHMV	PPHMV	PPHMV	NG/J		
6/ 1/79		55.4	6.6	11.3	28.	529.	35.	662.	12.	389.		
6/ 2/79		19.8	8.3	11.0	21.	455.	30.	644.	11.	378.		
6/ 3/79		14.4	9.0	.0	16.	392.	24.	588.	9.	345.		
6/ 4/79		34.7	8.5	.0	18.	389.	26.	559.	9.	328.		
6/ 5/79		19.7	9.5	10.3	20.	369.	32.	485.	11.	285.		
6/ 6/79		22.6	8.1	10.4	21.	366.	30.	514.	11.	302.		
6/ 7/79		29.4	8.3	10.8	31.	383.	44.	544.	16.	320.		
6/ 8/79		30.3	8.1	10.5	28.	410.	40.	572.	14.	336.		
6/ 9/79		19.9	8.4	10.1	27.	406.	38.	581.	14.	341.		
6/10/79		16.4	8.6	10.0	33.	396.	48.	576.	17.	338.		
6/11/79		18.6	8.5	10.3	38.	388.	55.	561.	20.	329.		
6/12/79		30.5	8.8	10.4	0.	408.	0.	602.	0.	353.		
6/13/79		23.3	9.0	10.6	0.	397.	0.	599.	0.	352.		
6/14/79		38.6	8.5	10.5	49.	444.	71.	641.	25.	376.		
6/15/79		18.3	9.2	10.2	86.	324.	131.	495.	47.	291.		
6/16/79		21.8	9.1	10.2	0.	364.	0.	551.	0.	323.		
6/17/79		19.4	8.8	10.3	0.	356.	0.	526.	0.	309.		
6/18/79		21.7	8.8	10.3	0.	357.	0.	530.	0.	311.		
6/19/79		20.7	8.9	10.0	35.	358.	52.	532.	19.	312.		
6/20/79		18.9	9.0	10.0	33.	361.	50.	544.	18.	319.		
6/21/79		31.7	8.8	10.7	21.	431.	31.	637.	11.	374.		
6/22/79		18.8	8.6	10.5	35.	450.	51.	656.	18.	385.		
6/23/79		22.6	8.4	10.6	36.	449.	52.	641.	18.	377.		
6/24/79		20.3	8.6	10.2	34.	395.	50.	577.	16.	339.		
6/25/79		23.1	9.0	10.2	36.	410.	54.	616.	19.	361.		
6/26/79		18.8	8.9	10.3	37.	427.	55.	639.	20.	375.		
6/27/79		20.2	8.6	10.3	15.	426.	22.	620.	8.	364.		
6/28/79		21.0	8.6	10.5	25.	473.	37.	686.	13.	403.		
6/29/79		19.8	8.5	10.4	34.	504.	48.	728.	17.	427.		
6/30/79		19.2	8.8	10.2	30.	438.	44.	647.	16.	380.		
7/ 1/79		17.6	8.8	9.9	33.	455.	48.	673.	17.	395.		
7/ 2/79		18.9	8.5	10.3	33.	436.	47.	629.	17.	369.		
7/ 3/79		37.2	8.3	10.6	19.	487.	28.	694.	10.	407.		
7/ 4/79		19.8	8.6	10.3	35.	424.	51.	618.	18.	363.		
7/ 5/79		20.7	8.5	10.3	15.	416.	21.	599.	7.	352.		
7/ 6/79		22.3	8.4	10.3	21.	385.	30.	550.	11.	323.		
7/ 7/79		19.1	8.5	10.2	35.	384.	50.	556.	18.	326.		
7/ 8/79		17.7	8.7	9.9	47.	351.	69.	514.	25.	302.		
7/ 9/79		18.4	8.4	10.3	80.	366.	115.	526.	41.	309.		
7/10/79		37.6	9.0	9.9	92.	453.	139.	681.	50.	400.		
7/11/79		45.6	7.8	11.2	75.	519.	102.	708.	37.	416.		
7/12/79		33.0	8.0	10.6	84.	407.	117.	566.	42.	332.		




Figure 1-1. NO Emissions from Site 3 - Pulverized Coal-Fired Boiler

1.3 CONCLUSIONS

Based on the results of this 30-day field test, the following conclusions are presented.

1. Staged combustion air is an effective NO_x control technology for certain pulverized-coal-fired boilers. The low NO_x mode (SCA) was maintained for 42 days with an average NO_x emission rate of 340 ng/J. Boiler load varied from 14.4 to 63.0 MW thermal input.
2. Boiler operation in the low NO_x mode (SCA) required special attention to the burners. With the upper two burners biased for operating air rich, a problem with flame stability can be encountered.
3. The continuous monitor system utilizing an extractive sampling system provided accurate, reliable data for the 30-day test period. Daily calibration of instruments is necessary as is preventive maintenance on the sample system.
4. Operation of industrial boilers usually is characterized by large swings in load. Any effective control technology must be capable of operation over large load changes. Staged combustion air by biasing the mills is effective at the upper load range but presents operational problems at low load.

SECTION 2.0

INSTRUMENTATION AND PROCEDURES

This section presents a description of the instrumentation used to measure the gaseous and particulate emissions, the test procedures, and techniques for certifying the continuous monitor and a description of the boiler tested.

2.1 EMISSIONS MEASUREMENT INSTRUMENTATION

The emissions measurements were made using a continuous monitor fabricated by KVB for this program. The analytical instrumentation and sample handling equipment are contained in a cabinet 1.2 m wide x 0.76 m deep x 1.83 m high (48"W x 30"D x 72"H). A photograph of the continuous monitor is shown in Figure 2-1. Gaseous emission measurements were made with the analytical instruments listed in Table 2-1.

Total particulate measurements were made using an EPA Method 5 sampling train manufactured by Western Precipitation Division of Joy Manufacturing Company. Samples for measurement of polycyclic organic matter (POM) were obtained using an XAD-2 module supplied by Battelle Columbus Laboratories. These modules were returned to Battelle for analysis following the test.

2.1.1 Gaseous Emissions

The continuous monitor is equipped with analytical instruments to measure concentrations of NO, CO, CO₂, and O₂. The sample gas is delivered to the analyzers at the proper condition and flow rate through the sampling




Figure 2-1. Photograph of KVB Continuous Monitor for measuring gaseous emissions.

TABLE 2-1. ANALYTICAL INSTRUMENTATION

<u>Emission Species</u>	<u>Manufacturer</u>	<u>Measurement Method</u>	<u>Model No.</u>
Nitrogen Oxides	Thermo Electron	Chemiluminescent	10A
Oxygen	Beckman Instrument	Polarographic	742
Carbon Dioxide	Horiba Instrument	NDIR	PIR-2000
Carbon Monoxide	Horiba Instrument	NDIR	PIR-2000
Opacity	Dynatron	Transmissometer	1100

and conditioning system shown schematically in Figure 2-2. A probe with a 0.7-micrometer sintered stainless steel filter was installed in the stack to sample the flue gas. The following paragraphs describe the analytical instrumentation.

A. Nitrogen Oxides--

The oxides of nitrogen monitoring instrument used was a Thermo Electron chemiluminescent nitric oxide analyzer. The operational basis of the instrument is the chemiluminescent reaction of NO and O₃ to form NO₂ in an excited state. Light emission results when excited NO₂ molecules revert to their ground state. The resulting chemiluminescence is monitored through an optical filter by a high sensitivity photomultiplier tube, the output of which is electronically processed so it is linearly proportional to the NO concentration.

Air for the ozonator is drawn from ambient through an air dryer and a 10-micrometer filter element. Flow control for the instrument is accomplished by means of a small bellows pump mounted on the vent of the instrument downstream of a separator which insures that no water collects in the pump.

The basic analyzer is sensitive only to NO molecules. To measure NOx (i.e., NO + NO₂), the NO₂ is first converted to NO. This is accomplished by a converter which is included with the analyzer. The conversion occurs as the gas passes through a thermally insulated, resistance heated, stainless steel coil. With the application of heat, NO₂ molecules in the sample gas are reduced to NO molecules, and the analyzer then reads NOx. NO₂ is obtained by the difference in readings obtained with and without the converter in operation.

Specifications

Accuracy: 1% of full scale

Span drift: \pm 1% of full scale in 24 hours

Zero drift: \pm 1 ppm in 24 hours




Figure 2-2. Schematic of continuous monitor sampling and conditioning system.

Power requirements: 115 ± 10V, 60 Hz, 1000 watts

Response: 90% of F.S. in 1 sec (NO_x mode); 0.7 sec (NO mode)

Output: 4-20 ma

Sensitivity: 0.5 ppm

Linearity: ± 1% of full scale

Vacuum detector operation

Range: 2.5, 10 25, 100, 250, 1000, 2500, 10,000 ppm F.S.

Only the NO concentration was measured during this program. Because of the added complexity of heated sample lines and controllers necessary for measuring NO_2 and the small percentage of NO_2 in the flue gas, based on previous tests (References 1, 2, and 3) EPA decided that only NO measurement was necessary. Therefore, an unheated sample line was installed, and the moisture was removed from the sample gas by a dropout flask and a refrigerated condenser.

B. Carbon Monoxide and Carbon Dioxide--

Carbon monoxide (CO) and carbon dioxide (CO_2) concentrations were measured by Horiba Instruments PIR-2000 short-path-length nondispersive infrared analyzers. These instruments measure the differential in infrared energy absorbed from energy beams passed through a reference cell (containing a gas selected to have minimal absorption of infrared energy in the wavelength absorbed by the gas component of interest) and a sample cell through which the sample gas flows continuously. The differential absorption appears as a reading on a scale of zero to 100% and is then related to the concentration of the species of interest by calibration curves supplied with the instrument. A linearizer was supplied with the CO analyzer to provide a linear output over the range of interest. The operating ranges for the CO analyzer are zero to 500, zero to 1000, and zero to 2000 ppm, and the ranges for the CO_2 analyzer are zero to 5, zero to 10, and zero to 20%.

Specifications


Accuracy: 1% of full scale

Repeatability: ± 0.5% of full scale

Zero drift: $\pm 1\%$ of full scale in 24 hours
Span drift: $\pm 1\%$ of full scale in 24 hours
Response time: selectable - 90% of full scale in 0.5, 1.2, 3, or 5 seconds
Power requirements: 115 VAC $\pm 10\%$, 60 Hz
Warm up time: 30 minutes
Output: 0-10 MV

C. Oxygen--

A Beckman Model 742 oxygen analyzer was used to continuously determine the oxygen content of the flue gas sample. The oxygen measuring element contains a silver anode and gold cathode that are protected from the sample by a thin membrane of Teflon. An aqueous KCL solution, retained in the sensor by the membrane, serves as an electrolytic agent. As Teflon is permeable to gases, oxygen will diffuse from the sample to the cathode in the following oxidation-reduction reaction:



With an applied potential between the cathode and anode, oxygen will be reduced at the cathode causing a current to flow. The magnitude of this current is proportional to the partial pressure of oxygen present in the sample. The instrument has operating ranges of zero to 1%, zero to 10%, and zero to 25% oxygen.

Specifications

Accuracy: $\pm 1\%$ of full scale or $\pm 0.05\% \text{ O}_2$ which ever is greater
Sensor stability: $\pm 1\%$ of full scale per 24 hours
Response time: 90% in 20 seconds
Output: 0-10 MV
Power requirement: 120 ± 10 VAC, 60 Hz

2.1.2 Particulate Emissions

Particulate samples were taken from two ports on the side of the duct located 90° from the gaseous emission sample port. The samples were taken using a Joy Manufacturing Company portable effluent sampler. This system, which meets the EPA design specifications for Test Method 5 (Determination of Particulate Emissions from Stationary Sources, Federal Register, Volume 42, No. 160, page 41754, August 18, 1977) is used to perform both the initial velocity traverse and the particulate sample collection. Dry particulates are collected in a heated case that contains, first, a cyclone to separate particles larger than 5 micrometers and, second, a 100-mm glass-fiber filter for retention of particles down to 0.3 micrometers. Condensable particulates are collected in a train of four Greenburg-Smith impingers in a chilled water bath.

2.1.3 Polycyclic Organic Matter (POM) Emissions

Particulate and gaseous samples for analysis of polycyclic organic matter were taken at the sample port used for Method 5 particulate tests. The sampling system is a modified Method 5 sampling train developed by Battelle Columbus Laboratories. A combination of conventional filtration with collection of organic vapors by means of a high surface area polymeric adsorbent (XAD-2) proved highly efficient for collection of all but the more volatile organic species. The modified sampling system consists of the standard EPA train with the adsorbent sampler (Figure 2-3) located between the filter and the impingers. With this system filterable particulate can be determined from the filter catch and the probe wash according to Method 5, whereas the organic materials present can be determined from the analysis of the filterable particulate and the adsorbent sampler catch. The impingers are only used to cool the stream and protect the dry-gas meter, and their contents are discarded.




Figure 2-3. Mark III adsorbent sampling system.

2.1.4 Opacity Measurement

Stack opacity was measured continuously in the stack with a transmissometer permanently installed by the plant. In addition to the transmissometer reading, a visual determination of opacity was made. The visual determination of opacity was made by a qualified observer provided by EPA. The procedure, Method 9-CFR60, Appendix A, was followed for all tests where particulate were measured. Opacity measurements for each particulate test are tabulated in Table 3-4.

2.1.5 Data Recording

The millivolt output from the gaseous analyzers was recorded on two dual-channel strip chart recorders and a 20-channel digital data logger. The following paragraphs describe the recorders.

A. Strip Chart Recorder--

The strip chart recorders were Linear Instruments Corp. Model 432 two-channel crossover recorders. The recorder specifications are as follows:

Input span: 1 mV to 100 VDC

Accuracy: $\pm 0.5\%$ span

Temperature stability: $1\mu\text{V}/^\circ\text{C}$

Response: 0.5 sec. over full 250 mm span

Zero: Right hand zero in standard. 100% zero suppression is standard

Power requirements: 115 VAC, 60 Hz, <20 watts

Weight: 11.4 kg (25 lb)

B. Digital Data Logger--

The data logger used for recording analyzer output was a Monitor Labs Model 9300 microprocessor-based data logger. The data logger has capability for input of 20 channels of analog voltage, current, and temperature. The data logger specifications are as follows:

Ranges: $\pm 30,000$ mW, ± 300.00 mW, ± 3.0000 V, ± 12.000 V

Resolution: $1\mu V$ on 30.000 mV range (1 part in 30,000 except on 12V range; then 1 part in 12,000)

Accuracy: $\pm 0.02\%$ reading $\pm 0.01\%$; Range ± 1 digit

Input impedance: 100 megohms

Temperature range: Operating, 0° to $50^\circ C$ (32° to $122^\circ F$)
Storage, -20° to $65^\circ C$ (-4° to $149^\circ F$)

Relative humidity: 0 - 95%, non-condensing

Main frame power: 115/230 V $\pm 10\%$, 60 Hz, less than 125 watts

Main frame dimensions: 18cm x 48.3cm x 56 cm (7" x 19" x 22")

Main frame weight: 18.2 kg (40 lb)

2.2 BOILER DESCRIPTION AND CHARACTERISTICS

The boiler tested at Site 3 was manufactured by Erie City Company in 1963 and is installed in a small midwestern power station. It is a 76.2 MW (260,000 lb/hr steam) pulverized-coal-burning unit of the two-drum Stirling type as shown in Figure 2-4. The unit is face-fired with four CE burners arranged in two rows of two. Pulverized coal is supplied to the burners by two CE Raymond Bowl mills.




Figure 2-4. Two-drum Stirling boiler for pulverized coal (Typ.).

The unit also has the capability to fire natural gas. The boiler utilizes either propane or natural gas for startup.

Incoming combustion air is preheated by a two-pass tubular-type air heater. The flue gases pass through a pendant-type superheater before beginning the final boiler pass. Superheated steam temperature is controlled at 910°F by a coil-type attemperator. Fly ash is removed by a ten-compartment structural baghouse similar to the type shown in Figure 2-5. Material collected in the baghouse hoppers is periodically discharged at the bottom through a pneumatic conveying system. Bottom ash from the boiler is mixed with water and piped to a settling pond and eventually used for landfill.




Figure 2-5. Typical simple baghouse with mechanical shaking (Wheelabrator Corporation, Mishawaka, Indiana).

The unit is a balanced draft type with both induced draft and forced draft fans.

The following design data apply to Test Site 3:

Boiler rating:	76.2 MW (260,000 lb/hr) steam flow
Design pressure:	6.3 MPa (900 psig)
Design temperature:	761K (910°F)
Year built:	1963
Furnace volume:	552 m ³ (19500 ft ³)
Furnace heating surface:	460 m ² (4950 ft ²)

SECTION 3.0

TEST RESULTS

This section summarizes the emission and efficiency data collected on the pulverized-coal-fired boiler. This field test took place over a period of 44 days. The tests were conducted with a low-sulfur western coal as the fuel. The results presented herein summarize the gaseous and particulate emissions data, efficiency, and conclusions for the boiler operating on the low-NO_x condition for extended duration.

3.1 CONTINUOUS MONITOR CERTIFICATION TEST 5

The continuous monitor described in the previous section was used to measure boiler gaseous emissions. Following shipment to the test site, the monitoring system was installed and certification tests performed in accordance with Performance Specifications 2 (PS2) and 3 (PS3), 40 CFR 60 Specifications. Appendix B (see Appendix D of this document) establishes minimum performance specifications that the NO monitoring system must meet in terms of eight parameters: accuracy, calibration error, two- and 24-hour zero drifts, two- and 24-hour calibration drifts, response time, and operational period.

The continuous monitor system was installed, and the analyzers were initially calibrated on May 30, 1979. A daily event schedule for the certification tests is presented in Table 3-1.

The performance of the continuous monitor is summarized in Table 3-2 where the measured values are compared with the specification values. Included in this table is the performance of the CO analyzer, which is not covered by the performance specification. The CO analyzer is used to monitor the combustion conditions in the boiler since it is a very sensitive indicator of combustion performance. Tables C-1 through C-18, Appendix C, show the performance of each of the analyzers for the certification tests.

TABLE 3-1. SCHEDULE OF CERTIFICATION TEST EVENTS

Date	Time	Event
6-4-79	1000	Calibration error determination
6-5-79	0850	Initial 24-hour zero and span reading. Initial 2-hour zero and span reading.
6-5-79	0850	1st 2-hour zero and span drift point
6-5-79	1050	2nd 2-hour zero and span drift point
6-5-79	1250	3rd 2-hour zero and span drift point
6-5-79	1450	4th 2-hour zero and span drift point
6-5-79	1650	5th 2-hour zero and span drift point
6-5-79	1850	6th 2-hour zero and span drift point
6-6-79	0850	7th 2-hour zero and span drift point
6-6-79	0850	1st 24-hour zero and calibration drift point. Initial 2-hour zero and calibration reading.
6-6-79	1050	8th 2-hour zero and span drift point
6-6-79	1250	9th 2-hour zero and span drift point
6-6-79	1450	10th 2-hour zero and span drift point
6-6-79	1650	11th 2-hour zero and span drift point
6-6-79	1850	12th 2-hour zero and span drift point
6-7-79	0850	2nd 24-hour zero and calibration drift point, initial 2-hour zero and calibration reading.
6-7-79	1050	13th 2-hour zero and span drift point
6-7-79	1250	14th 2-hour zero and span drift point
6-7-79	1450	15th 2-hour zero and span drift point
6-7-79	1650	16th 2-hour zero and span drift point
6-7-79	1850	17th 2-hour zero and span drift point
6-7-79	1000	Instrument response time tests
6-8-79	0850	3rd 24-hour zero and calibration drift
6-8-79	0930	1st set of relative accuracy samples taken
6-8-79	1030	2nd set of relative accuracy samples taken
6-8-79	1130	3rd set of relative accuracy samples taken
6-8-79	1230	4th set of relative accuracy samples taken
6-8-79	1330	5th set of relative accuracy samples taken
6-8-79	1430	6th set of relative accuracy samples taken
6-8-79	1530	7th set of relative accuracy samples taken
6-8-79	1630	8th set of relative accuracy samples taken
6-8-79	1730	9th set of relative accuracy samples taken
6-9-79	0850	4th 24-hour zero and calibration drift point
6-10-79	0850	5th 24-hour zero and calibration drift point
6-11-79	0850	6th 24-hour zero and calibration drift point
6-12-79	0850	7th and final 24-hour zero and calibration drift point
7-10-79	0830	1st set of relative accuracy samples taken
7-10-79	0930	2nd set of relative accuracy samples taken
7-10-79	1030	3rd set of relative accuracy samples taken
7-10-79	1130	4th set of relative accuracy samples taken
7-10-79	1230	5th set of relative accuracy samples taken
7-10-79	1330	6th set of relative accuracy samples taken
7-10-79	1430	7th set of relative accuracy samples taken
7-10-79	1530	8th set of relative accuracy samples taken
7-10-79	1630	9th set of relative accuracy samples taken

TABLE 3-2. INSTRUMENT SPECIFICATIONS AND PERFORMANCE

Parameter	Specifications		Performance
A. Thermo Electron Series 10 NOx Analyzer			
1. Accuracy		≤ 20% of mean ref. value	17.70%
2. Calibration error	mid high	≤ 5% cal gas value	1.05%
		≤ 5% of cal gas value	0%
3. Zero drift (2 hour)		2% of span	1.99%
4. Zero drift (24 hour)		2% of span	1.79%
5. Calibration drift (2 hour)		2% of span	1.40%
6. Calibration drift (24 hour)		2.5% of span	0%
7. Response time		15 minute maximum	83 sec
8. Operational period		168 hour minimum	720 hr
B. Horiba Instruments PIR 2000 CO₂ Analyzer			
1. Zero drift (2 hour)		≤ 0.4 pct CO ₂	0%
2. Zero drift (24 hour)		≤ 0.5 pct CO ₂	0%
3. Calibration drift (2 hour)		≤ 0.4 pct CO ₂	0.05%
4. Calibration drift (24 hour)		≤ 0.5 pct CO ₂	0%
5. Response time		10 minutes	77 sec
6. Operational period		168 hour minimum	720 hr
C. Beckman Instruments Model 742 O₂ Analyzer			
1. Zero drift (2 hour)		≤ 0.4 pct O ₂	DNA*
2. Zero drift (24 hour)		≤ 0.5 pct O ₂	DNA*
3. Calibration drift (2 hour)		≤ 0.4 pct O ₂	0.07%
4. Calibration drift (24 hour)		≤ 0.5 pct O ₂	0.16%
5. Response time		10 minutes	89 sec
6. Operational period		168 hour minimum	720 hr
D. Horiba Instruments PIR 2000 CO Analyzer			
1. Calibration error	mid high	≤ 5% of cal gas value	CO instrument was out for service
		≤ 5% of cal gas value	
2. Zero drift (2 hour)		2% of span	
3. Zero drift (24 hour)		2% of span	
4. Calibration drift (2 hour)		2% of span	
5. Calibration drift (24 hour)		2.5% of span	
6. Response time		15 minute maximum	
7. Operational period		168 hour minimum	

* Instrument has no zero adjustment.

Certified calibration gases were obtained from Scott Environmental Technology, Inc. The calibration gases included 50% and 90% span gases for the NO, CO₂, CO, and O₂ analyzers and a zero gas (N₂). In addition to the certified analysis supplied by the vendor, sample flasks were taken for each calibration gas and sent to an independent laboratory for analysis.

Relative accuracy tests for the NO analyzer were performed as outlined in PS2 using EPA Reference Method 7 (phenoldisulfonic acid [PDS] colorimetric) as the standard. Nine sets of three PDS flasks were collected at one-hour intervals at the beginning and end of the 30-day test period. At the fifteenth day, an abbreviated series of six flasks were taken. All sample flasks were returned to an independent laboratory for analysis. The results of the relative accuracy determination are shown in Tables C-17 and C-18 for the beginning and end of the 30-day test period. Both tests show that the NO instrument was well within the accuracy requirements of PS2. The relative accuracy of the Thermo Electron NO analyzer was % based on the first PDS test series and % based on the final test series. The relative accuracy requirement set forth in PS2 is \leq 20% of mean reference value.

3.2 PULVERIZED COAL-FIRED BOILER TESTS

The continuous monitor was installed by KVB personnel on May 30, 1979, outside the control room at Site 3, a pulverized-coal-fired boiler. A single unheated 9.5 mm (3/8") nylon sample line was strung from the duct downstream of the baghouse to the continuous monitor. A single stainless steel probe with a sintered stainless steel filter was installed in the sampling port. Particulate samples were collected from two ports in the stack located 90 deg apart.

The boiler was initially tested in the as-found condition on June 6, 1979. The boiler load for these tests was 49.2 MW thermal output (168,000 lb steam/hr).

Boiler operation was then modified to incorporate staged combustion as the control technology. Staged combustion was achieved by biasing the coal pulverizing mills which feed the burners. The boiler has two rows of two burners on the front face and two pulverizing mills. Each mill feeds one row

of burners. In order to effect staged combustion, the power to the mills was biased so that the lower burners were fed more coal than the upper burners. The total air flow was held constant, which produced a fuel-rich condition in the lower zone with an air-rich zone above. With two burners biased to give staged combustion, the maximum steam flow was approximately 200,000 lb/hr.

3.2.1 Gaseous Emissions

A summary of the daily observations of gaseous emissions and comments on boiler operating conditions is presented in Table 3-3. These data were recorded hourly by a technician. Also included in Table 3-3 are the particulate and efficiency measurements for the boiler. These data are used to verify measurements recorded on the strip charts and the automatic data logger.

3.2.2 Particulate Emissions

The results of the particulate tests are presented in Table 3-4 for low-NO_x tests and baseline tests. Two of the tests (Nos. 3-3 and 3-4) were also used for collecting samples for analysis of polycyclic organic matter (POM) by modifying the Method 5 sampling train as described in paragraph 2.1.3. The average particulate loading for the unmodified operation (Tests 3, 4, 5, and 6) was 6.2 ng/J (0.0143 lb/10⁶ Btu), while the average particulate loading in the modified or low-NO_x mode was 6.3 ng/J (0.0147 lb/10⁶ Btu). These data show that there is no significant difference in particulate emission between operation in the modified condition and operation in the normal mode.

The boilers at this facility had recently been outfitted with baghouse-type particulate collection equipment, and the stack effluent was extremely clear of any particulate matter. No visible emission was detected at any time during the test period.

3.2.3 POM Emissions

Samples were collected for analysis of polycyclic organic matter using a Method 5 sampling train with XAD-2, a POM absorber, inserted. Sample time was extended to two hours to provide a large enough sample for Battelle to analyze. Following the sampling period, the organic resin module was sealed and returned to Battelle Columbus Laboratories for analysis. The sampling probe and glassware were washed with a 50-50 mixture of methylene chloride and methanol per Battelle instructions. The filter and wash were also sent to Battelle following weighing.

TABLE 3-3. SUMMARY OF GASEOUS AND PARTICULATE EMISSIONS AT SITE 3
PULVERIZED COAL FIRED BOILER

Date 1979	Load Condition	Time		Nominal Steam Load			NO ^a			CO ^a			Particulate		Stack Temp.		Comments
		Start	Finish	Genar.	MW	X lb/hr	MWTH	% O ₂	% CO ₂	mg/J	ppm	mg/J	ppm	mg/J	lb/MMB	*K	*F
6/1	High	2100	2200	22	198	58.0	6.4	11.3	379	646	12	34					As Found
	Low	2000	2100	19	172	50.4	6.4	11.2	355	605	13	37					
	7 Mr. Average	1700	2400	21	187	55.4	6.6	11.3	389	662	12	35					
6/2	High	2000	2100	24	208	55.1	6.1	0	424	722	12	35					SCA
	Low	1300	1900	5	48	14.2	7.6	13.3	339	577	12	32					
	24 Hr. Average	0000	2400	8	69	19.8	8.3	11.0	378	644	11	30					
6/3	High	1100	1200	7	64	18.8	9.1	0	351	597	7	19					SCA
	Low	1200	2400	5	48	14.1	7.9	0	310	527	11	31					
	24 Hr. Average	0000	2400	5	49	14.4	9.0	0	345	588	9	24					
6/4	High	1000	1500	24	208	60.0	8.5	0	411	701	8	22					SCA + LEA
	Low	0000	0700	5	48	14.1	10.1	0	297	506	6	16					
	Average	0900	1700	22	191	55.4	8.3	0	390	663	8	22					
	24 Hr. Average	0000	2400	14	120	34.7	8.5	0	328	559	9	26					
6/5	High	1600	1700	11	100	28.7	8.7	10.4	338	581	11	32					SCA
	Low	0000	0200	6	50	14.5	9.2	0	233	397	9	26					
	Average	0900	1700	9	76	22.0	8.9	10.3	393	498	15	41					
	24 Hr. Average	0000	2400	8	68	19.7	9.5	10.3	285	485	11	32					
6/6	High	1600	1900	18	162	47.4	7.2	10.8	266	453	2	6					SCA + LEA
	Low	0000	1300	6	56	16.2	8.2	10.4	305	519	11	30					
	Average	0900	1700	9	83	23.9	8.1	10.3	304	518	16	44					
	24 Hr. Average	0000	2400	9	78	22.6	8.1	10.4	302	514	11	30					

* Corrected to 3% O₂.

(continued)

**SCA = Staged Combustion Air
LEA = Low Excess Air

TABLE 3-3. (continued)

Date 1979	Load Condition	Time		Nominal Steam Load				NO ^a		CO ^a		Particulate		Stack Temp.		Comments		
		Start	Finish	Gen. MM	K lb/hr	MTH	% O ₂	% CO ₂	ng/J	ppm	ng/J	ppm	ng/J	lb/MMB	°K	°F	EIF.%	
6/7	High	1500	1900	19.0	168	49.2	7.4	11.6	285	466	16	42			449	349		SCA + LEA
	Low	1100	--	6.6	60	17.6	9.1	10.3	335	549	14	37			430	315		
	Average	0900	1700	11.6	100	29.3	8.4	10.8	316	518	15	40			439	330		
	Partic. Test 3-1	1500	1900	19.0	168	49.2	7.4	11.6	305	499	16	42	12.77	.0297	449	349	85.70	Low NO _x condition, Meth. 5 Test
	24 Hr. Average	0000	2400	11.6	100	29.3	8.4	10.7	337	551	16	44						
6/8	High	0900	1100	19.5	168	49.2	7.7	11.5	397	650	15	40			445	342		SCA + LEA
	Low	1300	1400	19.0	164	48.1	7.8	11.3	342	559	20	53			447	345		
	Average	0900	1700	19.2	166	48.6	7.7	11.3	369	604	19	50			446	344		
	Partic. Test 3-2	1300	1700	19.0	166	48.6	7.8	11.1	348	569	22	60	8.43	.0196	447	345	84.67	Low NO _x condition, Meth. 5 Test
	24 Hr. Average	0000	2400	11.9	103	30.2	8.3	10.8	345	564	22	58						
6/9	High	1100	1300	10.5	85	24.9	8.6	10.1	367	600	14	38			415	288		SCA + LEA
	Low	0900	--	7.5	64	18.8	8.0	10.9	328	537	19	50			423	302		
	Average	0800	1500	9.3	78	22.9	8.5	10.2	359	587	15	41			417	292		
	24 Hr. Average	0000	2400	7.9	68	19.9	8.6	10.2	346	566	17	46						
	6/10	High	1200	--	7.5	64	18.8	7.4	10.1	351	574	17	45			415	288	
6/11	Low	1500	--	7.1	60	17.6	8.6	10.0	360	590	22	58			416	290		
	Average	0800	1500	7.3	62	18.2	8.7	10.0	360	590	21	56			415	287		
	24 Hr. Average	0000	2400	7.3	63	18.5	8.8	10.1	352	576	17	47						
	High	0800	1100	8.4	69	20.2	8.5	10.6	336	550	17	46			422	300		CO instrument disconnected for service
	Low	1500	--	7.6	56	16.4	8.5	10.3	350	573	--	--			422	300		
6/12	Average	0800	1500	8.1	67	19.6	8.5	10.5	343	562	--	--			422	300		SCA + LEA
	24 Hr. Average	0000	2400	7.3	63	18.5	8.6	10.4	343	562	--	--						
	High	1500	--	19.0	164	48.1	7.7	11.2	396	648	--	--			449	349		SCA + LEA
	Low	0800	--	8.7	74	21.7	8.9	10.3	367	600	--	--			422	300		
	Average	0800	1500	12.0	102	29.9	8.2	10.7	371	608	--	--			431	317		
25	Part. Test 3-3	1500	1800	19.0	164	48.1	7.4	11.3	361	591	--	--	7.75	.0180	446	344	85.06	Low NO _x condition, Meth. 5 Test, POM
	24 Hr. Average	0000	2400	12.1	104	30.5	8.6	10.3	373	610	--	--						

* Corrected to 3% O₂.

(continued)

TABLE 3-3. (continued)

Date 1979	Load Condition	Time		Nominal Steam Load			NO ^a		CO ^a		Particulate		Stack Temp.		Comments		
		Start	Finish	Gen. MW	K lb/hr	MWTH	% O ₂	% CO ₂	ng/J	ppm	ng/J	ppm	ng/J	lb/HOB	°K	°F	Eff. %
6/13	High	0800	1400	11.5	94	27.5	8.7	10.8	395	646	--	--			426	308	SCA + LEA
	Low	1500	--	9.0	76	22.3	8.6	10.9	381	624	--	--			427	310	
	Average	0800	1500	11.2	92	27.0	8.7	10.8	393	643	--	--			426	308	
	24 Hr. Average	0000	2400	9.3	80	23.4	9.0	10.6	371	607	--	--					
6/14	High	1300	1600	24.0	215	63.0	8.5	10.8	495	810	--	--			461	371	
	Low	1100	1200	7.0	58	17.0	8.6	10.4	284	464	--	--			425	305	
	Average	0800	1600	15.6	158	46.3	8.4	10.7	393	644	--	--			441	334	
	Partic. Test 3-4	1300	1600	24.0	215	63.0	8.2	10.8	495	810	--	--	7.82	.0180	461	371	83.85 Baseline, Meth. 5 Test, POM
6/15	24 Hr. Average	0000	2400	15.3	132	38.7	8.4	10.7	393	643	--	--					
	High	1100	1300	7.8	66	19.3	9.1	10.5	310	507	--	--			436	326	Baseline
	Low	0800	--	7.0	60	17.6	9.2	10.0	266	436	--	--			432	318	
	Average	0800	1500	7.6	65	19.0	9.1	10.3	302	495	--	--			435	324	
6/16	24 Hr. Average	0000	2400	7.2	62	18.2	9.2	10.2	304	497	--	--					
	Spot Reading	1200	--	7.2	60	17.6	9.4	9.9	330	540	--	--			436	325	SCA
	24 Hr. Average	0000	2400	8.6	74	21.7	9.0	10.3	334	546	--	--					
	Spot Reading	1200	--	7.8	68	19.9	8.9	10.1	337	551	--	--			433	320	SCA
6/17	24 Hr. Average	0000	2400	7.7	66	19.3	8.8	10.3	321	526	--	--					
	High	1000	--	11.2	100	29.3	9.1	10.2	357	584	--	--			433	320	SCA + LEA
	Low	1200	1500	7.0	60	17.6	9.1	10.1	331	542	--	--			433	320	
	Average	0800	1500	8.8	77	22.6	8.9	10.2	338	554	--	--			433	320	
6/18	24 Hr. Average	0000	2400	8.6	74	21.7	8.8	10.3	322	527							
	High	0900	--	11.5	100	29.3	8.9	10.1	350	573	--	--			427	310	SCA + LEA
	Low	1100	1300	7.0	60	17.6	9.0	9.9	332	543	--	--			433	320	
	Average	0800	1500	8.8	77	22.6	9.2	9.7	329	539	--	--			432	318	
6/19	24 Hr. Average	0000	2400	8.2	71	20.8	9.0	9.9	343	561							
	High	0900	--	10.0	79	23.1	8.6	10.0	335	549	24	65			430	315	CO instrument back in service
	Low	1000	1500	7.5	65	19.0	8.8	10.1	337	551	18	48			420	322	SCA + LEA
	Average	0800	1500	7.9	68	19.9	8.8	10.1	336	550	20	53			434	321	
6/20	24 Hr. Average	0000	2400	7.5	65	19.0	9.0	10.1	328	538	9	2					

^a Corrected to 34 O₂.

(continued)

TABLE 3-3. (continued)

Date 1979	Load Condition	Time		Gener. MW	Nominal Steam Load		NO ^a		CO ^a		Particulate		Stack Temp.		Comments			
		Start	Finish		K lb/hr	MWTH	% O ₂	% CO ₂	ng/J	ppm	ng/J	ppm	ng/J	lb/MMB	"K	"F	Eff.%	
6/21	High	1400	1500	17.0	149	43.7	7.8	11.4	459	751	<1	<1			455	360		SCA + LEA
	Low	1200	--	8.0	70	20.5	8.4	10.7	295	483	5	13			436	325		
	Average	0800	1500	12.2	102	29.9	8.6	10.7	368	602	3	9			424	330		
	24 Hr. Average	0000	2400	12.5	108	31.6	8.8	10.7	389	637	12	31						
6/22	Steady Load	0800	1500	7.5	65	19.0	8.7	10.5	400	655	14	37			420	297		LEA
	24 Hr. Average	0000	2400	7.4	64	18.8	8.6	10.5	399	653	16	44						
6/23	Spot Reading	1300	--	11.7	100	29.3	8.2	10.6	406	665	23	63			427	310		SCA + LEA
	24 Hr. Average	0000	2400	8.9	77	22.6	8.4	10.7	390	638	17	46						
6/24	Spot Reading	1300	--	8.0	70	20.5	8.5	10.7	340	557	7	20			436	325		SCA + LEA
	24 Hr. Average	0000	2400	8.0	69	20.2	8.7	10.7	349	571	16	43						
6/25	High	1500	1700	11.3	94	27.5	8.9	10.5	340	557	6	15			425	305		SCA + LEA
	Low	0800	--	8.5	70	20.5	9.1	10.2	341	558	33	88			427	310		
	Average	0800	1700	10.5	88	25.8	9.0	10.6	317	519	13	36			426	307		
	24 Hr. Average	0000	2400	9.2	79	23.1	8.9	10.4	346	566	19	50						
6/26	High	1000	1100	9.9	83	24.3	9.0	10.5	396	648	48	129			426	308		SCA + LEA
	Low	1200	1600	7.0	60	17.6	8.4	10.7	370	606	16	44			427	307		
	Average	0800	1600	8.2	70	20.5	8.7	10.6	382	625	27	72			425	305		
	24 Hr. Average	0000	2400	7.4	64	18.8	8.8	10.4	385	631	19	50						
6/27	High	1200	1300	10.2	87	25.5	8.6	12.4	394	645	16	43			426	307		Data logger out 1200-1400 SCA+LEA
	Low	1500	1600	8.1	68	19.9	8.5	14.2	395	647	14	37			430	315		
	Average	0800	1600	9.3	77	22.6	8.6	12.1	392	642	16	42			427	309		
	24 Hr. Average	0000	2400	8.0	69	20.2	8.6	12.7	374	613	15	39						
6/28	High	1000	--	10.8	90	26.4	8.2	10.9	404	661	13	34			426	307		SCA + LEA
	Low	1500	--	7.8	70	20.5	8.2	10.8	380	622	15	40			432	319		
	Average	0800	1600	9.2	77	22.6	8.3	10.7	373	611	15	40			429	312		
	24 Hr. Average	0000	2400	8.4	72	21.1	8.6	10.5	419	686	14	37						
6/29	High	1300	--	13.2	114	33.4	8.1	11.0	458	749	4	10			446	344		SCA + LEA
	Low	0700	--	6.6	54	15.8	8.7	10.3	521	853	34	92			430	314		
	Average	0700	1500	9.9	84	24.6	8.5	10.6	444	726	12	33			435	324		
	24 Hr. Average	0000	2400	7.9	68	19.9	8.5	10.4	446	730	18	48						

^a Corrected to 3% O₂.

(continued)

TABLE 3-3. (continued)

Date 1979	Load Condition	Time		Nominal Steam Load			NO ^a		CO ^a		Particulate		Stack Temp.			Comments	
		Start	Finish	Gener. kW	K lb/hr	MMTH	% O ₂	% CO ₂	ng/J	ppm	ng/J	ppm	ng/J	lb/MMB	*K	*F	Eff.%
							66	19.3	8.7	10.6	417	682	7	19	425	305	SCA + LEA
6/30	Spot Reading	1000	--	7.8	66	19.3	8.7	10.6	417	682	7	19					SCA + LEA
	24 Hr. Average	0000	2400	7.7	66	19.3	8.8	10.1	395	646	16	44					
7/1	Spot Reading	0800	--	6.2	50	14.7	9.2	9.8	398	651	8	22					SCA + LEA
	24 Hr. Average	0000	0800	7.0	60	17.6	9.2	9.6	397	649	19	52					Data logger out 0800-2400 No data taken
7/2	High	0900	1000	8.3	70	20.5	8.5	10.5	391	640	2	6					Data logger out 0000-1300 SCA + LEA
	Low	1600	--	7.8	66	19.3	8.3	10.7	364	595	8	22					No data taken
	Average	0800	1600	8.1	68	19.9	8.4	10.5	375	613	6	17					
	24 Hr. Average	1300	2400	7.5	65	19.0	8.4	10.6	365	598	11	29					
7/3	High	1500	--	24.9	223	65.3	8.0	11.0	521	853	4	10					SCA + LEA
	Low	1100	--	8.2	69	20.2	8.4	10.6	381	623	3	8					425 305
	Average	0800	1500	15.1	136	39.8	8.4	10.7	421	689	6	16					440 333
	24 Hr. Average	0000	2400	14.7	127	37.2	8.3	10.6	421	690	10	27					
7/4	Spot Reading	1100	--	8.6	73	21.4	8.5	10.5	375	613	5	13					SCA + LEA
	24 Hr. Average	0000	1800	7.9	68	19.9	8.6	10.2	373	611	18	48					Data logger out 1900-2400 No data taken
7/5	High	1100	--	11.8	101	29.6	9.1	9.8	469	768	3	9					SCA + LEA
	Low	1200	--	8.7	76	22.3	8.7	10.2	359	588	8	21					429 312
	Average	0900	1600	9.8	86	25.2	8.3	10.5	370	605	7	18					Data logger out 0000-0800
	24 Hr. Average	0900	2400	8.2	71	20.8	8.3	10.4	346	566	7	19					
7/6	High	1200	--	12.3	100	29.3	8.3	10.6	332	544	7	19					SCA + LEA
	Low	0800	--	7.7	67	19.6	8.8	10.7	318	521	7	18					422 301
	Average	0800	1500	10.2	88	25.8	8.5	10.5	328	537	197	23					425 305
	24 Hr. Average	0000	2400	8.8	76	22.3	8.4	10.4	335	549	11	29					
7/7	Spot Reading	1100	--	8.3	74	21.7	8.5	10.3	352	576	17	47					SCA + LEA
	24 Hr. Average	0000	2400	7.5	65	19.0	8.5	10.2	337	552	19	50					
7/8	Spot Reading	1300	--	6.2	50	14.7	9.0	9.6	337	552	27	72					SCA + LEA
	24 Hr. Average	0000	1700	7.0	60	17.6	8.9	10.0	345	565	32	87					Data logger out 1700-2400

^a Corrected to 3% O₂.

(continued)

TABLE 3-3. (continued)

Date 1979	Load Condition	Time		Gener. MW	Nominal Steam Load			NO ^a		CO ^a		Particulate		Stack Temp.		Comments		
		Start	Finish		K lb/hr	MWTH	% O ₂	% CO ₂	ng/J	ppm	ng/J	ppm	ng/J	lb/MMB	°K	°F	Eff.%	
7/9	High	0900	--	9.8	73	21.4	8.3	10.7	340	557	33	89			429	312	SCA + LEA	
	Low	1300	1600	7.1	59	17.3	8.5	10.5	315	516	41	111			425	306	Data logger out 0000-0700	
	Average	0900	1600	7.6	62	18.2	8.5	10.5	327	536	36	96			426	308		
	24 Hr. Average	0800	2400	7.3	63	18.5	8.5	10.5	317	519	59	135						
7/10	High	1600	1900	21.3	189	55.4	8.3	10.7	504	825	38	101			464	375		
	Low	0800	--	7.7	67	19.6	8.6	10.5	360	589	35	93			426	308	Baseline	
	Average	0800	1900	18.3	163	47.8	8.4	10.7	472	773	39	106			454	358	Unit #7 down 2100-2400	
	Partic. Test 3-5	1100	1400	19.6	173	50.7	8.2	10.8	496	809	33	90	6.41	.0149	457	363	84.88	
	Partic. Test 3-6	1600	1900	21.3	189	55.4	8.3	10.7	504	825	38	101	4.27	.0099	464	375	84.47 Baseline, Meth. 5 Test	
	24 Hr. Average	0000	2100	14.8	128	37.5	9.0	9.9	415	679	52	139					Baseline, Meth. 5 Test	
29	7/11	High	1600	--	21.1	186	54.5	7.7	11.2	475	777	38	103			459	367	
	Low	1300	--	19.0	166	48.6	7.8	11.5	380	622	36	97			454	358	SCA + LEA	
	Average	0900	1800	20.0	176	51.6	7.7	11.4	414	677	36	96			455	360	Unit #7 down 0000-0800	
	Partic. Test 3-7	1000	1300	19.1	167	48.9	7.8	11.6	385	630	36	97	2.53	.0059	454	357	85.65	
	Partic. Test 3-8	1500	1800	20.8	185	54.2	7.8	11.2	458	749	36	97	3.20	.0074	459	366	85.14 Low NO _x condition, Meth. 5 Test	
	24 Hr. Average	0800	2400	18.1	156	45.7	7.8	11.2	428	701	39	104					Low NO _x condition, Meth. 5 Test	
7/12	High	0800	--	19.4	164	48.1	7.2	11.6	330	540	34	91			443	338	SCA + LEA	
	Low	1200	--	19.0	168	49.2	7.7	11.3	375	614	36	96			454	358		
	Average	0800	1300	19.2	168	49.2	7.6	11.3	365	598	35	94			452	354		
	Partic. Test 3-9	1000	1300	19.1	170	49.8	7.7	11.2	370	606	35	95	3.24	.0075	454	358	85.34	
	24 Hr. Average	0000	1300	13.1	113	33.1	8.0	10.7	348	569	43	116					Low NO _x condition, Meth. 5 Test	

^a Corrected to 3% O₂.

TABLE 3-4. PARTICULATE DATA SUMMARY - SITE 3,
PULVERIZED COAL FIRED BOILER

Test No.	Date	Load		O ₂	Particulate		Opacity	Test Description
	1979	MW	10 ³ lb/hr	%	ng/J	lb/10 ⁶ Btu	%	
3-1	6/7	49.2	168	7.4	12.77	0.0297	0	Low NOx
3-2	6/8	48.6	166	7.8	8.43	0.0196	0	Low NOx
3-3	6/12	48.0	164	7.4	7.75	0.0180	0	Low NOx-POM sample
3-4	6/14	63.0	215	8.2	7.82	0.0180	0	Baseline-POM sample
3-5	7/10	50.7	173	8.2	6.41	0.0149	0	Baseline
30	3-6	7/10	55.4	189	8.3	4.27	0.0099	Baseline
3-7	7/11	48.9	167	7.8	2.53	0.0059	0	Low NOx
3-8	7/11	54.2	185	7.8	3.20	0.0074	0	Low NOx
3-9	7/12	49.8	170	7.7	3.24	0.0075	0	Low NOx

These samples were analyzed by capillary-EI GC-MS utilizing a 30M SE-52 column with hydrogen as a carrier gas. All data were collected by single ion monitoring (SIM) to improve selectivity and sensitivity.

The results of the analyses are presented in μg per total sample. The quantitative detection limit was $0.5 \mu\text{g}$; thus samples with POM's present at levels lower than this are reported as $< 0.5 \mu\text{g}$ (the standard deviation at lower levels was prohibitively high for accurate quantitation). Samples reporting POM values of ND (none detected) are at a level of less than $0.1 \mu\text{g}$ (the approximate qualitative detection limit). The standard deviation on points around $0.5 \mu\text{g}$ averaged around $\pm 20\%$; at levels around $5 \mu\text{g}$ it averaged around $\pm 15\%$; and at levels above $12 \mu\text{g}$ the standard deviation averaged around $\pm 10\%$.

The results of the Battelle analyses are presented in Table 3-5 for the low-NO_x and baseline operating conditions. The POM analyses for the low-NO_x condition are presented in the first six columns for the XAD-2 module, the filter and probe wash, and total. The corresponding data for the unmodified condition are shown in the last six columns.

The total POM showed only a very small difference (about 3.5%) between the two conditions. The low-NO_x condition resulted in a 40% lower phenanthrene measurement but showed a corresponding increase in benzofluoranthenes and perylene.

3.2.4 Boiler Efficiency

Boiler efficiency calculations were made for as-found and low-NO_x operating conditions. The ASME Abbreviated Efficiency Test Method was used to determine the boiler efficiency. This test method is described in Appendix A.

Coal, fly ash, and bottom ash samples were collected during the test series. The coal and ash samples were submitted to an independent laboratory for ultimate and heating value analyses. Fly ash and bottom ash samples were analyzed for carbon content and heating value. The fly ash with the highest carbon content did not ignite in the colorimeter; therefore, the determination

TABLE 3-5. SUMMARY OF POM ANALYSES FOR SITE 3, PULVERIZED COAL FIRED BOILER

PAH	LOW NO _X TEST						BASE LINE TEST					
	XAD-2 Module		Filter & Probe Wash		Total		XAD-2 Module		Filter & Probe Wash		Total	
	µg	µg/m ³	µg	µg/m ³	µg	µg/m ³	µg	µg/m ³	µg	µg/m ³	µg	µg/m ³
Phenanthrene	39.0	25.81	1.1	0.73	40.1	26.54	87.4	42.84	2.9	1.42	90.3	44.26
Anthracene	3.0	1.98	ND	-	3.0	1.98	1.0	0.49	<0.5	<0.24	1.0<1.5	0.49<0.74
Methyl Anthracenes/Phenanthrenes	25.2	16.68	1.7	1.12	26.9	17.80	27.9	13.68	3.8	1.86	31.7	15.54
Fluoranthene	2.5	1.65	<0.5	<0.33	2.5<3.0	1.65<1.98	2.8	1.37	<0.5	<0.24	2.8<3.3	1.37<1.62
Pyrene	4.8	3.18	0.6	0.40	5.4	3.57	5.4	2.65	0.7	0.34	6.1	2.99
Methyl Pyrene/Fluoranthene	1.4	0.93	<0.5	<0.33	1.4<1.9	.93<1.26	1.4	0.69	<0.5	<0.24	1.4<1.9	0.69<0.93
Benzo(c)phenanthrene	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-
Benz(a)anthracene	ND	-	ND	-	ND	-	ND	-	<0.5	<0.24	<0.5	<0.24
Chrysene	ND	-	<0.5	<0.33	<0.5	<0.33	<0.5	<0.24	<0.5	<0.24	<1.0	<0.49
Methyl Chrysene	ND	-	<0.5	<0.33	<0.5	<0.33	ND	-	<0.5	<0.24	<0.5	<0.24
Dimethylbenzanthracenes	<0.5	<0.33	ND	-	<0.5	<0.33	ND	-	ND	-	ND	-
Benzofluoranthenes	10.9	7.21	<0.5	<0.33	10.9<11.4	7.21<7.54	1.2	0.59	<0.5	<0.24	1.2<1.7	0.59<0.83
Benz(e)pyrene	1.5	0.99	<0.5	<0.33	1.5<2.0	0.99<1.32	0.9	0.44	<0.5	<0.24	0.9<1.4	0.44<0.69
Benz(a)pyrene	<0.5	<0.33	ND	-	<0.5	<0.33	1.0	0.49	ND	-	1.0	0.49
Perylene	5.9	3.90	<0.5	<0.33	5.9<6.4	3.90<4.24	<0.5	<0.24	<0.5	<0.24	<1.0	<0.49
Indeno-pyrene	ND	-	ND	-	ND	-	<0.5	<0.24	<0.5	<0.24	<1.0	<0.49
Benzo(ghi)perylene	ND	-	<0.5	<0.33	<0.5	<0.33	<0.5	<0.24	<0.5	<0.24	<1.0	<0.49
3-Methylcholanthrene	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-
Dibenzanthracenes	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-
Dibenzpyrenes	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-
Coronene	ND	-	<0.5	<0.33	<0.5	<0.33	ND	-	<0.5	<0.24	<0.5	<0.24
TOTAL (µg/m ³)	62.3<62.9		2.3<4.9		64.6<67.8		63.2<64.2		3.6<6.5		66.8<70.7	
Sample Volume (m ³)	----- 1.511 -----						----- 2.040 -----					

N

X-811-6015-1224

of the heat of combustion was not attempted on the remaining fly ash sample with the lower carbon content. The results of the coal, fly ash, and bottom ash analyses are tabulated in Table 3-6. Tabulated chronologically, the data indicate that the ash content of the coal changed from 14.95% to 7.36% during the test series.

Table 3-7 lists a summary of the boiler efficiencies. The data in this table show that during low-NO_x operation with low excess air, an efficiency increase of about 1% was achieved, with the primary contribution due to dry gas losses.

Figure 3-1 shows unit efficiency as a function of excess oxygen for the boiler. This figure clearly illustrates the effect of low-NO_x operation on boiler efficiency.

3.2.5 Data Reduction

The gaseous emissions data measured by the analyzers were recorded on both strip chart recorders and an automatic data logger. A log of all appropriate control room data was also kept. Daily steam flow charts were also collected from the operators.

A tabulation of hourly averages was compiled for the entire test period. Each hourly average consists of approximately 900 measurements from each analyzer. After the data were compiled, they were spot checked and edited to detect obvious errors and anomalies. The data were then keypunched on cards for input to the computer. Table 3-8 is an example of the listing of hourly averages. The entire listing of hourly averages is presented in Appendix E.

After data editing was completed, 24-hour averages were calculated. For an average to be valid, at least 75 percent of the hourly points in that interval had to be valid. Table 3-9 shows a summary of the 24-hour averages for the 30-day test at Site 3.

A statistical summary was prepared to determine the following parameters for the 24-hour averages: mean, standard deviation, maximum, minimum, range, and average deviation. These parameters were calculated assuming the data were normally distributed. When the data were plotted on normal probability paper it was apparent that the data were not normally distributed.

TABLE 3-6. SUMMARY OF COAL AND ASH ANALYSIS
FROM SITE 3

<u>Coal</u>	<u>Test</u>	<u>Test</u>
3-1	3-5	3-5
3-2	3-6	3-7
3-3	3-8	3-8
3-4	3-9	
Ultimate Analysis:		
Moisture, percent	5.6	10.67
Carbon, percent	57.40	59.55
Hydrogen, percent	4.31	4.15
Nitrogen, percent	1.25	1.03
Sulfur, percent	0.73	0.30
Ash, percent	14.95	7.36
Oxygen, percent (by difference)	15.76	16.94
Heat of Combustion:		
Gross Btu/lb	10,160	10,910
Net Btu/lb	9,760	10,520
<u>Ash</u>		
Fly Ash:		
Carbon, percent	1.76	1.72
Bottom Ash:		
Carbon, percent	11.72	11.72
Gross Btu/lb	1,800	1,800
Net Btu/lb	1,750	1,750

**TABLE 3-7. SUMMARY OF BOILER EFFICIENCY CALCULATIONS FOR SITE 3
PULVERIZED COAL FIRED BOILER**

<u>Test Number</u> <u>Date</u>	3-1 6-7-79	3-2 6-8-79	3-3 6-12-79	3-4 6-14-79	3-5 7-10-79	3-6 7-10-79	3-7 7-11-79	3-8 7-11-79	3-9 7-12-79
Test Load									
10^3 lb/hr	168	166	164	215	173	189	167	185	170
Generator MW	19.0	19.0	19.0	24.0	19.6	21.3	19.1	20.8	19.1
Percent of Capacity	65	64	63	83	67	73	64	71	65
Stack O ₂ , percent	7.4	7.8	7.4	8.2	8.2	8.3	7.8	7.8	7.7
Stack CO, ppm	42	60	--	--	90	101	97	97	95
Stack Temperature (°K/°F)	449/349	447/345	446/344	461/371	457/363	464/375	454/357	459/366	454/358
Ambient Temperature (°K/°F)	294/70	294/70	294/70	294/70	294/70	294/70	294/70	294/70	294/70
Boiler Heat Losses									
Dry Gas	7.57	8.57	8.18	9.39	8.85	9.30	8.11	8.64	8.41
Moisture in Fuel	0.65	0.65	0.65	0.67	1.16	1.17	1.16	1.16	1.16
Moisture from H ₂	4.47	4.50	4.50	4.63	4.06	4.08	4.05	4.07	4.05
Combustibles	1.06	1.06	1.06	1.06	0.49	0.49	0.49	0.49	0.49
Radiation	0.55	0.55	0.55	0.40	0.55	0.50	0.55	0.50	0.55
Total Losses	14.30	15.33	14.94	16.15	15.12	15.53	14.35	14.86	14.66
Boiler Efficiency, percent	85.70	84.67	85.06	83.85	84.88	84.47	85.65	85.14	85.34




Figure 3-1. Boiler Efficiency vs Excess O₂. Pulverized Coal Fired Boiler, Site 3.

TABLE 3-8. FORMAT OF HOURLY EMISSIONS DATA FOR
SITE 3, PULVERIZED COAL FIRED BOILER

HOURLY DATA												
DRY STACK GAS CONCENTRATION												
DATE	TIME	LOAD	O2	CO2	CH4	NO	CO	NO	CO	NO	NG/J	NG/J
		MWTH	VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	PPMV	PPMV	NG/J	NG/J
		MEAS										
6/ 2/79	100	39.8	7.4	11.0	19.	501.	25.	665.	9.	390.		
6/ 2/79	200	17.6	6.5	9.9	18.	428.	27.	618.	9.	363.		
6/ 2/79	300	15.2	9.4	9.4	17.	417.	26.	650.	9.	381.		
6/ 2/79	400	15.2	9.5	.0	15.	418.	23.	656.	8.	385.		
6/ 2/79	500	15.8	9.6	.0	15.	414.	24.	655.	8.	385.		
6/ 2/79	600	15.8	9.6	.0	13.	415.	21.	656.	8.	386.		
6/ 2/79	700	15.8	9.2	.0	13.	416.	19.	636.	7.	373.		
6/ 2/79	800	16.4	8.9	.0	12.	413.	18.	616.	7.	361.		
6/ 2/79	900	16.8	9.1	.0	13.	430.	20.	652.	7.	383.		
6/ 2/79	1000	15.8	9.2	.0	16.	443.	24.	678.	9.	398.		
6/ 2/79	1100	15.8	9.8	.0	15.	454.	24.	707.	8.	415.		
6/ 2/79	1200	20.2	9.5	.0	22.	445.	35.	699.	13.	411.		
6/ 2/79	1300	15.2	9.1	.0	23.	455.	35.	690.	12.	405.		
6/ 2/79	1400	14.4	8.2	.0	24.	461.	35.	649.	12.	361.		
6/ 2/79	1500	14.1	.0	13.3	19.	465.	26.	398.	6.	234.		
6/ 2/79	1600	14.6	8.1	.0	25.	446.	34.	624.	12.	366.		
6/ 2/79	1700	14.1	7.4	.0	27.	453.	36.	600.	13.	352.		
6/ 2/79	1800	14.1	7.4	.0	27.	455.	36.	603.	13.	354.		
6/ 2/79	1900	14.1	7.0	.0	28.	458.	36.	590.	13.	346.		
6/ 2/79	2000	36.9	6.4	.0	28.	510.	35.	630.	13.	370.		
6/ 2/79	2100	55.1	6.1	.0	29.	597.	35.	722.	12.	424.		
6/ 2/79	2200	35.2	6.5	.0	28.	534.	35.	664.	13.	390.		
6/ 2/79	2300	14.1	7.2	.0	29.	453.	38.	592.	14.	347.		
6/ 2/79	2400	14.1	7.4	.0	25.	437.	33.	579.	12.	340.		

TABLE 3-9. SUMMARY OF 24-HOUR AVERAGES OF STACK EMISSIONS
FROM A PULVERIZED-COAL-FIRED BOILER (SITE 3)

DATE	TIME	24 HOUR DATA									
		DRY STACK GAS CONCENTRATION									
		LOAD	O2	CO2	CU	NO	CU	NO	CO	NO	NG/J
MTH	MEAS	MEAS	PPMV	NG/J							
MEAS	MEAS	MEAS	MEAS	MEAS	MEAS	MEAS	MEAS	MEAS	MEAS	MEAS	MEAS
6/ 1/79		55.4	6.6	11.3	28.	529.	35.	662.	12.	389.	*
6/ 2/79		19.8	8.3	11.0	21.	455.	30.	644.	11.	378.	*
6/ 3/79		14.4	9.0	.0	16.	392.	24.	588.	9.	345.	*
6/ 4/79		34.7	8.5	.0	18.	389.	26.	559.	9.	328.	*
6/ 5/79		19.7	9.5	10.3	20.	309.	32.	485.	11.	285.	*
6/ 6/79		22.6	8.1	10.4	21.	366.	30.	514.	11.	302.	*
6/ 7/79		29.4	8.3	10.8	31.	383.	44.	544.	16.	320.	*
6/ 8/79		30.3	8.1	10.5	28.	410.	40.	572.	14.	336.	*
6/ 9/79		19.9	8.4	10.1	27.	406.	38.	581.	14.	341.	*
6/10/79		16.4	8.6	10.0	33.	396.	48.	576.	17.	338.	*
6/11/79		18.6	8.5	10.3	38.	388.	55.	561.	20.	329.	*
6/12/79		30.5	8.8	10.4	0.	408.	0.	602.	0.	353.	*
6/13/79		23.3	9.0	10.6	0.	397.	0.	599.	0.	352.	*
6/14/79		38.6	8.5	10.5	49.	444.	71.	641.	25.	376.	*
6/15/79		18.3	9.2	10.2	86.	324.	131.	495.	47.	291.	*
6/16/79		21.8	9.1	10.2	0.	364.	0.	551.	0.	323.	*
6/17/79		19.4	8.8	10.3	0.	356.	0.	526.	0.	309.	*
6/18/79		21.7	8.8	10.3	0.	357.	0.	530.	0.	311.	*
6/19/79		20.7	8.9	10.0	35.	358.	52.	532.	19.	312.	*
6/20/79		18.9	9.0	10.0	33.	361.	50.	544.	18.	319.	*
6/21/79		31.7	8.8	10.7	21.	431.	31.	637.	11.	374.	*
6/22/79		18.8	8.6	10.5	35.	450.	51.	656.	18.	385.	*
6/23/79		22.6	8.4	10.6	36.	449.	52.	641.	18.	377.	*
6/24/79		20.3	8.6	10.2	34.	395.	50.	577.	16.	339.	*
6/25/79		23.1	9.0	10.2	36.	410.	54.	616.	19.	361.	*
6/26/79		18.8	8.9	10.3	37.	427.	55.	639.	20.	375.	*
6/27/79		20.2	8.6	10.3	15.	426.	22.	620.	8.	364.	*
6/28/79		21.0	8.6	10.5	25.	473.	37.	686.	13.	403.	*
6/29/79		19.8	8.5	10.4	34.	504.	48.	728.	17.	427.	*
6/30/79		19.2	8.8	10.2	30.	438.	44.	647.	16.	380.	*
7/ 1/79		17.6	8.8	9.9	33.	455.	48.	673.	17.	395.	*
7/ 2/79		18.9	8.5	10.3	33.	436.	47.	629.	17.	369.	*
7/ 3/79		37.2	8.3	10.6	19.	487.	28.	694.	10.	407.	*
7/ 4/79		19.8	8.6	10.3	35.	424.	51.	618.	16.	363.	*
7/ 5/79		20.7	8.5	10.3	15.	416.	21.	599.	7.	352.	*
7/ 6/79		22.3	8.4	10.3	21.	385.	30.	550.	11.	323.	*
7/ 7/79		19.1	8.5	10.2	35.	384.	50.	556.	18.	326.	*
7/ 8/79		17.7	8.7	9.9	47.	351.	69.	514.	25.	302.	*
7/ 9/79		18.4	8.4	10.3	80.	366.	115.	526.	41.	309.	*
7/10/79		37.6	9.0	9.9	92.	453.	139.	681.	50.	400.	*
7/11/79		45.6	7.8	11.2	75.	519.	102.	708.	37.	416.	*
7/12/79		33.0	8.0	10.6	84.	407.	117.	566.	42.	332.	*

Further analysis indicated that the data were log-normally distributed. The graph shown in Figure 3-2 illustrates the performance of the pulverized-coal-fired boiler based on the 24-hour averages for all data. The mean NO emission rate is 340 ng/J with a geometric dispersion of 1.13. The data presented in this figure represent 42 24-hour averages. A frequency chart of the hourly averages is presented as Table 3-10. These data were then used to prepare the graph shown as Figure 3-2. The data were subsequently divided into two load ranges to determine the effect boiler load has on the distribution.

Table 3-11 presents a frequency distribution of NO_x emissions for boiler load less than 20 MW thermal output and for greater than 20 MW. The data for less than 20 MW are plotted in Figure 3-3. This curve shows the mean value is 340 ng/J with a dispersion of 1.13. The data for greater than 20 MW are presented in Figure 3-4 where the mean value is 350 ng/J with a dispersion of 1.10. These data show that 99% of the data are less than 430 ng/J for boiler loads greater than 20 MW and 460 ng/J for loads less than 20 MW.

The 24-hour average NO_x emissions data were plotted as a function of time from the start of testing. These data are presented in Figure 3-5. Solid symbols indicate steam loads greater than 20 MW thermal output and open symbols indicate steam loads less than 20 MW. This figure illustrates the variation in NO_x emissions measurements for this unit. Figure 3-6 shows the daily average excess O_2 as a function of time from the start of testing. As this illustrates the excess O_2 did not vary greatly over the test period. These measurements were made in the stack downstream of the baghouse. A measurement of stack gas O_2 was made at the boiler outlet for comparison purposes. The excess O_2 measured at the boiler outlet was 4.2% compared with 8.5% O_2 after the baghouse.




Figure 3-2. NO Emissions from Site 3 - Pulverized Coal-Fired Boiler

TABLE 3-10. NO EMISSION - FREQUENCY DATA
SITE 3 - PULVERIZED COAL-FIRED BOILER

Call	Frequency	Cum. Frequency	Plot Percent
280-295	2	2	5
296-310	4	6	14
311-325	6	12	28
326-340	7	19	44
341-355	5	24	56
356-370	4	28	65
371-385	7	35	81
386-400	3	38	88
401-415	2	40	93
416-430	2	42	98

$$\bar{x} = 340 \text{ ng/J}$$

$$g.d = 1.13$$

TABLE 3-11. NO EMISSION-FREQUENCY DATA FOR
SITE 3 - PULVERIZED-COAL-FIRED BOILER

Cell	Frequency	Cum. Frequency	Load	Percent Plot
			<20 MW	
285-294	2	2		10
295-304	1	3		15
305-314	2	5		25
315-324	1	6		30
325-334	2	8		40
335-344	2	10		50
345-354	1	11		55
355-364	1	12		60
365-374	1	13		65
375-384	3	16		80
385-394	1	17		85
395-404	1	18		90
405-414	0	-		-
415-424	0	-		-
425-434	1	19		95

Cell	Frequency	Cum. Frequency	Load	Percent Plot
			>20 MW	
301-310	1	1		4
311-320	3	4		17
321-330	3	7		29
331-340	3	10		42
341-350	0	10		42
351-360	3	13		54
361-370	2	15		62
371-380	3	18		75
381-390	1	19		79
391-400	1	20		83
401-410	2	22		92
411-420	1	23		96




Figure 3-3. NO Emissions from Site 3, a Pulverized Coal Fired Boiler
Boiler Load <20 MW




Figure 3-4. NO Emissions from Site 3, a Pulverized Coal Fired Boiler
Boiler Load >20 MW




Figure 3-5. Daily average NO_x emissions for Site 3 - Pulverized coal fired boiler




Figure 3-6. Daily average O₂ measurements for Site 3. Pulverized coal fired boiler.

Emission factors for the pulverized-coal-fired boiler were calculated using the procedure set forth in 40 CFR 60, Subpart D. The NO emission factor (dry basis) was calculated using the following equation:

$$E = C_d F_d \frac{20.9}{20.9 - \% O_{2d}}$$

where

E = pollutant emission rate, ng/J (lb/million Btu)

C_d = NO concentration, ng/scm (lb/scf)

F_d = stoichiometric conversion factor, 2.63×10^{-7} dscm/J
(9,780 dscf/million Btu), for bituminous coal

O_{2d} = oxygen concentration, percent by volume, dry

The conversion of measured NO values (ppmV) to ng/scm is made by multiplying by 1.912×10^6 . To convert from ppm to lb/scf, multiply by 1.19×10^{-7} .

NO_x emissions are measured as NO and the NO_x emission rates reported herein are calculated based on the molecular weight of NO_2 .

SECTION 4.0

REFERENCES

1. Maloney, K. L. et al., "Systems Evaluation of the Use of Low-Sulfur Western Coal in Existing Small and Intermediate-Sized Boilers," EPA Contract No. 68-02-1863, EPA 600/7-78-153a.
2. Cato, G. A. et al., "Field Testing: Application of Combustion Modifications to Control Pollutant Emissions from Industrial Boilers - Phase I," EPA 650/2-74-078a, NTIS No. PB 238 920, June 1975.
3. Cato, G. A. et al., "Field Testing: Application of Combustion Modifications to Control Pollutant Emissions from Industrial Boilers - Phase II," EPA 600-2-76-086a, NTIS No. PB 253 500, April 1976.
4. Devitt, T. et al., "Population and Characterization of Industrial/Commercial Boilers in the U.S.," EPA-600/7-79-178a, August 1979.

APPENDIX A

EFFICIENCY MEASUREMENTS

EFFICIENCY

Unit efficiencies for boilers are calculated and reported according to the ASME Power Test Codes for Steam Generation Units, PTC 4.1-1965. These codes present instructions for two acceptable methods of determining thermal efficiency. One method is the direct measurement of input and output and requires the accurate measurement of the quantity and high-heating value of the fuel, heat credits, and the heat absorbed by the working fluids. The second method involves the direct measurements of heat losses and is referred to as the heat loss method. This method requires the determination of losses, heat credits, and ultimate analysis and high-heat value of the fuel. Some of the major heat losses include losses due to heat in dry flue gas, losses due to fuel moisture content, losses due to combustible material in refuse and flue gas, and radiation losses. Heat credits are defined as those amounts added to the process in forms other than the chemical heat in the fuel "as fired." These include quantities such as sensible heat in the fuel, heat in the combustion air, and heat from power conversion in a pulverizer or fan. The relationships between input, output, credits, and losses for a steam generator are illustrated in Figure A-1.

KVB's experience has shown the heat-loss efficiency determination method to be the most reliable when working with industrial boilers. Accurate fuel input measurements are rarely possible on industrial boilers due to the lack of adequate instrumentation, thus making the input-output method undesirable. The accuracy of the efficiency based on the heat loss method is determined primarily by the accuracy of the flue gas temperature measurement immediately following the last heat removal station, the stack gas excess O₂ level, the fuel analysis, the ambient temperature, and proper identification of the combustion device external surfaces (for radiation losses). Determination of the radiation and other associated losses may appear to be a rather imposing calculation, but in practice it can be accomplished by utilizing standard efficiency calculation procedures. Inaccuracies in determining efficiency occasionally occur even with the heat




Figure A-1. Heat balance of steam generator.

loss method primarily because of out-of-calibration unit instrumentation such as the stack gas exit temperature. However, this problem has been resolved by KVB test engineers through the use of portable instrumentation and separate temperature readings.

The abbreviated efficiency test procedure which considers only the major losses and the chemical heat in the fuel as input will be followed. Tables A-1 and A-2 are the ASME Test Forms for Abbreviated Efficiency Tests on steam generators which exemplify the type of forms to be used for recording the necessary data and performing the required calculations.

KVB has developed a program for the HP-67 calculator which will provide the heat loss efficiency from the stack data. Figure A-2 shows the HP-67 keyed calculation sheet for calculating efficiency by the ASME Heat Loss Method.

SUMMARY SHEET

TABLE A-1
ASME TEST FORM
FOR ABBREVIATED EFFICIENCY TEST

PTC 4.1-a(1964)

		TEST NO.	BOILER NO	DATE
OWNER OF PLANT		LOCATION		
TEST CONDUCTED BY		OBJECTIVE OF TEST		
BOILER MAKE & TYPE		DURATION		
STOKER TYPE & SIZE		RATED CAPACITY		
PULVERIZER, TYPE & SIZE		BURNER, TYPE & SIZE		
FUEL USED	MINE	COUNTY	STATE	SIZE AS FIRED
PRESSURES & TEMPERATURES				
1	STEAM PRESSURE IN BOILER DRUM	psig		COAL AS FIRED PROX. ANALYSIS
2	STEAM PRESSURE AT S. H. OUTLET	psig	37	MOISTURE
3	STEAM PRESSURE AT R. H. INLET	psig	38	VOL MATTER
4	STEAM PRESSURE AT R. H. OUTLET	psig	39	FIXED CARBON
5	STEAM TEMPERATURE AT S. H. OUTLET	F	40	ASH
6	STEAM TEMPERATURE AT R. H. INLET	F		TOTAL
7	STEAM TEMPERATURE AT R. H. OUTLET	F	41	Btu per lb AS FIRED
8	WATER TEMP. ENTERING (ECON) (BOILER)	F	42	ASH SOFT TEMP. ASTM METHOD
9	STEAM QUALITY %, MOISTURE OR P.P.M.			COAL OR OIL AS FIRED ULTIMATE ANALYSIS
10	AIR TEMP. AROUND BOILER (AMBIENT)	F	43	CARBON
11	TEMP AIR FOR COMBUSTION (This is Reference Temperature) †	F	44	HYDROGEN
12	TEMPERATURE OF FUEL	F	45	OXYGEN
13	GAS TEMP LEAVING (Boiler) (Econ.) (Air Htr.)	F	46	NITROGEN
14	GAS TEMP. ENTERING AH (If conditions to be corrected to guaranteed)	F	47	SULPHUR
	UNIT QUANTITIES		40	ASH
15	ENTHALPY OF SAT. LIQUID (TOTAL HEAT)	Btu/lb	37	MOISTURE
16	ENTHALPY OF (SATURATED) (SUPERHEATED) STM	Btu/lb		TOTAL
17	ENTHALPY OF SAT. FEED TO (BOILER) (ECON.)	Btu/lb		COAL PULVERIZATION
18	ENTHALPY OF REHEATED STEAM R. H. INLET	Btu/lb	48	GRINDABILITY INDEX*
19	ENTHALPY OF REHEATED STEAM R. H. OUTLET	Btu/lb	49	FINENESS % THRU 50 M ²
20	HEAT ABS/LB OF STEAM (ITEM 16 - ITEM 17)	Btu/lb	50	FINENESS % THRU 200 M ²
21	HEAT ABS/LB R. H. STEAM (ITEM 19 - ITEM 18)	Btu/lb	64	INPUT-OUTPUT EFFICIENCY OF UNIT %
22	DRY REFUSE (ASH PIT + FLY ASH) PER LB AS FIRED FUEL	lb/lb		HEAT LOSS EFFICIENCY
23	Btu PER LB IN REFUSE (WEIGHTED AVERAGE)	Btu/lb	65	HEAT LOSS DUE TO DRY GAS
24	CARBON BURNED PER LB AS FIRED FUEL	lb/lb	66	HEAT LOSS DUE TO MOISTURE IN FUEL
25	DRY GAS PER LB AS FIRED FUEL BURNED	lb/lb	67	HEAT LOSS DUE TO H ₂ O FROM COMB OF N ₂
	HOURLY QUANTITIES		68	HEAT LOSS DUE TO COMBUST. IN REFUSE
26	ACTUAL WATER EVAPORATED	lb/hr	69	HEAT LOSS DUE TO RADIATION
27	REHEAT STEAM FLOW	lb/hr	70	UNMEASURED LOSSES
28	RATE OF FUEL FIRING (AS FIRED wt)	lb/hr	71	TOTAL
29	TOTAL HEAT INPUT (Item 28 x Item 41) 1000	kB/hr	72	EFFICIENCY = (100 - Item 71)
30	HEAT OUTPUT IN BLOW-DOWN WATER	kB/hr		
31	TOTAL HEAT (Item 26+Item 20)+(Item 27+Item 21)+Item 30 OUTPUT 1000	kB/hr		
FLUE GAS ANAL. (BOILER)(ECON) (AIR HTR) OUTLET				
32	CO ₂	% VOL		
33	O ₂	% VOL		
34	CO	% VOL		
35	N ₂ (BY DIFFERENCE)	% VOL		
36	EXCESS AIR	%		

* Not Required for Efficiency Testing

† For Point of Measurement See Par. 7.2.B.1-PTC 4.1-1964

CALCULATION SHEET

TABLE A-2
ASME TEST FORM
FOR ABBREVIATED EFFICIENCY TEST

PTC 4.1-b (1964)

Revised September, 1965

OWNER OF PLANT	TEST NO.	BOILER NO.	DATE
30 HEAT OUTPUT IN BOILER BLOW-DOWN WATER = LB OF WATER BLOW-DOWN PER HR X		[ITEM 15 ITEM 17] ----- 1000	LB/hr
24 If impractical to weigh refuse, this item can be estimated as follows DRY REFUSE PER LB OF AS FIRED FUEL = $\frac{\% \text{ ASH IN AS FIRED COAL}}{100 - \% \text{ COMB. IN REFUSE SAMPLE}}$			
25 CARBON BURNED PER LB AS FIRED FUEL = $\frac{100}{100} - \left[\frac{\text{ITEM 22} \times \text{ITEM 23}}{14,500} \right] = \dots$			NOTE: IF FLUE DUST & ASH PIT REFUSE DIFFER MATERIALLY IN COMBUSTIBLE CONTENT, THEY SHOULD BE ESTIMATED SEPARATELY. SEE SECTION 7, COMPUTATIONS.
26 DRY GAS PER LB AS FIRED FUEL = $\frac{11\text{CO}_2 + 8\text{O}_2 + 7(\text{N}_2 + \text{CO})}{3(\text{CO}_2 + \text{CO})} \times (\text{LB CARBON BURNED PER LB AS FIRED FUEL} + \frac{3}{8})$ $= \frac{11 \times \text{ITEM 32} + 8 \times \text{ITEM 33} + 7 \left(\text{ITEM 35} + \text{ITEM 34} \right)}{3 \times (\text{ITEM 32} + \text{ITEM 34})} \times \left[\frac{\text{ITEM 24} + \text{ITEM 47}}{267} \right] = \dots$			
36 EXCESS AIR = $100 \times \frac{\text{O}_2 - \frac{\text{CO}}{2}}{.2682\text{N}_2 - (\text{O}_2 - \frac{\text{CO}}{2})} = 100 \times \frac{\text{ITEM 33} - \frac{\text{ITEM 34}}{2}}{.2682(\text{ITEM 35}) - (\text{ITEM 33} - \frac{\text{ITEM 34}}{2})} = \dots$			
	HEAT LOSS EFFICIENCY	Btu/lb AS FIRED FUEL	LOSS THV X 100 =
65 HEAT LOSS DUE TO DRY GAS = $\frac{\text{LB DRY GAS PER LB AS FIRED FUEL} \times C_p \times (\text{T}_{\text{vap}} - \text{T}_{\text{air}})}{\text{Unit}} = \frac{\text{ITEM 25} \times 0.24 \times (\text{ITEM 13}) - (\text{ITEM 11})}{\dots} = \dots$		$\frac{65}{41} \times 100 =$	
66 HEAT LOSS DUE TO MOISTURE IN FUEL = $\frac{\text{LB H}_2\text{O PER LB AS FIRED FUEL} \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA & T GAS LVG}) - (\text{ENTHALPY OF LIQUID AT T AIR})]}{100} = \frac{\text{ITEM 37} \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA & T ITEM 13}) - (\text{ENTHALPY OF LIQUID AT T ITEM 11})]}{100} = \dots$		$\frac{66}{41} \times 100 =$	
67 HEAT LOSS DUE TO H ₂ O FROM COMB. OF H ₂ = $9\text{H}_2 \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA & T GAS LVG}) - (\text{ENTHALPY OF LIQUID AT T AIR})]$ $= 9 \times \frac{\text{ITEM 44}}{100} \times [(\text{ENTHALPY OF VAPOR AT 1 PSIA & T ITEM 13}) - (\text{ENTHALPY OF LIQUID AT T ITEM 11})] = \dots$		$\frac{67}{41} \times 100 =$	
68 HEAT LOSS DUE TO COMBUSTIBLE IN REFUSE = $\text{ITEM 22} \times \text{ITEM 23} = \dots$		$\frac{68}{41} \times 100 =$	
69 HEAT LOSS DUE TO RADIATION = $\frac{\text{TOTAL BTU RADIATION LOSS PER HR}}{\text{LB AS FIRED FUEL} - \text{ITEM 20}} = \dots$		$\frac{69}{41} \times 100 =$	
70 UNMEASURED LOSSES ** = \dots		$\frac{70}{41} \times 100 =$	
71 TOTAL = \dots		\dots	
72 EFFICIENCY = $(100 - \text{ITEM 71})$		\dots	

† For rigorous determination of excess air see Appendix 9.2 - PTC 4.1-1964

* If losses are not measured, use ABMA Standard Radiation Loss Chart, Fig. B, PTC 4.1-1964

** Unmeasured losses listed in PTC 4.1 but not tabulated above may be provided for by assigning a mutually agreed upon value for Item 70.

FIGURE A-2

HP-67 KEYED CALCULATION SHEET

ASME ABBREVIATED EFFICIENCY CALCULATION - HEAT LOSS METHOD

Test No. _____ Date _____ Location _____ Unit No. _____ Fuel _____
(Turn Calculator Off and Then On. Load Program Card.)

- | | | | | | | |
|--|---|--|-------------|---|-------------|--|
| A. FROM FUEL ANALYSIS: | Wt. % in as-fired fuel: C | % Moisture | % H | % S | % N | |
| | A1: (STO 0) | | A2: (STO 1) | A3: (STO 2) | A4: (STO 3) | |
| High heating value of fuel as-fired | | | Btu/lb | | | |
| | A5: (STO 4) | | | | | |
| B. FROM FLUE GAS ANALYSIS: | Volume % in flue gas of: O ₂ | % CO ₂ | % CO | | | |
| | B1: (STO 5) | | B2: (STO 6) | B3: (STO 7) | | |
| C. FROM REFUSE (FLY ASH AND ASH PIT) ANALYSIS: | C1. Fraction of dry refuse in fuel | _____ lbs dry refuse/lb as-fired fuel
(STO 8) | | | | |
| | C2. Heating value of dry refuse (weighted average) | _____ Btu/lb dry refuse
(STO 9) | | | | |
| | C3. Wt. % of combustibles in refuse | _____
(if P > S) (STO 4) (if P < S) | | | | |
| D. MEASURED TEMPERATURES | D1. Gas temp. leaving boiler, econ. or air heater | _____ °F
(STO A) | | | | |
| | D2. Comb. air temp. | _____ °F
(STO B) | | | | |
| E. FROM STEAM TABLES: | E1. Enthalpy: H ₂ O(g) at temp. D1 & 1 psia | _____ Btu/lb
(STO C) | | | | |
| | E2. Enthalpy: H ₂ O(l) at comb. air temp. | _____ Btu/lb
(STO D) | | | | |
| F. FROM ABIA STANDARD RADIATION LOSS CHART (UNLESS MEASURED): | F1. Heat loss due to radiation | _____ % of gross heat input
(STO E) | | | | |
| G. FROM UNIT SPECIFICATIONS (if available, otherwise enter 0): | G1. Unmeasured losses | _____ % of gross heat input
(if P > S) (STO 0) (if P < S) | | | | |
| 1. Excess Air % | $\frac{100 (B1 - B3)}{0.5364(100 - B1 - B2) - (2B1 - B3)}$ | (A) _____ % | | | | |
| 2. (Optional) Pounds dry gas per pound of fuel = | $\frac{B1 + 4B2 + 700}{3(B2 + B3)} \times \left[\frac{A1}{100} - \frac{C1 \times C2}{14500 \left(1 - \frac{C3}{100}\right)} + \frac{3A4}{800} \right]$ | | | | | (R/S) _____ lbs dry gas/lb as-fired fuel |
| <u>Heat Losses</u> | | <u>% of Gross Heat Input</u> | | <u>(Optional) Btu/lb as-fired fuel*</u> | | |
| 3. Due to dry gas = $\frac{24 \times E1 \cdot 2 \times (D1 - D2)}{A5}$ | (B) | | | (R/S) _____ | | |
| 4. Due to moisture in fuel = $\frac{A2 \times (E1 - E2)}{A5}$ | (C) | | | (R/S) _____ | | |
| 5. Due to H ₂ O from combustion of H ₂ = $\frac{9 \times A3(E1 - E2)}{A5}$ | (D) | | | (R/S) _____ | | |
| 6. Due to combustibles in refuse = $\frac{100 \times C1 \times C2}{A5}$ | (E) | | | (R/S) _____ | | |
| 7. Total Losses = Sum of calculated losses + F1 + G1 | (f a) | | | (R/S) _____ | | |
| 8. Efficiency = 100 - Total Losses | (f b) | | | | | |

*Calculated as percent of gross heat input x AS + 100

APPENDIX B

DATA RECORDING FORMATS

DOCUMENTATION OF RESULTS

Field Measurements

During testing, two sets of measurements are recorded: 1) control room data which indicate the operating condition of the device and 2) emissions data that are the readouts of the individual analyzers.

The concentration of nitric oxide (NO), carbon dioxide (CO_2), carbon monoxide (CO), and oxygen (O_2) are measured and recorded. The concentration of these species are measured and displayed continuously by analyzers and strip chart recorders mounted in a console. The strip chart recordings are retained for future reference. Opacity, particulate loading, and POM concentration are measured at the sampling port and the measurements recorded on data sheets.

A number of data sheets have been developed for use in field measurements. These data sheets are listed below together with their purpose. An example of each sheet follows.

Figure No.	Title	Purpose
B-1	Thirty-Day Field Test Data Sheets	Record control room data
B-2	Gaseous Emissions Data	Record Gaseous Emissions Analyzer data
B-3	Nozzle Size, Q_m and ΔH Calculations	Calculate nozzle size, flow rate, and ΔH for Method 5 Test
B-4	Response Time for Continuous Instruments	Continuous monitor certification
B-5	Zero and Calibration Drift (24 hr)	Continuous monitor certification
B-6	Zero and Calibration Drift (2 hr)	Continuous monitor certification
B-7	Accuracy Determination (NOx)	Continuous monitor certification
B-8	Calibration Error Determination	Continuous monitor certification

<u>Figure No.</u>	<u>Title</u>	<u>Purpose</u>
B-9	Analysis of Calibration Gas Mixture	Continuous monitor certification
B-10	Particulate Calculation Sheet	Calculate weight of solid particulate catch
B-11	Stack Data	Record volumes, temperatures, pressures of Method 5 control unit.
B-12	Particulate Emission Calculations	Calculate particulate emission factors
B-13	Velocity Traverse	Record temperature and velocity profile of stack
B-14	Liquid or Solid Fuel Calculation	Calculate stoichiometric properties of fuel

Figure B-1.

KVB, Inc.

THIRTY DAY FIELD TEST DATA SHEET

Site _____ Fuel _____

<u>Test No.</u>				
<u>Date</u>				
<u>Time</u>				
<u>Load</u>				
<u>Test Description</u>				
<u>Windbox, in. H₂O</u>				
<u>Furnace, in. H₂O</u>				
<u>Overfire air, in. H₂O</u>				
<u>Boiler exit, in. H₂O</u>				
<u>Economizer exit, in. H₂O</u>				
<u>ID fan inlet, in. H₂O</u>				
<u>Steam flow, kpph</u>				
<u>Integrated steam flow</u>	<u>Time/</u>			
	<u>k lbs</u>			
<u>Air flow indic.</u>				
<u>Superheater outlet temp. °F</u>				
<u>Flue gas temp,</u>				
<u>economizer inlet, °F</u>				
<u>Flue gas temp,</u>				
<u>economizer outlet, °F</u>				
<u>Temp F.W. economizer</u>				
<u>outlet, °F</u>				
<u>Feed Water Control, %</u>				
<u>Temp F.W. heater, °F</u>				
<u>F.W. economizer inlet, °F</u>				
<u>Steam pressure, psig</u>				
<u>Fuel feed</u>				
<u>Overfire air damper</u>				
<u>F.D. fan</u>				
<u>F.D. fan damper</u>				
<u>I.D. fan</u>				
<u>I.D. fan damper</u>				

(continued)

Figure B-1. (Continued)

THIRTY DAY FIELD TEST DATA SHEET

Page 2

Comments:

Figure B-2.

KVB, INC.

Date _____

GASEOUS EMISSIONS DATA

Engr.

Low NO_x Control Method _____

Unit No. _____ **Location** _____

Fuel _____ **Capacity** _____

Unit Type _____ **Burner Type** _____

1. Test No.							
2. Time							
3. Load							
4. Process Rate							
5. Flue Diam. or Size, ft							
6. Probe Position							
7. Oxygen (%)							
8. NO _x (hot) read/3% O ₂ (ppm)							
9. NO (hot) read/3% O ₂ (ppm)							
10. NO ₂ (hot) read/3% O ₂ (ppm)							
11. Carbon Dioxide (%)							
12. Carbon Monoxide (ppm) uncor/cor							
13. Opacity							
14. Atmos. Temp. (°F/°C)							
15. Dew Point Temp. (°F/°C)							
16. Atmos. Pressure (in. Hg)							
17. Relative Humidity (%)							

Data Sheet

6015-23

9/29/78

KVB11-60

KVB11-0013-1224

Figure B-3.

HP-67 Keyed Calculation Sheet
NOZZLE SIZE, Q_m and ΔH CALCULATIONS

Test No. _____ Date _____ Location _____
 Unit No. _____ Fuel _____ Sampling Method _____
 Crew: Engr. _____ Techs. _____

DATA

<u>Constants</u>	<u>Key</u>	<u>Actual Conditions</u>	<u>Key</u>
Pitot Factor, F_p	(STO 1)	Meter Temperature, T_m ($^{\circ}$ F)	(STO 5)
Orifice Factor, J	(STO 2)	Barom. Press., P_{bar} (in. Hg)	(STO 6)
Orifice Diam., D_o (in.)	(STO 3)	Static Press. Diff., ΔP_s (lwg)	(STO 7)
Ideal Meter Flow, Q_m (ACFM)	(STO 4)	Nozzle Temp., T_n ($^{\circ}$ F)	(STO 8)
		Stack Vel. Press., Δp (lwg)	(STO 9)

NOTE: TO RECALCULATE IDEAL NOZZLE SIZE,
RESTORE DATA IN REGISTERS 4 THRU 8, CLEAR
STACK AND RE-ENTER % H_2O , % O_2 , and % CO_2

Gaseous Stack Composition

% H_2O	(%)	ENTER
% O_2 dry	(%)	ENTER
% CO_2 dry	(%)	

IDEAL NOZZLE CALCULATION

(A) Ideal Nozzle Size, D_n (Ideal) _____ inches

METER FLOW RATE AND ORIFICE PRESS. DIFF. CALCULATIONS

Actual Nozzle Size, D_n (Actual) _____ inches

(C) Actual Meter Flow Rate, Q_m (Actual) _____ ACFM (on meter)

(RCL 7) Orifice Press. Diff., ΔH to obtain Q_m (Actual) _____ lwg

NOTE: To Determine Q_m and ΔH for Other Actual Nozzle Size, Key in D_n (Actual). Press C for Q_m , then RCL 7 for ΔH .

For one D_n (Actual) with Changing Stack Velocity Pressure (Δp) and Nozzle Temperature (T_n)
(It is not necessary to restore data in registers 4-8 for these calculations)

Δp (ENTER) (lwg)	T_n ($^{\circ}$ F)	(E) Q_m (ACFM)	(R/S) $\Delta H'$ (lwg)
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

EQUATIONS

$$(1) n_d = 1/25 (4 + CO_2 + 4 O_2) + 28 \quad (\text{lb/lb mole}) \quad (2) n_d = n_d \left(\frac{10 H_2O - 100}{-100} \right) + \frac{18}{100} (10 H_2O) \quad (\text{lb/lb mole})$$

$$(3) P_g = 13.6 P_{bar} + \Delta P_s \quad (\text{in. of water}) \quad (4) V_n = 182875 P_g / (\Delta p (T_n + 460)) / P_g R_g \quad (\text{ft/min})$$

$$(5) Q_m = \frac{Q_m (\text{Ideal}) (T_n + 460) 13.6 P_{bar} (182875 V_n^2 J^2 D_o^4) (T_n + 460)}{(1 - (10 H_2O/100)) (T_n + 460) P_g (182875 V_n^2 J^2 D_o^4) (T_n + 460) - 768 D_n^2 n_d (\text{Ideal})} \quad (\text{ACFM})$$

$$(6) D_n (\text{Ideal}) = \sqrt{183.35 (Q_m / V_n)} \quad (\text{in.}) \quad (7) Q_m (\text{Actual}) = V_n D_n^2 (\text{Actual}) / 183.35 \quad (\text{ACFM})$$

$$(8) Q_{m1} = \frac{Q_m (\text{Actual}) (T_n + 460) (1 - (10 H_2O/100)) (13.6 P_{bar} + \Delta P_s)}{(T_n + 460) (13.6 P_{bar} + \Delta H_{1-1})} \quad \text{assume } \Delta H_0 = \Delta P_s \quad (\text{ACFM})$$

$i = 1, n$ where $n = \text{number of iterations to obtain } \Delta H_{1-1}$. $\frac{(\Delta H_{i-1} - \Delta H_i)}{\Delta H_{i-1}} \leq 0.001$

$$(9) \Delta H_i = \frac{768 D_{n1}^2 n_d 13.6 P_{bar}}{182875 V_n^2 J^2 D_o^4 (T_n + 460) - 768 Q_{m1}^2 n_d} \quad (\text{in. of water})$$

Figure B-4.

KVB

Engineer _____

MONITOR PERFORMANCE TEST DATA SHEET

RESPONSE TIME FOR CONTINUOUS INSTRUMENTS

Date of Test _____

Span Gas Concentration _____ ppm

Analyzer Span Setting _____ ppm

1 _____ seconds

Upscale 2 _____ seconds

3 _____ seconds

Average upscale response _____ seconds

1 _____ seconds

Downscale 2 _____ seconds

3 _____ seconds

Average downscale response _____ seconds.

System average response time (slower time) = _____ seconds.

$$\% \text{ deviation from slower} = \left[\frac{\text{average upscale minus average downscale}}{\text{slower time}} \right] \times 100\% = \underline{\quad}$$

Figure B-5.

KVB

Engineer _____

MONITOR PERFORMANCE TEST DATA SHEET

ZERO AND CALIBRATION DRIFT (24-HOUR)

$$\text{Zero Drift} = [\text{Mean Zero Drift} * \underline{\hspace{2cm}} + \text{C.I. (Zero)} \underline{\hspace{2cm}}] \\ \div [\text{Instrument Span}] \times 100 = \underline{\hspace{2cm}}.$$

Calibration Drift = [Mean Span Drift * _____ + C.I. (Span) _____]
 ÷ [Instrument Span] x 100 = _____.

Absolute Value

Figure B-6.

MONITOR PERFORMANCE TEST DATA SHEET
ZERO AND CALIBRATION DRIFT (2 HOUR)

Engineer _____

Data Set No.	Time		Zero Reading	Zero Drift (Δ Zero)	Span Reading	Span Drift (Δ Span)	Calibration Drift (Span-Zero)
1	Begin	End					
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							

Zero Drift = [Mean Zero Drift* _____ + CI (Zero) _____] \div [Span] \times 100 = _____.
 Calibration Drift = [Mean Span Drift* _____ + CI (Span) _____] \div [Span] \times 100 = _____.

*Absolute Value.

65

KVB11-6017-1224

KVB

Data Sheet 6017-33
 40CFR60/App. B
 7/1/77

Figure B-7.

KVB

MONITOR PERFORMANCE TEST DATA SHEET
ACCURACY DETERMINATION (NO_x)

Engineer _____

Test No.	Date and Time	Reference Method Samples				Analyzer 1-Hour Average (ppm)* NO_x	Difference (ppm) NO_x		
		NO_x Sample 1 (ppm)	NO_x Sample 2 (ppm)	NO_x Sample 3 (ppm)	NO_x Sample Average (ppm)				
1									
2									
3									
4									
5									
6									
7									
8									
9									
Mean reference method test value (NO_x) _____						Mean of the differences _____			
95% Confidence intervals = <u> </u> ppm (NO_x)									
Accuracies = <u> </u> % (NO_x)									
* Explain and report method used to determine integrated averages									

Figure B-8.

KVB

Engineer _____

MONITOR PERFORMANCE TEST DATA SHEET

CALIBRATION ERROR DETERMINATION

Calibration Gas Mixture Data

Mid (50%) _____ ppm High (90%) _____ ppm

Run #	Calibration Gas Concentration, ppm	Measurement System Reading, ppm	Differences ¹ , ppm
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			

Mid High

Mean difference _____

Confidence interval + _____ + _____

Calibration error = $\frac{\text{Mean Difference}^2 + \text{C.I.}}{\text{Average Calibration Gas Concentration}} \times 100$ %

¹ Calibration gas concentration - measurement system reading

² Absolute value

Figure B-9.

KVB

Engineer _____

MONITOR PERFORMANCE TEST DATA SHEET

ANALYSIS OF CALIBRATION GAS MIXTURES

Date: _____

Reference Method Used: _____

Mid-Range Calibration Gas Mixture

Sample 1 _____ ppm

Sample 2 _____ ppm

Sample 3 _____ ppm

Average _____ ppm

High-Range (span) Calibration Gas Mixture

Sample 1 _____ ppm

Sample 2 _____ ppm

Sample 3 _____ ppm

Average _____ ppm

Data Sheet 6017-30

40CFR60/App. B

7/1/77

KVB11-6015-1224

Figure B-10.

PARTICULATE CALCULATION SHEET

Test Crew _____

Test No. _____ Date _____ Location _____
 Box No. _____ Sample Probe Position _____
 Test Description _____

Dry Gas Meter Vol. (ft³)

Final _____
 Initial _____
 Total _____

Impinger Water Vol (ml)

	1	2	3	S. Gel	Total
Final					
Initial					
Δ Vol					

Beaker No.						Filter No.	Blank No.
Date							
Weighed							
Tare	1						
Wt.	2						
	3						
	4						
	5						
	6						
Avg							
Bottle No.							
Content	Impinger (Water)	Probe (Acetone)	Probe (Water)	Cyclone (Acetone)	Flask (Dry)		
Rinse (ml)							
Date Weighed or 250 Bake							
Final	1						
Wt. 250	2						
	3						
	4						
	5						
	6						
Avg							
Residue wt							
Final 250-Tare							
Date Weighed or 650 Bake							
Final	1						
Wt. 650	2						
	3						
	4						
	5						
	6						
Avg							
Residue Wt							
Final 650-Tare							

Comments:

Data Sheet 6002-3

Figure B-11.

K V B. INC.

STACK DATATest No. _____
Engr. _____

Date _____ Location _____ Unit No. _____ Fuel _____
 Load _____ Kt/hr or MBtu/hr Filter No. _____
 Sample Box No. _____ Meter Box No. _____ Probe No. _____ Probe Length _____

Filter Heater Setting _____

Probe Heater Setting _____

Stack Moisture _____ %

Ambient Temperature _____ °F

Nozzle Diameter _____ in.


Atmospheric Pressure _____ in.Hg

Weather _____

Stack Gas Pressure, Ps _____ iwg

Abs. Stack Press., AP=P_s+407= _____ iwga

Stack Gas Sp. Gravity, Gs _____ n.d.

Stack Area, As _____ ft²

Remarks

Final Meter: _____

Initial Meter: _____

Time	Vm Meter Volume Reading (CF)	Vacuum Gage Reading (iwg)	ΔP Pitot Tube Pressure (iwg)	H Orifice Pressure Diff (°F)	Stack Temp. (°F)	Impinger Temperature		Filter Box Temp. (°F)	Meter Temp. (°F)
						Out (°F)	In (°F)		
Total									
Avg.									

+ 460

T _s =		°R
------------------	--	----

HP-67 KEYED CALCULATION SHEET*

Figure B-12.

PARTICULATE EMISSION CALCULATIONS

Test No. _____ Date _____ Location _____ Engr. _____

Unit No. _____ Fuel _____ Sampling Train and Method _____

Pitot Factor, F_s .83 Barometric Pressure, P_{bar} in. Hg
(STO 0)

Tot. Liquid Collected, V_{lc} ml Total Particulate, M_n gm
(STO 1) (STO 2)

Velocity Head, ΔP iwg Stack Temp., T_s °F Stack Area, A_s ft²
(STO 3) (STO 4) (STO 5)

Sample Volume, V_m ft³ Stack Press., P_{sg} iwg Excess O₂, X_{O₂}%
(STO 6) (STO 7) (STO 8)%

Orifice Press. Diff., H iwg, (Flue Gas Density/Air Density) @ T_s , Gs n.d.
(STO 9) (STO A)

Sample Time, θ min Nozzle Dia., D_n in. Meter Temp., T_m °F
(STO B) (STO C) (STO D)

Select Fe	Oil (A)	Gas (B)	Coal (C)	Other:
SC Feet/10 ⁴ Btu	92.2	87.4	98.2	(-)

Press (E) if meter is not temperature compensated.

1. Sample Gas Volume $V_{m_{std}} = 0.0334 V_m (P_{bar} + H/13.6)$ SCF
2. Water Vapor $V_{w_{std}} = 0.0474 V_{lc}$ SCF
3. Moisture Content $B_{wo} = \text{Eq. 2} / (\text{Eq. 1} + \text{Eq. 2})$ N.D.
4. Concentration a. $C = 0.0154 M_n / V_{m_{std}}$ grains/DSCF
b. $C = 2.205 \times 10^{-6} M_n / V_{m_{std}}$ lb/DSCF
c. $C = \text{Eq. 4b} \times 16.018 \times 10^3$ grams/DSCM
5. Abs. Stack Press. $P_s = P_{bar} \times 13.6 + P_{sg}$ in. w abs.
6. Stack Gas Speed $V_s = 174 F_s \sqrt{\Delta P T_s} \sqrt{\frac{407}{P_s} \times \frac{1.00}{G_s}}$ ft/min
7. Stack Gas Flow a. $Q_{sw} = \text{Eq. 6} \times A_s \times \frac{530}{T_s} \times \frac{P_s}{407}$ WSCF/min
Rate @ 70°F
b. $Q_{sd} = \text{Eq. 7a} \times (1. - \text{Eq. 3})$ DSCF/min
8. Material Flow $M_s = \text{Eq. 7b} \times \text{Eq. 4b} \times 60$ lb/hr
9. X_{O₂} factor $X_{O_2} f = 2090 / (20.9 - X_{O_2} \%)$ N.D.
10. Emission a. $E = \text{Eq. 4b} \times F_e \times \text{Eq. 9}$ lb/MMBtu
b. $E = \text{Eq. 4c} \times F_m \times \text{Eq. 9} \times 1000$ ng/joule
11. * Isokinetic $I = \frac{14077 \times T_s (V_{m_{std}} + V_{w_{std}})}{\theta \times V_s \times P_s \times D_n^2}$ *

*If calculating by hand:

- 1) Convert T_s and T_m to °R
- 2) Multiply Eq 1 by $530/T_m$ (°R) if meter not temperature compensated.
- 3) $F_m = 2.684 \times 10^{-5} \times F_e$

ХУВ, Інс.

Figure B-13.

VELOCITY TRAVERSE

* Object: _____ Test Description: _____

Date: _____

Location: _____

Unit: _____

Test: _____ **Personnel:** _____

Fuel: _____

Barometric Press. (in. Hg): _____

Absolute Static Press. in Stack (in. Hg): _____ (P_g)

Pitot Tube Coefficient: _____ (C_p)

$$V_s = 85.48 C_p \left[\frac{T}{P} \frac{\Delta P}{S^M S} \right]^{1/2}$$

Stack Cross Section




Figure B-14.

KVB

Test No. _____ Date _____ Location _____ Unit No. _____

Fuel _____ Fuel Sample No. _____ Fuel Sample Point _____

LIQUID OR SOLID FUEL CALCULATIONS

(S) (CL REG), (F) (P/S), (F) (CL REG). Load data card, then PGRM card (both sides)

*Input MMW (Btu/lb)	_____	(A)
*Input wt % C	_____	(R/S)
*Input wt % H	_____	(R/S)
*Input wt % S	_____	(R/S)
*Input wt % O	_____	(R/S)
*Input wt % N	_____	(R/S) - decimal point blinks after pressing; item #1 displayed

1. Dry stoichiometric moles flue gas/lb fuel = _____.
(One may proceed to items 9, 17, or 18 by pressing (F)(A), (E), or entering MW and pressing (B), respectively.)

*Input wt % H ₂ O in fuel (0 if none) _____		
(C)	2. Moles H ₂ O in flue gas/lb fuel	_____
(R/S)	3. Total moles of flue gas (stoichiometric)/lb fuel	_____
(R/S)	4. Dry volume/wet volume	_____
(R/S)	5. Volume % H ₂ O in flue gas	_____
(R/S)	6. Volume % CO ₂ , dry in flue gas	_____
(R/S)	7. SO ₂ (ppm by vol.), dry at stoichiometric	_____
(R/S)	8. NO (ppm by vol.), dry at stoichiometric	_____

(f) (A) 9. Stoichiometric air/fuel ratio (lb air/lb fuel) _____	
---	--

(Before items 10-16 may be determined, items 1-9 must be completed.)
(D) - 20.95 displayed

*Input measured vol. % O ₂ for O ₂ correction _____		
(R/S)	10. Gas moles at % O ₂ = 20.95 Gas moles, stoic. = 20.95 - % O ₂ _____	_____
(R/S)	11. Dry moles flue gas/lb fuel at % O ₂	_____
(R/S)	12. Vol. % CO ₂ , dry at % O ₂	_____
(R/S)	13. SO ₂ (ppm by vol.) dry at % O ₂	_____
(R/S)	14. NO (ppm by vol.) dry at % O ₂	_____
(R/S)	15. Vol. % H ₂ O at % O ₂	_____
(R/S)	16. Percent Excess Air (decimal pt. blinks)	_____

(RCL)(2)(E) 17. Converts item 1 to SCF dry flue gas at stoich/10 ⁶ Btu = _____	
---	--

Item 18.

- a. *Input MW, (B), program calculates K (lb/10⁶ Btu = ppm/K)
(MW = 46 for NOx, CO = 28, HC = 16, SOx = 64)
 1. *Input measured ppm at 3% O₂, dry, (R/S), program calculates lb/10⁶ Btu.
 2. (Optional) No input, (R/S), program converts lb/10⁶ Btu = ng/J
 3. Repeat steps (1) and (2) as necessary.
- b. *Enter next value of MW, complete step (a) followed by steps (1), (2), and (3).-- Repeat for all species desired.

	MW	K for lb/10 ⁶ Btu
NOx	46	_____
CO	28	_____
HC	16	_____
SOx	64	_____

*Indicates input is required

Data Sheet 6015-19

Revised 7/6/78

APPENDIX C

CONTINUOUS MONITOR CERTIFICATION DATA SHEETS

KVB11-6015-1224

MONITOR PERFORMANCE TEST DATA SHEET

Engineer _____

ACCURACY DETERMINATION (NO_x)

Test No.	Date and Time	Reference Method Samples				Analyzer 1-Hour Average (ppm)* NO_x	Difference (ppm) NO_x
		NO_x Sample 1 (ppm)	NO_x Sample 2 (ppm)	NO_x Sample 3 (ppm)	NO_x Sample Average (ppm)		
1	7-10-79 830	747	743	740	743	597	- 146
2	930	1002	1010	969	994	767	- 227
3	1030	929	921	1071	974	793	- 181
4	1130	1078	933	804	938	851	- 87
5	1230	916	917	932	922	839	- 83
6	1330	968	949	933	950	857	- 93
7	1430	973	934	1026	978	820	- 158
8	1530	1072	920	1103	1032	881	- 151
9	1630	949	937	952	946	857	- 89
Mean reference method test value (NO_x)						Mean of the differences	- 135
95% Confidence intervals = + 47.19 ppm (NO_x)							
Accuracies = $\frac{\text{Mean of the differences} + 95\% \text{ confidence interval}}{\text{Mean reference method value}} \times 100 = 19.34\% (\text{NO}_x)$							
* Explain and report method used to determine integrated averages							

KVB11-6015-1224

KVB

MONITOR PERFORMANCE TEST DATA SHEET
ACCURACY DETERMINATION (NO_x)

Engineer _____

Test No.	Date and Time	Reference Method Samples				Analyzer 1-Hour Average (ppm)* NO_x	Difference (ppm) NO_x
		NO_x Sample 1 (ppm)	NO_x Sample 2 (ppm)	NO_x Sample 3 (ppm)	NO_x Sample Average (ppm)		
1	6-8-79 9:30	749	772	752	758	681	-77
2	10:30	706	714	721	714	672	-42
3	11:30	NOT TAKEN	543	583	563	540	-23
4	12:30	555	552	538	548	488	-60
5	13:30	556	560	557	558	513	-45
6	14:30	626	619	615	620	557	-63
7	15:30	690	700	686	692	583	-109
8	16:30	694	689	700	694	594	-100
9	17:30	854	831	805	830	694	-136
Mean reference method test value (NO_x)						Mean of the differences	-72.7
664							
95% Confidence intervals = ± 33.91 ppm (NO_x)							
Accuracies = $\frac{\text{Mean of the differences} + 95\% \text{ confidence interval}}{\text{Mean reference method value}} \times 100 = 16.05\% (\text{NO}_x)$							
* Explain and report method used to determine integrated averages							

KVB11-6015-1224

KVB

KVB

MONITOR PERFORMANCE TEST DATA SHEET

RESPONSE TIME

O₂

Date of Test 6-7-79

Span Gas Concentration 9.27% ppm

Analyzer Span Setting 92.7 ppm

1 92.0 seconds

Upscale 2 89.5 seconds

3 85.0 seconds

Average upscale response 88.8 seconds

1 91.0 seconds

Downscale 2 91.2 seconds

3 90.2 seconds

Average downscale response 90.8 seconds.

System average response time (slower time) = 88.8 seconds.

$$\% \text{ deviation from slower} = \frac{\text{average upscale minus average downscale}}{\text{slower time}} \times 100\% = -0.2\%$$

40CFR60/App. B
7/1/77

KVB

MONITOR PERFORMANCE TEST DATA SHEET

RESPONSE TIME

CO₂

Date of Test 6-7-79

Span Gas Concentration 17.8% ppm

Analyzer Span Setting 95.0 ppm

1 77 seconds

Upscale 2 77 seconds

3 76.5 seconds

Average upscale response 76.8 seconds

1 79.4 seconds

Downscale 2 73.0 seconds

3 76.0 seconds

Average downscale response 76.1 seconds.

System average response time (slower time) = 76.8 seconds.

* deviation from slower = $\left[\frac{\text{average upscale minus average downscale}}{\text{slower time}} \right] \times 100\% = 91\%$.

KVB

MONITOR PERFORMANCE TEST DATA SHEET

RESPONSE TIME

- NO

Date of Test 6-7-79

Span Gas Concentration 234 ppm

Analyzer Span Setting 94.0 ppm

1 80.4 seconds

Upscale 2 78.6 seconds

3 86.4 seconds

Average upscale response 81.8 seconds

1 85.0 seconds

Downscale 2 80.0 seconds

3 83.0 seconds

Average downscale response 82.7 seconds.

System average response time (slower time) = 82.7 seconds.

% deviation from slower = $\left[\frac{\text{average upscale minus average downscale}}{\text{slower time}} \right] \times 100\% = -0.1\%$

KVB

MONITOR PERFORMANCE TEST DATA SHEET

RESPONSE TIME

CO

Date of Test 6-7-79

Span Gas Concentration 900 ppm

Analyzer Span Setting 90.0 ppm.

1 80.5 seconds

Upscale 2 81.6 seconds

3 81.0 seconds

Average upscale response 81.0 seconds

1 87.7 seconds

Downscale 2 87.0 seconds

3 84.0 seconds

Average downscale response 86.2 seconds.

System average response time (slower time) = 81.0 seconds.

% deviation from slower time = $\left[\frac{\text{average upscale minus average downscale}}{\text{slower time}} \right] \times 100\% = .06\%$

KVB

Engineer _____

MONITOR PERFORMANCE TEST DATA SHEET

ZERO AND CALIBRATION DRIFT (24-HOUR)

O₂

Date and Time	Zero Reading	Zero Drift (ΔZero)	Span Reading (After Zero Adjustment)	Calibration Drift (ΔSpan)
6-5-79 8:50	DNA	DNA	9.27%	-
6-6-79 8:50			9.20%	- .07
6-7-79 8:50			9.19%	- .01
6-8-79 8:50			9.27%	+ .08
6-9-79 8:50			9.17%	- .1
6-10-79 8:50			9.27%	0
6-11-79 8:50			9.27%	0
6-12-79 8:50			9.27%	0

$$\text{Zero Drift} = [\text{Mean Zero Drift}^* \underline{0} + \text{C.I. (Zero)} \underline{\text{DNA}}] \\ \div [\text{Instrument Span}] \times 100 = \underline{\text{DNA}}.$$

$$\text{Calibration Drift} = [\text{Mean Span Drift}^* \underline{.0371} + \text{C.I. (Span)} \underline{.1261}] \\ \div [\text{Instrument Span}] \times 100 = \underline{1.63}.$$

*Absolute Value

Data Sheet 6017-34
40CFR60/App. B
7/1/77

KVB

Engineer _____

MONITOR PERFORMANCE TEST DATA SHEET

ZERO AND CALIBRATION DRIFT (24-HOUR)

CO₂

Date and Time	Zero Reading	Zero Drift (ΔZero)	Span Reading (After Zero Adjustment)	Calibration Drift (ΔSpan)
6-5-79 8:50	0	-	17.8%	-
6-6-79 8:50	0	-	17.8%	-
6-7-79 8:50	0	-	17.8%	-
6-8-79 8:50	0	-	17.8%	-
6-9-79 8:50	0	-	17.8%	-
6-10-79 8:50	0	-	17.8%	-
6-11-79 8:50	0	-	17.8%	-
6-12-79 8:50	0	-	17.8%	-

$$\text{Zero Drift} = [\text{Mean Zero Drift}^* \underline{\quad 0 \quad} + \text{C.I. (Zero)} \underline{\quad 0 \quad}]$$

$$\div [\text{Instrument Span}] \times 100 = \underline{\quad 0 \quad}.$$

$$\text{Calibration Drift} = [\text{Mean Span Drift}^* \underline{\quad 0 \quad} + \text{C.I. (Span)} \underline{\quad 0 \quad}]$$

$$\div [\text{Instrument Span}] \times 100 = \underline{\quad 0 \quad}.$$

*Absolute Value

Data Sheet 6017-34
40CFR60/App. B
7/1/77

KVB

Engineer _____

MONITOR PERFORMANCE TEST DATA SHEET

ZERO AND CALIBRATION DRIFT (24-HOUR)

No.

Date and Time	Zero Reading	Zero Drift (ΔZero)	Span Reading (After Zero Adjustment)	Calibration Drift (ΔSpan)
6-5-79 8:50	0.0	-	234 PPM	0
6-6-79 8:50	- 6 PPM	- 6	234 PPM	0
6-7-79 8:50	+ 4 PPM	+ 4	234 PPM	0
6-8-79 8:50	- 3 PPM	- 3	234 PPM	0
6-9-79 8:50	0.0	0	234 PPM	0
6-10-79 8:50	0.0	0	234 PPM	0
6-11-79 8:50	+ 1 PPM	+ 1	234 PPM	0
6-12-79 8:50	0	0	234 PPM	0

Zero Drift = [Mean Zero Drift* 2 + C.I. (Zero) 2.20]
 ÷ [Instrument Span] x 100 = 1.79.

Calibration Drift = [Mean Span Drift* 0 + C.I. (Span) 0]
 ÷ [Instrument Span] x 100 = 0.

*Absolute Value

Data Sheet 6017-34
 40CFR60/App. B
 7/1/77

KVB

Engineer

MONITOR PERFORMANCE TEST DATA SHEET

ZERO AND CALIBRATION DRIFT (24-HOUR)

10

$$\text{Zero Drift} = \frac{[\text{Mean Zero Drift} * \underline{\hspace{2cm}} + \text{C.I. (Zero)} \underline{\hspace{2cm}}]}{\div [\text{Instrument Span}] \times 100} = \underline{\hspace{2cm}}.$$

$$\text{Calibration Drift} = [\text{Mean Span Drift} * \underline{\hspace{2cm}} + \text{C.I. (Span)} \underline{\hspace{2cm}}] \\ \div [\text{Instrument Span}] \times 100 = \underline{\hspace{2cm}}.$$

*Absolute Value

**Data Sheet 6017-34
40CFR60/App. B
7/1/77**

MONITOR PERFORMANCE TEST DATA SHEET
ZERO AND CALIBRATION DRIFT (2 HOUR)

OZ.

Data Set No.	Time		Date	Zero Reading	Zero Drift (Δ Zero)	Span Reading	Span Drift (Δ Span)	Calibration Drift (Span-Zero)
	Begin	End						
1 START	8:50		6-5-79	NO ZERO ADJUST	DNA	9.27%	-	-
2	10:50		6-5-79			9.27%	0	0
3	12:50		6-5-79			9.26%	- .01	.01
4	14:50		6-5-79			9.29%	+ .03	.03
5	16:50		6-5-79			9.4%	+ .11	.11
6	18:50		6-5-79			9.4%	0	0
7 START	8:50		6-6-79			9.27%	-	-
8	10:50		6-6-79			9.25%	- .02	.02
9	12:50		6-6-79			9.25%	0	0
10	14:50		6-6-79			9.25%	0	0
11	16:50		6-6-79			9.27%	+ .02	.02
12	18:50		6-6-79			9.27%	0	0
13 START	8:50		6-7-79			9.27%	-	-
14	10:50		6-7-79			9.29%	+ .02	.02
15	12:50		6-7-79			9.29%	0	0
16	14:50		6-7-79			9.29%	0	0
17	16:50		6-7-79			9.5%	+ .21	.21
18	18:50		6-7-79			9.6%	+ .1	.1
19 START	8:50		6-8-79			9.27%	-	-
20				↓	↓			

$$\text{Zero Drift} = [\text{Mean Zero Drift} * \underline{\text{DNA}} + \text{CI (Zero)} \underline{\text{DNA}}] \div [\text{Span}] \times 100 = \underline{\text{DNA}}.$$

$$\text{Calibration Drift} = [\text{Mean Span Drift} * \underline{.03} + \text{CI (Span)} \underline{.03}] \div [\text{Span}] \times 100 = \underline{.65\%}.$$

*Absolute Value.

85

KVB11-6015-1224

MONITOR PERFORMANCE TEST DATA SHEET
ZERO AND CALIBRATION DRIFT (2 HOUR)

CO

86

KBELL-6015-1224

Data Set No.	Time		Date	Zero Reading	Zero Drift (Δ zero)	Span Reading	Span Drift (Δ span)	Calibration Drift (Span-Zero)
	Begin	End						
1	8:50		6-5-79	0.0	0	900	0	-
2	10:50		6-5-79	5 PPM	5	900	0	-5
3	12:50		6-5-79	6 PPM	1	898	-2	-3
4	14:50		6-5-79	10 PPM	4	880	-18	-22
5	16:50		6-5-79	6 PPM	-4	870	-10	-6
6	18:50		6-5-79	0.0	-6	870	0	0
7	8:50		6-6-79	0.0	0	900	-	-
8	10:50		6-6-79	10 PPM	10	900	0	-10
9	12:50		6-6-79	10 PPM	0	900	0	0
10	14:50		6-6-79	10 PPM	0	900	0	0
11	16:50		6-6-79	15 PPM	5	900	0	-5
12	18:50		6-6-79	0.0	-15	900	0	+15
13	8:50		6-7-79	0.0	0	900	0	0
14	10:50		6-7-79	0.0	0	900	0	0
15	12:50		6-7-79	4 PPM	4	900	0	-4
16	14:50		6-7-79	0.0	0	900	0	0
17	16:50		6-7-79	0.0	0	900	0	0
18	18:50		6-7-79	0.0	0	910	10	10
19	8:50		6-8-79	0.0	-	900	-	-
20								

$$\text{Zero Drift} = [\text{Mean Zero Drift} * \underline{3.37} + \text{CI (Zero)} \underline{2.292}] \div [\text{Span}] \times 100 = \underline{.56\%}.$$

$$\text{Calibration Drift} = [\text{Mean Span Drift} * \underline{5.33} + \text{CI (Span)} \underline{3.6}] \div [\text{Span}] \times 100 = \underline{.89\%}.$$

*Absolute Value.

MONITOR PERFORMANCE TEST DATA SHEET
ZERO AND CALIBRATION DRIFT (2 HOUR)

N.O.

Data Set No.	Time		Date	Zero Reading	Zero Drift (Δ Zero)	Span Reading	Span Drift (Δ Span)	Calibration Drift (Span-Zero)
	Begin	End						
1	8:50		6-5-79	0.0	-	94.0 (234)	-	
2	10:50		6-5-79	5 PPM	+5	100 (240)	+6	+1
3	12:50		6-5-79	1	-4	94.0 (234)	-6	-2
4	14:50		6-5-79	5	+4	98.0 (245)	+11	+7
5	16:50		6-5-79	11	+6	100.0 (250)	+5	-1
6	18:50		6-5-79	10	-1	99.0 (248)	-2	-1
7 START	8:50		6-6-79	0	-	94.0 (234)	-	-
8	10:50		6-6-79	8	+8	97.0 (243)	+9	+1
9	12:50		6-6-79	15	+7	99.0 (248)	+5	-2
10	14:50		6-6-79	20	+5	99.0 (248)	0	-5
11	16:50		6-6-79	17	-3	100.0 (250)	+2	+5
12	18:50		6-6-79	12	-5	97.0 (243)	-7	-2
13	8:50		6-7-79	0	-	94.0 (234)	-	-
14	10:50		6-7-79	2.5	2.5	94.0 (234)	0	-2.5
15	12:50		6-7-79	2.5	0	97.0 (243)	+8	8
16	14:50		6-7-79	12	9.5	99.0 (248)	+5	-4.5
17	16:50		6-7-79	10	-2	98.0 (245)	-3	-1
18	18:50		6-7-79	10	0	98.0 (245)	0	0
19 START	8:50		6-8-79	0	-	94.0 (234)	-	-
20	10:50		6-8-79	2	+2	94.0 (234)	0	-2

Zero Drift = [Mean Zero Drift* 3.55 + CI (zero) 1.438] ÷ [Span] x 100 = 1.99%.

Calibration Drift = [Mean Span Drift* 2.50 + CI (Span) 1.19] ÷ [Span] x 100 = 1.4%.

*Absolute Value.

87

KV811-6015-1224

MONITOR PERFORMANCE TEST DATA SHEET
ZERO AND CALIBRATION DRIFT (2 HOUR)

NO.

Data Set No.	Time		Date	Zero Reading	Zero Drift (Δ zero)	Span Reading	Span Drift (Δ span)	Calibration Drift (Span-Zero)
	Begin	End						
21	12:50		6-8-79	2 PPM	0	94.0 (234)	0	0
22	14:50		6-8-79	2	0	94.0 (234)	0	0
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
Zero Drift = [Mean Zero Drift* _____ + CI (Zero) _____] ÷ [Span] × 100 = _____. Calibration Drift = [Mean Span Drift* _____ + CI (Span) _____] ÷ [Span] × 100 = _____.								
*Absolute Value.								

KVBL1-6015-1224

Data Sheet 6017-33
40CFR60/App. B
3/26/79 (Rev. 1)

MONITOR PERFORMANCE TEST DATA SHEET
ZERO AND CALIBRATION DRIFT (2 HOUR)

CO₂

Data Set No.	Time		Date	Zero Reading	Zero Drift (Δ Zero)	Span Reading	Span Drift (Δ Span)	Calibration Drift (Span-Zero)
	Begin	End						
1 START	8:50		6-5-79	0	-	17.8%	-	-
2	10:50		6-5-79	0	-	17.8%	0	0
3	12:50		6-5-79	0	-	17.8%	0	0
4	14:50		6-5-79	0	-	17.6%	-2	.2
5	16:50		6-5-79	0	-	17.6%	0	0
6	18:50		6-5-79	0	-	17.8%	+2	.2
7 START	8:50		6-6-79	0	-	17.8%	0	0
8	10:50		6-6-79	0	-	17.8%	0	0
9	12:50		6-6-79	0	-	17.8%	0	0
10	14:50		6-6-79	0	-	17.8%	0	0
11	16:50		6-6-79	0	-	17.8%	0	0
12	18:50		6-6-79	0	-	17.8%	0	0
13 START	8:50		6-7-79	0	-	17.8%	-	-
14	10:50		6-7-79	0	-	17.8%	0	0
15	12:50		6-7-79	0	-	17.8%	0	0
16	14:50		6-7-79	0	-	17.8%	0	0
17	16:50		6-7-79	0	-	17.8%	0	0
18	18:50		6-7-79	0	-	18.2%	+4	.4
19 START	8:50		6-8-79	0	-	17.8%	-	-
20								

$$\text{Zero Drift} = [\text{Mean Zero Drift} * 0 + \text{CI (Zero)} 0] \div [\text{Span}] \times 100 = 0.$$

$$\text{Calibration Drift} = [\text{Mean Span Drift} * .03 + \text{CI (Span)} .14] \div [\text{Span}] \times 100 = 0.9\%.$$

*Absolute Value.

89

KVBL1-6015-1224

KVB

MONITOR PERFORMANCE TEST DATA SHEET

CALIBRATION ERROR DETERMINATION

O₂

Calibration Gas Mixture Data

Mid (50%) 5.0% ppm

High (90%) 9.27% ppm

Run #	Calibration Gas Concentration, ppm	Measurement System Reading, ppm	Differences, ¹ ppm
1	0	0	0
2	5.0%	5.1%	.1
3	0	0	0
4	9.27%	9.21%	-.06
5	5.0%	5.18%	.18
6	9.27%	9.21%	-.06
7	5.0%	5.18%	.18
8	0	0	0
9	9.27%	9.21%	-.06
10	0	0	0
11	5.0%	5.1%	.1
12	9.27%	9.21%	-.06
13	0	0	0
14	9.27%	9.21%	-.06
15	5.0%	5.18%	.18

Mid High

Mean difference .15 -.06

Confidence interval + .05 + 0

$$\text{Calibration error} = \frac{\text{Mean Difference}^2 + \text{C.I.}}{\text{Average Calibration Gas Concentration}} \times 100 \quad \underline{4.09} \pm \underline{0.65}$$

¹Calibration gas concentration - measurement system reading

²Absolute value

KVB

MONITOR PERFORMANCE TEST DATA SHEET

CALIBRATION ERROR DETERMINATION

CO₂

Calibration Gas Mixture Data

Mid (50%) 10% ppm.

High (90%) 17.8% ppm.

Run #	Calibration Gas Concentration, ppm	Measurement System Reading, ppm	Differences, ¹ ppm
1	0	0	0
2	10%	9.8%	.2
3	0	0	0
4	17.8%	17.8%	0
5	10%	9.9%	.1
6	17.8%	17.8%	0
7	10.0	9.8%	.2
8	0	0	0
9	17.8%	17.8%	0
10	0	0	0
11	10.0%	9.8%	.2
12	17.8%	17.8%	0
13	0	0	0
14	17.8%	17.8%	0
15	10.0%	9.9%	.1

	Mid	High
Mean difference	<u>.16</u>	<u>0</u>
Confidence interval	<u>+ .07</u>	<u>+ 0</u>

$$\text{Calibration error} = \frac{\text{Mean Difference}^2 + \text{C.I.}}{\text{Average Calibration Gas Concentration}} \times 100 \quad \underline{2.3} \pm \underline{0.0}$$

¹Calibration gas concentration - measurement system reading

²Absolute value

KVB

MONITOR PERFORMANCE TEST DATA SHEET

CALIBRATION ERROR DETERMINATION

NO

Calibration Gas Mixture Data

Mid (50%) 120 ppm High (90%) 234 ppm

Run #	Calibration Gas Concentration, ppm	Measurement System Reading, ppm	Differences, ¹ ppm
1	0	0	0
2	120	120	0
3	0	0	0
4	234	234	0
5	120	119.5	.5
6	234	234	0
7	120	118.5	1.5
8	0	0	0
9	234	234	0
10	0	0	0
11	120	119.5	.5
12	234	234	0
13	0	0	0
14	234	234	0
15	120	120	0

	Mid	High
Mean difference	<u>0.50</u>	<u>0</u>
Confidence interval	<u>+0.76</u>	<u>+ 0</u>
Calibration error =	$\frac{\text{Mean Difference}^2 + \text{C.I.}}{\text{Average Calibration Gas Concentration}} \times 100$	<u>1.05</u> \pm <u>0</u>

¹ Calibration gas concentration - measurement system reading

² Absolute value

APPENDIX D

CONTINUOUS MONITOR PERFORMANCE SPECIFICATIONS

KVB11-6015-1224

PERFORMANCE SPECIFICATION 3—PERFORMANCE SPECIFICATIONS AND SPECIFICATION TEST PROCEDURES FOR MONITORS OF SO₂ AND NO_x FROM STATIONARY SOURCES

1. Principle and Applicability.

1.1 Principle. The concentration of sulfur dioxide or oxides of nitrogen pollutants in stack emissions is measured by a continuously operating emission measurement system. Concurrent with operation of the continuous monitoring system, the pollutant concentrations are also measured with reference methods (Appendix A). An average of the continuous monitoring system data is computed for each reference method testing period and compared to determine the relative accuracy of the continuous monitoring system. Other tests of the continuous monitoring system are also performed to determine calibration error, drift, and response characteristics of the system.

1.2 Applicability. This performance specification is applicable to evaluation of continuous monitoring systems for measurement of nitrogen oxides or sulfur dioxide pollutants. These specifications contain test procedures, installation requirements, and data computation procedures for evaluating the acceptability of the continuous monitoring systems.

2. Apparatus.

2.1 Calibration Gas Mixtures. Mixtures of known concentrations of pollutant gas in a diluent gas shall be prepared. The pollutant gas shall be sulfur dioxide or the appropriate oxide(s) of nitrogen specified by paragraph 6 and within subparts. For sulfur dioxide gas mixtures, the diluent gas may be air or nitrogen. For nitric oxide (NO) gas mixtures, the diluent gas shall be oxygen-free (<10 ppm) nitrogen, and for nitrogen dioxide (NO₂) gas mixtures the diluent gas shall be air. Concentrations of approximately 50 percent and 90 percent of span are required. The 90 percent gas mixture is used to set and to check the span and is referred to as the span gas.

2.2 Zero Gas. A gas certified by the manufacturer to contain less than 1 ppm of the pollutant gas or ambient air may be used.

2.3 Equipment for measurement of the pollutant gas concentration using the reference method specified in the applicable standard.

2.4 Data Recorder. Analog chart recorder or other suitable device with input voltage range compatible with analyzer system output. The resolution of the recorder's data output shall be sufficient to allow completion of the test procedures within this specification.

2.5 Continuous monitoring system for SO₂ or NO_x pollutants as applicable.

3. Definitions.

3.1 Continuous Monitoring System. The total equipment required for the determination of a pollutant gas concentration in a source effluent. Continuous monitoring systems consist of major subsystems as follows:

3.1.1 Sampling Interface That portion of an extractive continuous monitoring system that performs one or more of the following

operations: Acquisition, transportation, and conditioning of a sample of the source effluent or that portion of an in-situ continuous monitoring system that protects the analyzer from the effluent.

3.1.2 Analyzer. That portion of the continuous monitoring system which senses the pollutant gas and generates a signal output that is a function of the pollutant concentration.

3.1.3 Data Recorder. That portion of the continuous monitoring system that provides a permanent record of the output signal in terms of concentration units.

3.2 Span. The value of pollutant concentration at which the continuous monitoring system is set to produce the maximum data display output. The span shall be set at the concentration specified in each applicable subpart.

3.3 Accuracy (Relative). The degree of correctness with which the continuous monitoring system yields the value of gas concentration of a sample relative to the value given by a defined reference method. This accuracy is expressed in terms of error, which is the difference between the paired concentration measurements expressed as a percentage of the mean reference value.

3.4 Calibration Error. The difference between the pollutant concentration indicated by the continuous monitoring system and the known concentration of the test gas mixture.

3.5 Zero Drift. The change in the continuous monitoring system output over a stated period of time of normal continuous operation when the pollutant concentration at the time for the measurements is zero.

3.6 Calibration Drift. The change in the continuous monitoring system output over a stated time period of normal continuous operations when the pollutant concentration at the time of the measurements is the same known upscale value.

3.7 Response Time. The time interval from a step change in pollutant concentration at the input to the continuous monitoring system to the time at which 98 percent of the corresponding final value is reached as displayed on the continuous monitoring system data recorder.

3.8 Operational Period. A minimum period of time over which a measurement system is expected to operate within certain performance specifications without unscheduled maintenance, repair, or adjustment.

3.9 Stratification. A condition identified by a difference in excess of 10 percent between the average concentration in the duct or stack and the concentration at any point more than 1.0 meter from the duct or stack wall.

4. Installation Specifications. Pollutant continuous monitoring systems (SO₂ and NO_x) shall be installed at a sampling location where measurements can be made which are directly representative (4.1), or which can be corrected so as to be representative (4.2) of the total emissions from the affected

facility. Conformance with this requirement shall be accomplished as follows:

4.1 Effluent gases may be assumed to be nonstratified if a sampling location eight or more stack diameters (equivalent diameters) downstream of any air in-leakage is selected. This assumption and data correction procedures under paragraph 4.2.1 may not be applied to sampling locations upstream of an air preheater in a steam generating facility under Subpart D of this part. For sampling locations where effluent gases are either demonstrated (4.3) or may be assumed to be nonstratified (eight diameters), a point (extractive systems) or path (in-situ systems) of average concentration may be monitored.

4.2 For sampling locations where effluent gases cannot be assumed to be nonstratified (less than eight diameters) or have been shown under paragraph 4.3 to be stratified, results obtained must be consistently representative (e.g. a point of average concentration may shift with load changes) or the data generated by sampling at a point (extractive systems) or across a path (in-situ systems) must be corrected (4.2.1 and 4.2.2) so as to be representative of the total emissions from the affected facility. Conformance with this requirement may be accomplished in either of the following ways:

4.2.1 Installation of a diluent continuous monitoring system (O_2 or CO , as applicable) in accordance with the procedures under paragraph 4.3 of Performance Specification 3 of this appendix. If the pollutant and diluent monitoring systems are not of the

same type (both extractive or both in-situ), the extractive system must use a multipoint probe.

4.2.2 Installation of extractive pollutant monitoring systems using multipoint sampling probes or in-situ pollutant monitoring systems that sample or view emissions which are consistently representative of the total emissions for the entire cross section. The Administrator may require data to be submitted to demonstrate that the emissions sampled or viewed are consistently representative for several typical facility process operating conditions.

4.3 The owner or operator may perform a traverse to characterize any stratification of effluent gases that might exist in a stack or duct. If no stratification is present, sampling procedures under paragraph 4.1 may be applied even though the eight diameter criteria is not met.

4.4 When single point sampling probes for extractive systems are installed within the stack or duct under paragraphs 4.1 and 4.2.1, the sample may not be extracted at any point less than 1.5 meter from the stack or duct wall. Multipoint sampling probes installed under paragraph 4.2 may be located at any points necessary to obtain consistently representative samples.

5. Continuous Monitoring System Performance Specifications

The continuous monitoring system shall meet the performance specifications in Table 2-1 to be considered acceptable under this method.

TABLE 2-1—Performance specifications

Parameter	Specification
1. Accuracy ¹	≤ 20 pct of the mean value of the reference method test data.
2. Calibration error ¹	≤ 5 pct of each (50 pct, 90 pct) calibration gas mixture value.
3. Zero drift (2 h) ¹	2 pct of span Do.
4. Zero drift (24 h) ¹	Do.
5. Calibration drift (2 h) ¹	2.5 pct of span
6. Calibration drift (24 h) ¹	15 min maximum. 168 h minimum.
7. Response time	
8. Operational period	

¹ Expressed as sum of absolute mean value plus 60 pct confidence interval of a series of tests.

6. Performance Specification Test Procedures. The following test procedures shall be used to determine conformance with the requirements of paragraph 5. For NO_x analyzers that oxidize nitric oxide (NO) to nitrogen dioxide (NO_2), the response time test under paragraph 6.3 of this method shall be performed using nitric oxide (NO) span gas. Other tests for NO_x continuous monitoring systems under paragraphs 6.1 and 6.2 and all tests for sulfur dioxide systems shall be performed using the pollutant span gas specified by each subpart.

6.1 Calibration Error Test Procedure. Set up and calibrate the complete continuous monitoring system according to the manufacturer's written instructions. This may be accomplished either in the laboratory or in the field.

6.1.1 Calibration Gas Analyses. Triplicate analyses of the gas mixtures shall be performed within two weeks prior to use using Reference Methods 8 for SO_2 and 7 for NO_x . Analyze each calibration gas mixture (50%, 90%) and record the results on the example sheet shown in Figure 2-1. Each sample test result must be within 20 percent of the averaged result or the tests shall be repeated. This step may be omitted for non-extractive monitors where dynamic calibration gas mixtures are not used (6.1.2).

6.1.2 Calibration Error Test Procedure. Make a total of 15 nonconsecutive measurements by alternately using zero gas and each calibration gas mixture concentration (e.g. 0%, 50%, 90%, 90%, 50%, 50%, 0%, etc.). For non-extractive continuous monitoring systems this test procedure may be performed by using two or more calibration sys-

cells whose concentrations are certified by the manufacturer to be functionally equivalent to these gas concentrations. Convert the continuous monitoring system output readings to ppm and record the results on the example sheet shown in Figure 2-2.

6.2 Field Test for Accuracy (Relative), Zero Drift, and Calibration Drift. Install and operate the continuous monitoring system in accordance with the manufacturer's written instructions and drawings as follows:

6.2.1 Conditioning Period. Offset the zero setting at least 10 percent of the span so that negative zero drift can be quantified. Operate the system for an initial 168-hour conditioning period in normal operating manner.

6.2.2 Operational Test Period. Operate the continuous monitoring system for an additional 168-hour period retaining the zero offset. The system shall monitor the source effluent at all times except when being zeroed, calibrated, or backpurged.

6.2.2.1 Field Test for Accuracy (Relative). For continuous monitoring systems employing extractive sampling, the probe tip for the continuous monitoring system and the probe tip for the Reference Method sampling train should be placed at adjacent locations in the duct. For NO_x continuous monitoring systems, make 27 NO_x concentration measurements, divided into nine sets, using the applicable reference method. No more than one set of tests, consisting of three individual measurements, shall be performed in any one hour. All individual measurements of each set shall be performed concurrently, or within a three-minute interval and the results averaged. For SO₂ continuous monitoring systems, make nine SO₂ concentration measurements using the applicable reference method. No more than one measurement shall be performed in any one hour. Record the reference method test data and the continuous monitoring system concentrations on the example data sheet shown in Figure 2-3.

6.2.2.2 Field Test for Zero Drift and Calibration Drift. For extractive systems, determine the values given by zero and span gas pollutant concentrations at two-hour intervals until 15 sets of data are obtained. For non-extractive measurement systems the zero value may be determined by mathematically producing a zero-condition that provides a system check of the analyzer internal mirrors and all electronic circuitry, including the radiation source and detector assembly, or by inserting three or more calibration gas cells and computing the zero point from the upscale measurements. If this latter technique is used, a graph(s) must be retained by the owner or operator for each measurement system that shows the relationship between the upscale measurements and the zero point. The span of the system shall be checked by using a calibration gas cell certified by the manufacturer to be functionally equivalent to 60 percent of span concentration. Record the zero and span measure-

ments (or the computed zero drift) on the example data sheet shown in Figure 2-4. The two-hour periods over which measurements are conducted need not be consecutive but may not overlap. All measurements required under this paragraph may be conducted concurrent with tests under paragraph 6.2.2.1.

6.2.2.3 Adjustments. Zero and calibration corrections and adjustments are allowed only at 24-hour intervals or at such shorter intervals as the manufacturer's written instructions specify. Automatic corrections made by the measurement system without operator intervention or initiation are allowable at any time. During the entire 168-hour operational test period, record on the example sheet shown in Figure 2-5 the values given by zero and span gas pollutant concentrations before and after adjustment at 24-hour intervals.

6.3 Field Test for Response Time.

6.3.1 Scope of Test. Use the entire continuous monitoring system as installed, including sample transport lines if used. Flow rates, line diameters, pumping rates, pressures (do not allow the pressurized calibration gas to change the normal operating pressure in the sample line), etc., shall be at the nominal values for normal operation as specified in the manufacturer's written instructions. If the analyzer is used to sample more than one pollutant source (stack), repeat this test for each sampling point.

6.3.2 Response Time Test-Procedure. Introduce zero gas into the continuous monitoring system sampling interface or as close to the sampling interface as possible. When the system output reading has stabilized, switch quickly to a known concentration of pollutant gas. Record the time from concentration switching to 95 percent of final stable response. For non-extractive monitors, the highest available calibration gas concentration shall be switched into and out of the sample path and response times recorded. Perform this test sequence three (3) times. Record the results of each test on the example sheet shown in Figure 2-6.

7. Calculations, Data Analysis and Reporting

7.1 Procedure for determination of mean values and confidence intervals.

7.1.1 The mean value of a data set is calculated according to equation 2-1.

$$\bar{x} = \frac{1}{n} \sum_{i=1}^n x_i \quad \text{Equation 2-1}$$

where:

x_i = absolute value of the measurements,

\bar{x} = sum of the individual values,

\bar{x} = mean value, and

n = number of data points.

7.1.2 The 95 percent confidence interval (two-sided) is calculated according to equation 2-2:

$$C.I. = \frac{t_{\alpha/2}}{n\sqrt{n-1}} \sqrt{n(\sum x_i^2) - (\sum x_i)^2} \quad \text{Equation 2-2}$$

where:

$$\sum x_i = \text{sum of all data points},$$

$$t_{\alpha/2} = t_1 - \alpha/2, \text{ and}$$

C.I._α = 95 percent confidence interval estimate of the average mean value.

Values for 1.975

0.....	1.975
1.....	12.726
2.....	6.833
3.....	5.182
4.....	2.776
5.....	2.571
6.....	2.447
7.....	2.345
8.....	2.303
9.....	2.252
10.....	2.228
11.....	2.201
12.....	2.179
13.....	2.160
14.....	2.145
15.....	2.131

The values in this table are already corrected for n-1 degrees of freedom. Use n equal to the number of samples as data points.

7.2 Data Analysis and Reporting.

7.2.1 Accuracy (Relative). For each of the nine reference method test points, determine the average pollutant concentration reported by the continuous monitoring system. These average concentrations shall be determined from the continuous monitoring system data recorded under 7.2.2 by integrating or averaging the pollutant concentrations over each of the time intervals concurrent with each reference method testing period. Before proceeding to the next step, determine the basis (wet or dry) of the continuous monitoring system data and reference method test data concentrations. If the bases are not consistent, apply a moisture correction to either reference method concentrations or the continuous monitoring system concentrations as appropriate. Determine the correction factor by moisture tests concurrent with the reference method testing periods. Report the moisture test method and the correction procedure employed. For each of the nine test runs determine the difference for each test run by subtracting the respective reference method test concentrations (use average of each set of three measurements for NO_x) from the continuous monitoring system integrated or averaged concentrations. Using these data, compute the mean difference and the 95 percent confidence interval of the differences (equations 2-1 and 2-2). Accuracy is reported as the sum of the absolute value of the mean difference and the 95 percent confidence interval of the differences expressed as a percentage of the mean reference method value. Use the example sheet shown in Figure 2-3.

7.2.2 Calibration Error. Using the data from paragraph 6.1, subtract the measured pollutant concentration determined under paragraph 6.1.1 (Figure 2-1) from the value shown by the continuous monitoring system for each of the five readings at each con-

centration measured under 8.1.2 (Figure 2-2). Calculate the mean of these difference values and the 95 percent confidence intervals according to equations 2-1 and 2-2. Report the calibration error (the sum of the absolute value of the mean difference and the 95 percent confidence interval) as a percentage of each respective calibration gas concentration. Use example sheet shown in Figure 2-2.

7.2.3 Zero Drift (2-hour). Using the zero concentration values measured each two hours during the field test, calculate the differences between consecutive two-hour readings expressed in ppm. Calculate the mean difference and the confidence interval using equations 2-1 and 2-2. Report the zero drift as the sum of the absolute mean value and the confidence interval as a percentage of span. Use example sheet shown in Figure 2-4.

7.2.4 Zero Drift (24-hour). Using the zero concentration values measured every 24 hours during the field test, calculate the differences between the zero point after zero adjustment and the zero value 24 hours later just prior to zero adjustment. Calculate the mean value of these points and the confidence interval using equations 2-1 and 2-2. Report the zero drift (the sum of the absolute mean and confidence interval) as a percentage of span. Use example sheet shown in Figure 2-6.

7.2.5 Calibration Drift (2-hour). Using the calibration values obtained at two-hour intervals during the field test, calculate the differences between consecutive two-hour readings expressed as ppm. These values should be corrected for the corresponding zero drift during that two-hour period. Calculate the mean and confidence interval of these corrected difference values using equations 2-1 and 2-2. Do not use the differences between non-consecutive readings. Report the calibration drift as the sum of the absolute mean and confidence interval as a percentage of span. Use example sheet shown in Figure 2-4.

7.2.6 Calibration Drift (24-hour). Using the calibration values measured every 24 hours during the field test, calculate the differences between the calibration concentration reading after zero and calibration adjustment, and the calibration concentration reading 24 hours later after zero adjustment but before calibration adjustment. Calculate the mean value of these differences and the confidence interval using equations 2-1 and 2-2. Report the calibration drift (the sum of the absolute mean and confidence interval) as a percentage of span. Use the example sheet shown in Figure 2-6.

7.2.7 Response Time. Using the charts from paragraph 6.5, calculate the time interval from concentration switching to 95 percent to the final stable value for all upscale and downscale tests. Report the mean of the three upscale test times and the mean of the three downscale test times. The two average times should not differ by more than 15 percent of the slower time. Report the slower

App. B**Title 40—Protection of Environment**

time as the system response time. Use the example sheet shown in Figure 2-6.

7.2.8 Operational Test Period. During the 168-hour performance and operational test period, the continuous monitoring system shall not require any corrective maintenance, repair, replacement, or adjustment other than that clearly specified as required in the operation and maintenance manuals as routine and expected during a one-week period. If the continuous monitoring system operates within the specified performance parameters and does not require corrective maintenance, repair, replacement or adjustment other than as specified above during the 168-hour test period, the operational period will be successfully concluded. Failure of the continuous monitoring system to meet this requirement shall call for a repetition of the 168-hour test period. Portions of the test which were satisfactorily completed need not be repeated. Failure to meet any performance specifications shall call for a repetition of the one-week performance test period and that portion of the testing which is related to the failed specification. All maintenance and adjustments required shall be recorded. Output readings shall be recorded before, and after all adjustments.

8. References.

8.1 "Monitoring Instrumentation for the Measurement of Sulfur Dioxide in Stationary Source Emissions," Environmental Protection Agency, Research Triangle Park, N.C. February 1973.

8.2 "Instrumentation for the Determination of Nitrogen Oxides Content of Stationary Source Emissions," Environmental Protection Agency, Research Triangle Park, N.C. Volume 1, APTD-0847, October 1971; Volume 2, APTD-0842, January 1972.

8.3 "Experimental Statistics," Department of Commerce, Handbook 91, 1963, pp 8-31, paragraphs 8-3-1.4.

8.4 "Performance Specifications for Stationary-Source Monitoring Systems for Gases and Visible Emissions," Environmental Protection Agency, Research Triangle Park, N.C. EPA-650/2-74-013, January 1974.

Note _____	Reference Method Used _____
<u>High Range Calibration Gas Mixture</u>	
Sample 1	ppm
Sample 2	ppm
Sample 3	ppm
Average	ppm
<u>Mid-Range (approx) Calibration Gas Mixture</u>	
Sample 1	ppm
Sample 2	ppm
Sample 3	ppm
Average	ppm

Figure 2-1. Analysis of Calibration Gas Mixtures

Figure 2-2. PERFORMANCE TEST DATA SHEET
 Chapter I—Environmental Protection Agency

App.B

Calibration Gas Mixture Data (From Figure 2-1)			
	Mid (50%)	High (90%)	
Run #	Calibration Gas Concentration, ppm	Measurement System Reading, ppm	Differences, ¹ ppm
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
		Mid High	
Mean difference		—	—
Confidence interval		+ —	+ —
Calibration error =	$\frac{\text{Mean Difference}^2 + \text{C.I.}}{\text{Average Calibration Gas Concentration}} \times 100$	%	%
¹ Calibration gas concentration - measurement system reading			
² Absolute value			

Figure 2-2. Calibration Error Determination

App. B

Title 40—Protection of Environment

Test No.	Date and Time	Reference Method Samples						Analyzer 1-Hour Average (ppm)* SO ₂ NO _x	Difference (ppm) SO ₂ - NO _x								
		SO ₂ Sample 1 (ppm)	NO _x Sample 1 (ppm)	NO _x Sample 2 (ppm)	NO _x Sample 3 (ppm)	NO _x Sample Average (ppm)											
1		-	-	-	-	-	-	-	-								
2		-	-	-	-	-	-	-	-								
3		-	-	-	-	-	-	-	-								
4		-	-	-	-	-	-	-	-								
5		-	-	-	-	-	-	-	-								
6		-	-	-	-	-	-	-	-								
7		-	-	-	-	-	-	-	-								
8		-	-	-	-	-	-	-	-								
9		-	-	-	-	-	-	-	-								
Mean reference method test value (SO ₂)		Mean reference method test value (NO _x)				Mean of the differences											
95% Confidence Intervals = _____ ppm (SO ₂) = _____ ppm (NO _x)																	
Accuracy = _____ Mean of the differences + 95% confidence interval / Mean reference method value x 100 = _____ % (SO ₂) + _____ % (NO _x)																	
* Explain and report method used to determine integrated averages																	

Figure 2-3. Accuracy Determination (SO₂ and NO_x)

Data Set No.	Begin Date	End Date	Time	Zero Reading	Zero Drift (Zero)	Span Reading	Span Drift (Span)	Calibration Drift (Span-Zero)
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15	Zero Drift = (Mean Zero Drift) + CI (Zero) + (Span) x 100 = _____ % Calibration Drift = (Mean Span Drift) + CI (Span) + (Span) x 100 = _____ % Absolute Value.							

Figure 2-4. Zero and Calibration Drift (2 hour)

Chapter I—Environmental Protection Agency

App. B

Date of Test _____	
Span Gas Concentration _____ ppm	
Analyzer Span Setting _____ ppm	
Upscale	1 _____ seconds
	2 _____ seconds
	3 _____ seconds
	Average upscale response _____ seconds
Downscale	1 _____ seconds
	2 _____ seconds
	3 _____ seconds
	Average downscale response _____ seconds
System average response time (slower time) = _____ seconds.	
Deviation from slower = $\left[\frac{\text{average upscale minus average downscale}}{\text{slower time}} \right] \times 100\% = \underline{\hspace{2cm}}$	

CO₂ & O₂

Figure 2-6. Response Time

Performance Specification 3—Performance specifications and specification test procedures for monitors of CO₂ and O₂ from stationary sources.

1. Principle and Applicability.

1.1 Principle. Effluent gases are continuously sampled and are analyzed for carbon dioxide or oxygen by a continuous monitoring system. Tests of the system are performed during a minimum operating period to determine zero drift, calibration drift, and response time characteristics.

1.2 Applicability. This performance specification is applicable to evaluation of continuous monitoring systems for measurement of carbon dioxide or oxygen. These specifications contain test procedures, installation requirements, and data computation procedures for evaluating the acceptability of the continuous monitoring systems subject to approval by the Administrator. Sampling may include either extractive or non-extractive (in-situ) procedures.

2. Apparatus.

2.1 Continuous Monitoring System for Carbon Dioxide or Oxygen.

2.2 Calibration Gas Mixtures. Mixture of known concentrations of carbon dioxide or oxygen in nitrogen or air. Midrange and 90 percent of span carbon dioxide or oxygen concentrations are required. The 90 percent of span gas mixture is to be used to set and check the analyzer span and is referred to

as span gas. For oxygen analyzers, if the span is higher than 31 percent O₂, ambient air may be used in place of the 90 percent of span calibration gas mixture. Triplicate analyses of the gas mixture (except ambient air) shall be performed within two weeks prior to use using Reference Method 3 of this part.

2.3 Zero Gas. A gas containing less than 100 ppm of carbon dioxide or oxygen.

2.4 Data Recorder. Analog chart recorder or other suitable device with input voltage range compatible with analyzer system output. The resolution of the recorder's data output shall be sufficient to allow completion of the test procedures within this specification.

3. Definitions.

3.1 Continuous Monitoring System. The total equipment required for the determination of carbon dioxide or oxygen in a given source effluent. The system consists of three major subsystems:

3.1.1 Sampling Interface. That portion of the continuous monitoring system that performs one or more of the following operations: Delimitation, acquisition, transportation, and conditioning of a sample of the source effluent or protection of the analyzer from the hostile aspects of the sample or source environment.

3.1.2 Analyzer. That portion of the continuous monitoring system which senses the pollutant gas and generates a signal output that is a function of the pollutant concentration.

3.1.3 Data Recorder. That portion of the continuous monitoring system that provides a permanent record of the output signal in terms of concentration units.

3.2 Span. The value of oxygen or carbon dioxide concentration at which the continuous monitoring system is set that produces the maximum data display output. For the purposes of this method, the span shall be set no less than 1.5 to 2.5 times the normal carbon dioxide or normal oxygen concentration in the stack gas of the affected facility.

3.3 Midrange. The value of oxygen or carbon dioxide concentration that is representative of the normal conditions in the stack gas of the affected facility at typical operating rates.

3.4 Zero Drift. The change in the continuous monitoring system output over a stated period of time of normal continuous operation when the carbon dioxide or oxygen concentration at the time for the measurements is zero.

3.5 Calibration Drift. The change in the continuous monitoring system output over a stated time period of normal continuous operation when the carbon dioxide or oxygen continuous monitoring system is measuring the concentration of span gas.

3.6 Operational Test Period. A minimum period of time over which the continuous monitoring system is expected to operate within certain performance specifications without unscheduled maintenance, repair, or adjustment.

3.7 Response time. The time interval from a step change in concentration at the input to the continuous monitoring system to the time at which 95 percent of the corresponding final value is displayed on the continuous monitoring system data recorder.

4. Installation Specification.

Oxygen or carbon dioxide continuous monitoring systems shall be installed at a location where measurements are directly representative of the total effluent from the affected facility or representative of the same effluent sampled by a SO₂ or NO_x continuous monitoring system. This requirement shall be complied with by use of applicable requirements in Performance Specification 2 of this appendix as follows:

4.1 Installation of Oxygen or Carbon Dioxide Continuous Monitoring Systems Not Used to Convert Pollutant Data. A sampling location shall be selected in accordance with the procedures under paragraphs 4.2.1 or 4.2.2, or Performance Specification 2 of this appendix.

4.2 Installation of Oxygen or Carbon Dioxide Continuous Monitoring Systems Used

to Convert Pollutant Continuous Monitoring System Data to Units of Applicable Standards. The diluent continuous monitoring system (oxygen or carbon dioxide) shall be installed at a sampling location where measurements that can be made are representative of the effluent gases sampled by the pollutant continuous monitoring system(s). Conformance with this requirement may be accomplished in any of the following ways:

4.2.1 The sampling location for the diluent system shall be near the sampling location for the pollutant continuous monitoring system such that the same approximate point(s) (extractive systems) or path (in-situ systems) in the cross section is sampled or viewed.

4.2.2 The diluent and pollutant continuous monitoring systems may be installed at different locations if the effluent gases at both sampling locations are nonstratified as determined under paragraphs 4.1 or 4.2. Performance Specification 2 of this appendix and there is no in-leakage occurring between the two sampling locations. If the effluent gases are stratified at either location, the procedures under paragraph 4.2.2, Performance Specification 2 of this appendix shall be used for installing continuous monitoring systems at that location.

5. Continuous Monitoring System Performance Specifications.

The continuous monitoring system shall meet the performance specifications in Table 3-1 to be considered acceptable under this method.

6. Performance Specification Test Procedures.

The following test procedures shall be used to determine conformance with the requirements of paragraph 4. Due to the wide variation existing in analyzer designs and principles of operation, these procedures are not applicable to all analyzers. Where this occurs, alternative procedures, subject to the approval of the Administrator, may be employed. Any such alternative procedures must fulfill the same purpose (verify response, drift, and accuracy) as the following procedures, and must clearly demonstrate conformance with specifications in Table 3-1.

6.1 Calibration Check. Establish a calibration curve for the continuous monitoring system using zero, midrange, and span concentration gas mixtures. Verify that the resultant curve of analyzer reading compared with the calibration gas value is consistent with the expected response curve as described by the analyzer manufacturer. If the expected response curve is not produced, additional calibration gas measurements shall be made, or additional steps undertaken to verify the accuracy of the response curve of the analyzer.

6.2 Field Test for Zero Drift and Calibration Drift. Install and operate the continuous monitoring system in accordance

App. B

Title 40—Protection of Environment

with the manufacturer's written instructions and drawings as follows:

TABLE 3-1.—Performance specifications

Parameter	Specification
1. Zero drift (2 h) ¹	≤ 0.4 pct O ₂ or CO ₂
2. Zero drift (24 h) ¹	≤ 0.5 pct O ₂ or CO ₂
3. Calibration drift (2 h) ¹	≤ 0.4 pct O ₂ or CO ₂
4. Calibration drift (24 h) ¹	≤ 0.5 pct O ₂ or CO ₂
5. Operational period.....	168 h minimum
6. Response time.....	10 min.

¹ Expressed as sum of absolute mean value plus 95 percent confidence interval of a series of tests.

6.2.1 Conditioning Period. Offset the zero setting at least 10 percent of span so that negative zero drift may be quantified. Operate the continuous monitoring system for an initial 168-hour conditioning period in a normal operational manner.

6.2.2 Operational Test Period. Operate the continuous monitoring system for an additional 168-hour period maintaining the zero offset. The system shall monitor the source effluent at all times except when being zeroed, calibrated, or backpurged.

6.2.3 Field Test for Zero Drift and Calibration Drift. Determine the values given by zero and midrange gas concentrations at two-hour intervals until 15 sets of data are obtained. For non-extractive continuous monitoring systems, determine the zero value given by a mechanically produced zero condition or by computing the zero value from upscale measurements using calibrated gas cells certified by the manufacturer. The midrange checks shall be performed by using certified calibration gas cells functionally equivalent to less than 50 percent of span. Record these readings on the example sheet shown in Figure 3-1. These two-hour periods need not be consecutive but may not overlap. In-situ CO₂ or O₂ analyzers which cannot be fitted with a calibration gas cell may be calibrated by alternative procedures acceptable to the Administrator. Zero and calibration corrections and adjustments are allowed only at 24-hour intervals or at such shorter intervals as the manufacturer's written instructions specify. Automatic corrections made by the continuous monitoring system without operator intervention or initiation are allowable at any time. During the entire 168-hour test period, record the values given by zero and span gas concentrations before and after adjustment at 24-hour intervals in the example sheet shown in Figure 3-2.

6.3 Field Test for Response Time.

6.3.1 Scope of Test.

This test shall be accomplished using the continuous monitoring system as installed, including sample transport lines if used. Flow rates, line diameters, pumping rates, pressures (do not allow the pressurized calibration gas to change the normal operating pressure in the sample line), etc., shall be

at the nominal values for normal operation as specified in the manufacturer's written instructions. If the analyzer is used to sample more than one source (stack), this test shall be repeated for each sampling point.

6.3.2 Response Time Test Procedure.

Introduce zero gas into the continuous monitoring system sampling interface or as close to the sampling interface as possible. When the system output reading has stabilized, switch quickly to a known concentration of gas at 90 percent of span. Record the time from concentration switching to 95 percent of final stable response. After the system response has stabilized at the upper level, switch quickly to a zero gas. Record the time from concentration switching to 95 percent of final stable response. Alternatively, for nonextractive continuous monitoring systems, the highest available calibration gas concentration shall be switched into and out of the sample path and response times recorded. Perform this test sequence three (3) times. For each test, record the results on the data sheet shown in Figure 3-3.

7. Calculations, Data Analysis, and Reporting.

7.1 Procedure for determination of mean values and confidence intervals.

7.1.1 The mean value of a data set is calculated according to equation 3-1.

$$\bar{x} = \frac{1}{n} \sum_{i=1}^n x_i \quad \text{Equation 3-1}$$

where:

x_i =absolute value of the measurements,
 Σ =sum of the individual values.

\bar{x} =mean value, and

n =number of data points

7.2.1 The 95 percent confidence interval (two-sided) is calculated according to equation 3-2:

$$C.I. = \frac{t_{\alpha/2}}{n\sqrt{n-1}} \sqrt{\Sigma(x_i - \bar{x})^2} \quad \text{Equation 3-2}$$

where:

Σx =sum of all data points.

$t_{\alpha/2}=t_{\alpha/2}$, and

$C.I. = 95$ percent confidence interval estimates of the average mean value.

Values for $t_{\alpha/2}$

2	1.975
3	1.870
4	1.803
5	1.752
6	1.716
7	1.677
8	1.635
9	1.596
10	1.552
11	1.512
12	1.471
13	1.430
14	1.386
15	1.345
16	1.301

The values in this table are already corrected for $n-1$ degrees of freedom. Use n equal to the number of samples as data points.

7.2 Data Analysis and Reporting.

7.2.1 Zero Drift (2-hour). Using the zero concentration values measured each two hours during the field test, calculate the differences between the consecutive two-hour readings expressed in ppm. Calculate the mean difference and the confidence interval using equations 3-1 and 3-2. Record the sum of the absolute mean value and the confidence interval on the data sheet shown in Figure 3-1.

7.2.2 Zero Drift (24-hour). Using the zero concentration values measured every 24 hours during the field test, calculate the differences between the zero point after zero adjustment and the zero value 24 hours later just prior to zero adjustment. Calculate the mean value of these points and the confidence interval using equations 3-1 and 3-2. Record the zero drift (the sum of the absolute mean and confidence interval) on the data sheet shown in Figure 3-2.

7.2.3 Calibration Drift (2-hour). Using the calibration values obtained at two-hour intervals during the field test, calculate the differences between consecutive two-hour readings expressed as ppm. These values should be corrected for the corresponding zero drift during that two-hour period. Calculate the mean and confidence interval of these corrected difference values using equations 3-1 and 3-2. Do not use the differences between non-consecutive readings. Record the sum of the absolute mean and confidence interval upon the data sheet shown in Figure 3-1.

7.2.4 Calibration Drift (24-hour). Using the calibration values measured every 24 hours during the field test, calculate the differences between the calibration concentration reading after zero and calibration adjustment and the calibration concentration reading 24 hours later after zero adjustment but before calibration adjustment. Calculate the mean value of these differences and the confidence interval using equations 3-1 and 3-2. Record the sum of the absolute mean and

confidence interval on the data sheet shown in Figure 3-2.

7.2.5 Operational Test Period. During the 168-hour performance and operational test period, the continuous monitoring system shall not receive any corrective maintenance, repair, replacement, or adjustment other than that clearly specified as required in the manufacturer's written operation and maintenance manuals as routine and expected during a one-week period. If the continuous monitoring system operates within the specified performance parameters and does not require corrective maintenance, repair, replacement or adjustment other than as specified above during the 168-hour test period, the operational period will be successfully concluded. Failure of the continuous monitoring system to meet this requirement shall call for a repetition of the 168 hour test period. Portions of the test which were satisfactorily completed need not be repeated. Failure to meet any performance specifications shall call for a repetition of the one-week performance test period and that portion of the testing which is related to the failed specification. All maintenance and adjustments required shall be recorded. Output readings shall be recorded before and after all adjustments.

7.2.6 Response Time. Using the data developed under paragraph 5.8, calculate the time interval from concentration switching to 95 percent to the final stable value for all upscale and downscale tests. Report the mean of the three upscale test times and the mean of the three downscale test times. The two average times should not differ by more than 15 percent of the slower time. Report the slower time as the system response time. Record the results on Figure 3-3.

8. References.

8.1 "Performance Specifications for Stationary Source Monitoring Systems for Gases and Visible Emissions," Environmental Protection Agency, Research Triangle Park, N.C., EPA-650/2-74-012, January 1974.

8.2 "Experimental Statistics," Department of Commerce, National Bureau of Standards Handbook 91, 1963, pp. 8-81, paragraphs 8-8.1.4.

App. B **Title 40—Protection of Environment**

Data Set No.	Time Begin	Time End	Date	Zero Reading	Zero Drift (±Zero)	Span Reading	Span Drift (±Span)	Calibration Drift (±Span-±Zero)
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
	Zero Drift = [Mean Zero Drift] ^a + CI (Zero) _____ + _____.							
	Calibration Drift = [Mean Span Drift] _____ + CI (Span) _____ + _____.							
	^a Absolute Value.							

Figure 3-1. Zero and Calibration Drifts (2 Hour).

Chapter I—Environmental Protection Agency

App. B

App. C

Title 40—Protection of Environment

Date of Test	_____
Span Gas Concentration	_____ ppm
Analyzer Span Setting	_____ ppm
Upscale	1. _____ seconds 2. _____ seconds 3. _____ seconds
	Average upscale response _____ seconds
Downscale	1. _____ seconds 2. _____ seconds 3. _____ seconds
	Average downscale response _____ seconds
System average response time (slower time) = _____ seconds	
% deviation from slower = $\frac{\text{average upscale minus average downscale}}{\text{slower time}} \times 100\%$	
= _____.	

Figure 3-3. Response

[40 FR 48259, Oct. 6, 1975, 40 FR 59204, 59205, Dec. 22, 1975, as amended at 42 FR 6937, Jan. 31, 1977]

APPENDIX C—DETERMINATION OF EMISSION RATE CHANGE

1. Introduction.

1.1 The following method shall be used to determine whether a physical or operational change to an existing facility resulted in an increase in the emission rate to the atmosphere. The method used is the Student's *t* test, commonly used to make inferences from small samples.

2. Data.

2.1 Each emission test shall consist of a run (usually three) which produces a emission rates. These two sets of emission rates are generated, one before and one after the change, the two sets being of equal size.

2.2 When using manual emission tests, except as provided in § 60.8(b) of this part, the reference methods of Appendix A to this part shall be used in accordance with the procedures specified in the applicable subpart both before and after the change to obtain the data.

2.3 When using continuous monitors, the facility shall be operated as if a manual emission test were being performed. Valid data using the averaging time which would be required if a manual emission test were being conducted shall be used.

3. Procedure.

3.1 Subscripts *a* and *b* denote prechange and post-change respectively.

3.2 Calculate the arithmetic mean emission rate, \bar{E} , for each set of data using Equation 1.

$$\bar{E} = \sum_{i=1}^n E_i = \frac{E_1 + E_2 + \dots + E_n}{n} \quad (1)$$

where:

E_i = Emission rate for the *i*th run.

n = number of runs

3.3 Calculate the sample variance, S^2 , for each set of data using Equation 2.

$$S^2 = \frac{\sum_{i=1}^n (E_i - \bar{E})^2}{n-1} = \frac{\sum_{i=1}^n E_i^2 - (\sum_{i=1}^n E_i)^2/n}{n-1} \quad (2)$$

3.4 Calculate the pooled estimate, S_p , using Equation 3.

$$S_p = \left[\frac{(n_a - 1) S_a^2 + (n_b - 1) S_b^2}{n_a + n_b - 2} \right]^{1/2} \quad (3)$$

3.5 Calculate the test statistic, *t*, using Equation 4.

APPENDIX E

TABULATION OF HOURLY EMISSIONS DATA

KVB11-6015-1224

** 24 HOUR DATA
** DRY STACK GAS CONCENTRATION
**
** DATE TIME LUAD VUL% VUL% CO2 CO NO CO NO C11 NO NG/J NG/J **
** MM/DD/YY HH:MM MFAS MEAS PPMV PPMV PPMV PPMV NG/J NG/J **
**
** 6/ 1/79 55.4 6.6 11.3 28. 529. 35. 662. 12. 389. **
** 6/ 2/79 19.8 8.3 11.0 21. 455. 30. 644. 11. 378. **
** 6/ 3/79 19.4 9.0 .0 16. 392. 24. 588. 9. 345. **
** 6/ 4/79 34.7 8.5 .0 18. 389. 26. 559. 9. 328. **
** 6/ 5/79 19.7 9.5 10.3 20. 309. 32. 485. 11. 285. **
** 6/ 6/79 22.6 8.1 10.4 21. 366. 30. 514. 11. 302. **
** 6/ 7/79 29.4 9.3 10.8 31. 383. 44. 544. 16. 320. **
** 6/ 8/79 30.3 8.1 10.5 28. 410. 40. 572. 14. 336. **
** 6/ 9/79 19.9 8.4 10.1 27. 406. 38. 581. 14. 341. **
** 6/10/79 18.4 8.6 10.0 33. 396. 48. 576. 17. 338. **
** 6/11/79 18.6 8.5 10.3 38. 388. 55. 561. 20. 329. **
** 6/12/79 30.5 8.8 10.4 0. 408. 0. 602. 0. 353. **
** 6/13/79 23.3 9.0 10.6 0. 397. 0. 599. 0. 352. **
** 6/14/79 38.6 8.5 10.5 49. 448. 71. 641. 25. 376. **
** 6/15/79 18.3 9.2 10.2 66. 324. 131. 495. 47. 291. **
** 6/16/79 21.8 9.1 10.2 0. 364. 0. 551. 0. 323. **
** 6/17/79 19.4 8.8 10.3 0. 356. 0. 526. 0. 309. **
** 6/18/79 21.7 8.8 10.3 0. 357. 0. 530. 0. 311. **
** 6/19/79 20.7 8.9 10.0 35. 358. 52. 532. 19. 312. **
** 6/20/79 18.9 9.0 10.0 33. 361. 50. 544. 18. 319. **
** 6/21/79 31.7 8.8 10.7 21. 431. 31. 637. 11. 374. **
** 6/22/79 18.8 8.6 10.5 35. 450. 51. 656. 18. 385. **
** 6/23/79 22.6 8.4 10.6 36. 449. 52. 641. 18. 377. **
** 6/24/79 20.3 8.6 10.2 34. 395. 50. 577. 18. 339. **
** 6/25/79 23.1 9.0 10.2 36. 410. 54. 616. 19. 361. **
** 6/26/79 18.8 8.9 10.3 37. 427. 55. 630. 20. 375. **
** 6/27/79 20.2 8.6 10.3 15. 426. 22. 620. 8. 364. **
** 6/28/79 21.0 8.6 10.5 25. 473. 37. 686. 13. 403. **
** 6/29/79 19.8 8.5 10.4 34. 504. 48. 728. 17. 427. **
** 6/30/79 19.2 8.8 10.2 30. 438. 44. 647. 16. 380. **
** 7/ 1/79 17.6 8.8 9.9 33. 455. 48. 673. 17. 395. **
** 7/ 2/79 18.9 8.5 10.3 33. 436. 47. 624. 17. 360. **
** 7/ 3/79 37.2 8.3 10.6 19. 487. 28. 694. 10. 407. **
** 7/ 4/79 19.8 8.6 10.3 35. 424. 51. 618. 18. 363. **
** 7/ 5/79 20.7 8.5 10.3 15. 416. 21. 599. 7. 352. **
** 7/ 6/79 22.3 8.4 10.3 21. 385. 30. 550. 11. 323. **
** 7/ 7/79 19.1 8.5 10.2 35. 384. 50. 556. 18. 326. **
** 7/ 8/79 17.7 8.7 9.9 47. 351. 69. 514. 25. 302. **
** 7/ 9/79 18.4 8.4 10.3 80. 366. 115. 526. 41. 309. **
** 7/10/79 37.6 9.0 9.9 92. 453. 139. 681. 50. 400. **
** 7/11/79 45.6 7.8 11.2 75. 519. 102. 708. 37. 416. **
** 7/12/79 33.0 8.0 10.6 84. 407. 117. 566. 42. 332. **

KVB11-6015-1224

KVB11-6015-1224

DAILY DATA												
DRY STACK GAS CONCENTRATION												
		DATE	TIME	LOAD	O2 VOL%	CO2 VOL%	CHI PPMV	NO PPMV	CO PPMV	NO PPMV	CO NG/J	NO NG/J
				MWTH	MEAS	MEAS	MEAS	MEAS	3XO2	3XO2		
**	**	6/ 2/79	100	39.8	7.4	11.0	19.	501.	25.	665.	9.	390.
**	**	6/ 2/79	200	17.6	8.5	9.9	18.	428.	27.	618.	9.	363.
**	**	6/ 2/79	300	15.2	9.4	9.9	17.	417.	26.	650.	9.	381.
**	**	6/ 2/79	400	15.2	9.5	.0	15.	418.	23.	656.	8.	385.
**	**	6/ 2/79	500	15.8	9.6	.0	15.	414.	24.	655.	8.	385.
**	**	6/ 2/79	600	15.8	9.6	.0	13.	415.	21.	658.	8.	386.
**	**	6/ 2/79	700	15.8	9.2	.0	13.	416.	19.	636.	7.	373.
**	**	6/ 2/79	800	16.4	8.9	.0	12.	413.	18.	616.	7.	361.
**	**	6/ 2/79	900	16.4	9.1	.0	13.	430.	20.	652.	7.	383.
**	**	6/ 2/79	1000	15.8	9.2	.0	16.	443.	24.	678.	9.	398.
**	**	6/ 2/79	1100	15.8	9.4	.0	15.	454.	24.	707.	8.	415.
**	**	6/ 2/79	1200	20.2	9.5	.0	22.	445.	35.	699.	13.	411.
**	**	6/ 2/79	1300	15.2	9.1	.0	23.	455.	35.	690.	12.	405.
**	**	6/ 2/79	1400	14.4	8.2	.0	24.	461.	35.	649.	12.	381.
**	**	6/ 2/79	1500	14.1	.0	13.3	19.	465.	16.	398.	6.	234.
**	**	6/ 2/79	1600	14.6	8.1	.0	25.	446.	34.	624.	12.	366.
**	**	6/ 2/79	1700	14.1	7.4	.0	27.	453.	36.	600.	13.	352.
**	**	6/ 2/79	1800	14.1	7.4	.0	27.	455.	36.	603.	13.	354.
**	**	6/ 2/79	1900	14.1	7.0	.0	28.	458.	36.	590.	13.	346.
**	**	6/ 2/79	2000	36.9	6.4	.0	28.	510.	35.	630.	13.	370.
**	**	6/ 2/79	2100	55.1	6.1	.0	29.	597.	35.	722.	12.	424.
**	**	6/ 2/79	2200	35.2	6.5	.0	28.	534.	35.	664.	13.	390.
**	**	6/ 2/79	2300	14.1	7.2	.0	29.	453.	38.	592.	14.	347.
**	**	6/ 2/79	2400	14.1	7.4	.0	25.	437.	33.	579.	12.	380.

KVB11-6015-1224

DAILY DATA DRY STACK GAS CONCENTRATION											
		LOAD	O2	CO2	CO	NO	CO	NO	CO	NO	
DATE	TIME	MWTH	VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	PPM/V	NG/J	
6/ 3/79	100	14.1	8.1	.0	19.	417.	26.	584.	9.	343.	
6/ 3/79	200	14.1	8.6	.0	14.	413.	20.	601.	7.	353.	
6/ 3/79	300	14.1	9.3	.0	12.	405.	18.	624.	7.	367.	
6/ 3/79	400	14.1	10.3	.0	10.	404.	17.	682.	6.	401.	
6/ 3/79	500	14.1	10.6	.0	10.	399.	17.	693.	6.	407.	
6/ 3/79	600	14.1	10.6	.0	8.	395.	14.	686.	5.	403.	
6/ 3/79	700	14.1	10.5	.0	6.	396.	10.	681.	4.	400.	
6/ 3/79	800	14.1	10.5	.0	7.	393.	12.	676.	4.	397.	
6/ 3/79	900	14.1	10.7	.0	6.	391.	11.	686.	4.	403.	
6/ 3/79	1000	14.1	10.7	.0	7.	395.	12.	694.	4.	407.	
6/ 3/79	1100	14.7	9.4	.0	13.	412.	21.	670.	7.	393.	
6/ 3/79	1200	18.8	9.1	.0	13.	394.	19.	597.	7.	351.	
6/ 3/79	1300	14.1	8.8	.0	16.	403.	24.	596.	9.	350.	
6/ 3/79	1400	14.1	8.1	.0	19.	400.	26.	560.	9.	329.	
6/ 3/79	1500	14.1	7.7	.0	22.	406.	30.	550.	11.	323.	
6/ 3/79	1600	14.1	7.3	.0	24.	415.	32.	546.	12.	321.	
6/ 3/79	1700	14.1	7.1	.0	26.	428.	33.	555.	12.	326.	
6/ 3/79	1800	14.1	.0	.0	0.	0.	0.	0.	0.	0.	
6/ 3/79	1900	14.1	7.8	.0	26.	379.	35.	518.	13.	304.	
6/ 3/79	2000	14.1	7.7	.0	25.	378.	34.	513.	12.	301.	
6/ 3/79	2100	14.1	7.7	.0	25.	366.	34.	496.	12.	291.	
6/ 3/79	2200	14.1	8.0	.0	24.	354.	33.	492.	12.	289.	
6/ 3/79	2300	14.1	8.3	.0	22.	341.	31.	485.	11.	285.	
6/ 3/79	2400	14.1	8.7	.0	21.	334.	30.	491.	11.	288.	

KVB11-6015-1224

DAILY DATA												
DRY STACK GAS CONCENTRATION												
		DATE	TIME	LOAD	O2 VOL%	CO2 VOL%	CO PPMV	NU MEAS	CO PPMV	NO PPMV	CU NG/J	NO NG/J
		MTH		MEAS	MEAS	MEAS	MEAS	3202	3202			
**	6/ 4/79	100	14.1	8.8	.0	16.	323.	24.	478.	9.	281.	
**	6/ 4/79	200	14.1	9.2	.0	13.	298.	21.	455.	7.	267.	
**	6/ 4/79	300	14.1	9.5	.0	0.	315.	0.	495.	0.	291.	
**	6/ 4/79	400	14.1	9.9	.0	10.	304.	16.	490.	6.	290.	
**	6/ 4/79	500	14.1	10.5	.0	9.	298.	16.	513.	6.	301.	
**	6/ 4/79	600	14.1	11.1	.0	7.	295.	13.	539.	5.	316.	
**	6/ 4/79	700	14.1	11.7	.0	8.	293.	15.	570.	5.	335.	
**	6/ 4/79	800	23.4	11.5	.0	8.	276.	15.	526.	5.	309.	
**	6/ 4/79	900	43.4	10.7	.0	6.	375.	11.	658.	4.	386.	
**	6/ 4/79	1000	50.5	10.6	.0	8.	411.	15.	714.	5.	419.	
**	6/ 4/79	1100	60.9	10.8	.0	9.	455.	16.	807.	6.	474.	
**	6/ 4/79	1200	60.4	10.5	.0	13.	462.	22.	795.	8.	467.	
**	6/ 4/79	1300	60.4	8.9	.0	16.	475.	24.	708.	9.	416.	
**	6/ 4/79	1400	60.4	6.4	.0	18.	484.	22.	598.	8.	351.	
**	6/ 4/79	1500	57.7	5.9	.0	21.	498.	25.	595.	9.	349.	
**	6/ 4/79	1600	51.9	5.4	.0	26.	476.	30.	549.	11.	323.	
**	6/ 4/79	1700	48.6	5.1	.0	27.	483.	31.	547.	11.	321.	
**	6/ 4/79	1800	43.4	4.8	.0	28.	492.	31.	547.	11.	321.	
**	6/ 4/79	1900	38.7	6.8	.0	29.	436.	36.	554.	13.	325.	
**	6/ 4/79	2000	35.7	6.5	.0	27.	409.	34.	558.	12.	328.	
**	6/ 4/79	2100	31.4	6.4	.0	30.	432.	38.	533.	13.	313.	
**	6/ 4/79	2200	28.4	6.6	.0	30.	407.	38.	509.	14.	299.	
**	6/ 4/79	2300	19.0	7.2	.0	27.	303.	35.	396.	13.	233.	
**	6/ 4/79	2400	15.2	8.2	.0	22.	285.	31.	402.	11.	236.	

KVB11-6015-1224

HOURLY DATA DRY STACK GAS CONCENTRATION												
		DATE	TIME	LOAD	O2	CO2	CU	NO	CO	NO	CO	NO
				MWTH	VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	NG/J	NG/J
				MEAS								
**	6/ 5/79	100	14.4	8.8	.0	19.	266.	28.	394.	10.	231.	
**	6/ 5/79	200	14.6	9.6	.0	15.	253.	24.	400.	8.	235.	
**	6/ 5/79	300	15.8	10.5	.0	11.	246.	19.	423.	7.	248.	
**	6/ 5/79	400	15.2	11.2	.0	9.	241.	18.	445.	6.	261.	
**	6/ 5/79	500	14.6	11.7	.0	9.	239.	17.	464.	6.	273.	
**	6/ 5/79	600	14.9	12.2	.0	8.	232.	17.	477.	6.	280.	
**	6/ 5/79	700	16.4	12.1	.0	8.	230.	17.	468.	6.	275.	
**	6/ 5/79	800	16.4	11.9	.0	7.	225.	14.	407.	5.	262.	
**	6/ 5/79	900	16.4	10.8	.0	6.	114.	85.	202.	30.	119.	
**	6/ 5/79	1000	16.4	8.9	10.1	25.	355.	38.	529.	14.	311.	
**	6/ 5/79	1100	19.3	8.9	9.9	0.	377.	1.	562.	0.	330.	
**	6/ 5/79	1200	22.6	8.6	10.5	27.	356.	39.	517.	14.	304.	
**	6/ 5/79	1300	23.0	8.5	10.4	28.	352.	41.	508.	15.	298.	
**	6/ 5/79	1400	20.8	8.2	10.5	31.	348.	44.	491.	16.	288.	
**	6/ 5/79	1500	22.3	8.5	10.2	32.	365.	47.	527.	17.	309.	
**	6/ 5/79	1600	28.1	8.6	10.4	27.	389.	40.	567.	14.	333.	
**	6/ 5/79	1700	28.7	8.7	10.4	22.	396.	32.	581.	11.	341.	
**	6/ 5/79	1800	28.4	8.8	10.2	20.	389.	30.	576.	11.	338.	
**	6/ 5/79	1900	28.1	8.8	10.1	19.	507.	29.	750.	10.	440.	
**	6/ 5/79	2000	24.6	9.0	9.9	22.	0.	34.	0.	12.	0.	
**	6/ 5/79	2100	20.5	8.4	10.4	23.	0.	33.	0.	12.	0.	
**	6/ 5/79	2200	19.0	8.1	10.7	24.	0.	34.	0.	12.	0.	
**	6/ 5/79	2300	15.8	8.6	10.1	23.	0.	33.	0.	12.	0.	
**	6/ 5/79	2400	15.5	8.3	10.4	25.	0.	36.	0.	13.	0.	

KVB11-6015-1224

HOURLY DATA DRY STACK GAS CONCENTRATION											
DATE	TIME	LOAD	O2	CO2	CO	NO	CO	NO	CO	NO	
			VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	NG/J	NG/J	NG/J
MEAS	MEAS	MEAS	MEAS	MEAS	MEAS	3302	3302	3302	3302	3302	
6/ 6/79	100	15.8	8.1	10.6	25.	0.	36.	0.	13.	0.	**
6/ 6/79	200	15.8	8.2	10.5	22.	0.	31.	0.	11.	0.	**
6/ 6/79	300	15.8	8.2	10.5	15.	0.	21.	0.	8.	0.	**
6/ 6/79	400	16.0	8.2	10.5	16.	0.	22.	0.	8.	0.	**
6/ 6/79	500	16.1	8.3	10.3	4.	0.	6.	0.	2.	0.	**
6/ 6/79	600	16.1	8.3	10.3	0.	0.	0.	0.	0.	0.	**
6/ 6/79	700	16.4	8.2	10.5	3.	0.	4.	0.	1.	0.	**
6/ 6/79	800	16.7	8.0	10.6	6.	0.	9.	0.	3.	0.	**
6/ 6/79	900	16.7	7.5	10.1	0.	370.	0.	494.	0.	290.	**
6/ 6/79	1000	16.4	8.1	10.6	33.	348.	47.	486.	17.	205.	**
6/ 6/79	1100	16.1	8.5	10.2	33.	370.	47.	535.	17.	314.	**
6/ 6/79	1200	16.1	8.5	10.2	35.	376.	51.	543.	18.	319.	**
6/ 6/79	1300	16.4	8.4	10.3	37.	374.	53.	536.	19.	315.	**
6/ 6/79	1400	19.9	8.4	10.4	37.	365.	53.	523.	19.	307.	**
6/ 6/79	1500	26.4	8.6	10.2	36.	380.	52.	553.	19.	325.	**
6/ 6/79	1600	39.6	0	0	0.	0.	0.	0.	0.	0.	**
6/ 6/79	1700	47.5	6.7	10.7	3.	378.	4.	476.	2.	280.	**
6/ 6/79	1800	47.5	7.4	10.7	8.	285.	11.	378.	4.	222.	**
6/ 6/79	1900	47.2	7.5	11.0	2.	378.	3.	505.	1.	247.	**
6/ 6/79	2000	36.9	7.8	11.2	29.	415.	39.	568.	14.	333.	**
6/ 6/79	2100	20.5	8.5	10.3	29.	374.	42.	540.	15.	317.	**
6/ 6/79	2200	15.5	8.6	10.2	30.	365.	44.	531.	16.	312.	**
6/ 6/79	2300	15.2	8.7	10.1	29.	358.	43.	525.	15.	308.	**
6/ 6/79	2400	15.2	8.7	10.2	29.	352.	43.	517.	15.	303.	**

KVB11-6015-1224

**HOURLY DATA
DRY STACK GAS CONCENTRATION**

		DATE	TIME	LOAD	O2 VOL%	CO2 VOL%	CO PPMV	NO PPMV	CU PPMV	NO PPMV	CU NG/J	NO NG/J
				MWTH	MEAS	MEAS	MEAS	MEAS	3X02	3X02		
**	6/ 7/79	100	18.2	.8.7	10.1	28.	349.	41.	513.	15.	301.	**
**	6/ 7/79	200	15.2	.8.5	10.3	28.	341.	41.	492.	15.	289.	**
**	6/ 7/79	300	15.2	.8.6	10.2	29.	340.	43.	495.	15.	290.	**
**	6/ 7/79	400	15.5	.8.4	10.4	28.	342.	41.	490.	15.	288.	**
**	6/ 7/79	500	15.2	.8.5	10.3	28.	347.	40.	501.	14.	294.	**
**	6/ 7/79	600	15.2	.8.5	10.4	29.	342.	42.	493.	15.	290.	**
**	6/ 7/79	700	15.5	.8.4	10.4	31.	337.	45.	483.	16.	284.	**
**	6/ 7/79	800	16.1	.8.6	10.3	28.	348.	41.	506.	15.	297.	**
**	6/ 7/79	900	15.8	.8.7	10.2	28.	349.	41.	512.	15.	301.	**
**	6/ 7/79	1000	.0	.0	.0	0.	0.	0.	0.	0.	0.	**
**	6/ 7/79	1100	.0	.0	.0	0.	0.	0.	0.	0.	0.	**
**	6/ 7/79	1200	.0	.0	.0	0.	0.	0.	0.	0.	0.	**
**	6/ 7/79	1300	17.9	.8.8	10.5	29.	369.	43.	546.	15.	321.	**
**	6/ 7/79	1400	20.8	.8.5	10.6	34.	361.	50.	522.	18.	306.	**
**	6/ 7/79	1500	39.6	.7.6	11.3	28.	404.	38.	544.	14.	319.	**
**	6/ 7/79	1600	49.2	.7.4	11.7	32.	354.	42.	469.	15.	276.	**
**	6/ 7/79	1700	49.2	.7.8	11.5	31.	371.	43.	507.	15.	298.	**
**	6/ 7/79	1800	49.2	.7.8	11.5	32.	390.	44.	533.	16.	313.	**
**	6/ 7/79	1900	49.2	.7.7	11.6	33.	409.	45.	555.	16.	326.	**
**	6/ 7/79	2000	48.6	.0	.0	0.	0.	0.	0.	0.	0.	**
**	6/ 7/79	2100	48.3	.8.0	11.3	35.	514.	48.	713.	17.	419.	**
**	6/ 7/79	2200	48.3	.8.2	11.2	34.	509.	48.	718.	17.	421.	**
**	6/ 7/79	2300	36.9	.8.8	10.6	34.	466.	50.	689.	18.	405.	**
**	6/ 7/79	2400	17.9	.8.7	10.7	38.	413.	56.	606.	20.	356.	**

HOURLY DATA DRY STACK GAS CONCENTRATION											
			O2	CO2	CO	NO	CO	NO	CO	NO	
			LOAD	VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	PPMV	NG/J
	DATE	TIME	MWTH	MEAS	NG/J						
**	6/ 8/79	100	17.9	8.6	10.7	38.	413.	55.	601.	20.	353.
**	6/ 8/79	200	17.9	8.7	10.7	38.	411.	55.	604.	20.	354.
**	6/ 8/79	300	17.9	8.6	10.7	39.	409.	56.	596.	20.	350.
**	6/ 8/79	400	18.2	8.6	10.7	40.	410.	59.	597.	21.	350.
**	6/ 8/79	500	17.6	8.6	10.6	41.	413.	60.	601.	22.	353.
**	6/ 8/79	600	17.9	8.7	10.6	42.	411.	61.	603.	22.	354.
**	6/ 8/79	700	19.6	8.4	10.8	43.	412.	61.	590.	22.	347.
**	6/ 8/79	800	29.9	8.9	10.5	40.	412.	60.	615.	21.	361.
**	6/ 8/79	900	45.4	.0	.0	0.	0.	0.	0.	0.	0.
**	6/ 8/79	1000	49.2	.0	10.2	3.	498.	3.	427.	1.	250.
**	6/ 8/79	1100	49.2	7.0	10.3	3.	504.	5.	649.	2.	381.
**	6/ 8/79	1200	49.2	7.0	10.4	3.	412.	4.	531.	2.	312.
**	6/ 8/79	1300	48.6	7.0	10.4	4.	373.	5.	480.	2.	282.
**	6/ 8/79	1400	48.3	6.6	10.5	4.	385.	5.	482.	2.	283.
**	6/ 8/79	1500	48.3	6.7	10.4	4.	412.	5.	519.	2.	305.
**	6/ 8/79	1600	48.3	6.8	10.4	4.	431.	5.	547.	2.	321.
**	6/ 8/79	1700	48.3	7.1	10.3	5.	442.	6.	573.	2.	337.
**	6/ 8/79	1800	29.3	8.6	10.4	44.	223.	64.	325.	23.	191.
**	6/ 8/79	1900	16.1	8.9	9.9	44.	401.	66.	598.	24.	351.
**	6/ 8/79	2000	17.6	8.4	10.6	44.	404.	63.	578.	23.	339.
**	6/ 8/79	2100	18.5	8.7	10.3	42.	423.	62.	621.	22.	365.
**	6/ 8/79	2200	18.5	8.4	10.5	43.	413.	61.	592.	22.	347.
**	6/ 8/79	2300	18.5	8.6	10.3	42.	411.	61.	599.	22.	352.
**	6/ 8/79	2400	18.2	8.6	10.3	43.	410.	62.	596.	22.	350.

KVB11-6015-1224

DAILY DATA DRY STACK GAS CONCENTRATION												
			O2	CO2	CO	NO	CO	NO	CO	NO		
			LOAD	VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	PPMV	NG/J	
	DATE	TIME	MWTH	MEAS								
**	6/ 9/79	100	18.5	8.5	10.4	42.	412.	61.	595.	22.	349.	
**	6/ 9/79	200	18.5	8.4	10.5	41.	402.	59.	576.	21.	338.	
**	6/ 9/79	300	18.5	8.7	10.2	41.	408.	61.	598.	22.	351.	
**	6/ 9/79	400	18.5	8.7	10.2	42.	401.	62.	589.	22.	346.	
**	6/ 9/79	500	18.5	8.6	10.3	41.	398.	60.	579.	22.	340.	
**	6/ 9/79	600	18.5	8.5	10.3	41.	402.	60.	580.	21.	341.	
**	6/ 9/79	700	18.8	8.4	10.4	42.	394.	60.	565.	21.	332.	
**	6/ 9/79	800	18.8	8.4	10.5	42.	397.	60.	568.	21.	333.	
**	6/ 9/79	900	18.8	8.3	10.4	7.	0.	10.	0.	3.	0.	
**	6/ 9/79	1000	21.4	7.4	10.2	4.	412.	5.	546.	2.	321.	
**	6/ 9/79	1100	25.8	7.8	9.8	3.	443.	4.	605.	1.	355.	
**	6/ 9/79	1200	25.8	7.6	9.8	3.	438.	4.	589.	1.	346.	
**	6/ 9/79	1300	24.6	7.5	9.8	3.	439.	4.	586.	2.	344.	
**	6/ 9/79	1400	22.6	7.7	9.8	3.	419.	4.	568.	2.	334.	
**	6/ 9/79	1500	20.2	9.0	9.7	27.	400.	40.	602.	14.	354.	
**	6/ 9/79	1600	19.6	8.5	10.2	30.	397.	43.	573.	15.	337.	
**	6/ 9/79	1700	19.6	8.6	10.0	29.	406.	42.	591.	15.	347.	
**	6/ 9/79	1800	19.9	8.6	10.1	27.	411.	40.	598.	14.	351.	
**	6/ 9/79	1900	20.5	8.5	10.2	27.	409.	39.	591.	14.	347.	
**	6/ 9/79	2000	19.6	8.9	9.8	30.	389.	45.	580.	16.	341.	
**	6/ 9/79	2100	17.3	8.9	9.7	28.	394.	43.	587.	15.	345.	
**	6/ 9/79	2200	17.0	9.1	9.5	28.	380.	42.	576.	15.	338.	
**	6/ 9/79	2300	17.9	8.7	10.0	27.	384.	39.	563.	14.	331.	
**	6/ 9/79	2400	18.2	.0	11.5	0.	395.	0.	338.	0.	199.	

KVB11-6015-1224

DAILY DATA											
DRY STACK GAS CONCENTRATION											
		LOAD	O2	CO2	CO	NO	CO	NO	CO	NO	
DATE	TIME	MTH	VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	PPMV	PPMV	
		MEAS									
6/10/79	100	18.2	8.7	10.2	26.	392.	39.	575.	14.	337.	
6/10/79	200	18.2	8.7	10.2	23.	389.	34.	571.	12.	335.	
6/10/79	300	17.9	8.7	10.2	24.	386.	35.	566.	13.	333.	
6/10/79	400	17.9	8.6	10.3	24.	385.	35.	560.	13.	329.	
6/10/79	500	18.2	8.9	10.0	22.	379.	32.	566.	12.	332.	
6/10/79	600	18.8	8.6	10.3	24.	376.	35.	548.	12.	322.	
6/10/79	700	19.0	8.5	10.5	25.	388.	37.	560.	13.	329.	
6/10/79	800	19.0	8.7	10.3	25.	393.	36.	576.	13.	338.	
6/10/79	900	19.0	7.9	10.1	30.	403.	41.	555.	15.	326.	
6/10/79	1000	19.0	8.0	9.8	28.	404.	39.	561.	14.	329.	
6/10/79	1100	18.8	8.7	10.1	30.	395.	43.	580.	16.	340.	
6/10/79	1200	18.5	8.7	10.1	32.	397.	47.	582.	17.	342.	
6/10/79	1300	18.2	7.9	9.8	28.	408.	39.	562.	14.	330.	
6/10/79	1400	18.2	7.8	9.8	0.	415.	0.	567.	0.	333.	
6/10/79	1500	18.2	8.7	10.0	19.	401.	28.	588.	10.	346.	
6/10/79	1600	18.8	8.7	10.1	41.	407.	60.	597.	21.	351.	
6/10/79	1700	18.5	8.7	10.1	42.	408.	61.	598.	22.	351.	
6/10/79	1800	18.5	8.8	9.9	42.	410.	62.	606.	22.	356.	
6/10/79	1900	20.2	9.0	9.7	45.	387.	68.	582.	24.	342.	
6/10/79	2000	17.9	8.8	9.9	44.	405.	65.	599.	23.	352.	
6/10/79	2100	18.2	8.7	10.1	44.	402.	65.	590.	23.	346.	
6/10/79	2200	17.6	8.8	10.0	44.	396.	65.	586.	23.	344.	
6/10/79	2300	17.6	9.0	9.9	43.	392.	65.	590.	23.	346.	
6/10/79	2400	17.9	9.0	9.8	46.	381.	69.	573.	25.	337.	

KVB11-6015-1224

**HOURLY DATA
DRY STACK GAS CONCENTRATION**

		LOAD	O2	CO2	CU	NO	CO	NO	CO	NO	
		MWTH	VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	NG/J	NG/J	
	DATE	TIME	MEAS	MEAS	MEAS	MEAS	3X02	3X02			
**	6/11/79	100	17.0	8.5	10.4	50.	377.	72.	545.	26.	320.
**	6/11/79	200	17.0	8.7	10.3	50.	384.	73.	563.	26.	330.
**	6/11/79	300	17.6	8.8	10.1	47.	385.	70.	570.	25.	335.
**	6/11/79	400	17.6	8.6	10.3	50.	386.	72.	562.	26.	330.
**	6/11/79	500	17.9	8.5	10.4	50.	389.	72.	562.	26.	330.
**	6/11/79	600	20.2	8.7	10.2	48.	390.	70.	572.	25.	336.
**	6/11/79	700	20.8	8.7	10.4	48.	389.	70.	571.	25.	335.
**	6/11/79	800	20.5	8.7	10.3	49.	385.	72.	565.	26.	332.
**	6/11/79	900	20.8	8.3	10.5	14.	0.	20.	0.	7.	0.
**	6/11/79	1000	20.8	8.5	10.6	11.	388.	16.	560.	6.	329.
**	6/11/79	1100	20.8	8.5	10.6	25.	384.	36.	555.	13.	326.
**	6/11/79	1200	20.8	7.8	9.9	17.	396.	23.	541.	8.	318.
**	6/11/79	1300	20.5	8.2	10.7	0.	389.	0.	546.	0.	322.
**	6/11/79	1400	20.2	8.3	10.6	0.	403.	0.	573.	0.	337.
**	6/11/79	1500	16.4	8.7	10.2	0.	402.	0.	590.	0.	347.
**	6/11/79	1600	16.4	8.4	10.4	0.	392.	0.	561.	0.	330.
**	6/11/79	1700	16.4	8.5	10.3	0.	398.	0.	575.	0.	338.
**	6/11/79	1800	18.8	8.6	10.1	0.	387.	0.	563.	0.	331.
**	6/11/79	1900	17.6	8.6	10.2	0.	391.	0.	569.	0.	334.
**	6/11/79	2000	17.6	8.6	10.3	0.	391.	0.	568.	0.	334.
**	6/11/79	2100	17.6	8.5	10.5	0.	381.	0.	550.	0.	323.
**	6/11/79	2200	17.6	8.6	10.4	0.	379.	0.	552.	0.	324.
**	6/11/79	2300	17.6	8.7	10.4	0.	375.	0.	550.	0.	323.
**	6/11/79	2400	17.3	8.6	10.3	0.	379.	0.	552.	0.	324.

KVB11-6015-1224

HOURLY DATA
DRY STACK GAS CONCENTRATION

** DATE	TIME	LOAD	O2	CO2	CO	NO	CO	NO		
			VOLX	VOLX	PPMV	PPMV	PPMV	PPMV	NG/J	NG/J
** MEAS	MEAS	MEAS	MEAS	MEAS	MEAS	3202	3202			
** 6/12/79	100	22.3	9.0	10.0	0.	384.	0.	577.	0.	339.
** 6/12/79	200	22.3	8.9	10.1	0.	382.	0.	570.	0.	335.
** 6/12/79	300	34.0	8.9	10.1	0.	381.	0.	568.	0.	333.
** 6/12/79	400	47.5	9.0	10.1	0.	378.	0.	569.	0.	334.
** 6/12/79	500	48.3	9.0	10.1	0.	377.	0.	567.	0.	333.
** 6/12/79	600	48.1	9.0	10.2	0.	370.	0.	557.	0.	327.
** 6/12/79	700	47.8	9.0	10.2	0.	380.	0.	572.	0.	336.
** 6/12/79	800	47.8	9.0	10.2	0.	382.	0.	575.	0.	338.
** 6/12/79	900	47.8	8.9	10.2	0.	0.	0.	0.	0.	0.
** 6/12/79	1000	48.1	8.8	10.2	0.	406.	0.	601.	0.	353.
** 6/12/79	1100	47.8	8.8	10.4	0.	402.	0.	595.	0.	350.
** 6/12/79	1200	31.6	8.7	10.4	0.	431.	0.	632.	0.	371.
** 6/12/79	1300	20.2	7.9	9.9	0.	447.	0.	615.	0.	361.
** 6/12/79	1400	18.2	8.7	7.1	0.	258.	0.	378.	0.	222.
** 6/12/79	1500	18.5	0.	10.5	0.	0.	0.	0.	0.	0.
** 6/12/79	1600	18.5	0.	11.1	0.	0.	0.	0.	0.	0.
** 6/12/79	1700	18.5	0.	11.0	0.	0.	0.	0.	0.	0.
** 6/12/79	1800	18.5	0.	11.3	0.	0.	0.	0.	0.	0.
** 6/12/79	1900	18.5	0.	11.2	0.	0.	0.	0.	0.	0.
** 6/12/79	2000	20.2	7.8	11.1	0.	511.	0.	698.	0.	410.
** 6/12/79	2100	21.4	7.8	11.2	0.	507.	0.	693.	0.	407.
** 6/12/79	2200	21.4	8.2	11.2	0.	490.	0.	691.	0.	406.
** 6/12/79	2300	22.3	8.9	11.0	0.	453.	0.	675.	0.	396.
** 6/12/79	2400	22.3	10.0	10.4	0.	412.	0.	676.	0.	397.

KVB11-6015-1224

DAILY DATA												
DRY STACK GAS CONCENTRATION												
		DATE	TIME	LOAD	O2	CO2	CO	NO	CO	NO	CO	
				MTH	VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	NG/J	
					MEAS	MEAS	MEAS	MEAS	3xO2	3xO2		
**	**	6/13/79	100	19.9	9.8	10.4	0.	401.	0.	647.	0.	380.
**	**	6/13/79	200	20.5	9.7	10.4	0.	397.	0.	634.	0.	372.
**	**	6/13/79	300	21.1	9.7	10.4	0.	388.	0.	619.	0.	364.
**	**	6/13/79	400	21.1	9.7	10.4	0.	389.	0.	622.	0.	365.
**	**	6/13/79	500	21.1	9.7	10.4	0.	385.	0.	615.	0.	361.
**	**	6/13/79	600	23.8	9.8	10.3	0.	354.	0.	571.	0.	335.
**	**	6/13/79	700	27.5	9.8	10.5	0.	374.	0.	603.	0.	354.
**	**	6/13/79	800	27.5	9.6	10.6	0.	373.	0.	591.	0.	347.
**	**	6/13/79	900	27.5	8.6	10.3	0.	364.	0.	530.	0.	311.
**	**	6/13/79	1000	27.5	8.9	10.0	0.	0.	0.	0.	0.	0.
**	**	6/13/79	1100	27.5	8.7	10.3	0.	394.	0.	578.	0.	339.
**	**	6/13/79	1200	27.5	8.4	11.0	0.	442.	0.	633.	0.	371.
**	**	6/13/79	1300	27.5	8.5	11.0	0.	436.	0.	629.	0.	369.
**	**	6/13/79	1400	24.6	8.5	10.7	0.	440.	0.	635.	0.	373.
**	**	6/13/79	1500	22.0	8.6	10.8	0.	421.	0.	613.	0.	360.
**	**	6/13/79	1600	22.0	8.6	10.9	0.	429.	0.	624.	0.	366.
**	**	6/13/79	1700	21.7	8.6	10.9	0.	430.	0.	625.	0.	367.
**	**	6/13/79	1800	21.7	8.6	10.8	0.	406.	0.	591.	0.	347.
**	**	6/13/79	1900	21.4	8.9	10.4	0.	305.	0.	455.	0.	267.
**	**	6/13/79	2000	21.4	8.8	10.7	0.	415.	0.	615.	0.	361.
**	**	6/13/79	2100	21.4	8.9	10.6	0.	403.	0.	601.	0.	353.
**	**	6/13/79	2200	21.4	8.9	10.6	0.	399.	0.	596.	0.	350.
**	**	6/13/79	2300	21.1	8.9	10.6	0.	393.	0.	587.	0.	345.
**	**	6/13/79	2400	20.2	8.9	10.5	0.	392.	0.	584.	0.	343.

KVB11-6015-1224

HOURLY DATA											
DRY STACK GAS CONCENTRATION											
**	DATE	TIME	LOAD	O2 MWHM	VOLX MEAS	CO2 VOLX MEAS	CO PPMV MEAS	NO PPMV MEAS	CO PPMV MEAS	NO NG/J	CO NG/J
**	6/15/79	100	16.6	9.4	9.9	75.	277.	117.	431.	42.	253.
**	6/15/79	200	15.8	9.2	10.1	77.	271.	118.	414.	42.	243.
**	6/15/79	300	15.8	9.5	9.8	83.	286.	130.	408.	46.	263.
**	6/15/79	400	15.8	9.5	9.7	87.	289.	136.	454.	49.	267.
**	6/15/79	500	15.8	9.4	9.8	87.	292.	135.	455.	48.	267.
**	6/15/79	600	15.8	9.5	9.7	89.	295.	139.	463.	50.	272.
**	6/15/79	700	16.4	9.3	9.9	90.	288.	139.	485.	50.	261.
**	6/15/79	800	17.3	9.3	9.9	91.	291.	141.	449.	50.	264.
**	6/15/79	900	18.8	9.2	10.1	92.	289.	141.	442.	50.	259.
**	6/15/79	1000	19.0	9.0	9.9	0.	290.	0.	436.	0.	256.
**	6/15/79	1100	19.3	9.2	10.2	0.	337.	0.	515.	0.	303.
**	6/15/79	1200	19.0	9.1	10.4	0.	334.	0.	507.	0.	298.
**	6/15/79	1300	19.0	8.9	10.6	0.	338.	0.	504.	0.	296.
**	6/15/79	1400	19.3	9.0	10.5	0.	345.	0.	520.	0.	305.
**	6/15/79	1500	19.3	9.1	10.3	0.	350.	0.	531.	0.	312.
**	6/15/79	1600	19.0	9.2	10.4	0.	356.	0.	545.	0.	320.
**	6/15/79	1700	18.8	9.2	10.4	0.	358.	0.	548.	0.	321.
**	6/15/79	1800	18.8	9.2	10.3	0.	361.	0.	552.	0.	324.
**	6/15/79	1900	21.4	9.0	10.5	0.	365.	0.	549.	0.	323.
**	6/15/79	2000	20.5	9.1	10.5	0.	360.	0.	546.	0.	321.
**	6/15/79	2100	18.8	9.1	10.4	0.	353.	0.	536.	0.	315.
**	6/15/79	2200	18.8	9.2	10.5	0.	352.	0.	539.	0.	316.
**	6/15/79	2300	18.8	9.2	10.5	0.	352.	0.	538.	0.	316.
**	6/15/79	2400	18.5	9.1	10.4	0.	339.	0.	514.	0.	302.

KVB11-6015-1224

```

*****+
**          HOURLY DATA
**          DRY STACK GAS CONCENTRATION
**
**          O2      CO2     CO      NO      CU      NO      CO      NO
**          VOL%    VOL%    PPMV    PPMV    PPMV    PPMV    NG/J    NG/J
**          MEAS    MEAS    MEAS    MEAS    3X02    3X02
**          DATE    TIME   MTH    LOAD
**          MEAS
*****+
** 6/16/79   100  18.8  9.3  10.3  0.  336.  0.  519.  0.  305.  **
** 6/16/79   200  18.8  9.3  10.3  0.  341.  0.  526.  0.  309.  **
** 6/16/79   300  18.8  9.3  10.2  0.  339.  0.  524.  0.  308.  **
** 6/16/79   400  18.8  9.3  10.1  0.  340.  0.  525.  0.  308.  **
** 6/16/79   500  18.8  9.3  10.1  0.  334.  0.  515.  0.  302.  **
** 6/16/79   600  18.8  9.2  10.1  0.  326.  0.  499.  0.  293.  **
** 6/16/79   700  19.6  9.2  10.1  0.  346.  0.  529.  0.  310.  **
** 6/16/79   800  22.6  9.2  10.2  0.  374.  0.  572.  0.  336.  **
** 6/16/79   900  23.4  9.1  10.2  0.  376.  0.  570.  0.  335.  **
** 6/16/79  1000  23.4  9.1  10.2  0.  379.  0.  574.  0.  337.  **
** 6/16/79  1100  20.5  9.2  10.2  0.  371.  0.  567.  0.  333.  **
** 6/16/79  1200  17.6  9.4  10.0  0.  340.  0.  529.  0.  311.  **
** 6/16/79  1300  17.6  9.3  10.2  0.  345.  0.  532.  0.  313.  **
** 6/16/79  1400  17.6  9.3  10.1  0.  337.  0.  521.  0.  306.  **
** 6/16/79  1500  21.1  8.8  10.2  0.  350.  0.  518.  0.  304.  **
** 6/16/79  1600  29.3  8.8  10.4  0.  404.  0.  598.  0.  351.  **
** 6/16/79  1700  29.3  8.8  10.4  0.  403.  0.  597.  0.  350.  **
** 6/16/79  1800  29.3  8.9  10.3  0.  397.  0.  593.  0.  348.  **
** 6/16/79  1900  26.1  8.9  10.3  0.  392.  0.  585.  0.  344.  **
** 6/16/79  2000  23.4  8.9  10.3  0.  402.  0.  600.  0.  352.  **
** 6/16/79  2100  23.4  8.6  10.5  0.  374.  0.  544.  0.  320.  **
** 6/16/79  2200  23.4  8.7  10.5  0.  392.  0.  575.  0.  338.  **
** 6/16/79  2300  23.4  8.8  10.4  0.  385.  0.  570.  0.  334.  **
** 6/16/79  2400  19.3  8.8  10.3  0.  358.  0.  530.  0.  311.  **
*****+

```

KVB11-6015-1224

HOURLY DATA												
DRY STACK GAS CONCENTRATION												
		DATE	TIME	LOAD	O2 VOLT	CO2 VOL%	CO PPMV	NO PPMV	CO PPMV	NO PPMV	CO NG/J	NO NG/J
		MTH		MEAS	MEAS	MEAS	MEAS	MEAS	MEAS	MEAS		
**	6/17/79	100	18.8	8.9	10.3	0.	346.	0.	516.	0.	303.	**
**	6/17/79	200	18.8	8.9	10.3	0.	334.	0.	498.	0.	293.	**
**	6/17/79	300	18.8	8.9	10.2	0.	330.	0.	492.	0.	289.	**
**	6/17/79	400	18.8	8.9	10.2	0.	335.	0.	500.	0.	294.	**
**	6/17/79	500	18.8	8.9	10.2	0.	336.	0.	501.	0.	294.	**
**	6/17/79	600	18.8	8.9	10.2	0.	335.	0.	500.	0.	294.	**
**	6/17/79	700	18.8	8.9	10.2	0.	338.	0.	504.	0.	296.	**
**	6/17/79	800	19.6	8.9	10.2	0.	346.	0.	516.	0.	303.	**
**	6/17/79	900	19.9	9.0	10.1	0.	366.	0.	551.	0.	323.	**
**	6/17/79	1000	19.9	8.9	10.2	0.	362.	0.	540.	0.	317.	**
**	6/17/79	1100	19.9	8.9	10.2	0.	358.	0.	534.	0.	318.	**
**	6/17/79	1200	19.9	8.9	10.2	0.	364.	0.	543.	0.	319.	**
**	6/17/79	1300	19.9	8.9	10.0	0.	380.	0.	567.	0.	333.	**
**	6/17/79	1400	19.9	8.6	10.3	0.	400.	0.	583.	0.	342.	**
**	6/17/79	1500	19.9	8.6	10.4	0.	381.	0.	554.	0.	325.	**
**	6/17/79	1600	19.9	8.6	10.6	0.	387.	0.	563.	0.	330.	**
**	6/17/79	1700	19.9	8.7	10.4	0.	382.	0.	561.	0.	329.	**
**	6/17/79	1800	22.6	8.5	10.5	0.	361.	0.	521.	0.	306.	**
**	6/17/79	1900	18.8	8.7	10.4	0.	361.	0.	530.	0.	311.	**
**	6/17/79	2000	18.8	8.6	10.4	0.	351.	0.	511.	0.	300.	**
**	6/17/79	2100	18.8	8.6	10.4	0.	351.	0.	511.	0.	300.	**
**	6/17/79	2200	18.8	8.6	10.4	0.	351.	0.	511.	0.	300.	**
**	6/17/79	2300	19.0	8.7	10.4	0.	347.	0.	510.	0.	299.	**
**	6/17/79	2400	19.0	8.7	10.4	0.	348.	0.	511.	0.	300.	**

KVB11-6015-1224

KVB11-6015-1224

KVB11-6015-1224

HOURLY DATA DRY STACK GAS CONCENTRATION												
		DATE	TIME	LOAD	O2	CO2	CO	NO	CO	NO	CO	NO
				MWTH	VOLX	VOLX	PPMV	PPMV	PPMV	PPMV	NG/J	NG/J
				MEAS	MEAS	MEAS	MEAS	MEAS	3%O2	3%O2		
**	6/20/79	100	16.8	8.8	10.0	45.	0.	67.	0.	24.	0.	
**	6/20/79	200	16.8	8.8	10.0	46.	0.	68.	0.	24.	0.	
**	6/20/79	300	16.8	8.8	9.9	46.	0.	68.	0.	24.	0.	
**	6/20/79	400	17.6	9.0	9.7	47.	0.	71.	0.	25.	0.	
**	6/20/79	500	14.4	9.4	9.2	50.	0.	78.	0.	28.	0.	
**	6/20/79	600	17.6	9.1	9.6	49.	0.	75.	0.	27.	0.	
**	6/20/79	700	19.9	8.8	10.0	48.	0.	71.	0.	25.	0.	
**	6/20/79	800	20.8	8.8	10.1	48.	0.	71.	0.	25.	0.	
**	6/20/79	900	25.5	8.7	10.2	46.	0.	67.	0.	24.	0.	
**	6/20/79	1000	20.2	8.7	10.1	45.	0.	67.	0.	24.	0.	
**	6/20/79	1100	19.0	8.8	10.1	45.	0.	66.	0.	24.	0.	
**	6/20/79	1200	18.8	8.8	10.1	48.	0.	65.	0.	23.	0.	
**	6/20/79	1300	16.8	8.8	9.8	25.	378.	37.	559.	13.	328.	
**	6/20/79	1400	16.8	8.8	9.9	16.	386.	24.	571.	8.	335.	
**	6/20/79	1500	16.8	8.9	10.3	11.	374.	16.	559.	6.	328.	
**	6/20/79	1600	16.8	8.9	10.4	13.	367.	19.	547.	7.	321.	
**	6/20/79	1700	18.2	9.2	10.3	0.	367.	0.	561.	0.	329.	
**	6/20/79	1800	17.6	9.0	10.4	7.	350.	11.	526.	4.	309.	
**	6/20/79	1900	17.6	8.8	10.6	21.	336.	32.	498.	11.	292.	
**	6/20/79	2000	17.6	9.4	10.1	23.	358.	36.	557.	13.	327.	
**	6/20/79	2100	17.6	9.5	9.9	27.	357.	42.	561.	15.	329.	
**	6/20/79	2200	20.5	9.7	9.8	31.	364.	49.	582.	17.	341.	
**	6/20/79	2300	21.1	9.7	9.9	30.	371.	48.	593.	17.	348.	
**	6/20/79	2400	17.9	9.3	10.3	33.	325.	51.	501.	18.	294.	

KVB11-6015-1224

```

*****  

**          HOURLY DATA  

**          DRY STACK GAS CONCENTRATION  

**  

**          U2      CO2     CO      NO      CO      NO      CU      NO  

**          LOAD    VOL%   VOL%   PPMV   PPMV   PPMV   NG/J   NG/J  

**          DATE    TIME   MWTH   MEAS   MEAS   MEAS   3XU2  3XO2  

*****  

** 6/21/79   100  17.9  9.4  10.2  32.  332.  49.  517.  18.  304. **  

** 6/21/79   200  18.0  9.4  10.4  30.  329.  47.  513.  17.  301. **  

** 6/21/79   300  18.5  9.4  10.3  27.  328.  43.  510.  15.  299. **  

** 6/21/79   400  18.8  9.5  10.0  25.  333.  40.  524.  14.  307. **  

** 6/21/79   500  19.0  9.6  10.1  24.  338.  38.  536.  14.  314. **  

** 6/21/79   600  18.8  9.7  9.9   22.  336.  35.  537.  13.  315. **  

** 6/21/79   700  18.8  9.6  10.0  22.  332.  35.  525.  12.  309. **  

** 6/21/79   800  21.1  9.4  10.3  21.  355.  33.  553.  12.  325. **  

** 6/21/79   900  24.6  9.7  10.0  1.   371.  2.   593.  1.   348. **  

** 6/21/79  1000  24.9  9.2  10.5  7.   378.  11.  579.  4.   340. **  

** 6/21/79  1100  24.3  9.0  10.5  4.   385.  6.   580.  2.   340. **  

** 6/21/79  1200  22.6  8.5  10.6  8.   357.  11.  515.  4.   302. **  

** 6/21/79  1300  25.5  8.4  10.6  9.   350.  13.  501.  5.   294. **  

** 6/21/79  1400  38.1  7.9  11.2  8.   511.  11.  704.  4.   413. **  

** 6/21/79  1500  45.7  7.8  11.4  1.   552.  1.   754.  0.   443. **  

** 6/21/79  1600  50.1  7.9  11.3  6.   559.  8.   770.  3.   452. **  

** 6/21/79  1700  50.1  8.1  11.3  24.  554.  34.  775.  12.  455. **  

** 6/21/79  1800  48.9  8.1  11.3  35.  550.  49.  769.  18.  451. **  

** 6/21/79  1900  48.1  8.1  11.3  34.  555.  48.  776.  17.  456. **  

** 6/21/79  2000  48.1  8.2  11.2  31.  530.  44.  747.  16.  438. **  

** 6/21/79  2100  48.1  8.2  11.4  32.  531.  45.  748.  16.  439. **  

** 6/21/79  2200  45.1  8.2  11.3  33.  519.  47.  732.  17.  430. **  

** 6/21/79  2300  36.9  8.3  11.2  33.  499.  47.  709.  17.  417. **  

** 6/21/79  2400  27.0  9.0  10.3  33.  470.  50.  706.  18.  415. **
*****
```

KVB11-6015-1224

HOURLY DATA
DRY STACK GAS CONCENTRATION

DATE	TIME	LOAD	O2	CO2	CO	NO	CO	NO	CO	NO
		MWTH	VOLX	VOLX	PPMV	PPMV	PPMV	PPMV	NG/J	NG/J
MEAS	MEAS	MEAS	MEAS	MEAS	3XO2	3XO2	NG/J	NG/J		
6/22/79	100	18.8	8.8	10.7	38.	466.	57.	689.	20.	404.
6/22/79	200	17.9	8.6	10.7	40.	437.	59.	636.	21.	374.
6/22/79	300	17.9	8.6	10.6	41.	440.	59.	641.	21.	376.
6/22/79	400	17.9	8.7	10.5	41.	439.	60.	645.	21.	379.
6/22/79	500	18.2	8.8	10.4	41.	441.	60.	652.	21.	383.
6/22/79	600	17.6	8.8	10.3	41.	442.	60.	654.	21.	384.
6/22/79	700	18.2	8.8	10.4	40.	447.	60.	661.	21.	388.
6/22/79	800	17.9	8.8	10.4	40.	439.	60.	649.	21.	381.
6/22/79	900	18.8	8.8	10.4	38.	443.	57.	655.	20.	385.
6/22/79	1000	18.8	8.8	10.4	38.	438.	56.	648.	20.	380.
6/22/79	1100	18.8	8.8	10.4	37.	436.	55.	645.	20.	379.
6/22/79	1200	18.8	8.8	10.4	36.	434.	53.	642.	19.	377.
6/22/79	1300	18.8	8.5	10.6	0.	453.	0.	655.	0.	384.
6/22/79	1400	18.2	8.6	10.5	0.	459.	0.	668.	0.	392.
6/22/79	1500	18.2	8.6	10.5	0.	468.	0.	681.	0.	400.
6/22/79	1600	18.5	8.6	10.5	11.	465.	16.	677.	6.	397.
6/22/79	1700	18.2	8.5	10.4	26.	473.	37.	683.	13.	401.
6/22/79	1800	17.9	8.5	10.5	6.	480.	9.	694.	3.	407.
6/22/79	1900	17.6	8.5	10.5	30.	477.	43.	689.	15.	404.
6/22/79	2000	20.8	8.5	10.4	26.	439.	38.	633.	14.	372.
6/22/79	2100	22.9	8.5	10.4	34.	435.	50.	628.	18.	369.
6/22/79	2200	22.3	8.2	10.7	38.	440.	53.	620.	19.	364.
6/22/79	2300	19.9	8.4	10.5	39.	445.	56.	638.	20.	374.
6/22/79	2400	19.0	8.5	10.4	48.	453.	70.	655.	25.	384.

KVB11-6015-1224

HOURLY DATA											
DRY STACK GAS CONCENTRATION											
		LOAD	O2 VOL%	CO2 VOL%	CO PPMV	NO PPMV	NO PPMV	CO PPMV	NO NG/J	CO NG/J	NO NG/J
DATE	TIME	NWTH	MEAS	MEAS	MEAS	MEAS	MEAS	MEAS	3202	3202	
** 6/23/79	100	19.0	8.4	10.5	42.	457.	61.	655.	22.	385.	**
** 6/23/79	200	19.9	8.2	10.7	45.	466.	63.	657.	23.	386.	**
** 6/23/79	300	19.9	8.1	10.7	45.	465.	64.	650.	23.	382.	**
** 6/23/79	400	19.9	8.2	10.7	47.	466.	66.	657.	24.	386.	**
** 6/23/79	500	19.3	8.1	10.7	47.	473.	66.	662.	24.	389.	**
** 6/23/79	600	19.3	8.1	10.7	57.	478.	80.	668.	29.	392.	**
** 6/23/79	700	19.9	8.2	10.7	48.	472.	68.	665.	24.	391.	**
** 6/23/79	800	20.5	8.2	10.7	48.	462.	68.	651.	24.	382.	**
** 6/23/79	900	20.5	8.3	10.6	48.	451.	68.	640.	24.	376.	**
** 6/23/79	1000	21.4	8.2	10.7	47.	454.	67.	639.	24.	375.	**
** 6/23/79	1100	25.5	8.2	10.7	47.	458.	66.	645.	24.	379.	**
** 6/23/79	1200	27.8	8.2	10.6	46.	474.	64.	668.	23.	392.	**
** 6/23/79	1300	27.8	8.2	10.7	46.	473.	65.	667.	23.	392.	**
** 6/23/79	1400	27.8	8.4	10.7	0.	477.	0.	682.	0.	401.	**
** 6/23/79	1500	25.5	8.4	10.5	15.	463.	21.	663.	8.	389.	**
** 6/23/79	1600	23.8	8.4	10.5	15.	443.	21.	634.	8.	372.	**
** 6/23/79	1700	23.4	8.4	10.5	15.	440.	21.	630.	8.	370.	**
** 6/23/79	1800	23.4	8.6	10.5	15.	428.	22.	623.	8.	366.	**
** 6/23/79	1900	24.3	8.8	10.5	18.	395.	27.	584.	10.	343.	**
** 6/23/79	2000	24.0	8.6	10.3	20.	415.	29.	604.	10.	355.	**
** 6/23/79	2100	23.7	8.6	10.3	25.	418.	36.	608.	13.	357.	**
** 6/23/79	2200	23.4	8.6	10.4	30.	418.	44.	608.	16.	357.	**
** 6/23/79	2300	23.1	8.6	10.5	30.	417.	44.	607.	16.	356.	**
** 6/23/79	2400	19.9	8.6	10.4	35.	421.	51.	613.	18.	360.	**

KVB11-6015-1224

 **
 ** HOURLY DATA
 ** DRY STACK GAS CONCENTRATION
 **
 **
 ** DATE TIME LUAD O2 CO2 CO NO CO NO CO NO
 ** MTH VOL% VOL% PPMV PPMV PPMV PPMV NG/J NG/J
 ** MEAS MEAS MEAS MEAS 3%O2 3%O2 NG/J

 ** 6/24/79 100 20.2 8.6 10.3 30. 425. 44. 618. 16. 363.
 ** 6/24/79 200 20.2 8.6 10.3 40. 425. 58. 618. 21. 363.
 ** 6/24/79 300 20.5 8.7 10.3 40. 423. 59. 621. 21. 364.
 ** 6/24/79 400 20.8 8.7 10.3 50. 422. 73. 619. 26. 364.
 ** 6/24/79 500 20.8 8.7 10.3 50. 420. 73. 616. 26. 362.
 ** 6/24/79 600 21.1 8.7 10.3 51. 418. 75. 613. 27. 360.
 ** 6/24/79 700 20.2 8.7 10.3 55. 418. 81. 613. 29. 360.
 ** 6/24/79 800 20.2 8.7 10.3 56. 409. 82. 600. 29. 352.
 ** 6/24/79 900 21.1 8.6 10.3 60. 406. 87. 591. 31. 347.
 ** 6/24/79 1000 21.1 8.6 10.3 60. 402. 87. 585. 31. 343.
 ** 6/24/79 1100 20.8 8.6 10.3 60. 400. 87. 582. 31. 342.
 ** 6/24/79 1200 20.5 8.6 10.3 60. 400. 87. 582. 31. 342.
 ** 6/24/79 1300 20.2 8.6 10.3 55. 395. 80. 575. 29. 338.
 ** 6/24/79 1400 20.2 8.5 10.3 10. 380. 14. 549. 5. 322.
 ** 6/24/79 1500 19.9 8.5 10.3 10. 380. 14. 549. 5. 322.
 ** 6/24/79 1600 20.2 8.5 10.3 10. 377. 14. 544. 5. 320.
 ** 6/24/79 1700 19.9 8.5 10.3 10. 378. 14. 546. 5. 320.
 ** 6/24/79 1800 19.9 8.5 10.3 10. 381. 14. 550. 5. 323.
 ** 6/24/79 1900 19.9 8.5 10.3 10. 380. 14. 549. 5. 322.
 ** 6/24/79 2000 21.7 8.5 10.2 10. 350. 14. 505. 5. 297.
 ** 6/24/79 2100 20.5 8.8 10.0 20. 375. 30. 555. 11. 326.
 ** 6/24/79 2200 19.3 8.8 10.0 20. 372. 30. 550. 11. 323.
 ** 6/24/79 2300 19.0 8.9 10.0 20. 380. 30. 567. 11. 333.
 ** 6/24/79 2400 19.3 8.9 10.0 20. 374. 30. 558. 11. 326.

KVB11-6015-1224

HOURLY DATA DRY STACK GAS CONCENTRATION												
		DATE	TIME	LOAD	O2 VOL%	CO2 VOL%	CO PPMV	NO PPMV	CO PPMV	NO PPMV	CO NG/J	NO NG/J
				MWTH	MEAS	MEAS	MEAS	MEAS	3XO2	3XO2		
**	6/25/79	100	19.9	8.9	9.9	30.	375.	45.	559.	16.	328.	**
**	6/25/79	200	20.2	8.9	9.9	35.	375.	52.	559.	19.	328.	**
**	6/25/79	300	20.2	8.9	9.9	38.	378.	57.	564.	20.	331.	**
**	6/25/79	400	19.9	8.9	9.9	42.	377.	63.	562.	22.	330.	**
**	6/25/79	500	19.9	9.0	9.9	48.	377.	72.	567.	26.	333.	**
**	6/25/79	600	19.9	9.0	9.9	50.	377.	75.	567.	27.	333.	**
**	6/25/79	700	20.2	9.0	10.0	55.	376.	83.	566.	30.	332.	**
**	6/25/79	800	20.8	9.0	10.0	60.	374.	90.	563.	32.	330.	**
**	6/25/79	900	20.8	9.0	10.0	60.	374.	90.	563.	32.	330.	**
**	6/25/79	1000	22.0	.0	10.1	60.	378.	51.	324.	18.	190.	**
**	6/25/79	1100	25.5	.0	10.1	60.	378.	51.	324.	18.	190.	**
**	6/25/79	1200	26.7	.0	10.2	30.	420.	26.	360.	9.	211.	**
**	6/25/79	1300	27.5	9.0	10.1	10.	455.	15.	684.	5.	402.	**
**	6/25/79	1400	27.8	9.7	10.7	5.	456.	8.	729.	3.	428.	**
**	6/25/79	1500	27.8	9.1	10.8	6.	450.	9.	682.	3.	401.	**
**	6/25/79	1600	27.8	9.0	10.0	10.	428.	15.	643.	5.	378.	**
**	6/25/79	1700	27.8	8.6	10.7	13.	441.	20.	641.	7.	377.	**
**	6/25/79	1800	25.8	8.7	10.6	20.	447.	30.	656.	11.	385.	**
**	6/25/79	1900	24.6	8.9	10.5	29.	443.	44.	660.	16.	388.	**
**	6/25/79	2000	24.6	9.1	10.3	38.	414.	57.	628.	21.	369.	**
**	6/25/79	2100	23.4	8.9	10.5	38.	435.	56.	649.	20.	381.	**
**	6/25/79	2200	23.4	8.9	10.6	40.	432.	60.	645.	21.	379.	**
**	6/25/79	2300	19.9	9.0	10.5	42.	431.	63.	649.	23.	381.	**
**	6/25/79	2400	18.8	9.2	10.3	41.	445.	63.	681.	22.	400.	**

KVB11-6015-1224

DAILY DATA												
DRY STACK GAS CONCENTRATION												
DATE	TIME	LOAD	O2	CO2	CO	NO	CO	NO	CO	NO	NG/J	NG/J
		MWTH	VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	PPM	PPM	NG/J	NG/J
		MEAS										
6/27/79	100	16.1	8.8	10.2	8.	418.	12.	618.	4.	363.		
6/27/79	200	16.1	8.7	10.2	10.	413.	14.	606.	5.	356.		
6/27/79	300	16.1	8.6	10.3	10.	415.	15.	604.	5.	355.		
6/27/79	400	16.4	8.5	10.3	10.	418.	15.	604.	5.	355.		
6/27/79	500	16.7	8.5	10.2	11.	422.	16.	609.	6.	358.		
6/27/79	600	16.4	8.6	10.2	11.	422.	16.	614.	6.	360.		
6/27/79	700	17.0	8.6	10.2	11.	414.	16.	603.	6.	354.		
6/27/79	800	20.5	8.7	10.1	11.	417.	16.	612.	6.	359.		
6/27/79	900	19.3	—	10.0	20.	410.	17.	351.	6.	206.		
6/27/79	1000	24.6	8.7	10.4	29.	441.	43.	646.	15.	380.		
6/27/79	1100	24.9	8.6	10.5	30.	445.	44.	648.	16.	380.		
6/27/79	1200	25.2	8.5	10.5	30.	448.	43.	647.	15.	380.		
6/27/79	1300	25.2	8.5	10.5	30.	455.	43.	657.	15.	386.		
6/27/79	1400	23.7	8.5	10.5	15.	460.	22.	664.	8.	390.		
6/27/79	1500	19.6	8.5	10.5	22.	453.	32.	654.	11.	384.		
6/27/79	1600	19.6	8.6	10.4	23.	455.	34.	662.	12.	388.		
6/27/79	1700	23.7	8.6	10.3	11.	450.	17.	655.	6.	384.		
6/27/79	1800	25.2	8.6	10.4	19.	448.	28.	652.	10.	383.		
6/27/79	1900	25.2	8.6	10.4	18.	439.	26.	639.	9.	375.		
6/27/79	2000	23.4	8.6	10.4	18.	421.	26.	612.	9.	359.		
6/27/79	2100	19.9	8.7	10.3	8.	390.	11.	572.	4.	336.		
6/27/79	2200	17.0	8.6	10.4	0.	396.	1.	576.	0.	338.		
6/27/79	2300	16.7	8.7	10.4	1.	390.	1.	572.	0.	336.		
6/27/79	2400	16.4	8.8	10.2	0.	379.	0.	561.	0.	329.		

HOURLY DATA DRY STACK GAS CONCENTRATION													
		DATE	TIME	LOAD	O2 VOL%	CO2 VOL%	CO PPMV	NU PPMV	CU PPMV	NO PPMV	CO NG/J	NO NG/J	
				MWTH	MEAS	MEAS	MEAS	MEAS	3%O2	3%O2			
**	**	6/28/79	100	17.6	8.8	10.2	9.	370.	13.	548.	5.	322.	**
**	**	6/28/79	200	17.9	8.7	10.2	0.	367.	0.	539.	0.	316.	**
**	**	6/28/79	300	18.2	8.7	10.2	3.	352.	5.	516.	2.	303.	**
**	**	6/28/79	400	18.2	8.8	10.2	21.	342.	31.	505.	11.	297.	**
**	**	6/28/79	500	18.2	8.8	10.1	19.	336.	28.	498.	10.	292.	**
**	**	6/28/79	600	18.2	8.8	10.1	24.	329.	36.	487.	13.	286.	**
**	**	6/28/79	700	18.5	8.8	10.1	8.	329.	12.	487.	4.	286.	**
**	**	6/28/79	800	19.9	8.8	10.1	25.	320.	38.	473.	13.	278.	**
**	**	6/28/79	900	23.4	8.4	10.7	25.	831.	36.	617.	13.	362.	**
**	**	6/28/79	1000	24.9	8.3	10.8	27.	461.	38.	655.	14.	385.	**
**	**	6/28/79	1100	26.7	8.4	10.7	27.	460.	38.	659.	14.	387.	**
**	**	6/28/79	1200	20.5	8.3	10.8	30.	422.	43.	600.	15.	352.	**
**	**	6/28/79	1300	19.9	8.2	10.9	29.	427.	40.	603.	14.	354.	**
**	**	6/28/79	1400	19.9	8.3	10.8	29.	441.	42.	627.	15.	368.	**
**	**	6/28/79	1500	19.6	8.2	10.7	33.	444.	47.	626.	17.	367.	**
**	**	6/28/79	1600	20.5	8.3	10.8	24.	468.	35.	665.	12.	390.	**
**	**	6/28/79	1700	27.2	8.3	10.8	18.	613.	26.	871.	9.	512.	**
**	**	6/28/79	1800	29.0	8.4	10.8	21.	664.	31.	951.	11.	559.	**
**	**	6/28/79	1900	28.7	8.4	10.8	26.	672.	37.	962.	13.	565.	**
**	**	6/28/79	2000	28.1	8.4	10.8	31.	675.	45.	967.	16.	568.	**
**	**	6/28/79	2100	20.2	8.5	10.7	39.	612.	57.	884.	20.	519.	**
**	**	6/28/79	2200	17.6	8.8	10.3	45.	588.	67.	870.	24.	511.	**
**	**	6/28/79	2300	15.8	9.1	10.0	45.	611.	69.	927.	25.	544.	**
**	**	6/28/79	2400	15.2	9.1	9.9	49.	606.	75.	920.	27.	540.	**

KVB11-6015-1224

HOURLY DATA											
DRY STACK GAS CONCENTRATION											
DATE	TIME	LOAD	O2 .	CO2	CO	NO	CO	NO	CO	NO	
			VUL%	VOL%	PPMV	PPMV	PPMV	PPMV	NG/J	NG/J	NG/J
6/29/79	100	15.2	9.0	10.1	52.	600.	78.	903.	28.	530.	**
6/29/79	200	15.2	9.0	10.0	54.	596.	81.	897.	29.	527.	**
6/29/79	300	15.2	9.0	9.9	56.	590.	84.	887.	30.	521.	**
6/29/79	400	15.2	9.0	9.8	58.	586.	87.	882.	31.	518.	**
6/29/79	500	15.2	8.9	10.0	60.	592.	89.	883.	32.	518.	**
6/29/79	600	15.2	9.0	9.9	61.	587.	92.	883.	33.	519.	**
6/29/79	700	15.5	8.7	10.2	61.	579.	90.	849.	32.	499.	**
6/29/79	800	17.6	8.5	10.5	62.	588.	90.	849.	32.	498.	**
6/29/79	900	19.3	8.4	10.8	6.	647.	0.	640.	0.	376.	**
6/29/79	1000	22.3	8.3	10.8	16.	450.	22.	640.	8.	376.	**
6/29/79	1100	24.6	8.3	10.8	14.	462.	19.	656.	7.	385.	**
6/29/79	1200	26.7	9.0	10.0	11.	460.	17.	692.	6.	406.	**
6/29/79	1300	28.1	8.2	10.8	10.	531.	14.	749.	5.	440.	**
6/29/79	1400	32.5	8.0	11.1	11.	540.	16.	749.	6.	440.	**
6/29/79	1500	25.8	5.7	10.0	12.	480.	14.	565.	5.	332.	**
6/29/79	1600	22.3	8.0	10.7	16.	452.	22.	627.	8.	368.	**
6/29/79	1700	21.4	8.3	10.9	19.	454.	28.	645.	10.	379.	**
6/29/79	1800	21.4	8.3	10.8	24.	654.	34.	646.	12.	379.	**
6/29/79	1900	21.4	8.3	10.8	29.	654.	41.	646.	15.	379.	**
6/29/79	2000	19.9	8.4	10.8	34.	463.	49.	663.	18.	389.	**
6/29/79	2100	19.6	8.4	10.7	11.	426.	16.	609.	6.	358.	**
6/29/79	2200	15.8	8.8	10.3	44.	446.	65.	660.	23.	388.	**
6/29/79	2300	14.1	9.4	9.7	46.	429.	72.	668.	26.	392.	**
6/29/79	2400	14.6	9.1	9.8	10.	430.	15.	653.	5.	383.	**

KVB11-6015-1224

```

*****  

**          HOURLY DATA  

**          DRY STACK GAS CONCENTRATION  

**  

**          DATE    TIME   LOAD  VOLX  CO2    CO     NO      CU      NO      CO      NO  

**          MMTH   MEAS   MEAS  MEAS  PPMV  PPMV  MEAS  3%O2  3%O2  NG/J   NG/J  

*****  

** 6/30/79   100   14.1   9.3   9.4   53.   421.   81.   650.   29.   382.   **  

** 6/30/79   200   14.1   9.3   9.6   55.   414.   85.   639.   31.   375.   **  

** 6/30/79   300   14.1   9.3   9.5   58.   412.   89.   636.   32.   373.   **  

** 6/30/79   400   14.1   9.3   9.5   59.   409.   91.   631.   32.   371.   **  

** 6/30/79   500   14.1   9.3   9.5   61.   408.   94.   630.   34.   370.   **  

** 6/30/79   600   14.1   9.3   9.5   63.   410.   97.   633.   35.   372.   **  

** 6/30/79   700   14.1   9.3   9.5   65.   409.   100.   631.   36.   370.   **  

** 6/30/79   800   14.1   9.2   9.6   66.   411.   102.   628.   36.   369.   **  

** 6/30/79   900   17.6   8.6   10.3   70.   438.   102.   638.   36.   375.   **  

** 6/30/79  1000   19.0   8.5   10.4   68.   454.   98.   655.   35.   385.   **  

** 6/30/79  1100   19.9   8.4   10.7   10.   458.   15.   656.   5.   385.   **  

** 6/30/79  1200   22.3   8.3   10.8   6.   459.   8.   653.   3.   383.   **  

** 6/30/79  1300   23.4   8.3   10.8   3.   455.   4.   647.   2.   380.   **  

** 6/30/79  1400   23.4   8.4   10.7   2.   454.   2.   650.   1.   382.   **  

** 6/30/79  1500   23.7   8.4   10.7   3.   455.   4.   651.   1.   382.   **  

** 6/30/79  1600   22.9   8.4   10.7   2.   454.   3.   650.   1.   382.   **  

** 6/30/79  1700   22.6   8.5   10.7   3.   455.   5.   657.   2.   386.   **  

** 6/30/79  1800   25.8   8.5   10.6   3.   469.   5.   677.   2.   397.   **  

** 6/30/79  1900   25.8   8.5   10.6   5.   466.   7.   673.   3.   395.   **  

** 6/30/79  2000   25.8   8.5   10.6   8.   463.   11.   669.   4.   393.   **  

** 6/30/79  2100   24.6   8.5   10.6   10.   458.   15.   661.   5.   388.   **  

** 6/30/79  2200   19.9   8.6   10.5   19.   421.   28.   613.   10.   360.   **  

** 6/30/79  2300   16.7   8.8   10.1   14.   432.   21.   639.   8.   375.   **  

** 6/30/79  2400   15.2   9.1   9.8   10.   430.   15.   653.   5.   383.   **

```

KVB11-6015-1224

HOURLY DATA												
DRY STACK GAS CONCENTRATION												
		DATE	TIME	LOAD	O2 VOL%	CO2 VOL%	CO . PPMV	NO MEAS	CO PPMV	NO 3X02	CO NG/J	NO NG/J
		MWTH	MEAS	MEAS	MEAS	MEAS	MEAS	3X02	PPMV	NG/J	NG/J	
**	**	7/ 1/79	100	14.6	9.2	9.6	22.	426.	34.	651.	12.	382.
**	**	7/ 1/79	200	14.6	9.2	9.6	26.	428.	40.	655.	14.	385.
**	**	7/ 1/79	300	14.6	9.2	9.6	31.	429.	47.	657.	17.	386.
**	**	7/ 1/79	400	14.6	9.2	9.6	35.	424.	53.	649.	19.	381.
**	**	7/ 1/79	500	14.6	9.1	9.6	39.	423.	59.	642.	21.	377.
**	**	7/ 1/79	600	14.6	9.1	9.6	42.	423.	64.	642.	23.	377.
**	**	7/ 1/79	700	14.6	9.1	9.6	45.	425.	68.	645.	24.	379.
**	**	7/ 1/79	800	14.6	9.2	9.7	34.	426.	52.	651.	19.	382.
**	**	7/ 1/79	900	15.2	8.8	10.0	25.	448.	37.	663.	13.	389.
**	**	7/ 1/79	1000	18.2	8.8	10.0	25.	470.	37.	695.	13.	408.
**	**	7/ 1/79	1100	18.8	8.7	10.1	25.	472.	37.	693.	13.	407.
**	**	7/ 1/79	1200	19.3	8.5	10.1	25.	475.	36.	686.	13.	403.
**	**	7/ 1/79	1300	18.8	8.5	10.1	25.	475.	36.	686.	13.	403.
**	**	7/ 1/79	1400	18.8	8.5	10.1	25.	481.	36.	694.	13.	408.
**	**	7/ 1/79	1500	18.8	8.6	10.1	25.	483.	36.	703.	13.	413.
**	**	7/ 1/79	1600	19.0	8.6	10.1	26.	482.	38.	701.	14.	412.
**	**	7/ 1/79	1700	18.8	8.6	10.1	28.	487.	41.	709.	15.	416.
**	**	7/ 1/79	1800	19.9	8.6	10.1	30.	478.	44.	696.	16.	408.
**	**	7/ 1/79	1900	20.2	8.6	10.0	32.	471.	47.	685.	17.	402.
**	**	7/ 1/79	2000	20.5	8.6	10.0	36.	472.	52.	687.	19.	403.
**	**	7/ 1/79	2100	20.5	8.6	10.0	40.	463.	58.	674.	21.	396.
**	**	7/ 1/79	2200	20.8	8.7	10.0	45.	440.	66.	646.	24.	379.
**	**	7/ 1/79	2300	19.3	8.6	10.0	48.	461.	70.	671.	25.	394.
**	**	7/ 1/79	2400	17.6	8.7	10.0	50.	457.	73.	671.	26.	394.

KVB11-6015-1224

```

*****  

**  

      HOURLY DATA  

** DRY STACK GAS CONCENTRATION  

**  

**  

**          O2      CO2      CO      NO      CO      NO      CO      NO  

**          VOL%    VOL%    PPMV    PPMV    PPMV    PPMV    NG/J    NG/J  

**          MEAS    MEAS    MEAS    MEAS    3XO2    3XO2  

**  

** DATE   TIME   LOAD  

** MMTH   MEAS  

*****  

** 7/ 2/79  100  16.7  8.8  10.0  55.  448.  81.  663.  29.  389.  

** 7/ 2/79  200  16.7  8.6  10.0  60.  448.  87.  652.  31.  383.  

** 7/ 2/79  300  17.0  8.7  10.0  65.  455.  95.  668.  34.  392.  

** 7/ 2/79  400  17.0  8.7  10.0  65.  457.  95.  671.  34.  394.  

** 7/ 2/79  500  17.0  8.6  10.0  66.  453.  96.  659.  34.  387.  

** 7/ 2/79  600  17.0  8.7  10.0  67.  448.  98.  657.  35.  386.  

** 7/ 2/79  700  17.0  8.6  10.0  70.  452.  102.  658.  36.  386.  

** 7/ 2/79  800  18.8  8.6  10.0  23.  454.  33.  661.  12.  388.  

** 7/ 2/79  900  20.5  8.4  10.3  20.  452.  29.  647.  10.  380.  

** 7/ 2/79  1000 20.5  8.4  10.2  18.  458.  26.  656.  9.  385.  

** 7/ 2/79  1100 20.5  8.3  10.2  17.  462.  24.  656.  9.  385.  

** 7/ 2/79  1200 20.2  8.3  10.2  20.  450.  28.  639.  10.  375.  

** 7/ 2/79  1300 19.9  8.4  10.2  20.  425.  29.  609.  10.  357.  

** 7/ 2/79  1400 19.9  8.4  10.6  23.  417.  33.  597.  12.  351.  

** 7/ 2/79  1500 19.9  8.4  10.4  23.  410.  33.  587.  12.  344.  

** 7/ 2/79  1600 19.9  8.4  10.7  18.  418.  26.  598.  9.  351.  

** 7/ 2/79  1700 19.9  8.4  10.7  17.  423.  24.  606.  8.  356.  

** 7/ 2/79  1800 19.9  8.4  10.7  18.  426.  25.  610.  9.  358.  

** 7/ 2/79  1900 19.3  8.4  10.6  19.  423.  27.  606.  10.  356.  

** 7/ 2/79  2000 19.0  8.4  10.7  20.  439.  29.  628.  10.  369.  

** 7/ 2/79  2100 19.3  8.4  10.7  3.   434.  5.   622.  2.   365.  

** 7/ 2/79  2200 19.3  8.5  10.5  30.  386.  44.  557.  16.  327.  

** 7/ 2/79  2300 18.8  8.5  10.4  24.  412.  35.  595.  12.  349.  

** 7/ 2/79  2400 18.8  8.5  10.5  25.  408.  36.  589.  13.  346.  

*****

```

KVB11-6015-1224

 **
 ** HOURLY DATA
 ** DRY STACK GAS CONCENTRATION
 **
 **

		DATE	TIME	LOAD	O2 VOL%	CO2 VOL%	CO PPMV	NO MEAS	CO PPMV	NO 3202	CO NG/J	NO NG/J	
				MWTH	MEAS	MEAS	MEAS	MEAS	PPMV	3202			
**	7/ 3/79	100	18.8	8.5	10.5	26.	424.	37.	612.	13.	359.	**	**
**	7/ 3/79	200	18.8	8.5	10.5	27.	422.	39.	609.	14.	357.	**	**
**	7/ 3/79	300	18.8	8.5	10.5	29.	398.	41.	574.	15.	337.	**	**
**	7/ 3/79	400	19.0	8.5	10.4	31.	390.	45.	563.	16.	330.	**	**
**	7/ 3/79	500	19.0	8.5	10.4	36.	400.	51.	577.	18.	339.	**	**
**	7/ 3/79	600	19.0	8.5	10.4	40.	391.	58.	564.	21.	331.	**	**
**	7/ 3/79	700	19.0	8.5	10.4	46.	390.	66.	564.	24.	331.	**	**
**	7/ 3/79	800	19.6	8.5	10.2	49.	391.	71.	564.	25.	331.	**	**
**	7/ 3/79	900	19.9	8.5	10.6	11.	357.	15.	515.	5.	302.	**	**
**	7/ 3/79	1000	20.5	8.5	10.6	7.	422.	10.	609.	4.	357.	**	**
**	7/ 3/79	1100	20.5	8.4	10.6	6.	427.	9.	611.	3.	359.	**	**
**	7/ 3/79	1200	24.3	8.6	10.4	5.	452.	8.	659.	3.	387.	**	**
**	7/ 3/79	1300	49.2	7.9	11.1	4.	573.	6.	788.	2.	463.	**	**
**	7/ 3/79	1400	61.5	8.3	10.8	5.	610.	7.	867.	2.	509.	**	**
**	7/ 3/79	1500	63.9	8.2	10.8	7.	620.	10.	874.	4.	513.	**	**
**	7/ 3/79	1600	65.6	8.1	10.9	12.	610.	16.	853.	6.	501.	**	**
**	7/ 3/79	1700	65.6	8.1	10.9	12.	606.	16.	847.	6.	497.	**	**
**	7/ 3/79	1800	65.6	8.1	11.0	13.	614.	18.	859.	6.	504.	**	**
**	7/ 3/79	1900	65.6	8.1	10.9	14.	603.	19.	843.	7.	495.	**	**
**	7/ 3/79	2000	65.3	8.1	10.9	15.	604.	21.	845.	8.	496.	**	**
**	7/ 3/79	2100	65.3	8.1	10.8	16.	606.	23.	847.	8.	497.	**	**
**	7/ 3/79	2200	43.9	8.2	10.7	7.	532.	9.	749.	3.	440.	**	**
**	7/ 3/79	2300	23.4	8.7	10.3	22.	424.	32.	622.	11.	365.	**	**
**	7/ 3/79	2400	19.6	8.4	10.6	27.	415.	38.	594.	14.	349.	**	**

KVB11-6015-1224

DAILY DATA												
DRY STACK GAS CONCENTRATION												
		DATE	TIME	LOAD	VOL%	CO2	CO	NO	CO	NO	CO	NO
				MWTH	MEAS	MEAS	PPMV	PPMV	PPMV	PPMV	PPMV	PPMV
**	7/ 4/79	100	17.6	8.6	10.2	30.	405.	44.	589.	16.	346.	
**	7/ 4/79	200	16.4	8.6	10.2	34.	415.	49.	603.	18.	354.	
**	7/ 4/79	300	16.7	8.6	10.2	39.	418.	57.	608.	20.	357.	
**	7/ 4/79	400	16.7	8.7	10.2	47.	420.	69.	616.	25.	362.	
**	7/ 4/79	500	17.0	8.7	10.1	55.	422.	81.	620.	29.	364.	
**	7/ 4/79	600	17.0	8.8	10.1	62.	422.	91.	624.	33.	366.	
**	7/ 4/79	700	17.3	8.8	10.1	64.	423.	95.	626.	34.	367.	
**	7/ 4/79	800	17.3	8.8	10.1	67.	419.	100.	621.	36.	364.	
**	7/ 4/79	900	17.6	8.8	10.1	67.	418.	100.	619.	36.	363.	
**	7/ 4/79	1000	17.9	8.8	10.1	68.	416.	101.	615.	36.	361.	
**	7/ 4/79	1100	18.8	8.7	10.1	49.	422.	72.	619.	26.	363.	
**	7/ 4/79	1200	21.1	8.6	10.3	6.	427.	8.	621.	3.	365.	
**	7/ 4/79	1300	23.4	8.6	10.4	0.	437.	0.	636.	0.	373.	
**	7/ 4/79	1400	26.4	8.6	10.4	0.	444.	0.	646.	0.	379.	
**	7/ 4/79	1500	24.9	8.6	10.3	0.	424.	0.	617.	0.	362.	
**	7/ 4/79	1600	23.4	8.6	10.4	0.	419.	0.	610.	0.	358.	
**	7/ 4/79	1700	23.4	8.4	10.6	0.	415.	0.	595.	0.	349.	
**	7/ 4/79	1800	23.4	8.4	10.6	12.	414.	17.	592.	6.	348.	
**	7/ 4/79	1900	23.4	8.4	10.5	10.	426.	14.	610.	5.	358.	
**	7/ 4/79	2000	19.6	8.4	10.5	11.	400.	15.	573.	5.	336.	
**	7/ 4/79	2100	17.6	8.6	10.3	10.	448.	15.	652.	5.	383.	
**	7/ 4/79	2200	19.9	8.6	10.3	10.	436.	15.	635.	5.	373.	
**	7/ 4/79	2300	20.5	8.5	10.3	11.	440.	16.	635.	6.	373.	
**	7/ 4/79	2400	17.6	8.7	10.2	11.	438.	16.	643.	6.	377.	

KVB11-6015-1224

**HOURLY DATA
DRY STACK GAS CONCENTRATION**

		LOAD	O2 VOL%	CO2 VOL%	CO PPMV	NO PPMV	CO PPMV	NO PPMV	CO NG/J	NO NG/J	
**	DATE	TIME	MTH	MEAS	MEAS	MEAS	MEAS	3CO2	3CO2	**	
**	7/ 4/79	100	17.6	8.6	10.2	30.	405.	44.	589.	16.	346.
**	7/ 4/79	200	16.4	8.6	10.2	34.	415.	49.	603.	18.	354.
**	7/ 4/79	300	16.7	8.6	10.2	39.	418.	57.	608.	20.	357.
**	7/ 4/79	400	16.7	8.7	10.2	47.	420.	69.	616.	25.	362.
**	7/ 4/79	500	17.0	8.7	10.1	55.	422.	81.	620.	29.	364.
**	7/ 4/79	600	17.0	8.8	10.1	62.	422.	91.	624.	33.	366.
**	7/ 4/79	700	17.3	8.8	10.1	64.	423.	95.	626.	34.	367.
**	7/ 4/79	800	17.3	8.8	10.1	67.	419.	100.	621.	36.	364.
**	7/ 4/79	900	17.6	8.8	10.1	67.	418.	100.	619.	36.	363.
**	7/ 4/79	1000	17.9	8.8	10.1	68.	416.	101.	615.	36.	361.
**	7/ 4/79	1100	18.8	8.7	10.1	49.	422.	72.	619.	26.	363.
**	7/ 4/79	1200	21.1	8.6	10.3	6.	427.	8.	621.	3.	365.
**	7/ 4/79	1300	23.4	8.6	10.4	0.	437.	0.	636.	0.	373.
**	7/ 4/79	1400	26.4	8.6	10.4	0.	444.	0.	646.	0.	379.
**	7/ 4/79	1500	24.9	8.6	10.3	0.	624.	0.	617.	0.	362.
**	7/ 4/79	1600	23.4	8.6	10.4	0.	419.	0.	610.	0.	358.
**	7/ 4/79	1700	23.4	8.4	10.6	0.	415.	0.	595.	0.	349.
**	7/ 4/79	1800	23.4	8.4	10.6	12.	414.	17.	592.	6.	348.
**	7/ 4/79	1900	23.4	8.4	10.5	10.	426.	14.	610.	5.	358.
**	7/ 4/79	2000	19.6	8.4	10.5	11.	400.	15.	573.	5.	336.
**	7/ 4/79	2100	17.6	8.6	10.3	10.	448.	15.	652.	5.	383.
**	7/ 4/79	2200	19.9	8.6	10.3	10.	436.	15.	635.	5.	373.
**	7/ 4/79	2300	20.5	8.5	10.3	11.	440.	16.	635.	6.	373.
**	7/ 4/79	2400	17.6	8.7	10.2	11.	438.	16.	643.	6.	377.

KVB11-6015-1224

HOURLY DATA DRY STACK GAS CONCENTRATION											
DATE	TIME	LOAD	O2	CO2	CO	NO	CO	NO	CO	NO	
			VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	NG/J	NG/J	NG/J
7/ 5/79	100	17.6	8.7	10.2	12.	447.	18.	656.	6.	385.	**
7/ 5/79	200	17.6	8.7	10.2	12.	447.	18.	656.	6.	385.	**
7/ 5/79	300	17.6	8.7	10.2	13.	448.	19.	657.	7.	386.	**
7/ 5/79	400	17.6	8.7	10.2	13.	448.	19.	657.	7.	386.	**
7/ 5/79	500	17.6	8.8	10.2	13.	442.	19.	654.	7.	384.	**
7/ 5/79	600	16.7	8.8	10.2	18.	443.	27.	655.	10.	385.	**
7/ 5/79	700	16.7	8.7	10.2	20.	454.	29.	666.	10.	391.	**
7/ 5/79	800	16.7	8.8	10.2	21.	460.	31.	680.	11.	400.	**
7/ 5/79	900	20.2	8.5	10.0	22.	430.	32.	621.	11.	364.	**
7/ 5/79	1000	26.4	8.3	10.6	13.	518.	18.	735.	6.	432.	**
7/ 5/79	1100	26.4	8.1	10.8	12.	529.	16.	740.	6.	435.	**
7/ 5/79	1200	23.4	8.7	10.1	14.	412.	21.	604.	8.	355.	**
7/ 5/79	1300	23.4	8.5	10.4	14.	392.	20.	566.	7.	332.	**
7/ 5/79	1400	23.4	8.3	10.6	13.	388.	19.	551.	7.	324.	**
7/ 5/79	1500	23.4	8.2	10.6	13.	378.	18.	532.	6.	312.	**
7/ 5/79	1600	23.4	8.2	10.5	11.	381.	16.	536.	6.	315.	**
7/ 5/79	1700	23.4	8.2	10.5	10.	377.	14.	532.	5.	312.	**
7/ 5/79	1800	23.4	8.2	10.5	9.	372.	13.	525.	5.	308.	**
7/ 5/79	1900	23.4	8.2	10.5	11.	381.	15.	538.	5.	316.	**
7/ 5/79	2000	20.5	8.3	10.4	16.	356.	23.	506.	8.	297.	**
7/ 5/79	2100	19.6	8.3	10.4	15.	376.	22.	535.	8.	314.	**
7/ 5/79	2200	19.0	8.2	10.4	17.	367.	24.	518.	9.	304.	**
7/ 5/79	2300	19.3	8.4	10.2	17.	371.	25.	531.	9.	312.	**
7/ 5/79	2400	19.0	8.4	10.1	19.	376.	27.	538.	10.	316.	**

KVB11-6015-1224

HOURLY DATA DRY STACK GAS CONCENTRATION													
		DATE	TIME	LOAD	O2 VOL%	CO2 VOL%	CO PPMV	NO PPMV	CO PPMV	NO PPMV	CO NG/J	NO NG/J	
				MWTH	MEAS	MEAS	MEAS	MEAS	3202	3202			
**	**	7/ 6/79	100	19.0	8.4	10.2	19.	375.	28.	538.	10.	316.	**
**	**	7/ 6/79	200	19.0	8.5	10.0	20.	384.	30.	555.	11.	326.	**
**	**	7/ 6/79	300	19.3	8.4	10.1	23.	380.	33.	544.	12.	319.	**
**	**	7/ 6/79	400	19.6	8.5	10.0	24.	383.	35.	552.	12.	324.	**
**	**	7/ 6/79	500	19.0	8.4	10.1	26.	375.	37.	538.	13.	316.	**
**	**	7/ 6/79	600	19.0	8.5	10.0	28.	375.	40.	541.	14.	318.	**
**	**	7/ 6/79	700	19.3	8.4	10.2	31.	368.	45.	527.	16.	309.	**
**	**	7/ 6/79	800	19.3	8.3	10.1	40.	360.	57.	511.	20.	300.	**
**	**	7/ 6/79	900	21.1	8.4	10.3	31.	362.	45.	519.	16.	305.	**
**	**	7/ 6/79	1000	24.9	8.5	10.5	13.	374.	19.	541.	7.	317.	**
**	**	7/ 6/79	1100	25.8	8.4	10.5	11.	372.	16.	532.	6.	313.	**
**	**	7/ 6/79	1200	29.3	8.4	10.6	12.	379.	18.	543.	6.	319.	**
**	**	7/ 6/79	1300	27.5	8.4	10.5	13.	378.	19.	542.	7.	318.	**
**	**	7/ 6/79	1400	27.8	8.4	10.5	14.	381.	20.	546.	7.	320.	**
**	**	7/ 6/79	1500	27.0	8.5	10.5	19.	382.	27.	552.	10.	324.	**
**	**	7/ 6/79	1600	25.5	8.5	10.4	19.	400.	28.	578.	10.	339.	**
**	**	7/ 6/79	1700	23.7	8.2	10.6	19.	409.	26.	577.	9.	339.	**
**	**	7/ 6/79	1800	22.3	8.3	10.5	20.	411.	28.	584.	10.	343.	**
**	**	7/ 6/79	1900	22.3	8.3	10.5	21.	412.	29.	585.	10.	343.	**
**	**	7/ 6/79	2000	22.3	8.3	10.5	26.	380.	36.	540.	13.	317.	**
**	**	7/ 6/79	2100	22.6	8.2	10.5	22.	405.	31.	571.	11.	335.	**
**	**	7/ 6/79	2200	21.1	8.2	10.5	23.	406.	32.	572.	12.	336.	**
**	**	7/ 6/79	2300	19.3	8.5	10.2	5.	390.	7.	563.	3.	331.	**
**	**	7/ 6/79	2400	18.8	8.5	10.2	29.	384.	42.	554.	15.	326.	**

KVB11-6015-1224

HOURLY DATA DRY STACK GAS CONCENTRATION												
			O2	CO2	CO	NO	CO	NO	CO	NO		
		DATE	TIME	LOAD	VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	NG/J	NO NG/J
				MWTH	MEAS	MEAS	MEAS	MEAS	3%O2	3%O2		
**	7/ 7/79	100	18.2	8.6	10.2	32.	381.	47.	554.	17.	325.	**
**	7/ 7/79	200	18.8	8.6	10.1	35.	383.	51.	558.	18.	328.	**
**	7/ 7/79	300	18.5	8.6	10.1	39.	380.	56.	553.	20.	325.	**
**	7/ 7/79	400	18.5	8.6	10.1	42.	377.	61.	549.	22.	322.	**
**	7/ 7/79	500	18.2	8.6	10.1	45.	386.	66.	561.	24.	330.	**
**	7/ 7/79	600	18.2	8.6	10.1	49.	386.	72.	561.	26.	330.	**
**	7/ 7/79	700	18.8	8.6	10.1	52.	395.	76.	575.	27.	338.	**
**	7/ 7/79	800	18.8	8.5	10.1	56.	389.	81.	561.	29.	330.	**
**	7/ 7/79	900	18.2	8.5	10.1	58.	383.	84.	554.	30.	325.	**
**	7/ 7/79	1000	17.6	8.5	10.1	62.	378.	90.	546.	32.	321.	**
**	7/ 7/79	1100	21.1	8.5	10.2	56.	400.	81.	578.	29.	339.	**
**	7/ 7/79	1200	21.1	8.5	10.3	28.	404.	40.	584.	14.	343.	**
**	7/ 7/79	1300	21.1	8.5	10.3	23.	406.	33.	586.	12.	344.	**
**	7/ 7/79	1400	21.1	8.6	10.3	21.	408.	30.	594.	11.	349.	**
**	7/ 7/79	1500	21.1	8.5	10.3	21.	373.	30.	539.	11.	316.	**
**	7/ 7/79	1600	19.0	8.6	10.3	21.	393.	30.	572.	11.	336.	**
**	7/ 7/79	1700	18.8	8.6	10.3	20.	383.	29.	558.	10.	328.	**
**	7/ 7/79	1800	18.5	8.6	10.2	19.	373.	28.	543.	10.	319.	**
**	7/ 7/79	1900	19.3	8.6	10.2	19.	370.	27.	538.	10.	316.	**
**	7/ 7/79	2000	19.3	8.4	10.4	25.	357.	37.	512.	13.	300.	**
**	7/ 7/79	2100	18.8	8.5	10.3	23.	371.	34.	536.	12.	315.	**
**	7/ 7/79	2200	18.5	8.5	10.3	25.	371.	36.	535.	13.	314.	**
**	7/ 7/79	2300	18.2	8.5	10.3	27.	373.	39.	538.	14.	316.	**
**	7/ 7/79	2400	18.2	8.6	10.2	30.	382.	44.	556.	16.	326.	**

KVB11-6015-1224

HOURLY DATA												
DRY STACK GAS CONCENTRATION												
			O2	CO2	CO	NO	CU	NO	CO	NO		
			LOAD	VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	NG/J	NG/J	
			MWTH	MEAS	MEAS	MEAS	MEAS	MEAS	MEAS			
**	7/ 8/79	100	19.3	8.8	10.0	32.	390.	47.	578.	17.	339.	**
**	7/ 8/79	200	18.8	8.8	10.1	38.	387.	55.	573.	20.	336.	**
**	7/ 8/79	300	18.2	8.8	10.1	44.	389.	65.	575.	23.	338.	**
**	7/ 8/79	400	18.2	8.8	10.0	51.	384.	76.	569.	27.	334.	**
**	7/ 8/79	500	18.2	8.8	10.0	59.	384.	88.	564.	31.	333.	**
**	7/ 8/79	600	18.2	8.8	10.0	67.	382.	99.	565.	35.	331.	**
**	7/ 8/79	700	18.2	8.8	10.0	71.	385.	106.	570.	38.	334.	**
**	7/ 8/79	800	18.5	8.8	10.0	74.	386.	110.	570.	39.	335.	**
**	7/ 8/79	900	15.2	9.1	9.7	78.	376.	118.	571.	42.	335.	**
**	7/ 8/79	1000	15.2	9.2	9.6	84.	369.	129.	565.	46.	331.	**
**	7/ 8/79	1100	15.2	9.2	9.5	90.	373.	137.	571.	49.	336.	**
**	7/ 8/79	1200	15.2	.0	.0	0.	0.	0.	0.	0.	0.	**
**	7/ 8/79	1300	14.6	9.1	9.7	77.	371.	117.	563.	42.	331.	**
**	7/ 8/79	1400	14.6	.0	9.5	30.	9.	26.	8.	9.	4.	**
**	7/ 8/79	1500	14.6	8.8	9.6	39.	380.	58.	562.	21.	330.	**
**	7/ 8/79	1600	17.6	8.4	10.1	38.	376.	54.	538.	19.	316.	**
**	7/ 8/79	1700	19.6	8.3	10.0	29.	375.	41.	533.	15.	313.	**
**	7/ 8/79	1800	20.2	8.2	10.0	25.	380.	35.	536.	13.	314.	**
**	7/ 8/79	1900	19.3	8.3	10.0	22.	380.	31.	540.	11.	317.	**
**	7/ 8/79	2000	19.0	8.3	10.0	22.	380.	31.	540.	11.	317.	**
**	7/ 8/79	2100	19.0	8.3	10.0	24.	382.	34.	543.	12.	319.	**
**	7/ 8/79	2200	19.0	8.4	10.0	28.	279.	40.	400.	14.	235.	**
**	7/ 8/79	2300	18.8	8.3	10.0	29.	278.	41.	395.	15.	232.	**
**	7/ 8/79	2400	18.8	8.3	10.0	30.	281.	43.	399.	15.	234.	**

KVB11-6015-1224

HOURLY DATA											
DRY STACK GAS CONCENTRATION											
		LOAD	O2	CO2	CO	NO	CO	NO	CO	NO	
		MWTH	VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	PPMV	PPMV	
			MEAS								
DATE	TIME						3XO2	3XO2	NG/J	NG/J	
7/ 9/79	100	18.8	8.5	9.8	30.	387.	43.	559.	15.	328.	
7/ 9/79	200	18.8	8.5	9.8	35.	392.	51.	566.	18.	332.	
7/ 9/79	300	18.8	8.4	9.8	37.	388.	53.	556.	19.	326.	
7/ 9/79	400	18.2	8.4	9.8	45.	387.	64.	554.	23.	325.	
7/ 9/79	500	17.9	8.4	9.8	52.	387.	74.	554.	27.	325.	
7/ 9/79	600	17.6	8.5	9.8	56.	387.	81.	559.	29.	328.	
7/ 9/79	700	18.2	8.4	9.8	65.	390.	93.	558.	33.	328.	
7/ 9/79	800	20.2	8.2	10.0	70.	397.	99.	560.	35.	329.	
7/ 9/79	900	23.4	7.9	10.4	0.	322.	0.	444.	0.	260.	
7/ 9/79	1000	18.8	8.6	10.3	59.	388.	87.	565.	31.	331.	
7/ 9/79	1100	18.2	8.4	10.5	56.	382.	80.	547.	29.	321.	
7/ 9/79	1200	18.8	8.4	10.6	52.	381.	75.	546.	27.	320.	
7/ 9/79	1300	17.9	8.5	10.5	72.	362.	104.	523.	37.	307.	
7/ 9/79	1400	17.6	8.5	10.5	77.	357.	111.	516.	40.	303.	
7/ 9/79	1500	17.6	8.5	10.5	77.	359.	112.	518.	40.	304.	
7/ 9/79	1600	17.6	8.5	10.5	82.	354.	118.	512.	42.	300.	
7/ 9/79	1700	17.9	8.4	10.6	97.	352.	140.	505.	50.	296.	
7/ 9/79	1800	17.9	8.5	10.5	110.	353.	159.	510.	57.	300.	
7/ 9/79	1900	17.6	8.5	10.5	122.	358.	176.	517.	63.	304.	
7/ 9/79	2000	17.6	8.5	10.5	127.	348.	184.	502.	66.	295.	
7/ 9/79	2100	18.2	8.5	10.5	128.	336.	185.	485.	66.	285.	
7/ 9/79	2200	18.8	8.5	10.5	129.	341.	187.	492.	67.	289.	
7/ 9/79	2300	18.2	8.6	10.4	129.	333.	188.	485.	67.	285.	
7/ 9/79	2400	18.8	8.6	10.4	129.	331.	187.	482.	67.	283.	

KVB11-6015-1224

DAILY DATA												
DRY STACK GAS CONCENTRATION												
		DATE	TIME	LOAD	O2	CO2	CO	NO	CO	NO	CO	NO
				MWTH	VOL%	VOL%	PPMV	PPMV	PPMV	PPMV	PPM/V	NG/J
				MEAS	MEAS							
**	7/10/79	100	18.5	8.7	10.3	129.	327.	190.	480.	68.	282.	**
**	7/10/79	200	18.5	8.8	10.2	129.	328.	192.	485.	68.	285.	**
**	7/10/79	300	18.8	8.8	10.1	130.	328.	193.	485.	69.	285.	**
**	7/10/79	400	18.8	8.8	10.1	132.	328.	195.	485.	70.	285.	**
**	7/10/79	500	18.8	8.8	10.1	133.	339.	196.	502.	70.	295.	**
**	7/10/79	600	19.6	8.8	10.0	136.	371.	201.	549.	72.	322.	**
**	7/10/79	700	19.6	8.8	10.0	140.	383.	207.	567.	74.	333.	**
**	7/10/79	800	23.4	8.7	10.1	129.	390.	189.	572.	67.	336.	**
**	7/10/79	900	23.4	8.8	10.2	66.	407.	98.	603.	35.	354.	**
**	7/10/79	1000	36.9	8.1	10.9	84.	487.	118.	680.	42.	400.	**
**	7/10/79	1100	50.4	8.2	10.9	81.	560.	114.	789.	41.	464.	**
**	7/10/79	1200	50.4	8.3	10.8	53.	577.	76.	820.	27.	481.	**
**	7/10/79	1300	50.4	8.3	10.7	54.	583.	76.	829.	27.	486.	**
**	7/10/79	1400	50.4	8.3	10.7	67.	580.	95.	825.	34.	484.	**
**	7/10/79	1500	50.4	8.3	10.7	65.	580.	93.	824.	33.	484.	**
**	7/10/79	1600	52.7	8.2	10.8	67.	581.	95.	818.	34.	480.	**
**	7/10/79	1700	55.1	8.1	11.0	72.	590.	100.	825.	36.	484.	**
**	7/10/79	1800	55.1	8.4	10.7	72.	587.	103.	840.	37.	493.	**
**	7/10/79	1900	55.1	8.8	10.3	72.	571.	107.	845.	38.	496.	**
**	7/10/79	2000	55.7	12.4	5.7	66.	357.	138.	752.	49.	441.	**
**	7/10/79	2100	55.1	14.5	3.0	63.	253.	177.	707.	63.	415.	**
**	7/10/79	2200	29.3	.0	.0	0.	0.	0.	0.	0.	0.	**
**	7/10/79	2300	.0	.0	.0	0.	0.	0.	0.	0.	0.	**
**	7/10/79	2400	.0	.0	.0	0.	0.	0.	0.	0.	0.	**

KVB11-6015-1224

HOURLY DATA DRY STACK GAS CONCENTRATION													
		LOAD	O2 VOL%	O2 MEAS	CO2 VOL%	CO2 MEAS	CO PPMV	CO PPMV	CO PPMV	NO 3XO2	NO 3XO2	CO NG/J	NO NG/J
DATE	TIME	MTH											
7/11/79	100	.0	.0	.0	.0	.0	0.	0.	0.	0.	0.	0.	
7/11/79	200	.0	.0	.0	.0	.0	0.	0.	0.	0.	0.	0.	
7/11/79	300	.0	.0	.0	.0	.0	0.	0.	0.	0.	0.	0.	
7/11/79	400	.0	.0	.0	.0	.0	0.	0.	0.	0.	0.	0.	
7/11/79	500	.0	.0	.0	.0	.0	0.	0.	0.	0.	0.	0.	
7/11/79	600	.0	.0	.0	.0	.0	0.	0.	0.	0.	0.	0.	
7/11/79	700	.0	.0	.0	.0	.0	0.	0.	0.	0.	0.	0.	
7/11/79	800	.0	.0	.0	.0	.0	0.	0.	0.	0.	0.	0.	
7/11/79	900	.0	.0	.0	.0	.0	0.	0.	0.	0.	0.	0.	
7/11/79	1000	48.6	7.9	11.5	71.	456.	97.	630.	35.	370.	**	**	
7/11/79	1100	48.6	7.9	11.6	71.	460.	97.	633.	35.	372.	**	**	
7/11/79	1200	48.6	7.8	11.6	70.	473.	96.	646.	34.	379.	**	**	
7/11/79	1300	48.6	7.7	11.6	72.	459.	98.	623.	35.	366.	**	**	
7/11/79	1400	49.8	7.6	11.5	68.	461.	91.	620.	33.	364.	**	**	
7/11/79	1500	49.8	7.7	11.3	68.	520.	92.	706.	33.	414.	**	**	
7/11/79	1600	49.8	7.8	11.2	69.	557.	94.	762.	34.	447.	**	**	
7/11/79	1700	49.8	7.7	11.1	70.	577.	95.	782.	34.	459.	**	**	
7/11/79	1800	49.8	7.8	11.1	76.	552.	104.	754.	37.	443.	**	**	
7/11/79	1900	50.4	7.7	11.1	79.	556.	108.	753.	38.	442.	**	**	
7/11/79	2000	50.4	7.8	11.0	81.	580.	111.	792.	40.	465.	**	**	
7/11/79	2100	49.8	8.1	10.7	84.	575.	118.	804.	42.	472.	**	**	
7/11/79	2200	40.4	8.0	10.8	86.	552.	119.	765.	43.	449.	**	**	
7/11/79	2300	29.3	7.6	11.1	88.	536.	118.	721.	42.	423.	**	**	
7/11/79	2400	20.5	7.7	11.3	69.	463.	94.	628.	34.	369.	**	**	

KVB11-6015-1224

FIN

KVB11-6015-1224

APPENDIX F

SUMMARY OF PREVIOUS TEST DATA

The results of gaseous emissions tests conducted under a previous EPA program are presented in Table F-1. These tests were conducted under Contract No. 68-02-1074 and the results are reported in EPA-600/2-76-086a. The data presented herein were used to establish the baseline emissions for the boiler at Site 3.

At a load of 14.7 MW (130,000 lb/hr steam flow) the average NO emissions were 456 ng/J (777 ppm, 3% O₂ dry).

Table F-2 presents a summary of the coal fuel analyses from the previous tests.

TABLE F-1. SUMMARY OF GASEOUS EMISSIONS AT SITE 3
PULVERIZED COAL FIRED BOILER

(Data was taken during EPA Contract No. 68-02-1074.)

Date 1974	Nominal Steam Load		O ₂ Percent	CO ₂ Percent	NO*		CO* ppm
	MW	K lb/Hr.			ng/J	ppm	
12-5	14.9	132	7.3	12.7	474	775	0
12-5	7.5	66	7.2	11.9	495	809	0
12-5	14.7	130	7.7	11.5	480	785	0
12-9	14.7	130	7.4	11.9	468	765	0
12-9	14.7	130	7.4	11.8	478	782	0

*Corrected to 3% O₂ Dry

TABLE F-2. SUMMARY OF COAL AND ASH ANALYSIS
FROM SITE 3

(Samples were taken during EPA Contract No. 68-02-1074.)

ULTIMATE ANALYSIS

<u>Stream</u>	<u>Run</u>	<u>Percent by Weight, As Received</u>					
		<u>Carbon</u>	<u>Hydrogen</u>	<u>Nitrogen</u>	<u>Sulfur</u>	<u>Ash</u>	<u>Oxygen^{a/}</u>
Coal	169-3	62.95	5.16	0.85	1.28	10.78	18.98

a/ By difference.

PROXIMATE ANALYSIS

<u>Stream</u>	<u>Run</u>	<u>Percent by Weight, As Received</u>						<u>Heat of Combustion (Btu/lb)</u>
		<u>Moisture</u>	<u>Ash</u>	<u>Volatile Matter</u>	<u>Fixed Carbon</u>	<u>Sulfur</u>		
Coal	169-3	6.85	10.78	38.26	44.11	1.28		11,136
Bottom Ash	169-3	1.42	92.44	6.11	0.03	0.56		<u>a/</u>
Fly Ash	169-3	0.06	99.14	2.03	<u>a/</u>	0.22		82

a/ Ash gained weight due to high iron content.

TECHNICAL REPORT DATA <i>(Please read Instructions on the reverse before completing)</i>			
1. REPORT NO. EPA-600/7-80-085c	2.	3. RECIPIENT'S ACCESSION NO.	
4. TITLE AND SUBTITLE Thirty-day Field Tests of Industrial Boilers: Site 3-- Pulverized-coal-fired Boiler		5. REPORT DATE April 1980	6. PERFORMING ORGANIZATION CODE
7. AUTHOR(S) W. A. Carter and H. J. Buening		8. PERFORMING ORGANIZATION REPORT NO.	
9. PERFORMING ORGANIZATION NAME AND ADDRESS KVB, Inc. P.O. Box 19518 Irvine, California 92714		10. PROGRAM ELEMENT NO. EHE624	11. CONTRACT/GRANT NO. 68-02-2645, Task 4
12. SPONSORING AGENCY NAME AND ADDRESS EPA, Office of Research and Development Industrial Environmental Research Laboratory Research Triangle Park, NC 27711		13. TYPE OF REPORT AND PERIOD COVERED Task Final; 3/79-3/80	
		14. SPONSORING AGENCY CODE EPA/600/13	
15. SUPPLEMENTARY NOTES IERL-RTP project officer is Robert E. Hall, Mail Drop 65, 919/541-2477.			
16. ABSTRACT This is a final report for a test program to evaluate the long-term effectiveness of combustion modifications for lowering emissions from industrial boilers. Previous short-term tests had been performed on industrial boilers to determine the effect of combustion modifications on such air pollutant emissions as NOx, SOx, CO, HC, and particulate. The objective of this program was to determine if the combustion modification techniques which were effective for the short-term tests are feasible for longer periods. The report gives results of a 30-day field test of a pulverized-coal-fired, water-tube boiler rated at 76.2 MW (260,000 lb steam/hr) output. Staged combustion air and low excess air were used to effectively control NOx emissions. However, such additional operational problems as flame instability can be encountered. The baseline NO measurement was 498 ng/J (815 ppm at 3% O2, dry) with the unit operating at about 70% of capacity. At the same load, low NOx operations yielded NO at an emission level of 422 ng/J (691 ppm at 3% O2, dry) for a 15% NO reduction. During 30 days of firing under low NOx operation with loads of 15 to 63 MW, the average NO emission level was 340 ng/J (557 ppm at 3% O2, dry). Boiler efficiency increased about 1% under low NOx firing conditions.			
17. KEY WORDS AND DOCUMENT ANALYSIS			
a. DESCRIPTORS	b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group	
Pollution Boilers Pulverized Fuels Coal Combustion Field Tests Sulfur Oxides	Nitrogen Oxides Carbon Monoxide Hydrocarbons Dust	Pollution Control Stationary Sources Industrial Boilers Combustion Modification Staged Combustion Low Excess Air Particulate	13B 13A 21D 21B 14B 07B
18. DISTRIBUTION STATEMENT Release to Public		19. SECURITY CLASS (This Report) Unclassified	21. NO. OF PAGES 161
		20. SECURITY CLASS (This page) Unclassified	22. PRICE