



Research and Development

EVALUATION OF
SIMULTANECUS SO_2/NO_x
CONTROL TECHNOLOGY

Prepared for

Office of Environmental Engineering
and Technology Demonstration

Prepared by

Air and Energy Engineering Research
Laboratory
Research Triangle Park NC 27711

EPA REVIEW NOTICE

This report has been reviewed by the U.S. Environmental Protection Agency, and approved for publication. Approval does not signify that the contents necessarily reflect the views and policy of the Agency, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

This document is available to the public through the National Technical Information Service, Springfield, Virginia 22161.

EPA-600/R-93-188
September 1993

EVALUATION OF SIMULTANEOUS SO₂/NO_x CONTROL TECHNOLOGY

by:

Kevin R. Bruce and Walter F. Hansen
Acurex Environmental Corporation
4915 Prospectus Drive
P.O. Box 13109
Research Triangle Park, NC 27709

EPA Contract No. 68-DO-0141

EPA Project Officer: Brian K. Gullett
U.S. Environmental Protection Agency
Air and Energy Engineering Research Laboratory
Research Triangle Park, NC 27711

Prepared for:

Nalco Fuel Tech
P.O. Box 3031
Naperville, IL 60566-7031
(Under Cooperative Research and Development Agreement)
and
U.S. Environmental Protection Agency
Office of Research and Development
Washington, DC 20460

ABSTRACT

The Clean Air Act Amendments of 1990 have led to accelerated research into novel SO₂ and NO_x control technologies for coal-fired industrial boilers. One of these technologies is the combination of sorbent injection and selective non-catalytic reduction (SNCR) for simultaneous SO₂/NO_x removal. The work presented herein concentrated on characterizing several process operational parameters of this technology: injection temperature, sorbent type, and reductant/pollutant stoichiometric ratio. A slurry composed of a urea-based solution (NO_xOUT A or NO_xOUT A+)* and various Ca-based sorbents was injected at a range of temperatures and reactant/pollutant stoichiometries in a natural-gas-fired, pilot-scale reactor with doped pollutants. Up to 80 percent reduction of SO₂ and NO_x at reactant/pollutant stoichiometric ratios of 2 and 1.5, respectively, was achieved. SO₂ emission reductions from slurry injection were enhanced moderately when compared with dry sorbent injection methods, possibly caused by sorbent fracturing to smaller, more reactive particles. Emissions from NH₃ slip (unreacted nitrogen-based reducing agent) and N₂O formation were reduced in comparison with other published results, while similar NO_x reductions were obtained. Increased CO emissions, caused by the decomposition of urea, were moderate. Emissions of CO, NH₃, and N₂O for the enhanced urea solution (NO_xOUT A+) were substantially less than the levels observed during urea (NO_xOUT A) injection. The injection of the urea-based solution enhanced the SO₂ removal, probably because of the formation of (NH₄)₂Ca(SO₄)₂•H₂O. The results of this pilot-scale study have shown high reduction of both SO₂ and NO_x.

(*) Where used throughout this report, NO_xOUT A and NO_xOUT A+ are registered trademarks of Nalco Fuel Tech.

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
Abstract	ii
Acknowledgements	vi
Executive Summary	vii
1.0 INTRODUCTION	1
2.0 OBJECTIVES	3
3.0 EXPERIMENTAL	4
3.1 Furnace	4
3.2 Furnace Operation During Natural Gas Firing	6
3.3 Emissions Sampling	7
3.4 Solid Sampling	11
3.5 Sorbent Delivery	13
3.6 Temperature Profiles	15
3.7 Waste Solid Resistivity	16
3.8 Testing and Calculations	16
3.9 Slurry Injection Nozzle Characterization	20
3.10 Sorbent Type	21
3.11 Ammonia Solution Injection	21
4.0 QUALITY ASSURANCE	23
4.1 Quality Assurance Procedures	23
4.2 Quality Assurance Audit	26
5.0 RESULTS AND DISCUSSION	27
5.1 General	27
5.2 Sulfur Dioxide Tests	27
5.2.1 Comparison	29
5.2.2 Temperature	31
5.2.3 Dry Versus Slurry Injection	31
5.2.4 Effect of NO _x OUT A	31

(continued)

TABLE OF CONTENTS (concluded)

<u>Section</u>	<u>Page</u>
5.2.5 Ca(OH) ₂ vs. Slaked CaO	32
5.2.6 Particle Size Effects	32
5.3 Nitrogen Oxide Tests	34
5.3.1 N ₂ O	34
5.3.2 NH ₃	37
5.3.3 Comparison	38
5.4 Coal Tests	41
5.5 Resistivity Results	43
6.0 CONCLUSIONS AND RECOMMENDATIONS	45
References	47
Appendix A. Innovative Furnace Data Log Sheets	A-1
Appendix B. LIMB Innovative Furnace Performance Evaluation Audit	B-1
Appendix C. Resistivity Test Results	C-1
Appendix D. Graphical Interpolation of Test Results	D-1

LIST OF TABLES

<u>Table</u>	<u>Page</u>
1 Data Quality Objectives for Measured Parameters	24
2 Calibration Procedures for Process Measurement/Feed Devices	25

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
1 Schematic of Innovative Furnace Reactor System.	5
2 Flue Gas Components Sampling System	8
3 Schematic of the Two Methods of N ₂ O Sampling	10
4 Ammonia Sampling Apparatus	10
5 Solid Sampling System	12
6 Equipment Schematic for Dry Injection	14
7 Equipment Schematic for Slurried Injection	14
8 Temperature Profile of Furnace During Dry and Slurry Injection While Firing Natural Gas	17
9 Spray Droplet Size as a Function of Liquid Flow	22
10 Spray Droplet Size as a Function of Carrier Gas Pressure	22
11 Effect of Injection Temperature on SO ₂ Removal in CaCO ₃ Tests	28
12 Effect of Injection Temperature on SO ₂ Removal in Ca(OH) ₂ and CaO Tests	30
13 Effect of Sorbent Particle Size on SO ₂ Removal	33
14 Effect of Injection Temperature on Emissions Using NO _x OUT A	35
15 Effect of Injection Temperature on Emissions Using NO _x OUT A+	35
16 Effect of N/NO _{xi} on Emissions Using NO _x OUT A	36
17 Effect of N/NO _{xi} on Emissions Using NO _x OUT A+	36
18 Effect of Injection Temperature on NO _x Removal Using NH ₃ Solution	39
19 Effect of NO/NO _{xi} on NO _x Removal Using NH ₃ Solution	39
20 Effect of Injection Temperature on Emissions Using NH ₃ Water	40
21 Effect of NO/NO _{xi} on emissions using NH ₃ water	40
22 Effect of Injection Temperature on ΔN ₂ O/ΔNO _x	42
23 Effect of Injection Temperature on NH ₃ Emissions at N/NO _{xi} = 1.5	42

ACKNOWLEDGEMENTS

The assistance of EPA Project Officer Brian K. Gullett in preparing this report is gratefully acknowledged. His contribution consisted of substantive preparation of the results, discussion, and conclusion sections, as well as providing overall guidance for the project. Additionally, the help of George R. Gillis and Frank E. Briden, of the EPA (AEERL) with equipment construction and solid material analyses, respectively, is greatly appreciated. The facilities operation, by Charles B. Courtney of Acurex Environmental Corporation, was also of great value to the success of this work. Special thanks to the Tenn Luttrell Company for providing the sorbents.

EXECUTIVE SUMMARY

The project work reported herein was initiated through a Cooperative Research and Development Agreement (CRADA) between the U.S. Environmental Protection Agency's (EPA) Air and Energy Engineering Research Laboratory (AEERL) and Nalco Fuel Tech, a commercial licensor of a urea-based reducing agent injection technology for NO_x reduction.

Experimental testing of Nalco Fuel Tech's urea-based NO_xOUT A and NO_xOUT A+ reducing agents for NO_x control, in combination with calcium-based sorbent injection for SO₂ control, was conducted from June 1991 to November 1991. Testing was performed at the EPA Environmental Research Center in Research Triangle Park, NC in a pollutant-doped, natural gas-fired furnace (14,650 W).

The project scope of work included testing furnace sorbent injection of several calcium-based sorbents to remove SO₂ from flue gas. The tested sorbents came from a single source of commercially prepared Ca(OH)₂, CaCO₃, and CaO. A comparison of SO₂ removal efficiency was made between dry and slurry injection. The effect of CaCO₃ sorbent particle size was also studied.

Slurry sorbent injection was found to be superior to dry injection for SO₂ removal. Dry injection of Ca(OH)₂ achieved a maximum of 60 percent SO₂ removal (at a Ca/S ratio = 2), while the Ca(OH)₂ slurry removed 72 percent. Removal efficiency with Ca(OH)₂ was superior to CaCO₃ in both dry (43 percent) and slurry (58 percent) testing. CaO was tested in slurry form by slaking to form Ca(OH)₂ slurry, and compared to the commercially prepared Ca(OH)₂. The slaked CaO proved identical in its SO₂ removal performance to the commercially prepared Ca(OH)₂.

Investigation into the effect of sorbent particle size on removal efficiency showed that the increasing reactivity of the sorbent with SO_2 was inversely proportional to the sorbent particle size. After sieving the CaCO_3 sorbent, a significant increase in performance was observed with the finer particle size, with SO_2 capture comparable to $\text{Ca}(\text{OH})_2$ of equivalent size for dry injection. Results from this work indicate $\text{Ca}(\text{OH})_2$ to be superior to CaCO_3 under all conditions of slurry injection.

$\text{NO}_x\text{OUT A}$ and $\text{NO}_x\text{OUT A+}$ reducing agents were tested over a range of injection temperatures (821-1,170 °C) to investigate the effect on NO_x removal efficiency. Additionally, the effect of varying the molar ratio of reducing agent to baseline NO_x concentration from 0.8 to 3.5 was studied. Finally, the reducing agent injection for NO_x removal was coupled with slurried sorbent injection for SO_2 removal.

Both reducing agents achieved maximum NO_x removal when injected at a temperature of about 1,100 °C. Almost no difference in the two reducing agents existed at the optimum temperature; approximately 80 percent NO_x removal was observed for both reducing agents. At temperatures higher than the optimum, NO_x removal efficiency dropped quickly. At about 1,170 °C, the reducing agents began producing NO_x , caused probably by high temperature oxidation of the NH_3 produced by urea decomposition. At temperatures lower than the optimum, NO_x removal efficiency gradually decreased. The $\text{NO}_x\text{OUT A+}$ yielded a wider injection temperature window; that is, NO_x removal efficiency remained higher than with $\text{NO}_x\text{OUT A}$ as injection temperature decreased.

Varying the molar ratio of reducing agent (urea) to baseline NO_x , or N/NO_{xi} , showed that increasing N/NO_{xi} to a value of near 2 produced significant improvement in NO_x removal. Further N/NO_{xi} increases had little or no effect on removal efficiency. Comparing the two reducing agents during N/NO_{xi} variation shows no appreciable differences in behavior.

Coupling reducing agent injection with slurried sorbent injection produced some promising results. The co-injection of $\text{NO}_x\text{OUT A}$ improved all the sorbents' performances. The effect was not as pronounced with CaCO_3 as that of $\text{Ca}(\text{OH})_2$ and slaked CaO . A maximum SO_2 removal

enhancement of 2-3 percent absolute was observed with CaCO_3 , while a 10 percent absolute enhancement was observed for Ca(OH)_2 and slaked CaO . CaCO_3 slurry with the $\text{NO}_x\text{OUT A}$ reducing agent achieved a maximum of about 60 percent SO_2 removal of approximately 1,000 °C. SO_2 removals of more than 80 percent were observed with Ca(OH)_2 at the same temperature. As was previously stated, the slaked CaO performed identically to the Ca(OH)_2 .

The work mentioned above also entailed characterizing NH_3 , N_2O , and CO emissions produced by injecting the reducing agent over a range of temperatures and $\text{N/NO}_{x\text{i}}$. Each reducing agent produced maximum NH_3 slip (unreacted nitrogen-based reducing agent) at the lower injection temperatures; around 821 °C, the amount of slip was about 140 ppm for both $\text{NO}_x\text{OUT A}$ and $\text{NO}_x\text{OUT A+}$. As injection temperature increased, NH_3 slip for the $\text{NO}_x\text{OUT A}$ decreased quickly, while slip from $\text{NO}_x\text{OUT A+}$ dropped off almost completely at around 875 °C. At 900-1,000 °C, slip generated by $\text{NO}_x\text{OUT A}$ gradually decreased to a level of about 60 ppm. Throughout this temperature regime, $\text{NO}_x\text{OUT A+}$ produced negligible NH_3 slip (<10 ppm).

CO emissions produced by $\text{NO}_x\text{OUT A}$ rose gradually from about 20 ppm at 800 °C to a maximum of 25 ppm at 1,100 °C. $\text{NO}_x\text{OUT A+}$ produced low CO at 800-1,000 °C (<10 ppm), with a maximum of 50 ppm around 1,100 °C.

N_2O production by $\text{NO}_x\text{OUT A}$ was negligible at lower injection temperatures (approximately 25 ppm), but increased with injection temperature to a maximum of 200 ppm at approximately 1,150 °C, about 42 percent of the NO_x reduced. $\text{NO}_x\text{OUT A+}$ produced only moderate levels of N_2O (typically <40 ppm, less than 20 percent of the NO_x reduced) over the entire temperature range. A maximum of about 30 ppm was observed at around 1,150 °C.

Aqueous ammonia solution injection was performed to ensure that these results would be reproducible on other facilities. Available data for NO_x removal using aqueous ammonia injection showed comparable results to others' work. These data validated improvements shown by this work with both NO_xOUT solutions and suggested the applicability of these results to other facilities.

Testing of the solid waste ash/sorbent/urea mixtures indicated that ash resistivities increased to levels exceeding 10^{13} ohm-cm. This resistivity level can adversely affect electrostatic precipitator performance. However, these laboratory values were obtained at low temperatures. Resistivity values decrease at higher precipitator temperatures and typically are lower in the field than in laboratory measurements. Further work in pilot-scale precipitators would help determine whether particle collection will be adversely affected by sorbent/reducing agent injection.

SECTION 1
INTRODUCTION

Passage of the 1990 Clean Air Act Amendments (CAAA) has initiated extensive evaluation and planning for strategies to meet SO₂ and NO_x emission requirements. Furnace sorbent injection of calcium-based material for SO₂ removal is a technology that has been field tested on a number of units, achieving, for example, 63 percent SO₂ removal at a Ca/S (molar ratio) = 2 with a calcium hydroxide [Ca (OH)₂] sorbent and 72 percent with a surfactant-modified Ca(OH)₂ sorbent on a 105 MW(e) wall-fired unit.¹ Typically, lower SO₂ removals are achieved with calcium carbonate (CaCO₃) sorbents.

The anticipated NO_x regulations may be met, at least in part, by selective non-catalytic reduction (SNCR) which has achieved about 60 percent NO_x reduction on a 150 MW(e) coal-fired boiler at a molar ratio of reducing agent nitrogen to initial NO_x concentration (N/NO_{x,i}) of 2.² SNCR has also been the subject of numerous laboratory and pilot-scale studies.^{3,4} SNCR involves high-temperature furnace injection (800-1,100 °C) of a nitrogen-based reducing agent such as urea (NH₂CONH₂) or ammonia (NH₃), which converts NO_x to N₂ and H₂O.

Most concerns with using SNCR center around NH₃ emissions, or slip, which results from incomplete reaction of the injected reducing agent and the production of nitrous oxide (N₂O) caused by incomplete reduction of NO_x. NH₃ slip can cause ammonium bisulfate (NH₄HSO₄) formation around 300 °C and ammonium sulfate [(NH₄)₂SO₄] formation around 150 °C. The former can deposit upon air preheater surfaces reducing heat transfer and increasing pressure drop. It can also cause

NH_4Cl formation around 100 °C which results in a visible white plume in the stack emissions. N_2O has been implicated as a contributor to stratospheric ozone depletion and global warming, the latter because of its ability to absorb infrared radiation.^{5,6}

Research has demonstrated that levels of N_2O and NH_3 emissions from various SNCR compounds are extremely sensitive to injection temperature.^{7,8} Efforts to widen the applicable temperature injection window and control NH_3 slip and N_2O production through using additives have brought about some success, yet concerns remain to be addressed on the SNCR-type process.⁹ Similar research on SO_2/NO_x control processes has shown considerable merit, while significant questions still remain in the industry concerning NH_3 emissions and N_2O by-product formation.¹⁰

To further investigate simultaneous SO_2/NO_x control by sorbent/reducing agent injection, the U.S. Environmental Protection Agency (EPA) entered into a Cooperative Research and Development Agreement (CRADA) with Nalco Fuel Tech to test $\text{NO}_x\text{OUT A}$ and $\text{NO}_x\text{OUT A+}$, two commercial reducing agents produced by Nalco Fuel Tech, in conjunction with sorbent injection in AEERL's 14,650 W pilot facility. Variables of operation included injection temperature, stoichiometric ratio, and sorbent type. Emissions monitoring results for SO_2 , NO_x , N_2O , CO, and NH_3 are reported.

SECTION 2

OBJECTIVES

The principal objective of this research was to demonstrate the effectiveness of simultaneous SO_2 and NO_x removal by concurrent injection of a calcium-based slurry and $\text{NO}_x\text{OUT A}$ (or $\text{NO}_x\text{OUT A+}$), a urea-based reducing agent, while minimizing emissions of N_2O and NH_3 . Other secondary objectives defined in the CRADA between EPA and Nalco Fuel Tech included:

- Characterizing the operating conditions for sorbent slurry injection
- Comparing the removal efficiency of dry vs. slurry injection
- Evaluating the benefit of finely ground limestones/hydrated lime
- Optimizing injecting conditions, with targets of 60 percent SO_2 removal at $\text{Ca/S} = 2$ and 60-70 percent NO_x reduction at an $\text{N/NO}_{x\text{i}}$ of 2
- Comparing CO , NH_3 , and N_2O emissions produced by the injection of $\text{NO}_x\text{OUT A}$ and $\text{NO}_x\text{OUT A+}$ (an enhanced urea-based reducing agent) over a wide range of injection temperatures and reducing agent/ NO_x stoichiometries

SECTION 3 EXPERIMENTAL

3.1 FURNACE

The Innovative Furnace Reactor (IFR) system consists of a furnace, coal or natural gas feeders, a sorbent feeding system, emissions monitoring systems, and a particulate matter sampling system.

The furnace is a refractory-lined, down-fired cylindrical combustor capable of burning a variety of fuels including coal, natural gas, and some oils. The furnace is used to simulate the gaseous combustion environment and quench rate conditions anticipated in utility and industrial boilers. The internal bore (diameter) of the furnace is 15.2 cm while the length is about 4 m. It is constructed of several stacked rolled steel rings 76.2 cm in diameter and varying between 30-60 cm high. The rings are insulated by four courses of refractory, the last of which is a hard-faced, erosion-resistant type that forms the internal bore. An illustrated cross-section of the IFR is shown in Figure 1. Various view and injection/sample ports are along the length of the reactor while fuel and combustion air are fed in at the top of the furnace and burned. Coal feed is controlled by a vibrating-hopper, screw-type feeder. The coal is loaded into the feeder hopper where it is metered into a downward facing funnel-shaped receiver. At the receiver, the coal flow is aspirated into and through a copper line and delivered to the burner. Natural gas is metered into the burner through a rotameter at a known flow and pressure. Two types of air flow are provided in the burner region; the axial and tangential air flows at the burner are fully adjustable by flow and pressure. The combustion products travel down and out of the refractory-lined sections into a water-cooled junction where they turn 90° into a sampling stack.




Figure 1. Schematic of Innovative Furnace Reactor system.

3.2 FURNACE OPERATION DURING NATURAL GAS FIRING

Typical set-up procedures for natural gas firing included introducing the fuel (nominally CH₄, 37.8 kJ/L) through an axial feeder tube at the burner on the top of the combustor. There were four input gas flows to the furnace: CH₄ gas, axial air, tangential air, and sorbent/slurry transport air. All gas flows were controlled through rotameters. Sorbent delivery air flows were slightly different for the two types of injection (slurry/dry). The injection lances used required different flows to establish optimum sorbent atomization/distribution.

During slurry injection, 6.47 standard L/s of total pre-combustion air was supplied to the furnace through the three previously stated air flows. Natural gas was supplied at a rate of 0.557 standard L/s to yield an air/fuel combustion stoichiometry of approximately 1.20. The distribution of air flow was 67.4 percent through the tangential air supply, 14.6 percent through the axial air, and 18.0 percent through the sorbent injection lance. The majority of the air was supplied tangentially at the burner to ensure good mixing of the doping gases.

Dry injection trials required a total air supply of 6.56 standard L/s. The natural gas flow remained the same, but the combustion stoichiometry was slightly higher. Air flow distribution was 69.7 percent through the tangential air, 14.6 percent through the axial air, and 15.7 percent through the sorbent probe.

During natural gas burns, simulation of combustion products formed during true coal burning was performed by doping the feed natural gas with known concentrations of bottled NH₃ and SO₂. The NH₃ was added to the combustion zone by mixing with the natural gas feed stream. The two gases mixed just before entering the burner. The NH₃ was quantitatively oxidized to NO_x during combustion. SO₂ was introduced into the furnace by being added to the tangential air flow at the burner. Controlling these dopant gases allowed simulation of a wide range of NO_x and SO₂ emissions.

3.3 EMISSIONS SAMPLING

The sampling stack connected to the water-cooled junction is an insulated stainless steel pipe approximately 18 cm in diameter. Ports are installed along the pipe to enable several samples of stack gas to be extracted. Just past the water-cooled junction is a particulate matter filter through which the gas sample for SO₂ analysis is drawn. A schematic of the emissions monitoring/sampling system is shown in Figure 2. Particulate matter filters inside the stack are capable of blocking particles greater than 20 µm in diameter.

In these tests, the SO₂ sample passed out of the stack through a port and into a Mott sintered metal filter that removed all particles ≥ 0.5 µm. The resulting "particulate matter-clean" gas was passed on to an ultraviolet analyzer through a heated sample line maintained at approximately 350 °C. The SO₂ sample entered the measurement cell of the analyzer, was drawn through by a pump, and passed through a rotameter at the outlet.

A gas sample for analysis of NO_x, CO₂, CO, and O₂ was drawn through a particulate matter filter at another port in the stack section. The sample passed through a Hankison drying unit, then traveled to a junction where it was split into two portions; one was analyzed for NO by the chemiluminescent method, the other for CO, CO₂, and O₂. Only NO concentration was determined because it was found during initial testing that NO₂ concentration contributes less than 5 percent to the NO_x value. The NO sample stream was drawn through a rotameter and directly into a chemiluminescent analyzer. The sample was then exhausted to a stack.

The second portion of the split sample passed through a canister of anhydrous CaSO₄ then was split into three streams. Each stream passed through a rotameter and into the respective analyzer (CO₂, CO, O₂). CO and CO₂ were each detected and measured in separate infrared emissions analyzers, while the O₂ level was measured by a paramagnetic oxygen analyzer. These remaining sample streams were then exhausted to the atmosphere. Outputs from all the analyzers were recorded on strip chart recorders. The previously mentioned analyzers remained on-line for the duration of all




Figure 2. Flue gas components sampling system.

trials and were zeroed and spanned with gases of known concentration before and after each daily trial. The span gases used for all analyzers bracket the expected concentrations of effluent components. All measured values for NO, CO₂, CO, O₂ were corrected for the removed flue gas water based on calculation from fuel and injected water.

N₂O samples were analyzed by two different methods. Schematics of the N₂O sampling systems are shown in Figure 3. A gas chromatograph, equipped with an electron capture detector, two columns, and employing a backflush method to prevent interference from higher molecular weight compounds, was used to take grab samples of stack gas before and during sorbent/reducing agent injections.¹¹ A second analyzer, a tunable diode laser (TDL), monitored real-time stack N₂O emissions. The TDL is an experimental analyzer that uses laser light tuned to the same wavelength as the infrared absorption line of a known N₂O span gas. The stack gas N₂O infrared absorption line is then compared to the known laser output, and through a series of electronic components simulating second derivative spectroscopy, the stack gas concentration of N₂O is output to a strip chart recorder. This method and apparatus, detailed further in Reference 12, were calibrated for this work at 20-80 ppm, with an accuracy of ± 0.75 ppm. The two methods' results were comparable. Tests conducted at six varying conditions showed a linear correlation coefficient exceeding 0.99 between the two methods (for further comparison of N₂O analytical methods see Reference 13).

Ammonia stack gas concentrations were determined by withdrawing a stack gas sample through high flow, inline 10 µm filters and bubbling it through a solution of 0.02 N H₂SO₄. An equipment layout is shown in Figure 4. The gas was drawn through the impingers by a pump and the amount of stack gas sampled was monitored by a dry gas meter connected in-line. Approximately 20 L of stack gas passed through the impingers for any one test at about 2 L/min. After the sample was drawn, the impingers were washed with deionized water (DI H₂O) into a 500 mL volumetric flask. The total solution volume was then brought to 500 mL with DI H₂O. The solution was then analyzed for NH₃ with an ion selective electrode (ISE) by the following method. A 100 mL sample of the 500




Figure 3. Schematic of the two methods of N₂O sampling.




Figure 4. Ammonia sampling apparatus.

mL. NH_3 solution was transferred to a 125 mL Erlenmeyer flask. As a pH adjustor, 1 mL of 10 M NaOH solution was added. A stir bar was placed in the flask, and the solution was allowed to stir for about 1 min. The ISE was then immersed into the stirred flask solution where it began to equilibrate. A meter monitored NH_3 concentration as well as how quickly the reading changed. An indicator on the meter indicated when the concentration reading stabilized and the reading was recorded.

The ISE meter was calibrated with known standards before any NH_3 determination. The resulting calibration curve was checked against the known limits of the meter. In all instances during the program, calibration of the meter fell well within limits designated by the manufacturer. All NH_3 measurements were corrected for flue gas water by accounting for water from combustion and injection.

3.4 SOLID SAMPLING

Solid samples were collected with the apparatus shown in Figure 5. A solid sampling port at the bottom of the refractory-lined section of the furnace was uncovered and a water-cooled sampling probe was inserted into the furnace center. The probe opening (about 2.5 cm) faced up toward the downward flow of reacted solids. The reacted solids were aspirated into the probe isokinetically to not bias the collected particle size. The solids were drawn out of the probe through a heated sample line and captured on filter paper in an enclosed filtering unit. The resulting cleaned gas was then passed through ice-chilled impingers that cooled the gas to condense moisture. The dry gas passed through a gas meter that was monitored to maintain the correct sampling rate. After sufficient sample had been collected, the filter paper was removed from the unit and the sample volume carefully scraped from the paper.

Solid samples collected were tested for resistivity, a measure of the ability of the solid to be collected by an electrostatic precipitator. Some of these solid samples were analyzed by X-ray diffraction to identify reaction compounds. Diffraction analyses were run on a Siemens diffractometer with a copper $\text{K}\alpha$ target source running at 50 kV and 40 mA.




Figure 5. Solid sampling system.

3.5 SORBENT DELIVERY

Sorbent was injected into the furnace by two methods (see Figures 6 and 7). Dry sorbent (either $\text{Ca}(\text{OH})_2$ or CaCO_3) was loaded into a hopper mounted on a K-Tron loss-in-weight, twin-screw, dry materials feeder. The dry sorbent feeder is a totally enclosed and pressurized system. During runs, sorbent transport air was supplied to the feeder where it traveled into a delivery line to the water-cooled injection probe. Injection air flowed continuously during trials as part of the furnace air supply. When injection took place, the feeder screws were started and the sorbent was metered into the air stream. The feeder was calibrated gravimetrically before and after each run. All sorbent feeder settings were then determined for trial use.

Slurried sorbent was prepared by adding a predetermined amount of sorbent to DI H_2O in a mixing tank. A mixing motor provided power to an impeller to keep the sorbent in constant suspension. DI H_2O was metered into a spray nozzle by a peristaltic pump where it mixed with air. The water sprayed into the furnace was used to establish baseline conditions. During sorbent injection, a valve switched the pumped liquid from water to the slurry mix. After the injection, flow was switched back to water. NO_x OUT solution was metered into the slurry stream at the probe inlet; the flow was produced by a dual syringe pump. A typical slurry injection run involved establishing a baseline condition (with water injection), injecting slurry without NO_x OUT flow, adding NO_x OUT to the slurry flow, and finally returning to baseline water injection. In instances where NO_x OUT was injected without slurry, it was metered in with the water flow at the nozzle inlet.

Dry and slurry injection required two different types of injectors. The dry injection probe was constructed of three concentric stainless steel tubes. The interior tube forming the injection orifice is 0.64-cm x 0.089-cm wall thickness tubing and is protected from furnace heat by a water jacket formed by a 0.95-cm tube placed inside a 1.27-cm tube. This jacket enclosed the 0.64-cm delivery tube. The three are welded together and a cooling water inlet/outlet is provided. The three tubes are bent




Figure 6. Equipment schematic for dry injection.




Figure 7. Equipment schematic for slurried injection.

together in a smooth radius at a 90° angle so that placing them into the injection ports on the side of the furnace allows the orifice to point downward.

Slurry was injected into the furnace through an injection probe with a 3-mm orifice. The probe was commercially manufactured by Turbotak and is constructed of stainless steel in much the same way as the dry probe and is water-cooled. Three inlets at the supply end of the probe allow water (or slurry), air, and NO_xOUT to mix before being sprayed into the furnace. The probe is about 90 cm long and 3 cm in diameter with no bends. The orifice is drilled at 90° to the axis of the interior supply tube giving a downward spray.

Actual sorbent particle size was determined by using a Micromeritics Sedigraph Model 5100. For slurry injections, a Munhall particle size classifier determined spray droplet size produced by the spray nozzle. Water and air flows through the nozzle were set to actual run conditions. The spray produced was passed through a low-intensity laser beam produced by the Munhall device. The diffraction of the laser light by the spray stream was analyzed by computer software provided with the Munhall to determine an average spray particle size. In early classification of the nozzles, a wide range of air and water flows and pressures were examined. The flows that produced the most uniform tiny spray particles were chosen for actual injections.

3.6 TEMPERATURE PROFILES

Furnace temperature profiles were determined using a suction pyrometer. All injection conditions (coal or natural gas firing) were profiled. The applicable injection conditions were set up in the furnace for testing at a particular injection port. The suction pyrometry probe was inserted two or three ports below the injection port and allowed to equilibrate. During these tests, no sorbent was used, but the applicable injection air and water were fed through the nozzle. After equilibration, the reading was recorded and the pyrometry probe moved to the next higher port. Again, after equilibration, the reading was taken. The final reading was taken at the port just below the injection point. These data points allowed a temperature profile to be drawn for dry and wet injection during

coal or natural gas firing at any port. The resulting line allowed extrapolation over the distances between ports to arrive at the correct port temperature. A typical profile during natural gas burning is shown in Figure 8.


3.7 WASTE SOLID RESISTIVITY

As described in Section 3.4, collected solid samples were measured for resistivity by a procedure detailed in Reference 14. Adding calcium-based sorbent to typical coal fly ash changes the overall characteristics of the mixture, making measurement by standard methods impossible, therefore, a modified method was developed. Ca(OH)_2 contained in the sample decomposes at about 300 °C, accompanied by large changes in particle surface area. Older methods used for coal ash analysis were performed at temperatures in excess of 450 °C. The newer method employs temperatures less than 250 °C so as not to initiate a change in the Ca(OH)_2 present in the sample. In addition, older methods measure resistivity as a function of increasing sample temperature. The newer method begins at the higher temperature and records resistivity as temperature decreases. The resistivity measurements on solid samples collected during these trials were performed in a 5 percent humidity chamber.

3.8 TESTING AND CALCULATIONS

Data produced during trials were recorded on an "Innovative Furnace Data Log" form. All data collected during the trial program are included in Appendix A. Furnace set-up conditions and trial notes were written in the blanks provided at the top of the form. The data logged during the trial, including O_2 , CO_2 , CO, NO_x , and SO_2 concentrations, were written in the tabular matrix in the center of the page. This section also includes sorbent feed information. The bottom of the sheet also provides furnace set-up information such as air and gas flows. These data were used for material balance calculations.

The starting point for many of the calculations involved determining the total flue gas flow (Q). This value was required to calculate Ca/S ratios and was found by determining molar flows of




	DISTANCE BELOW BURNER (cm)	DRY INJECTION TEMPERATURE (°C)	SLURRY INJECTION TEMPERATURE (°C)
PORT 2R	43	1,311	1,170
PORT 3R	74	NM	1,137
PORT 3M	81	1,265	1,087
PORT 4U	104	1,209	997
PORT 4L	145	1,087	887
PORT 5	168	1,020	821
PORT 6	203	950	NM

Figure 8. Temperature profile of furnace during dry and slurry injection while firing natural gas (including tabulated temperature vs. injection location data).

NM = Not measured.

input air and natural gas from the known rotameter settings, then calculating the resultant flows of combustion products.

For natural gas burns, the combustion reaction can be considered as follows:



The furnace usually runs with roughly 20-25 percent excess air so the above reaction consumes 100 percent of the natural gas. Combustion air is dried ambient air assumed to be 21 percent O_2 and balance N_2 .

The molar flows (at STP) of the supplied air and natural gas were calculated from pressure and float heights from rotameters:

Let: P_x = pressure at rotameter x in bars
 H_x = observed flow on calibrated rotameter in standard L/min at 25 °C (1 bar)
 F_x = flow of supply air/gas in standard L/min at pressure P_x
 M_x = molar flow of gas/min

Then: $F_x = H_x * (1 + P_x)^{1/2}$
 $M_{\text{air}} = F_{\text{air}} * [1 \text{ mol}/24.1 \text{ L}]$
 $M_{\text{air total}} = M_{\text{axial air}} + M_{\text{tangential air}} + M_{\text{sorbent air}}$
 $M_{\text{N}_2} = 0.79 * M_{\text{air total}}$
 $M_{\text{O}_2} = 0.21 * M_{\text{air total}}$

Because methane is less dense than air, a correction factor must be introduced into the equation to convert methane volumetric flow to molar flow. This correction factor is the square root of the ratio of the densities (ρ) of CH_4 and air.

$$M_{\text{CH}_4} = F_{\text{CH}_4} \times [(\rho_{\text{air}}/\rho_{\text{CH}_4})]^{1/2} \times [1 \text{ mol}/24.1 \text{ L}]$$

One mole of CH_4 consumes 2 moles of O_2 and forms 3 moles of products.

Then: $M_{\text{O}_2, \text{excess}} = M_{\text{O}_2} - [2 * M_{\text{CH}_4}]$
 $M_{\text{CO}_2} = M_{\text{CH}_4}$
 $M_{\text{H}_2\text{O}} = [2 * M_{\text{CH}_4}] + M_{\text{slurry water}}$
 $Q = M_{\text{N}_2} + M_{\text{O}_2, \text{excess}} + M_{\text{H}_2\text{O}} + M_{\text{CO}_2}$ (in moles per min)

NOTE: molar slurry water flow is determined from flow information on the daily trial data log form.

The molar ratio of injected calcium to sulfur in SO₂ is calculated as follows:

Let: D = flow of dry sorbent in grams/min

[SO₂] = SO₂ concentration in furnace at baseline in ppm, wet basis

Then:

$$Ca/S = \frac{(D/MW_{sorbent})}{([SO_2] / 1,000,000) \times Q}$$

For coal burning conditions:

Let: F_{coal} = coal flow in grams/min

W_{sulfur} = fraction sulfur in coal (w/w)

MW_S = molecular weight of sulfur

Then: Ca/S =

$$Ca/S = \frac{(D/MW_{sorbent})}{(F_{coal} \times W_{sulfur})/MW_S}$$

In any instances where furnace concentrations of flue gas components are reported or used for calculations, they have been corrected to 0 percent excess O₂ to account for furnace inleakage and excess combustion air. This calculation is as follows:

Let: [X] = the actual furnace concentration of component X in ppm

[O₂] = the concentration of O₂ in the furnace in percent

Then: [X]_{0%O₂} = [X] * {21/(21 - [O₂])}

Removal percentage of SO₂ or NO_x during injections is calculated:

Let: [C]_{BL} = concentration of NO_x or SO₂ at baseline in ppm, wet basis

[C]_{test} = concentration of NO_x or SO₂ during injection in ppm, wet basis

Then: Removal percent = {1 - ([C]_{test}/[C]_{BL})} * 100

[C]_{BL} is the average of the component concentration before and after the injection, while

[C]_{test} is the concentration during the injection.

N/NO_x_i was calculated from NO_xOUT flow, composition, and baseline NO_x concentration:

Let: [NO_x]_{BL} = baseline NO_x concentration in ppm, wet basis

ρ = the NO_xOUT solution density

L = flow of NO_xOUT in mL/min

W_{urea} = fraction urea in solution (w/w)

MW_{urea} = molecular weight of urea

Then:

$$N/NO_{xi} = \frac{\left[\left((L \times \rho \times W_{urea}) / MW_{urea} \right) \times (2 \text{ mols N/mol urea}) \right]}{\left([NO_x]_{BL} / 1,000,000 \right) \times Q}$$

3.9 SLURRY INJECTION NOZZLE CHARACTERIZATION

Two slurry injection nozzles were acquired for use in the testing. One nozzle was purchased from Turbotak, Inc. (of Canada), and the other was acquired from Caldyn (of Germany). Before the nozzles were used in actual testing, a set of tests were devised to investigate the spray characteristics of each to determine the conditions that would produce the minimal spray droplet size.

Spray droplet size was determined with a particle size analyzer purchased from the Munhall Co. The analyzer (Model No. PSA-32) is of the forward diffraction, Fraunhofer-type. It measures the diffraction of laser light on a focusing lens which passes the diffracted light to a multi-ring photodiode detector. The detector then outputs the generated signals to a processor which provides a visual display of results.

Each nozzle was characterized with the air and liquid flows to be used during in-furnace operation. The spray droplet size and distribution was then measured in an out-of-furnace test. Because each nozzle was similar in design and construction, one nozzle was used to 'zero-in' on the specific optimal air and liquid flow settings. Once this step was completed, the other nozzle was set up identically and compared.

Variation of liquid flow rate was only slightly effective in reducing droplet size, while carrier air pressure (at constant mass flow) had a significant effect on droplet size. Optimal pressure was found to be about 4.8 bar at a volumetric air flow of about 1.18 standard L/s. Liquid flow rate was set at about 50 mL/min. The Turbotak, Inc. nozzle resulted in a droplet D_{50} of about 13 μm ($D_{90} = 88 \mu\text{m}$), while the Caldyn nozzle achieved a D_{50} of 10 μm ($D_{90} = 60 \mu\text{m}$). Although the Caldyn nozzle did provide superior atomization, it was not engineered with the correct cooling jacket,

therefore, the Turbotak, Inc. nozzle was chosen for the trial work. Data from characterizing the Turbotak nozzle are shown in Figures 9 and 10.

3.10 SORBENT TYPE

The sorbents used in the testing were from a single source; they were commercially prepared Ca(OH)_2 , CaCO_3 , and CaO from the Tenn Luttrell Company. The sorbents were provided in 20-L steel buckets. All sorbent containers were kept tightly sealed when not in use to prevent any moisture or CO_2 in the room air from contaminating the supplies. Particle size analyses were performed on the received sorbents; diameters (D_{50}) determined by sedimentation were $2.55\ \mu\text{m}$, $5.80\ \mu\text{m}$, and $12.5\ \mu\text{m}$ for the Ca(OH)_2 , CaO , and CaCO_3 , respectively.

3.11 AMMONIA SOLUTION INJECTION

To collect data for comparison with results from other researchers, NH_3 solution was injected at varying temperature and reductant/pollutant stoichiometry. This solution was prepared by diluting a given quantity of NH_4OH solution with DI H_2O . The resultant preparation was then injected into the furnace in a manner identical to the NO_x OUT injection.




Figure 9. Spray droplet size as a function of liquid flow.




Figure 10. Spray droplet size as a function of carrier gas pressure.

SECTION 4

QUALITY ASSURANCE

4.1 QUALITY ASSURANCE PROCEDURES

Data collected during all projects conducted on the IFR are subject to scrutiny under guidelines provided by a predetermined Quality Assurance (QA) Project Plan. The plan regulates furnace operation, data collection devices, and procedures. The major parameters measured in the furnace are coal feed rate, natural gas flow rate, combustion air flows, dry sorbent feed rate, slurry sorbent feed rate, urea feed rate, slurry composition, furnace temperature profile, and flue gas composition, namely, SO₂, NO/NO_x, CO, CO₂, and O₂. The data quality objectives for each of these parameters are shown in Table 1. If during any time, the data quality objectives of any measured parameter are not met, the Project Engineer and Acurex Environmental QA Officer confer to decide on a course of remedy. Combustion conditions are verified by comparing O₂ and CO₂ levels against theoretical values obtained from certified analysis of burned coal. Natural gas combustion conditions are verified by comparing calculations of theoretical O₂ and CO₂ present in the effluent based on the natural gas feed rate and combustion air flow.

As stated in Section 3.2, continuous emission monitors are zeroed (with zero-grade N₂) and spanned before and after each daily trial with gases of known concentration. Table 2 lists the calibration information applicable to the gas analyzers. The two analyzer response values are used to calculate a percent difference value. If this value exceeds 10 percent (the precision value given in Table 1) during any time, the device is checked for proper operation, and repaired if necessary.

TABLE 1. DATA QUALITY OBJECTIVES FOR MEASURED PARAMETERS

	MEASUREMENT METHOD	COMPLETENESS (%)	ACCURACY (%)	PRECISION (%)
GAS FEED RATE	ROTAMETER	90	± 10	± 10
COAL FEED RATE	GRAVIMETRICALLY	90	± 10	± 10
COMBUSTION AIR FLOWS	ROTAMETERS	90	± 10	± 10
SORBENT FEED RATE	GRAVIMETRICALLY	90	± 10	± 10
UREA FEED RATE	SYRINGE PUMP	90	± 10	± 10
SLURRY FEED RATE	VOLUMETRICALLY	90	± 10	± 10
SLURRY COMPOSITION	GRAVIMETRICALLY	90	± 10	± 10
TEMPERATURES	THERMOCOUPLES	90	± 10	± 10
SO ₂ CONCENTRATION	ULTRAVIOLET	90	± 10	± 10
NO/NO _x CONCENTRATION	CHEMILUMINESCENT	90	± 10	± 10
CO CONCENTRATION	INFRARED	90	± 10	± 10
CO ₂ CONCENTRATION	INFRARED	90	± 10	± 10
O ₂ CONCENTRATION	PARAMAGNETIC	90	± 10	± 10
PARTICULATE SAMPLING	PNEUMATIC EXTRACTIVE	90	NONE	NONE

(temperature units are °C)

TABLE 2. CALIBRATION PROCEDURES FOR PROCESS MEASUREMENT/FEED DEVICES

	PROCEDURE	MULTI-POINT CALIBRATION RANGES	REQUIRED EQUIPMENT AND REAGENTS	CALIBRATION FREQUENCY
SO ₂ ANALYZER (5000 ppm RANGE)	1. ZERO WITH N ₂ 2. MULTI(3) POINT WITH SO ₂	70-90% URL 40-60% URL 5-20% URL	CERTIFIED SO ₂ CYLINDER AND GAS DILUTION CHAMBER	SEMIANNUAL MULTI-POINT CALIBRATION. DAILY HIGH SPAN AND ZERO CHECK.
NO/NO _x ANALYZER (1000 ppm RANGE)	1. ZERO WITH N ₂ 2. MULTI(3) POINT WITH NO	70-90% URL 40-60% URL 5-20% URL	CERTIFIED NO CYLINDER AND GAS DILUTION CHAMBER	SEMIANNUAL MULTI-POINT CALIBRATION. DAILY HIGH SPAN AND ZERO CHECK.
CO ANALYZER	1. ZERO WITH N ₂ 2. MULTI(3) POINT WITH CO	70-90% URL 40-60% URL 5-20% URL	CERTIFIED CO CYLINDER AND GAS DILUTION CHAMBER	SEMIANNUAL MULTI-POINT CALIBRATION. DAILY HIGH SPAN AND ZERO CHECK.
CO ₂ ANALYZER	1. ZERO WITH N ₂ 2. MULTI(3) POINT WITH CO ₂	70-90% URL 40-60% URL 5-20% URL	CERTIFIED CO ₂ CYLINDER AND GAS DILUTION CHAMBER	SEMIANNUAL MULTI-POINT CALIBRATION. DAILY HIGH SPAN AND ZERO CHECK.
O ₂ ANALYZER	1. ZERO WITH N ₂ 2. MULTI(3) POINT WITH O ₂	70-90% URL 40-60% URL	CERTIFIED O ₂ CYLINDER AND GAS DILUTION CHAMBER	SEMIANNUAL MULTI-POINT CALIBRATION. DAILY HIGH SPAN AND ZERO CHECK.
ROTAMETERS	PERFORM MULTIPPOINT CALIBRATION WITH DRY GAS METER	80-100% FULL SCALE 50-70% FULL SCALE 10-30% FULL SCALE	DRY GAS METER, STOP WATCH, VACUUM PUMP	INITIALLY AND UPON REPAIR/REPLACEMENT
STRIP CHART RECORDER	CHECK STRIP CHART READING AGAINST INPUT VOLTAGES	80-100% FULL SCALE 50-70% FULL SCALE	CONSTANT VOLTAGE SOURCE AND DIGITAL VOLTMETER	ANNUALLY
COAL/SORBENT FEEDER	PERFORM MULTIPPOINT CALIBRATIONS	NORMAL OPERATING RANGES DURING TESTING	STOP WATCH, TARED BEAKER, SCALE	CHECK BEFORE AND AFTER RUNS
SLURRY/UREA FEEDER	SPECIFIC SETTINGS ARE CALIBRATED BEFORE EACH RUN		STOPWATCH, GRADUATED CYLINDER	DAILY, DURING RUNS

URL-upper range limit

4.2 QUALITY ASSURANCE AUDIT

A QA audit was initiated on December 4, 1991. Two gas cylinders were delivered to the testing area for analysis. The component concentration in the cylinders was unknown to operation personnel. Operation personnel were asked to analyze the contents of each cylinder and report the results. These results revealed that the analyzers audited fell well within the data quality objectives established. A memorandum describing the results of this audit, from the Project QA Officer, is provided in Appendix B.

SECTION 5

RESULTS AND DISCUSSION

5.1 GENERAL

All results from sorbent injection tests were developed into percent SO₂ removal vs. Ca/S ratio graphic relationships. Data collected during the trials were entered into a spreadsheet. The equations previously expressed in Section 3.8 of this report were used. Through a series of calculations, percent SO₂ removal, corresponding Ca/S ratio, percent NO_x removal, and N/NO_{x,i} were produced. A typical trial, encompassing a full work day, entailed injecting a sorbent (either dry or slurried) at constant temperature while varying Ca/S ratio. Duplicate data at each Ca/S ratio were collected. The resulting removal and stoichiometry values were then plotted. Percent removal was plotted on the y-axis, while Ca/S (or N/NO_{x,i}) was plotted along the x-axis. A third-order polynomial expression was curve fit through the plotted points. Lotus Freelance (the graphics software package used) yielded the equation of the curve which allowed determining removal at Ca/S of exactly 2. All subsequent expressions of SO₂ removals in this report are at a Ca/S value of 2. Data collected throughout the trial work are presented graphically in Appendix D.

5.2 SULFUR DIOXIDE TESTS

Initial tests compared the SO₂ removal of slurry against dry injection modes for Ca(OH)₂ and CaCO₃. Figure 11 shows the effect of varying injection temperature on the SO₂ removal by CaCO₃ at a Ca/S ratio of 2. The SO₂ removal during dry CaCO₃ injection was fairly independent of injection temperature, given the relative error in the plotted values (± 5 percent based on previously run replicate tests) and showed a maximum of about 42 percent. Slurry injection appeared to have relative




Figure 11. Effect of injection temperature on SO₂ removal in CaCO₃ tests
(Ca/S = 2, SO_{2i} = 2,500 ppm).

maxima in SO₂ removal, about 57 percent around 1,000 °C. Adding NO_xOUT A solution to the slurry water (replacing an equal volume of water) may have caused a slight increase in SO₂ capture, but insufficient runs were completed for statistical certainty. The same tests for dry injection of Ca(OH)₂ (Figure 12) indicate that SO₂ removal, with an apparent optimum injection temperature above 1,000 °C, was relatively independent of injection temperature. The slurry injection curve is similar to the dry sorbent injection curve except for a significant increase in SO₂ removal by slurry injection around 1,000 °C, where SO₂ capture increases to about 72 percent. Tests with urca (NO_xOUT A) added to the slurry water followed the temperature response of the sorbent-alone slurry, but indicated significantly higher SO₂ removal (about 10 percent, absolute), up to a maximum around 82 percent capture.

Limited tests were also done with commercially available Tenn Luttrell CaO (lime). In these tests, Ca(OH)₂ was tested against a CaO slaked with the slurry injection water before injection. The results (also shown on Figure 11 for a single injection temperature) indicate that injecting a CaO slaked under non-optimized hydration conditions yields equal SO₂ capture to the Ca(OH)₂. Similarly, injecting the slaked CaO slurry with NO_xOUT A solution resulted in equivalent capture to the Ca(OH)₂ with NO_xOUT A, about 82 percent at Ca/S = 2.

5.2.1 Comparison

The SO₂ removals reported in Figure 11 for dry CaCO₃ particles are equivalent to previous results (about 40 percent) for testing in this furnace and others^{15,16}. The SO₂ removal results for dry Ca(OH)₂ sorbent injection, about 60 percent, are also similar to earlier testing in this reactor and numerous tests by others^{15,17,18}. While comparing results between dissimilar furnaces, fuels, initial SO₂ concentrations (SO_{2i}), and sorbents is difficult, the results for CaCO₃ slurry injection (about 42 percent at Ca/S = 2) are consistent with results from Reference 19 of 40-55 percent at Ca/S = 2 and four different coal/sorbent combinations. Later work indicates SO₂ removals with a Ca(OH)₂ slurry (Ca/S = 2) of 78 percent, comparable to our peak value of = 72 percent¹⁰.




Figure 12. Effect of injection temperature on SO₂ removal in Ca(OH)₂ and CaO tests (Ca/S = 2, SO_{2i} = 2,500 ppm).

5.2.2 Temperature

The results for both dry and slurry $\text{Ca}(\text{OH})_2$ injection (Figure 12) are similar to those found for dry and slurry CaCO_3 injection in that, with some exceptions, they are relatively insensitive to temperature. While greater sensitivity to injection temperature for dry sorbent injection may be observed in other facilities, this phenomenon is a strong function of reactor quench rate.^{16,18} The temperature response profile of SO_2 capture becomes flatter for lower quench rates. The IFR has a fairly moderate quench rate of about 250 °C/s. Results from a pilot facility operating at a quench rate of 500 °C/s did show greater temperature sensitivity of SO_2 capture with slurry injection¹⁶. As expected with this higher quench rate, the optimum slurry injection temperature (about 1,200 °C) was determined to be about 200 °C higher than in our work (about 1,000 °C).

5.2.3 Dry Versus Slurry Injection

The equal or greater capture by CaCO_3 slurry versus dry injection has been attributed to particle fragmentation or delayed sintering²⁰.

The levels of SO_2 removal, approximately 60 percent (excluding the urea addition results), are typical for dry $\text{Ca}(\text{OH})_2$ sorbents, while the range of data on our tests is insufficient to be conclusive. Significantly greater SO_2 removals (about 10 percent, absolute) with slurry versus dry injection result at one temperature (1,000 °C). Unfortunately, further definition of this temperature peak was impossible because of injection port limitations. The mechanism for this enhanced removal during slurry (vs. dry) injection remains speculative.

5.2.4 Effect of NO_x OUT A

Tests with NO_x OUT A added to the $\text{Ca}(\text{OH})_2$ slurry showed significant improvement over the slurry alone or dry tests. Improvements in SO_2 capture of about 10 percent absolute occur at 880-1,170 °C. This phenomenon was also observed when testing a hydrated lime/urea mixture and comparing it with the hydrated lime alone³. The researchers speculated that the enhancement was either caused by increases in sorbent surface area and porosity from urea decomposition in the sorbent

crystal structure or by reactions between SO_2 and urea decomposition products in the sampling system. Work by others has shown that SO_2 capture is possible with NH_3 alone²¹. It is possible that the NH_3 slip created by urea decomposition may be directly removing SO_2 as well. Our results suggest that the mechanism for enhancing the sorbent's ability to capture SO_2 is probably the reaction of the sorbent and urea-based compound with SO_2 . X-ray diffraction results from IFR solid sampling during NO_x OUT A injection indicate, along with the expected CaSO_4 , the significant presence of $(\text{NH}_4)_2\text{Ca}(\text{SO}_4)_2 \cdot \text{H}_2\text{O}$ (koktaite). Clearly, at these high temperatures, CaO , SO_2 , and the urea breakdown product (NH_3) may react together to increase SO_2 removals beyond that expected simply from the presence of CaO [from $\text{Ca}(\text{OH})_2$ or CaCO_3] alone.

5.2.5 $\text{Ca}(\text{OH})_2$ vs. Slaked CaO

The inability to distinguish between the SO_2 reactivity of the slurries from commercially available $\text{Ca}(\text{OH})_2$ vs. laboratory-slaked CaO suggests the simplicity of the hydration process towards producing reactive sorbents. Purchase costs of hydration and transportation of the added weight of H_2O in $\text{Ca}(\text{OH})_2$ to the site can be avoided if CaO is mixed at the boiler site. While improved methods of CaO slaking are likely to increase the sorbent reactivity, our rudimentary methods of sorbent slaking were sufficient to match the results of manufacturer-supplied $\text{Ca}(\text{OH})_2$.

5.2.6 Particle Size Effects

Tests varying the particle size of CaCO_3 sorbent were conducted for dry, slurry, and slurry with NO_x OUT A injection conditions. Results at the optimum injection temperature for SO_2 removal at a Ca/S ratio of 2/1 are compared against the $\text{Ca}(\text{OH})_2$ results (Figure 13). Smaller particles generally remove more SO_2 , whether they are CaCO_3 or $\text{Ca}(\text{OH})_2$. The enhancement of dry sorbent SO_2 capture by either slurry injection or NO_x OUT A addition is probably maintained independent of particle size. Equivalently sized CaCO_3 was indistinguishable in removal efficiency to $\text{Ca}(\text{OH})_2$. For slurry injection, however, $\text{Ca}(\text{OH})_2$ is clearly superior in removal efficiency.




Figure 13. Effect of sorbent particle size on SO₂ removal.

5.3 NITROGEN OXIDE TESTS

Tests were conducted over a range of temperatures to measure the temperature sensitivity of both NO_xOUT A and NO_xOUT A+ reducing agents. Tests varied from about 821 to 1,170 °C with a N/NO_{xi} of about 1.5 (note that urea breaks down into 2 moles of reducing agent nitrogen per mole of urea). The results of testing with NO_xOUT A, encompassing NO_x, NH₃, N₂O, and CO emissions, are shown in Figure 14.

For reference, SO₂ removal results from slurry injection are superimposed on this figure, although these results were not obtained simultaneously. (Other results showed that the effect of concurrent sorbent injection upon NO_x removal is unnoticeable; tests with and without sorbent in the slurry did not prove to affect NO_x removals.) For NO_xOUT A, a peak NO_x reduction of 82 percent was achieved at the optimum temperature of about 1,100 °C, while NO_x reductions greater than 60 percent were obtained at injection temperatures of 950 to 1,140 °C.

In comparison to these results, Figure 15 shows the results of NO_xOUT A+. The maximum NO_x reduction was 80 percent at the optimum injection temperature of around 1,100 °C and an N/NO_{xi} of about 1.5. NO_x removals of greater than 60 percent were achieved at injection temperatures ranging from 887 to 1,137 °C.

The effect of N/NO_{xi} upon NO_x removal for NO_xOUT A and NO_xOUT A+ is shown in Figures 16 and 17, respectively. NO_x removal increases with N/NO_{xi} until around an N/NO_{xi} of 2.0, where the NO_x removal starts to level off. Figures 16 and 17 show inflections in the curves at around an N/NO_{xi} = 1.5, caused by including data from Figures 14 and 15. The data used to produce Figures 14 and 15 were collected during a different trial run day than those for Figures 16 and 17. Furnace temperatures vary slightly from day to day causing slight differences in the removal results.

5.3.1 N₂O

N₂O emission levels (Figure 14) for NO_xOUT A generally appear to follow NO_x removal levels; peak N₂O emission (200 ppm) occurs at a slightly higher temperature (1,137°C) than peak NO_x




Figure 14. Effect of injection temperature on emissions using NO_xOUT A (N/NO_{xi} = 1.5, NO_{xi} = 600 ppm).




Figure 15. Effect of injection temperature on emissions using NO_xOUT A+ (N/NO_{xi} = 1.5, NO_{xi} = 600 ppm).




Figure 16. Effect of N/NO_{xi} on emissions using NO_x OUT A (injection temperature = 1,087 °C. NO_{xi} = 600 ppm).




Figure 17. Effect of N/NO_{xi} on emissions using NO_x OUT A+ (injection temperature = 1,087 °C. NO_{xi} = 600 ppm).

removal (1,100 °C). Peak N₂O emissions using NO_xOUT A+ (Figure 15) appear to occur about 50 °C higher than the optimum injection temperature for NO_x removal. For both urea solutions, N₂O emissions follow a similar temperature response, although levels for the latter (peak value of 36 ppm) are consistently about one-fourth of the former.

For tests conducted near the optimum injection temperature for NO_x removal (1,087 °C), increasing N/NO_{xi} values results in greater N₂O emissions for both urea solutions (Figures 16 and 17, respectively). N₂O concentration ranges from 70-220 ppm for an N/NO_{xi} of 0.8-3.5, respectively, for NO_xOUT A. NO_xOUT A+ appears to be less sensitive to N/NO_{xi} increases, ranging from 25 to 115 ppm for N/NO_{xi} values of 0.8-3.5. For both urea-based chemicals, N₂O emissions are only slightly affected by changing N/NO_{xi} values between 1.5 and 3.5.

Injection of NO_xOUT A at near optimum temperature (1,087 °C) with Ca(OH)₂ slurry at varying Ca/S ratio resulted in N₂O production of 66 ppm, 51 ppm, and 64 ppm at Ca/S about 3, 2, and 1, respectively. N/NO_{xi} was held constant at about 1.5 for this testing. Correspondingly, injection of NO_xOUT A+ yielded N₂O emissions of 35 ppm, 27 ppm, and 33 ppm at Ca/S about 3, 2, and 1. These results (not shown in a figure), when compared with Figures 16 and 17, suggest that the presence of sorbent addition may aid reduction in N₂O levels. This possibility has not been verified.

5.3.2 NH₃

NH₃ concentrations for NO_xOUT A injection (Figure 14) reach a maximum of 140 ppm at 821 °C. Increases in injection temperature show declining concentrations of NH₃ slip. Peak NH₃ levels of 135 ppm for NO_xOUT A+ (Figure 15) at 821 °C are reduced below 5 ppm at injection temperatures of 887 °C and higher.

Changes in N/NO_{xi} values affect NH₃ emissions, as seen in Figures 16 and 17. Increases in N/NO_{xi} for both urea-based solutions result in higher levels of NH₃. Unlike N₂O, NH₃ levels with NO_xOUT A and A+ are a stronger function of N/NO_{xi} changes from 1.5 to 3.5.

Coupling the reducing agent injection (at N/NO_{xi} about 1.5) with $Ca(OH)_2$ slurry near optimum injection temperature (1,087 °C) produces NH_3 slip of less than 35 ppm at Ca/S between 0.8 and 2.0 for NO_x OUT A (results not shown). Slip was somewhat less for NO_x OUT A+. A maximum of 12 ppm was observed at Ca/S between 0.8 and 2.0. The reduction in NH_3 slip during sorbent/urea co-injection could be attributed to NH_3 combining with Ca and SO_2 to form $(NH_4)_2Ca(SO_4)_2 \cdot H_2O$ as previously mentioned.

5.3.3 Comparison

IFR test results (Figure 16) show NO_x removals with NO_x OUT A at 1,087 °C and varying N/NO_{xi} that are similar to those demonstrated in Reference 10. While less similar results have been reported by References 8 and 9 with urea injection, direct comparison is made tenuous by experimental differences in reducing agent phase (solid urea) and NO_{xi} value (250 ppm), respectively.

Tests with NH_3 solution injection were conducted to obtain data to compare others' results to assess any reactor-specific trends and validate the findings of this work, particularly in reference to N_2O and NH_3 emissions.

The NO_x removal results of NH_3 solution injection at N/NO_{xi} of 1.3 are shown in Figure 18, indicating that NO_x removal exceeds 50 percent over a fairly broad temperature range, 887-1,140 °C. These findings are fairly consistent with NO_x removal results of Reference 8 at an N/NO_{xi} of 2, given the differences in operating conditions. The NO_x removal response to varying the N/NO_{xi} of the NH_3 solution is shown in Figure 19, compared with References 4 and 8.

The NH_3 slip and N_2O emissions during injection of NH_3 water at N/NO_{xi} of 1.3 is shown in Figure 20. The decline of NH_3 slip at 827 °C is unexpected, yet was confirmed by repeated testing. Figure 21 shows the effect of N/NO_{xi} on NH_3 slip and N_2O emissions.

CO emissions reported in Figures 14-17 are included to show the effect of injection temperature and N/NO_{xi} . These emission levels, generally 40 ppm or less, are similar to those of




Figure 18. Effect of injection temperature on NO_x removal using NH₃ solution (N/NO_{xi} = 1.3) compared with Reference 8 (N/NO_{xi} = 2).




Figure 19. Effect of NO/NO_{xi} on NO_x removal using NH₃ solution (NO_{xi} = 600 ppm) compared with Reference 8 (NO_{xi} = 700 ppm) and Reference 4 (NO_{xi} = 619 ppm).




Figure 20. Effect of injection temperature on emissions using NH₃ water (N/NO_{xi} = 1.3, NO_{xi} = 600 ppm).




Figure 21. Effect of N/NO_{xi} on emissions using NH₃ water (injection temperature 997 °C, NO_{xi} = 600 ppm).

Reference 9. A significant increase in CO emissions at lower injection temperatures is not observed, perhaps because our injection range did not extend sufficiently low⁹.

The trends seen in the NH₃ solution injection results indicate that reactor-specific differences in removing NO_x under similar testing conditions between these three laboratories are not substantial and that results obtained in our research may apply equally well to others' reactors.

Values of N₂O production as a function of NO_x reduction (plotted as $\Delta N_2O/\Delta NO_x$ in Figure 22) for NO_xOUT A+ were almost exclusively less than those of References 8 and 22 with pure urea. Work reported in Reference 8 was done on a pilot-scale, natural gas-fired combustor (described in Reference 9), doped with NH₃ to produce NO_x, and Reference 22 used a pilot-scale 2 MW (t) coal-fired circulating fluidized bed. This suggests that technical improvements to the pure urea solution, represented NO_xOUT A+ formulations, can affect N₂O emissions in SNCR processes.

Levels of NH₃ emissions for both urea-based solutions show trends of reduction with increases in temperature, consistent with results of others⁹. Figure 23 compares the NH₃ slip emissions during injection of both urea solutions with those from Reference 9. NH₃ slip values in our work are significantly less throughout the full temperature range. This may be caused by subtle differences in the experimental combustors combined with the increased reactivity of the enhanced urea formulation at lower temperatures. Use of NO_xOUT A+ vs. NO_xOUT A solution in this work improved the NO_x removal values at lower temperatures. This result raises the possibility of staged injection of these chemicals at low and high temperatures, respectively. This result also has the additional benefit of reducing the local "load" of the nitrogen-reducing agent injected into the flue gases, and thereby possibly minimizing potential NH₃ slip problems.

5.4 COAL TESTS

Very limited testing was completed under actual coal-burning conditions. Pittsburgh #8 coal (2.6 weight percent sulfur) was burned in the IFR, and the resulting combustion products treated with Ca(OH)₂ slurry, NO_xOUT A and NO_xOUT A+. Injections were made at 1,151 °C and 1,041 °C.




Figure 22. Effect of injection temperature on $\Delta N_2O/\Delta NO_x$.




Figure 23. Effect of injection temperature on NH₃ emissions at N/NO_x_i = 1.5 compared with Reference 9.

Injection of the slurry and NO_xOUT A at 1,151 °C gave 69 percent SO₂ removal, and 36 percent NO_x removal at stoichiometries of 4.5 and 2.6, respectively. At the lower injection temperature, the NO_xOUT A slurry improved to 86 percent SO₂ capture at Ca/S = 3.3. NO_x removal declined, however, to 19 percent at N/NO_{xi} = 2.4.

The NO_xOUT A+ slurry achieved 70 percent and 60 percent SO₂ and NO_x removal, respectively, at Ca/S = 4.5 and N/NO_{xi} = 1.6 at 1,151 °C. Injection at 1,041 °C resulted in SO₂ removal identical to the NO_xOUT A slurry at this temperature. NO_x removal was 21 percent at a lower N/NO_{xi} of 1.5.

NH₃ slip was about 19 and 10 ppm for NO_xOUT A and NO_xOUT A+, respectively, at the higher injection temperature (1,151 °C). Slip sharply increased to well above 110 ppm for both reducing agents at 1,041 °C.

N₂O production by each reducing agent was greater at 1,151 °C; NO_xOUT A generated 65 ppm N₂O while NO_xOUT A+ yielded 58 ppm. At 1,041 °C, NO_xOUT A and NO_xOUT A+ generated 43 and 18 ppm N₂O, respectively.

CO emissions during this limited testing were very high (300 ppm). The change in CO emissions during urea injection was indistinguishable because of these unusually high baseline levels. These high levels of CO are not generally experienced during coal burns on this reactor. It is believed that the burn conditions set up produced a nonrepresentative combustion effluent. This effluent could have adversely affected the obtained results; the results are certainly not consistent with those obtained during natural gas testing. Additional testing with coal could provide more information on this anomaly.

5.5 RESISTIVITY RESULTS

Four solid samples were collected for resistivity measurement. These samples were collected during injection when burning Pittsburgh #8 coal. Samples during dry injection of Ca(OH)₂, slurry injection of Ca(OH)₂, slurry/NO_xOUT A injection, and coal alone were obtained. Resistivity for the

coal alone sample could not be measured by the method employed.¹⁴ Facilities were not available to determine resistivity of coal-only fly ash by common methods. The resistivity for the sample collected during dry sorbent injection was about 7.5×10^{13} ohm-cm. During slurry injection the resistivity increased to about 9.1×10^{13} ohm-cm. A further increase to 2.0×10^{14} ohm-cm was realized during slurry/NO_xOUT A injection. The resultant curves generated during resistivity determinations are given in Appendix C.

Electrostatic precipitator (ESP) performance can be profoundly affected by changes in fly ash resistivity. Preferential ESP operating conditions require coal fly ash resistivity to be no more than about 10^{10} ohm-cm. Adding reacted sorbent material to the fly ash mixture causes changes in the chemical properties of the ash; the resulting resistivity is usually somewhat greater than 10^{10} ohm-cm. The results obtained from this work indicate that adding sorbent and urea to the coal fly ash causes significant increase in ash resistivity. These increases substantially exceed a level giving acceptable ESP performance.²³ High values of ash resistivity are known to cause a decrease in the current density of the particulate matter charging field which results in the degradation of ESP performance. This reduction in current density will cause sparking, or the formation of a stable back-corona.

Laboratory measurements of resistivity typically range as much as 2-3 orders of magnitude higher than field values obtained for the same material. Furthermore, the modifications made to the measurement method, because of the presence of calcium sorbents also probably resulted in higher values for resistivity. Whether or not sorbent/reducing agent injection will adversely impact particle collection has not been effectively evaluated. Flue gas conditioning methods such as the addition of humidity or sulfur trioxide may also be used to lower ash resistivity.

SECTION 6

CONCLUSIONS AND RECOMMENDATIONS

This work has demonstrated successful pilot-scale coupling of calcium-based sorbent injection with SNCR technologies in a slurry injection process. SO₂ and NO_x removals of about 60-80 percent at Ca/S = 2 and an N/NO_{xi} = 1.5, respectively, have been consistently observed.

SO₂ emission control is enhanced by combining the technologies. Identification of NH₄/Ca/SO₄ compounds suggests that the urea-based solutions react with Ca and SO₂ to effect additional SO₂ removal. Some evidence exists for the enhancement of SO₂ capture during slurry vs. dry injection of sorbents, albeit over a narrow temperature range.

NO_x removals of 60-80 percent at N/NO_{xi} = 1.5 were typically observed. NO_x removals greater than 60 percent were observed over a broad temperature range: 950-1,150 °C for NO_xOUT A, and 850-1,150 °C for NO_xOUT A+.

Comparative levels of NH₃ and N₂O are significantly reduced below levels previously reported for urea injection by using modified urea-based solutions. Near the peak NO_x removal levels (80 percent) for NO_xOUT A+ solution (NO_{x,init} = 600 ppm, N/NO_{xi} = 1.5), emission levels of NH₃ and N₂O were below 18 and 30 ppm, respectively.

The synergistic effect urea has shown on sorbent SO₂ capture ability has not been fully explained. This work identified the presence of (NH₄)₂Ca(SO₄)₂ • H₂O in reacted solids. However, the formation mechanism of this compound is unknown, as is its effect upon properties of the ash/sorbent waste.

Adding lime and urea causes chemical changes to the fly ash/sorbent mixture producing ash resistivities in excess 10^{13} ohm-cm. While resistivity values exceeding 10^{10} have been known to cause degradation in ESP performance, derivation of accurate values from laboratory-scale equipment at ambient temperature (especially in the presence of calcium sorbents) is considerably suspect.

No effort was made to further characterize urea/slurry injection in coal-fired systems; only limited information was obtained in this effort. The results were not comparable to those obtained during natural gas firing.

The process may also be broadened in its applicability to a wider market by considering options for dealing with additional pollutants (e.g., HCl and mercury) and improving emission removal performance. The latter suggestion may be accomplished by process alternatives such as staged reducing agent injection, sorbent enhancement, or a combination of technologies (e.g., SCR, sorbent recycle, multiple sorbent injections).

REFERENCES

1. Nolan, P. S., T. J. Purdon, M.E. Peruski, M. T. Santucci, M. J. DePero, R. V. Hendriks, and D. G. Lachapelle, "Results of the EPA LIMB Demonstration at Edgewater." In: Proceedings: 1990 SO₂ Control Symposium, Vol. 1, U.S. EPA, EPA-600/9-91-015a (NTIS PB91-197210), 3A-83 to -102, May 1991.
2. Hofmann, J. E., J. von Bergmann, D. Bökenbrink, and K. Hein. "NO_x Control in a Brown Coal-Fired Utility Boiler." In Proceedings: 1989 Joint Symposium on Stationary Combustion NO_x Control, Vol. 2, U.S. EPA, EPA-600/9-89-062b (NTIS PB89-220537), 7A-53 to -66, June 1989.
3. Muzio, L. J., R. M. Himes, and R. E. Thompson, Simultaneous NO_x/SO₂ Removal by the Dry Injection of Lime-Urea/Hydrate. U.S. Department of Energy DOE/PC/88860-T1 (DE90009566), March 1990.
4. Mangal, R., M. Mozes, R. Gaikwad, R. Thampi, and D. MacDonald. "Additive Injection for NO_x Control." In proceedings: 1989 Intern. Symp. on Combustion in Industrial Furnaces and Boilers, sponsored by the American Flame Research Committee, Short Hills, NJ, September 1989.
5. Crutzen, P. J. and C. J. Howard, "The Effect of the HO₂ + NO Reaction Rate Constant on the One Dimensional Model Calculations of Stratospheric Ozone Perturbations," Pure and Applied Geophysics, **116**, 497-510 (1978).
6. Kramlich, J. C., R. K. Lyon, and W. S. Lanier, EPA/NOAA/NASA/USDA N₂O Workshop, Volume I: Measurement Studies and Combustion Sources, U.S. EPA, EPA-600/8-88-079 (NTIS PB88-214911), May 1988.
7. Epperly, W. R. and J. E. Hofmann, "Control of Ammonia and Carbon Monoxide Emissions in SNCR Technologies," In Proceedings: AIChE Summer National Meeting, AIChE, Philadelphia, PA, August 1989.
8. Muzio, L. J., T. A. Montgomery, G. C. Quartucy, J. A. Cole, and J. C. Kramlich. "N₂O Formation in Selective Non-catalytic NO_x Reduction Processes." Presented at: 1991 Joint EPA/EPRI Symposium on Stationary Combustion NO_x Control, Washington, DC, March 25-28, 1991.

9. Teixeira, D. P., L. J. Muzio, T. A. Montgomery, G. C. Quartucy, and T. D. Martz. "Widening the Urea Temperature Window." Presented at: 1991 Joint EPA/EPRI Symposium on Stationary Combustion NO_x Control, Washington, DC, March 25-28, 1991.
10. Mangal, R., M. S. Mozes, P. L. Feldman, and K. S. Kumar. "Ontario Hydro's Sonox Process for Controlling Acid Gas Emissions." Presented at: 1991 Joint EPA/EPRI Symposium on Stationary Combustion NO_x Control, Washington, DC, March 25-28, 1991.
11. Ford, J. S. Recommended Operating Procedure No. 45: Analysis of Nitrous Oxide from Combustion Sources. U.S. EPA, EPA-600/8-90-053 (NTIS PB90-238502), June 1990.
12. Briden, F. E., D. F. Natschke, and R. B. Snoddy. "The Practical Application of Tunable Diode Laser Infrared Spectroscopy to the Monitoring of Nitrous Oxide and Other Combustion Process Stream Gases." Presented at: 1991 Joint EPA/EPRI Symposium on Stationary Combustion NO_x Control, Washington, DC, March 25-28, 1991.
13. Montgomery, R. A., G. S. Samuelsen, and L. J. Muzio. "Continuous Infrared Analysis of N₂O in Combustion Products." JAPCA, **39**, 721-726 (1989).
14. Young, R. P. Measurement and Prediction of the Resistivity of Ash/Sorbent Mixtures Produced by Sulfur Oxide Control Processes. U.S. EPA, EPA-600/7-91-009 (NTIS PB92-126812), December 1991.
15. Snow, G. C. and J. M. Lorrain. Evaluation of Innovative Combustion Technology for Simultaneous Control of SO_x and NO_x. U.S. EPA, EPA-600/2-87-032 (NTIS PB87-188926), April 1987.
16. Newton, G. H., D. K. Moyeda, G. Kindt, J. M. McCarthy, S. L. Chen, J. A. Cole, and J. C. Kramlich. Fundamental Studies of Dry Injection of Calcium-Based Sorbents for SO₂ Control in Utility Boilers. U.S. EPA, EPA-600/2-88-069 (NTIS PB89-134142), December 1988.
17. Gullett, B. K. and F. E. Briden. Furnace Sorbent Reactivity Testing for Control of SO₂ Emissions from Illinois Coals. U.S. EPA, EPA-600/2-89-065 (NTIS PB90-150830), December 1989.
18. Overmoe, B. J., J. M. McCarthy, S. L. Chen, W. R. Seeker, and D. W. Pershing. Reactivity Study of SO₂ Control with Atmospheric and Pressure Hydrated Sorbents. U.S. EPA, EPA-600/7-86-040 (NTIS PB87-129250), November 1986.
19. Mangal, R., M. Mozes, R. Thampi, and D. MacDonald. "In-Furnace Sorbent Slurry Injection for SO₂ Control." In Proceedings: Sixth Annual Int. Pittsburgh Coal Conference. Univ. of Pittsburgh, School of Engineering, Pittsburgh, PA, September 25-29, 1989.
20. Torbov, T. L., G. R. Offen, and S. K. Demike. Method for Reduction of Sulfur Products in the Exhaust Gases of a Combustion Chamber. U.S. Patent Number 4,555,996, issued Dec. 3, 1985.

21. Pakrasii. A., W.T. Davis. G.D. Reed, and T.C. Keener. "A Combined $\text{Ca}(\text{OH})_2/\text{NH}_3$ Flue Gas Desulfurization Process for High Sulfur Coal: Results of a Pilot Plant Study." JAWMA, **40**, 987-992 (1990)
22. Hulgaard, T. Nitrous Oxide Emissions from Danish Power Plants. CIEC Report No. 9002, Department of Chemical Engineering, Technical University of Denmark, DK-2800 Lyngby, Denmark, February 1990.
23. McDonald, J.R. and A.H. Dean 1982. Electrostatic Precipitator Manual, pp. 215-219. Noyes Data Corporation, Park Ridge, NJ.

APPENDIX A
INNOVATIVE FURNACE DATA LOG SHEETS

Innovative Furnace Data Log

Date: 12/3/90

Initials: PLG + CBC

Test: # N1

NH₃ Rotameter:

Setting (BB height): 30

Fuel: ~~CH₄~~ CH₄

Slurry: water

% Excess Air (measured):

Injection Port: 2nd RT

SO₂ Rotameter

Setting (BB height):

Draft (inches of Water): 0.3

Starting Temperature: 2077 °F
(thermocouple across from injection point)

Ending Temperature: 1953 °F

	Stage Air (float height)	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	7.475	2.6	14	399	---	47.2	
NSR 1	1.03 @ 70	7.625	7.4	15	400	1.32	47.2	
BL	1.03 @ 70	7.65	7.4	15	399	---	47.2	
NSR 2	1.03 @ 70	7.55	7.46	22	370	1.32	47.2	
BL	1.03 @ 70	7.65	7.44	15	400	---	47.2	
NSR 1	1.03 @ 70	7.5	7.4	12	397	1.32	47.2	
BL	1.03 @ 70	7.625	7.44	18	398	---	47.2	47.75
BL	1.03 @ 70	7.625	7.38	15	400	---	46.5	
NSR 2	1.03 @ 70	7.5	7.5	17	293	2.70	46.5	
BL	1.03 @ 70	7.7	7.4	16	400	---	46.5	
NSR 2	1.03 @ 70	7.5	7.5	18	288	2.70	46.5	
BL	1.03 @ 70	7.7	7.4	15	400	---	46.5	46.2
BL	1.03 @ 70	7.775	7.3	15	398	---	45.7	
NSR 3	"	7.5	7.5	30	211	4.02	45.7	
BL	"	7.975	7.24	25	394	---	45.7	
NSR 3	"	7.7	7.4	28	168	4.02	45.7	
BL	"	7.95	7.26	23	390	---	45.7	45.7

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air
Start	4.551 @ 45 PSI	@ 45 PSI	.82 @ 2	N/A
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	N/A

Innovative Furnace Data Log

Date: 12/14/70

Initials PWG + EBC

Test: #112

NH₃ Rotameter
 Setting (BB height): 38.5
 Fuel: Natural Gas
 Slurry: Water
 % Excess Air (measured): 53.5

SO₂ Rotameter
 Setting (BB height): 0
 Draft (inches of water): 0.2
 Injection Port: 3rd Row 4

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	7.875	7.35	14	380	0	0	47.2	
NSR1	1.03 @ 70	7.06	7.8	14	225	0	1.34 0 EBC	47.2	
BL	1.03 @ 70	7.19	7.8	10	340	0	0	47.2	
NSR1	1.03 @ 70	7.19	7.86	14	215	0	1.34	47.2	
BL	1.03 @ 70	7.25	7.8	10	331	0	—	47.2	47.9
	@								
BL	1.03 @ 70	7.375	7.6	10	338	0	—	46.4	
NSR2	1.03 @ 70	7.05	7.9	18	108	0	2.68	46.4	
BL	1.03 @ 70	7.3	7.7	9	337	0	—	46.4	
NSR2*	1.03 @ 70	7.06	7.9	17.5	75	0	2.68	46.4	
BL	1.03 @ 70	7.25	7.5	13	335	0	—	46.4	46.2
	@								
BL**	1.03 @ 70	7.45	7.7	14	338	0	4.02 ⁰	45.6	
NSR3	1.03 @ 70	7.0	7.9	20	45	0	4.02	45.6	
BL	1.03 @ 70	7.325	7.74	7	340	0	0	45.6	
NSR3	1.03 @ 70	7.0	7.9	20	40	0	4.02	45.6	
BL	1.03 @ 70	7.325	7.66	7	342	0	—	45.6	45.8
	1.03 @ 70								

Furnace

Temperature at ~~0~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2082	2137	1888
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2074	2071	1792

* Note: NH₃ BL setting = 36.5 A-3

Innovative Furnace Data Log

Date: 12/5/90
 Initials: PBC
 Test: N3

NH₃ Rotameter
 Setting (BB height): 103.5
 Fuel: methanol gas
 Slurry: H₂O
 % Excess Air (measured): _____

SO₂ Rotameter
 Setting (BB height): N/A
 Draft (inches of water): 0.3
 Injection Port: 3M middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	7.675	7.4	7	383	0	—	47.1	
NSR1	1.03 @ 70	7.625	7.46	10	200	0	1.34	47.1	
BL	1.03 @ 70	7.725	7.4	6	381	0	—	47.1	
NSR1	1.03 @ 70	7.625	7.5	7.5	185	0	1.34	47.1	
BL	1.03 @ 70	7.225	5	7.49	375		—	47.1	49.0
	@								
BL	1.03 @ 70	7.875	5	7.4	375	0	—	46.3	
NSR2	1.03 @ 70	7.625	7.52	20	80	0	2.66	46.3	
BL	1.03 @ 70	7.8	7.4	12	378	0	—	46.3	
NSR2	1.03 @ 70	7.55	7.52	20	73	0	2.66	46.3	
BL	1.03 @ 70	7.8	7.36	2	379	0	—	46.3	45.7
	@								
BL	1.03 @ 70	7.825	7.36	3	375	0	—	45.7	
NSR3	1.03 @ 70	7.475	7.54	15	38	0	4.02	45.7	
BL	1.03 @ 70	7.95	7.4	4	373	0	—	45.7	
NSR3	1.03 @ 70	7.5	7.6	21	28	0	4.02	45.7	
* BL	1.03 @ 70	7.75	7.42	5	360	0	—	45.7	45.9
	@								

Furnace Section
 Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2138	2199	1952
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2110	2111	1842

* NO Level Dropped Due to NH₃ Drop from 103.5 BB to 100.5 BBs

Innovative Furnace Data Log

Date: 12/5/90
 Initials: EBE TPWG
 Test: *N₄

NH₃ Rotameter
 Setting (BB height): 110 III
 Fuel: NATURAL GAS
 Slurry: H₂O
 % Excess Air (measured): 5%

SO₂ Rotameter
 Setting (BB height): N/A
 Draft (inches of water): 0.3
 Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.125	7.06	6	360	0	—	27.2	
NSR1	1.03 @ 70	8.00	7.16	13	198	0	1.34	27.2	
BL	1.03 @ 70	8.075	7.14	6	363	0	—	27.2	
NSR1	1.03 @ 70	8.0	7.1	14	200	0	1.34	27.2	
BL	1.03 @ 70	8.1	7.06	5	361	0	—	27.2	27.2
	@								
BL	1.03 @ 70	7.8	7.3	6	375	0	—	46.5	
NSR2	1.03 @ 70	7.65	7.4	25	53	0	2.68	46.5	
BL	1.03 @ 70	7.875	7.26	4	375	0	—	46.5	
NSR2	1.03 @ 70	7.675	7.44	27	52	0	2.68	46.5	
BL	1.03 @ 70	7.8	7.24	7	374	0	—	46.5	46.0
	@								
BL	1.03 @ 70	8.0	7.2	7	375	0	—	45.2	
NSR3	1.03 @ 70	7.58	7.4	32.5	35	0	4.02	45.2	
BL	1.03 @ 70	7.9	7.25	10	375	0	—	45.2	
NSR3	1.03 @ 70	7.75 7.75	7.4	35	29	0	4.02	45.2	
BL	1.03 @ 70	7.87	7.25	10	383	0	—	45.2	44.2
	@								

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2114	2178	1830
Finish	4.56 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2121	2185	1787

589

323

45 @ 2

Innovative Furnace Data Log

Date: 12/6/90
 Initials: CBE
 Test: #N5

NH₃ Rotameter
 Setting (BB height): 145
 Fuel: Natural Gas
 Slurry: H₂O
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): N/A
 Draft (inches of water): 0.3
 Injection Port: 4th upper

*NSR1
 is achieved
 by feeding a
 25% off rot
 no rot sd.*

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.075	7.08	3	374	0	—		
NSR2	1.03 @ 70	8.0	7.16	15	243	0	1.34		
BL	1.03 @ 70	8.1	7.14	8	375	0	—		
NSR2	1.03 @ 70	8.025	7.18	18	242	0	1.34		47.9
BL	1.03 @ 70	8.1	7.16	8	378	0	—		47.8
	@								
BL	1.03 @ 70	8.175	7.1	7	376	0	—	47.0	
NSR3	1.03 @ 70	8.0	7.16	20	175	0	2.01	47.0	
BL	1.03 @ 70	8.125	7.1	8	375	0	—	47.0	
NSR3	1.03 @ 70	8.0	7.11	20	165	0	2.01	47.0	
BL	1.03 @ 70	8.125	7.05	8	375	0	—	47.0	45.8
	@								
BL	1.03 @ 70	8.25	7.0	8	375	0	—	47.0	
NSR1	1.03 @ 70	8.125	7.1	12.5	325	0	1.45	47.0	
BL	1.03 @ 70	8.125	7.1	8	375	0	—	47.0	
NSR1	1.03 @ 70	8.0	7.1	13	300	0	1.45	47.0	
BL	1.03 @ 70	8.075	7.1	8	375	0	—	47.0	47.8
	@								

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 up
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2130	2241	182
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2126	2201	178

see note on back

Innovative Furnace Data Log

Date: 12/7/90
 Initials: EBP
 Test: #NG

NH₃ Rotameter
 Setting (BB height): 85
 Fuel: NATURAL GAS
 Slurry: H₂O
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): N/A
 Draft (inches of water): 0.3
 Injection Port: 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	7.0	7.86	5	393	2	—	47.0	
NSR2	1.03 @ 70	6.875	7.9	20	133	2	1.34	47.0	
BL	1.03 @ 70	6.95	7.86	7	393	3	—	47.0	
NSR2	1.03 @ 70	6.9	7.9	22	130	2	1.34	47.0	
BL	1.03 @ 70	6.925	7.86	11	390	3	—	47.0	
BL	0.97 @ 80	6.925	7.86	11	390	3	—	47.0	
NSR2	0.97 @ 80	6.875 6.875	7.86 7.86	17	120	3	1.34	47.0	
BL	0.97 @ 80	6.925	7.86	10	388	0	—	47.0	
BL	0.93 @ 90	6.85	7.84	11	383	0	—	47.0	
NSR2	0.93 @ 90	6.825	7.86	26	112	0	1.34	47.0	
BL	0.93 @ 90	6.825	7.88	7	375	0	—	47.0	
BL	1.03 @ 70	6.85	7.88	7	375	0	—	47.0	
NSR2	1.03 @ 70	6.715	7.96	27	120	0	1.34	47.0	
BL	1.03 @ 70	6.95	7.9	9	378	0	—	47.0	
BL	1.03 @ 70	6.975	7.8	2100 7	375	0	—	47.0	47.9
NSR1	1.03 @ 70	6.85	7.86	25	219	0	1.4	46.7	
BL	1.03 @ 70	6.95	7.84	8	373	0	—	46.7	
NSR1	1.03 @ 70	6.875	7.88	26	238	0	1.4	46.7	
BL	1.03 @ 70	7.0	7.8	12	376	0	—	46.7	47.0

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2083	2085	1818
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2071	2032	1703

Innovative Furnace Data Log

Date: 12/12/190

Initials CBC

Test: #N7

NH₃ Rotameter
Setting (BB height): 69 / 25

Fuel: NATURAL GAS

Slurry: H₂O

% Excess Air (measured): 27.5% / 55%

SO₂ Rotameter
Setting (BB height): N/A

Draft (inches of water): 0.3

Injection Port: 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	N ₂ ^{1.03} @70	4.825	7.44	20	370	0	—	46.8	
MSR1	N ₂ ^{1.03} @70	4.7	7.48	56	108	0	1.46	46.8	
BL	N ₂ ^{1.03} @70	4.725	7.46	24	368	0	—	46.8	
MSR1	N ₂ ^{1.03} @70	4.65	7.5	61	86	0	1.46	46.8	
BL	N ₂ ^{1.03} @70	4.75	7.48	30	365	0	—	46.8	
BL	1.03 @ 70	7.95	7.46	9	303	0	—	46.8	
MSR1	1.03 @ 70	7.9	7.5	21	155	0	1.46	46.8	
BL	1.03 @ 70	7.975	7.46	10	302	0	—	46.8	
MSR1	1.03 @ 70	7.925	7.5	21	148	0	1.46	46.8	
BL	1.03 @ 70	8.0	7.46	8	300	0	—	46.8	48.0
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Level
Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2130	2126	1850
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2124	2080	1775

Innovative Furnace Data Log

Date: 12/12/90

Initials: COE

Test: #N7 cont.

NH₃ Rotameter

Setting (BB height):

Fuel: NATURAL GAS

Slurry: H₂O

% Excess Air (measured):

	N ₂	AIR
	69	24

SO₂ Rotameter

Setting (BB height):

Draft (inches of water): 0.4

Injection Port: 3rd middle

N/A

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.1	7.42	7	295	0	—	47.1	
MSR2	1.03 @ 70	8.0	7.48	28	51	0	1.38	47.1	
BL	1.03 @ 70	8.125	7.4	9	294	0	—	47.1	
MSR2	1.03 @ 70	8.05	7.46	29	52	0	1.38	47.1	
BL	1.03 @ 70	8.1	7.36	8	289	0	—	47.1	
BL	^{N₂} 1.03 @ 70	5.075	7.34	12	357	0	—	47.1	
MSR2	^{N₂} 1.03 @ 70	4.925	7.42	28	23	0	1.38	47.1	
BL	^{N₂} 1.03 @ 70	5.0	7.4	13	360	0	—	47.1	OBE
MSR2	^{N₂} 1.03 @ 70	4.825	7.48	52	13	0	1.38	47.1	47.5
BL	^{N₂} 1.03 @ 70	4.95	7.38	19	355	0	—	47.1	47.5
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 uppe
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2120	2057	1718
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2114	2036	1665

Innovative Furnace Data Log

Date: 12/12/90

Initials: EBE

Test: #N7 cont

NH₃ Rotameter

Setting (BB height): 67 / 24

Fuel: NATURAL GAS

Slurry: H₂O

% Excess Air (measured): _____

N₂ | Air

SO₂ Rotameter

Setting (BB height): N/A

Draft (inches of water): 0.3

Injection Port: 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	N ₂ @ 70	4.95	7.42	18	357	0	—	47.0	
NSR3	N ₂ @ 70	4.75	7.48	435	3	0	2.00	47.0	
BL	N ₂ @ 70	4.975	7.38	17	356	0	—	47.0	
NSR3	N ₂ @ 70	4.925	7.46	155	4	0	2.00	47.0	
BL	N ₂ 1.03 @ 70	4.95	7.36	21	355	0	—	47.0	
BL	1.03 @ 70	8.075	7.36	11	298	0	—	47.0	
NSR3	1.03 @ 70	8.0	7.42	48	27	0	2.00	47.0	
BL	1.03 @ 70	8.125	7.26	12	295	0	—	47.0	
NSR3	1.03 @ 70	7.925	7.48	51	25	0	2.06	47.0	
BL	1.03 @ 70	8.075	7.36	12	297	0	—	47.0	46.8
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Level
Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 uope
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2112	2033	1655
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2111	2024	1626

Innovative Furnace Data Log

Date: 12-14, 90
 Initials: CBC
 Test: #N8

NH₃ Rotameter
 Setting (BB height): 35 (New Rotameter)
 Fuel: NATURAL GAS
 Slurry: H₂O
 % Excess Air (measured): _____

SO₂ Rotameter
 Setting (BB height): N/A
 Draft (inches of water): 0.3
 Injection Port: 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	7.9	7.52	7	363	0	—	46.9	
MSR3	1.03 @ 70	7.8	7.6	19	42	0	2.00	46.9	
BL	1.03 @ 70	7.95	7.46	8	363	0	—	46.9	
MSR3	1.03 @ 70	7.275	7.88	24	35	0	2.00	46.9	
BL	1.03 @ 70	7.95	7.76	8	375	0	—	46.9	47.8
	@								
BL	1.03 @ 70	7.6	7.62	10	377	0	—	47.1	
MSR2	1.03 @ 70	7.475	7.72	34	48 34	0	1.4	47.1	
BL	1.03 @ 70	7.575	7.66	9	375	0	—	47.1	
MSR2	1.03 @ 70	7.475	7.7	33	43	0	1.4	47.1	
BL	1.03 @ 70	7.575	7.62	10	375	0	—	47.1	47.0
	@								
BL	1.03 @ 70	7.35	7.72	23	382	0	—	46.8	
MSR1	1.03 @ 70	7.3	7.72	40	163	0	1.42	46.8	
BL	1.03 @ 70	7.325	7.66	20	380	0	—	46.8	
MSR1	1.03 @ 70	7.275	7.76	41	160	0	1.42	46.8	
BL	1.03 @ 70	7.35	7.7	20	376	0	—	46.8	46.3
	@								

5%
 2.1%

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upp
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2107	2120	1865
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2134	2035	1634

Innovative Furnace Data Log

Date: 2/14/90
 Initials: EBE
 Test: #N8 Cont

NH₃ Rotameter
 Setting (BB height): 25
 Fuel: Natural Gas
 Slurry: H₂O
 % Excess Air (measured): _____

SO₂ Rotameter
 Setting (BB height): 55
 Draft (inches of water): 0.4-0.5
 Injection Port: 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	7.625	7.64	16	374	1625	—	47.1	
NSR2	1.03 @ 70	7.85	7.74	40	27	1650	1.4	47.1	
BL	1.03 @ 70	7.575	7.64	23	372	1670	—	47.1	
NSR2	1.03 @ 70	7.475	7.7	45	25	1625 1680	1.4	47.1	
BL	1.03 @ 70	7.525	7.66	27	373	1680	—	47.1	47.0
	@								
BL	1.03 @ 70	7.55	7.66	33	373	1690	—	47.0	
NSR3	1.03 @ 70	7.375	7.8	55	12	1700	2.00	47.0	
BL	1.03 @ 70	7.4	7.8	32	373 375	1740	—	47.0	
NSR3	1.03 @ 70	7.275	7.9	60	11	1725	2.00	47.0	
BL	1.03 @ 70	7.2	7.86	32	378	1745	—	47.0	47.7
	@								
BL	1.03 @ 70	7.5	7.66	30	375	1700	—	46.8	
NSR1	1.03 @ 70	7.3	7.84	50	140	1725	1.42	46.8	
BL	1.03 @ 70	7.325	7.76	30	375	1725	—	46.8	
NSR1	1.03 @ 70	7.225	7.82	51	148	1710	1.42	46.8	
BL	1.03 @ 70	7.375	7.78	32	375	1715	—	46.8	46.2
	@								

1.0% excess

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2129	2129 2060	1724
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2132	2038	1649

600
26

Innovative Furnace Data Log

Date: 12/19/90

Initials: EBE

Test: *N₂

NH₃ Rotameter

Setting (BB height): 32 / 21

Fuel: Natural Gas

Slurry: H₂O

% Excess Air (measured): —

SO₂ Rotameter

Setting (BB height): NA

Draft (inches of water): 0.3

Injection Port: 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	4.025	7.8	5	391	0	—	47.1	
NSR2	1.03 @ 70	3.925	7.88	7	72	0	1.31	47.1	
BL	1.03 @ 70	4.075	7.8	5	388	0	—	47.1	
NSR2	1.03 @ 70	3.925	7.88	8	61	0	1.31	47.1	
BL	1.03 @ 70	4.025	7.8	6	386	0	—	47.1	
	@						1.31		
BL	1.03 @ 70	7.225	7.78	6	320	0	—	47.1	
NSR2	1.03 @ 70	7.05	7.9	11	88	0	1.31	47.1	
BL	1.03 @ 70	7.2	7.86	3	319	0	—	47.1	
NSR2	1.03 @ 70	7.1	7.94	11	83	0	1.31	47.1	
BL	1.03 @ 70	7.225	7.84	2	318	0	—	47.1	45.9
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Level
Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2235	2245	1981
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2214	2173	1907

Innovative Furnace Data Log

Date: 2/19/90

Initials: CBE

Test: # N9 cont

NH₃ Rotameter
 Setting (BB height): 32 / 21 N₂ / Air
 Fuel: Natural Gas
 Slurry: H₂O
 % Excess Air (measured): ✓

SO₂ Rotameter N/A
 Setting (BB height): _____
 Draft (inches of water): 0.4
 Injection Port: 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	7.6	7.64	3	300 ³¹⁰	0	—	46.9	
NSR3	1.03 @ 70	7.475	7.74	15	38	0	2.04	46.9	
BL	1.03 @ 70	7.6	7.6	2	309	0	—	46.9	
NSR3	1.03 @ 70	7.475	7.72	17	35	0	2.04	46.9	
BL	1.03 @ 70	7.675	7.6	2	310	0	—	46.9	
	@						2.04		
BL	¹² 1.03 @ 70	4.55	7.58	2	380	0	—	46.9	
NSR3	¹³ 1.03 @ 70	4.3	7.72	11	25	0	2.04	46.9	
BL	¹² 1.03 @ 70	4.5	7.62	2	380	0	—	46.9	
NSR3	¹² 1.03 @ 70	4.375	7.72	12	21	0	2.04	46.9	
BL	¹³ 1.03 @ 70	4.475	7.6	3	381	0	—	46.9	46.5
	@								
	@								
	@								
	@								
	@								
	@								
	@								

2 } {

Level
Temperature at Port °F:

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2210	2158	1886
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2189	2108	1795

Innovative Furnace Data Log

Date: 12/19/90

Initials EBP

Test: #M9 cont

NH₃ Rotameter

Setting (BB height): 32/21 N₂ | AIR

Fuel: Natural Gas

Slurry: H₂O

% Excess Air (measured): —

SO₂ Rotameter

Setting (BB height): N/A

Draft (inches of water): 0.4

Injection Port: 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	^M 1.03 @ 70	4.475	7.64	2	376	0	—	46.9	
NSRI	^b 1.03 @ 70	4.4	7.66	7	157	0	1.4	46.9	
BL	^M 1.03 @ 70	4.5	7.62	2	375	0	—	46.9	
NSRI	^M 1.03 @ 70	4.425	7.66	8	170	0	1.4	46.9	
BL	^M 1.03 @ 70	4.55	7.6	3	374	0	—	46.9	
	@								
BL	1.03 @ 70	7.7	7.5	4	311	0	—	46.9	
NSRI	1.03 @ 70	7.675	7.58	18	142	0	1.4	46.9	
BL	1.03 @ 70	7.75	7.56	4	309	0	—	46.9	
NSRI	1.03 @ 70	7.7	7.6	20	141	0	1.4	46.9	
BL	1.03 @ 70	7.775	7.6 7.54	4	308	0	—	46.9	46.5
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Level
Temperature at Pot (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2183	2097	1776
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2173	2076	1717

Innovative Furnace Data Log

Date: 11/21/19

Initials CBC

Test: #ND

NH₃ Rotameter
 Setting (BB height): 46-47
 Fuel: NATURAL GAS
 Slurry: H₂O
 % Excess Air (measured): —

SO₂ Rotameter
 Setting (BB height): N/A
 Draft (inches of water): 0.5
 Injection Port: 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	7.875	7.36	10	375		—	46.8	
NSR2	1.03 @ 70	7.775	7.48	15	135		1.4	46.8	
BL	1.03 @ 70	8.05	7.36	11	373		—	46.8	
NSR2	1.03 @ 70	7.8	7.48	17	127		1.4	46.8	
BL	1.03 @ 70	7.95	7.38	10	375		—	46.8	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 uppe
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2203	2197	1951
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2194	2167	1917

Innovative Furnace Data Log

Date: 1/10/91

Initials COE

Test: #11 Cont.

NH₃ Rotameter
Setting (BB height): 19

Fuel: Natural gas

Slurry: Terra Luffell Ca(OH)₂ (20%) 18%

% Excess Air (measured): —

SO₂ Rotameter
Setting (BB height): 58

Draft (inches of water): 0.2

Injection Port: 3rd middle

35-80
1.42%

Cal(OH)₂ slurry
2.15 + NSR2
Cals BL
Cals
Cals + NSR2
BL
@
@
@
@
@
@
@

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.5	7.2	6	368	1550		48 (H ₂ O)	
Cals	1.03 @ 70	8.35	7.2	8	372	325		53 (Slurry)	
BL	1.03 @ 70	8.25	7.34	10	378	1425		48 (H ₂ O)	
Cals	1.03 @ 70	8.1	7.24	12	378	225		52.5 (Slurry)	
BL	1.03 @ 70	8.175	7.42	7	378	1415		47.5 (H ₂ O)	
Cals	1.03 @ 70	8.1	7.36	8	378	600		49.5 (Slurry)	
2.15 + NSR2	1.03 @ 70	7.975	7.4	39	93	380 (25 Slurry)	2.2	49.5 (Slurry)	
Cals BL	1.03 @ 70	8.075	7.4	9	380	7400		48 (H ₂ O)	
Cals	1.03 @ 70	8.125	7.38	0	370	540		50 (Slurry)	
Cals + NSR2	1.03 @ 70	8.075	7.4	1	75	445 (25 Slurry)	2.2	50 (Slurry)	
BL	1.03 @ 70	8.2	7.36	0	360	1365		48 (H ₂ O)	
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1912	1955	1705
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1928	1897	1536

Innovative Furnace Data Log

Date: 1/11/91

Initials CBE

Test: #N12

NH₃ Rotameter
 Setting (BB height): 22
 Fuel: NATURAL GAS
 Slurry: Ca(OH)₂ Slurry
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 75
 Draft (inches of water): 0.2
 Injection Port: 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	(pure sl) NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
<i>12% CalOH₂ slurry</i> BL	1.03 @ 70	5.2	8.9	0	445	2025	—	(H ₂ O) 48	
CalS	1.03 @ 70	4.75	9.1	3	457	915	—	(slurry) 49.8	①
CalS+NSR	1.03 @ 70	4.25	9.44	13	45	660	1.45	(slurry) 49.8	
BL	1.03 @ 70	5.025	8.86	3	385	1900	—	(H ₂ O) 48.5	
CalS	1.03 @ 70	5.05	8.86	20 with line	450	1000	—	(slurry) 49	
CalS+NSR	1.03 @ 70	4.95	8.9	70	75	800	1.45	(slurry) 49	②
BL	1.03 @ 70	5.1	8.86	20	449	1840 #265 case	—	(H ₂ O) 48	
<i>10% slurry</i> CalS	1.03 @ 70	5.075	8.86	20	451	1265	—	(slurry) 48.8	
NSR+CalS	1.03 @ 70	4.95	8.9	70	68	1840 #265 case	1.45	(slurry) 48.8	③
BL	1.03 @ 70	5.075	8.86	18	448	1860	—	(H ₂ O) 48	
<i>10% slurry</i> CalS	1.03 @ 70	5.05	8.84	20	453	1300	—	(slurry) 48.8	④
CalS+NSR	1.03 @ 70	4.9	8.96	68	83	1125	1.45	(slurry) 48.8	
BL	1.03 @ 70	5.0	8.98	18	427	1740	—	(H ₂ O) 48	
	@								
	@								
	@								
	@								
	@								

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1970	1969	1664
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2080	1991	1539

Innovative Furnace Data Log

Date: 1/14/97

Initials ABC

Test: #N13

NH₃ Rotameter
 Setting (BB height): N/A
 Fuel: NATURAL GAS
~~Slurry~~ Sorbent: Tenn Lutrol Ca(OH)₂
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 52
 Draft (inches of water): 0.3-0.4
 Injection Port: 3rd middle

	Sorbent Air Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml /min)	Ending Feed Rate (ml /min)
BL	1.25 @ 30	6.45	8.36	51	110	1750			
Cal's	1.25 @ 30	6.375	8.34	50	111	1155		0.023 3%	2.72
BL	1.25 @ 30	6.425	8.36	52	111	1740			
Cal's	1.25 @ 30	6.35	8.36	52	111	1160		0.023 3%	2.72
BL	1.25 @ 30	6.375	8.38	52	111	1775			
Cal's	1.25 @ 30	6.3	8.38	50	112	665		0.047 6%	5.81
BL	1.25 @ 30	6.35	8.38	53	111	1750			
Cal's	1.25 @ 30	6.25	8.4	52	113	680		0.047 6%	5.81
BL	1.25 @ 30	6.35	8.4	53	112	1750			
Cal's	1.25 @ 30	6.2	8.42	50	111	300		0.070 9%	8.50
BL	1.25 @ 30	6.225	8.42	53	112	1675			
Cal's	1.25 @ 30	6.125	8.46	52	111	255		0.070 9%	8.50
BL	1.25 @ 30	6.225	8.46	54	112	1675			
	@								
	@								
	@								
	@								
	@								

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2188	2212	1951
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2188	2191	1919

Innovative Furnace Data Log

Date: 1/15/91

Initials: abe

Test: #N14

NH₃ Rotameter
 Setting (BB height): 22
 Fuel: methanol gas
 Slurry: Ca(OH)₂ Tennantrell
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 65
 Draft (inches of water): 0.3-0.4
 Injection Port: 3rd Right

1/19/91

1
1a
2
2a
3
3a
4
4a
5

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
1	BL 1.03 @ 70	6.0	8.5	11	452	1750	—	(H ₂ O) 48	
	Cals @	5.975	8.5	11	458	865	—	(Slurry) 51	① 17.
1a	Cals+NSR @	5.75	8.6	12	100	725	1.35	(Slurry) 51	11 1.
2	BL @	5.87	8.5	5	460	1700	—	(H ₂ O) 48	
	Cals @	5.875	8.52	5	468	1075	—	(Slurry) 51	② 18
2a	Cals+NSR @	5.7	8.64	10	110	925	1.35	(Slurry) 51	11
3	BL @	5.875	8.54	4	463	1780	—	(H ₂ O) 48	
	Cals @	5.825	8.5	4	465	250	—	(Slurry) 51	③ 18.
3a	Cals+NSR @	5.65	8.56	11	68	165	1.35	(Slurry) 51	11 1.
4	BL @	5.825	8.56	4	466	1715	—	(H ₂ O) 48	
	Cals @	5.75	8.5	5	468	325	—	(Slurry) 51	④
4a	Cals+NSR @	5.625	8.58	4	85	205	1.35	(Slurry) 51	11
5	BL @	5.8	8.54	5	472	1625	—	(H ₂ O) 48	
	Cals @	5.75	8.5	11 14	475	650	—	(Slurry) 50.5	⑤ 16.
	Cals+NSR @							(Slurry)	11
	BL @							(H ₂ O) 48	
	Cals @							(Slurry)	
	Cals+NSR @							(Slurry)	
	BL @							(H ₂ O) 48	

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2095	2029	1700
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2118	2018	1581

Innovative Furnace Data Log

Date: 1/16/91

Initials PLW & CCB

Test: N15

NH₃ Rotameter
 Setting (BB height): 25
 Fuel: Natural Gas
 Slurry: Calcium Hydroxide
 % Excess Air (measured): _____

SO₂ Rotameter
 Setting (BB height): 57
 Draft (inches of water): 0.2-0.3
 Injection Port: 3rd Right

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	5.75	8.5	17	410	1875	—	48 (H ₂ O)	(12.5)
NSR	1.03 @ 70	5.3	8.84	29	105	1950	1.4	48	
BL	1.03 @ 70	5.425	8.72	18	415	1990	—	48	
NSR	1.03 @ 70	5.2	8.98	33	115	2005 1970	1.4	48	
BL	1.03 @ 70	5.225	8.94	20	423	2005	—	48 ↓	
CLS	1.03 @ 70	4.88	8.95	18	430	575	—	(Slurry) 55	
calstNSR	1.03 @ 70	4.5	9.2	28	175	305	1.4	(Slurry) 55	
BL	1.03 @ 70	4.55	9.26	22	445	1750	—	(H ₂ O) 48	
calstNSR	1.03 @ 70	4.475	9.24	20	443	500	—	Slurry 55	
calstNSR	1.03 @ 70	4.325	9.36	28	200	300	1.4	(Slurry) 55	
BL	1.03 @ 70	4.475	9.36	23	444	1750	—	(H ₂ O) 48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.57 @ 45 PSI	1 @ 45 PSI	0.82 @ 2 PSI	— @ —	2003	2084	1770
Finish	4.57 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2024	2074	1693

Innovative Furnace Data Log

Date: 1/18/91
 Initials PBC
 Test: #N16

NH₃ Rotameter
 Setting (BB height): 27
 Fuel: natural gas
 Slurry: Ca(OH)₂ (Tennantroll)
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 60
 Draft (inches of water): 0.4
 Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	5.925	8.48	12	428	1795	—	(H ₂ O) 48	
1 NSR	1.03 @ 70	5.85	8.54	24	92	1860	1.4	(H ₂ O) 48	
BL	1.03 @ 70	5.95	8.46	14	423	1895	—	(H ₂ O) 48	
2 NSR	1.03 @ 70	5.85	8.52	27	96	1915	1.4	(H ₂ O) 48	
BL	1.03 @ 70	5.9	8.46	14	420	1990	—	(H ₂ O) 48	
3 Cals	1.03 @ 70	5.785	8.52	14	430	625	—	(Slurry) 52	12
3 Cals+NSR	1.03 @ 70	5.525	8.6	31	95	410	1.4	(Slurry) 52	
BL	1.03 @ 70	5.85	8.54	14	427	2015	—	(H ₂ O) 48	
4 Cals	1.03 @ 70	5.55	8.66	16	438	700	—	(Slurry) 52	12
4 Cals+NSR	1.03 @ 70	5.35	8.76	38	98	550	1.4	(Slurry) 52	
BL	1.03 @ 70	5.5	8.78	15	440	1950	—	(H ₂ O) 48	
5 Cals	1.03 @ 70	5.45	8.76	18	438	1000	—	(Slurry) 52	12
5 Cals+NSR	1.03 @ 70	5.325	8.84	43	70	800	1.4	(Slurry) 52	
BL	1.03 @ 70	5.45	8.78	15	438	1990	—	(H ₂ O) 48	
Cals	1.03 @ 70						—	(Slurry) 52	
Cals+NSR	1.03 @ 70						—	(Slurry) 52	
BL	1.03 @ 70						—	(H ₂ O) 48	
	@								

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2017	2139	1848
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	?	?	?

Innovative Furnace Data Log

Date: 1/21/91
 Initials EBY
 Test: #M17

NH₃ Rotameter
 Setting (BB height): 22
 Fuel: NATURAL GAS
 Slurry: Ca(OH)₂ Tumbert
 % Excess Air (measured): -

SO₂ Rotameter
 Setting (BB height): 62
 Draft (inches of water): 0.2
 Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
	BL	1.03 @ 70	5.15	8.96	15	433	2050	-	48.2
10	NSR	1.03 @ 70	5.075	9.0	23	90	2085	1.4	
	BL	1.03 @ 70	5.275	8.82	20	424	2105	-	
11	NSR	1.03 @ 70	5.2	9.0	24	73	2125	1.4	
	BL	1.03 @ 70	5.35	8.92	23	425	2160	-	
1	ca/s	1.03 @ 70	5.275	8.96	24	443	990	-	(slow) 47.5 (1)
6	ca/s+NSR	1.03 @ 70	5.0	9.04	34	110	690	1.4	(slow) 47.5
	BL	1.03 @ 70	5.225	8.96	25	440	1885	-	(H ₂ O) 48.2
7	ca/s	1.03 @ 70	5.13	9.0	25	445	900	-	(slow) 47.5 (2)
7a	ca/s+NSR	1.03 @ 70	4.99	9.2	35	150	300	1.4	(slow) 47.5
	BL	1.03 @ 70	5.075	9.0	30	438	1890	-	(H ₂ O) 48.2
8	ca/s	1.03 @ 70	5.1	9.0	30	442	280	-	(slow) 46 (3)
8a	ca/s+NSR	1.03 @ 70	4.95	9.04	46	100	130	1.4	(slow) 46
	BL	1.03 @ 70	5.06	9.0	30	430	1813	-	(H ₂ O) 48
9	ca/s	1.03 @ 70	5.05	8.96	33	430	475	-	(slow) 46 (4)
9a	ca/s+NSR	1.03 @ 70	4.875	9.04	51	100	160	1.4	(slow) 46
	BL	1.03 @ 70	5.125	8.95	30	430	1800	-	(H ₂ O) 48
	@								

Level
 Temperature at ~~exit~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upp
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	- @ -	2128	2259	1966
Finish	4.6 @ 45	1.0 @ 45	.92 @ 2	- @ -	2221	2101	1866

Innovative Furnace Data Log

Date: 1/22/91

Initials CBC

Test: #N18

NH₃ Rotameter
Setting (BB height): N/A

SO₂ Rotameter
Setting (BB height): 60

Fuel: NATURAL GAS

Draft (inches of water): 0.2

Slurry: Dry Sorbant Ca(OH)₂ Tenbut

Injection Port: 9th upper

% Excess Air (measured): _____

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Feeder setting NO OUT Feed Rate (ml/min)	Starting Feed Rate (g/min) (ml/min)	Ending Feed Rate (g/min) (ml/min)
BL	1.25 @ 30	5.375	8.92	15	88	1875	—	—	—
Cal's	1.25 @ 30	5.35	8.98	15	87	1325	0.024	3	2.88
BL	1.25 @ 30	5.375	8.96	16	86	1885	—	—	—
Cal's	1.25 @ 30	5.25	8.96	15	87	1330	0.024	3	2.88
BL	1.25 @ 30	5.2	8.98	15	87	1930	—	—	—
Cal's	1.25 @ 30	5.1	9.04	15	89	780	0.048	6	5.95
BL	1.25 @ 30	5.15	9.06	15	88	1900	—	—	—
Cal's	1.25 @ 30	4.975	9.08	16	89	790	0.048	6	5.95
BL	1.25 @ 30	5.025	9.1	15	87	1925	—	—	—
Cal's	1.25 @ 30	4.95	9.12	14	90	475	0.071	9	8.78
BL	1.25 @ 30	5.025	9.08	14	88	1920	—	—	—
Cal's	1.25 @ 30	4.85	9.14	15	89	340	0.071	9	8.78
BL	1.25 @ 30	4.95	9.14	15	89	1915	—	—	—
	@								
	@								
	@								
	@								
	@								

sections

Temperature at ~~exit~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2093	2212	1944
Finish	4.6 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2062	2167	1880

Innovative Furnace Data Log

Date: 12/8/91

Initials CBE

Test: #N19

NH₃ Rotameter
Setting (BB height): N/A

SO₂ Rotameter
Setting (BB height): 41

Fuel: NATURAL GAS

Draft (inches of water): 0.2 - 0.3

Slurry: Dry Int of Tenn Lintell (calOH)

Injection Port: 4th Lower

% Excess Air (measured): _____

	Sorbant Air Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	feeder setting NO OUT Feed Rate (ml/min)	Starting Feed Rate (g/min)	Ending Feed Rate (g/min)
BL	1.25 @ 30	5.975	8.5	19	61	1855	_____	_____	_____
cal/s	@	5.875	8.54	24	60	1275	0.023	3	3.05
BL	@	5.95	8.48	18	61	1840	_____	_____	_____
cal/s	@	5.95	8.5	23	63	1245	0.023	3	3.05
BL	@	5.975	8.5	18	62	1835	_____	_____	_____
cal/s	@	5.85	8.52	27	63	725	0.047	6	6.25
BL	@	5.95	8.5	16	63	1805	_____	_____	_____
cal/s	@	5.825	8.52	26	69	705	0.047	6	6.25
BL	@	5.825	8.52	19	63	1780	_____	_____	_____
cal/s	@	5.8	8.54	27	66	290	0.070	9	9.28
BL	@	5.85	8.5	19	64	1745	_____	_____	_____
cal/s	@	5.75	8.56	25	68	275	0.070	9	9.28
BL	↓ @ ↓	5.825	8.56	19	68	1745	_____	_____	_____
	@								
	@								
	@								
	@								
	@								

(Level)
Temperature at ~~Port~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1755	1925	1631
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1867	2020	1690

Innovative Furnace Data Log

Date: 1/28/91

Initials CBP

Test: #N20

NH₃ Rotameter
Setting (BB height): N/A

SO₂ Rotameter
Setting (BB height): 37/38

Fuel: NATURAL GAS

Draft (inches of water): 0.2

Slurry: Dry Inj. of Tempelwell calOH₂

Injection Port: 5th

% Excess Air (measured):

	Subst Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Feeder setting NO OUT Feed Rate (ml/min)	Starting Feed Rate (g /min)	Ending Feed Rate (g /min)
B -	1.25 @ 30	5.85	8.56	24	64	1815	—	—	—
Cal's	@	5.825	8.58	33	65	1250	0.023	3	3.05
BL	@	5.85	8.6	23	64	1765	—	—	—
Cal's	@	5.775	8.6	34	64	1250	0.023	3	3.05
BL	@	5.775	8.62	23	65	1770	—	—	—
Cal's	@	5.725	8.62	44	68	725	0.047	6	6.25
BL	@	5.775	8.6	24	64	1745	—	—	—
Cal's	@	5.675	8.6	44	67	640	0.047	6	6.25
BL	@	5.7	8.6	25	68	1710	—	—	—
Cal's	@	5.575	8.64	55	71	275	0.070	9	9.28
BL	@	5.675	8.6	24	68	1660	—	—	—
Cal's	@	5.6	8.62	51	68	255	0.070	9	9.28
BL	✓ @ ↓	5.675	8.64	27	70	1645	—	—	—
	@								
	@								
	@								
	@								
	@								

Level
Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 uppe
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1900	2050	1716
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1952	2099	1767

Innovative Furnace Data Log

Date: 1/30/91
 Initials: EBP
 Test: #N21

NH₃ Rotameter
 Setting (BB height): N/A
 Fuel: natural gas
 Slurry: Tennantell Ca(OH)₂ by Int.
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 35
 Draft (inches of water): 0.1
 Injection Port: 6th

	Soibant Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Feed Rate (lb/min)	Starting Feed Rate (lb/min)	Ending Feed Rate (lb/min)	
BL	1.25 @ 30	4.45	9.32	22	81	2000				
calc	@	4.325	9.38	20	82	1315	0.023	3		
BL	@	4.375	9.4	20	83	1890				
calc	@	4.25	9.38	29	84	1265	0.023	3		
BL	@	4.225	9.44	20	84	1855				
calc	@	4.0	9.56	35	84	560	0.047	6		
BL	@	Base line would not come								
calc	@	back up - blew line out					0.047	6		
BL	@	4.2	9.5	19	82	1850				
calc	@	4.1	9.52	33	83	690	0.047	96		
BL	@	4.125	9.52	18	84	1795				
calc	@	4.05	8.5	33	84	615	0.047	96		
BL	✓ @ ✓	4.1	9.48	19	83	1750				
BL	@	4.15	9.46	18	84	1765				
calc	@	3.95	9.5	39	85	195	0.070	9		
BL	@	4.1	9.48	18	83	1670				
calc	@	3.95	9.5	36	84	150	0.070	9		
BL	✓ @ ✓	4.025	9.48	18	83	1625				

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2100	2253	1988
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2072	2226	1965

Innovative Furnace Data Log

Date: 1/31/19
 Initials: CBC
 Test: #N22

NH₃ Rotameter ⁵⁵
 Setting (BB height): 93
 Fuel: natural gas
 Slurry: Ca(OH)₂ Tenn Luffco
 % Excess Air (measured): —

SO₂ Rotameter
 Setting (BB height): 57
 Draft (inches of water): 0.3
 Injection Port: 4th lower

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 80	3.8	9.3	18	473	2100	—	48	
NSR	@	3.475	9.5	34	345	2110	1.4	48	
BL	@	3.6	9.4	20	450	2150	—	48	
NSR	@	3.45	9.48	37	323	2115	1.4	48	
BL	@	3.575	9.46	20	453	2130	—	48	
ca/s	@	3.45	9.48	22	465	630	—	(start) 59.5	
ca/s+NSR	@	3.3	9.54	34	370	400	1.4	(start) 59.5	
BL	@	3.275	9.62	21	440	1750	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Slurry Setting $(54.5 \frac{ml}{min}) (1.08 \frac{g}{ml}) (1758) = 10.35 \frac{g}{min} Ca(OH)_2$ Slurry Level Temperature at ~~200~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2021	2193	1934
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2005	2174	1917

Innovative Furnace Data Log

Date: 2/5/91

Initials EBC

Test: #N23

NH₃ Rotameter
 Setting (BB height): 91
 Fuel: natural GAS
 Slurry: Ca(OH)₂ Tonn Lwt
 % Excess Air (measured): _____

SO₂ Rotameter
 Setting (BB height): 55
 Draft (inches of water): 0.2
 Injection Port: 4th lower

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	3.05	9.75	42	493	2090	—	48	
NSR	@	3.075	9.88	62	325	2100	1.4		
BL	@	3.2	9.8	44	495	2120	—		
NSR	@	3.0	9.92	65	328	2135	1.4		
BL	@	3.15	9.86	46	500	2155	—	↓	
CalS	@	3.1	9.78	47	488	650	—	(slurry) 52.1	
Cal/NSR	@	2.85	9.88	60	370	490	1.4	(slurry) 52.1	
BL	@	3.1	9.86	44	485	1675	—	48	
CalS	@						—	(slurry) 52.1	
Cal/NSR	@						1.4	(slurry) 52.1	
BL	@						—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	↓ @ ↓								

$(52.1 \frac{ml}{min})(1.08 \frac{g}{ml})(.1154) = 6.49 \frac{g}{min} \text{ Ca(OH)}_2 \text{ Slurry}$

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2019	2198	1922
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	—	—	—

Innovative Furnace Data Log

Date: 2, 7, 91

Initials: PBC

Test: #N24

NH₃ Rotameter
 Setting (BB height): 31
 Fuel: Natural Gas
 Slurry: Ca(OH)₂ Term Lot
 % Excess Air (measured): _____

SO₂ Rotameter PBC
 Setting (BB height): 68 63
 Draft (inches of water): 0.2-0.3
 Injection Port: 2nd Right

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	5.1	8.96	8	485	1900	—	48	
NSR	@	5.0	9.0	12	550	1915	1.4	48	
BL	@	5.125	9.0	10	485 480	1915 1905	—	48	
NSR	@	4.95	9.1	18	548	1955	1.4	48	
BL	@	5.1	9.02	12	489	1975	—	48	
Cal/s	@	4.975	9.02	12	475	760	—	(slurry) 50.5	①
Cal/NSR	@	4.95	9.06	11	573	625	1.4	(slurry) 50.5	①
BL	@	5.45	8.76	10	460	2075	—	48	
Cal/s	@	5.425	8.78	10	460	600	—	(slurry) 50.5	①
Cal/NSR	@	5.25	8.88	10	580	425	1.4	(slurry) 50.5	①
BL	@	5.375	8.88	11	461	2025	—	48	
Cal/s	@	5.525	8.7	15	475	975	1.4	(slurry) 49.5	②
Cal/NSR	@	Slurry kept		plugging		—	1.4	(slurry) 49.5	
BL	@						—	48	
Cal/s	@							(slurry) 49.5	
Cal/NSR	@							(slurry) 49.5	
BL	@							48	
	✓ @ ✓								

#1 Slurry setting $(50.5 \frac{ml}{min}) (1.10 \frac{g}{ml}) (0.1432) = 7.95 \frac{g}{min}$ Ca(OH)₂ Slurry Section
 #2 Slurry setting $(49.5 \frac{ml}{min}) (1.08 \frac{g}{ml}) (0.0950) = 5.08 \frac{g}{min}$ Ca(OH)₂ Slurry Temperature at ~~200~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
.art	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1910	2104	1939
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1817	2007	1811

Innovative Furnace Data Log

Date: 2/8/91
 Initials: ABC
 Test: #125

NH₃ Rotameter
 Setting (BB height): 278
 Fuel: NATURAL GAS
 Slurry: Ca(OH)₂ Tenn Lint
 % Excess Air (measured): _____

SO₂ Rotameter
 Setting (BB height): 74/25
 Draft (inches of water): 0.3-0.4
 Injection Port: 2nd Right

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	5.2	9.0	13	490	1925	—	48	9.3
NSR	@	5.1	9.2	22	405	1990	1.4		
BL	@	5.175	9.2	20	370 400	2035	—		
NSR	@	4.975	9.3	24	398	2050	1.4		
BL	@	5.1	9.24	19	451	2075	—		
CalS	@	5.1	9.24	17	455	1225	—	(slurry) 43	
CalStNSR	@	4.875	9.3	21	530	1105	1.4	(slurry) 43	
BL	@	5.35	8.84	19	445	1915	—	48	
CalS	@	5.325	8.94	19	438	1130	—	(slurry) 43	
CalStNSR	@	5.125	9.08	19	495	1000	1.4	(slurry) 43	
BL	√ @ √	5.35	8.96	17	439	1850	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Slurry setting (43 $\frac{\text{g}}{\text{min}}$) \times (1.08 $\frac{\text{g}}{\text{ml}}$) \times (0.936) = 4.35 $\frac{\text{g}}{\text{min}}$ Ca(OH)₂ Level
 Temperature at ~~Exit~~ (°F)

Part	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @	1888	2050	1869
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @	1811	1963	1782

Innovative Furnace Data Log

Date: 2/11/91

Initials: EBC

Test: #N26

NH₃ Rotameter

Setting (BB height): 60

Fuel: natural gas

Slurry: Ca(OH)₂ Tumbert.

% Excess Air (measured):

SO₂ Rotameter

Setting (BB height): 66

Draft (inches of water): 0.4

Injection Port: 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	5.35	8.9	15	433	1915	—	48	
NSR	@	5.25	8.96	20	215	1930	1.4		
BL	@	5.45	8.86	13	430	1945	—		
NSR	@	5.35	8.98	24	205	1970	1.4		
BL	@	5.4	8.92	21	432	2015	—		
Cal/s	@	5.35	8.88	19	428	1260	—	(slurry) 48.5	① 9.4
Cal/s+NSR	@	5.45	8.96	22	300	775	1.4	(slurry) 48.5	①
BL	@	5.325	8.9	20	430	1975	—	48	
Cal/s+NSR	@	5.35	8.94	18	425	1100	—	(slurry) 48.5	①
Cal/s+NSR	@	5.125	8.98	20	310	900	1.4	(slurry) 48.5	①
BL	@	5.025	9.06	17	440	1975	—	48	
Cal/s	@	5.1	9.0	15	450	875	—	(slurry) 47	③ 11.4
Cal/s+NSR	@	4.925	9.1	16	325	750	1.4	(slurry) 47	③
BL	@	4.95	9.08	15	455	2050	—	48	
Cal/s	@	5.025	9.06	15	452	1000	—	(slurry) 47	②
Cal/s+NSR	@	4.85	9.1	19	325	850	1.4	(slurry) 47	②
BL	@	4.85	9.16	15	450	2200	—	48	
	✓ @ ✓								

slurry setting #1 $(48.5 \frac{ml}{min})(1.07 \frac{lb}{ft^3})(0.940) = 4.88 \frac{lb}{min} \text{ Ca(OH)}_2 \text{ slurry}$
 slurry setting #2 $(47 \frac{ml}{min})(1.09 \frac{lb}{ft^3})(1.149) = 5.88 \frac{lb}{min} \text{ Ca(OH)}_2 \text{ slurry}$
 Section Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2018	2123	1906
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1948	1982	1705

Innovative Furnace Data Log

Date: 2/12/91
 Initials: EBE
 Test: #N27

NH₃ Rotameter
 Setting (BB height): N/A
 Fuel: NATURAL GAS
 Slurry: DY Int Ca(OH)₂
 % Excess Air (measured): _____

SO₂ Rotameter
 Setting (BB height): 54
 Draft (inches of water): 0.4
 Injection Port: 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Feeder Setting NO ₂ OUT Feed Rate (ml/min)	Starting Feed Rate (g/min)	Ending Feed Rate (g/min)
BL	1.25 @ 30	5.25	8.98	11	78	1765	_____	_____	_____
Cal's	@	5.1	9.1	11	78	1575	0.023	3	
BL	@	5.15	9.06	10	77	2110	_____	_____	_____
Cal's	@	5.125	9.08	11	78	1625	0.023	3	
BL	@	5.125	9.08	11	78	2100	_____	_____	_____
Cal's	@	5.0	9.12	11	78	1215	0.047	6	
BL	@	5.1	9.12	11	78	2120	_____	_____	_____
Cal's	@	5.025	9.14	10	77	1250	0.047	6	
BL	@	5.05	9.14	10	77	2150	_____	_____	_____
Cal's	@	4.85	9.22	9	79	775	0.070	9	
BL	@	4.95	9.22	10	78	2130	_____	_____	_____
Cal's	@	4.825	9.24	10	77	800	0.070	9	
BL	@	4.875	9.2	10	77	2120	_____	_____	_____
	@								
	@								
	@								
	@								
	@								
	@								

Section
 Temperature at ~~Bottom~~ (°F)

Part	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1863	2032	1868
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1846	2014	1859

Innovative Furnace Data Log

Date: 2/13/91

Initials: ERC

Test: #228

NH₃ Rotameter

Setting (BB height): N/A

Fuel: NATURAL GAS

Slurry: DRY INT. Ca(OH)₂ (Tenn-Lint)

% Excess Air (measured):

SO₂ Rotameter

Setting (BB height): 51

Draft (inches of water): 0.3-0.4

Injection Port: 1st upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	feed rate Setting NO OUT Feed Rate (lb/hr)	Starting Feed Rate (lb /min)	Ending Feed Rate (lb /min)
BL	1.25 @ 30	5.35	8.98	12	81	2025	—	—	—
Calcs	@	5.25	9.0	12	82	1400	0.023	3	—
BL	@	5.3	9.0	13	81	2050	—	—	—
Calcs	@	5.225	9.02	12	82	1465	0.023	3	—
BL	@	5.275	9.09	13	83	2090	—	—	—
Calcs	@	5.125	9.08	12	82	800	0.047	6	6.01
BL	@	5.175	9.08	13	82	2060	—	—	—
Calcs	@	5.075	9.12	13	83	815	0.047	6	6.01
BL	@	5.1	9.12	13	82	810	—	—	—
Calcs	@	4.975	9.18	12	83	375	0.070	9	—
BL	@	5.0	9.18	12	84	2100	—	—	—
Calcs	@	4.875	9.22	11	83	375	0.070	9	—
BL	@	4.975	9.2	11	84	2140	—	—	—
	@								
	@								
	@								
	@								
	@								
	@								

Temperature at ~~2~~ ^{section} (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1798	2007	1753
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1797	2024	1754

Innovative Furnace Data Log

Date: 2/13/91
 Initials: CSB
 Test: #129

NH₃ Rotameter
 Setting (BB height): 61
 Fuel: NATURAL GAS
 Slurry: Ca(OH)₂ Tenn Lint
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 49
 Draft (inches of water): 0.3
 Injection Port: 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
DL	1.03 @ 70	5.25	8.86	11	465	1945	—	48	15.53 ⁱⁿ
NSR	@	5.25	8.92	14	252	1960	1.4		
BL	@	5.0 5.225	8.8	13	466	1975	—		
NSR	@	5.225	8.8	20	235	1965	1.4		
BL	@	5.35	8.76	12	461	1990	—		
CalS	@	5.35	8.68	12	463	525	—	(Slurry) 49.8	
CalS+NSR	@	5.35	8.78	17	266 256	285	1.4	(Slurry) 49.8	
BL	@	5.1	9.0	13	455	1905	—	48	
CalS	@	5.1	9.0	10	450	600	—	(Slurry) 49.8	
CalS+NSR	@	5.0	8.96	15	300	360	1.4	(Slurry) 49.8	
BL	@	5.225	8.86	13	473	1875	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Slurry setting $(49.8 \frac{ml}{min})(1.09 \frac{g}{ml})(.1553) = 8.43 \frac{g}{min}$ Ca(OH)₂ slurry
 Section Temperature at ~~Port~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1786	1958	1734
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1758	1919	1689

Innovative Furnace Data Log

Date: 2/14/91

Initials: ABC

Test: ABC *N 30

NH₃ Rotameter
 Setting (BB height): 21
 Fuel: Natural Gas
 Slurry: calohz Tennant
 % Excess Air (measured): _____

SO₂ Rotameter
 Setting (BB height): 46
 Draft (inches of water): 0.3
 Injection Port: 2nd Right

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	4.625	9.58 9.58	12	468	1875	—	48	
CalS	@	4.475	9.39	11	470	490	—	(slurry)	
CalS+NR	@	4.325	9.5	13	580	1925 250	1.4	(slurry)	14.25 ⁴⁰
BL	@	4.475	9.5	10	470	1925	—	48	
CalS	@	4.375	9.52	11	470	475	—	(slurry) 48.2	
CalS+NR	@	4.2	9.58	12	660	165	1.4	(slurry) 48.2	
BL	✓ @ ✓	4.325	9.5	12	473	1990	—	48	
CalS	@	4.275	9.52	10	468	550	—	(slurry) 48.2	
CalS+NR	@	4.075	9.56	11	500	275	1.4	(slurry) 48.2	
BL	✓ @ ✓	4.3	9.62	11	471	1925	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

section
 Temperature at ~~exit~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
rt	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1699	1963	1827
finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1597	1850	1717

15.7

Innovative Furnace Data Log

Date: 2/15/91

Initials ebc

Test: #N3

NH₃ Rotameter
 Setting (~~BB~~ height): ebc 75
 Fuel: natural GAS
 Slurry: Ca(OH)₂ (Terra Cat)
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 68
 Draft (inches of water): ebc ~~0.5~~ 0.2-0.5
 Injection Port: 4th lower

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1,03 @ 70	4.0	9.08 9.08	15	473	2100	—	47.8 47.8	18.25
Cal/s	@	3.95	7.28	16	480	500	—	(Slurry) 50	
Cal/s+MSR	@	3.725	9.38	24	240	175	1.4	(Slurry) 50	
BL	@	3.975	9.36	18	473	2040	—	47.8	
Cal/s	@	3.875	9.3	17	482	325	—	(Slurry) 50	
Cal/s+MSR	@	3.7	9.42	29	215	195	1.4	(Slurry) 50	
BL	@	4.4	9.0	17	438	200	—	47.8	
MSR	@	4.325	9.12	50	100	2090	1.4	47.8	
BL	@	4.425	9.04	18	445	2105	—	47.8	
MSR	@	4.325	9.16	51	98	2120	1.4	47.8	
BL	✓ @ ✓	4.425	9.08	19	441	2120	—	47.8	
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Slurry Setting (50 $\frac{ml}{min}$) \times (1.14 $\frac{g}{ml}$) \times (.1824) = 10.90 $\frac{g}{min}$ Ca(OH)₂ Slurry ²⁰⁰⁰ ₁₈₀₀ $\frac{g}{min}$
 Temperature at ~~exit~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1812	2112	1920
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1804	2096	1900

Innovative Furnace Data Log

Date: 2/25/91

Initials CBP

Test: #N32

NH₃ Rotameter

Setting (BB height): 38

Fuel: NATURAL GAS

Slurry: CaO₃ (As Rec.) Term Unit

% Excess Air (measured): _____

SO₂ Rotameter

Setting (BB height): 49

Draft (inches of water): 0.2

Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03@70	4.325	9.58	20	463	1875	—	48	12.96
CalS	@	4.2	9.98	20	445	1150	—	(slurry) 49	
CalS+NR	@	4.1	10.06	29	300	1150	1.4	(slurry) 49	
BL	@	4.3	10.0	21	435	1995	—	48	
CalS	@	4.225	10.0	21	435	1175	—	(slurry) 49	Reading at Blow Back
CalS+NR	@	4.1	10.1	21	450	1260	1.4 ea	(slurry) 49	Reading at Blow Back
BL	✓ @ ✓	3.975	10.26	31	245	1170	1.4	(slurry) 49	
BL	✓ @ ✓	4.225	9.68	19	455	1955	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

$$\left(\frac{49 \text{ ml}}{\text{min}} \right) (1.11 \text{ g/ml}) \left(\frac{12.74}{100} \right) = \frac{6.93}{7.05} \text{ g/min CaO}_3 \text{ Slurry}$$

Section
Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1813	2033	1775
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1810	2017	1731

Innovative Furnace Data Log

Date: 2/27/91

Initials CBP

Test: #N33

NH₃ Rotameter
Setting (BB height): 43.5

Fuel: Natural Gas

Slurry: CaCO₃ (AS Received) Tank wt

% Excess Air (measured):

SO₂ Rotameter
Setting (BB height): 54

Draft (inches of water): 0.5

Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	5.425	9.0	17	450	1895	—	48	
CalS	@	5.225	9.5	18	430	930	—	(S) 50	(1)
CalS+NSR	@	5.125	9.6	28	260	900	1.4	(S) 50	(1)
BL	@	5.375	9.04	18	448	1925	—	48	
CalS	@	5.225	9.52	17	428	1000	—	(S) 50	(1)
CalS+NSR	@	5.1	9.6	31	228	980	1.4	(S) 50	(1)
BL	@	5.25	9.04	18	445	1920	—	48	
CalS	@	5.2	9.36	19	474	1475	—	(S) 50	(2)
CalS+NSR	@	5.1	9.4	34	227	1490	1.4	(S) 50	(2)
BL	@	5.2	9.1	17	446	1970	—	48	
CalS	@						—	(S)	
CalS+NSR	@						1.4	(S)	
BL	∇ @ ∇						—	48	
	@								
	@								
	@								
	@								
	@								

Slurry setting #1 (50 $\frac{ml}{min}$) (1.12 $\frac{g}{min}$) (.1446) = 8.10 $\frac{g}{min}$ CaCO₃ Slurry section
 Slurry setting #2 (50 $\frac{ml}{min}$) (1.06 $\frac{g}{min}$) (.0813) = 4.31 $\frac{g}{min}$ CaCO₃ Slurry Temperature at ~~exit~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1787	2002	1705
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1705	1992	1681

Innovative Furnace Data Log

Date: 2/28/91

Initials: BBE

Test: #234

NH₃ Rotameter Setting (BB height): 43

SO₂ Rotameter Setting (BB height): 58

Fuel: Natural Gas

Draft (inches of water): 0.4

Slurry: CaCO₃ (ASR) tumbler

Injection Port: 4th upper

% Excess Air (measured):

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 170	5.125	9.18	15	467	1925	—	48	
Cal/s	@	2.125 2.125	9.52	16	461	1920	—	(S) 49	
Cal/s+NR	@	4.6	9.68	27	275	1400	1.4	(S) 49	
BL	@	4.7	9.38	15	475	2150	—	48	
Cal/s	@	4.6	9.16	15	440	1690	—	(S) 49	
Cal/s+NR	@	4.475	9.7	23	315	1445 1680	1.4	(S) 49	
BL	↓ @ ↓	4.625	9.38	15	445	2250	—	48	
Cal/s	@	4.575	9.7	18	435	1725	—	(S) 49	
Cal/s+NR	@	4.425	9.82	27	294	1750	1.4	(S) 49	
BL	↓ @ ↓	4.6	9.5	18	468	2275	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Slurry setting $(49 \frac{ml}{min})(1.06 \frac{g}{ml})(.0809) = 4.20 \frac{g}{min}$ CaCO₃ Slurry section
 Temperature at (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1788	2018	1781
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1789	2005	1732

Innovative Furnace Data Log

Date: 3/1/91

Initials CBP

Test: #N35

NH₃ Rotameter
Setting (BB height): N/A

Fuel: NATURAL GAS

SO₂ Rotameter
Setting (BB height): 28

Draft (inches of water): 0.3 → 0.4

Injection Port: 5th level

Dry Sorbent ~~Setting~~: CaCO₃ (As Received) Tonn Lut.
% Excess Air (measured): —

	Sorbent Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Feeder Setting NO OUT Feed Rate Setting	Starting Feed Rate (#/min)	Ending Feed Rate (#/min)
BL	1.25 @ 30	5.1	9.3	20	66	1900	—	—	—
Cal/s	@	5.05	9.58	21	68	1540	0.011	4.05	4.01
BL	@	5.075	9.38	20	68	1920	—	—	—
Cal/s	@	5.0	9.62	20	67	1525	0.011	4.05	4.01
BL	@	5.05	9.42	19	68	1875	—	—	—
Cal/s	@	4.975	9.8	20	67	1165	0.022	8.11	7.82
BL	@	5.0	9.48	19	67	1865	—	—	—
Cal/s	@	4.95	9.88	21	67	1135	0.022	8.11	7.82
BL	@	4.975	9.42	20	68	1870	—	—	—
Cal/s	@	4.9	10.02	23	66	810	0.033	12.16	11.88
BL	@	4.975	9.52	20	68	1865	—	—	—
Cal/s	@	4.875	10.06	23	67	775	0.033	12.16	11.88
BL	√ @ √	4.95	9.6	18	68	1820	—	—	—
	@								
	@								
	@								
	@								
	@								

Section

Temperature at ~~in~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1819	2077	1856
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	1829	2088	1861

Innovative Furnace Data Log

Date: 3/27/91

Initials CBE

Test: #N37

NH₃ Rotameter

Setting (BB height): 40

Fuel: NATURAL GAS

Slurry: Ca(OH)₂ Ten Unit

% Excess Air (measured):

SO₂ Rotameter

Setting (BB height): 40

Draft (inches of water): 0.8 - 1.0

Injection Port: 4th lower

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.625	7.06	25	363	1505	—	48	
NSR	@	8.575	7.10	75	250	1500	1.4		12.6
BL	@	8.5	7.08	28	355	1525	—		
BL NSR	@	8.5	7.10	35	380	1600	1.4		
NSR BL	@	8.425	7.20	85	250	1640	— 1.4	↓	
BL Cals	@	8.35	7.18	37	380	1650	—	↓	
6 Cals NSR	@	8.125	7.20	45	395	825	—	(S) 49	
2.5/NSR BL	@	8.125	7.22	100	240	650	1.4	(S) 49	
Cals BL	@	8.125	7.32	40	390	1575	—	48	
BL Cals	@	7.5	7.50	70	405	800	—	(S) 49	
BL Cals	@	8.55	7.02	42	380	750	1.4	(S) 49	Little Blow BACK
BL Cals	@	8.475	7.00	45	382	900	—	(S) 49	"
Cals BL	@	7.85	7.40	55	400	725	—	(S) 49	Little Blow BACK
Cals	@	8.00	7.28	55	394	1675	—	(S) 49	Empty Ash pot
Cals BL	@	7.775	7.42	55	400	700	—	(S) 49	Little Blow BACK
BL	@	7.625	7.66	45	405	1520	—	48	
	@								
	@								

9/4/92 4.58

Section
Temperature at ~~out~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	2.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2042	1680
Finish	2.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2177	1801

Innovative Furnace Data Log

Date: 3/28/91
 Initials: EBC
 Test: N36

NH₃ Rotameter
 Setting (BB height): 80
 Fuel: NATURAL GAS
 Slurry: Ca(OH)₂ Tennant
 % Excess Air (measured): —

SO₂ Rotameter
 Setting (BB height): 40 cbe 35
 Draft (inches of water): 4.2 cbe 1.0
 Injection Port: 5th

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	9.725	6.26	4	213	1290	—	48.2	(15.48%)
CalS	@	9.075	6.5	4	223	175	—	(S) 49	
CalS+NSR	@	9.40	6.32	4	45	125	1.4	(S) 49	
BL	@	9.30	6.84	3	215	1210	—	48.2	
CalS	@	9.425	6.28	4	210	145	—	(S) 49	
CalS+NSR	@	9.35	6.4	4	40	75	1.4	(S) 49	
BL	↓ @ ↓	9.625	6.18	4	205	1340	—	48.2	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Slurry setting $(49 \frac{ml}{min})(1.10 \frac{g}{ml})(.1598) = 8.61 \frac{g}{min}$ Ca(OH)₂ slurry. Section Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 uppe
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2239	1974
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2200	1975

Innovative Furnace Data Log

Date: 3/29/91
 Initials: EBE
 Test: #N39

NH₃ Rotameter
 Setting (BB height): 40
 Fuel: natural gas
 Slurry: Ca(OH)₂ Term Lint
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 35
 Draft (inches of water): 0.9-1.0
 Injection Port: 5th

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	9.90	6.38	12	352	1245	—	48	
Cal/s	@	10.25	6.10	15	342	475	—	(5) 49	9.60
Cal/s+NSR	@	10.875	6.00	30	140	300	1.4	(5) 49	
BL	@	10.925	5.60	6	320	1300	—	48	
Cal/s	@	10.875	5.60	9	318	600	—	(5) 49	
Cal/s+NSR	@	10.825	5.66	19	180	570	1.4	(5) 49	
BL	@	10.875	5.66	14	312	1250	—	48	
NSR	@	10.875	5.78	31	295	1265	1.4	48	
BL	@	10.725	5.70	22	310	1320	—	48	
NSR	@	10.75	5.72	37	298	1325	1.4	48	
BL	√ @ √	10.625	5.74	24	312	1340	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Slurry setting $(49 \frac{\text{ml}}{\text{min}})(1.07 \frac{\text{g}}{\text{ml}})(0.0960) = 5.03 \frac{\text{g}}{\text{min}} \text{ Ca(OH)}_2 \text{ slurry}$

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
tart	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Blocked	2190	1883
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2246	1923

Innovative Furnace Data Log

Date: 4/22/91
 Initials: EDC
 Test: #141

NH₃ Rotameter
 Setting (BB height): 102
 Fuel: NATURAL GAS
 Slurry: Ca(OH)₂
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 90
 Draft (inches of water): 1.0
 Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.875	6.70	19	312	1475	—	48	
Cal/S	@	8.75	6.80	17	325	240	—	(S) 49	14.11
Cal/S+NSR	@	8.625	6.90	32	257	100	1.4	(S) 49	
BL	@	8.85	6.86	21	305	1450	—	48	
Cal/S	@	8.65	6.90	36	300	450	—	(S) 49	
Cal/S+NSR	@	8.625	6.88	43	180	375	1.4	(S) 49	
BL	√ @ √	8.875	6.78	30	295	1450	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Slurry Setting $(49 \frac{ml}{min}) \times (1.09 \frac{g}{ml}) \times (.1471) = 7.86 \frac{g}{min}$ Ca(OH)₂ Slurry
 Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2157	1843
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Out	2080	1716

Innovative Furnace Data Log

Date: 4.3.97
 Initials: CB
 Test: #N42

NH₃ Rotameter 40
 Setting (BB height):
 Fuel: natural GAS
 Slurry: Ca(OH)₂ Turn Lot
 % Excess Air (measured): —

SO₂ Rotameter 42
 Setting (BB height):
 Draft (inches of water): 1.0
 Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.65	7.10	10	374	1505	—	48	alt
cal/s	@	8.75	7.08	15	370	540	—	(S) 48	0 8.2
BL cal/s	@	8.75	7.10	20	370	1540	7.4 ore	(S) 48	
als BL	@	8.50	7.30	15	3735	775	—	(S) 48	0
cal/s + NSR	@	8.85	7.10	40	30	590	1.4	(S) 48	0
BL	@	8.625	7.18	11	375	1625	—	48	
cal/s	@	8.725	7.10	10	376	890	—	(S) 48	0
cal/s + NSR	@	8.625	7.10	42	27	750	1.4	(S) 48	0
BL	@	8.70	7.10	9	370	1575	—	48	
cal/s	@	8.75	7.10	9	372	1250	—	(S) 48.5	0 7.84
cal/s + NSR	@	8.625	7.06	40	30	1175	1.4	(S) 48.5	0
BL	@	8.75	7.08	8	368	1600	—	48	
	@								
	@								
	@								
	@								
	@								
	@								

(Slurry setting #1) = $(48 \frac{ml}{min}) (1.07 \frac{g}{ml}) (0.0820) = 4.21 \frac{g}{min} Ca(OH)_2$ slurry
 (Slurry setting #2) = $(48.5 \frac{ml}{min}) (1.03 \frac{g}{ml}) (0.0384) = 1.92 \frac{g}{min} Ca(OH)_2$ slurry
 Section Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2 ore	3 ore	4 upper
art	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	2153 Inlet	1831 2105	1831
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2153	1701

Innovative Furnace Data Log

Date: 4/4/91
 Initials: EBC
 Test: #243

NH₃ Rotameter
 Setting (BB height): N/A
 Fuel: natural gas
 Slurry: Dry Inj Ca(OH)₂
 % Excess Air (measured): —

SO₂ Rotameter
 Setting (BB height): 33-34
 Draft (inches of water): 1.0
 Injection Port: 6th

	Solvent Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Feeder Setting NO_x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.25 @ 30	8.85	6.98	17		1475			
Calcs	@	8.75	7.0	18		900	0.023	3	
BL	@	8.60	7.08	17		1430			
Calcs	@	8.50	7.10	17		925	0.023	3	
BL	@	8.575	7.10	17		1450			
Calcs	@	8.65	7.10	10		475	0.047	6	5.98
BL	@	8.725	7.02	7		1375			
Calcs	@	8.675	7.04	7		495	0.047	6	
BL	@	8.625	7.06	10		1375 ^{EBC} ₁₃₉₀			
Calcs	@	8.575	7.06	9		310	0.070	9	
BL	@	8.625	7.10	9		1375			
Calcs	@	8.55	7.08	10		275	0.070	9	
BL	√ @ √	8.55	7.08	10		1390			
	@								
	@								
	@								
	@								
	@								

Section
 Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2188	1879
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2189	1872

Innovative Furnace Data Log

Date: 4/9/91

Initials CBC

Test: #114

NH₃ Rotameter

Setting (BB height): n/a

Fuel: NATURAL GAS

SO₂ Rotameter

Setting (BB height): 35^{or} 35

Draft (inches of water): 1.0

Injection Port: 4th upper

Dry Ing

Slurry: CaCO₃ (as received) Temp Lut

% Excess Air (measured):

	serbt Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Feedg setting NO _x OUT Feed Rate (mt/min)	Starting Feed Rate #/min	Ending Feed Rate (#/min)
BL	1.25 @ 30	11.00	5.82	21	75	1175	—	—	—
Calc	@	10.875	6.00	20	75	920	0.010	4.05	—
BL	@	10.95	5.86	12	76	1160	—	—	—
Calc	@	10.875	6.04	5	75	910	0.010	4.05	—
BL	@	10.875	5.90	6	75	1160	—	—	—
Calc	@	10.875	6.20	18	75	615	0.020	8.11	7.95
BL	@	10.825	5.96	3	74	1200	—	—	—
Calc	@	10.725	6.30	3	75	700	0.020	8.11	7.95
BL	@	10.70	6.00	3	75	1200	—	—	—
Calc	@	10.675	6.40	3	75	490	0.030	12.16	—
BL	@	10.70	6.00	3	75	1170	—	—	—
Calc	@	10.75	6.46	6	75	475	0.030	12.16	—
BL	↓ @ ↓	10.65	6.04	7	75	1125	—	—	—
	@								
	@								
	@								
	@								
	@								

Section
Temperature at ~~port~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2047	1731
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	unt	2056	1732

Innovative Furnace Data Log

Date: 4/9/91

Initials: EBE

Test: #N45

NH₃ Rotameter

Setting (BB height): N/A

Fuel: NATURAL GAS

SO₂ Rotameter

Setting (BB height): 35

Draft (inches of water): 0.9-1.0

Injection Port: 5th

Dry Inj Slurry: CaCO₃ (As Received) Tenn Lint
 % Excess Air (measured):

	Subst Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Feed Setting NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.25 @ 30	10.625	6.00	16	76	1225	0.010	6	
Cal's	@	10.55	6.18	18	76	925	0.010	4.05	
BL	@	10.55	5.96	17	75	1225	0.010		
Cal's	@	10.50	6.20	22	75	895	0.010	4.65	
BL	@	10.575	6.02	16	75	1225	0.020		
Cal's	@	10.525	6.30	20	75	650	0.020	8.11	7.95
BL	@	10.60	6.00	19	75	1220			
Cal's	@	10.525	6.30	23	76	625	0.020	8.11	7.95
BL	@	10.60	6.04	21	76	1220			
Cal's	@	10.50	6.42	26	76	450	0.030	12.16	
BL	@	10.60	6.02	23	75	1220			
Cal's	@	10.50	6.40	29	76	430	0.030	12.16	
BL	✓ @ ✓	10.575	6.06	30	75	1225			
	@								
	@								
	@								
	@								
	@								

Section
Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2059	1735
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2083	1776

Innovative Furnace Data Log

Date: 4/17/91

Initials CSL

Test: # N46

NH₃ Rotameter

Setting (BB height): N/A

Fuel: natural gas

Slurry: CaCO₃ (AS Rec.)

% Excess Air (measured): —

SO₂ Rotameter

Setting (BB height): —

Draft (inches of water): 1.0

Injection Port: 3rd middle

	Subst	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL		1.25 @ 30	11.00	5.88	14	60	1300	—		
calc	@		10.875	6.08	15	62	1030	0.011	4.05	4.12
BL	@		10.875	5.94	15	63	1300	—		
calc	@		10.825	6.12	16	64	1050	0.011	4.05	
BL	@		10.825	5.96	16	64	1300	—		
calc	@		10.70	6.24	17	64	800	0.022	8.11	8.61
BL	@		10.725	6.02	18	64	1300	—		
calc	@		10.575	6.40	19	64	750	0.022	8.11	8.61
BL	@		11.025	5.82	20	63	1225	—		
calc	@		10.90	6.44	22	65	520	0.033	12.16	13.00
BL	@		10.975	6.00	17	65	1300	—		
calc	@		10.875	6.46	16	63	610	0.033	12.16	13.00
BL	@		10.95	5.90	16	63	1260	—		
	@									
	@									
	@									
	@									
	@									

Section
Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	1971	1710
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	1966	1710

Innovative Furnace Data Log

Date: 4/15/91

Initials EDC

Test: # N47

NH₃ Rotameter

Setting (BB height): N/A

Fuel: NATURAL GAS

SO₂ Rotameter

Setting (BB height): 44

Draft (inches of water): 1.0

Injection Port: CaCO₃ (as received) Tank-Try

Injection Port: 4th Lower

% Excess Air (measured): _____

	Solvent Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Feeder setting NO OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.25 @ 30	8.875	7.04	19	81	1495	_____	_____	_____
calls	@	8.85	7.20	19	83	1100	0.010	4.05	
BL	@	8.875	7.00	20	84	1440	_____	_____	_____
calls	@	8.85	7.16	20	84	1100	0.010	4.05	
BL	@	8.925	7.04	20	84	1500	_____	_____	_____
calls	@	8.85	7.38	20	84	875	0.020	8.11	
BL	@	8.90	7.06	20	84	1500	_____	_____	_____
calls	@	8.85	7.38	21	85	900	0.020	8.11	
BL	@	8.975	7.10	21	84	1450	_____	_____	_____
calls	@						0.030 ^{0.02}	12.16 ^{0.15}	
BL	@	8.50	7.26	21	86	1600	_____	_____	_____
calls	@	8.45	7.66	25	85	625	0.030	12.16	11.85
BL	✓ @ ✓	8.575	7.20	24	84	1455	_____	_____	_____
calls	@	8.50	7.68	25	84	575	0.030	12.16	11.85
BL	✓ @ ✓	8.6	7.20	25	89	1360	_____	_____	_____
	@								
	@								
	@								

Section
Temperature at ~~Port~~ (°F)

Part	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2064	1825
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2104	1853

Innovative Furnace Data Log

Date: 4/16/91
 Initials: eB
 Test: # 45

NH₃ Rotameter
 Setting (BB height): N/A
 Fuel: NATURAL GAS
~~Calorific Value: CalO₂ (As Received) Term Unit~~
 % Excess Air (measured):

SO₂ Rotameter 44
 Setting (BB height):
 Draft (inches of water): 1/10
 Injection Port: 6th

DW/TS

	Subst Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Freder Setting NO OUT x Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.25 @ 30	8.75	7.20	8	80	1500			
Calcs	@	8.80	7.34	10	82	1125	0.011	4.05	
BL	@	8.85	7.18	10	84	1455			
Calcs	@	8.875	7.30	10	84	1125	0.011	4.05	
BL	@	8.925	7.10	10	84	1470			
Calcs	@	8.875	7.40	14	85	850	0.022	8.11	8.2
BL	@	8.875	7.10	12	85	1460			
eB Calcs	@						0.022	8.11	
BL	@	8.875	7.10	12	85	1520			
Calcs	@	8.85	7.40	17	85	900	0.022	12.16	8.11
BL	@	8.90	7.12	15	85	1500			
Calcs	@	8.75	7.56	16	85	675	0.033	12.16	
BL	✓ @ ✓	8.875	7.14	20	85	1510			
Calcs	@	8.75	7.56	20	86	650	0.033	12.16	
BL	✓ @ ✓	8.85	7.12	20	80	1510			
	@								
	@								
	@								

section
 Temperature at ~~BB~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Backed	2085	1881
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2111	1889

Innovative Furnace Data Log

Date: 4/16/91
 Initials: EBC
 Test: #N49

NH₃ Rotameter
 Setting (BB height): N/A
 Fuel: NATURAL GAS
~~Setting: Dry Dig. CaCO₃ (as Received)~~
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 44
 Draft (inches of water): 1.0 - 1.1
 Injection Port: 7/4

	Substant Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Feeder Setting NO OUT Feed Rate (g/min)	Starting Feed Rate (g/min)	Ending Feed Rate (g/min)
BL	1.25 @ 30	8.80	7.14	22	90	1520	—	—	—
Cals	@	8.625	7.30	25	89	1300	0.011	4.05	—
BL	@	8.65	7.20	25	89	1555	—	—	—
Cals	@	8.60	7.30	28	89	1275	0.011	4.05	—
BL	@	8.70	7.20	26	88	1560	—	—	—
Cals	@	8.65	7.38	29	88	1090	0.022	8.11	8.2
BL	@	8.65	7.22	28	89	1570	—	—	—
Cals	@	8.65	7.38	31	88	1090	0.022	8.11	8.2
BL	@	8.675	7.20	30	88	1575	—	—	—
Cals	@	8.65	7.40	37	88	940	0.033	12.16	—
BL	@	8.70	7.20	34	87	1570	—	—	—
Cals	@	8.65	7.40 ¹⁰	36	88	970	0.033	12.16	—
BL	∨ @ ∨	8.675	7.20	35	88	1550	—	—	—
	@								
	@								
	@								
	@								
	@								

Section
 Temperature at ~~FBH~~ (°F)

Part	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2111	1889
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Out	2121	1896

Innovative Furnace Data Log

Date: 4/17/91

Initials: EDP

Test: #NSO

NH₃ Rotameter
 Setting (BB height): 47
 Fuel: NATURAL GAS
 Slurry: CaCO₃ (ms Received)
 % Excess Air (measured): —

SO₂ Rotameter
 Setting (BB height): 49
 Draft (inches of water): 1.0
 Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.80	7.10	7	375	1490	—	48	
Cals	@	8.75	7.28	5	370	945	—	(S) 49	①
Cals+NSR	@	8.625	7.36	20	145	875	1.4	(S) 49	①
BL	@	8.625	7.12	7	377	1485	—	48	
Cals	@	8.60	7.30	8	379	960	—	(S) 49	①
Cals+NSR	@	8.55	7.34	24	190	940	1.4	(S) 49	①
BL	@	8.675	7.00	10	375	1525	—	48	
Cals	@	8.675	7.12	14	374	1150	—	(S) 50	②
Cals+NSR	@	8.575	7.20	32	198	1150	1.4	(S) 50	②
BL	@	8.675	7.02	16	376	1500	—	48	
Cals	@	8.65	7.10	17	373	1170	—	(S) 50	②
Cals+NSR	@	8.375	7.24	48	110	1075	1.4	(S) 50	②
BL	@	8.70	6.94	23	373	1495	—	48	
Cals	@	8.85	6.96	24	370	1325	—	(S) 49.5	③
Cals+NSR	@	8.725	7.00	42	175	1300	1.4	(S) 49.5	③
BL	@	8.85	6.86	24	372	1475	—	48	
Cals	@	8.80	6.94	25	374	1275	1.4	(S) 49.5	③
Cals+NSR	@	8.60	7.08	48	166	1275	1.4	(S) 49.5	③
BL	√	8.625	6.92	26	375	1585	—	48	Section

Temperature at ~~—~~ (°F)

Part	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2022	1765
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Out	2012	1663

Slurry setting #1) = $(49 \frac{ml}{min})(1.11\%)(.1334) = 7.26 \frac{g}{min} \text{ CaCO}_3 \text{ Slurry}$
 Slurry setting #2) = $(50 \frac{ml}{min})(1.07\%)(.0907) = 4.85 \frac{g}{min} \text{ CaCO}_3 \text{ Slurry}$
 Slurry setting #3) = $(49.5 \frac{ml}{min})(1.04\%)(.0520) = 2.68 \frac{g}{min} \text{ CaCO}_3 \text{ Slurry}$

Innovative Furnace Data Log

Date: 4/18/91
 Initials: EBP
 Test: #N51

NH₃ Rotameter
 Setting (BB height): 58
 Fuel: NATURAL GAS
 Slurry: CaCO₃ (AS RECEIVED) Tumbler
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 39
 Draft (inches of water): 0.9-1.1
 Injection Port: 4th Lower

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	9.50	6.60	7	315	1350	—	48	
CalS	@ 9.15 9.75	9.50	6.68	11	318	1100	—	(S) 49.5	(1)
CalS+NR	@	9.45	6.72	56	49	1025	1.4	(S) 49.5	(1)
BL	@ 9.20 9.75	9.50	6.76	13	318	1325	—	48	
BL	@	9.50	6.58	17	311	1325	—	48	
CalS	@	9.60	6.60	17	314	1050	—	(S) 49.5	(1)
CalS+NR	@	9.625	6.60	69	68	1050	1.4	(S) 49.5	(1)
BL	@	9.725	6.48	19	306	1325	—	48	
CalS	@	9.75	6.56	21	310	850	—	(S) 48.5	(2)
CalS+NR	@	9.60	6.60	75	62	840	1.4	(S) 48.5	(2)
BL	@	9.70	6.42	25	306	1325	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Slurry Setting #1) = $(49.5 \frac{ml}{min})(1.05 \frac{g}{ml})(.0586) = 2.94 \frac{g}{min} \text{ CaCO}_3 \text{ Slurry}$
 Slurry Setting #2) = $(48.5 \frac{ml}{min})(1.08 \frac{g}{ml})(.1144) = 5.99 \frac{g}{min} \text{ CaCO}_3 \text{ Slurry}$ Temperature at ~~port~~ Section (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	1991	1842
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2077	1812

Innovative Furnace Data Log

Date: 4/19/91
 Initials: CBY
 Test: #NS2

NH₃ Rotameter Setting (BB height): 58
 Fuel: NATURAL GAS
 Slurry: CaCO₃ (As Received) Tamm Linton
 % Excess Air (measured): _____

SO₂ Rotameter Setting (BB height): 46
 Draft (inches of water): 0.9-1.1
 Injection Port: 4th LOWER

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.55	6.66	20	327	1460	—	48	
CalS	@ 9.00	8.45	6.80	20	331	975	—	(S) 48.5	0
CalSWR	@	8.95	6.88	20	50	900	1.4	(S) 48.5	0
BL	@	9.15	6.66	20	323	1375	—	48	
CalS	@	9.25	6.76	20	327	930	—	(S) 48.5	0
CalSWR	@ 9.20	9.15	6.80	20	327.5	900	1.4	(S) 48.5	0
BL	@	9.50	6.50	20	321	1400	—	48	
CalS	@	9.25	6.90	20	330	775	—	(S) 49	0
CalSWR	@	9.00	7.04	70	73	750	1.4	(S) 49	0
BL	@	9.075	6.82	20	331	1345	—	48	
CalS	@	8.95	7.10	25	332	615	—	(S) 49	0
CalSWR	@	8.875	7.14	90	45	620	1.4	(S) 49	0
BL	@	9.00	6.90	19	320	1325	—	48	
	@								
	@								
	@								
	@								
	@								

(Slurry setting #1) = (48.5 ml/min) × (1.13 %/ml) × (1180) = 6.47 %/min CaCO₃ Slurry
 (Slurry setting #2) = (49 ml/min) × (1.13 %/ml) × (1539) = 8.52 %/min CaCO₃ Slurry Temperature at Section (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2027	1805
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2088	1830

Innovative Furnace Data Log

Date: 4/22/91
 Initials: EBP
 Test: #153

NH₃ Rotameter Setting (BB height): 35
 Fuel: NATURAL GAS
 Slurry: CaCO₃ (AS Rec) Transport
 % Excess Air (measured):

SO₂ Rotameter Setting (BB height): 50
 Draft (inches of water): 1.0
 Injection Port: 3rd Right

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.80	7.12	10	380	1410	—	48	
calc	@	8.85	7.10	15	373	750	—	(5) 48	(1)
calc/MSR	@	8.75	7.40	36	233	625	1.4	(5) 48	(1)
BL	@	8.75	7.10	40	380	1300	—	48	
calc	@	8.625	7.44	25	379	750	—	(5) 48	(1)
calc/MSR	@	8.50	7.54	40	170	600	1.4	(5) 48	(2) (1)
BL	@	8.825	7.06	25	380	1125	—	48	
BL	@	8.95	7.00	27	378	1375	—	48	
calc	@	8.825	7.24	29	382	900	—	(5) 46	(2)
calc/MSR	@	8.625	7.30	40	290	900	1.4	(5) 46	(2)
BL	@	8.85	7.06	29	382	1200	—	48	
calc	@	8.725	7.30	30	383	875	—	(5) 46	(2)
calc/MSR	@	8.50	7.50	42	250	850	1.4	(5) 46	(2)
BL	@	8.75	7.20	25	378	1250	—	48	
	@								
	@								
	@								
	@								

(Slurry setting #1) = $(48 \frac{ml}{min}) (1.14 \frac{lb}{ft^3}) (1801) = 9.86 \frac{lb}{min} CaCO_3$ slurry
 (Slurry setting #2) = $(46 \frac{ml}{min}) (1.09 \frac{lb}{ft^3}) (11078) = 5.41 \frac{lb}{min} CaCO_3$ slurry
 Section Temperature at ~~Exit~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Behind	1953	1802
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	1882	1675

Innovative Furnace Data Log

Date: 4/23/91
 Initials: gdc
 Test: #NS4

NH₃ Rotameter Setting (BB height): 33
 Fuel: natural gas
 Slurry: CaCO₃ (as Rec.) Tenn. Lut.
 % Excess Air (measured):

SO₂ Rotameter Setting (BB height): 62
 Draft (inches of water): 1.0
 Injection Port: 3rd Right

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	9.125	6.90	20	365	1475	—	48	
cal/s	@	9.10	7.12	21	366	1025	—	(S) 49	0
cal+NSR	@	8.975	7.20	35	250	1000	1.4	(S) 49	0
BL	@	9.10	7.00	22	361	1405	—	48	
cal/s	@	9.00	7.28	19	360	1025 1050	—	(S) 49	0
cal+NSR	@	8.875	7.30	25	250	1025	1.4	(S) 49	0
BL	@	9.00	7.10	15	360	1475	—	48	
cal/s	@	9.00	7.20	15	363	1240	—	(S) 50	0
cal+NSR	@	8.90	7.28	25	245	1200	1.4	(S) 50	0
B2	@	9.05	7.00	16	362	1445	—	48	
cal/s	@	8.95	7.22	19	360	1250	—	(S) 50	0
cal+NSR	@	8.875	7.26	25	260	1225	1.4	(S) 50	0
BL	√ @ √	9.025	7.00	18	363	1475	—	48	
	@								
	@								
	@								
	@								
	@								

(Slurry setting #1) = $(49 \frac{\text{ml}}{\text{min}})(1.09 \frac{\text{lb}}{\text{ft}^3})(1.087) = 5.81 \frac{\text{lb}}{\text{min}} \text{ CaCO}_3 \text{ Slurry}$

(Slurry setting #2) = $(50 \frac{\text{ml}}{\text{min}})(1.05 \frac{\text{lb}}{\text{ft}^3})(0.661) = 3.47 \frac{\text{lb}}{\text{min}} \text{ CaCO}_3 \text{ Slurry}$ Temperature at ~~exit~~ ^{Section} (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.87 @ 2	— @ —	burned	1989	1843
Finish	4.58 @ 45	1.0 @ 45	0.87 @ 2	— @ —	out	1889	1693

Innovative Furnace Data Log

Date: 4/25/91

Initials: EBE

Test: #255

NH₃ Rotameter

Setting (BB height): N/A

Fuel: NATURAL GAS

~~Supply:~~ Dry Int: Less than 10 ppm CO₂

% Excess Air (measured):

SO₂ Rotameter

Setting (BB height): 45

Draft (inches of water): 1.0

Injection Port: 5th

Feeds not.	Solvent Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Feeder Setting NO OUT Feed Rate (min /min)	Starting Feed Rate (min /min)	Ending Feed Rate (min /min)
	BL 1.25 @ 30	9.05	7.10	16	75	1425	—	—	—
	Calc @	8.975	7.28	18	78	845	0.031	4.05	—
	BL @	8.85	7.32	11	78	1425	—	—	—
	Calc @	8.975	7.48	10	80	930	0.031	4.05	2.90
	BL @	8.925	7.30	5	80	1340	—	—	—
	Calc @	8.875	7.46	5	80	925	0.031 0.067 ⁵⁰⁰	8.11 4.05	2.90
	BL @	8.925	7.30	3	80	1320	—	—	—
	Calc @	8.85	7.58	5	80	580	0.063	8.11	6.28
	BL @	9.10	7.04	0	80	1525	—	—	—
	Calc @	9.00	7.40	0	81	625	0.063 0.095 ⁵⁰⁰	8.11 12.16	6.28
	BL @	9.10	7.10	0	81	1310	—	—	—
	Calc @	8.95	7.54	2	81	340	0.095	12.16	9.44
	BL @	9.05	7.10	5.2%	81	1250	—	—	—
	Calc @	8.90	7.50	3	82	390	0.095	12.16	9.44
	BL @	8.95	7.12	3	83	1525	—	—	—
	@								
	@								
	@								

@ Section
Temperature at Port (°F)

Port	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2080	1869
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2108	1875

Innovative Furnace Data Log

Date: 4/26/91
 Initials: ebc
 Test: #152

NH₃ Rotameter
 Setting (BB height): 33
 Fuel: natural gas
 Slurry: Less than 10 μm CaCO₃
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 51
 Draft (inches of water): 1.0
 Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.90	7.10	11	330	1410	—	48	
Cal's	@	8.625	7.40	13	330	690	—	(5) 50	
Cal's/MSR	@	8.575	7.52	22	125	600	1.4	(5) 50	
BL	@ 8.625	8.625	7.44	18	330	750	—	48	
Cal's	@	8.65	7.46	18	335	750	—	(3) 50	
Cal's/MSR	@	8.55	7.50	31	145	775	1.4	(5) 50	
BL	@	8.70	7.20	20	335	1375	—	48	
	@		7.20						
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Slurry setting = $(50 \frac{ml}{min})(1.11 \frac{g}{ml})(.1477) = 8.20 \frac{g}{min}$ CaCO₃ Slurry (Less than 10 μm) section
 Temperature at ~~Point~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2095	1853
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2073	1806

Innovative Furnace Data Log

Date: 4/26/91

Initials: ESC

Test: #257

NH₃ Rotameter

Setting (BB height): 32

Fuel: natural gas

Slurry: less than 10µm CaCO₃

% Excess Air (measured):

SO₂ Rotameter

Setting (BB height): 55

Draft (inches of water): 1.0

Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.80	7.12	14	338	1525	—	48	
cal/s	@	9.00	7.10	15	323	805	—	(S) 49	(C) 1
cal/s MSR	@	8.925	7.20	34	75	840	1.4	(S) 49	(C) 1
BL	@	9.25	6.80	15	320	1450	—	48	
cal/s	@	8.975	7.12	20	330	990	—	(S) 49	(C) 1
cal/s MSR	@	8.85	7.28	33	85	1000	1.4	(S) 49	(C) 1
BL	@	8.95	7.04	20	325	1495	—	48	
cal/s	@	9.125	7.00	20	325	1315	—	(S) 50	(C) 2
cal/s MSR	@	9.00	7.04	29	170	1280	1.4	(S) 50	(C) 2
BL	@	9.125	6.90	21	325	1550	—	48	
cal/s	@	9.225	6.82	22	326	1355	—	(S) 50	(C) 2
cal/s MSR	@	9.15	6.98	30	270	1325	1.4	(S) 50	(C) 2
BL	✓ @ ✓	9.10	7.00	23	326	1515	—	48	
	@								
	@								
	@								
	@								
	@								

Slurry setting #1 = $(49 \frac{ml}{min}) (1.08 \frac{in}{in}) (1.0892) = 4.72 \frac{g}{min} \text{ CaCO}_3 \text{ Slurry } (>10\mu m)$ Section
 Slurry setting #2 = $(50 \frac{ml}{min}) (1.04 \frac{in}{in}) (1.0532) = 2.77 \frac{g}{min} \text{ CaCO}_3 \text{ Slurry } (>10\mu m)$ Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2068	1775
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2045	1708

Innovative Furnace Data Log

Date: 4/29/91

Initials EBP

Test: # N58

NH₃ Rotameter

Setting (BB height): N/A

Fuel: NATURAL GAS

Slurry: 75µm > CaCO₃ > 25µm

% Excess Air (measured):

SO₂ Rotameter

Setting (BB height): 52

Draft (inches of water): 1.0

Injection Port: 544

e/c	scrub Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	Feeder Setting		Starting Feed Rate (g/min)	Ending Feed Rate (g/min)
							NO _x OUT Feed Rate (m ³ /min)	e/c		
BL	1.25 @ 30	8.70	7.28	6	86	1445	—	—	—	—
calc	@	8.775	7.38	6	85	1070	0.013	4.05		
BL	@	8.50	7.40	7	87	1420	—	—	—	—
calc	@	8.75	7.30	7	87	1100	0.013	4.05		
BL	@	8.60	7.34	8	85	1400	—	—	—	—
calc	@	8.50	7.70	8	86	865	0.026	8.11	8.24	
BL	@	8.60	7.34	3	87	1390	—	—	—	—
calc	@	8.50	7.70	0	88	825	0.026	8.11	8.24	
BL	@	8.60	7.36	3	87	1465	—	—	—	—
calc	@	8.75	7.66	0	87	675	0.039	12.16		
BL	@	8.75	7.22	0	88	1375	—	—	—	—
calc	@	8.60	7.76	0	89	640	0.039	12.16		
calc	@	8.825	7.14	0	88	1225	—	—	—	—
	@									
	@									
	@									
	@									
	@									
	@									

Section
Temperature at Exit (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2120	1917
Finish	4.8 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2133	1916

Innovative Furnace Data Log

Date: 5/2/91
 Initials EBE
 Test: #259

NH₃ Rotameter
 Setting (BB height): 33
 Fuel: natural gas
 Slurry: 75µm > CaCO₃ > 25µm
 % Excess Air (measured): —

SO₂ Rotameter
 Setting (BB height): 64
 Draft (inches of water): 0.9-1.1
 Injection Port: 9th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	W03 @ 70	8.95	7.02	14	334	1415	—	48	
Cal/s	@	8.975	7.24	14	334	970	—	(S) 50.5	①
Cal/stair	@	8.75	7.32	23	184	950	1.4	(S) 50.5	①
BL	@	8.85	7.06	17	335	1275	—	48	
Cal/s	@	8.75	7.30	17	338	950	—	(S) 50.5	①
Cal/stair	@	8.55	7.46	29	155	875	1.4	(S) 50.5	①
BL	@	8.775	7.10	18	339	1385	—	48	
Cal/s	@	9.125	6.99	18	335	1090	—	(S) 51.5	②
Cal/stair	@	9.00	7.06	29	175	1070	1.4	(S) 51.5	②
BL	@	8.875	7.04	18	335	1300	—	48	
Cal/s	@	8.85	7.12	19	335	1160	—	(S) 51.5	②
Cal/stair	@	8.725	7.20	31	160	1150	1.4	(S) 51.5	②
BL	@	8.825	7.06	18	337	1275	—	48	
Cal/s	@	8.85	7.08	18	340	1225	—	(S) 51.5	③
Cal/stair	@	8.625	7.18	33	165	1225	1.4	(S) 51.5	③
BL	@	8.75	7.08	19	340	1325	—	48	
Cal/s	@	8.825	7.06	19	340	1240	—	(S) 51.5	③
Cal/stair	@	8.70	7.18	38	135	1230	1.4	(S) 51.5	③
BL	@	8.725	7.06	20	343	1370	—		

Section
 Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	10 @ 45	0.82 @ 2	— @ —	Burned	2009	1760
Finish	4.58 @ 45	10 @ 45	0.82 @ 2	— @ —	out	2011	1655

(S.S.#1) = (50.5) (1.132) (0.1568) = 8.95 % CaCO₃ slurry 75µm > CaCO₃ > 25µm
 (S.S.#2) = (51.5) (1.062) (0.0811) = 4.43 % CaCO₃ " " " "
 (S.S.#3) = (51.5) (1.042) (0.0476) = 2.55 % CaCO₃ " " " "

Innovative Furnace Data Log

Date: 5/3/91

Initials CBP

Test: #N60

NH₃ Rotameter Setting (BB height): 32

Fuel: NATURAL GAS

Slurry: CaO (Tanner hwt)

% Excess Air (measured):

SO₂ Rotameter Setting (BB height): 67

Draft (inches of water): 1.0

Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
~BL	103@70	9.10	7.02	18	330	1410	—	48	
Calcs	@	8.875	7.00	18	335	600	—	(5) 52	(1)
Calcs+SR	@	8.875	7.06	27	110	600	1.4	(5) 52	(1)
BL	@	8.775	7.12	24	340	1400	—	48	*
Calcs	@	8.75	7.08	25	330	900	—	(5) 52	(1)
Calcs+SR	@	8.625	7.20	35	125	825	1.4	(5) 52	0
BL	@	8.625	7.22	30	331	1400	—	48	
Calcs	@	8.575	7.22	30	330	920	—	(5) 52	(2)
Calcs+SR	@	8.55	7.26	39	125	920	1.4	(5) 52	(2)
BL	@	8.475	7.28	34	339	1440	—	48	
Calcs	@	8.485	7.30	34	335	990	—	(5) 52	(2)
Calcs+SR	@	8.40	7.32	43	140	890	1.4	(5) 52	(2)
BL	@	8.825	7.06	39	326	1420	—	48	
Calcs	@	8.80	7.10	38	328	1210	—	(5) 52.5	(2)
Calcs+SR	@	8.775	7.08	45	125	1200	1.4	(5) 52.5	(2)
BL	@	8.70	7.08	45	324	1500	—	48	.
Calcs	@	8.725	7.08	41	320	1350	—	(5) 52.5	(3)
Calcs+SR	@	8.55		43	225	1445	1.4	(5) 52.5	(3)
BL	✓	8.75		43	325	1475	—	48	

Temperature at ^{Section} Pot (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2051	1835
Finish	4.56 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2022	1681

(slurry setting #1) = (52 ~~ml~~) (1.11 %e) (1.546) = 8.92 % CaO Slurry
 (slurry setting #2) = (52 ~~ml~~) (1.06 %e) (0.862) = 4.75 % CaO Slurry
 (slurry setting #3) = (52 ~~ml~~) (1.05 %e) (0.628) = 3.46 % CaO Slurry

Innovative Furnace Data Log

Date: 5/16/91

Initials: ebc

Test: #N101

NH₃ Rotameter Setting (BB height): 32

SO₂ Rotameter Setting (BB height): 66

Fuel: NATURAL GAS

Draft (inches of water): 0.9-1.1

Slurry: Terminant (As Rec) CaCO₃

Injection Port: 4th upper

% Excess Air (measured): —

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.975	7.10	15	335	1385	—	48	
Cal/s	@	8.975	7.30	16	335	940	—	(S) 49	(1)
Cal/sensor	@	8.90	7.34	28	183	925	1.4	(S) 49	(1)
BL	@	8.80	7.20	16	345	1475	—	48	
Cal/s	@	8.75	7.32	20	340	1275	—	(S) 49.5	(2)
Cal/sensor	@	8.525	7.42	37	195	1240	1.4	(S) 49.5	(2)
BL	@	8.90	7.08	25	335	1425	—	48	
Cal/s	@	8.85	7.20	30	338	1220	—	(S) 49.5	(2)
Cal/sensor	@	8.80	7.26	45	200	1220	1.4	(S) 49.5	(2)
BL	@	8.75	7.14	32	345	1525	—	48	
Cal/s	@	8.50 8.98	7.38	33 200	140 330	1425	—	(S) 50	(3)
Cal/sensor	@	8.50	7.36	56	140	1525 1400	1.4	(S) 50	(3)
BL	@	8.625	7.24	35	355	1525	—	48	
	@								
	@								
	@								
	@								
	@								

Section Temperature at PER (°C)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 up
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	1997	17
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	1996	165

$(SS \#1) = (49 \frac{ml}{min}) (1.11 \frac{g}{cc}) (.124) = 7.02 \text{ g/min CaCO}_3 \text{ Slurry}$
 $(SS \#2) = (49.5 \frac{ml}{min}) (1.07 \frac{g}{cc}) (.0823) = 4.34 \text{ g/min CaCO}_3 \text{ Slurry}$
 $(SS \#3) = (50 \frac{ml}{min}) (1.05 \frac{g}{cc}) (.0509) = 2.67 \text{ g/min CaCO}_3 \text{ Slurry}$

Innovative Furnace Data Log

Date: 5/14/91

Initials EBC + w.H

Test: #N62

NH₃ Rotameter
Setting (BB height): 32

Fuel: NATURAL GAS

Slurry: 25 ppm > CaCO₃ > 25 ppm

% Excess Air (measured):

SO₂ Rotameter
Setting (BB height): 50

Draft (inches of water): 0.9-1.0

Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	7.50	7.90	22	370	1650	—	48	
Cals	@	7.575	8.10	21	370	935	—	(S) 48.5	⓪
Cals+USR	@	7.50	8.18	35	300	875	1.4	(S) 48.5	⓪
BL	@	7.625	7.74	40	360	1575	—	48	
Cals	@	7.575	8.00	40	365	950	—	(S) 48.5	⓪
Cals+USR	@	7.475	8.10	55	265	935	1.4	(S) 48.5	⓪
BL	@	7.575	7.76	43	360	1475	—	48	
Cals	@	7.55	7.88	44	357	1200	—	(S) 50	⓪
Cals+USR	@	7.45	7.94	58	255	1175	1.4	(S) 50	⓪
BL	@	7.45	7.80	49	365	1505	—	48	
Cals	@	7.40	7.92	50	368	1185	—	(S) 50	⓪
Cals+USR	@	7.325	7.98	63	260	1175	1.4	(S) 50	⓪
BL	√ @ √	7.40	7.82	50	359	1475	—	48	
	@								
	@								
	@								
	@								
	@								

Temperature at ^{section} Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.87 @ 2	— @ —	Burned	2052	1794
Finish	4.58 @ 45	1.0 @ 45	0.87 @ 2	— @ —	out	2039	1714

(SS#1) = $(48.5 \frac{ml}{min}) (1.13 \frac{g}{ml}) (1513) = 8.29 \frac{g}{min}$ CaCO₃ Slurry

(SS#2) = $(50 \frac{ml}{min}) (1.06 \frac{g}{ml}) (0.857) = 4.54 \frac{g}{min}$ CaCO₃ Slurry

Innovative Furnace Data Log

Date: 5/15/98

Initials: ERC

Test: #N63

NH₃ Rotameter Setting (BB height): 32

Fuel: natural gas

Slurry: 25µm > CaCO₃ > 25µm

% Excess Air (measured): 1

SO₂ Rotameter Setting (BB height): 52

Draft (inches of water): 0.9-1.0

Injection Port: 4th ~ 1/2" dia

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.00	7.60	30	355	1575	—	48	
cat/s	@	8.075	7.69	36	352	1320	—	(S) 50	
cat+MSR	@	7.975	7.70	53	168	125	1.4	(S) 50	
BA	@	8.15	7.52	50	355	1575	—	48	
cat/s	@	8.075	7.62	55	350	1375	—	(S) 50	
cat+MSR	@	8.00	7.66	80	200	1360	1.4	(S) 50	
BL	@	8.15	7.48	75	250	1600	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Slurry setting = $(50 \frac{ml}{min}) (1.05 \%) (.0529) = 2.78 \%$ CaCO₃ slurry reaction
 Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.8 @ 2	— @ —	Burned	2056	1776
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2043	1710

Innovative Furnace Data Log

Date: 5/16/91
 Initials: EBP
 Test: #N64

NH₃ Rotameter
 Setting (BB height): 32-33
 Fuel: NATURAL GAS
 Slurry: CaO (Tenn LMT)
 % Excess Air (measured): _____

SO₂ Rotameter
 Setting (BB height): 47-48
 Draft (inches of water): 0.9-1.0
 Injection Port: 4 1/2 upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.625	7.28	56	330	1510	—	48	
Cal's	@	8.525	7.24	60	330	400	—	(5) 50.5	(1)
Cal's + WSR	@	8.40	7.34	80	135	125	1.4	(5) 50.5	(1)
BL	@	8.475	7.32	62	330	1525	—	48	
Cal's	@	8.40	7.32	63	325	400	—	(5) 50.5	(1)
Cal's + WSR	@	8.275	7.32	80	113	375	1.4	(5) 50.5	(1)
BL	@	8.40	7.34	65	325	1560	—	48	
Cal's	@	8.375	7.32	69	328	715	—	(5) 51	(2)
Cal's + WSR	@	8.25	7.42	90	80	500	1.4	(5) 51	(2)
BL	@	8.425	7.32	65	325	1585	—	48	
Cal's	@	8.35	7.32	65	325	800	—	(5) 51	(2)
Cal's + WSR	↓ @ ↓	8.25	7.36	80	100	625	1.4	(5) 51	(2)
BL	@	8.35	7.34	69	326	1610	—	48	
	@								
	@								
	@								
	@								
	@								

section
 Temperature at ~~Exit~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	<i>in</i>	2014	175.
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	<i>out</i>	2024	1678

(SS#1) = $(50.5 \frac{ml}{min}) (1.09 \%)(11382) = 7.61 \% \text{ CaO "Slurry"}$

(SS#2) = $(51 \frac{ml}{min}) (1.05 \%)(.0941) = 4.88 \% \text{ CaO "Slurry"}$

Innovative Furnace Data Log

Date: 6/3/91

Initials: EBC, AD, KRB, WH

Test: *NGS

NH₃ Rotameter

Setting (BB height): 32

Fuel: NATURAL GAS

Slurry: Ca(OH)₂

% Excess Air (measured): _____

SO₂ Rotameter

Setting (BB height): 43

Draft (inches of water): 1.0

Injection Port: 4th lance

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	7.70	7.54	22	331	1585	—	48	
cuts	@						20.5	39.5	90C
CalstrsR	91-06-03-01	7.475	7.50	83	50	550	7.0	39.5	
c BL	@						—	48	90C
CalstrsR	91-06-03-02	7.50	7.60	73	45	562.50	7.0	39.5	
BL	91-06-03-02	7.625	7.60	18	336	1450	—	* Flow RATE	
	@								WAS never reset
	@								FOR 48 ml/min
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Slurry settings = $(39.5 \frac{ml}{min}) (1.09 \frac{g}{L}) (1.444) = 6.22 \frac{g}{min}$ CalOR slurry Section
Temperature at ~~exit~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned		
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out		

107.59

Innovative Furnace Data Log

Date: 6/4/91

Initials: EBE

Test: #N66

NH₃ Rotameter

Setting (BB height): 43-4 ^{EBE} 32

Fuel: NATURAL GAS

Slurry: Ca(OH)₂

% Excess Air (measured): —

SO₂ Rotameter

Setting (BB height): 43-44

Draft (inches of water): 1.0

Injection Port: 4th Lower

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	7.875	7.50	15	340	1570	—	48	
Caps	@	7.775	7.50	20	338	325	—	(S) 47	
Calst+NR	@	7.675	7.56	80	45	250	1.4	(S) 47	
BL	@	7.75	7.60	15	340	1400	—	48	
CalS	@	7.725	7.60	22	340	515	—	(S) 47	
Calst+NR	@	7.675	7.58	65	60	550	1.4	(S) 47	
BL	@	7.725	7.60	16	335	1430	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Section
Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Paused	2113	1776
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Out	2122	1792

Slurry setting = $(47 \frac{\text{ml}}{\text{min}}) (1.10 \frac{\text{g}}{\text{ml}}) (.1455) = 7.52 \text{ g/min Ca(OH)}_2 \text{ Slurry}$

Innovative Furnace Data Log

Date: 6/5/91
 Initials: PBP
 Test: #N67

NH₃ Rotameter
 Setting (BB height): 34-35
 Fuel: Natural Gas
 Slurry: Ca(OH)₂
 % Excess Air (measured): —

SO₂ Rotameter
 Setting (BB height): 44-43'
 Draft (inches of water): 1.0
 Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.09 @ 70	7.75	7.62	20	340	1625	—	48	91-06-05-01
oils	@	7.60	7.60	19	355	500	—	(S) 47.5	
CalcWSR	@	7.475	7.70	45	135	125	1.4	(S) 47.5	91-06-05-02
CalcWSR	@						1.4	47.5(S)	91-06-05-03
BL	@						—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Section
 Temperature at Point (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Bulged	2072	1707
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2091	1689

(Slurry settings) = $(47.5 \frac{\text{ml}}{\text{min}}) (1.10 \frac{\text{g}}{\text{ml}}) (1.482) = 7.74 \frac{\text{g}}{\text{min}} \text{ Ca(OH)}_2 \text{ slurry}$

Innovative Furnace Data Log

Date: 6/7/81

Initials: CBT

Test: #N68 / #N69

NH₃ Rotameter 4u | 3m

Setting (BB height): 35 | 35

Fuel: natural gas

Slurry: calc Ca(OH)₂

% Excess Air (measured): _____

SO₂ Rotameter

Setting (BB height): 4u | 3m
40 | 44

Draft (inches of water): 1.0

Injection Port: 4th upper | 3rd middle

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	8.675	7.08	13	325	1520	—	48	91-06-07-
calc	@	8.75	6.98	12	325	350	—	(S) 41.5	0
calc usage	@ 8.525	10.00	7.12	20	262	275	6.5	(S) 41.5	91-06-07-C
	@						—		
	@								
	@	TEST # N69							
	@								
BL	1.03 @ 70	8.625	7.10	14	355	1550	—	47.5	91-06-07-
calc	@	8.625	7.10	12	360	475	—	(S) 41	0
calc usage	@	8.50	7.04	18	390	400	6.5	(S) 41	91-06-07-
	@						—	—	
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Section
Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	burned	2047	1649
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2051	1600

Slurry setting #1) = $(41.5 \frac{ml}{min}) (1.11 \frac{g}{ml}) (.1481) = 6.82 \frac{g}{min} Ca(OH)_2$

Slurry setting #2) = $(41.0 \frac{ml}{min}) (1.08 \frac{g}{ml}) (.1418) = 6.28 \frac{g}{min} Ca(OH)_2$

Innovative Furnace Data Log

Date: 6/10/91
 Initials: EBZ
 Test: #70

NH₃ Rotameter
 Setting (BB height): 38
 Fuel: Natural Gas
 Slurry: Ca(OH)₂
 % Excess Air (measured): _____

SO₂ Rotameter
 Setting (BB height): 45
 Draft (inches of water): 1.0
 Injection Port: 5th

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	@	7.825	7.50	20	357	1575	—	48	91-06-10-01
	@								
CalS	@	7.825	7.40	27	355	325	—	(S) 42.5	
	@								
CalSynse	@	7.475	7.60	30	80	725	6.5	(S) 42.5	91-06-10-02
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Section
 Temperature at ~~BAR~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2170	1882
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	CUT	2171	1885

Slurry setting = $(42.5 \frac{\text{ml}}{\text{min}})(1.10\%)(.1439) = 6.73 \frac{\text{g}}{\text{min}} \text{ Ca(OH)}_2$

Innovative Furnace Data Log

Date: 6/11/91

Initials: CBP

Test: #71/#725th 4L

52 | 4L

NH₃ Rotameter
Setting (BB height): 37 | 37

SO₂ Rotameter
Setting (BB height): 52 | 49

Fuel: natural gas

Draft (inches of water): 1.0

Slurry: N/A

Injection Port: 5th

% Excess Air (measured): —

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	7.875	7.42	14	352	1565	—	48	91-06-11-01
	@				120				
NSR	1.03 @ 70	7.725	7.50	110	1100	1675	5.5	44	91-06-11-02
	@								
	@								
BL	1.03 @ 70	7.90	7.40	14	345	1615	—	47.9	91-06-11-03
	@								
NSR	1.03 @ 70	7.85	7.46	80	90	1625	5.5	44	91-06-11-04
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Section
Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2108	1772
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	OUT	2134	1818

Innovative Furnace Data Log

Date: 6/12/91

Initials: EBE

Test: #N 73 + #N 74 4u | 3m

NH₃ Rotameter Setting (BB height): 35 | 35

Fuel: NATURAL GAS

Slurry: N/A

% Excess Air (measured): -

SO₂ Rotameter Setting (BB height): 52 | 45

Draft (inches of water): 1.0

Injection Port: 4u | 3m

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT [†] Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	7.65	7.62	16	373	1650	—	48	91-06-12-01
	@								
MSR	1.03 @ 70	7.50	7.62	31	293	1720	5.5	44	91-06-12-02
	@								
	@								
	@								
BL	1.03 @ 70	7.625	7.52	21	388	1525	—	48	91-06-12-01
	@								
MSR	1.03 @ 70	7.45	7.60	33	388	1570	5.2	44	91-06-12-01
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Section
Temperature at ~~Point~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2068	1683
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	1965	1571

Innovative Furnace Data Log

1403E
 Date: 6/15/91
 Initials: EBE
 Test: #n75

NH₃ Rotameter
 Setting (BB height): n/A
 Fuel: Pitts #8 (26.3 g/min)
 Slurry: Ca(OH)₂
 % Excess Air (measured): +

SO₂ Rotameter
 Setting (BB height): N/A
 Draft (inches of water): 1.0
 Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT ^A Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	10.45	9.20	150	385	800	—	48	91-06-15-0
	@								19
CalS	1.03 @ 70	10.325	9.20	168	385	275	—	(S) 44.5	
	@								
also NSR	1.03 @ 70	10.375 10.125	9.20	600	160	250	4.3	(S) 44.5	91-06-15-0
	@								
	@								
	@								
	@								
CalS NSR	1.03 @ 70	10.25	9.20	650	250	250	1.4	(S) 44.5	91-06-14-03
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Not out #

Slurry setting = $(44.5 \frac{\text{ml}}{\text{min}}) (1.08 \frac{\text{g}}{\text{ml}}) (.1487) = 7.15 \frac{\text{g}}{\text{min}}$ Cal(OH)₂ Slurry
 Temperature at ~~Exit~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	0.95 @ 45	0.8 @ 45	— @ —	1.59 @ 30	Burned	1891	1445
Finish	0.95 @ 45	0.8 @ 45	— @ —	1.59 @ 30	out	1917	1402

Innovative Furnace Data Log

Date: 6/17/91
 Initials: EBZ
 Test: #N76

NH₃ Rotameter
 Setting (BB height): N/A
 Fuel: Pits #8 coal (26.7 g/min)
 Slurry: Ca(OH)₂
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): N/A
 Draft (inches of water): 1.0
 Injection Port: 4th lower

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	10.375	9.20	60	365	750	—	48	91-06-17-01
	@								
CalS	1.03 @ 70	10.575	8.96	100	380	75	—	(S) 44	
	@								91-06-17-
CalSR	1.03 @ 70	10.75	8.70	320	285	100	1.4	(S) 44	91-06-17-01
	@								
	@						Not out AT		
	@								
ANSR2	1.03 @	10.625	8.60	160	280	100	4.3	(S) 44	91-06-17-01
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Section
 Temperature at ~~Port~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	0.95 @ 45	08 @ 45	— @ —	1.60 @ 30	Burned	1998	1694
Finish	0.95 @ 45	08 @ 45	— @ —	1.60 @ 30	out	2001	1676

(Slurry. Setting) = $(44 \frac{\text{ml}}{\text{min}})(1.07 \frac{\text{g}}{\text{ml}})(1.121) = 5.28 \frac{\text{g}}{\text{min}} \text{ Ca(OH)}_2 \text{ slurry}$

Innovative Furnace Data Log

Date: 6/18/91

Initials: ERL

Test: *N77, *N78, *N79
5 | 4L | 4U

NH₃ Rotameter Setting (BB height): 30 | 30 | 30

Fuel: WAWM GAS

Slurry: N/A

% Excess Air (measured): —

SO₂ Rotameter Setting (BB height): 51 | 45 | 45

Draft (inches of water): 1.0

Injection Port: 5th, 4th lower, 4th upper

(176ml Nitrogen A)
(1824ml D₂ H₂)

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT ^A Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)	
M BL	1.03 @ 70	8.725	6.90	0	380	1475	—	48	91-06-18	-01
	@									
NSR	1.03 @ 70	8.825	6.90	30	250	1535	10	38.5	91-06-18	-02
	@									
	@									
	@									
L BL	1.03 @ 70	8.75	6.84	15	383	1500	—	48.5	91-06-18	-03
	@									
NSR	1.03 @ 70	8.75	6.90	55	180	1525	10	38.5	91-06-18	-04
	@									
	@									
BL	1.03 @ 70	8.725	6.92	10	388	1500	—	48	91-06-18	-0
	@									
NSR	1.03 @ 70	9.125	6.76	45	180	1500	10	39	91-06-18	-0
	@									
	@									
	@									
	@									

Temperature at ^{Section} Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Barred	2039	1671
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2086	1710

Innovative Furnace Data Log

Date: 6 / 19 / 91

Initials: CBC

Test: #A80, #A81, #A82

NH₃ Rotameter

Setting (BB height): 3M | 3R | 2R

Fuel: NATURAL GAS

Slurry: TV/A

% Excess Air (measured): —

SO₂ Rotameter

Setting (BB height): 47 | 43 | 38

Draft (inches of water): 0.9-1.0-1.1

Injection Port: 3M, 3R, 2R

(17mm rotameter)
(1824mm) D.I. flow

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT # Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
<u>BL</u>	<u>1.03 @ 70</u>	<u>8.45</u>	<u>6.80</u>	<u>15</u>	<u>389</u>	<u>1525</u>	<u>—</u>	<u>48</u>	<u>91-06-19-01</u>
	@								
<u>NSR</u>	<u>1.03 @ 70</u>	<u>9.00</u>	<u>6.78</u>	<u>44</u>	<u>98</u>	<u>1575</u>	<u>10</u>	<u>38</u>	
	@								
	@								
<u>BL</u>	<u>1.03 @ 70</u>	<u>8.325</u>	<u>7.20</u>	<u>20</u>	<u>395</u>	<u>1550</u>	<u>—</u>	<u>48</u>	<u>91-06-19-0</u>
	@								
<u>NSR</u>	<u>1.03 @ 70</u>	<u>8.95</u>	<u>6.86</u>	<u>46</u>	<u>100</u>	<u>1525</u>	<u>10</u>	<u>38-38</u>	<u>91-06-19-</u>
	@								
	@								
<u>BL</u>	<u>1.03 @ 70</u>	<u>8.95</u>	<u>6.80</u>	<u>18</u>	<u>370</u>	<u>1445</u>	<u>—</u>	<u>48.5</u>	<u>91-06-19-02</u>
	@								
<u>NSR</u>	<u>1.03 @ 70</u>	<u>8.875</u>	<u>6.86</u>	<u>28</u>	<u>260</u>	<u>1625</u>	<u>10</u>	<u>39</u>	<u>91-06-19-06</u>
	@								
	@								
	@								
	@								
	@								

Temperature at Section (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	<u>4.58 @ 45</u>	<u>1.0 @ 45</u>	<u>0.82 @ 2</u>	<u>— @ —</u>	<u>Blind</u>	<u>1913</u>	<u>1531</u>
Finish	<u>4.58 @ 45</u>	<u>1.0 @ 45</u>	<u>0.82 @ 2</u>	<u>— @ —</u>	<u>ant</u>	<u>1794</u>	<u>1430</u>

Innovative Furnace Data Log

Date: 9/17/91

Initials: ABC + WH

Test: CNI

NH₃ Rotameter

Setting (BB height): 15.5

Fuel: NATURAL GAS

Slurry: H₂O

% Excess Air (measured):

SO₂ Rotameter

Setting (BB height): 127

Draft (inches of water): 1.0

Injection Port: 5th

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	H ₂ O Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)	SH %
BL	1.03 @ 70	11.46	5.08	12.78	268.65	1154.1	—	48		91
NSR	@	11.52	5.06	23.53	198.25	1174.2	(A) 8	40		
BL	@	11.59	5.00	12.41	267.42	1189.6	—	48		
NSR	@	11.33	5.16	24.09	201.70	1248.3	(A) 8	40		91
BL	@	11.15	5.25	12.04	266.92	1307.0	—	48		
NSR	@	11.02	5.32	15.38	177.42	1366.4	(A) 8	40		
BL	@	11.52	5.05	12.78	246.12	1333.2	—	48		
NSR	@	11.70	4.91	14.08	165.61	1370.3	(A) 8	40		91
BL	@	10.48	5.56	14.77	248.39	1419.7	—	48		
	@									
	@		Room Air			Blank				91
	@									
	@									
	@									
	@									
	@									
	@									
	@									
	@									

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2070	1644
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2113	1686

*. oxant A → 921.3 ml D.I H₂O ; 78.7 ml NOxout A

NOxout A → 846.9 ml D.I H₂O ; 153.6 ml NOxout A

Innovative Furnace Data Log

Date: 9/13/91 — Friday The 13th
 Initials: EBE + WJF
 Test: CN2

NH₃ Rotameter
 Setting (BB height): 15
 Fuel: natural GAS
 Slurry: DI H₂O
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 25.5
 Draft (inches of water): 1.0
 Injection Port: 4th Lower

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)	SA #
BL	1.03 @ 70	11.163	5.258	12.78	273.59	1158.0	—	48		
NSR	@	11.231	5.277	29.64	168.97	1164.9	(A) 8	40		
BL	@	11.209	5.206	10.93	267.42	1185.0	—	48		
NSR	@	11.222	5.225	31.68	172.06	1206.6	(A) 8	40		91-01
BL	@	10.844	5.366	11.12	261.24	1256.0	—	48		
NSR	@	10.779	5.455	14.45	100.17	1273.0	(A*) 8	40		
BL	@	10.755	5.399	11.67	260.13	1267.6	—	48		
NSR	@	10.842	5.425	15.01	105.61	1277.6	(A*) 8	40		91-01
BL	✓ @ ✓	10.689	5.506	12.60	258.77	1297.7	—	48		
	@									
	@									
	@									
	@									
	@									
	@									
	@									
	@									
	@									

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	1.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	burned	2055	1650
Finish	1.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2093	1668

* not out A solution The same AS 9/12/91

- not out A* solution The same AS 9/12/91

Innovative Furnace Data Log

Date: 9/13/91

Initials: GBC with CNB

Test: Ag Mirror IA + N₂O Sampling

NH₃ Rotameter
 Setting (BB height): 1605
 Fuel: NATURAL GAS
 Slurry: DI H₂O
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): 24
 Draft (inches of water): 1.0
 Injection Port: 4th upper

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	H ₂ O Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	10.956	5.343	12.6	296.44	1222.8	—	48	
NSR	@	10.941	5.347	48.73	77.95	1224.4	(A) 8	40	
BL	@	10.971	5.365	12.78	296.20	1215.9	—	48	
NSR	@	10.925	5.343	50.58	76.83	1218.2	(A) 8	40	9/1
BL	@	10.805	5.328	12.97	290.27	1218.2	—	48	
NSR	@	10.851	5.358	20.94	59.54	1228.2	(A) 8	40	
BL	@	10.941	5.329	12.78	295.33	1222.1	—	48	
NSR	@	10.882	5.325	20.57	59.54	1229.8	(A) 8	40	9/1
3L	✓ @ ✓	10.792	5.366	12.97	292.24	1205.1	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Section Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2096	1667
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2070	1623

* Notant A => Same as yesterday's solution

* Notant A+ => Same as yesterday's solution

Innovative Furnace Data Log

Date: 9/13/91
 Initials: CBC+NEH
 Test: CN4

NH₃ Rotameter
 Setting (BB height): 16
 Fuel: NATURAL GAS
 Slurry: _____
 % Excess Air (measured): _____

SO₂ Rotameter
 Setting (BB height): 25.5
 Draft (inches of water): 1.0
 Injection Port: 3M

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	DE H ₂ O Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	10.68	5.466	15.19	304.22	1211.2		48	
NSR	@	10.60	5.510	66.51	51.01	1227.5	8.0	40	A
BL	@	10.50	5.547	14.27	304.84	1222.8		48	
NSR	@	10.505	5.599	52.06	56.82	1243.7	8.0	40	A
BL	@	10.712	5.744	15.93	309.78	1271.5		48	
NSR	@	10.922	5.292	38.35	52.87	1230.5	8.0	40	At
BL	@	10.885	5.336	14.82	288.04	1221.3		48	
NSR	@	10.418	5.566	47.99	55.95	1225.1	8.0	40	At
BL	✓ @	10.885	5.336	14.82	288.04	1221.3		48	
	@								
	@	P LOST LAST BL DUE TO ERROR IN MOVING							
	@	PERRG							
	@								
	@								
	@								
	@								
	@								
	@								

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2031	1599
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2003	1576

Innovative Furnace Data Log

Date: 9/13/91
 Initials: BCW & CNS
 Test: Ammonia and N₂O sampling

NH₃ Rotameter Setting (BB height): 16.5
 Fuel: natural GAS
 Slurry: DI H₂O
 % Excess Air (measured):

SO₂ Rotameter Setting (BB height): 25
 Draft (inches of water): 1.0
 Injection Port: 3 R

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (mL/min)	Starting Feed Rate (mL/min)	Ending Feed Rate (mL/min)
BL	1.03 @ 70	11.129	5.151	14.82	273.84	1189.6	—	40	
NSR	@	11.299	5.091	50.77	57.93	1209.7	(A) 8	40	
BL	@	11.410	5.080	17.05	271.99	1203.5	—	48	
NSR	@	11.428	5.003	53.36	57.86	1225.9	(A) 8	40	91-01
BL	@	11.666	4.917	15.75	272.36	1220.5	—	48	
NSR	@	11.552	4.910	27.98	104.87	1237.7	(A) 8	40	
BL	@	11.648	4.928	16.49	276.56	1235.2	—	48	
NSR	@	11.663	4.917	26.50	105.48	1243.7	(A) 8	40	91-0
BL	✓ @ ✓	10.688	5.532	16.68	284.34	1246.8	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	inward	1997	1544
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	1971	1434

Innovative Furnace Data Log

Date: 9/16/91

Initials: EBE run CNG

Test: Ammonia and N₂O Sampling

NH₃ Rotameter
 Setting (BB height): 16
 Fuel: natural GAS
 Slurry: DI H₂O
 % Excess Air (measured): —

SO₂ Rotameter
 Setting (BB height): 27.5
 Draft (inches of water): 1.0
 Injection Port: 2R

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)	S#
BL	1.07 @ 70	11.496	5.043	16.86	285.85	1171.1	—	48		91-0
NSR	@	11.500	5.040	21.12	196.89	1205.1	(A) 8	40		
BL	@	11.99	4.754	18.53	276.8	1395.8	—	48		
NSR	@	12.139	4.643	23.90	180.46	1487.6	(A) 8	40		91-6
BL	@	12.463	4.480	17.05	277.67	1664.4	—	48		
NSR	@	11.796	4.891	21.31	335.22	1710.7	(A) 8	40		
BL	@	11.852	4.723	17.97	285.99	1750.1	—	48		
NSR	@	11.561	4.969	19.45	337.20	1795.6	(A) 8	40		91-0
BL	√ @ √	11.811	4.791	18.34	286.07	1930	—	48		
	@									
	@									
	@									
	@									
	@									
	@									
	@									
	@									
	@									

Section
 Temperature at ~~2R~~ (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	1961	1899
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	cut	1844	1578

Innovative Furnace Data Log

SO₂ Levels are
Due to Bad Analyzer

Date: 9/16/91

Initials: EBC + WH CNT

Test: Ammonia and N₂O Sampling

NH₃ Rotameter

Setting (BB height): 15

Fuel: NATURAL GAS

Slurry: AT H₂O

% Excess Air (measured): —

SO₂ Rotameter

Setting (BB height): 11

Draft (inches of water): 1.0

Injection Port: 3 m

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)
BL	1.03 @ 70	11.666	4.899	18.53	258.65	1697.6	—	—	91-01
NSR	@	11.642	4.910	59.47	57.93	1875.9	(AT) 5	40	
BL	@	11.657	4.877	18.71	258.40	1883.6	—	48	
NSR	@	11.700	4.891	66.51	61.39	1916.8	(AT) 5	40	91-09
BL	@	11.549	4.928	19.64	265.44	1968.6	—	48	
NSR	@	11.583	4.832	38.72	81.65	1992.5	(AT) 5	40	
BL	@	11.620	4.899	19.64	268.28	2012.6	—	48	
NSR	@	11.188	5.054	42.80	87.20	2044.2	(AT) 5	40	91-01
BL	@	10.608	5.503	20.20	265.32	2120.6	—	48	
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								
	@								

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	458 @ 45	110 @ 45	182 @ 2	— @ —	Round	1922	1523
Finish	@	@	@	@	out		

Innovative Furnace Data Log

Date: 9/17/91

Initials: EBC + WJ CNB

Test: Ammonia + N₂O sampling

NH₃ Rotameter

Setting (BB height): 14

Fuel: natural gas

Slurry: DI H₂O

% Excess Air (measured):

SO₂ Rotameter

Setting (BB height): N/A

Draft (inches of water): 1.0

Injection Port: 3m

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)	Slurry #
BL	103 @ 70	11.953	5.088	17.05	214.50 274.96	N/A	—	48		
NSR ≈ 0.5	@	11.425	5.099	22.42	152.17		(A) 8	40		
BL	@	12.049	4.695	15.93	239.13		—	48		
NSR ≈ 0.5	@	12.071	4.706	24.27	128.46		(A) 8	40		91-09
BL	@	12.018	4.765	17.79	237.52		—	48		
NSR ≈ 0.5	@	11.963	4.725	17.05	166.50		(A) 8	40		
BL	@	11.957	4.773	15.56	236.17		—	48		
NSR ≈ 0.5	@	11.957	4.758	19.93	162.43		(A) 8	40		91-01
BL	@	11.904	4.732	17.97	236.66		—	48		
NSR ≈ 1.5	@	11.852	4.765	51.14	29.69		(A) 8	40		
BL	@	11.898	4.802	15.93	235.67		—	48		
NSR ≈ 1.5	@	11.879	4.806	54.84	32.24		(A) 8	40		91-09
BL	@	11.901	4.797	16.68	232.58		—	48		
NSR ≈ 1.5	@	11.932	4.754	33.54	29.69		(A) 8	40		
BL	@	11.932	4.713	17.05	230.98		—	48		
NSR ≈ 1.5	√ @	11.975	4.713	36.69	31.50		(A) 8	40		91-09
BL	@	11.997	4.662	16.89	229.99		—	48		
	@									

Section
Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2129	1789
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	out	2006	1546

Date: 9/17/91

Innovative Furnace Data Log

Initials: EBC + w H CNB

Test: Ammonia and N₂O Sampling

NH₃ Rotameter
 Setting (BB height): 14
 Fuel: Natural Gas
 Slurry: D.I. H₂O
 % Excess Air (measured):

SO₂ Rotameter
 Setting (BB height): N/A
 Draft (inches of water): 1.0
 Injection Port: 307

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)	Sam #
BL	1.03 @ 70	11.997	4.662	16.89	229.99	N/A	—	48		
NSR ≈ 2.0	@	11.978	4.721	57.69	36.56		(A*) 8	40		
BL	@	12.071	4.665	17.97	227.27		—	48		
NSR ≈ 2.0	@	11.978	4.691	62.07	38.66		(A*) 8	40		91-09
BL	@	11.941	4.706	17.23	225.67		—	48		
NSR = 2.0	@	11.876	4.773	49.47	29.77		(A*) 8	40		
BL	@	11.923	4.691	17.97	226.41		—	48		
NSR ≈ 2.0	@	11.858	4.721	43.17	31.00		(A*) 8	40		91-09
BL	✓ @ ✓	11.898	4.699	17.97	223.81	✓	—	48		
	@									
	@									
	@									
	@									
	@									
	@									
	@									
	@									
	@									
	@									

Section
 Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 45	— @ —	Burned	4006	1546
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 45	— @ —	out	1979	1463

Date: 9/21/91 Innovative Furnace Data Log

Initials: EBR + JHP CNIO
 Test: Ammonia Stand N₂O Sampling

NH₃ Rotameter 3m / 3R
 Setting (BB height): 14.5 / 14.5
 Fuel: Natural Gas
 Slurry: D.I H₂O
 % Excess Air (measured): —

SO₂ Rotameter 3m / 3R
 Setting (BB height): 25 / 22
 Draft (inches of water): 1.0
 Injection Port: 3m / 3R

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	<u>A</u> NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)	St #
BC	1.03 @ 70	11.759	4.999	12.23	263.71	1117.8	—	48		
M NSR	@	11.997	4.869	12.259	43.73	1143.3	8	40		
BC	@	12.058	4.825	12.78	262.98	1133.3	—	48		
NSR	@	12.089	4.814	29.27	42.61	1159.5	8	40		910;
BC	↓ @ ↓	11.493	5.162	13.71	264.95	1177.3	—	48		
	@									
	@									
	@									
BC	1.03 @ 70	12.620	4.517	13.16	249.38	1007.4	—	48		
E NSR	@	12.673	4.447	28.16	50.27	1024.4	8	40		
BC	@	12.735	4.443	12.04	245.92	1029.1	—	48		
NSR	@	12.707	4.476	29.27	51.51	1038.3	8	40		910;
BC	↓ @ ↓	10.752	5.662	12.60	248.64	1049.1	—	48		
	@									
	@									
	@									
	@									
	@									

Section
 Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.87 @ 2	— @ —	Burned	2043	1663
Finish	4.58 @ 45	1.0 @ 45	0.83 @ 2	— @ —	out	1974	1544

Innovative Furnace Data Log

Date: 12/2/91

Initials: ebe CN13

Test: N_2 + Ammonia Testing

NH_3 Rotameter

Setting (BB height): 15

Fuel: Natural Gas

Slurry: Terra Luttrel $Ca(OH)_2$

% Excess Air (measured):

SO_2 Rotameter

Setting (BB height): 4/8

Draft (inches of water): 1.0

Injection Port: 3m

	Stage Air (float height) @ PSI	O ₂ (%)	CO ₂ (%)	CO (ppm)	NO (ppm)	SO ₂ (ppm)	NO _x OUT Feed Rate (ml/min)	Starting Feed Rate (ml/min)	Ending Feed Rate (ml/min)	
BL	1.03 @ 70	9.792	6.148	10.19	317.07	1346.3	(W) 5	(W) 48		
CalS	@	9.529	6.240	11.86	321.39	485.39	(W) 5	(S) 47	5.50	
CalS+NSR	@	9.477	6.218	26.12	101.66	353.57	(A) 5	(S) 47	5.50	91-1
BL	@	9.810	6.099	9.63	307.81	1381.1	(W) 5	(W) 48		
CalS	@	9.638	6.114	12.41	308.05	573.59	(W) 5	(S) 47	5.50	
CalS+NSR	@	9.533	6.129	22.79	75.96	535.76	(A) 5	(S) 47	6.50	91-1
BL	@	9.749	6.044	12.04	295.95	1447.5	(W) 5	(W) 48		
BL	@	9.739	6.044	10.38	292.24	1357.9	(W) 5	(W) 48		
CalS	@	9.659	6.114	12.60	294.34	948.77	(W) 5	(S) 48	2.94	
CalS+NSR	@	9.585	6.088	37.98	120.92	945.68	(A) 5	(S) 48	2.94	91-1
BL	@	9.468	6.185	13.34	300.02	1359.5	(W) 5	(W) 48		
CalS	@	9.418	6.136	13.34	300.64	1043.7	(W) 5	(S) 48	2.94	
CalS+NSR	@	9.369	6.196	23.72	70.90	988.91	(A) 5	(S) 48	2.94	91-1
BL	@	9.319	6.236	11.12	293.97	1307.0	(W) 5	(W) 48		
	@									
	@									
	@									
	@									

Temperature at Port (°F)

	Tangential Air	Axial Air	Primary Gas	Coal Transport Air	2	3	4 upper
Start	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	Burned	2012	1614
Finish	4.58 @ 45	1.0 @ 45	0.82 @ 2	— @ —	ant	1974	1447

APPENDIX B

LIMB INNOVATIVE FURNACE PERFORMANCE EVALUATION AUDIT

To: Judy Ford
From: Libby Beach
Date: December 16, 1991
Subject: LIMB Innovative Furnace PEA

Results were received Friday, December 13, from an internal performance evaluation audit (PEA) given on the LIMB Innovative Furnace. The purpose of the audit was to evaluate the performance of the furnace SO₂, O₂, and CO₂ CEM's. Two cylinders of known gas concentrations were delivered to the C-Wing facility on December 4, 1991, for analysis. The results were reported as follows:


	<u>Analysis Required</u>	<u>Reported Concentration</u>	<u>Actual Concentration</u>	<u>%Difference</u>
CYLINDER 1	SO ₂	3189.8 ppm	3040.0 ppm	4.9
CYLINDER 2	O ₂	9.93 %	10.0 %	0.7
	CO ₂	11.72 %	12.0 %	2.3

Reported results are all well within the +/- 10% data quality objectives established in the project's QAPjP. No corrective actions were taken as a result of this audit.

cc K. Bruce
W. Hansen
G. Gillis
8420.266
8420.012


APPENDIX C
RESISTIVITY TEST RESULTS

PITTS #8 & TENN
12/10/91
5% WATER




PITT#8 WITH TENN CUT
 12/11/91
 5% WATER

C-3



PITTS #8 TENN CUT
 12/12/91
 5% WATER



APPENDIX D
GRAPHICAL INTERPOLATION OF TEST RESULTS

Listing of Nalco/Fuel Tech Trial Runs(Original CRADA Scope of Work)

DATE	TRIAL	FIGURE	DESCRIPTION
12/03/90	N1	NFT1203A	NOXOUT A@2R VARYING NSR
12/04/90	N2	NFT1204A	NOXOUT A@3R VARYING NSR
12/05/90	N3	NFT1205A	NOXOUT A@3M VARYING NSR
12/05/90	N4	NFT1205B	NOXOUT A@4U VARYING NSR
12/06/90	N5	NFT1206A	same as above
12/07/90	N6	NFT1207A	NOXOUT A@3M VARYING NSR
12/12/90	N7	NFT1212A	NOXOUT A@3M VARYING NSR/XS OXYGEN
12/14/90	N8	NFT1214A	NOXOUT A@3M VARYING NSR, W/SO2 ADDED
12/19/90	N9	NFT1219A	NOXOUT A@3M VARYING NSR/XS OXYGEN
01/02/91	N10	NFT0102A	NOXOUT A@3M VARYING NSR
01/10/91	N11	NFT0110A	NOXOUT A@3M 1 NSR, VARY Ca/S(Ca(OH)2)
01/11/91	N12	NFT0111A	same as above
01/14/91	N13	NFT0114A	DRY Ca(OH)2@3M, VARY Ca/S
01/15/91	N14	NFT0115A	NOXOUT A@3R 1 NSR, VARY Ca/S(Ca(OH)2)
01/16/91	N15	NFT0116A	same as above
01/18/91	N16	NFT0121A	NOXOUT A@4U 1 NSR, VARY Ca/S(Ca(OH)2)
01/21/91	N17	NFT0121A	same as above
01/22/91	N18	NFT0122A	DRY Ca(OH)2@4U, VARY Ca/S
01/28/91	N19	NFT0128A	DRY Ca(OH)2@4L, VARY Ca/S
01/28/91	N20	NFT0128B	DRY Ca(OH)2@5, VARY Ca/S
01/30/91	N21	NFT0130B	DRY Ca(OH)2@6, VARY Ca/S
01/31/91	N22	*****	NOXOUT A@4L 1 NSR, VARY Ca/S(Ca(OH)2)
02/05/91	N23	*****	same as above
02/07/91	N24	NFT0208A	NOXOUT A@2R 1 NSR, VARY Ca/S(Ca(OH)2)
02/08/91	N25	NFT0208A	same as above
02/11/91	N26	NFT0213B	NOXOUT A@3M 1 NSR, VARY Ca/S(Ca(OH)2)
02/12/91	N27	NFT0212A	DRY Ca(OH)2@3M, VARY Ca/S
02/13/91	N28	NFT0213A	DRY Ca(OH)2@4U, VARY Ca/S
02/13/91	N29	NFT0213B	NOXOUT A@3M 1 NSR, VARY Ca/S(Ca(OH)2)
02/14/91	N30	NFT0214A	NOXOUT A@2R 1 NSR, VARY Ca/S(Ca(OH)2)
02/15/91	N31	NFT0327B	NOXOUT A@4L 1 NSR, VARY Ca/S(Ca(OH)2)
02/25/91	N32	NFT0228A	NOXOUT A@4U 1 NSR, VARY Ca/S(CaCO3)
02/27/91	N33	NFT0228A	same as above
02/28/91	N34	NFT0228A	same as above
03/01/91	N35	NFT0301A	DRY CaCO3@5, VARY Ca/S
03/22/91	N36	NFT0327A	NOXOUT A@4L 1 NSR, VARY Ca/S(Ca(OH)2)
03/27/91	N37	NFT0327A	same as above
03/28/91	N38	*****	NOXOUT A@5 1 NSR, Ca/S≈3(Ca(OH)2)
03/29/91	N39	*****	NOXOUT A@5 1 NSR, Ca/S≈2(Ca(OH)2)
04/01/91	N40	NFT0403A	NOXOUT A@4U 1 NSR, Ca/S≈2(Ca(OH)2)
04/02/91	N41	NFT0403A	NOXOUT A@4U 1 NSR, Ca/S≈3(Ca(OH)2)
04/03/91	N42	NFT0403A	NOXOUT A@4U 1 NSR, VARY Ca/S(Ca(OH)2)
04/04/91	N43	NFT0404A	DRY Ca(OH)2@6, VARY Ca/S
04/09/91	N44	NFT0409A	DRY CaCO3@4U VARY Ca/S
04/09/91	N45	NFT0409B	DRY CaCO3@5, VARY Ca/S
04/12/91	N46	NFT0412A	DRY CaCO3@3M, VARY Ca/S
04/15/91	N47	NFT0415A	DRY CaCO3@4L, VARY Ca/S
04/16/91	N48	NFT0416	DRY CaCO3@6, VARY Ca/S
04/16/91	N49	NFT0416A	DRY CaCO3@7, VARY Ca/S
04/17/91	N50	*****	NOXOUT A@4U 1 NSR, VARY Ca/S(CaCO3)


DATE	TRIAL	FIGURE	DESCRIPTION
04/18/91	N51	NFT0418A	NOXOUT A@4L 1 NSR, VARY Ca/S(CaCO3)
04/19/91	N52	NFT0419A	NOXOUT A@4L 1 NSR, VARY Ca/S(CaCO3)
04/22/91	N53	NFT0423A	NOXOUT A@3R 1 NSR, VARY Ca/S(CaCO3)
04/23/91	N54	NFT0423A	same as above
04/25/91	N55	*****	DRY CaCO3@5, VARY Ca/S, D50<10µM
04/25/91	N56	NFT0426	NOXOUT A@4U 1 NSR, Ca/S≈3(CaCO3<10µm)
04/26/91	N57	NFT0426	NOXOUT A@4U 1 NSR, Ca/S≈2,1 (CaCO3<10µm)
04/29/91	N58	NFT0429	DRY CaCO3@5, VARY Ca/S, 75µm>D50>25µm
05/02/91	N59	NFT0502	NOXOUT A@4U 1 NSR, VARY Ca/S (75µm>CaCO3>25µm)
05/03/91	N60	NFT0503	NOXOUT A@4U 1 NSR, VARY Ca/S(SLAKED CaO)
05/06/91	N61	*****	NOXOUT A@4U 1 NSR, VARY Ca/S(CaCO3)
05/14/91	N62	NFT0502	NOXOUT A@4U 1 NSR, VARY Ca/S (75µm>CaCO3>25µm)
05/15/91	N63	NFT0502	same as above
05/16/91	N64	NFT0503A	NOXOUT A@4U 1 NSR, VARY Ca/S(SLAKED CaO)
05/31/91	QC1	NFT0531	DRY Ca(OH)2@5, Ca/S≈2, FOR QC CHECK
06/03/91	N65	*****	NOXOUT A+@4L 1 NSR, Ca/S≈2(Ca(OH)2)
06/04/91	N66	NFT0604	NOXOUT A@4L 1 NSR, Ca/S≈2(Ca(OH)2)
06/05/91	N67	*****	NOXOUT A@4U 1 NSR, Ca/S≈2(Ca(OH)2)
06/07/91	N68	*****	same as above
06/07/91	N69	*****	NOXOUT A@3M 1 NSR, Ca/S≈2(Ca(OH)2)
06/10/91	N70	*****	NOXOUT A@5 1 NSR, Ca/S≈2(Ca(OH)2)
06/11/91	N71	*****	NOXOUT A@5 1 NSR
06/11/91	N72	*****	NOXOUT A@4L 1 NSR
06/12/91	N73	*****	NOXOUT A@4U 1 NSR
06/12/91	N74	*****	NOXOUT A@3M 1 NSR
06/14/91	N75	*****	NOXOUT A&A+@4L 1 NSR, Ca/S≈2(Ca(OH)2, PITTS#8 COAL)
06/17/91	N76	*****	NOXOUT A&A+@4L 1 NSR, Ca/S≈1(Ca(OH)2, PITTS#8 COAL)
06/18/91	N77	*****	NOXOUT A@5 NSR≈1
06/18/91	N78	*****	NOXOUT A@4L NSR≈1
06/18/91	N79	*****	NOXOUT A@4U NSR≈1
06/19/91	N80	*****	NOXOUT A@3M NSR≈1
06/19/91	N81	*****	NOXOUT A@3R NSR≈1
06/19/91	N82	*****	NOXOUT A@2R NSR≈1

Listing of Nalco/Fuel Tech Trial Runs(Continuation Scope of Work)

DATE	TRIAL	FIGURE	DESCRIPTION
09/12/91	CN1	*****	NOXOUT A&A+@5 NSR≈1
09/13/91	CN2	*****	NOXOUT A&A+@4L NSR≈1
09/13/91	CN3	*****	NOXOUT A&A+@4U NSR≈1
09/13/91	CN4	*****	NOXOUT A&A+@3M NSR≈1
09/13/91	CN5	*****	NOXOUT A&A+@3R NSR≈1
09/16/91	CN6	*****	NOXOUT A&A+@2R NSR≈1
09/16/91	CN7	*****	NOXOUT A&A+@3M VARY NSR(≈1.0)
09/17/91	CN8	*****	NOXOUT A&A+@3M VARY NSR(≈0.5, 1.5)
09/17/91	CN9	*****	NOXOUT A&A+@3M VARY NSR(≈2.0)
09/21/91	CN10	*****	NOXOUT A@3M,3R NSR≈1, W/SO2
11/26/91	CN11	*****	NOXOUT A@3M NSR≈1, Ca/S≈3(Ca(OH)2)
11/27/91	CN12	*****	NOXOUT A+@3M NSR≈1, Ca/S≈3(Ca(OH)2)
12/02/91	CN13	*****	NOXOUT A&A+ NSR≈1, Ca/S≈2,1(Ca(OH)2)

Nalco Fueltech Test Results


Ca(OH)₂ slurry injected at Port 3M



1/10/91
NFT0110A.DRW
N11a & N11b

Nalco Fueltech Test Results

Dry Injection of Ca(OH)₂ at port 3M




D-6

1/14/91
NFT0114A.DRW
N13

Nalco Fueltech Test Results

Ca(OH)₂ slurry injected at Port 3R




Slurry (SO₂) slurry with NO_xOUT (SO₂) NO_xOUT (NO_x) NO_xOUT (NO_x) with slurry
 ○ ● ■ □

1/15/91 and 1/16/91
 NFT0116A.DRW
 N14 & N15

Nalco Fueltech Test Results

Ca(OH)₂ slurry injected at Port 4U



Slurry (SO₂)

slurry with NO_xOUT (SO₂)

NO_xOUT (NO_x) baseline


NO_xOUT (NO_x) with slurry

D-8

1/18/91 and 1/21/91
NFT0121A.DRW
N16 & N17

Nalco Fueltech Test Results

Dry Injection of Ca(OH)₂ at port 4U




D-9

1/22/91
NFT0122A.DRW
N18

Nalco Fueltech Test Results

Dry Injection of $\text{Ca}(\text{OH})_2$ at port 4L




D-10

1/28/91
NFT0128A.DRW
N19

Nalco Fueltech Test Results

Dry Injection of Ca(OH)₂ at port 5




D-11

1/28/91
NFT0128B.DRW
N20

Nalco Fueltech Test Results

Dry Injection of Ca(OH)₂ at port 6




D-12

1/30/91
NFT0130B.DRW
N21

Nalco Fueltech Test Results

Ca(OH)₂ slurry injected at Port 2R




D-13

2/7/91 and 2/8/91
 NFT0208A.DRW
 N24 & N25

Nalco Fueltech Test Results

Dry Injection of Ca(OH)₂ at port 3M




D-14

2/12/91
NFT0212A.DRW
N27

Nalco Fueltech Test Results

Ca(OH)₂ slurry injected at Port 3M (repeats)




Slurry (SO₂) slurry with NO_xOUT (SO₂)

○ ●

2/11/91, 2/13/91, 1/10/91, and 1/11/91
 NFT0213B.DRW
 N11, N12, N26, & N29

Nalco Fueltech Test Results

Ca(OH)₂ slurry injected at Port 2R




Slurry (SO₂) slurry with NO_xOUT (SO₂)

2/7/91, 2/8/91, and 2/14/91
NFT0214A.DRW
N24, N25, & N30

Nalco Fueltech Test Results

As received CaCO₃ slurry injected as 4U




D-17

2/25/91, 2/27/91 and 2/28/91
 NFT0228A.DRW
 N32, N33, & N34

Nalco Fueltech Test Results

Dry Injection of as received CaCO₃ Port 5




D-18

3/01/91
NFT0301A.DRW
N35

Nalco Fueltech Test Results

Ca(OH)₂ slurry injected at Port 4L (repeats)


D-19



3/22/91 and 3/27/91
 NFT0327A.DRW
 N36 & N37

Nalco Fueltech Test Results

Ca(OH)₂ slurry injected at Port 4L




Slurry (SO₂) slurry with NO_xOUT (SO₂)

2/15/91, 3/22/91, and 3/27/91
NFT0327B.DRW
N31, N36 & N37

Nalco Fueltech Test Results

Ca(OH)₂ slurry injected at Port 4U

(repeat tests)




D-21

4/1/91, 4/2/91, and 4/3/91
NFT0403A.DRW
N40, N41 & N42

Nalco Fueltech Test Results

Ca(OH)₂ slurry injected at Port 4U

all tests



Slurry (SO₂) slurry with NO_xOUT (SO₂)


4/1/91, 4/2/91, 4/3/91, 1/18/91, and 1/21/91

NFT0403B.DRW

N40, N41, N42, N16 & N17

Nalco Fueltech Test Results

Dry Injection of $\text{Ca}(\text{OH})_2$ at Port 6




D-23

4/4/91
NFT0404A.DRW
N43

Nalco Fueltech Test Results

Dry Injection of as received CaCO₃ at Port 4U




D-24

4/09/91
NFT0409A.DRW
N44

Nalco Fueltech Test Results

Dry Injection of as received CaCO₃ at 3M




D-25

4/12/91
NFT0412A.DRW
N46

Nalco Fueltech Test Results

Dry Injection of as received CaCO₃ at 4L




D-26

4/15/91
NFT0415.DRW
N47

Nalco Fueltech Test Results

Dry Injection of as received CaCO₃ at Port 6




D-27

4/16/91
NFT0416.DRW
N48

Nalco Fueltech Test Results

Dry Injection of as received CaCO₃ at Port 7




D-28

4/16/91
NFT0416A.DRW
N49

Nalco Fueltech Test Results

CaCO₃ slurry injection at 4L




D-29

4/18/91 and 4/19/91
NFT0418A.DRW
N51 & N52

Nalco Fueltech Test Results

CaCO₃ slurry injection at 3R




D-30

4/22/91 and 4/23/91
NFT0423A.DRW
N53 & N54

Nalco Fueltech Test Results

Dry Injection of CaCO₃; <10 Micrometers (Port 5)




D-31

4/25/91
NFT0425A.DRW
N55

Nalco Fueltech Test Results

CaCO₃ slurry injection at 4U

2.7 m average diameter CaCO₃




slurry (SO₂) slurry with NO_xOUT (SO₂)

4/26/9
NFT0426.DRW
N56 & N57

Nalco Fueltech Test Results

Dry Injection of CaCO₃ Port 5

75 > CaCO₃ > 25 m




D-33

4/29/91
NFT0429.DRW
N58

Nalco Fueltech Test Results

Slurry Injection of CaCO₃ at Port 4U

20.68 m ave diameter



D-34

CaCO₃ slurry

slurry with NO_xOUT

CaCO₃ slurry

slurry with NO_xOUT

5/2/91

5/2/91

5/15/91 and 5/16/91

5/15/91 and 5/16/91

●

△

○

■


5/3/91, 5/15/91 and 5/16/91 (re-test)

NFT0502.DRW

N59 & N63

Nalco Fueltech Test Results

Slurry Injection of Hydrated CaO



CaO hydrate slurry slurry with NOxOUT CaO hydrate slurry slurry with NOxOUT

5/3/91 5/3/91 5/16/91 5/16/91

5/3/91 and 5/16/91 (re-test)
 NFT0503A.DRW
 N60 & N64

TECHNICAL REPORT DATA <i>(Please read Instructions on the reverse before completing)</i>				
1. REPORT NO. EPA-600/R-93-188		2.		3.
4. TITLE AND SUBTITLE Evaluation of Simultaneous SO ₂ /NO _x Control Technology			5. REPORT DATE September 1993	
7. AUTHOR(S) Kevin R. Bruce and Walter F. Hansen			6. PERFORMING ORGANIZATION CODE	
9. PERFORMING ORGANIZATION NAME AND ADDRESS Acurex Environmental Corporation P. O. Box 13109 Research Triangle Park, North Carolina 27709			8. PERFORMING ORGANIZATION REPORT NO.	
12. SPONSORING AGENCY NAME AND ADDRESS EPA, Office of Research and Development Air and Energy Engineering Research Laboratory Research Triangle Park, NC 27711			10. PROGRAM ELEMENT NO.	
			11. CONTRACT/GRANT NO. 68-DO-0141	
13. TYPE OF REPORT AND PERIOD COVERED Task Final; 10/90 - 5/93			14. SPONSORING AGENCY CODE EPA/600/13	
15. SUPPLEMENTARY NOTES AEERL project officer is Brian K. Gullett, Mail Drop 4, 919/541-1534.				
16. ABSTRACT The report gives results of work concentrating on characterizing three process operational parameters of a technology that combines sorbent injection and selective non-catalytic reduction for simultaneous sulfur dioxide/nitrogen oxide (SO ₂ /NO _x) removal from coal-fired industrial boilers: injection temperature, sorbent type and reductant/pollutant stoichiometric ratio. A slurry composed of a urea-based (NO _x OUT A or NO _x OUT A+) and various calcium-based sorbents was injected at a range of temperatures and reactant/pollutant stoichiometries into a natural-gas-fired pilot-scale reactor with doped pollutants. Up to 80% reduction of SO ₂ and NO _x at reactant/pollutant stoichiometric ratios of 2 and 1.5, respectively, was achieved. SO ₂ emission reductions from slurry injection were enhanced moderately when compared with dry sorbent injection methods, possibly caused by sorbent fracturing to smaller, more reactive particles. Emissions from ammonia (NH ₃) slip (unreacted nitrogen-based reducing agent) and nitrous oxide (N ₂ O) formation were reduced in comparison with other published results, while similar NO _x reductions were obtained. Increased carbon monoxide (CO) emissions, caused by the decomposition of urea, were moderate. The results of this pilot-scale study have shown high reduction of both SO ₂ and NO _x .				
17. KEY WORDS AND DOCUMENT ANALYSIS				
a. DESCRIPTORS		b. IDENTIFIERS/OPEN ENDED TERMS	c. COSATI Field/Group	
Pollution	Sorbents	Pollution Control	13B	11G
Nitrogen Oxides	Catalysis	Stationary Sources	07B	07D
Sulfur Dioxide	Urea	Sorbent Injection		07C
Boilers	Slurries	Selective Non-catalytic	13A	
Coal	Calcium	Reduction (SNCR)	21D	
Combustion	Ammonia		21B	
18. DISTRIBUTION STATEMENT Release to Public		19. SECURITY CLASS (This Report) Unclassified	21. NO. OF PAGES 196	
		20. SECURITY CLASS (This page) Unclassified	22. PRICE	